

DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	259821-1
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2024 - Part 3 - searchable
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/30/2024 4:56:32 PM
Docketed Date:	10/30/2024

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2024 00:00	0	1.7	7.7	14.4	6.4	799,533.2	0.00	1.00
07/01/2024 01:00	0	1.7	7.7	14.4	6.8	800,165.2	0.00	1.00
07/01/2024 02:00	0	1.7	7.9	14.4	6.8	800,165.2	0.00	1.00
07/01/2024 03:00	0	1.7	7.8	14.3	5.9	789,908.9	0.00	1.00
07/01/2024 04:00	0	1.7	7.7	14.3	7.8	790,946.3	0.00	1.00
07/01/2024 05:00	0	1.7	7.8	14.3	8.1	791,361.3	0.00	1.00
07/01/2024 06:00	0	1.7	7.7	14.3	5.7	792,813.7	0.00	1.00
07/01/2024 07:00	-1	1.7	7.6	14.4	1.2	805,010.9	0.00	1.00
07/01/2024 08:00	-1	1.7	7.6	14.4	1.0	804,378.8	0.00	1.00
07/01/2024 09:00	-1	1.6	7.6	14.4	1.7	803,536.1	0.00	1.00
07/01/2024 10:00	-1	1.6	7.6	14.5	1.8	814,593.5	0.00	1.00
07/01/2024 11:00	-1	1.6	7.5	14.5	2.1	813,737.6	0.00	1.00
07/01/2024 12:00	-1	1.6	7.4	14.5	1.7	813,095.7	0.00	1.00
07/01/2024 13:00	-1	1.6	7.1	14.5	1.1	811,383.9	0.00	1.00
07/01/2024 14:00	0	1.6	7.0	14.4	1.2	801,850.6	0.00	1.00
07/01/2024 15:00	0	1.7	7.0	14.3	1.1	792,606.2	0.00	1.00
07/01/2024 16:00	0	1.7	7.1	14.4	1.1	803,536.1	0.00	1.00
07/01/2024 17:00	0	1.7	7.2	14.4	3.4	854,731.5	0.00	1.00
07/01/2024 18:00	1	2.0	11.2	13.1	20.2	981,771.9	0.00	1.00
07/01/2024 19:00	2	2.3	13.5	11.9	31.1	1,027,068.3	0.00	1.00
07/01/2024 20:00	1	2.0	11.9	12.8	20.8	1,011,852.5	0.00	1.00
07/01/2024 21:00	0	1.6	7.5	14.4	2.2	858,734.4	0.00	1.00
07/01/2024 22:00	-1	1.6	7.5	14.4	1.3	802,061.3	0.00	1.00
07/01/2024 23:00	-1	1.6	7.5	14.4	1.8	801,429.3	0.00	1.00
Average/Sum#:	0	1.7	8.1	14.2	5.9	831,928.0	0.00 #	24.00 #
Minimum:	-1	1.6	7.0	11.9	1.0	789,908.9	0.00	1.00
Maximum:	2	2.3	13.5	14.5	31.1	1,027,068.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/02/2024 00:00	-1	1.7	7.5	14.4	2.6	802,061.3	0.00	1.00
07/02/2024 01:00	0	1.7	7.8	14.4	6.8	802,693.4	0.00	1.00
07/02/2024 02:00	0	1.7	8.1	14.4	8.3	802,061.3	0.00	0.82
07/02/2024 03:00	0	1.7	8.1	14.4	9.3	801,850.6	0.00	1.00
07/02/2024 04:00	0	1.7	8.1	14.4	9.1	803,746.8	0.00	1.00
07/02/2024 05:00	0	1.6	7.9	14.4	6.6	873,482.1	0.00	1.00
07/02/2024 06:00	-1	1.7	7.8	14.3	2.7	804,225.6	0.00	1.00
07/02/2024 07:00	-1	1.7	7.7	14.4	1.9	805,221.5	0.00	1.00
07/02/2024 08:00	-1	1.6	7.8	14.5	2.4	813,951.6	0.00	1.00
07/02/2024 09:00	-1	1.6	7.8	14.5	2.5	812,239.8	0.00	1.00
07/02/2024 10:00	-1	1.6	7.5	14.5	1.4	810,956.0	0.00	1.00
07/02/2024 11:00	0	1.6	7.2	14.6	0.8	822,524.1	0.00	1.00
07/02/2024 12:00	0	1.7	7.2	14.4	2.2	812,174.0	0.00	1.00
07/02/2024 13:00	0	1.7	7.6	14.3	6.7	925,191.4	0.00	1.00
07/02/2024 14:00	1	2.1	12.5	12.7	21.7	1,005,190.9	0.00	1.00
07/02/2024 15:00	1	2.2	13.1	12.3	26.0	1,008,915.5	0.00	1.00
07/02/2024 16:00	1	2.3	13.7	12.1	28.0	1,004,970.8	0.00	1.00
07/02/2024 17:00	2	2.3	13.2	11.9	29.0	1,005,157.5	0.00	1.00
07/02/2024 18:00	2	2.3	13.3	12.0	30.0	1,020,298.1	0.00	1.00
07/02/2024 19:00	1	2.3	13.0	12.0	28.7	1,013,835.6	0.00	1.00
07/02/2024 20:00	1	2.2	13.3	12.1	28.0	1,019,443.1	0.00	1.00
07/02/2024 21:00	1	2.1	12.6	12.5	23.3	1,020,547.2	0.00	1.00
07/02/2024 22:00	0	1.5	7.6	14.4	3.7	912,668.7	0.00	1.00
07/02/2024 23:00	-1	1.6	7.5	14.5	1.6	821,654.6	0.00	1.00
Average/Sum#:	0	1.8	9.5	13.7	11.8	888,544.2	0.00 #	23.82 #
Minimum:	-1	1.5	7.2	11.9	0.8	801,850.6	0.00	0.82
Maximum:	2	2.3	13.7	14.6	30.0	1,020,547.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/03/2024 00:00	-1	1.6	7.5	14.4	1.3	809,013.8	0.00	1.00
07/03/2024 01:00	0	1.7	7.4	14.4	1.0	804,168.1	0.00	1.00
07/03/2024 02:00	-1	1.7	7.7	14.4	1.1	804,168.1	0.00	1.00
07/03/2024 03:00	0	1.7	7.8	14.4	5.0	804,589.5	0.00	1.00
07/03/2024 04:00	0	1.7	7.9	14.4	8.0	803,957.5	0.00	1.00
07/03/2024 05:00	0	1.6	8.1	14.4	8.8	804,800.2	0.00	1.00
07/03/2024 06:00	0	1.7	8.0	14.4	5.8	803,957.5	0.00	1.00
07/03/2024 07:00	-1	1.6	7.9	14.4	4.1	802,904.1	0.00	1.00
07/03/2024 08:00	-1	1.6	7.9	14.5	2.1	815,021.5	0.00	1.00
07/03/2024 09:00	-1	1.6	7.8	14.5	4.8	813,951.6	0.00	1.00
07/03/2024 10:00	-1	1.6	7.6	14.5	0.9	811,811.9	0.00	1.00
07/03/2024 11:00	-1	1.6	7.4	14.6	1.3	824,045.7	0.00	1.00
07/03/2024 12:00	0	1.6	7.1	14.6	1.2	825,132.5	0.00	1.00
07/03/2024 13:00	0	1.6	7.1	14.6	0.9	843,608.9	0.00	1.00
07/03/2024 14:00	0	1.9	10.3	13.5	15.8	986,355.7	0.00	1.00
07/03/2024 15:00	1	2.0	12.1	12.8	20.7	1,007,118.6	0.00	1.00
07/03/2024 16:00	1	2.1	12.8	12.3	26.8	1,016,240.3	0.00	1.00
07/03/2024 17:00	2	2.3	12.9	12.0	28.8	1,012,450.8	0.00	1.00
07/03/2024 18:00	1	2.3	12.8	12.0	28.3	1,011,373.8	0.00	1.00
07/03/2024 19:00	1	2.3	12.8	12.0	27.8	1,007,834.8	0.00	1.00
07/03/2024 20:00	1	2.1	12.7	12.6	22.1	1,018,983.7	0.00	1.00
07/03/2024 21:00	0	1.6	7.9	14.2	4.7	881,132.6	0.00	1.00
07/03/2024 22:00	0	1.6	7.4	14.5	0.9	815,877.4	0.00	1.00
07/03/2024 23:00	0	1.6	7.4	14.5	0.6	816,947.2	0.00	1.00
Average/Sum#:	0	1.8	9.0	13.9	9.3	872,726.9	0.00 #	24.00 #
Minimum:	-1	1.6	7.1	12.0	0.6	802,904.1	0.00	1.00
Maximum:	2	2.3	12.9	14.6	28.8	1,018,983.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/04/2024 00:00	0	1.6	7.5	14.4	1.1	805,221.5	0.00	1.00
07/04/2024 01:00	-1	1.7	7.5	14.4	1.3	804,800.2	0.00	1.00
07/04/2024 02:00	-1	1.7	7.9	14.4	2.9	804,589.5	0.00	1.00
07/04/2024 03:00	0	1.7	7.8	14.4	4.8	805,221.5	0.00	1.00
07/04/2024 04:00	0	1.7	7.8	14.4	7.3	806,485.6	0.00	1.00
07/04/2024 05:00	0	1.7	7.8	14.4	6.3	806,696.3	0.00	1.00
07/04/2024 06:00	0	1.7	7.9	14.4	5.7	805,642.9	0.00	1.00
07/04/2024 07:00	-1	1.6	7.7	14.4	1.1	804,800.2	0.00	1.00
07/04/2024 08:00	-1	1.6	7.7	14.5	1.6	816,091.3	0.00	1.00
07/04/2024 09:00	-1	1.6	7.6	14.5	1.0	815,449.4	0.00	1.00
07/04/2024 10:00	0	1.6	7.2	14.5	0.2	814,165.6	0.00	1.00
07/04/2024 11:00	0	1.6	6.9	14.6	0.7	827,088.9	0.00	1.00
07/04/2024 12:00	0	1.6	6.8	14.6	0.6	825,567.3	0.00	1.00
07/04/2024 13:00	0	1.6	6.8	14.6	0.6	824,697.8	0.00	1.00
07/04/2024 14:00	0	1.6	6.7	14.6	0.9	824,915.2	0.00	1.00
07/04/2024 15:00	0	1.6	7.0	14.6	1.4	823,611.0	0.00	1.00
07/04/2024 16:00	0	1.6	7.1	14.5	6.3	915,374.6	0.00	1.00
07/04/2024 17:00	0	1.6	7.1	14.4	2.5	838,298.4	0.00	1.00
07/04/2024 18:00	0	1.6	7.0	14.5	5.1	937,627.8	0.00	1.00
07/04/2024 19:00	0	1.6	7.3	14.5	0.8	814,165.6	0.00	1.00
07/04/2024 20:00	-1	1.6	7.6	14.5	1.0	812,239.8	0.00	1.00
07/04/2024 21:00	-1	1.7	7.7	14.5	1.9	812,667.8	0.00	1.00
07/04/2024 22:00	-1	1.7	7.7	14.5	4.4	813,309.7	0.00	1.00
07/04/2024 23:00	0	1.6	7.8	14.5	5.6	817,161.2	0.00	1.00
Average/Sum#:	0	1.6	7.4	14.5	2.7	823,995.4	0.00 #	24.00 #
Minimum:	-1	1.6	6.7	14.4	0.2	804,589.5	0.00	1.00
Maximum:	0	1.7	7.9	14.6	7.3	937,627.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/05/2024 00:00	0	1.6	7.4	14.6	10.7	974,247.6	0.00	1.00
07/05/2024 01:00	0	1.6	7.6	14.6	11.4	973,160.8	0.00	1.00
07/05/2024 02:00	0	1.6	7.9	14.6	11.5	972,291.3	0.00	1.00
07/05/2024 03:00	0	1.6	8.1	14.4	5.9	804,589.5	0.00	1.00
07/05/2024 04:00	0	1.7	7.9	14.4	8.7	804,589.5	0.00	1.00
07/05/2024 05:00	0	1.7	7.8	14.4	8.4	804,589.5	0.00	1.00
07/05/2024 06:00	0	1.6	7.8	14.4	6.0	803,746.8	0.00	1.00
07/05/2024 07:00	-1	1.6	7.8	14.4	1.7	802,904.1	0.00	1.00
07/05/2024 08:00	-1	1.7	7.6	14.5	1.8	813,737.6	0.00	1.00
07/05/2024 09:00	-1	1.6	7.6	14.5	1.9	812,453.8	0.00	1.00
07/05/2024 10:00	-1	1.6	7.5	14.5	1.4	810,956.0	0.00	1.00
07/05/2024 11:00	0	1.6	7.2	14.5	1.5	810,314.1	0.00	1.00
07/05/2024 12:00	0	1.6	6.9	14.5	0.8	809,458.2	0.00	1.00
07/05/2024 13:00	0	1.6	6.9	14.6	0.6	821,654.6	0.00	1.00
07/05/2024 14:00	0	1.5	6.8	14.6	0.4	821,002.5	0.00	1.00
07/05/2024 15:00	0	1.6	7.1	14.6	2.1	821,002.5	0.00	1.00
07/05/2024 16:00	-1	1.6	7.3	14.5	1.1	806,890.5	0.00	1.00
07/05/2024 17:00	0	1.7	7.9	14.2	7.0	907,907.9	0.00	1.00
07/05/2024 18:00	1	2.2	13.0	12.3	25.8	1,009,233.9	0.00	1.00
07/05/2024 19:00	0	1.9	10.4	13.3	15.4	1,005,626.0	0.00	1.00
07/05/2024 20:00	0	1.7	8.0	14.1	5.8	864,952.6	0.00	1.00
07/05/2024 21:00	0	1.6	7.2	14.5	1.1	811,383.9	0.00	1.00
07/05/2024 22:00	0	1.6	7.4	14.5	0.5	811,597.9	0.00	1.00
07/05/2024 23:00	-1	1.7	7.5	14.5	1.9	812,453.8	0.00	1.00
Average/Sum#:	0	1.7	7.9	14.3	5.6	853,781.0	0.00 #	24.00 #
Minimum:	-1	1.5	6.8	12.3	0.4	802,904.1	0.00	1.00
Maximum:	1	2.2	13.0	14.6	25.8	1,009,233.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/06/2024 00:00	-1	1.6	7.6	14.4	1.9	801,007.9	0.00	1.00
07/06/2024 01:00	-1	1.6	7.6	14.4	1.4	801,850.6	0.00	1.00
07/06/2024 02:00	-1	1.7	7.8	14.4	2.3	802,061.3	0.00	1.00
07/06/2024 03:00	0	1.7	7.7	14.4	5.4	802,482.7	0.00	1.00
07/06/2024 04:00	0	1.7	7.8	14.4	6.6	804,168.1	0.00	1.00
07/06/2024 05:00	0	1.7	7.8	14.4	8.3	805,221.5	0.00	1.00
07/06/2024 06:00	-1	1.6	7.7	14.4	3.8	804,589.5	0.00	1.00
07/06/2024 07:00	-1	1.7	7.7	14.4	2.5	802,904.1	0.00	1.00
07/06/2024 08:00	-1	1.6	7.7	14.5	1.0	814,379.6	0.00	1.00
07/06/2024 09:00	-1	1.7	7.6	14.5	2.0	812,881.8	0.00	1.00
07/06/2024 10:00	0	1.6	7.2	14.5	1.0	812,453.8	0.00	1.00
07/06/2024 11:00	0	1.5	6.8	14.6	0.6	824,045.7	0.00	1.00
07/06/2024 12:00	0	1.6	6.8	14.3	0.3	791,153.8	0.00	1.00
07/06/2024 13:00	0	1.6	6.7	14.3	0.8	791,568.8	0.00	1.00
07/06/2024 14:00	0	1.7	6.8	14.4	4.0	879,591.8	0.00	1.00
07/06/2024 15:00	0	1.6	6.9	14.4	1.2	804,800.2	0.00	1.00
07/06/2024 16:00	0	1.6	6.7	14.4	1.4	838,930.4	0.00	1.00
07/06/2024 17:00	0	1.8	8.9	13.8	10.3	916,550.0	0.00	1.00
07/06/2024 18:00	1	2.2	12.6	12.3	24.7	1,003,819.9	0.00	1.00
07/06/2024 19:00	1	2.1	11.5	12.8	18.8	997,312.9	0.00	1.00
07/06/2024 20:00	0	1.8	9.1	13.6	11.4	968,727.1	0.00	1.00
07/06/2024 21:00	0	1.6	6.5	14.5	1.7	982,776.0	0.00	1.00
07/06/2024 22:00	-1	1.6	6.7	14.5	2.5	965,444.2	0.00	1.00
07/06/2024 23:00	0	1.7	7.3	14.4	2.3	827,343.0	0.00	1.00
Average/Sum#:	0	1.7	7.8	14.2	4.8	852,336.0	0.00 #	24.00 #
Minimum:	-1	1.5	6.5	12.3	0.3	791,153.8	0.00	1.00
Maximum:	1	2.2	12.6	14.6	24.7	1,003,819.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2024 00:00	-1	1.7	7.5	14.5	1.9	815,021.5	0.00	1.00
07/07/2024 01:00	-1	1.6	7.7	14.5	2.4	815,235.5	0.00	1.00
07/07/2024 02:00	-1	1.6	7.9	14.4	1.4	803,325.4	0.00	1.00
07/07/2024 03:00	0	1.7	7.8	14.4	5.3	803,957.5	0.00	1.00
07/07/2024 04:00	0	1.7	7.8	14.4	5.6	804,589.5	0.00	1.00
07/07/2024 05:00	0	1.7	7.8	14.4	6.3	805,010.9	0.00	1.00
07/07/2024 06:00	-1	1.6	7.7	14.4	4.3	805,010.9	0.00	1.00
07/07/2024 07:00	-1	1.6	7.7	14.4	1.7	803,536.1	0.00	1.00
07/07/2024 08:00	0	1.6	7.6	14.5	1.2	814,593.5	0.00	1.00
07/07/2024 09:00	-1	1.6	7.4	14.5	1.4	813,951.6	0.00	1.00
07/07/2024 10:00	0	1.6	7.1	14.5	0.2	813,737.6	0.00	1.00
07/07/2024 11:00	0	1.5	6.9	14.5	0.2	812,881.8	0.00	1.00
07/07/2024 12:00	0	1.6	6.7	14.4	0.4	842,722.7	0.00	1.00
07/07/2024 13:00	0	1.6	7.0	14.4	3.5	837,455.7	0.00	1.00
07/07/2024 14:00	0	1.6	6.8	14.5	3.2	918,370.2	0.00	1.00
07/07/2024 15:00	0	1.7	6.9	14.4	3.5	862,316.0	0.00	1.00
07/07/2024 16:00	1	2.2	12.0	12.3	24.8	997,928.2	0.00	1.00
07/07/2024 17:00	1	2.2	12.8	12.1	25.9	995,322.5	0.00	1.00
07/07/2024 18:00	1	2.2	13.5	12.2	25.9	1,003,772.3	0.00	1.00
07/07/2024 19:00	1	2.2	13.6	12.3	25.3	1,011,304.0	0.00	1.00
07/07/2024 20:00	1	2.2	13.4	12.4	24.2	1,013,212.9	0.00	1.00
07/07/2024 21:00	0	1.7	8.9	13.9	8.7	919,079.4	0.00	1.00
07/07/2024 22:00	0	1.6	7.4	14.4	0.7	804,378.8	0.00	1.00
07/07/2024 23:00	-1	1.7	7.5	14.4	1.8	803,746.8	0.00	1.00
Average/Sum#:	0	1.8	8.6	14.0	7.5	863,352.6	0.00 #	24.00 #
Minimum:	-1	1.5	6.7	12.1	0.2	803,325.4	0.00	1.00
Maximum:	1	2.2	13.6	14.5	25.9	1,013,212.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2024 00:00	0	1.7	7.6	14.4	5.6	804,168.1	0.00	1.00
07/08/2024 01:00	0	1.7	7.7	14.4	7.9	804,800.2	0.00	1.00
07/08/2024 02:00	0	1.6	8.0	14.4	6.8	805,432.2	0.00	1.00
07/08/2024 03:00	0	1.7	7.8	14.4	6.2	805,853.6	0.00	1.00
07/08/2024 04:00	0	1.7	7.8	14.4	7.3	806,274.9	0.00	1.00
07/08/2024 05:00	0	1.7	7.8	14.4	7.1	806,064.3	0.00	1.00
07/08/2024 06:00	0	1.7	7.8	14.4	6.1	806,485.6	0.00	1.00
07/08/2024 07:00	-1	1.6	7.7	14.4	2.3	805,432.2	0.00	1.00
07/08/2024 08:00	-1	1.6	7.7	14.4	2.1	804,800.2	0.00	1.00
07/08/2024 09:00	-1	1.6	7.6	14.4	2.1	803,536.1	0.00	1.00
07/08/2024 10:00	0	1.6	7.5	14.5	0.5	814,807.5	0.00	1.00
07/08/2024 11:00	0	1.6	7.3	14.5	0.9	813,951.6	0.00	1.00
07/08/2024 12:00	0	1.5	6.8	14.3	0.2	797,586.0	0.00	1.00
07/08/2024 13:00	0	1.6	6.9	14.4	1.4	831,345.9	0.00	1.00
07/08/2024 14:00	0	1.6	6.7	14.6	6.3	1,005,114.0	0.00	1.00
07/08/2024 15:00	0	1.7	7.0	14.4	4.6	891,600.6	0.00	1.00
07/08/2024 16:00	0	1.8	9.4	13.8	14.5	964,383.4	0.00	1.00
07/08/2024 17:00	1	2.3	13.5	12.1	27.0	1,007,771.9	0.00	1.00
07/08/2024 18:00	1	2.2	13.3	12.1	28.1	1,017,575.7	0.00	1.00
07/08/2024 19:00	1	2.2	13.7	12.4	25.4	1,024,490.5	0.00	1.00
07/08/2024 20:00	1	2.2	13.4	12.4	24.7	1,018,207.3	0.00	1.00
07/08/2024 21:00	1	2.1	12.8	12.7	22.7	1,029,907.3	0.00	1.00
07/08/2024 22:00	1	2.1	12.7	12.7	22.7	1,027,235.3	0.00	1.00
07/08/2024 23:00	1	2.0	11.6	13.1	20.1	1,030,930.8	0.00	1.00
Average/Sum#:	0	1.8	9.2	13.8	10.5	888,656.5	0.00 #	24.00 #
Minimum:	-1	1.5	6.7	12.1	0.2	797,586.0	0.00	1.00
Maximum:	1	2.3	13.7	14.6	28.1	1,030,930.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/09/2024 00:00	0	1.7	8.9	14.0	11.8	936,567.2	0.00	1.00
07/09/2024 01:00	0	1.7	8.0	14.3	6.1	794,888.6	0.00	1.00
07/09/2024 02:00	0	1.7	8.2	14.3	9.3	795,096.1	0.00	1.00
07/09/2024 03:00	0	1.7	8.1	14.3	9.2	795,926.1	0.00	1.00
07/09/2024 04:00	0	1.7	8.1	14.3	9.5	801,320.8	0.00	1.00
07/09/2024 05:00	0	1.7	7.9	14.3	8.8	795,926.1	0.00	1.00
07/09/2024 06:00	0	1.7	7.8	14.3	9.0	795,926.1	0.00	1.00
07/09/2024 07:00	0	1.7	7.8	14.3	7.0	795,511.1	0.00	1.00
07/09/2024 08:00	0	1.7	7.7	14.4	5.1	806,907.0	0.00	1.00
07/09/2024 09:00	-1	1.7	7.6	14.4	2.4	804,800.2	0.00	1.00
07/09/2024 10:00	-1	1.6	7.6	14.4	0.8	803,325.4	0.00	1.00
07/09/2024 11:00	0	1.6	7.5	14.4	0.7	802,482.7	0.00	1.00
07/09/2024 12:00	0	1.6	7.4	14.5	1.2	824,008.3	0.00	1.00
07/09/2024 13:00	0	1.6	7.4	14.5	10.0	1,004,173.2	0.00	1.00
07/09/2024 14:00	0	1.6	7.3	14.5	8.6	972,505.3	0.00	1.00
07/09/2024 15:00	0	1.7	7.8	14.2	7.2	915,674.8	0.00	1.00
07/09/2024 16:00	1	2.2	12.9	12.5	24.6	1,022,503.5	0.00	1.00
07/09/2024 17:00	1	2.2	13.4	12.3	25.3	1,014,011.0	0.00	1.00
07/09/2024 18:00	1	2.2	13.5	12.1	28.0	1,020,221.2	0.00	1.00
07/09/2024 19:00	1	2.2	13.6	12.4	25.8	1,028,840.5	0.00	1.00
07/09/2024 20:00	1	2.1	13.2	12.6	24.8	1,033,667.9	0.00	1.00
07/09/2024 21:00	1	2.1	13.1	12.6	24.9	1,034,657.9	0.00	1.00
07/09/2024 22:00	1	2.1	12.9	12.7	24.1	1,036,921.5	0.00	1.00
07/09/2024 23:00	0	1.8	9.3	13.8	13.9	1,002,380.1	0.00	1.00
Average/Sum#:	0	1.8	9.5	13.8	12.4	901,593.4	0.00 #	24.00 #
Minimum:	-1	1.6	7.3	12.1	0.7	794,888.6	0.00	1.00
Maximum:	1	2.2	13.6	14.5	28.0	1,036,921.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2024 00:00	0	1.6	7.2	14.5	10.5	1,003,745.3	0.00	1.00
07/10/2024 01:00	0	1.6	7.3	14.5	10.7	992,190.8	0.00	1.00
07/10/2024 02:00	0	1.6	7.4	14.5	11.3	1,014,016.0	0.00	1.00
07/10/2024 03:00	0	1.7	7.5	14.4	11.2	972,080.6	0.00	1.00
07/10/2024 04:00	0	1.6	7.5	14.4	11.9	1,000,311.8	0.00	1.00
07/10/2024 05:00	0	1.6	7.7	14.4	10.4	925,941.6	0.00	1.00
07/10/2024 06:00	0	1.7	7.7	14.3	7.1	800,490.8	0.00	1.00
07/10/2024 07:00	-1	1.7	7.6	14.3	3.5	800,490.8	0.00	1.00
07/10/2024 08:00	-1	1.7	7.6	14.3	1.2	798,623.4	0.00	1.00
07/10/2024 09:00	-1	1.6	7.5	14.4	1.9	806,064.3	0.00	1.00
07/10/2024 10:00	0	1.6	7.4	14.5	0.7	817,589.2	0.00	1.00
07/10/2024 11:00	0	1.6	7.2	14.5	0.7	816,733.3	0.00	1.00
07/10/2024 12:00	0	1.6	6.9	14.5	0.4	813,951.6	0.00	1.00
07/10/2024 13:00	0	1.6	6.9	14.5	4.9	899,112.7	0.00	1.00
07/10/2024 14:00	0	1.6	7.0	14.5	6.7	955,601.5	0.00	1.00
07/10/2024 15:00	0	1.6	6.9	14.5	3.5	888,842.0	0.00	1.00
07/10/2024 16:00	0	1.6	7.1	14.5	4.8	901,038.5	0.00	1.00
07/10/2024 17:00	1	2.1	12.0	12.6	23.0	1,004,629.5	0.00	1.00
07/10/2024 18:00	1	2.3	13.0	12.1	27.5	1,010,417.3	0.00	1.00
07/10/2024 19:00	1	2.2	13.5	12.2	26.4	1,016,049.9	0.00	1.00
07/10/2024 20:00	1	2.1	13.1	12.5	23.2	1,014,515.2	0.00	1.00
07/10/2024 21:00	0	2.0	11.2	13.1	17.9	1,012,320.6	0.00	1.00
07/10/2024 22:00	0	1.8	9.1	13.7	13.6	978,187.4	0.00	1.00
07/10/2024 23:00	0	1.5	7.2	14.4	4.6	900,238.5	0.00	1.00
Average/Sum#:	0	1.7	8.5	14.0	9.9	922,632.6	0.00 #	24.00 #
Minimum:	-1	1.5	6.9	12.1	0.4	798,623.4	0.00	1.00
Maximum:	1	2.3	13.5	14.5	27.5	1,016,049.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2024 00:00	0	1.6	7.0	14.3	0.7	796,963.5	0.00	1.00
07/11/2024 01:00	0	1.7	7.1	14.3	0.6	795,096.1	0.00	1.00
07/11/2024 02:00	0	1.7	7.3	14.3	4.7	795,096.1	0.00	1.00
07/11/2024 03:00	0	1.7	7.4	14.3	2.0	795,303.6	0.00	1.00
07/11/2024 04:00	0	1.7	7.4	14.3	1.2	795,718.6	0.00	1.00
07/11/2024 05:00	0	1.7	7.4	14.3	1.2	796,548.5	0.00	1.00
07/11/2024 06:00	0	1.7	7.3	14.3	1.2	797,378.5	0.00	1.00
07/11/2024 07:00	0	1.7	7.2	14.3	1.0	796,963.5	0.00	1.00
07/11/2024 08:00	0	1.7	7.1	14.3	1.1	797,378.5	0.00	1.00
07/11/2024 09:00	0	1.7	7.1	14.3	0.7	795,926.1	0.00	1.00
07/11/2024 10:00	0	1.6	7.0	14.3	0.6	795,096.1	0.00	1.00
07/11/2024 11:00	0	1.6	7.0	14.6	0.6	827,523.6	0.00	1.00
07/11/2024 12:00	0	1.6	6.7	14.5	2.7	871,510.2	0.00	1.00
07/11/2024 13:00	0	1.6	7.1	14.5	9.2	992,190.8	0.00	1.00
07/11/2024 14:00	1	2.2	12.2	12.6	23.7	1,012,384.1	0.00	1.00
07/11/2024 15:00	1	2.2	14.0	12.2	28.6	1,015,105.5	0.00	1.00
07/11/2024 16:00	1	2.2	14.3	12.3	28.0	1,022,609.7	0.00	1.00
07/11/2024 17:00	1	2.2	14.2	12.2	28.5	1,016,049.9	0.00	1.00
07/11/2024 18:00	1	2.2	14.1	12.2	28.4	1,015,735.1	0.00	1.00
07/11/2024 19:00	1	2.2	14.1	12.2	27.8	1,013,374.0	0.00	1.00
07/11/2024 20:00	1	2.2	14.3	12.3	27.3	1,023,087.4	0.00	0.97
07/11/2024 21:00	1	2.2	14.1	12.3	26.7	1,021,017.3	0.00	1.00
07/11/2024 22:00	0	1.9	11.2	13.2	17.1	983,317.8	0.00	1.00
07/11/2024 23:00	0	1.6	7.7	14.5	9.4	989,409.1	0.00	1.00
Average/Sum#:	0	1.9	9.6	13.6	11.4	898,366.0	0.00 #	23.97 #
Minimum:	0	1.6	6.7	12.2	0.6	795,096.1	0.00	0.97
Maximum:	1	2.2	14.3	14.6	28.6	1,023,087.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2024 00:00	0	1.6	7.4	14.3	2.1	830,784.1	0.00	1.00
07/12/2024 01:00	0	1.6	7.2	14.3	0.5	795,096.1	0.00	1.00
07/12/2024 02:00	-1	1.7	7.5	14.3	1.0	795,511.1	0.00	1.00
07/12/2024 03:00	0	1.7	7.5	14.3	1.7	796,548.5	0.00	1.00
07/12/2024 04:00	-1	1.7	7.5	14.3	1.2	797,171.0	0.00	1.00
07/12/2024 05:00	-1	1.7	7.5	14.3	1.6	798,623.4	0.00	1.00
07/12/2024 06:00	0	1.7	7.5	14.4	2.7	849,675.2	0.00	1.00
07/12/2024 07:00	0	1.7	7.3	14.3	1.1	797,586.0	0.00	1.00
07/12/2024 08:00	0	1.7	7.2	14.3	1.0	797,171.0	0.00	1.00
07/12/2024 09:00	0	1.7	7.1	14.3	1.0	793,643.7	0.00	1.00
07/12/2024 10:00	0	1.6	7.0	14.3	0.6	792,398.7	0.00	1.00
07/12/2024 11:00	0	1.7	6.7	14.5	2.8	906,387.8	0.00	1.00
07/12/2024 12:00	0	1.6	6.7	14.5	6.3	982,348.0	0.00	1.00
07/12/2024 13:00	0	1.6	6.8	14.6	5.9	999,897.2	0.00	1.00
07/12/2024 14:00	0	1.9	9.0	13.9	12.6	956,445.1	0.00	1.00
07/12/2024 15:00	0	1.9	10.3	13.4	16.7	1,000,227.6	0.00	1.00
07/12/2024 16:00	1	2.0	11.3	13.1	19.2	1,008,809.3	0.00	1.00
07/12/2024 17:00	2	2.3	13.2	12.0	28.8	996,140.8	0.00	1.00
07/12/2024 18:00	1	2.2	13.4	12.1	27.9	1,004,970.8	0.00	1.00
07/12/2024 19:00	1	2.1	13.2	12.5	23.8	1,004,407.6	0.00	1.00
07/12/2024 20:00	1	2.1	12.6	12.8	22.3	1,018,446.0	0.00	1.00
07/12/2024 21:00	0	1.6	8.2	14.2	6.8	934,683.2	0.00	1.00
07/12/2024 22:00	0	1.7	6.9	14.5	8.0	974,003.1	0.00	1.00
07/12/2024 23:00	0	1.6	7.3	14.3	2.0	814,185.0	0.00	1.00
Average/Sum#:	0	1.8	8.6	13.9	8.2	893,548.3	0.00 #	24.00 #
Minimum:	-1	1.6	6.7	12.0	0.5	792,398.7	0.00	1.00
Maximum:	2	2.3	13.4	14.6	28.8	1,018,446.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2024 00:00	-1	1.7	7.2	14.3	1.7	790,531.3	0.00	1.00
07/13/2024 01:00	-1	1.7	7.4	14.3	2.8	786,796.6	0.00	1.00
07/13/2024 02:00	0	1.7	7.8	14.4	7.3	812,595.4	0.00	1.00
07/13/2024 03:00	0	1.7	7.8	14.4	7.1	817,651.7	0.00	1.00
07/13/2024 04:00	0	1.7	7.8	14.4	7.9	797,005.0	0.00	1.00
07/13/2024 05:00	0	1.6	7.8	14.4	8.4	797,847.7	0.00	1.00
07/13/2024 06:00	0	1.7	7.8	14.4	8.7	797,215.7	0.00	1.00
07/13/2024 07:00	0	1.6	7.8	14.4	5.9	797,005.0	0.00	1.00
07/13/2024 08:00	0	1.8	9.2	13.9	13.1	841,217.8	0.00	1.00
07/13/2024 09:00	0	1.6	8.0	14.4	6.8	850,517.9	0.00	1.00
07/13/2024 10:00	0	1.6	7.7	14.4	6.3	805,853.6	0.00	1.00
07/13/2024 11:00	0	1.6	7.8	14.5	5.5	816,091.3	0.00	1.00
07/13/2024 12:00	-1	1.6	7.7	14.5	2.8	814,807.5	0.00	1.00
07/13/2024 13:00	-1	1.6	7.4	14.5	1.3	816,091.3	0.00	1.00
07/13/2024 14:00	0	1.6	7.1	14.5	1.0	818,873.0	0.00	1.00
07/13/2024 15:00	0	1.6	7.1	14.6	0.8	836,218.3	0.00	1.00
07/13/2024 16:00	0	1.7	7.4	14.5	4.0	837,702.6	0.00	1.00
07/13/2024 17:00	0	1.6	7.2	14.5	4.0	874,719.8	0.00	1.00
07/13/2024 18:00	0	1.6	7.6	14.4	8.5	956,490.3	0.00	1.00
07/13/2024 19:00	0	1.7	7.4	14.3	1.4	806,508.0	0.00	1.00
07/13/2024 20:00	0	1.7	7.5	14.3	4.9	835,141.4	0.00	1.00
07/13/2024 21:00	0	1.7	7.5	14.3	5.0	810,450.2	0.00	1.00
07/13/2024 22:00	0	1.7	7.8	14.4	8.5	818,705.1	0.00	1.00
07/13/2024 23:00	0	1.6	8.1	14.5	10.0	827,217.9	0.00	1.00
Average/Sum#:	0	1.7	7.7	14.4	5.6	823,468.9	0.00 #	24.00 #
Minimum:	-1	1.6	7.1	13.9	0.8	786,796.6	0.00	1.00
Maximum:	0	1.8	9.2	14.6	13.1	956,490.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2024 00:00	0	1.6	8.1	14.5	9.8	825,292.2	0.00	1.00
07/14/2024 01:00	0	1.7	8.1	14.4	9.7	811,542.0	0.00	1.00
07/14/2024 02:00	0	1.6	8.2	14.4	9.4	808,381.7	0.00	1.00
07/14/2024 03:00	0	1.7	8.0	14.4	8.8	804,378.8	0.00	1.00
07/14/2024 04:00	0	1.7	8.0	14.4	9.7	804,589.5	0.00	1.00
07/14/2024 05:00	0	1.7	8.0	14.4	9.8	805,221.5	0.00	1.00
07/14/2024 06:00	0	1.7	7.9	14.4	9.8	805,432.2	0.00	1.00
07/14/2024 07:00	0	1.7	7.9	14.4	9.8	805,642.9	0.00	1.00
07/14/2024 08:00	0	1.7	7.9	14.4	9.8	805,432.2	0.00	1.00
07/14/2024 09:00	0	1.7	7.9	14.4	8.9	805,642.9	0.00	1.00
07/14/2024 10:00	0	1.6	7.8	14.4	7.4	804,168.1	0.00	1.00
07/14/2024 11:00	0	1.6	7.8	14.5	5.6	815,449.4	0.00	1.00
07/14/2024 12:00	-1	1.6	7.8	14.5	3.2	814,379.6	0.00	1.00
07/14/2024 13:00	-1	1.6	7.7	14.5	1.8	813,523.7	0.00	1.00
07/14/2024 14:00	0	1.6	7.5	14.5	3.2	852,038.7	0.00	1.00
07/14/2024 15:00	0	1.6	7.4	14.5	1.6	828,929.7	0.00	1.00
07/14/2024 16:00	0	1.6	7.2	14.4	1.1	808,171.1	0.00	1.00
07/14/2024 17:00	0	1.6	7.2	14.4	2.9	825,236.2	0.00	1.00
07/14/2024 18:00	0	1.7	7.3	14.5	3.5	881,994.9	0.00	1.00
07/14/2024 19:00	0	1.6	7.4	14.4	3.6	863,790.8	0.00	1.00
07/14/2024 20:00	0	1.7	7.4	14.4	4.3	862,105.3	0.00	1.00
07/14/2024 21:00	0	1.6	7.5	14.4	7.5	902,977.4	0.00	1.00
07/14/2024 22:00	-1	1.7	7.4	14.3	3.3	794,681.1	0.00	1.00
07/14/2024 23:00	0	1.7	7.6	14.4	8.2	805,432.2	0.00	1.00
Average/Sum#:	0	1.7	7.7	14.4	6.4	823,101.4	0.00 #	24.00 #
Minimum:	-1	1.6	7.2	14.3	1.1	794,681.1	0.00	1.00
Maximum:	0	1.7	8.2	14.5	9.8	902,977.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2024 00:00	0	1.7	7.7	14.4	8.3	805,853.6	0.00	1.00
07/15/2024 01:00	0	1.7	7.7	14.4	9.5	805,853.6	0.00	1.00
07/15/2024 02:00	0	1.7	8.0	14.4	9.5	805,642.9	0.00	1.00
07/15/2024 03:00	0	1.7	8.1	14.4	10.3	855,995.6	0.00	1.00
07/15/2024 04:00	0	1.7	8.1	14.3	9.7	794,058.7	0.00	1.00
07/15/2024 05:00	0	1.7	8.0	14.3	10.1	793,643.7	0.00	1.00
07/15/2024 06:00	0	1.7	7.9	14.3	9.8	794,266.1	0.00	1.00
07/15/2024 07:00	0	1.7	7.9	14.4	9.5	805,432.2	0.00	1.00
07/15/2024 08:00	0	1.7	7.9	14.4	9.0	806,696.3	0.00	1.00
07/15/2024 09:00	0	1.7	7.7	14.4	7.0	805,853.6	0.00	1.00
07/15/2024 10:00	0	1.6	7.7	14.4	6.1	805,642.9	0.00	1.00
07/15/2024 11:00	-1	1.6	7.7	14.5	3.0	817,161.2	0.00	1.00
07/15/2024 12:00	-1	1.6	7.8	14.5	2.4	816,733.3	0.00	1.00
07/15/2024 13:00	-1	1.6	7.7	14.5	1.4	816,733.3	0.00	1.00
07/15/2024 14:00	-1	1.6	7.6	14.5	1.2	816,305.3	0.00	1.00
07/15/2024 15:00	-1	1.6	7.5	14.6	2.0	847,086.8	0.00	1.00
07/15/2024 16:00	-1	1.6	7.7	14.5	2.5	818,231.1	0.00	1.00
07/15/2024 17:00	-1	1.6	7.6	14.5	1.3	819,728.9	0.00	1.00
07/15/2024 18:00	-1	1.6	7.8	14.5	2.1	818,873.0	0.00	1.00
07/15/2024 19:00	0	1.6	7.3	14.3	0.5	798,830.9	0.00	1.00
07/15/2024 20:00	0	1.7	7.7	14.4	7.0	808,592.4	0.00	1.00
07/15/2024 21:00	0	1.7	7.8	14.4	9.6	807,749.7	0.00	1.00
07/15/2024 22:00	0	1.7	7.9	14.4	9.7	806,907.0	0.00	1.00
07/15/2024 23:00	0	1.7	7.8	14.4	9.8	807,328.3	0.00	1.00
Average/Sum#:	0	1.7	7.8	14.4	6.3	811,633.4	0.00 #	24.00 #
Minimum:	-1	1.6	7.3	14.3	0.5	793,643.7	0.00	1.00
Maximum:	0	1.7	8.1	14.6	10.3	855,995.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2024 00:00	0	1.6	7.9	14.4	9.8	806,907.0	0.00	1.00
07/16/2024 01:00	0	1.7	8.0	14.4	10.0	806,696.3	0.00	1.00
07/16/2024 02:00	0	1.7	8.2	14.4	9.9	807,539.0	0.00	1.00
07/16/2024 03:00	0	1.7	8.2	14.4	9.6	807,749.7	0.00	1.00
07/16/2024 04:00	0	1.7	8.0	14.4	10.6	865,476.2	0.00	1.00
07/16/2024 05:00	0	1.6	8.6	14.4	12.8	929,312.5	0.00	1.00
07/16/2024 06:00	0	1.7	8.5	14.3	11.0	796,341.0	0.00	1.00
07/16/2024 07:00	0	1.7	8.4	14.3	10.7	796,341.0	0.00	0.97
07/16/2024 08:00	0	1.7	8.3	14.4	10.4	807,117.7	0.00	0.53
07/16/2024 09:00	0	1.7	8.3	14.4	9.9	806,274.9	0.00	0.33
07/16/2024 10:00	-1	1.6	7.9	14.4	5.6	804,589.5	0.00	0.92
07/16/2024 11:00	-1	1.7	7.8	14.5	5.5	815,663.4	0.00	1.00
07/16/2024 12:00	-1	1.6	7.8	14.5	3.5	814,807.5	0.00	1.00
07/16/2024 13:00	-1	1.6	7.9	14.5	2.0	813,095.7	0.00	1.00
07/16/2024 14:00	-1	1.6	7.8	14.5	3.6	846,047.5	0.00	1.00
07/16/2024 15:00	0	1.6	8.0	14.4	9.9	954,594.1	0.00	1.00
07/16/2024 16:00	-1	1.6	7.9	14.5	3.5	812,025.9	0.00	1.00
07/16/2024 17:00	0	1.7	8.9	14.2	12.6	946,538.0	0.00	0.93
07/16/2024 18:00	0	1.8	10.9	13.7	17.3	1,059,972.5	0.00	1.00
07/16/2024 19:00	0	1.8	9.8	13.8	17.6	1,043,269.9	0.00	1.00
07/16/2024 20:00	0	1.8	10.3	13.7	17.1	997,017.0	0.00	1.00
07/16/2024 21:00	0	1.7	7.7	14.4	11.8	952,276.6	0.00	1.00
07/16/2024 22:00	0	1.7	8.2	14.3	11.3	865,434.7	0.00	1.00
07/16/2024 23:00	0	1.7	8.4	14.3	10.7	796,133.5	0.00	1.00
Average/Sum#:	0	1.7	8.4	14.3	9.9	864,634.2	0.00 #	22.68 #
Minimum:	-1	1.6	7.7	13.7	2.0	796,133.5	0.00	0.33
Maximum:	0	1.8	10.9	14.5	17.6	1,059,972.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2024 00:00	0	1.7	8.4	14.3	10.8	797,586.0	0.00	1.00
07/17/2024 01:00	0	1.7	8.4	14.3	10.6	798,208.4	0.00	1.00
07/17/2024 02:00	0	1.7	8.5	14.3	10.5	798,000.9	0.00	1.00
07/17/2024 03:00	0	1.7	8.5	14.3	10.7	798,208.4	0.00	1.00
07/17/2024 04:00	0	1.7	8.4	14.3	10.6	803,188.2	0.00	1.00
07/17/2024 05:00	0	1.7	8.3	14.4	11.7	886,544.3	0.00	1.00
07/17/2024 06:00	0	1.7	8.4	14.3	10.9	797,793.4	0.00	1.00
07/17/2024 07:00	0	1.7	8.3	14.3	10.6	797,378.5	0.00	1.00
07/17/2024 08:00	0	1.7	8.3	14.3	10.0	796,133.5	0.00	1.00
07/17/2024 09:00	0	1.7	8.4	14.4	9.4	807,539.0	0.00	1.00
07/17/2024 10:00	0	1.6	8.1	14.4	8.8	806,064.3	0.00	1.00
07/17/2024 11:00	-1	1.6	7.9	14.4	2.3	803,746.8	0.00	1.00
07/17/2024 12:00	-1	1.6	7.8	14.5	1.2	815,663.4	0.00	1.00
07/17/2024 13:00	-1	1.6	7.8	14.5	3.1	814,379.6	0.00	1.00
07/17/2024 14:00	0	1.7	8.1	14.5	5.9	812,453.8	0.00	1.00
07/17/2024 15:00	-1	1.6	8.0	14.5	5.0	812,025.9	0.00	1.00
07/17/2024 16:00	-1	1.6	7.8	14.5	0.9	811,597.9	0.00	1.00
07/17/2024 17:00	0	1.7	7.6	14.5	4.4	887,772.2	0.00	1.00
07/17/2024 18:00	0	1.6	7.8	14.5	6.8	902,750.2	0.00	1.00
07/17/2024 19:00	0	1.6	7.9	14.5	9.1	1,000,321.7	0.00	1.00
07/17/2024 20:00	0	1.7	7.6	14.5	11.1	1,026,426.4	0.00	1.00
07/17/2024 21:00	0	1.6	7.4	14.5	11.5	1,025,784.5	0.00	1.00
07/17/2024 22:00	0	1.6	7.6	14.4	7.6	908,455.1	0.00	1.00
07/17/2024 23:00	-1	1.7	7.4	14.3	2.3	795,926.1	0.00	0.35
Average/Sum#:	0	1.7	8.0	14.4	7.7	845,997.9	0.00 #	23.35 #
Minimum:	-1	1.6	7.4	14.3	0.9	795,926.1	0.00	0.35
Maximum:	0	1.7	8.5	14.5	11.7	1,026,426.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2024 00:00	0	1.7	7.5	14.4	7.8	806,274.9	0.00	0.13
07/18/2024 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2024 02:00	0	1.7	7.8	14.4	9.5	805,432.2	0.00	0.05
07/18/2024 03:00	0	0.0	7.8	0.0	7.9	251,869.3	0.00	0.07
07/18/2024 04:00	1	1.9	7.8	14.3	10.2	796,756.0	0.00	0.15
07/18/2024 05:00	0	1.8	8.0	14.4	8.6	808,803.1	0.00	0.48
07/18/2024 06:00	0	1.7	7.9	14.3	8.3	796,341.0	0.00	1.00
07/18/2024 07:00	-1	1.6	7.8	14.4	2.1	807,328.3	0.00	1.00
07/18/2024 08:00	-1	1.7	7.8	14.4	1.4	806,064.3	0.00	1.00
07/18/2024 09:00	-1	1.6	7.9	14.5	2.0	816,733.3	0.00	1.00
07/18/2024 10:00	-1	1.6	7.7	14.5	0.9	815,449.4	0.00	1.00
07/18/2024 11:00	0	1.7	7.3	14.5	1.7	859,527.8	0.00	1.00
07/18/2024 12:00	0	1.7	7.4	14.4	4.8	888,440.4	0.00	1.00
07/18/2024 13:00	0	1.7	7.1	14.4	4.3	884,437.5	0.00	1.00
07/18/2024 14:00	0	1.6	7.2	14.5	10.2	981,278.2	0.00	1.00
07/18/2024 15:00	0	7.4	14.8	14.9	4.5	832,381.8	0.25	0.43
07/18/2024 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2024 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2024 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2024 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2024 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2024 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2024 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2024 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	2.1	8.1	14.5	5.6	836,089.2	0.25 #	10.31 #
Minimum:	-1	1.6	7.1	14.3	0.9	796,341.0	0.00	0.00
Maximum:	1	7.4	14.8	14.9	10.2	981,278.2	0.25	1.00
%SI	37.50	41.67	37.50	41.67	37.50	41.67	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2024 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2024 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:28 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2024 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2024 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2024 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2024 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2024 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2024 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2024 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2024 07:00	0	18.8	21.8	16.7	0.0	757,096.1	0.38	0.38
07/20/2024 08:00	0	3.7	9.0	14.5	8.1	839,414.4	0.72	1.00
07/20/2024 09:00	0	1.6	8.7	14.5	9.2	814,593.5	0.00	1.00
07/20/2024 10:00	-1	1.6	8.4	14.5	3.4	813,737.6	0.00	1.00
07/20/2024 11:00	-1	1.7	8.4	14.5	4.5	846,689.4	0.00	1.00
07/20/2024 12:00	0	1.6	7.9	14.6	5.8	894,473.2	0.00	1.00
07/20/2024 13:00	0	1.6	7.5	14.6	9.5	997,506.1	0.00	1.00
07/20/2024 14:00	0	1.7	9.0	14.2	13.1	970,656.2	0.00	1.00
07/20/2024 15:00	0	1.9	11.0	13.4	17.6	1,008,809.3	0.00	1.00
07/20/2024 16:00	0	1.9	10.9	13.4	16.9	1,010,270.0	0.00	1.00
07/20/2024 17:00	1	2.1	12.8	12.8	22.0	1,014,895.6	0.00	1.00
07/20/2024 18:00	1	2.2	14.2	12.4	25.9	1,016,596.2	0.00	1.00
07/20/2024 19:00	1	2.2	13.9	12.5	25.2	1,024,133.8	0.00	1.00
07/20/2024 20:00	1	2.1	13.9	12.5	25.3	1,023,318.7	0.00	1.00
07/20/2024 21:00	1	2.1	13.9	12.6	25.6	1,031,688.0	0.00	1.00
07/20/2024 22:00	1	2.1	13.7	12.7	25.2	1,040,428.5	0.00	1.00
07/20/2024 23:00	1	2.1	13.1	12.8	23.9	1,041,946.0	0.00	1.00
Average/Sum#:	0	3.0	11.7	13.7	15.4	949,779.6	1.10 #	16.38 #
Minimum:	-1	1.6	7.5	12.4	0.0	757,096.1	0.00	0.00
Maximum:	1	18.8	21.8	16.7	25.9	1,041,946.0	0.72	1.00
%SI	33.33	29.17	29.17	29.17	29.17	29.17	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2024 00:00	0	1.7	9.5	14.0	13.1	961,375.6	0.00	1.00
07/21/2024 01:00	0	1.7	8.0	14.4	6.3	807,117.7	0.00	1.00
07/21/2024 02:00	0	1.7	8.2	14.4	9.1	807,117.7	0.00	1.00
07/21/2024 03:00	0	1.7	8.2	14.4	9.7	808,171.1	0.00	1.00
07/21/2024 04:00	0	1.7	8.2	14.4	10.1	808,381.7	0.00	1.00
07/21/2024 05:00	0	1.7	8.2	14.4	10.1	810,067.2	0.00	1.00
07/21/2024 06:00	0	1.7	8.2	14.4	10.0	809,224.5	0.00	1.00
07/21/2024 07:00	0	1.7	8.1	14.4	9.3	809,435.2	0.00	1.00
07/21/2024 08:00	0	1.7	8.1	14.4	8.9	808,381.7	0.00	1.00
07/21/2024 09:00	0	1.7	8.0	14.4	7.8	807,328.3	0.00	1.00
07/21/2024 10:00	0	1.6	8.0	14.4	6.7	806,064.3	0.00	1.00
07/21/2024 11:00	-1	1.6	8.0	14.4	4.8	804,378.8	0.00	1.00
07/21/2024 12:00	-1	1.6	7.8	14.5	0.7	815,663.4	0.00	1.00
07/21/2024 13:00	-1	1.6	7.8	14.5	1.5	814,807.5	0.00	1.00
07/21/2024 14:00	-1	1.6	7.6	14.5	1.1	813,737.6	0.00	1.00
07/21/2024 15:00	0	1.6	7.4	14.5	1.0	813,523.7	0.00	1.00
07/21/2024 16:00	0	1.6	7.4	14.5	0.4	812,881.8	0.00	1.00
07/21/2024 17:00	0	1.7	7.0	14.5	3.7	899,326.7	0.00	1.00
07/21/2024 18:00	0	1.6	7.0	14.5	8.9	984,487.7	0.00	1.00
07/21/2024 19:00	0	1.6	7.3	14.5	9.2	961,806.7	0.00	1.00
07/21/2024 20:00	0	1.6	7.5	14.5	10.0	972,933.2	0.00	1.00
07/21/2024 21:00	0	1.6	7.2	14.5	10.8	979,566.4	0.00	1.00
07/21/2024 22:00	0	1.6	7.7	14.4	5.2	862,316.0	0.00	1.00
07/21/2024 23:00	0	1.7	7.5	14.5	9.0	935,488.0	0.00	1.00
Average/Sum#:	0	1.7	7.8	14.4	7.0	854,732.6	0.00 #	24.00 #
Minimum:	-1	1.6	7.0	14.0	0.4	804,378.8	0.00	1.00
Maximum:	0	1.7	9.5	14.5	13.1	984,487.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:28 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2024 00:00	0	1.7	7.8	14.4	7.9	875,378.2	0.00	1.00
07/22/2024 01:00	0	1.7	7.7	14.4	6.8	806,485.6	0.00	1.00
07/22/2024 02:00	0	1.7	8.3	14.5	12.5	983,203.9	0.00	1.00
07/22/2024 03:00	0	1.6	8.1	14.5	9.4	979,994.3	0.00	1.00
07/22/2024 04:00	0	1.6	7.8	14.5	12.6	1,014,443.9	0.00	1.00
07/22/2024 05:00	0	1.6	7.9	14.4	10.3	940,267.9	0.00	1.00
07/22/2024 06:00	0	1.7	7.8	14.3	5.7	796,133.5	0.00	1.00
07/22/2024 07:00	0	1.6	7.8	14.4	6.2	806,485.6	0.00	1.00
07/22/2024 08:00	-1	1.6	7.8	14.4	2.1	805,010.9	0.00	1.00
07/22/2024 09:00	-1	1.6	7.6	14.4	2.1	804,589.5	0.00	1.00
07/22/2024 10:00	0	1.6	7.5	14.5	0.7	815,021.5	0.00	1.00
07/22/2024 11:00	0	1.6	7.1	14.6	2.1	879,692.1	0.00	1.00
07/22/2024 12:00	0	1.7	6.8	14.6	4.6	992,071.9	0.00	1.00
07/22/2024 13:00	0	1.6	6.8	14.6	6.7	1,000,114.5	0.00	1.00
07/22/2024 14:00	0	1.6	7.0	14.6	9.7	1,000,984.0	0.00	1.00
07/22/2024 15:00	2	2.4	12.6	12.2	23.5	960,328.5	0.00	1.00
07/22/2024 16:00	1	2.2	13.6	12.3	27.9	1,016,081.0	0.00	1.00
07/22/2024 17:00	1	2.2	14.4	12.2	29.7	1,015,262.9	0.00	1.00
07/22/2024 18:00	1	2.2	14.4	12.3	27.9	1,012,577.9	0.00	1.00
07/22/2024 19:00	1	2.2	13.9	12.4	26.6	1,018,046.2	0.00	1.00
07/22/2024 20:00	0	2.0	11.8	13.0	18.9	1,012,854.0	0.00	1.00
07/22/2024 21:00	0	2.0	11.4	13.1	18.8	1,015,656.4	0.00	1.00
07/22/2024 22:00	0	1.8	8.5	14.0	10.4	965,345.0	0.00	1.00
07/22/2024 23:00	0	1.7	7.1	14.5	9.3	988,125.3	0.00	1.00
Average/Sum#:	0	1.8	9.2	13.9	12.2	937,673.1	0.00 #	24.00 #
Minimum:	-1	1.6	6.8	12.2	0.7	796,133.5	0.00	1.00
Maximum:	2	2.4	14.4	14.6	29.7	1,018,046.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2024 00:00	0	1.6	7.3	14.5	9.4	956,885.3	0.00	1.00
07/23/2024 01:00	0	1.7	7.1	14.5	9.1	978,710.5	0.00	1.00
07/23/2024 02:00	0	1.6	7.9	14.5	10.2	947,042.6	0.00	1.00
07/23/2024 03:00	0	1.7	8.4	14.3	8.8	905,895.0	0.00	1.00
07/23/2024 04:00	1	2.1	13.2	12.8	24.8	1,042,960.4	0.00	1.00
07/23/2024 05:00	1	2.1	13.7	12.7	26.1	1,048,945.7	0.00	1.00
07/23/2024 06:00	1	2.1	13.4	12.7	24.6	1,038,090.5	0.00	1.00
07/23/2024 07:00	1	2.1	13.5	12.7	24.7	1,041,430.5	0.00	1.00
07/23/2024 08:00	1	2.1	13.8	12.6	25.1	1,032,348.0	0.00	1.00
07/23/2024 09:00	1	2.1	14.0	12.5	25.5	1,021,688.4	0.00	1.00
07/23/2024 10:00	1	2.1	14.1	12.5	25.5	1,020,058.1	0.00	1.00
07/23/2024 11:00	1	2.2	14.0	12.5	25.7	1,022,503.5	0.00	1.00
07/23/2024 12:00	1	2.3	13.8	12.2	27.5	1,009,124.1	0.00	1.00
07/23/2024 13:00	2	2.3	12.9	12.0	28.9	1,005,219.0	0.00	1.00
07/23/2024 14:00	2	2.3	12.9	12.0	29.5	1,004,295.8	0.00	1.00
07/23/2024 15:00	2	2.2	13.2	12.1	29.9	1,013,218.4	0.00	1.00
07/23/2024 16:00	2	2.2	13.3	12.1	30.1	1,011,195.4	0.00	1.00
07/23/2024 17:00	2	2.3	13.2	12.1	30.2	1,013,218.4	0.00	1.00
07/23/2024 18:00	2	2.2	13.3	12.1	29.1	1,010,417.3	0.00	1.00
07/23/2024 19:00	1	2.2	14.1	12.3	28.7	1,026,272.1	0.00	1.00
07/23/2024 20:00	1	2.2	14.3	12.3	27.5	1,022,609.7	0.00	1.00
07/23/2024 21:00	1	2.2	14.3	12.4	27.4	1,033,512.6	0.00	1.00
07/23/2024 22:00	1	2.2	14.4	12.4	27.6	1,035,929.3	0.00	1.00
07/23/2024 23:00	1	2.1	13.5	12.6	25.0	1,033,337.9	0.00	1.00
Average/Sum#:	1	2.1	12.7	12.7	24.2	1,011,454.5	0.00 #	24.00 #
Minimum:	0	1.6	7.1	12.0	8.8	905,895.0	0.00	1.00
Maximum:	2	2.3	14.4	14.5	30.2	1,048,945.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2024 00:00	0	1.8	10.2	13.7	16.3	1,039,431.1	0.00	1.00
07/24/2024 01:00	0	1.6	8.6	14.1	7.1	869,785.9	0.00	1.00
07/24/2024 02:00	0	1.7	7.8	14.3	0.5	798,208.4	0.00	1.00
07/24/2024 03:00	-1	1.7	7.8	14.4	3.3	847,989.7	0.00	1.00
07/24/2024 04:00	1	1.9	11.1	13.6	20.3	1,005,682.8	0.00	1.00
07/24/2024 05:00	0	2.0	12.3	13.3	21.8	1,057,700.1	0.00	1.00
07/24/2024 06:00	0	1.6	8.3	14.4	7.6	880,434.5	0.00	1.00
07/24/2024 07:00	0	1.7	8.3	14.6	10.5	936,425.4	0.00	1.00
07/24/2024 08:00	0	1.6	8.5	14.5	8.5	836,846.7	0.00	1.00
07/24/2024 09:00	0	1.6	7.5	14.5	10.3	970,151.6	0.00	1.00
07/24/2024 10:00	0	1.6	8.1	14.4	11.9	976,504.9	0.00	1.00
07/24/2024 11:00	1	1.9	12.5	12.8	21.3	999,848.9	0.00	1.00
07/24/2024 12:00	1	2.0	14.7	12.4	29.2	1,033,190.4	0.00	1.00
07/24/2024 13:00	1	2.1	14.3	12.3	28.8	1,020,858.1	0.00	1.00
07/24/2024 14:00	1	2.2	13.6	12.2	28.9	1,020,929.5	0.00	1.00
07/24/2024 15:00	2	2.2	13.1	12.1	29.1	1,011,195.4	0.00	1.00
07/24/2024 16:00	1	2.2	13.0	12.2	28.4	1,020,614.7	0.00	1.00
07/24/2024 17:00	2	2.3	12.9	12.0	29.9	1,014,758.9	0.00	1.00
07/24/2024 18:00	1	2.2	13.4	12.2	29.7	1,034,623.7	0.00	1.00
07/24/2024 19:00	1	2.2	14.6	12.3	29.6	1,038,533.2	0.00	1.00
07/24/2024 20:00	1	2.2	14.9	12.4	29.5	1,048,495.8	0.00	1.00
07/24/2024 21:00	1	2.2	14.8	12.4	28.9	1,041,890.3	0.00	1.00
07/24/2024 22:00	0	1.9	11.4	13.5	19.3	1,044,833.8	0.00	1.00
07/24/2024 23:00	0	1.8	10.7	13.7	17.2	998,348.4	0.00	1.00
Average/Sum#:	1	1.9	11.4	13.3	19.5	981,136.8	0.00 #	24.00 #
Minimum:	-1	1.6	7.5	12.0	0.5	798,208.4	0.00	1.00
Maximum:	2	2.3	14.9	14.6	29.9	1,057,700.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2024 00:00	0	1.6	8.0	14.6	12.3	973,595.5	0.00	1.00
07/25/2024 01:00	0	1.6	8.2	14.5	9.8	883,064.8	0.00	1.00
07/25/2024 02:00	0	1.7	8.4	14.4	9.6	805,432.2	0.00	1.00
07/25/2024 03:00	0	1.7	8.2	14.4	9.5	805,853.6	0.00	1.00
07/25/2024 04:00	0	1.6	8.1	14.5	10.3	880,069.1	0.00	1.00
07/25/2024 05:00	0	1.6	8.1	14.6	12.2	977,508.2	0.00	1.00
07/25/2024 06:00	0	1.6	8.3	14.5	7.8	865,519.0	0.00	1.00
07/25/2024 07:00	0	1.7	8.1	14.4	9.4	806,064.3	0.00	1.00
07/25/2024 08:00	0	1.6	8.1	14.4	7.9	805,642.9	0.00	1.00
07/25/2024 09:00	-1	1.7	7.8	14.3	1.5	798,000.9	0.00	1.00
07/25/2024 10:00	-1	1.7	7.8	14.3	1.7	797,793.4	0.00	1.00
07/25/2024 11:00	0	1.7	7.6	14.3	1.6	797,171.0	0.00	1.00
07/25/2024 12:00	0	1.7	7.6	14.4	4.5	910,983.2	0.00	1.00
07/25/2024 13:00	0	1.9	11.0	13.5	17.4	1,026,883.2	0.00	1.00
07/25/2024 14:00	0	2.1	13.3	12.8	24.8	1,031,633.0	0.00	1.00
07/25/2024 15:00	1	2.1	13.6	12.8	23.7	1,038,057.5	0.00	1.00
07/25/2024 16:00	1	2.1	13.5	12.7	24.4	1,026,734.3	0.00	1.00
07/25/2024 17:00	1	2.1	14.1	12.5	26.5	1,031,959.1	0.00	1.00
07/25/2024 18:00	1	2.2	14.5	12.3	27.4	1,025,953.6	0.00	1.00
07/25/2024 19:00	1	2.2	14.3	12.4	27.0	1,031,096.0	0.00	1.00
07/25/2024 20:00	1	2.1	14.3	12.5	27.2	1,040,925.6	0.00	1.00
07/25/2024 21:00	0	1.9	10.9	13.6	16.8	1,015,812.7	0.00	1.00
07/25/2024 22:00	0	1.6	7.8	14.4	9.2	920,885.2	0.00	1.00
07/25/2024 23:00	0	1.7	8.2	14.5	9.1	818,231.1	0.00	1.00
Average/Sum#:	0	1.8	10.0	13.8	13.8	921,452.9	0.00 #	24.00 #
Minimum:	-1	1.6	7.6	12.3	1.5	797,171.0	0.00	1.00
Maximum:	1	2.2	14.5	14.6	27.4	1,040,925.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2024 00:00	0	1.6	8.3	14.5	9.9	817,375.2	0.00	1.00
07/26/2024 01:00	0	1.6	8.3	14.4	10.1	804,589.5	0.00	1.00
07/26/2024 02:00	0	1.7	8.6	14.4	9.9	805,010.9	0.00	1.00
07/26/2024 03:00	0	1.7	8.6	14.4	10.5	805,010.9	0.00	1.00
07/26/2024 04:00	0	1.7	8.5	14.4	10.5	805,432.2	0.00	1.00
07/26/2024 05:00	0	1.7	8.5	14.4	10.5	805,010.9	0.00	1.00
07/26/2024 06:00	0	1.6	8.4	14.4	10.1	803,746.8	0.00	1.00
07/26/2024 07:00	0	1.6	8.4	14.5	9.7	814,807.5	0.00	1.00
07/26/2024 08:00	0	1.6	8.4	14.5	9.0	813,951.6	0.00	1.00
07/26/2024 09:00	0	1.6	8.5	14.5	9.4	813,095.7	0.00	1.00
07/26/2024 10:00	0	1.6	8.3	14.5	6.8	812,881.8	0.00	1.00
07/26/2024 11:00	-1	1.6	8.1	14.6	4.9	825,132.5	0.00	1.00
07/26/2024 12:00	-1	1.6	7.8	14.6	1.3	826,436.7	0.00	1.00
07/26/2024 13:00	-1	1.6	7.7	14.6	2.7	826,002.0	0.00	1.00
07/26/2024 14:00	-1	1.6	7.6	14.6	2.3	828,393.1	0.00	1.00
07/26/2024 15:00	-1	1.6	7.7	14.6	2.0	828,175.7	0.00	1.00
07/26/2024 16:00	-1	1.6	7.8	14.6	2.9	827,958.3	0.00	1.00
07/26/2024 17:00	-1	1.7	8.0	14.6	4.6	852,086.3	0.00	1.00
07/26/2024 18:00	0	1.7	8.5	14.4	12.7	999,469.1	0.00	1.00
07/26/2024 19:00	0	1.6	7.7	14.5	11.2	984,701.7	0.00	1.00
07/26/2024 20:00	0	1.6	8.0	14.4	8.8	896,867.6	0.00	1.00
07/26/2024 21:00	0	1.7	8.1	14.4	10.3	804,168.1	0.00	1.00
07/26/2024 22:00	0	1.7	8.1	14.4	10.2	806,064.3	0.00	1.00
07/26/2024 23:00	0	1.7	8.1	14.3	10.2	795,303.6	0.00	1.00
Average/Sum#:	0	1.6	8.2	14.5	7.9	833,403.0	0.00 #	24.00 #
Minimum:	-1	1.6	7.6	14.3	1.3	795,303.6	0.00	1.00
Maximum:	0	1.7	8.6	14.6	12.7	999,469.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2024 00:00	0	1.7	8.2	14.3	10.0	796,133.5	0.00	1.00
07/27/2024 01:00	0	1.7	8.5	14.3	10.7	797,793.4	0.00	1.00
07/27/2024 02:00	0	1.7	8.8	14.3	10.6	798,000.9	0.00	1.00
07/27/2024 03:00	0	1.7	8.7	14.3	10.4	798,208.4	0.00	1.00
07/27/2024 04:00	0	1.7	8.7	14.3	10.6	799,038.4	0.00	1.00
07/27/2024 05:00	0	1.7	8.8	14.3	10.7	799,660.8	0.00	1.00
07/27/2024 06:00	0	1.7	8.7	14.3	11.0	799,868.3	0.00	1.00
07/27/2024 07:00	0	1.7	8.7	14.3	10.9	798,830.9	0.00	1.00
07/27/2024 08:00	0	1.7	8.5	14.3	10.8	797,793.4	0.00	1.00
07/27/2024 09:00	0	1.7	8.5	14.3	10.9	797,586.0	0.00	1.00
07/27/2024 10:00	0	1.7	8.5	14.4	10.9	809,224.5	0.00	1.00
07/27/2024 11:00	0	1.7	8.5	14.4	10.7	809,013.8	0.00	1.00
07/27/2024 12:00	0	1.7	8.4	14.4	10.3	807,749.7	0.00	1.00
07/27/2024 13:00	0	1.6	8.1	14.4	8.1	806,064.3	0.00	1.00
07/27/2024 14:00	0	1.7	8.1	14.4	6.0	805,010.9	0.00	1.00
07/27/2024 15:00	0	1.7	8.1	14.4	7.5	804,168.1	0.00	1.00
07/27/2024 16:00	0	1.7	8.1	14.4	8.8	804,589.5	0.00	1.00
07/27/2024 17:00	0	1.7	8.1	14.4	9.2	805,010.9	0.00	1.00
07/27/2024 18:00	0	1.7	8.1	14.4	9.1	806,485.6	0.00	1.00
07/27/2024 19:00	0	1.7	8.0	14.4	9.3	807,328.3	0.00	1.00
07/27/2024 20:00	0	1.7	8.1	14.3	9.9	795,511.1	0.00	1.00
07/27/2024 21:00	0	1.7	8.1	14.3	10.1	796,133.5	0.00	1.00
07/27/2024 22:00	0	1.7	8.0	14.3	9.8	796,963.5	0.00	1.00
07/27/2024 23:00	0	1.7	8.1	14.3	9.9	797,586.0	0.00	1.00
Average/Sum#:	0	1.7	8.4	14.3	9.8	801,406.4	0.00 #	24.00 #
Minimum:	0	1.6	8.0	14.3	6.0	795,511.1	0.00	1.00
Maximum:	0	1.7	8.8	14.4	11.0	809,224.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2024 00:00	0	1.7	8.1	14.3	9.8	798,000.9	0.00	1.00
07/28/2024 01:00	0	1.7	8.2	14.3	10.2	798,830.9	0.00	1.00
07/28/2024 02:00	0	1.7	8.7	14.3	10.7	799,245.9	0.00	1.00
07/28/2024 03:00	0	1.7	8.6	14.3	10.3	799,245.9	0.00	1.00
07/28/2024 04:00	0	1.7	8.6	14.3	10.7	799,453.4	0.00	1.00
07/28/2024 05:00	0	1.7	8.6	14.3	10.8	800,075.8	0.00	1.00
07/28/2024 06:00	0	1.7	8.6	14.3	11.1	800,075.8	0.00	1.00
07/28/2024 07:00	0	1.7	8.5	14.3	10.9	799,660.8	0.00	1.00
07/28/2024 08:00	0	1.7	8.4	14.3	10.5	798,623.4	0.00	1.00
07/28/2024 09:00	0	1.7	8.3	14.3	10.3	797,586.0	0.00	1.00
07/28/2024 10:00	0	1.7	8.4	14.4	9.7	808,592.4	0.00	1.00
07/28/2024 11:00	0	1.6	8.1	14.4	7.3	804,800.2	0.00	1.00
07/28/2024 12:00	0	1.7	8.0	14.4	5.8	804,168.1	0.00	1.00
07/28/2024 13:00	-1	1.6	7.6	14.4	1.4	805,432.2	0.00	1.00
07/28/2024 14:00	0	1.7	7.6	14.3	1.1	795,718.6	0.00	1.00
07/28/2024 15:00	-1	1.7	7.6	14.3	1.4	795,926.1	0.00	1.00
07/28/2024 16:00	0	1.7	7.6	14.3	1.3	795,096.1	0.00	1.00
07/28/2024 17:00	-1	1.7	7.6	14.3	3.3	815,015.0	0.00	1.00
07/28/2024 18:00	0	1.7	8.3	14.5	8.4	816,947.2	0.00	1.00
07/28/2024 19:00	0	1.6	8.0	14.4	8.6	803,957.5	0.00	1.00
07/28/2024 20:00	0	1.7	7.9	14.4	8.8	806,696.3	0.00	1.00
07/28/2024 21:00	0	1.7	8.0	14.4	9.6	808,803.1	0.00	1.00
07/28/2024 22:00	0	1.7	8.0	14.4	9.5	809,856.5	0.00	1.00
07/28/2024 23:00	0	1.7	8.0	14.4	9.7	810,488.6	0.00	1.00
Average/Sum#:	0	1.7	8.1	14.3	8.0	803,012.4	0.00 #	24.00 #
Minimum:	-1	1.6	7.6	14.3	1.1	795,096.1	0.00	1.00
Maximum:	0	1.7	8.7	14.5	11.1	816,947.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2024 00:00	0	1.7	8.1	14.3	9.9	799,868.3	0.00	1.00
07/29/2024 01:00	0	1.7	8.1	14.3	9.9	800,283.3	0.00	1.00
07/29/2024 02:00	0	1.7	8.4	14.3	9.8	800,283.3	0.00	1.00
07/29/2024 03:00	0	1.7	8.4	14.3	9.4	801,113.3	0.00	1.00
07/29/2024 04:00	0	1.7	8.4	14.3	10.5	801,528.2	0.00	1.00
07/29/2024 05:00	0	1.7	8.5	14.3	10.8	802,150.7	0.00	1.00
07/29/2024 06:00	0	1.7	8.6	14.3	11.0	801,320.8	0.00	1.00
07/29/2024 07:00	0	1.7	8.5	14.3	10.8	800,905.8	0.00	1.00
07/29/2024 08:00	0	1.7	8.4	14.3	10.6	798,830.9	0.00	1.00
07/29/2024 09:00	0	1.7	8.5	14.4	10.4	809,645.8	0.00	1.00
07/29/2024 10:00	0	1.7	8.3	14.4	9.5	809,013.8	0.00	1.00
07/29/2024 11:00	0	1.6	7.9	14.4	6.1	806,485.6	0.00	1.00
07/29/2024 12:00	-1	1.6	7.8	14.4	1.4	804,378.8	0.00	1.00
07/29/2024 13:00	-1	1.7	7.9	14.5	2.0	816,091.3	0.00	1.00
07/29/2024 14:00	-1	1.6	7.9	14.5	2.0	815,235.5	0.00	1.00
07/29/2024 15:00	-1	1.7	8.0	14.5	4.2	814,593.5	0.00	1.00
07/29/2024 16:00	0	1.6	8.0	14.5	6.6	845,405.6	0.00	1.00
07/29/2024 17:00	0	1.7	9.3	14.0	13.6	947,086.0	0.00	1.00
07/29/2024 18:00	0	2.0	12.5	13.3	21.6	1,071,935.0	0.00	1.00
07/29/2024 19:00	0	1.8	9.9	13.8	17.0	1,039,605.3	0.00	1.00
07/29/2024 20:00	0	1.8	9.7	13.8	16.9	1,037,483.6	0.00	1.00
07/29/2024 21:00	0	1.7	8.9	14.1	12.8	944,097.3	0.00	1.00
07/29/2024 22:00	0	1.7	8.1	14.3	9.3	795,718.6	0.00	1.00
07/29/2024 23:00	0	1.7	8.1	14.3	9.7	795,718.6	0.00	1.00
Average/Sum#:	0	1.7	8.6	14.2	9.8	848,282.5	0.00 #	24.00 #
Minimum:	-1	1.6	7.8	13.3	1.4	795,718.6	0.00	1.00
Maximum:	0	2.0	12.5	14.5	21.6	1,071,935.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2024 00:00	0	1.7	8.2	14.3	10.3	796,341.0	0.00	1.00
07/30/2024 01:00	0	1.7	8.3	14.3	10.5	796,341.0	0.00	1.00
07/30/2024 02:00	0	1.7	8.5	14.3	10.4	796,756.0	0.00	1.00
07/30/2024 03:00	0	1.7	8.4	14.3	10.3	796,548.5	0.00	1.00
07/30/2024 04:00	0	1.7	8.3	14.3	10.5	798,000.9	0.00	1.00
07/30/2024 05:00	0	1.7	8.2	14.4	10.7	881,277.3	0.00	1.00
07/30/2024 06:00	0	1.7	8.3	14.3	10.6	796,548.5	0.00	1.00
07/30/2024 07:00	0	1.7	8.3	14.3	10.5	796,756.0	0.00	1.00
07/30/2024 08:00	0	1.7	8.2	14.4	9.9	807,539.0	0.00	1.00
07/30/2024 09:00	0	1.7	8.1	14.4	9.8	806,485.6	0.00	1.00
07/30/2024 10:00	0	1.6	7.8	14.4	6.1	804,168.1	0.00	1.00
07/30/2024 11:00	-1	1.6	7.7	14.4	4.3	802,272.0	0.00	1.00
07/30/2024 12:00	0	1.7	7.8	14.5	6.2	818,659.0	0.00	1.00
07/30/2024 13:00	-1	1.6	7.7	14.5	1.5	813,309.7	0.00	1.00
07/30/2024 14:00	-1	1.6	7.8	14.5	2.2	812,025.9	0.00	1.00
07/30/2024 15:00	0	1.7	8.0	14.3	7.0	902,160.2	0.00	1.00
07/30/2024 16:00	0	2.0	12.0	13.1	19.8	1,023,732.5	0.00	1.00
07/30/2024 17:00	1	2.2	13.8	12.5	25.8	1,030,002.8	0.00	1.00
07/30/2024 18:00	1	2.2	14.0	12.4	26.4	1,025,940.5	0.00	1.00
07/30/2024 19:00	1	2.1	13.5	12.6	25.0	1,031,523.0	0.00	1.00
07/30/2024 20:00	1	2.0	12.6	12.8	23.2	1,028,928.0	0.00	1.00
07/30/2024 21:00	0	1.9	10.3	13.6	15.9	988,424.3	0.00	1.00
07/30/2024 22:00	0	1.7	7.8	14.3	4.4	796,133.5	0.00	1.00
07/30/2024 23:00	0	1.7	7.8	14.4	7.4	830,081.9	0.00	1.00
Average/Sum#:	0	1.8	9.2	14.0	11.6	865,831.5	0.00 #	24.00 #
Minimum:	-1	1.6	7.7	12.4	1.5	796,133.5	0.00	1.00
Maximum:	1	2.2	14.0	14.5	26.4	1,031,523.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2024 00:00	0	1.7	7.7	14.3	8.1	792,813.7	0.00	1.00
07/31/2024 01:00	0	1.7	7.7	14.3	9.4	793,228.7	0.00	1.00
07/31/2024 02:00	0	1.7	8.0	14.3	9.3	793,851.2	0.00	1.00
07/31/2024 03:00	0	1.7	8.0	14.3	8.8	802,980.7	0.00	1.00
07/31/2024 04:00	0	1.7	7.9	14.4	10.3	913,300.7	0.00	1.00
07/31/2024 05:00	0	1.6	8.2	14.4	11.8	925,520.2	0.00	1.00
07/31/2024 06:00	0	1.7	8.2	14.3	10.3	794,681.1	0.00	1.00
07/31/2024 07:00	0	1.7	8.2	14.3	10.0	794,473.6	0.00	1.00
07/31/2024 08:00	0	1.7	8.1	14.4	9.1	805,221.5	0.00	1.00
07/31/2024 09:00	0	1.6	7.8	14.4	7.1	803,325.4	0.00	1.00
07/31/2024 10:00	0	1.6	7.8	14.4	5.6	801,429.3	0.00	1.00
07/31/2024 11:00	-1	1.6	7.7	14.5	2.6	820,370.8	0.00	1.00
07/31/2024 12:00	0	1.7	7.8	14.5	6.7	842,837.9	0.00	1.00
07/31/2024 13:00	-1	1.6	7.6	14.5	1.4	812,025.9	0.00	1.00
07/31/2024 14:00	0	1.7	7.1	14.4	3.0	838,298.4	0.00	1.00
07/31/2024 15:00	0	1.7	7.7	14.3	6.9	910,044.7	0.00	1.00
07/31/2024 16:00	1	2.2	12.4	12.8	21.5	1,008,809.3	0.00	1.00
07/31/2024 17:00	1	2.0	11.8	13.0	20.0	1,016,147.6	0.00	1.00
07/31/2024 18:00	1	2.2	13.4	12.4	24.6	1,000,807.6	0.00	1.00
07/31/2024 19:00	1	1.9	11.7	13.1	20.0	1,019,167.8	0.00	1.00
07/31/2024 20:00	1	2.1	13.3	12.7	24.3	1,033,414.4	0.00	1.00
07/31/2024 21:00	1	2.1	12.7	12.8	22.9	1,023,010.7	0.00	1.00
07/31/2024 22:00	1	2.0	12.0	13.1	22.2	1,041,289.2	0.00	1.00
07/31/2024 23:00	0	1.9	10.5	13.5	16.8	982,654.5	0.00	1.00
Average/Sum#:	0	1.8	9.3	13.9	12.2	890,404.4	0.00 #	24.00 #
Minimum:	-1	1.6	7.1	12.4	1.4	792,813.7	0.00	1.00
Maximum:	1	2.2	13.4	14.5	24.6	1,041,289.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2024 00:00	0	1.6	7.5	14.4	9.1	933,947.4	0.00	1.00
08/01/2024 01:00	0	1.7	7.6	14.3	5.0	820,824.7	0.00	1.00
08/01/2024 02:00	0	1.7	7.9	14.3	7.2	799,453.4	0.00	1.00
08/01/2024 03:00	0	1.7	7.9	14.3	7.8	818,127.3	0.00	1.00
08/01/2024 04:00	0	1.7	7.8	14.4	6.3	866,318.9	0.00	1.00
08/01/2024 05:00	0	1.6	7.9	14.5	12.5	977,854.6	0.00	1.00
08/01/2024 06:00	0	1.6	8.1	14.4	7.8	823,340.1	0.00	1.00
08/01/2024 07:00	0	5.7	13.6	14.8	6.1	746,897.5	0.20	0.55
08/01/2024 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2024 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2024 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2024 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2024 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2024 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2024 14:00	0	16.9	20.9	17.3	0.0	744,053.9	0.40	0.40
08/01/2024 15:00	0	2.9	8.3	14.3	8.0	922,079.1	0.73	1.00
08/01/2024 16:00	1	2.1	14.0	12.6	24.1	1,037,957.7	0.00	1.00
08/01/2024 17:00	0	2.1	13.6	12.7	22.0	1,030,575.4	0.00	1.00
08/01/2024 18:00	1	2.1	14.3	12.5	24.8	1,034,567.5	0.00	1.00
08/01/2024 19:00	0	2.0	12.8	12.9	18.4	1,033,059.5	0.00	1.00
08/01/2024 20:00	0	2.1	14.0	12.6	22.4	1,042,247.4	0.00	1.00
08/01/2024 21:00	0	2.1	13.7	12.6	21.7	1,037,627.7	0.00	1.00
08/01/2024 22:00	0	2.0	12.4	13.0	17.6	1,044,749.5	0.00	1.00
08/01/2024 23:00	0	1.8	9.8	13.8	11.3	1,038,448.0	0.00	1.00
Average/Sum#:	0	3.0	11.2	13.9	12.9	930,673.9	1.33 #	16.95 #
Minimum:	0	1.6	7.5	12.5	0.0	744,053.9	0.00	0.00
Maximum:	1	16.9	20.9	17.3	24.8	1,044,749.5	0.73	1.00
%SI	29.17	25.00	25.00	25.00	25.00	25.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2024 00:00	0	1.5	7.8	14.4	0.8	944,481.5	0.00	1.00
08/02/2024 01:00	0	1.5	7.7	14.3	0.6	846,760.7	0.00	1.00
08/02/2024 02:00	0	1.5	7.8	14.3	0.1	800,075.8	0.00	1.00
08/02/2024 03:00	0	1.0	7.8	14.4	0.0	849,885.8	0.00	1.00
08/02/2024 04:00	0	1.3	7.8	14.6	0.0	1,004,027.2	0.00	1.00
08/02/2024 05:00	0	1.5	7.9	14.5	0.0	984,273.8	0.00	1.00
08/02/2024 06:00	0	1.4	7.8	14.5	0.0	977,426.7	0.00	1.00
08/02/2024 07:00	0	1.3	7.7	14.6	0.0	997,723.5	0.00	1.00
08/02/2024 08:00	0	1.4	7.7	14.5	0.5	993,046.7	0.00	1.00
08/02/2024 09:00	0	1.6	8.6	14.2	4.1	1,003,972.0	0.00	1.00
08/02/2024 10:00	1	2.2	13.7	12.5	20.3	1,034,078.4	0.00	1.00
08/02/2024 11:00	0	2.2	13.9	12.5	21.8	1,040,110.4	0.00	1.00
08/02/2024 12:00	1	2.2	14.0	12.4	22.2	1,027,390.5	0.00	1.00
08/02/2024 13:00	1	2.2	14.0	12.4	22.4	1,030,290.5	0.00	1.00
08/02/2024 14:00	0	2.1	13.6	12.5	20.6	1,024,459.9	0.00	1.00
08/02/2024 15:00	0	2.0	12.5	12.9	17.7	1,028,266.5	0.00	1.00
08/02/2024 16:00	0	1.9	10.1	13.6	12.3	1,021,440.5	0.00	1.00
08/02/2024 17:00	0	1.9	10.5	13.4	14.0	1,024,512.0	0.00	1.00
08/02/2024 18:00	0	1.9	12.3	13.3	19.0	1,065,448.2	0.00	1.00
08/02/2024 19:00	0	1.8	10.0	13.8	12.6	1,040,183.9	0.00	1.00
08/02/2024 20:00	0	1.8	9.9	13.8	12.3	1,039,026.6	0.00	1.00
08/02/2024 21:00	0	1.8	9.4	13.9	8.3	1,001,049.2	0.00	1.00
08/02/2024 22:00	0	1.6	7.3	14.5	0.1	979,780.4	0.00	1.00
08/02/2024 23:00	0	1.5	7.5	14.5	0.2	963,518.4	0.00	1.00
Average/Sum#:	0	1.7	9.9	13.8	8.7	988,384.5	0.00 #	24.00 #
Minimum:	0	1.0	7.3	12.4	0.0	800,075.8	0.00	1.00
Maximum:	1	2.2	14.0	14.6	22.4	1,065,448.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2024 00:00	0	1.3	7.7	14.4	0.1	905,084.2	0.00	1.00
08/03/2024 01:00	0	1.2	7.9	14.4	0.2	828,396.4	0.00	1.00
08/03/2024 02:00	0	1.1	8.2	14.4	0.0	807,328.3	0.00	1.00
08/03/2024 03:00	0	1.1	8.2	14.4	0.0	806,696.3	0.00	1.00
08/03/2024 04:00	0	1.1	8.1	14.4	0.0	806,907.0	0.00	1.00
08/03/2024 05:00	0	0.9	8.1	14.4	0.0	807,960.4	0.00	1.00
08/03/2024 06:00	0	0.9	7.9	14.4	0.0	807,749.7	0.00	1.00
08/03/2024 07:00	0	1.0	8.0	14.4	0.0	807,117.7	0.00	1.00
08/03/2024 08:00	0	1.0	8.0	14.4	0.0	806,485.6	0.00	1.00
08/03/2024 09:00	0	1.0	8.1	14.5	0.0	817,161.2	0.00	1.00
08/03/2024 10:00	0	0.8	7.9	14.5	0.0	815,877.4	0.00	1.00
08/03/2024 11:00	0	0.8	7.7	14.5	0.0	814,593.5	0.00	1.00
08/03/2024 12:00	0	0.9	7.4	14.5	0.0	814,379.6	0.00	1.00
08/03/2024 13:00	0	0.9	7.2	14.6	0.0	826,654.1	0.00	1.00
08/03/2024 14:00	0	0.8	7.2	14.6	0.0	826,219.4	0.00	1.00
08/03/2024 15:00	0	1.0	7.3	14.6	0.0	826,654.1	0.00	1.00
08/03/2024 16:00	0	1.1	7.2	14.6	0.0	826,436.7	0.00	1.00
08/03/2024 17:00	0	1.4	7.5	14.5	1.7	915,374.6	0.00	1.00
08/03/2024 18:00	1	2.3	13.7	12.4	20.3	1,008,057.5	0.00	1.00
08/03/2024 19:00	0	2.0	12.6	13.0	18.4	1,031,401.9	0.00	1.00
08/03/2024 20:00	0	1.7	9.5	13.9	7.4	938,838.2	0.00	1.00
08/03/2024 21:00	0	1.5	7.7	14.4	0.4	905,084.2	0.00	1.00
08/03/2024 22:00	0	1.5	7.9	14.6	4.0	967,509.2	0.00	1.00
08/03/2024 23:00	0	1.6	8.3	14.5	1.2	847,973.3	0.00	1.00
Average/Sum#:	0	1.2	8.3	14.3	2.2	856,914.2	0.00 #	24.00 #
Minimum:	0	0.8	7.2	12.4	0.0	806,485.6	0.00	1.00
Maximum:	1	2.3	13.7	14.6	20.3	1,031,401.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2024 00:00	0	1.5	8.2	14.5	0.0	818,231.1	0.00	1.00
08/04/2024 01:00	0	1.6	8.0	14.4	0.0	806,274.9	0.00	1.00
08/04/2024 02:00	0	1.4	8.2	14.4	0.0	806,907.0	0.00	0.95
08/04/2024 03:00	0	1.1	8.2	14.4	0.0	807,117.7	0.00	0.90
08/04/2024 04:00	0	1.1	8.2	14.4	0.0	808,171.1	0.00	1.00
08/04/2024 05:00	0	1.1	8.2	14.4	0.0	809,013.8	0.00	1.00
08/04/2024 06:00	0	1.0	8.1	14.4	0.0	809,645.8	0.00	1.00
08/04/2024 07:00	0	0.9	8.2	14.4	0.0	808,803.1	0.00	1.00
08/04/2024 08:00	0	1.0	8.1	14.4	0.0	808,171.1	0.00	1.00
08/04/2024 09:00	0	1.1	8.1	14.4	0.0	806,907.0	0.00	1.00
08/04/2024 10:00	0	1.1	8.0	14.5	0.0	818,445.0	0.00	1.00
08/04/2024 11:00	0	1.1	8.0	14.5	0.0	817,161.2	0.00	1.00
08/04/2024 12:00	0	1.0	7.8	14.5	0.0	815,877.4	0.00	1.00
08/04/2024 13:00	0	0.9	7.6	14.6	0.0	826,654.1	0.00	1.00
08/04/2024 14:00	0	0.8	7.3	14.6	0.0	826,871.5	0.00	1.00
08/04/2024 15:00	0	1.0	7.4	14.6	0.0	826,436.7	0.00	1.00
08/04/2024 16:00	0	1.0	7.4	14.6	0.0	825,784.6	0.00	1.00
08/04/2024 17:00	0	1.7	9.3	13.9	7.2	932,773.6	0.00	1.00
08/04/2024 18:00	1	2.2	14.0	12.6	21.0	1,034,822.9	0.00	1.00
08/04/2024 19:00	0	1.9	11.0	13.5	14.2	1,033,915.4	0.00	1.00
08/04/2024 20:00	0	1.9	10.0	13.7	12.9	1,032,584.0	0.00	1.00
08/04/2024 21:00	0	1.5	7.2	14.5	0.3	984,487.7	0.00	1.00
08/04/2024 22:00	0	1.5	7.4	14.4	0.2	949,537.8	0.00	1.00
08/04/2024 23:00	0	1.4	7.7	14.4	0.5	884,437.5	0.00	1.00
Average/Sum#:	0	1.3	8.4	14.3	2.3	862,459.7	0.00 #	23.85 #
Minimum:	0	0.8	7.2	12.6	0.0	806,274.9	0.00	0.90
Maximum:	1	2.2	14.0	14.6	21.0	1,034,822.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2024 00:00	0	1.0	7.8	14.3	0.2	814,600.0	0.00	1.00
08/05/2024 01:00	0	1.1	8.0	14.4	0.0	807,960.4	0.00	1.00
08/05/2024 02:00	0	1.1	8.2	14.3	0.0	796,548.5	0.00	1.00
08/05/2024 03:00	0	1.0	8.1	14.3	0.0	796,963.5	0.00	1.00
08/05/2024 04:00	0	1.1	7.8	14.5	0.0	933,134.3	0.00	1.00
08/05/2024 05:00	0	1.5	8.2	14.4	0.4	924,466.8	0.00	1.00
08/05/2024 06:00	0	0.9	8.1	14.4	0.1	866,740.3	0.00	1.00
08/05/2024 07:00	0	0.7	8.0	14.3	0.0	799,660.8	0.00	1.00
08/05/2024 08:00	0	0.7	7.9	14.4	0.1	811,120.6	0.00	1.00
08/05/2024 09:00	0	0.8	8.0	14.4	0.0	810,488.6	0.00	1.00
08/05/2024 10:00	0	0.8	8.0	14.4	0.0	809,435.2	0.00	1.00
08/05/2024 11:00	0	0.8	8.0	14.5	0.0	820,584.8	0.00	1.00
08/05/2024 12:00	0	0.9	7.5	14.5	0.0	917,300.4	0.00	1.00
08/05/2024 13:00	0	1.0	7.7	14.3	0.0	800,490.8	0.00	1.00
08/05/2024 14:00	0	1.0	7.6	14.4	0.1	876,010.2	0.00	1.00
08/05/2024 15:00	0	1.1	7.8	14.4	0.0	808,381.7	0.00	1.00
08/05/2024 16:00	0	1.3	7.8	14.4	0.0	808,381.7	0.00	1.00
08/05/2024 17:00	0	1.4	7.6	14.4	0.0	858,102.4	0.00	1.00
08/05/2024 18:00	0	2.0	11.1	13.3	14.5	969,768.7	0.00	1.00
08/05/2024 19:00	0	1.4	8.9	14.1	3.9	873,813.6	0.00	1.00
08/05/2024 20:00	0	1.3	7.8	14.5	0.2	881,353.0	0.00	1.00
08/05/2024 21:00	0	1.5	7.8	14.5	0.4	926,715.2	0.00	1.00
08/05/2024 22:00	0	1.4	7.8	14.5	0.2	927,357.1	0.00	1.00
08/05/2024 23:00	0	1.0	7.9	14.4	0.0	811,120.6	0.00	1.00
Average/Sum#:	0	1.1	8.1	14.3	0.8	852,104.1	0.00 #	24.00 #
Minimum:	0	0.7	7.5	13.3	0.0	796,548.5	0.00	1.00
Maximum:	0	2.0	11.1	14.5	14.5	969,768.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2024 00:00	0	0.9	8.0	14.4	0.0	809,013.8	0.00	1.00
08/06/2024 01:00	0	0.9	8.0	14.4	0.0	809,645.8	0.00	1.00
08/06/2024 02:00	0	0.8	8.2	14.4	0.0	809,856.5	0.00	1.00
08/06/2024 03:00	0	0.7	8.3	14.3	0.0	797,793.4	0.00	1.00
08/06/2024 04:00	0	0.6	8.2	14.3	0.0	799,038.4	0.00	1.00
08/06/2024 05:00	0	0.6	8.3	14.3	0.1	807,545.4	0.00	1.00
08/06/2024 06:00	0	0.6	8.4	14.3	0.0	812,110.2	0.00	1.00
08/06/2024 07:00	0	0.7	8.5	14.4	0.0	810,699.2	0.00	1.00
08/06/2024 08:00	0	0.8	8.5	14.4	0.0	809,224.5	0.00	1.00
08/06/2024 09:00	0	0.8	8.1	14.4	0.0	806,696.3	0.00	1.00
08/06/2024 10:00	0	0.9	8.0	14.5	0.0	817,375.2	0.00	1.00
08/06/2024 11:00	0	0.9	8.0	14.5	0.0	816,305.3	0.00	1.00
08/06/2024 12:00	0	0.8	7.9	14.5	0.0	815,021.5	0.00	1.00
08/06/2024 13:00	0	0.8	7.8	14.6	0.0	827,088.9	0.00	1.00
08/06/2024 14:00	0	0.8	7.6	14.6	0.0	826,219.4	0.00	1.00
08/06/2024 15:00	0	1.1	7.8	14.6	0.0	825,784.6	0.00	1.00
08/06/2024 16:00	0	1.2	7.6	14.6	0.0	867,954.2	0.00	1.00
08/06/2024 17:00	0	1.6	8.1	14.3	2.0	900,707.8	0.00	1.00
08/06/2024 18:00	0	2.2	14.0	12.6	21.9	1,026,573.3	0.00	1.00
08/06/2024 19:00	0	1.8	10.5	13.7	13.4	1,030,872.2	0.00	1.00
08/06/2024 20:00	0	1.6	9.2	14.1	7.3	945,909.8	0.00	1.00
08/06/2024 21:00	0	1.5	7.4	14.5	0.0	983,203.9	0.00	1.00
08/06/2024 22:00	0	1.5	7.7	14.5	0.5	957,099.3	0.00	1.00
08/06/2024 23:00	0	1.4	8.0	14.4	0.3	864,001.4	0.00	1.00
Average/Sum#:	0	1.1	8.4	14.3	1.9	857,322.5	0.00 #	24.00 #
Minimum:	0	0.6	7.4	12.6	0.0	797,793.4	0.00	1.00
Maximum:	0	2.2	14.0	14.6	21.9	1,030,872.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2024 00:00	0	1.5	8.2	14.5	0.2	819,728.9	0.00	1.00
08/07/2024 01:00	0	1.2	8.3	14.5	0.0	818,231.1	0.00	1.00
08/07/2024 02:00	0	1.1	8.6	14.5	0.0	818,659.0	0.00	1.00
08/07/2024 03:00	0	1.2	8.5	14.4	0.0	807,539.0	0.00	1.00
08/07/2024 04:00	0	1.2	8.5	14.4	0.0	808,171.1	0.00	1.00
08/07/2024 05:00	0	1.2	8.4	14.4	0.0	813,648.8	0.00	1.00
08/07/2024 06:00	0	1.3	8.4	14.4	0.3	851,360.6	0.00	1.00
08/07/2024 07:00	0	1.1	8.2	14.4	0.0	807,539.0	0.00	1.00
08/07/2024 08:00	0	1.2	8.3	14.5	0.0	818,873.0	0.00	1.00
08/07/2024 09:00	0	1.4	8.2	14.5	0.0	817,161.2	0.00	1.00
08/07/2024 10:00	0	1.4	8.1	14.5	0.0	816,519.3	0.00	1.00
08/07/2024 11:00	0	1.2	7.8	14.5	0.0	815,877.4	0.00	1.00
08/07/2024 12:00	0	1.1	7.7	14.5	0.0	814,807.5	0.00	1.00
08/07/2024 13:00	0	1.1	7.8	14.6	0.0	826,002.0	0.00	1.00
08/07/2024 14:00	0	1.2	7.8	14.6	0.0	825,349.9	0.00	1.00
08/07/2024 15:00	0	1.5	8.0	14.7	0.4	838,220.2	0.00	1.00
08/07/2024 16:00	0	1.5	7.9	14.6	0.1	824,263.1	0.00	1.00
08/07/2024 17:00	0	1.4	7.7	14.6	0.0	872,736.3	0.00	1.00
08/07/2024 18:00	0	1.5	8.0	14.4	0.3	862,105.3	0.00	1.00
08/07/2024 19:00	0	1.4	7.6	14.4	0.3	889,915.2	0.00	1.00
08/07/2024 20:00	0	1.2	7.7	14.3	0.1	831,199.1	0.00	1.00
08/07/2024 21:00	0	1.1	7.8	14.3	0.0	807,130.4	0.00	1.00
08/07/2024 22:00	0	1.0	7.9	14.3	0.1	807,130.4	0.00	1.00
08/07/2024 23:00	0	1.1	8.0	14.3	0.0	798,415.9	0.00	1.00
Average/Sum#:	0	1.3	8.1	14.5	0.1	825,441.0	0.00 #	24.00 #
Minimum:	0	1.0	7.6	14.3	0.0	798,415.9	0.00	1.00
Maximum:	0	1.5	8.6	14.7	0.4	889,915.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2024 00:00	0	1.2	7.9	14.3	0.0	798,623.4	0.00	1.00
08/08/2024 01:00	0	1.3	8.0	14.3	0.0	799,245.9	0.00	1.00
08/08/2024 02:00	0	1.5	8.3	14.3	0.0	799,245.9	0.00	1.00
08/08/2024 03:00	0	1.5	8.5	14.3	0.2	800,075.8	0.00	1.00
08/08/2024 04:00	0	1.1	8.8	14.4	0.0	810,067.2	0.00	1.00
08/08/2024 05:00	0	1.1	8.7	14.4	0.0	815,123.5	0.00	1.00
08/08/2024 06:00	0	1.1	8.3	14.4	0.3	850,517.9	0.00	1.00
08/08/2024 07:00	0	0.9	8.2	14.4	0.0	808,171.1	0.00	1.00
08/08/2024 08:00	0	0.8	8.2	14.4	0.0	807,539.0	0.00	1.00
08/08/2024 09:00	0	0.9	8.1	14.4	0.0	806,485.6	0.00	1.00
08/08/2024 10:00	0	0.9	8.1	14.4	0.0	805,853.6	0.00	1.00
08/08/2024 11:00	0	0.8	7.9	14.5	0.0	818,659.0	0.00	1.00
08/08/2024 12:00	0	0.9	7.9	14.5	0.0	816,091.3	0.00	1.00
08/08/2024 13:00	0	0.9	7.7	14.5	0.0	815,021.5	0.00	1.00
08/08/2024 14:00	0	0.8	7.6	14.5	0.0	814,165.6	0.00	1.00
08/08/2024 15:00	0	0.9	7.6	14.6	0.0	827,088.9	0.00	1.00
08/08/2024 16:00	0	1.1	7.5	14.6	0.0	825,784.6	0.00	1.00
08/08/2024 17:00	0	1.3	7.7	14.6	0.0	831,218.9	0.00	1.00
08/08/2024 18:00	0	1.1	7.8	14.5	0.0	825,292.2	0.00	1.00
08/08/2024 19:00	0	1.0	7.9	14.5	0.0	816,091.3	0.00	1.00
08/08/2024 20:00	0	1.1	7.9	14.5	0.1	857,388.0	0.00	1.00
08/08/2024 21:00	0	1.0	7.9	14.5	0.1	849,685.0	0.00	1.00
08/08/2024 22:00	0	1.0	8.0	14.4	0.0	806,696.3	0.00	1.00
08/08/2024 23:00	0	0.9	8.0	14.4	0.0	807,539.0	0.00	1.00
Average/Sum#:	0	1.0	8.0	14.4	0.0	817,152.9	0.00 #	24.00 #
Minimum:	0	0.8	7.5	14.3	0.0	798,623.4	0.00	1.00
Maximum:	0	1.5	8.8	14.6	0.3	857,388.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2024 00:00	0	1.0	8.1	14.4	0.0	808,381.7	0.00	1.00
08/09/2024 01:00	0	0.9	8.1	14.4	0.0	809,013.8	0.00	1.00
08/09/2024 02:00	0	0.9	8.2	14.4	0.0	808,803.1	0.00	1.00
08/09/2024 03:00	0	0.8	8.3	14.4	0.0	809,645.8	0.00	1.00
08/09/2024 04:00	0	0.8	8.2	14.3	0.0	797,586.0	0.00	1.00
08/09/2024 05:00	0	0.9	8.2	14.3	0.0	802,358.2	0.00	1.00
08/09/2024 06:00	0	1.0	8.2	14.4	0.1	897,921.0	0.00	1.00
08/09/2024 07:00	0	0.9	8.5	14.3	0.0	798,623.4	0.00	1.00
08/09/2024 08:00	0	1.1	8.4	14.4	0.0	809,224.5	0.00	1.00
08/09/2024 09:00	0	1.1	8.1	14.4	0.0	806,696.3	0.00	1.00
08/09/2024 10:00	0	1.1	8.1	14.4	0.0	805,010.9	0.00	1.00
08/09/2024 11:00	0	1.0	8.0	14.5	0.0	817,589.2	0.00	1.00
08/09/2024 12:00	0	0.9	7.9	14.5	0.0	816,091.3	0.00	1.00
08/09/2024 13:00	0	0.9	7.7	14.5	0.0	813,737.6	0.00	1.00
08/09/2024 14:00	0	0.9	7.6	14.6	0.0	826,002.0	0.00	1.00
08/09/2024 15:00	0	0.9	7.5	14.6	0.0	825,132.5	0.00	1.00
08/09/2024 16:00	0	0.9	7.6	14.6	0.0	824,915.2	0.00	1.00
08/09/2024 17:00	0	1.0	7.6	14.4	0.0	840,194.5	0.00	1.00
08/09/2024 18:00	0	1.1	7.8	14.4	0.0	824,814.8	0.00	1.00
08/09/2024 19:00	0	1.1	7.7	14.3	0.0	796,756.0	0.00	1.00
08/09/2024 20:00	0	1.3	7.8	14.4	0.0	808,592.4	0.00	1.00
08/09/2024 21:00	0	1.5	8.2	14.5	0.0	818,445.0	0.00	1.00
08/09/2024 22:00	0	1.4	8.3	14.4	0.0	806,907.0	0.00	1.00
08/09/2024 23:00	0	1.2	8.4	14.4	0.0	807,328.3	0.00	1.00
Average/Sum#:	0	1.0	8.0	14.4	0.0	815,823.8	0.00 #	24.00 #
Minimum:	0	0.8	7.5	14.3	0.0	796,756.0	0.00	1.00
Maximum:	0	1.5	8.5	14.6	0.1	897,921.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2024 00:00	0	1.1	8.3	14.4	0.0	809,013.8	0.00	1.00
08/10/2024 01:00	0	1.1	8.3	14.4	0.0	809,645.8	0.00	1.00
08/10/2024 02:00	0	1.0	8.5	14.4	0.0	810,067.2	0.00	1.00
08/10/2024 03:00	0	0.7	8.4	14.3	0.0	796,963.5	0.00	1.00
08/10/2024 04:00	0	0.6	8.3	14.3	0.0	796,963.5	0.00	1.00
08/10/2024 05:00	0	0.7	8.3	14.3	0.0	797,378.5	0.00	1.00
08/10/2024 06:00	0	0.7	8.3	14.4	0.0	810,699.2	0.00	1.00
08/10/2024 07:00	0	0.8	8.3	14.4	0.0	810,699.2	0.00	1.00
08/10/2024 08:00	0	0.8	8.1	14.4	0.0	809,013.8	0.00	1.00
08/10/2024 09:00	0	0.8	8.1	14.4	0.0	808,171.1	0.00	1.00
08/10/2024 10:00	0	0.9	8.1	14.4	0.0	808,592.4	0.00	1.00
08/10/2024 11:00	0	0.8	8.1	14.5	0.0	821,226.7	0.00	1.00
08/10/2024 12:00	0	0.7	8.0	14.5	0.0	819,087.0	0.00	1.00
08/10/2024 13:00	0	0.9	7.9	14.5	0.0	843,907.8	0.00	1.00
08/10/2024 14:00	0	1.0	8.0	14.5	0.0	815,449.4	0.00	1.00
08/10/2024 15:00	0	1.2	7.8	14.6	0.0	827,958.3	0.00	1.00
08/10/2024 16:00	0	1.4	7.6	14.6	0.0	827,741.0	0.00	1.00
08/10/2024 17:00	0	1.4	7.2	14.5	0.0	863,593.3	0.00	1.00
08/10/2024 18:00	0	1.0	7.7	14.4	0.0	805,853.6	0.00	1.00
08/10/2024 19:00	0	1.0	7.9	14.5	0.0	816,733.3	0.00	1.00
08/10/2024 20:00	0	1.0	7.9	14.5	0.0	818,231.1	0.00	1.00
08/10/2024 21:00	0	1.0	7.9	14.5	0.0	817,803.1	0.00	1.00
08/10/2024 22:00	0	1.1	8.0	14.4	0.0	805,432.2	0.00	1.00
08/10/2024 23:00	0	1.2	8.0	14.4	0.0	806,696.3	0.00	1.00
Average/Sum#:	0	1.0	8.0	14.4	0.0	814,871.7	0.00 #	24.00 #
Minimum:	0	0.6	7.2	14.3	0.0	796,963.5	0.00	1.00
Maximum:	0	1.4	8.5	14.6	0.0	863,593.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2024 00:00	0	1.2	8.2	14.4	0.0	807,539.0	0.00	1.00
08/11/2024 01:00	0	1.2	8.2	14.4	0.0	807,749.7	0.00	1.00
08/11/2024 02:00	0	1.3	8.4	14.4	0.0	809,013.8	0.00	1.00
08/11/2024 03:00	0	1.3	8.4	14.4	0.0	809,435.2	0.00	1.00
08/11/2024 04:00	0	1.3	8.3	14.4	0.0	809,645.8	0.00	1.00
08/11/2024 05:00	0	1.2	8.2	14.4	0.0	810,067.2	0.00	1.00
08/11/2024 06:00	0	1.1	8.2	14.4	0.0	810,277.9	0.00	1.00
08/11/2024 07:00	0	1.0	8.1	14.4	0.0	810,067.2	0.00	1.00
08/11/2024 08:00	0	1.0	8.1	14.4	0.0	808,592.4	0.00	1.00
08/11/2024 09:00	0	1.2	8.0	14.4	0.0	807,749.7	0.00	1.00
08/11/2024 10:00	0	1.3	8.0	14.4	0.0	805,853.6	0.00	1.00
08/11/2024 11:00	0	1.3	8.0	14.5	0.0	816,947.2	0.00	1.00
08/11/2024 12:00	0	1.2	7.6	14.5	0.0	904,462.0	0.00	1.00
08/11/2024 13:00	0	1.5	7.3	14.5	0.0	1,002,889.4	0.00	1.00
08/11/2024 14:00	0	1.6	7.4	14.5	0.0	1,004,601.2	0.00	1.00
08/11/2024 15:00	0	1.5	7.4	14.5	0.0	999,465.8	0.00	1.00
08/11/2024 16:00	0	1.5	7.3	14.5	0.0	984,273.8	0.00	1.00
08/11/2024 17:00	0	1.4	7.5	14.5	0.1	938,483.6	0.00	1.00
08/11/2024 18:00	0	1.7	8.0	14.3	2.8	983,495.7	0.00	1.00
08/11/2024 19:00	0	1.9	10.5	13.7	11.7	1,034,105.6	0.00	1.00
08/11/2024 20:00	0	2.0	11.9	13.1	16.5	1,038,655.7	0.00	1.00
08/11/2024 21:00	0	1.7	9.4	13.9	8.8	999,679.8	0.00	1.00
08/11/2024 22:00	0	1.2	8.3	14.3	0.3	800,283.3	0.00	1.00
08/11/2024 23:00	0	1.2	8.3	14.4	0.0	811,963.3	0.00	1.00
Average/Sum#:	0	1.4	8.3	14.3	1.7	883,970.7	0.00 #	24.00 #
Minimum:	0	1.0	7.3	13.1	0.0	800,283.3	0.00	1.00
Maximum:	0	2.0	11.9	14.5	16.5	1,038,655.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2024 00:00	0	1.3	8.3	14.3	0.0	800,490.8	0.00	1.00
08/12/2024 01:00	0	1.5	8.4	14.3	0.0	801,113.3	0.00	1.00
08/12/2024 02:00	0	1.4	8.7	14.3	0.0	801,735.7	0.00	1.00
08/12/2024 03:00	0	1.0	8.6	14.3	0.1	802,150.7	0.00	1.00
08/12/2024 04:00	0	1.1	8.4	14.3	0.0	838,668.7	0.00	1.00
08/12/2024 05:00	0	1.0	8.5	14.4	0.5	885,069.5	0.00	1.00
08/12/2024 06:00	0	0.9	8.5	14.3	0.0	802,358.2	0.00	1.00
08/12/2024 07:00	0	0.9	8.5	14.3	0.0	802,150.7	0.00	1.00
08/12/2024 08:00	0	1.0	8.4	14.4	0.0	813,227.4	0.00	1.00
08/12/2024 09:00	0	1.2	8.3	14.4	0.0	812,174.0	0.00	1.00
08/12/2024 10:00	0	1.2	8.1	14.4	0.0	809,435.2	0.00	1.00
08/12/2024 11:00	0	1.2	7.8	14.4	0.0	807,328.3	0.00	1.00
08/12/2024 12:00	0	1.3	7.9	14.5	0.0	818,017.1	0.00	1.00
08/12/2024 13:00	0	1.2	7.9	14.5	0.0	816,947.2	0.00	1.00
08/12/2024 14:00	0	1.0	7.8	14.5	0.0	816,519.3	0.00	1.00
08/12/2024 15:00	0	1.1	7.9	14.5	0.0	816,947.2	0.00	1.00
08/12/2024 16:00	0	1.1	7.8	14.5	0.0	816,519.3	0.00	1.00
08/12/2024 17:00	0	1.2	7.9	14.3	0.4	904,442.6	0.00	1.00
08/12/2024 18:00	0	1.9	10.4	13.7	11.6	1,032,013.4	0.00	1.00
08/12/2024 19:00	0	1.7	10.0	14.0	10.5	999,679.8	0.00	1.00
08/12/2024 20:00	0	1.3	8.4	14.5	0.6	846,047.5	0.00	1.00
08/12/2024 21:00	0	1.1	8.3	14.4	0.0	806,485.6	0.00	1.00
08/12/2024 22:00	0	1.1	8.3	14.4	0.0	807,539.0	0.00	1.00
08/12/2024 23:00	0	1.0	8.3	14.4	0.0	808,171.1	0.00	1.00
Average/Sum#:	0	1.2	8.4	14.3	1.0	836,051.3	0.00 #	24.00 #
Minimum:	0	0.9	7.8	13.7	0.0	800,490.8	0.00	1.00
Maximum:	0	1.9	10.4	14.5	11.6	1,032,013.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2024 00:00	0	0.9	8.4	14.4	0.0	807,960.4	0.00	1.00
08/13/2024 01:00	0	0.9	8.3	14.4	0.0	807,960.4	0.00	1.00
08/13/2024 02:00	0	0.9	8.7	14.4	0.0	808,803.1	0.00	1.00
08/13/2024 03:00	0	0.9	8.6	14.4	0.0	809,435.2	0.00	1.00
08/13/2024 04:00	0	0.9	8.5	14.4	0.0	809,224.5	0.00	1.00
08/13/2024 05:00	0	0.9	8.5	14.4	0.0	814,912.8	0.00	1.00
08/13/2024 06:00	0	0.9	8.3	14.3	0.0	798,208.4	0.00	1.00
08/13/2024 07:00	0	1.1	8.2	14.4	0.0	809,435.2	0.00	1.00
08/13/2024 08:00	0	1.3	8.1	14.4	0.0	808,592.4	0.00	1.00
08/13/2024 09:00	0	1.4	8.5	14.4	0.0	807,749.7	0.00	1.00
08/13/2024 10:00	0	1.4	8.3	14.4	0.0	806,907.0	0.00	1.00
08/13/2024 11:00	0	1.3	8.1	14.4	0.0	805,642.9	0.00	1.00
08/13/2024 12:00	0	1.1	8.2	14.5	0.0	817,161.2	0.00	1.00
08/13/2024 13:00	0	1.0	8.3	14.5	0.0	817,161.2	0.00	1.00
08/13/2024 14:00	0	1.2	8.2	14.5	0.0	816,519.3	0.00	1.00
08/13/2024 15:00	0	1.4	8.2	14.5	0.0	816,091.3	0.00	1.00
08/13/2024 16:00	0	1.5	8.1	14.5	0.1	815,877.4	0.00	1.00
08/13/2024 17:00	0	1.7	9.5	13.8	7.4	939,888.0	0.00	1.00
08/13/2024 18:00	0	1.9	11.4	13.7	14.4	1,084,127.6	0.00	1.00
08/13/2024 19:00	0	1.6	9.1	14.1	6.4	941,680.6	0.00	1.00
08/13/2024 20:00	0	1.0	7.8	14.4	0.0	814,280.8	0.00	1.00
08/13/2024 21:00	0	1.1	8.2	14.4	0.1	818,283.7	0.00	1.00
08/13/2024 22:00	0	1.2	8.1	14.4	0.0	806,274.9	0.00	1.00
08/13/2024 23:00	0	1.3	8.1	14.4	0.0	806,696.3	0.00	1.00
Average/Sum#:	0	1.2	8.5	14.4	1.2	832,869.8	0.00 #	24.00 #
Minimum:	0	0.9	7.8	13.7	0.0	798,208.4	0.00	1.00
Maximum:	0	1.9	11.4	14.5	14.4	1,084,127.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2024 00:00	0	1.5	8.2	14.4	0.0	807,539.0	0.00	1.00
08/14/2024 01:00	0	1.6	8.2	14.4	0.0	808,803.1	0.00	1.00
08/14/2024 02:00	0	1.1	8.4	14.4	0.0	809,645.8	0.00	1.00
08/14/2024 03:00	0	0.9	8.3	14.4	0.0	810,067.2	0.00	1.00
08/14/2024 04:00	0	0.9	8.3	14.3	0.0	798,623.4	0.00	1.00
08/14/2024 05:00	0	0.9	8.3	14.3	0.0	797,586.0	0.00	1.00
08/14/2024 06:00	0	0.9	8.3	14.3	0.0	798,000.9	0.00	1.00
08/14/2024 07:00	0	0.9	8.2	14.4	0.0	809,856.5	0.00	1.00
08/14/2024 08:00	0	1.0	8.1	14.4	0.0	809,013.8	0.00	1.00
08/14/2024 09:00	0	1.1	8.2	14.4	0.0	807,328.3	0.00	1.00
08/14/2024 10:00	0	1.1	8.1	14.4	0.0	806,696.3	0.00	1.00
08/14/2024 11:00	0	1.0	8.1	14.5	0.0	818,017.1	0.00	1.00
08/14/2024 12:00	0	0.9	8.1	14.5	0.0	816,947.2	0.00	1.00
08/14/2024 13:00	0	1.1	8.1	14.5	0.0	815,235.5	0.00	1.00
08/14/2024 14:00	0	1.1	8.1	14.5	0.0	814,593.5	0.00	1.00
08/14/2024 15:00	0	1.3	8.0	14.5	0.0	813,737.6	0.00	1.00
08/14/2024 16:00	0	1.3	7.8	14.5	0.0	822,724.5	0.00	1.00
08/14/2024 17:00	0	1.9	10.8	13.5	11.1	1,010,228.1	0.00	1.00
08/14/2024 18:00	1	2.0	14.2	12.4	23.3	1,032,546.0	0.00	1.00
08/14/2024 19:00	1	1.9	14.3	12.4	25.1	1,038,184.8	0.00	1.00
08/14/2024 20:00	0	1.6	10.8	13.5	12.5	988,021.2	0.00	1.00
08/14/2024 21:00	-1	1.4	8.1	14.6	1.2	965,987.6	0.00	1.00
08/14/2024 22:00	0	1.1	8.1	14.4	0.0	817,441.0	0.00	1.00
08/14/2024 23:00	0	1.3	8.1	14.5	0.7	943,191.0	0.00	1.00
Average/Sum#:	0	1.2	8.9	14.2	3.1	856,667.3	0.00 #	24.00 #
Minimum:	-1	0.9	7.8	12.4	0.0	797,586.0	0.00	1.00
Maximum:	1	2.0	14.3	14.6	25.1	1,038,184.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2024 00:00	0	0.9	8.2	14.4	0.0	807,117.7	0.00	1.00
08/15/2024 01:00	0	0.8	8.1	14.4	0.0	807,960.4	0.00	1.00
08/15/2024 02:00	0	0.8	8.3	14.4	0.0	809,224.5	0.00	1.00
08/15/2024 03:00	0	0.7	8.3	14.3	0.0	796,963.5	0.00	1.00
08/15/2024 04:00	0	0.7	8.1	14.4	0.0	844,618.8	0.00	1.00
08/15/2024 05:00	0	1.0	8.5	14.4	0.3	892,864.7	0.00	1.00
08/15/2024 06:00	0	0.9	8.5	14.3	0.0	798,208.4	0.00	1.00
08/15/2024 07:00	0	1.1	8.5	14.4	0.0	810,488.6	0.00	1.00
08/15/2024 08:00	0	1.0	8.2	14.4	0.2	808,381.7	0.00	1.00
08/15/2024 09:00	0	1.0	8.1	14.4	0.0	806,485.6	0.00	1.00
08/15/2024 10:00	0	1.2	8.1	14.4	0.0	805,642.9	0.00	1.00
08/15/2024 11:00	0	1.1	8.0	14.4	0.0	803,746.8	0.00	1.00
08/15/2024 12:00	0	1.0	8.0	14.5	0.0	813,951.6	0.00	1.00
08/15/2024 13:00	0	1.0	8.0	14.5	0.0	812,025.9	0.00	1.00
08/15/2024 14:00	0	1.0	8.1	14.5	0.0	810,742.0	0.00	1.00
08/15/2024 15:00	0	1.3	8.5	14.3	2.6	890,125.8	0.00	1.00
08/15/2024 16:00	0	1.7	11.0	13.6	14.2	1,025,567.5	0.00	1.00
08/15/2024 17:00	0	1.8	12.7	13.0	19.5	1,030,188.5	0.00	1.00
08/15/2024 18:00	0	1.8	14.0	12.6	23.2	1,032,678.0	0.00	1.00
08/15/2024 19:00	0	1.8	12.8	12.9	18.8	1,031,005.4	0.00	1.00
08/15/2024 20:00	0	1.4	9.1	14.0	6.7	919,499.0	0.00	1.00
08/15/2024 21:00	0	0.9	7.6	14.3	0.0	794,058.7	0.00	1.00
08/15/2024 22:00	0	1.1	7.9	14.4	0.0	805,010.9	0.00	1.00
08/15/2024 23:00	0	1.1	8.0	14.4	0.2	815,544.9	0.00	1.00
Average/Sum#:	0	1.1	8.9	14.2	3.6	857,170.9	0.00 #	24.00 #
Minimum:	0	0.7	7.6	12.6	0.0	794,058.7	0.00	1.00
Maximum:	0	1.8	14.0	14.5	23.2	1,032,678.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2024 00:00	0	1.0	8.1	14.4	0.0	806,485.6	0.00	1.00
08/16/2024 01:00	0	1.0	8.1	14.4	0.0	806,696.3	0.00	1.00
08/16/2024 02:00	0	0.9	8.4	14.4	0.0	807,960.4	0.00	1.00
08/16/2024 03:00	0	0.8	8.2	14.3	0.0	796,133.5	0.00	1.00
08/16/2024 04:00	0	0.8	8.0	14.4	0.0	876,010.2	0.00	1.00
08/16/2024 05:00	0	1.0	8.4	14.4	0.2	903,820.1	0.00	1.00
08/16/2024 06:00	0	1.0	8.4	14.3	0.0	798,208.4	0.00	1.00
08/16/2024 07:00	0	1.1	8.4	14.4	0.0	810,067.2	0.00	1.00
08/16/2024 08:00	0	1.1	8.1	14.4	0.1	807,749.7	0.00	1.00
08/16/2024 09:00	0	1.1	8.0	14.4	0.0	805,221.5	0.00	1.00
08/16/2024 10:00	0	1.2	8.0	14.4	0.0	803,536.1	0.00	1.00
08/16/2024 11:00	0	1.1	8.0	14.5	0.0	814,593.5	0.00	1.00
08/16/2024 12:00	0	1.1	8.0	14.5	0.0	813,309.7	0.00	1.00
08/16/2024 13:00	0	1.0	7.9	14.5	0.0	821,440.7	0.00	1.00
08/16/2024 14:00	0	1.0	7.9	14.5	0.0	812,025.9	0.00	1.00
08/16/2024 15:00	0	1.1	7.8	14.5	0.0	811,597.9	0.00	1.00
08/16/2024 16:00	0	1.2	7.8	14.5	0.0	810,956.0	0.00	1.00
08/16/2024 17:00	0	1.3	7.8	14.5	0.0	816,305.3	0.00	1.00
08/16/2024 18:00	0	1.1	7.9	14.5	0.0	813,309.7	0.00	1.00
08/16/2024 19:00	0	1.0	7.7	14.4	0.0	806,696.3	0.00	1.00
08/16/2024 20:00	0	1.2	7.9	14.4	0.0	804,168.1	0.00	1.00
08/16/2024 21:00	0	1.4	7.4	14.5	0.6	979,994.3	0.00	1.00
08/16/2024 22:00	0	1.4	8.0	14.4	0.6	940,267.9	0.00	1.00
08/16/2024 23:00	0	1.2	7.9	14.5	0.6	935,488.0	0.00	1.00
Average/Sum#:	0	1.1	8.0	14.4	0.1	833,418.4	0.00 #	24.00 #
Minimum:	0	0.8	7.4	14.3	0.0	796,133.5	0.00	1.00
Maximum:	0	1.4	8.4	14.5	0.6	979,994.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2024 00:00	0	1.2	8.2	14.4	0.6	883,173.4	0.00	1.00
08/17/2024 01:00	0	0.9	7.9	14.4	0.0	805,853.6	0.00	1.00
08/17/2024 02:00	0	0.8	8.2	14.4	0.0	806,485.6	0.00	1.00
08/17/2024 03:00	0	0.7	8.1	14.3	0.0	794,888.6	0.00	1.00
08/17/2024 04:00	0	0.6	8.1	14.3	0.0	796,341.0	0.00	1.00
08/17/2024 05:00	0	0.7	8.1	14.4	0.1	884,648.2	0.00	1.00
08/17/2024 06:00	0	0.7	7.9	14.3	0.0	795,303.6	0.00	1.00
08/17/2024 07:00	0	0.7	7.9	14.3	0.0	795,303.6	0.00	1.00
08/17/2024 08:00	0	0.7	7.8	14.4	0.0	806,907.0	0.00	1.00
08/17/2024 09:00	0	0.9	7.8	14.4	0.0	805,642.9	0.00	1.00
08/17/2024 10:00	0	1.0	7.7	14.4	0.0	803,746.8	0.00	1.00
08/17/2024 11:00	0	0.9	7.7	14.4	0.0	802,272.0	0.00	1.00
08/17/2024 12:00	0	0.9	7.7	14.4	0.0	801,850.6	0.00	1.00
08/17/2024 13:00	0	0.9	7.7	14.4	0.0	801,218.6	0.00	1.00
08/17/2024 14:00	0	0.7	7.7	14.4	0.0	802,272.0	0.00	1.00
08/17/2024 15:00	0	0.7	7.7	14.4	0.0	802,482.7	0.00	1.00
08/17/2024 16:00	0	0.8	7.6	14.4	0.0	802,272.0	0.00	1.00
08/17/2024 17:00	0	0.9	7.5	14.4	0.0	812,806.0	0.00	1.00
08/17/2024 18:00	0	0.8	7.7	14.4	0.0	804,589.5	0.00	1.00
08/17/2024 19:00	0	0.8	7.6	14.4	0.0	805,010.9	0.00	1.00
08/17/2024 20:00	0	0.8	7.7	14.3	0.0	793,021.2	0.00	1.00
08/17/2024 21:00	0	0.9	7.7	14.3	0.0	793,436.2	0.00	1.00
08/17/2024 22:00	0	1.1	7.8	14.3	0.0	794,058.7	0.00	1.00
08/17/2024 23:00	0	1.2	7.8	14.3	0.0	794,473.6	0.00	1.00
Average/Sum#:	0	0.8	7.8	14.4	0.0	807,835.8	0.00 #	24.00 #
Minimum:	0	0.6	7.5	14.3	0.0	793,021.2	0.00	1.00
Maximum:	0	1.2	8.2	14.4	0.6	884,648.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2024 00:00	0	1.3	7.8	14.3	0.0	795,718.6	0.00	1.00
08/18/2024 01:00	0	1.3	7.9	14.3	0.0	796,133.5	0.00	1.00
08/18/2024 02:00	0	1.5	8.1	14.3	0.0	796,133.5	0.00	1.00
08/18/2024 03:00	0	1.6	8.0	14.3	0.0	796,548.5	0.00	1.00
08/18/2024 04:00	0	1.6	7.9	14.3	0.0	797,378.5	0.00	1.00
08/18/2024 05:00	0	1.6	7.9	14.3	0.0	797,793.4	0.00	1.00
08/18/2024 06:00	0	1.5	7.9	14.3	0.0	797,171.0	0.00	1.00
08/18/2024 07:00	0	1.4	8.0	14.3	0.0	796,963.5	0.00	1.00
08/18/2024 08:00	0	1.2	8.0	14.3	0.0	796,548.5	0.00	1.00
08/18/2024 09:00	0	1.1	7.9	14.4	0.0	807,117.7	0.00	1.00
08/18/2024 10:00	0	1.0	8.0	14.4	0.0	805,642.9	0.00	1.00
08/18/2024 11:00	0	1.0	8.1	14.4	0.0	804,168.1	0.00	1.00
08/18/2024 12:00	0	1.1	8.2	14.5	0.0	815,877.4	0.00	1.00
08/18/2024 13:00	0	0.9	8.2	14.5	0.1	815,663.4	0.00	1.00
08/18/2024 14:00	0	0.9	8.3	14.5	0.0	815,021.5	0.00	1.00
08/18/2024 15:00	0	1.2	8.3	14.5	0.0	814,593.5	0.00	1.00
08/18/2024 16:00	0	1.4	8.3	14.5	0.0	831,711.3	0.00	1.00
08/18/2024 17:00	0	1.5	8.4	14.5	0.3	830,641.5	0.00	1.00
08/18/2024 18:00	0	1.4	8.5	14.5	0.3	815,663.4	0.00	1.00
08/18/2024 19:00	0	1.6	8.3	14.5	0.0	817,161.2	0.00	1.00
08/18/2024 20:00	0	1.2	8.3	14.4	0.0	806,696.3	0.00	0.87
08/18/2024 21:00	0	1.1	8.3	14.4	0.2	811,752.6	0.00	0.97
08/18/2024 22:00	0	1.1	8.3	14.4	0.0	806,485.6	0.00	0.68
08/18/2024 23:00	0	1.0	8.4	14.4	0.2	816,809.0	0.00	1.00
Average/Sum#:	0	1.3	8.1	14.4	0.0	807,724.8	0.00 #	23.52 #
Minimum:	0	0.9	7.8	14.3	0.0	795,718.6	0.00	0.68
Maximum:	0	1.6	8.5	14.5	0.3	831,711.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2024 00:00	0	0.9	8.3	14.4	0.1	808,592.4	0.00	1.00
08/19/2024 01:00	0	0.9	8.3	14.4	0.0	808,381.7	0.00	1.00
08/19/2024 02:00	0	0.9	8.4	14.4	0.0	808,803.1	0.00	1.00
08/19/2024 03:00	0	0.9	8.5	14.3	0.0	796,756.0	0.00	1.00
08/19/2024 04:00	0	1.0	8.1	14.4	0.0	905,294.9	0.00	1.00
08/19/2024 05:00	0	1.4	8.5	14.4	0.5	922,149.3	0.00	1.00
08/19/2024 06:00	0	1.4	8.6	14.3	0.0	798,000.9	0.00	1.00
08/19/2024 07:00	0	1.5	8.5	14.3	0.0	797,793.4	0.00	1.00
08/19/2024 08:00	0	1.0	8.5	14.4	1.8	809,224.5	0.00	1.00
08/19/2024 09:00	0	0.9	8.4	14.4	0.0	808,592.4	0.00	1.00
08/19/2024 10:00	0	1.4	8.3	14.4	0.3	806,274.9	0.00	1.00
08/19/2024 11:00	-1	1.6	8.2	14.5	2.4	816,733.3	0.00	1.00
08/19/2024 12:00	-1	1.6	8.2	14.5	2.7	816,305.3	0.00	1.00
08/19/2024 13:00	-1	1.6	8.3	14.5	4.1	814,593.5	0.00	1.00
08/19/2024 14:00	-1	1.6	8.3	14.5	3.9	814,165.6	0.00	1.00
08/19/2024 15:00	-1	1.6	8.4	14.5	4.8	813,951.6	0.00	1.00
08/19/2024 16:00	-1	1.6	8.6	14.5	5.0	813,737.6	0.00	1.00
08/19/2024 17:00	-1	1.6	8.5	14.5	4.9	813,951.6	0.00	1.00
08/19/2024 18:00	-1	1.6	8.4	14.5	4.8	815,449.4	0.00	1.00
08/19/2024 19:00	-1	1.6	8.4	14.5	4.4	816,305.3	0.00	1.00
08/19/2024 20:00	-1	1.6	8.4	14.4	4.7	804,800.2	0.00	1.00
08/19/2024 21:00	-1	1.6	8.3	14.5	5.9	904,676.0	0.00	1.00
08/19/2024 22:00	-1	1.7	8.4	14.4	4.0	806,064.3	0.00	1.00
08/19/2024 23:00	-1	1.7	8.3	14.4	3.9	806,274.9	0.00	1.00
Average/Sum#:	-1	1.4	8.4	14.4	2.4	821,953.0	0.00 #	24.00 #
Minimum:	-1	0.9	8.1	14.3	0.0	796,756.0	0.00	1.00
Maximum:	0	1.7	8.6	14.5	5.9	922,149.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2024 00:00	-1	1.7	8.4	14.4	4.0	806,907.0	0.00	1.00
08/20/2024 01:00	-1	1.7	8.4	14.4	4.0	807,328.3	0.00	1.00
08/20/2024 02:00	-1	1.6	8.7	14.4	4.1	807,117.7	0.00	1.00
08/20/2024 03:00	-1	1.7	8.6	14.4	3.9	807,960.4	0.00	1.00
08/20/2024 04:00	-1	1.7	8.4	14.3	3.6	796,341.0	0.00	1.00
08/20/2024 05:00	-1	1.7	8.4	14.3	3.7	796,756.0	0.00	1.00
08/20/2024 06:00	-1	1.7	8.4	14.3	3.9	796,548.5	0.00	1.00
08/20/2024 07:00	-1	1.7	8.3	14.4	3.3	808,381.7	0.00	1.00
08/20/2024 08:00	-1	1.7	8.3	14.4	3.0	807,960.4	0.00	1.00
08/20/2024 09:00	-1	1.7	8.3	14.4	3.4	808,171.1	0.00	1.00
08/20/2024 10:00	-1	1.6	8.3	14.4	3.1	807,117.7	0.00	1.00
08/20/2024 11:00	-1	1.6	8.1	14.5	3.3	818,873.0	0.00	1.00
08/20/2024 12:00	0	0.0	8.1	0.0	6.7	250,558.8	0.00	1.00
08/20/2024 13:00	0	0.0	8.2	0.0	0.0	250,296.7	0.00	1.00
08/20/2024 14:00	0	1.7	8.1	14.5	4.5	816,519.3	0.00	1.00
08/20/2024 15:00	-1	1.6	8.0	14.5	4.7	817,161.2	0.00	1.00
08/20/2024 16:00	-1	1.6	8.1	14.5	4.7	816,305.3	0.00	1.00
08/20/2024 17:00	-1	1.6	7.9	14.5	5.1	857,816.0	0.00	1.00
08/20/2024 18:00	-1	1.6	8.3	14.5	4.8	817,803.1	0.00	1.00
08/20/2024 19:00	-1	1.6	8.1	14.5	3.9	818,873.0	0.00	1.00
08/20/2024 20:00	-1	1.7	8.2	14.4	4.3	805,432.2	0.00	1.00
08/20/2024 21:00	-1	1.7	8.3	14.4	4.8	798,901.1	0.00	1.00
08/20/2024 22:00	-1	1.7	8.3	14.4	4.4	801,218.6	0.00	1.00
08/20/2024 23:00	-1	1.7	8.4	14.4	4.5	801,007.9	0.00	1.00
Average/Sum#:	-1	1.7	8.3	14.4	4.0	810,022.8	0.00 #	24.00 #
Minimum:	-1	1.6	7.9	14.3	0.0	796,341.0	0.00	1.00
Maximum:	0	1.7	8.7	14.5	6.7	857,816.0	0.00	1.00
%SI	8.33	8.33	0.00	8.33	0.00	8.33	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2024 00:00	-1	1.7	8.4	14.4	4.4	800,797.2	0.00	1.00
08/21/2024 01:00	-1	1.7	8.4	14.4	4.3	801,640.0	0.00	1.00
08/21/2024 02:00	-1	1.7	8.6	14.4	4.4	802,272.0	0.00	1.00
08/21/2024 03:00	-1	1.7	8.5	14.4	4.3	803,325.4	0.00	1.00
08/21/2024 04:00	-1	1.7	8.5	14.4	4.1	803,957.5	0.00	1.00
08/21/2024 05:00	-1	1.7	8.4	14.4	3.9	806,696.3	0.00	1.00
08/21/2024 06:00	-1	1.7	8.3	14.4	3.9	805,432.2	0.00	1.00
08/21/2024 07:00	-1	1.7	8.3	14.4	3.2	806,907.0	0.00	1.00
08/21/2024 08:00	-1	1.7	8.3	14.4	3.5	806,696.3	0.00	1.00
08/21/2024 09:00	-1	1.7	8.2	14.4	3.7	805,642.9	0.00	1.00
08/21/2024 10:00	-1	1.6	8.2	14.5	3.4	816,091.3	0.00	1.00
08/21/2024 11:00	-1	1.6	8.3	14.5	2.8	814,593.5	0.00	1.00
08/21/2024 12:00	-1	1.6	8.3	14.5	2.7	814,165.6	0.00	1.00
08/21/2024 13:00	-1	1.6	8.2	14.5	3.1	813,523.7	0.00	1.00
08/21/2024 14:00	-1	1.6	8.3	14.5	4.3	812,239.8	0.00	1.00
08/21/2024 15:00	-1	1.6	8.4	14.5	4.6	812,453.8	0.00	1.00
08/21/2024 16:00	-1	1.6	8.3	14.5	4.9	832,995.2	0.00	1.00
08/21/2024 17:00	-1	1.6	8.4	14.5	4.7	832,781.2	0.00	1.00
08/21/2024 18:00	-1	1.6	8.4	14.5	3.9	815,235.5	0.00	1.00
08/21/2024 19:00	-1	1.7	8.1	14.4	3.7	801,640.0	0.00	1.00
08/21/2024 20:00	-1	1.7	8.1	14.4	4.0	798,269.1	0.00	1.00
08/21/2024 21:00	-1	1.7	8.2	14.4	4.0	802,693.4	0.00	1.00
08/21/2024 22:00	-1	1.7	8.2	14.4	3.8	797,215.7	0.00	1.00
08/21/2024 23:00	-1	1.7	8.1	14.4	3.6	797,005.0	0.00	1.00
Average/Sum#:	-1	1.7	8.3	14.4	3.9	808,511.2	0.00 #	24.00 #
Minimum:	-1	1.6	8.1	14.4	2.7	797,005.0	0.00	1.00
Maximum:	-1	1.7	8.6	14.5	4.9	832,995.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2024 00:00	-1	1.7	8.1	14.4	3.7	798,690.4	0.00	1.00
08/22/2024 01:00	-1	1.7	8.1	14.3	3.8	788,664.0	0.00	1.00
08/22/2024 02:00	-1	1.7	8.4	14.3	3.7	790,531.3	0.00	1.00
08/22/2024 03:00	-1	1.7	8.2	14.3	3.5	791,983.8	0.00	1.00
08/22/2024 04:00	-1	1.7	8.2	14.3	2.9	792,813.7	0.00	1.00
08/22/2024 05:00	-1	1.7	8.3	14.3	3.7	820,824.7	0.00	1.00
08/22/2024 06:00	-1	1.7	8.6	14.3	3.5	796,756.0	0.00	1.00
08/22/2024 07:00	-1	1.7	8.5	14.3	3.5	796,963.5	0.00	1.00
08/22/2024 08:00	-1	1.7	8.4	14.3	3.4	795,718.6	0.00	1.00
08/22/2024 09:00	-1	1.7	8.3	14.4	3.6	806,485.6	0.00	1.00
08/22/2024 10:00	-1	1.7	8.3	14.4	3.3	805,642.9	0.00	1.00
08/22/2024 11:00	-1	1.7	8.3	14.4	3.3	804,800.2	0.00	1.00
08/22/2024 12:00	-1	1.7	7.9	14.4	2.5	803,536.1	0.00	1.00
08/22/2024 13:00	-1	1.6	7.9	14.4	2.7	803,114.7	0.00	1.00
08/22/2024 14:00	-1	1.6	7.9	14.4	2.3	803,114.7	0.00	1.00
08/22/2024 15:00	-1	1.6	7.9	14.4	2.6	803,114.7	0.00	1.00
08/22/2024 16:00	-1	1.7	7.9	14.4	2.6	803,536.1	0.00	1.00
08/22/2024 17:00	-1	1.7	8.0	14.4	3.3	803,957.5	0.00	1.00
08/22/2024 18:00	-1	1.7	8.0	14.4	3.2	805,221.5	0.00	1.00
08/22/2024 19:00	-1	1.7	8.0	14.4	3.1	806,485.6	0.00	1.00
08/22/2024 20:00	-1	1.7	8.1	14.4	3.3	807,539.0	0.00	1.00
08/22/2024 21:00	-1	1.7	8.0	14.4	3.4	807,960.4	0.00	1.00
08/22/2024 22:00	-1	1.7	8.0	14.3	3.1	796,341.0	0.00	1.00
08/22/2024 23:00	-1	1.7	8.0	14.3	2.9	796,756.0	0.00	1.00
Average/Sum#:	-1	1.7	8.1	14.4	3.2	801,273.0	0.00 #	24.00 #
Minimum:	-1	1.6	7.9	14.3	2.3	788,664.0	0.00	1.00
Maximum:	-1	1.7	8.6	14.4	3.8	820,824.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2024 00:00	-1	1.7	8.1	14.3	2.8	796,756.0	0.00	1.00
08/23/2024 01:00	-1	1.7	8.1	14.3	2.6	797,171.0	0.00	1.00
08/23/2024 02:00	-1	1.7	8.3	14.3	2.3	797,378.5	0.00	1.00
08/23/2024 03:00	-1	1.7	8.4	14.3	2.7	798,208.4	0.00	1.00
08/23/2024 04:00	-1	1.7	8.8	14.3	2.3	799,245.9	0.00	1.00
08/23/2024 05:00	-1	1.7	8.8	14.3	2.1	800,075.8	0.00	1.00
08/23/2024 06:00	-1	1.7	8.7	14.3	2.6	800,075.8	0.00	1.00
08/23/2024 07:00	-1	1.7	8.6	14.3	3.0	798,830.9	0.00	1.00
08/23/2024 08:00	-1	1.7	8.5	14.3	3.4	798,000.9	0.00	1.00
08/23/2024 09:00	-1	1.7	8.6	14.4	3.8	809,224.5	0.00	1.00
08/23/2024 10:00	-1	1.7	8.7	14.4	3.3	808,381.7	0.00	1.00
08/23/2024 11:00	-1	1.7	8.7	14.4	3.6	807,539.0	0.00	1.00
08/23/2024 12:00	-1	1.7	8.7	14.4	3.2	807,328.3	0.00	1.00
08/23/2024 13:00	-1	1.7	8.7	14.4	3.9	807,328.3	0.00	1.00
08/23/2024 14:00	-1	1.7	8.8	14.4	4.3	807,539.0	0.00	1.00
08/23/2024 15:00	-1	1.7	8.7	14.4	3.9	806,907.0	0.00	1.00
08/23/2024 16:00	-1	1.7	8.6	14.4	3.7	806,907.0	0.00	1.00
08/23/2024 17:00	-1	1.6	8.4	14.4	2.9	806,274.9	0.00	1.00
08/23/2024 18:00	-1	1.7	8.3	14.4	3.6	806,274.9	0.00	1.00
08/23/2024 19:00	-1	1.7	8.2	14.4	3.5	807,117.7	0.00	1.00
08/23/2024 20:00	-1	1.7	8.2	14.4	3.2	807,117.7	0.00	1.00
08/23/2024 21:00	-1	1.7	8.2	14.4	3.0	807,117.7	0.00	1.00
08/23/2024 22:00	-1	1.7	8.2	14.4	3.0	807,960.4	0.00	1.00
08/23/2024 23:00	-1	1.6	8.3	14.4	4.5	865,054.8	0.00	1.00
Average/Sum#:	-1	1.7	8.5	14.4	3.2	806,409.0	0.00 #	24.00 #
Minimum:	-1	1.6	8.1	14.3	2.1	796,756.0	0.00	1.00
Maximum:	-1	1.7	8.8	14.4	4.5	865,054.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/24/2024 00:00	-1	1.7	8.2	14.4	3.1	809,013.8	0.00	1.00
08/24/2024 01:00	-1	1.7	8.1	14.3	2.9	797,793.4	0.00	1.00
08/24/2024 02:00	-1	1.7	8.4	14.3	2.8	797,586.0	0.00	1.00
08/24/2024 03:00	-1	1.7	8.1	14.3	2.7	798,000.9	0.00	1.00
08/24/2024 04:00	-1	1.7	8.0	14.3	1.9	806,508.0	0.00	1.00
08/24/2024 05:00	-1	1.7	8.3	14.3	2.8	846,553.3	0.00	1.00
08/24/2024 06:00	-1	1.7	8.3	14.3	2.7	819,994.7	0.00	1.00
08/24/2024 07:00	-1	1.7	8.3	14.3	1.4	800,283.3	0.00	1.00
08/24/2024 08:00	-1	1.7	8.2	14.3	1.4	799,868.3	0.00	1.00
08/24/2024 09:00	-1	1.7	8.2	14.3	1.4	799,038.4	0.00	1.00
08/24/2024 10:00	-1	1.7	8.3	14.3	1.5	798,208.4	0.00	1.00
08/24/2024 11:00	-1	1.7	8.4	14.4	1.7	809,645.8	0.00	1.00
08/24/2024 12:00	-1	1.7	8.3	14.4	1.7	808,803.1	0.00	1.00
08/24/2024 13:00	-1	1.7	8.3	14.4	2.1	808,803.1	0.00	1.00
08/24/2024 14:00	-1	1.7	8.3	14.3	1.7	799,038.4	0.00	1.00
08/24/2024 15:00	-1	1.7	8.2	14.3	1.2	798,000.9	0.00	1.00
08/24/2024 16:00	-1	1.7	8.4	14.4	2.2	808,381.7	0.00	1.00
08/24/2024 17:00	-1	1.7	8.5	14.4	2.4	808,381.7	0.00	1.00
08/24/2024 18:00	-1	1.7	8.4	14.4	2.3	808,592.4	0.00	1.00
08/24/2024 19:00	-1	1.7	8.3	14.4	2.1	809,013.8	0.00	1.00
08/24/2024 20:00	-1	1.7	8.3	14.4	2.1	810,067.2	0.00	1.00
08/24/2024 21:00	-1	1.7	8.4	14.3	1.8	799,660.8	0.00	1.00
08/24/2024 22:00	-1	1.7	8.5	14.3	1.5	801,528.2	0.00	1.00
08/24/2024 23:00	-1	1.7	8.5	14.3	1.5	801,528.2	0.00	1.00
Average/Sum#:	-1	1.7	8.3	14.3	2.0	806,012.2	0.00 #	24.00 #
Minimum:	-1	1.7	8.0	14.3	1.2	797,586.0	0.00	1.00
Maximum:	-1	1.7	8.5	14.4	3.1	846,553.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2024 00:00	-1	1.7	8.5	14.3	1.5	802,358.2	0.00	1.00
08/25/2024 01:00	-1	1.7	8.6	14.3	0.7	802,980.7	0.00	1.00
08/25/2024 02:00	0	1.6	8.8	14.3	0.2	804,018.1	0.00	1.00
08/25/2024 03:00	-1	1.7	8.9	14.3	1.2	804,848.1	0.00	1.00
08/25/2024 04:00	-1	1.7	9.0	14.3	1.4	806,093.0	0.00	1.00
08/25/2024 05:00	-1	1.7	8.9	14.3	1.1	806,508.0	0.00	1.00
08/25/2024 06:00	-1	1.7	8.7	14.3	0.5	806,093.0	0.00	1.00
08/25/2024 07:00	-1	1.7	8.6	14.3	0.7	805,885.5	0.00	1.00
08/25/2024 08:00	-1	1.7	8.6	14.3	2.3	804,225.6	0.00	1.00
08/25/2024 09:00	-1	1.7	8.6	14.4	3.5	816,598.3	0.00	1.00
08/25/2024 10:00	-1	1.7	8.4	14.4	3.1	816,176.9	0.00	1.00
08/25/2024 11:00	-1	1.6	8.2	14.4	2.6	812,174.0	0.00	1.00
08/25/2024 12:00	-1	1.6	8.3	14.5	3.0	822,082.6	0.00	1.00
08/25/2024 13:00	-1	1.6	8.3	14.5	3.0	822,082.6	0.00	1.00
08/25/2024 14:00	-1	1.6	8.3	14.5	2.9	820,584.8	0.00	1.00
08/25/2024 15:00	-1	1.6	8.4	14.5	4.1	821,012.7	0.00	1.00
08/25/2024 16:00	-1	1.6	8.2	14.4	3.7	816,809.0	0.00	1.00
08/25/2024 17:00	-1	1.6	8.2	14.5	5.5	916,230.5	0.00	1.00
08/25/2024 18:00	-1	1.6	8.0	14.7	6.0	1,018,675.0	0.00	1.00
08/25/2024 19:00	-1	1.6	8.0	14.7	5.7	1,017,349.8	0.00	1.00
08/25/2024 20:00	-1	1.6	8.1	14.6	5.4	952,510.7	0.00	1.00
08/25/2024 21:00	-1	1.7	8.1	14.4	3.1	811,120.6	0.00	1.00
08/25/2024 22:00	-1	1.7	8.2	14.4	3.2	812,595.4	0.00	1.00
08/25/2024 23:00	-1	1.6	8.2	14.4	3.6	826,500.3	0.00	1.00
Average/Sum#:	-1	1.7	8.4	14.4	2.8	839,396.4	0.00 #	24.00 #
Minimum:	-1	1.6	8.0	14.3	0.2	802,358.2	0.00	1.00
Maximum:	0	1.7	9.0	14.7	6.0	1,018,675.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2024 00:00	-1	1.7	8.1	14.4	2.5	813,438.1	0.00	1.00
08/26/2024 01:00	-1	1.7	8.2	14.4	2.2	813,859.4	0.00	1.00
08/26/2024 02:00	-1	1.7	8.5	14.3	2.0	801,528.2	0.00	1.00
08/26/2024 03:00	-1	1.7	8.5	14.3	2.3	801,943.2	0.00	1.00
08/26/2024 04:00	-1	1.6	8.0	14.4	2.9	889,072.4	0.00	1.00
08/26/2024 05:00	-1	1.6	8.2	14.5	4.6	980,850.2	0.00	1.00
08/26/2024 06:00	-1	1.7	8.5	14.3	2.7	819,372.3	0.00	1.00
08/26/2024 07:00	-1	1.7	8.3	14.3	2.2	806,715.5	0.00	1.00
08/26/2024 08:00	-1	1.7	8.3	14.3	3.5	805,885.5	0.00	1.00
08/26/2024 09:00	-1	1.7	8.3	14.4	3.9	814,912.8	0.00	1.00
08/26/2024 10:00	-1	1.6	8.2	14.4	3.1	809,013.8	0.00	1.00
08/26/2024 11:00	-1	1.7	8.2	14.5	3.5	820,156.8	0.00	1.00
08/26/2024 12:00	-1	1.6	8.1	14.5	4.1	818,873.0	0.00	1.00
08/26/2024 13:00	-1	1.6	8.3	14.5	4.1	818,231.1	0.00	1.00
08/26/2024 14:00	-1	1.6	8.2	14.5	3.7	816,947.2	0.00	1.00
08/26/2024 15:00	-1	1.6	8.1	14.5	4.1	816,519.3	0.00	1.00
08/26/2024 16:00	-1	1.6	7.9	14.5	4.4	858,243.9	0.00	1.00
08/26/2024 17:00	-1	1.6	7.6	14.4	4.6	897,710.4	0.00	1.00
08/26/2024 18:00	-1	1.6	7.7	14.4	5.0	920,674.5	0.00	1.00
08/26/2024 19:00	-1	1.6	8.0	14.4	4.3	843,776.1	0.00	1.00
08/26/2024 20:00	-1	1.6	8.1	14.5	3.9	843,051.9	0.00	1.00
08/26/2024 21:00	-1	1.6	8.0	14.4	3.7	807,539.0	0.00	1.00
08/26/2024 22:00	-1	1.7	8.0	14.4	3.4	807,539.0	0.00	1.00
08/26/2024 23:00	-1	1.7	8.0	14.4	3.4	808,592.4	0.00	1.00
Average/Sum#:	-1	1.6	8.1	14.4	3.5	834,768.6	0.00 #	24.00 #
Minimum:	-1	1.6	7.6	14.3	2.0	801,528.2	0.00	1.00
Maximum:	-1	1.7	8.5	14.5	5.0	980,850.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2024 00:00	-1	1.7	8.0	14.4	3.3	809,013.8	0.00	1.00
08/27/2024 01:00	-1	1.7	8.1	14.4	3.1	809,645.8	0.00	1.00
08/27/2024 02:00	-1	1.7	8.3	14.4	2.6	809,645.8	0.00	1.00
08/27/2024 03:00	-1	1.7	8.2	14.4	2.7	809,856.5	0.00	1.00
08/27/2024 04:00	-1	1.7	8.3	14.4	2.6	810,067.2	0.00	1.00
08/27/2024 05:00	-1	1.7	8.3	14.4	2.5	810,699.2	0.00	1.00
08/27/2024 06:00	-1	1.7	8.3	14.4	2.8	811,963.3	0.00	1.00
08/27/2024 07:00	-1	1.7	8.1	14.4	2.3	810,909.9	0.00	1.00
08/27/2024 08:00	-1	1.7	8.0	14.4	3.1	809,645.8	0.00	1.00
08/27/2024 09:00	-1	1.6	8.0	14.4	2.9	808,803.1	0.00	1.00
08/27/2024 10:00	-1	1.6	7.9	14.5	2.8	820,370.8	0.00	1.00
08/27/2024 11:00	-1	1.6	7.9	14.5	3.6	818,659.0	0.00	1.00
08/27/2024 12:00	-1	1.6	7.8	14.5	3.0	818,017.1	0.00	1.00
08/27/2024 13:00	-1	1.6	7.8	14.5	3.2	816,947.2	0.00	1.00
08/27/2024 14:00	-1	1.6	7.9	14.5	3.3	816,091.3	0.00	1.00
08/27/2024 15:00	-1	1.6	7.9	14.6	4.2	829,045.2	0.00	1.00
08/27/2024 16:00	-1	1.6	8.1	14.6	4.9	834,696.8	0.00	1.00
08/27/2024 17:00	-1	1.6	8.0	14.6	5.3	892,299.5	0.00	1.00
08/27/2024 18:00	-1	1.6	7.8	14.5	5.7	943,191.0	0.00	1.00
08/27/2024 19:00	-1	1.6	8.2	14.5	4.5	818,231.1	0.00	1.00
08/27/2024 20:00	-1	1.6	8.2	14.5	3.9	819,728.9	0.00	1.00
08/27/2024 21:00	-1	1.6	8.3	14.5	3.8	819,728.9	0.00	1.00
08/27/2024 22:00	-1	1.6	8.1	14.4	3.4	808,381.7	0.00	1.00
08/27/2024 23:00	-1	1.7	8.1	14.4	4.1	809,856.5	0.00	1.00
Average/Sum#:	-1	1.6	8.1	14.5	3.5	823,562.3	0.00 #	24.00 #
Minimum:	-1	1.6	7.8	14.4	2.3	808,381.7	0.00	1.00
Maximum:	-1	1.7	8.3	14.6	5.7	943,191.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2024 00:00	-1	1.7	8.1	14.4	4.2	810,699.2	0.00	1.00
08/28/2024 01:00	-1	1.7	8.0	14.4	3.6	810,909.9	0.00	1.00
08/28/2024 02:00	-1	1.7	8.2	14.4	3.2	811,120.6	0.00	1.00
08/28/2024 03:00	-1	1.7	8.2	14.4	3.5	811,331.3	0.00	1.00
08/28/2024 04:00	-1	1.7	8.3	14.4	3.8	822,286.7	0.00	1.00
08/28/2024 05:00	-1	1.7	8.1	14.4	5.5	912,458.0	0.00	1.00
08/28/2024 06:00	-1	1.6	8.4	14.3	3.4	825,389.4	0.00	1.00
08/28/2024 07:00	-1	1.7	8.2	14.3	2.8	800,490.8	0.00	1.00
08/28/2024 08:00	-1	1.7	8.1	14.3	3.5	800,283.3	0.00	1.00
08/28/2024 09:00	-1	1.7	7.9	14.3	3.3	799,245.9	0.00	1.00
08/28/2024 10:00	-1	1.7	8.0	14.3	4.0	799,453.4	0.00	1.00
08/28/2024 11:00	-1	1.6	8.0	14.5	3.8	818,445.0	0.00	1.00
08/28/2024 12:00	-1	1.6	7.8	14.5	3.3	816,947.2	0.00	1.00
08/28/2024 13:00	-1	1.6	7.7	14.5	2.4	816,519.3	0.00	1.00
08/28/2024 14:00	-1	1.6	7.6	14.5	2.2	815,235.5	0.00	1.00
08/28/2024 15:00	-1	1.6	7.5	14.6	2.8	828,175.7	0.00	1.00
08/28/2024 16:00	-1	1.6	7.7	14.6	3.4	833,609.9	0.00	1.00
08/28/2024 17:00	-1	1.6	7.7	14.6	3.4	833,392.6	0.00	1.00
08/28/2024 18:00	-1	1.6	7.9	14.6	3.4	831,871.0	0.00	1.00
08/28/2024 19:00	-1	1.6	8.5	14.5	4.5	816,305.3	0.00	1.00
08/28/2024 20:00	-1	1.6	8.4	14.5	3.1	819,087.0	0.00	1.00
08/28/2024 21:00	-1	1.6	8.2	14.5	2.9	821,654.6	0.00	1.00
08/28/2024 22:00	-1	1.7	8.1	14.4	3.4	811,331.3	0.00	1.00
08/28/2024 23:00	-1	1.7	8.1	14.4	2.7	811,963.3	0.00	1.00
Average/Sum#:	-1	1.7	8.0	14.4	3.4	819,925.3	0.00 #	24.00 #
Minimum:	-1	1.6	7.5	14.3	2.2	799,245.9	0.00	1.00
Maximum:	-1	1.7	8.5	14.6	5.5	912,458.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2024 00:00	-1	1.7	8.1	14.4	2.7	811,963.3	0.00	1.00
08/29/2024 01:00	-1	1.7	8.2	14.4	2.7	811,331.3	0.00	1.00
08/29/2024 02:00	-1	1.7	8.6	14.4	2.7	818,915.8	0.00	1.00
08/29/2024 03:00	-1	1.7	8.5	14.4	2.5	810,067.2	0.00	1.00
08/29/2024 04:00	-1	1.7	8.5	14.4	2.8	810,067.2	0.00	1.00
08/29/2024 05:00	-1	1.7	8.4	14.3	2.6	798,830.9	0.00	1.00
08/29/2024 06:00	-1	1.7	8.7	14.5	6.7	1,046,539.8	0.00	1.00
08/29/2024 07:00	-1	1.6	8.9	14.5	6.9	1,063,871.6	0.00	1.00
08/29/2024 08:00	-1	1.6	8.8	14.5	7.0	1,059,164.2	0.00	1.00
08/29/2024 09:00	-1	1.6	8.3	14.4	3.4	888,019.0	0.00	1.00
08/29/2024 10:00	-1	1.7	8.1	14.4	2.0	816,598.3	0.00	1.00
08/29/2024 11:00	-1	1.6	8.0	14.5	1.5	817,803.1	0.00	1.00
08/29/2024 12:00	-1	1.6	8.0	14.5	3.1	817,161.2	0.00	1.00
08/29/2024 13:00	-1	1.6	7.9	14.5	2.6	816,733.3	0.00	1.00
08/29/2024 14:00	-1	1.6	8.0	14.5	2.7	815,877.4	0.00	1.00
08/29/2024 15:00	-1	1.6	8.0	14.6	3.7	827,958.3	0.00	1.00
08/29/2024 16:00	-1	1.6	8.0	14.6	3.4	827,088.9	0.00	1.00
08/29/2024 17:00	-1	1.6	7.9	14.5	3.2	815,021.5	0.00	1.00
08/29/2024 18:00	-1	1.6	8.0	14.5	3.8	816,947.2	0.00	1.00
08/29/2024 19:00	-1	1.6	7.9	14.4	2.4	806,274.9	0.00	1.00
08/29/2024 20:00	-1	1.6	7.9	14.4	2.9	807,749.7	0.00	1.00
08/29/2024 21:00	-1	1.7	7.9	14.4	2.9	809,013.8	0.00	1.00
08/29/2024 22:00	-1	1.7	8.0	14.4	2.4	810,067.2	0.00	1.00
08/29/2024 23:00	-1	1.7	7.9	14.4	2.0	810,699.2	0.00	1.00
Average/Sum#:	-1	1.6	8.2	14.5	3.3	847,240.2	0.00 #	24.00 #
Minimum:	-1	1.6	7.9	14.3	1.5	798,830.9	0.00	1.00
Maximum:	-1	1.7	8.9	14.6	7.0	1,063,871.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2024 00:00	-1	1.7	8.0	14.4	1.9	811,120.6	0.00	1.00
08/30/2024 01:00	-1	1.7	8.1	14.3	1.9	799,453.4	0.00	1.00
08/30/2024 02:00	-1	1.7	8.3	14.3	1.7	799,868.3	0.00	1.00
08/30/2024 03:00	-1	1.7	8.4	14.3	1.9	800,283.3	0.00	1.00
08/30/2024 04:00	-1	1.7	8.2	14.3	1.3	802,150.7	0.00	1.00
08/30/2024 05:00	-1	1.7	8.2	14.3	1.0	800,490.8	0.00	1.00
08/30/2024 06:00	-1	1.7	8.1	14.3	1.0	800,698.3	0.00	1.00
08/30/2024 07:00	-1	1.7	8.1	14.3	1.3	800,283.3	0.00	1.00
08/30/2024 08:00	-1	1.7	8.2	14.4	1.9	811,331.3	0.00	1.00
08/30/2024 09:00	-1	1.7	8.1	14.4	2.0	810,067.2	0.00	1.00
08/30/2024 10:00	-1	1.6	8.0	14.4	1.4	809,013.8	0.00	1.00
08/30/2024 11:00	-1	1.6	8.0	14.5	1.3	819,728.9	0.00	1.00
08/30/2024 12:00	-1	1.6	8.0	14.5	2.0	818,231.1	0.00	1.00
08/30/2024 13:00	-1	1.6	8.0	14.5	2.4	817,803.1	0.00	1.00
08/30/2024 14:00	-1	1.6	7.9	14.5	2.4	816,947.2	0.00	1.00
08/30/2024 15:00	-1	1.6	7.8	14.6	2.8	829,479.9	0.00	1.00
08/30/2024 16:00	-1	1.6	7.8	14.6	3.7	843,174.2	0.00	1.00
08/30/2024 17:00	-1	1.6	7.8	14.5	3.0	817,375.2	0.00	1.00
08/30/2024 18:00	-1	1.6	7.9	14.5	3.1	818,445.0	0.00	1.00
08/30/2024 19:00	-1	1.6	7.9	14.5	2.1	820,370.8	0.00	1.00
08/30/2024 20:00	-1	1.7	8.0	14.4	2.5	808,803.1	0.00	1.00
08/30/2024 21:00	-1	1.6	8.0	14.4	3.2	814,702.2	0.00	1.00
08/30/2024 22:00	-1	1.7	8.1	14.4	2.9	810,277.9	0.00	1.00
08/30/2024 23:00	-1	1.7	8.1	14.4	2.6	811,752.6	0.00	1.00
Average/Sum#:	-1	1.7	8.0	14.4	2.1	812,160.5	0.00 #	24.00 #
Minimum:	-1	1.6	7.8	14.3	1.0	799,453.4	0.00	1.00
Maximum:	-1	1.7	8.4	14.6	3.7	843,174.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2024 00:00	-1	1.7	8.1	14.4	2.6	813,227.4	0.00	1.00
08/31/2024 01:00	-1	1.7	8.1	14.4	2.1	811,542.0	0.00	1.00
08/31/2024 02:00	-1	1.7	8.4	14.4	2.1	812,174.0	0.00	1.00
08/31/2024 03:00	-1	1.7	8.3	14.4	2.2	811,963.3	0.00	1.00
08/31/2024 04:00	-1	1.7	8.3	14.3	2.2	800,283.3	0.00	1.00
08/31/2024 05:00	-1	1.7	8.2	14.3	1.8	800,075.8	0.00	1.00
08/31/2024 06:00	-1	1.7	8.1	14.3	1.5	800,075.8	0.00	1.00
08/31/2024 07:00	-1	1.7	8.1	14.3	1.4	799,868.3	0.00	1.00
08/31/2024 08:00	-1	1.7	8.1	14.4	2.0	810,909.9	0.00	1.00
08/31/2024 09:00	-1	1.7	8.1	14.4	2.3	809,856.5	0.00	1.00
08/31/2024 10:00	-1	1.6	8.0	14.4	1.4	808,592.4	0.00	1.00
08/31/2024 11:00	-1	1.6	8.1	14.5	1.4	820,584.8	0.00	1.00
08/31/2024 12:00	-1	1.6	8.0	14.5	2.3	820,370.8	0.00	1.00
08/31/2024 13:00	-1	1.6	7.8	14.5	2.0	821,440.7	0.00	1.00
08/31/2024 14:00	-1	1.6	7.7	14.5	2.2	821,012.7	0.00	1.00
08/31/2024 15:00	-1	1.6	7.6	14.6	3.2	852,955.8	0.00	1.00
08/31/2024 16:00	0	1.6	8.2	14.2	6.1	911,995.8	0.00	1.00
08/31/2024 17:00	0	2.1	13.7	12.6	20.0	1,030,038.1	0.00	1.00
08/31/2024 18:00	0	2.1	13.4	12.7	17.7	1,034,249.4	0.00	1.00
08/31/2024 19:00	0	2.1	13.8	12.6	19.3	1,038,947.6	0.00	1.00
08/31/2024 20:00	0	1.9	10.7	13.5	10.3	986,540.7	0.00	1.00
08/31/2024 21:00	-1	1.7	7.4	14.4	4.4	969,552.5	0.00	1.00
08/31/2024 22:00	-1	1.6	7.6	14.5	5.0	988,339.3	0.00	1.00
08/31/2024 23:00	0	1.6	8.7	14.3	6.3	947,392.7	0.00	1.00
Average/Sum#:	-1	1.7	8.9	14.1	5.1	871,749.6	0.00 #	24.00 #
Minimum:	-1	1.6	7.4	12.6	1.4	799,868.3	0.00	1.00
Maximum:	0	2.1	13.8	14.6	20.0	1,038,947.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2024 00:00	-1	1.7	8.1	14.4	2.8	820,179.9	0.00	1.00
09/01/2024 01:00	-1	1.7	8.1	14.4	2.3	812,174.0	0.00	1.00
09/01/2024 02:00	-1	1.7	8.4	14.4	2.1	812,384.7	0.00	1.00
09/01/2024 03:00	-1	1.7	8.4	14.3	2.4	801,113.3	0.00	1.00
09/01/2024 04:00	-1	1.7	8.3	14.3	1.9	801,113.3	0.00	1.00
09/01/2024 05:00	-1	1.7	8.2	14.3	1.2	801,943.2	0.00	1.00
09/01/2024 06:00	-1	1.7	8.1	14.3	1.1	801,528.2	0.00	1.00
09/01/2024 07:00	-1	1.7	8.1	14.3	1.8	800,905.8	0.00	1.00
09/01/2024 08:00	-1	1.7	8.1	14.4	2.2	812,384.7	0.00	1.00
09/01/2024 09:00	-1	1.7	8.1	14.4	2.5	810,067.2	0.00	1.00
09/01/2024 10:00	-1	1.7	8.1	14.4	1.7	808,803.1	0.00	1.00
09/01/2024 11:00	-1	1.6	8.1	14.4	0.4	806,907.0	0.00	1.00
09/01/2024 12:00	-1	1.6	8.1	14.5	0.4	818,231.1	0.00	1.00
09/01/2024 13:00	-1	1.6	8.1	14.5	1.6	817,161.2	0.00	1.00
09/01/2024 14:00	-1	1.6	8.0	14.5	1.0	816,519.3	0.00	1.00
09/01/2024 15:00	-1	1.6	7.9	14.4	0.9	805,642.9	0.00	1.00
09/01/2024 16:00	-1	1.6	8.1	14.5	2.2	846,689.4	0.00	1.00
09/01/2024 17:00	-1	1.6	8.3	14.6	4.3	890,560.6	0.00	1.00
09/01/2024 18:00	-1	1.6	8.3	14.5	0.8	819,728.9	0.00	1.00
09/01/2024 19:00	-1	1.7	8.1	14.4	1.2	806,064.3	0.00	1.00
09/01/2024 20:00	-1	1.7	8.1	14.4	1.7	807,960.4	0.00	1.00
09/01/2024 21:00	-1	1.6	8.2	14.4	2.1	823,340.1	0.00	1.00
09/01/2024 22:00	-1	1.7	8.2	14.4	1.5	817,019.7	0.00	1.00
09/01/2024 23:00	-1	1.6	8.4	14.4	1.8	823,761.4	0.00	1.00
Average/Sum#:	-1	1.7	8.2	14.4	1.7	815,924.3	0.00 #	24.00 #
Minimum:	-1	1.6	7.9	14.3	0.4	800,905.8	0.00	1.00
Maximum:	-1	1.7	8.4	14.6	4.3	890,560.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/02/2024 00:00	-1	1.6	8.3	14.4	1.5	833,242.1	0.00	1.00
09/02/2024 01:00	-1	1.6	8.1	14.3	0.3	798,623.4	0.00	1.00
09/02/2024 02:00	0	1.6	8.3	14.3	0.2	799,660.8	0.00	1.00
09/02/2024 03:00	0	1.6	8.2	14.3	0.2	800,075.8	0.00	1.00
09/02/2024 04:00	0	1.6	8.2	14.3	0.0	800,283.3	0.00	1.00
09/02/2024 05:00	0	1.4	8.3	14.3	0.1	801,320.8	0.00	1.00
09/02/2024 06:00	0	1.4	8.5	14.3	0.0	801,320.8	0.00	1.00
09/02/2024 07:00	-1	1.6	8.4	14.3	0.4	800,075.8	0.00	1.00
09/02/2024 08:00	-1	1.7	8.4	14.3	1.1	800,698.3	0.00	1.00
09/02/2024 09:00	-1	1.7	8.4	14.4	1.0	811,542.0	0.00	1.00
09/02/2024 10:00	-1	1.6	8.2	14.4	0.7	809,435.2	0.00	1.00
09/02/2024 11:00	-1	1.6	8.0	14.4	0.4	807,117.7	0.00	1.00
09/02/2024 12:00	0	1.6	8.1	14.5	0.1	819,300.9	0.00	1.00
09/02/2024 13:00	0	1.6	8.3	14.5	0.2	818,445.0	0.00	1.00
09/02/2024 14:00	-1	1.6	8.3	14.6	1.3	865,780.5	0.00	1.00
09/02/2024 15:00	-1	1.6	8.2	14.5	1.5	836,204.8	0.00	1.00
09/02/2024 16:00	-1	1.6	8.0	14.5	2.4	896,973.0	0.00	1.00
09/02/2024 17:00	-1	1.6	7.8	14.4	1.9	900,238.5	0.00	1.00
09/02/2024 18:00	-1	1.6	7.9	14.4	1.7	908,244.4	0.00	1.00
09/02/2024 19:00	-1	1.6	8.0	14.4	1.2	845,250.9	0.00	1.00
09/02/2024 20:00	-1	1.7	8.1	14.4	1.7	836,613.0	0.00	1.00
09/02/2024 21:00	-1	1.7	8.0	14.4	0.9	809,435.2	0.00	1.00
09/02/2024 22:00	-1	1.7	8.0	14.4	0.6	810,067.2	0.00	1.00
09/02/2024 23:00	-1	1.7	8.0	14.4	0.4	810,699.2	0.00	1.00
Average/Sum#:	-1	1.6	8.2	14.4	0.8	825,860.4	0.00 #	24.00 #
Minimum:	-1	1.4	7.8	14.3	0.0	798,623.4	0.00	1.00
Maximum:	0	1.7	8.5	14.6	2.4	908,244.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2024 00:00	-1	1.7	8.1	14.4	0.6	811,331.3	0.00	1.00
09/03/2024 01:00	-1	1.7	8.2	14.3	0.7	798,623.4	0.00	1.00
09/03/2024 02:00	-1	1.7	8.5	14.3	0.7	800,283.3	0.00	1.00
09/03/2024 03:00	-1	1.6	8.5	14.3	1.0	800,075.8	0.00	1.00
09/03/2024 04:00	-1	1.7	8.5	14.3	0.8	799,453.4	0.00	1.00
09/03/2024 05:00	-1	1.6	8.5	14.4	2.2	871,375.3	0.00	1.00
09/03/2024 06:00	0	1.5	8.9	14.3	0.9	822,277.1	0.00	1.00
09/03/2024 07:00	-1	1.6	8.4	14.4	1.6	851,149.9	0.00	1.00
09/03/2024 08:00	-1	1.7	8.3	14.4	1.2	809,645.8	0.00	1.00
09/03/2024 09:00	-1	1.6	8.2	14.4	1.2	806,907.0	0.00	1.00
09/03/2024 10:00	-1	1.6	8.3	14.5	1.2	818,231.1	0.00	1.00
09/03/2024 11:00	-1	1.6	8.2	14.5	1.7	817,161.2	0.00	1.00
09/03/2024 12:00	-1	1.6	8.1	14.5	1.4	815,235.5	0.00	1.00
09/03/2024 13:00	-1	1.6	7.9	14.5	2.2	903,606.1	0.00	1.00
09/03/2024 14:00	-1	1.6	7.9	14.5	3.0	944,474.9	0.00	1.00
09/03/2024 15:00	-1	1.6	7.7	14.4	2.5	906,769.6	0.00	1.00
09/03/2024 16:00	0	1.7	9.6	14.0	8.2	963,360.3	0.00	1.00
09/03/2024 17:00	0	2.2	13.9	12.6	19.6	1,039,772.6	0.00	1.00
09/03/2024 18:00	0	2.1	14.3	12.5	19.4	1,035,871.7	0.00	1.00
09/03/2024 19:00	-1	1.8	10.9	13.5	9.6	990,056.8	0.00	1.00
09/03/2024 20:00	-1	1.6	7.5	14.5	2.2	1,016,155.7	0.00	1.00
09/03/2024 21:00	-1	1.6	7.6	14.5	2.4	1,016,583.6	0.00	1.00
09/03/2024 22:00	-1	1.6	8.1	14.5	3.0	911,095.2	0.00	1.00
09/03/2024 23:00	-1	1.6	8.5	14.6	6.3	1,013,808.8	0.00	1.00
Average/Sum#:	-1	1.7	8.9	14.2	3.9	890,137.7	0.00 #	24.00 #
Minimum:	-1	1.5	7.5	12.5	0.6	798,623.4	0.00	1.00
Maximum:	0	2.2	14.3	14.6	19.6	1,039,772.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2024 00:00	-1	1.7	8.4	14.5	3.4	906,387.8	0.00	1.00
09/04/2024 01:00	-1	1.6	8.3	14.5	4.0	907,029.7	0.00	1.00
09/04/2024 02:00	-1	1.7	8.4	14.4	1.6	817,862.4	0.00	1.00
09/04/2024 03:00	-1	1.7	8.3	14.5	3.9	948,326.4	0.00	1.00
09/04/2024 04:00	-1	1.6	8.3	14.5	4.1	956,885.3	0.00	1.00
09/04/2024 05:00	-1	1.6	8.2	14.5	4.8	1,008,452.7	0.00	1.00
09/04/2024 06:00	-1	1.6	8.3	14.4	2.2	849,675.2	0.00	1.00
09/04/2024 07:00	-1	1.7	8.0	14.4	0.6	814,491.5	0.00	1.00
09/04/2024 08:00	-1	1.6	8.1	14.4	1.2	812,384.7	0.00	1.00
09/04/2024 09:00	-1	1.6	8.2	14.5	0.7	822,938.5	0.00	1.00
09/04/2024 10:00	-1	1.6	8.2	14.5	1.7	820,798.7	0.00	1.00
09/04/2024 11:00	-1	1.6	8.0	14.5	1.2	819,728.9	0.00	1.00
09/04/2024 12:00	-1	1.6	7.7	14.6	1.0	831,871.0	0.00	1.00
09/04/2024 13:00	-1	1.5	7.3	14.6	2.2	906,428.5	0.00	1.00
09/04/2024 14:00	0	1.6	7.4	14.5	3.1	930,780.6	0.00	1.00
09/04/2024 15:00	-1	1.7	7.7	14.4	1.6	815,334.2	0.00	1.00
09/04/2024 16:00	0	1.8	9.4	13.9	9.2	940,598.9	0.00	1.00
09/04/2024 17:00	1	2.2	14.6	12.2	23.4	1,028,484.9	0.00	1.00
09/04/2024 18:00	0	2.1	14.2	12.4	21.7	1,033,512.6	0.00	1.00
09/04/2024 19:00	0	2.1	13.9	12.6	18.7	1,040,762.5	0.00	1.00
09/04/2024 20:00	0	2.1	14.0	12.7	18.9	1,053,120.8	0.00	1.00
09/04/2024 21:00	0	2.1	13.7	12.7	18.1	1,047,275.6	0.00	1.00
09/04/2024 22:00	0	2.1	13.1	12.9	16.5	1,053,772.1	0.00	1.00
09/04/2024 23:00	0	1.9	10.9	13.6	10.2	1,009,247.0	0.00	1.00
Average/Sum#:	-1	1.8	9.7	13.9	7.3	924,006.3	0.00 #	24.00 #
Minimum:	-1	1.5	7.3	12.2	0.6	812,384.7	0.00	1.00
Maximum:	1	2.2	14.6	14.6	23.4	1,053,772.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2024 00:00	-1	1.6	8.2	14.5	3.3	908,527.5	0.00	1.00
09/05/2024 01:00	-1	1.7	8.2	14.4	3.0	834,506.2	0.00	1.00
09/05/2024 02:00	-1	1.7	8.3	14.4	2.4	814,070.1	0.00	1.00
09/05/2024 03:00	-1	1.7	8.3	14.4	2.4	814,070.1	0.00	1.00
09/05/2024 04:00	-1	1.7	8.1	14.5	3.0	891,837.6	0.00	1.00
09/05/2024 05:00	-1	1.6	8.0	14.5	4.9	990,051.0	0.00	1.00
09/05/2024 06:00	-1	1.6	8.3	14.4	3.5	872,639.4	0.00	1.00
09/05/2024 07:00	-1	1.7	8.1	14.4	2.0	813,859.4	0.00	1.00
09/05/2024 08:00	-1	1.6	8.1	14.4	1.9	812,806.0	0.00	1.00
09/05/2024 09:00	-1	1.6	8.1	14.5	2.2	848,187.2	0.00	1.00
09/05/2024 10:00	0	1.6	7.8	14.5	3.4	942,121.2	0.00	1.00
09/05/2024 11:00	-1	1.6	7.8	14.5	2.1	872,794.1	0.00	1.00
09/05/2024 12:00	-1	1.6	7.3	14.5	3.2	992,618.7	0.00	1.00
09/05/2024 13:00	0	1.8	9.3	13.9	8.9	972,291.3	0.00	1.00
09/05/2024 14:00	1	2.2	14.2	12.2	22.7	1,025,651.6	0.00	1.00
09/05/2024 15:00	0	2.1	13.2	12.6	18.8	1,023,933.5	0.00	1.00
09/05/2024 16:00	0	2.1	13.7	12.6	20.6	1,037,957.7	0.00	1.00
09/05/2024 17:00	1	2.2	14.6	12.4	23.1	1,040,601.4	0.00	1.00
09/05/2024 18:00	0	2.1	14.6	12.5	21.0	1,043,371.0	0.00	1.00
09/05/2024 19:00	0	2.1	14.0	12.6	19.4	1,039,442.6	0.00	1.00
09/05/2024 20:00	0	2.1	13.7	12.8	18.4	1,054,118.6	0.00	1.00
09/05/2024 21:00	0	2.1	13.3	12.9	17.2	1,053,600.9	0.00	1.00
09/05/2024 22:00	0	2.0	12.5	13.1	16.1	1,057,090.3	0.00	1.00
09/05/2024 23:00	0	2.0	11.8	13.3	13.4	1,045,988.0	0.00	1.00
Average/Sum#:	0	1.8	10.4	13.7	9.9	950,089.0	0.00 #	24.00 #
Minimum:	-1	1.6	7.3	12.2	1.9	812,806.0	0.00	1.00
Maximum:	1	2.2	14.6	14.5	23.1	1,057,090.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2024 00:00	-1	1.6	8.4	14.5	4.3	905,317.9	0.00	1.00
09/06/2024 01:00	-1	1.6	8.3	14.5	3.3	824,864.2	0.00	1.00
09/06/2024 02:00	-1	1.7	8.4	14.4	3.1	811,963.3	0.00	1.00
09/06/2024 03:00	-1	1.7	8.2	14.4	2.9	813,016.7	0.00	1.00
09/06/2024 04:00	-1	1.7	8.1	14.5	4.1	883,706.7	0.00	1.00
09/06/2024 05:00	-1	1.6	8.4	14.6	6.6	1,000,331.9	0.00	1.00
09/06/2024 06:00	-1	1.6	8.7	14.5	5.8	930,352.7	0.00	1.00
09/06/2024 07:00	-1	1.6	8.4	14.5	4.7	908,741.5	0.00	1.00
09/06/2024 08:00	-1	1.6	8.3	14.4	2.3	811,542.0	0.00	1.00
09/06/2024 09:00	-1	1.6	8.2	14.5	1.8	822,296.5	0.00	1.00
09/06/2024 10:00	-1	1.6	8.2	14.5	2.3	821,226.7	0.00	1.00
09/06/2024 11:00	-1	1.6	8.1	14.6	2.3	861,650.5	0.00	1.00
09/06/2024 12:00	-1	1.6	7.4	14.6	3.3	972,726.1	0.00	1.00
09/06/2024 13:00	0	1.8	9.8	13.8	10.5	968,819.5	0.00	1.00
09/06/2024 14:00	0	2.2	14.4	12.4	22.0	1,027,712.7	0.00	1.00
09/06/2024 15:00	1	2.2	14.5	12.2	23.9	1,019,985.1	0.00	1.00
09/06/2024 16:00	0	2.1	13.3	12.7	20.1	1,032,078.4	0.00	1.00
09/06/2024 17:00	1	2.2	14.3	12.3	24.0	1,031,526.9	0.00	1.00
09/06/2024 18:00	1	2.2	14.7	12.2	24.5	1,034,938.5	0.00	1.00
09/06/2024 19:00	0	2.1	13.8	12.6	19.9	1,033,173.0	0.00	1.00
09/06/2024 20:00	0	2.1	13.7	12.7	19.4	1,043,768.6	0.00	1.00
09/06/2024 21:00	0	2.1	14.2	12.5	20.8	1,038,643.2	0.00	1.00
09/06/2024 22:00	0	2.1	13.7	12.7	19.2	1,050,281.7	0.00	1.00
09/06/2024 23:00	0	2.1	14.1	12.6	20.8	1,051,651.9	0.00	1.00
Average/Sum#:	0	1.8	10.7	13.6	11.3	945,846.5	0.00 #	24.00 #
Minimum:	-1	1.6	7.4	12.2	1.8	811,542.0	0.00	1.00
Maximum:	1	2.2	14.7	14.6	24.5	1,051,651.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:28 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2024 00:00	0	2.1	13.5	12.8	19.0	1,056,823.7	0.00	1.00
09/07/2024 01:00	0	1.8	10.6	13.6	11.4	996,115.5	0.00	1.00
09/07/2024 02:00	0	2.0	8.3	14.3	2.4	805,470.5	0.00	1.00
09/07/2024 03:00	-1	1.7	8.2	14.3	3.2	811,695.2	0.00	1.00
09/07/2024 04:00	-1	1.7	8.2	14.3	3.1	802,358.2	0.00	1.00
09/07/2024 05:00	-1	1.7	8.5	14.4	4.1	811,331.3	0.00	1.00
09/07/2024 06:00	-1	1.7	8.6	14.4	3.9	811,120.6	0.00	1.00
09/07/2024 07:00	-1	1.7	8.5	14.5	3.6	824,222.3	0.00	1.00
09/07/2024 08:00	-1	1.6	8.5	14.5	3.3	822,724.5	0.00	1.00
09/07/2024 09:00	-1	1.6	8.6	14.5	3.1	821,440.7	0.00	1.00
09/07/2024 10:00	-1	1.6	8.7	14.6	3.8	833,175.2	0.00	1.00
09/07/2024 11:00	-1	1.6	8.5	14.6	2.7	832,523.1	0.00	1.00
09/07/2024 12:00	-1	1.5	8.0	14.6	4.5	944,250.7	0.00	1.00
09/07/2024 13:00	-1	1.6	8.3	14.5	5.7	1,014,229.9	0.00	1.00
09/07/2024 14:00	0	2.0	11.8	13.2	13.8	1,030,269.5	0.00	1.00
09/07/2024 15:00	0	2.0	11.6	13.2	13.8	1,025,645.5	0.00	1.00
09/07/2024 16:00	0	1.9	11.0	13.5	11.9	1,036,876.3	0.00	1.00
09/07/2024 17:00	0	2.1	13.8	12.7	19.5	1,041,430.5	0.00	1.00
09/07/2024 18:00	0	2.1	14.1	12.7	20.2	1,051,617.7	0.00	1.00
09/07/2024 19:00	0	2.1	13.7	12.8	19.4	1,048,877.6	0.00	1.00
09/07/2024 20:00	0	2.1	14.0	12.7	20.1	1,049,947.7	0.00	1.00
09/07/2024 21:00	0	2.1	14.1	12.8	20.5	1,062,233.8	0.00	1.00
09/07/2024 22:00	0	2.1	14.2	12.8	20.8	1,066,798.5	0.00	1.00
09/07/2024 23:00	0	2.0	13.0	13.1	18.0	1,053,052.2	0.00	1.00
Average/Sum#:	0	1.9	10.7	13.7	10.5	943,926.3	0.00 #	24.00 #
Minimum:	-1	1.5	8.0	12.7	2.4	802,358.2	0.00	1.00
Maximum:	0	2.1	14.2	14.6	20.8	1,066,798.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2024 00:00	-1	1.6	8.3	14.4	5.1	912,247.3	0.00	1.00
09/08/2024 01:00	-1	1.7	8.7	14.3	4.6	804,848.1	0.00	1.00
09/08/2024 02:00	-1	1.7	8.9	14.3	4.6	805,885.5	0.00	1.00
09/08/2024 03:00	-1	1.7	8.8	14.3	4.6	806,508.0	0.00	1.00
09/08/2024 04:00	-1	1.7	8.8	14.3	4.5	806,922.9	0.00	1.00
09/08/2024 05:00	-1	1.7	8.7	14.3	4.1	807,337.9	0.00	1.00
09/08/2024 06:00	-1	1.7	8.9	14.3	4.3	806,300.5	0.00	1.00
09/08/2024 07:00	-1	1.7	8.9	14.4	4.3	815,755.6	0.00	1.00
09/08/2024 08:00	-1	1.6	8.7	14.4	3.8	814,070.1	0.00	1.00
09/08/2024 09:00	-1	1.6	8.5	14.5	2.4	824,222.3	0.00	1.00
09/08/2024 10:00	-1	1.6	8.8	14.5	2.6	822,296.5	0.00	1.00
09/08/2024 11:00	-1	1.6	8.6	14.5	2.8	821,226.7	0.00	1.00
09/08/2024 12:00	-1	1.6	8.2	14.6	2.0	854,260.0	0.00	1.00
09/08/2024 13:00	-1	1.6	8.8	14.4	5.2	959,861.2	0.00	1.00
09/08/2024 14:00	0	2.1	12.5	13.0	15.7	1,031,748.6	0.00	1.00
09/08/2024 15:00	0	2.1	13.3	12.8	18.2	1,040,762.5	0.00	1.00
09/08/2024 16:00	1	2.2	14.5	12.3	22.5	1,028,660.6	0.00	1.00
09/08/2024 17:00	1	2.2	14.7	12.2	23.9	1,032,105.3	0.00	1.00
09/08/2024 18:00	0	2.2	14.4	12.4	21.5	1,038,184.8	0.00	1.00
09/08/2024 19:00	0	2.1	14.2	12.5	20.6	1,038,806.2	0.00	1.00
09/08/2024 20:00	0	2.1	13.9	12.6	20.0	1,045,382.3	0.00	1.00
09/08/2024 21:00	0	1.9	10.9	13.5	10.8	982,654.5	0.00	1.00
09/08/2024 22:00	-1	1.6	7.8	14.4	3.9	928,891.1	0.00	1.00
09/08/2024 23:00	-1	1.7	7.9	14.4	3.1	863,580.1	0.00	1.00
Average/Sum#:	-1	1.8	10.2	13.8	9.0	903,854.9	0.00 #	24.00 #
Minimum:	-1	1.6	7.8	12.2	2.0	804,848.1	0.00	1.00
Maximum:	1	2.2	14.7	14.6	23.9	1,045,382.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2024 00:00	-1	1.7	8.0	14.3	4.3	805,055.5	0.00	1.00
09/09/2024 01:00	-1	1.7	8.1	14.4	4.4	815,966.3	0.00	1.00
09/09/2024 02:00	-1	1.7	8.5	14.4	4.0	817,862.4	0.00	1.00
09/09/2024 03:00	-1	1.7	8.4	14.4	3.9	817,019.7	0.00	1.00
09/09/2024 04:00	-1	1.7	8.2	14.4	4.7	867,583.0	0.00	1.00
09/09/2024 05:00	-1	1.6	8.3	14.4	6.4	956,911.6	0.00	1.00
09/09/2024 06:00	-1	1.7	8.6	14.3	4.5	827,049.3	0.00	1.00
09/09/2024 07:00	-1	1.7	8.3	14.3	3.1	808,790.3	0.00	1.00
09/09/2024 08:00	-1	1.7	8.3	14.3	2.5	806,715.5	0.00	1.00
09/09/2024 09:00	-1	1.6	8.4	14.5	2.0	825,506.1	0.00	1.00
09/09/2024 10:00	-1	1.6	8.4	14.5	2.5	825,934.1	0.00	1.00
09/09/2024 11:00	-1	1.6	8.2	14.5	1.8	822,296.5	0.00	1.00
09/09/2024 12:00	-1	1.6	8.1	14.6	2.8	871,649.5	0.00	1.00
09/09/2024 13:00	-1	1.6	8.0	14.5	2.5	858,243.9	0.00	1.00
09/09/2024 14:00	-1	1.6	7.8	14.6	1.6	832,523.1	0.00	1.00
09/09/2024 15:00	-1	1.6	7.5	14.6	2.2	884,474.3	0.00	1.00
09/09/2024 16:00	-1	1.6	7.7	14.5	3.5	935,488.0	0.00	1.00
09/09/2024 17:00	0	1.8	9.5	13.9	8.9	940,794.6	0.00	1.00
09/09/2024 18:00	0	2.0	12.3	12.9	15.0	1,028,608.9	0.00	1.00
09/09/2024 19:00	0	1.7	9.5	13.9	6.9	932,186.7	0.00	1.00
09/09/2024 20:00	-1	1.6	7.8	14.4	2.7	849,253.8	0.00	1.00
09/09/2024 21:00	-1	1.6	8.1	14.5	3.3	845,833.5	0.00	1.00
09/09/2024 22:00	-1	1.7	8.0	14.4	3.8	814,491.5	0.00	1.00
09/09/2024 23:00	-1	1.6	8.0	14.5	5.7	928,854.9	0.00	1.00
Average/Sum#:	-1	1.7	8.4	14.3	4.3	863,295.5	0.00 #	24.00 #
Minimum:	-1	1.6	7.5	12.9	1.6	805,055.5	0.00	1.00
Maximum:	0	2.0	12.3	14.6	15.0	1,028,608.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2024 00:00	0	1.7	8.2	14.4	4.9	846,514.9	0.00	1.00
09/10/2024 01:00	-1	1.7	8.1	14.4	3.0	815,544.9	0.00	1.00
09/10/2024 02:00	-1	1.7	8.3	14.3	2.8	803,810.6	0.00	1.00
09/10/2024 03:00	-1	1.7	8.4	14.3	2.4	804,018.1	0.00	1.00
09/10/2024 04:00	-1	1.7	8.4	14.3	1.7	804,640.6	0.00	1.00
09/10/2024 05:00	-1	1.6	8.4	14.4	2.2	899,395.8	0.00	1.00
09/10/2024 06:00	-1	1.6	8.8	14.3	1.7	821,239.7	0.00	1.00
09/10/2024 07:00	-1	1.7	8.7	14.3	1.8	805,678.0	0.00	1.00
09/10/2024 08:00	-1	1.7	8.6	14.3	3.5	805,055.5	0.00	1.00
09/10/2024 09:00	-1	1.7	8.6	14.4	3.2	816,598.3	0.00	1.00
09/10/2024 10:00	-1	1.7	8.5	14.4	2.9	813,648.8	0.00	1.00
09/10/2024 11:00	-1	1.7	8.2	14.4	2.2	811,120.6	0.00	1.00
09/10/2024 12:00	-1	1.6	8.2	14.4	1.6	810,067.2	0.00	1.00
09/10/2024 13:00	-1	1.6	8.2	14.5	1.2	823,152.4	0.00	1.00
09/10/2024 14:00	-1	1.7	8.2	14.5	1.3	823,580.4	0.00	1.00
09/10/2024 15:00	-1	1.7	8.2	14.5	1.0	822,938.5	0.00	1.00
09/10/2024 16:00	-1	1.6	8.2	14.5	1.3	821,226.7	0.00	1.00
09/10/2024 17:00	-1	1.7	8.0	14.4	1.1	808,381.7	0.00	1.00
09/10/2024 18:00	-1	1.7	8.1	14.4	1.9	810,699.2	0.00	1.00
09/10/2024 19:00	-1	1.7	8.1	14.4	1.9	813,016.7	0.00	1.00
09/10/2024 20:00	-1	1.7	8.2	14.4	2.1	813,438.1	0.00	1.00
09/10/2024 21:00	-1	1.7	8.2	14.3	1.9	801,320.8	0.00	1.00
09/10/2024 22:00	-1	1.7	8.2	14.3	1.3	801,113.3	0.00	1.00
09/10/2024 23:00	-1	1.7	8.2	14.3	0.7	801,735.7	0.00	1.00
Average/Sum#:	-1	1.7	8.3	14.4	2.1	816,580.7	0.00 #	24.00 #
Minimum:	-1	1.6	8.0	14.3	0.7	801,113.3	0.00	1.00
Maximum:	0	1.7	8.8	14.5	4.9	899,395.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2024 00:00	0	1.7	8.3	14.3	0.4	801,943.2	0.00	1.00
09/11/2024 01:00	0	1.6	8.2	14.3	0.4	802,150.7	0.00	1.00
09/11/2024 02:00	-1	1.7	8.4	14.3	0.5	801,735.7	0.00	1.00
09/11/2024 03:00	-1	1.7	8.4	14.3	0.6	801,528.2	0.00	1.00
09/11/2024 04:00	-1	1.7	8.4	14.3	0.5	801,943.2	0.00	1.00
09/11/2024 05:00	-1	1.6	8.1	14.4	0.8	882,541.3	0.00	1.00
09/11/2024 06:00	-1	1.6	8.7	14.3	1.8	831,614.1	0.00	1.00
09/11/2024 07:00	-1	1.7	8.6	14.3	2.1	801,735.7	0.00	1.00
09/11/2024 08:00	-1	1.7	8.6	14.3	3.4	802,150.7	0.00	1.00
09/11/2024 09:00	-1	1.7	8.5	14.4	2.4	813,859.4	0.00	1.00
09/11/2024 10:00	-1	1.7	8.5	14.4	1.3	813,648.8	0.00	1.00
09/11/2024 11:00	-1	1.6	8.2	14.4	0.6	812,595.4	0.00	1.00
09/11/2024 12:00	0	1.6	8.0	14.4	0.1	811,331.3	0.00	1.00
09/11/2024 13:00	0	1.6	8.1	14.5	0.1	821,868.6	0.00	1.00
09/11/2024 14:00	-1	1.6	8.2	14.5	0.4	819,942.8	0.00	1.00
09/11/2024 15:00	-1	1.6	8.2	14.5	0.9	819,728.9	0.00	1.00
09/11/2024 16:00	-1	1.6	8.2	14.5	1.5	820,370.8	0.00	1.00
09/11/2024 17:00	-1	1.6	8.4	14.5	1.5	820,370.8	0.00	1.00
09/11/2024 18:00	-1	1.6	8.3	14.4	0.8	809,435.2	0.00	1.00
09/11/2024 19:00	-1	1.7	8.3	14.4	0.7	810,277.9	0.00	1.00
09/11/2024 20:00	-1	1.7	8.3	14.4	1.7	811,120.6	0.00	1.00
09/11/2024 21:00	-1	1.7	8.3	14.4	2.3	811,542.0	0.00	1.00
09/11/2024 22:00	-1	1.7	8.1	14.4	1.7	812,384.7	0.00	1.00
09/11/2024 23:00	-1	1.7	8.0	14.3	1.3	800,698.3	0.00	1.00
Average/Sum#:	-1	1.7	8.3	14.4	1.2	814,021.6	0.00 #	24.00 #
Minimum:	-1	1.6	8.0	14.3	0.1	800,698.3	0.00	1.00
Maximum:	0	1.7	8.7	14.5	3.4	882,541.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/12/2024 00:00	-1	1.7	8.0	14.3	1.1	801,528.2	0.00	1.00
09/12/2024 01:00	-1	1.7	8.1	14.3	1.6	801,528.2	0.00	1.00
09/12/2024 02:00	-1	1.7	8.3	14.3	1.3	802,150.7	0.00	1.00
09/12/2024 03:00	-1	1.7	8.2	14.3	1.5	802,358.2	0.00	1.00
09/12/2024 04:00	-1	1.7	8.1	14.3	1.3	802,773.2	0.00	1.00
09/12/2024 05:00	0	1.6	8.2	14.3	0.2	803,188.2	0.00	1.00
09/12/2024 06:00	0	1.5	8.2	14.3	0.0	803,810.6	0.00	1.00
09/12/2024 07:00	0	1.8	8.1	14.4	1.6	815,966.3	0.00	1.00
09/12/2024 08:00	-1	1.7	8.1	14.4	3.1	816,176.9	0.00	1.00
09/12/2024 09:00	-1	1.7	8.1	14.4	1.6	816,176.9	0.00	1.00
09/12/2024 10:00	-1	1.7	8.1	14.4	1.2	815,334.2	0.00	1.00
09/12/2024 11:00	-1	1.6	8.2	14.5	1.2	822,296.5	0.00	1.00
09/12/2024 12:00	-1	1.6	8.2	14.5	0.7	822,296.5	0.00	1.00
09/12/2024 13:00	-1	1.6	8.2	14.5	0.7	821,868.6	0.00	1.00
09/12/2024 14:00	-1	1.6	8.2	14.5	1.1	821,440.7	0.00	1.00
09/12/2024 15:00	-1	1.6	8.4	14.5	1.6	821,226.7	0.00	1.00
09/12/2024 16:00	-1	1.7	8.4	14.5	1.9	821,012.7	0.00	1.00
09/12/2024 17:00	-1	1.6	8.4	14.5	1.3	820,798.7	0.00	1.00
09/12/2024 18:00	0	1.6	8.4	14.5	0.2	821,226.7	0.00	1.00
09/12/2024 19:00	-1	1.6	8.3	14.5	0.4	822,082.6	0.00	1.00
09/12/2024 20:00	-1	1.6	8.4	14.5	1.1	823,366.4	0.00	1.00
09/12/2024 21:00	-1	1.7	8.4	14.5	2.0	825,292.2	0.00	1.00
09/12/2024 22:00	-1	1.6	8.4	14.4	2.6	814,280.8	0.00	1.00
09/12/2024 23:00	-1	1.6	8.5	14.4	2.3	817,651.7	0.00	1.00
Average/Sum#:	-1	1.6	8.2	14.4	1.3	814,826.4	0.00 #	24.00 #
Minimum:	-1	1.5	8.0	14.3	0.0	801,528.2	0.00	1.00
Maximum:	0	1.8	8.5	14.5	3.1	825,292.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2024 00:00	-1	1.7	8.4	14.4	1.7	813,859.4	0.00	1.00
09/13/2024 01:00	-1	1.7	8.4	14.4	1.5	813,227.4	0.00	1.00
09/13/2024 02:00	-1	1.7	8.6	14.4	1.3	813,438.1	0.00	1.00
09/13/2024 03:00	-1	1.7	8.6	14.4	2.5	813,227.4	0.00	1.00
09/13/2024 04:00	-1	1.7	8.5	14.4	2.7	827,343.0	0.00	1.00
09/13/2024 05:00	-1	1.6	8.4	14.5	4.5	957,313.2	0.00	1.00
09/13/2024 06:00	-1	1.6	8.9	14.4	4.3	887,597.7	0.00	1.00
09/13/2024 07:00	-1	1.7	8.6	14.4	2.8	815,123.5	0.00	1.00
09/13/2024 08:00	-1	1.7	8.7	14.4	3.3	814,702.2	0.00	1.00
09/13/2024 09:00	-1	1.6	8.3	14.5	1.7	824,436.3	0.00	1.00
09/13/2024 10:00	-1	1.6	8.3	14.5	1.0	822,510.5	0.00	1.00
09/13/2024 11:00	-1	1.6	8.2	14.5	0.6	826,576.0	0.00	1.00
09/13/2024 12:00	0	1.5	8.3	14.6	0.8	867,519.5	0.00	1.00
09/13/2024 13:00	-1	1.6	8.3	14.5	2.7	932,278.4	0.00	1.00
09/13/2024 14:00	-1	1.6	8.1	14.5	2.9	945,972.7	0.00	1.00
09/13/2024 15:00	0	1.6	8.2	14.5	3.3	937,413.8	0.00	1.00
09/13/2024 16:00	-1	1.6	8.8	14.4	5.1	1,003,261.4	0.00	1.00
09/13/2024 17:00	0	2.3	14.3	12.2	22.1	1,046,586.5	0.00	1.00
09/13/2024 18:00	0	2.1	13.9	12.4	20.3	1,042,534.7	0.00	1.00
09/13/2024 19:00	0	1.6	8.8	14.2	3.0	901,776.2	0.00	1.00
09/13/2024 20:00	-1	1.6	8.0	14.4	0.8	821,865.3	0.00	1.00
09/13/2024 21:00	-1	1.7	8.0	14.4	0.7	813,016.7	0.00	1.00
09/13/2024 22:00	-1	1.7	8.0	14.4	1.8	828,817.8	0.00	1.00
09/13/2024 23:00	-1	1.6	8.3	14.5	4.2	899,968.6	0.00	1.00
Average/Sum#:	-1	1.7	8.9	14.3	4.0	877,931.9	0.00 #	24.00 #
Minimum:	-1	1.5	8.0	12.2	0.6	813,016.7	0.00	1.00
Maximum:	0	2.3	14.3	14.6	22.1	1,046,586.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2024 00:00	-1	1.6	8.4	14.5	5.0	907,243.7	0.00	1.00
09/14/2024 01:00	-1	1.7	8.5	14.4	3.6	822,286.7	0.00	1.00
09/14/2024 02:00	-1	1.6	8.8	14.4	3.4	812,384.7	0.00	1.00
09/14/2024 03:00	-1	1.7	8.7	14.6	6.8	994,897.7	0.00	1.00
09/14/2024 04:00	-1	1.6	9.2	14.5	7.3	969,937.6	0.00	1.00
09/14/2024 05:00	-1	1.6	9.4	14.6	8.7	1,059,021.5	0.00	1.00
09/14/2024 06:00	-1	1.6	8.9	14.4	4.1	858,313.1	0.00	1.00
09/14/2024 07:00	-1	1.6	8.5	14.4	2.8	813,648.8	0.00	1.00
09/14/2024 08:00	-1	1.6	8.3	14.5	3.1	824,864.2	0.00	1.00
09/14/2024 09:00	-1	1.6	8.4	14.5	3.1	823,794.4	0.00	1.00
09/14/2024 10:00	-1	1.6	8.4	14.5	1.6	822,724.5	0.00	1.00
09/14/2024 11:00	-1	1.6	8.4	14.5	0.6	821,654.6	0.00	1.00
09/14/2024 12:00	-1	1.6	8.3	14.5	1.0	824,008.3	0.00	1.00
09/14/2024 13:00	-1	1.6	8.2	14.6	1.5	837,522.6	0.00	1.00
09/14/2024 14:00	-1	1.6	8.3	14.6	0.9	837,739.9	0.00	1.00
09/14/2024 15:00	-1	1.6	8.2	14.6	1.0	834,262.0	0.00	1.00
09/14/2024 16:00	-1	1.6	8.3	14.6	3.3	882,083.2	0.00	1.00
09/14/2024 17:00	-1	1.6	8.4	14.5	4.4	964,802.3	0.00	1.00
09/14/2024 18:00	-1	1.6	8.4	14.4	2.8	913,932.8	0.00	1.00
09/14/2024 19:00	-1	1.7	7.9	14.4	1.6	810,909.9	0.00	1.00
09/14/2024 20:00	-1	1.7	8.2	14.4	2.8	809,645.8	0.00	1.00
09/14/2024 21:00	-1	1.7	8.2	14.4	3.0	812,174.0	0.00	1.00
09/14/2024 22:00	-1	1.7	8.4	14.4	3.1	814,702.2	0.00	1.00
09/14/2024 23:00	-1	1.7	8.4	14.4	2.7	815,123.5	0.00	1.00
Average/Sum#:	-1	1.6	8.5	14.5	3.3	861,986.6	0.00 #	24.00 #
Minimum:	-1	1.6	7.9	14.4	0.6	809,645.8	0.00	1.00
Maximum:	-1	1.7	9.4	14.6	8.7	1,059,021.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2024 00:00	-1	1.7	8.3	14.4	2.5	815,544.9	0.00	1.00
09/15/2024 01:00	-1	1.7	8.5	14.4	2.3	815,755.6	0.00	1.00
09/15/2024 02:00	-1	1.7	8.6	14.4	1.6	816,387.6	0.00	1.00
09/15/2024 03:00	-1	1.6	8.7	14.4	1.6	816,809.0	0.00	1.00
09/15/2024 04:00	-1	1.7	8.5	14.4	0.8	817,230.3	0.00	1.00
09/15/2024 05:00	-1	1.7	8.6	14.4	0.5	817,862.4	0.00	1.00
09/15/2024 06:00	-1	1.7	8.4	14.4	0.5	817,441.0	0.00	1.00
09/15/2024 07:00	-1	1.7	8.5	14.4	1.9	817,230.3	0.00	1.00
09/15/2024 08:00	-1	1.7	8.5	14.4	2.5	816,598.3	0.00	1.00
09/15/2024 09:00	-1	1.7	8.3	14.4	2.0	815,334.2	0.00	1.00
09/15/2024 10:00	-1	1.7	8.3	14.4	2.2	812,806.0	0.00	1.00
09/15/2024 11:00	-1	1.7	8.3	14.4	2.0	810,488.6	0.00	1.00
09/15/2024 12:00	-1	1.7	8.3	14.4	2.2	810,067.2	0.00	1.00
09/15/2024 13:00	-1	1.6	8.2	14.4	1.8	809,856.5	0.00	1.00
09/15/2024 14:00	-1	1.7	8.1	14.5	1.9	821,654.6	0.00	1.00
09/15/2024 15:00	-1	1.6	8.2	14.4	2.2	809,856.5	0.00	1.00
09/15/2024 16:00	-1	1.7	8.2	14.5	3.3	880,711.1	0.00	1.00
09/15/2024 17:00	-1	1.6	8.6	14.4	3.3	812,595.4	0.00	1.00
09/15/2024 18:00	-1	1.7	8.3	14.4	2.8	811,120.6	0.00	1.00
09/15/2024 19:00	-1	1.7	8.4	14.4	2.5	812,174.0	0.00	1.00
09/15/2024 20:00	-1	1.7	8.5	14.4	2.0	814,491.5	0.00	1.00
09/15/2024 21:00	-1	1.7	8.4	14.4	1.0	813,438.1	0.00	1.00
09/15/2024 22:00	-1	1.7	8.5	14.4	0.6	813,648.8	0.00	1.00
09/15/2024 23:00	0	1.6	8.4	14.4	0.2	814,070.1	0.00	1.00
Average/Sum#:	-1	1.7	8.4	14.4	1.8	817,215.5	0.00 #	24.00 #
Minimum:	-1	1.6	8.1	14.4	0.2	809,856.5	0.00	1.00
Maximum:	0	1.7	8.7	14.5	3.3	880,711.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2024 00:00	0	1.6	8.5	14.4	0.1	814,702.2	0.00	1.00
09/16/2024 01:00	0	1.6	8.4	14.4	0.1	815,334.2	0.00	1.00
09/16/2024 02:00	0	1.6	8.6	14.4	0.1	816,387.6	0.00	1.00
09/16/2024 03:00	0	1.5	8.6	14.3	0.0	804,848.1	0.00	1.00
09/16/2024 04:00	0	1.4	8.7	14.3	0.0	807,337.9	0.00	1.00
09/16/2024 05:00	0	1.5	8.6	14.4	0.3	898,553.1	0.00	1.00
09/16/2024 06:00	0	1.4	9.0	14.4	1.7	892,232.7	0.00	1.00
09/16/2024 07:00	-1	1.6	8.4	14.5	2.2	1,001,605.6	0.00	1.00
09/16/2024 08:00	-1	1.6	9.7	14.3	6.7	1,040,555.0	0.00	1.00
09/16/2024 09:00	-1	1.6	8.6	14.6	5.0	1,053,152.6	0.00	1.00
09/16/2024 10:00	-1	1.6	8.6	14.6	6.2	1,055,761.0	0.00	1.00
09/16/2024 11:00	-1	1.6	8.9	14.6	7.4	1,054,674.1	0.00	1.00
09/16/2024 12:00	-1	1.6	8.6	14.5	5.3	924,789.4	0.00	1.00
09/16/2024 13:00	-1	1.7	8.3	14.4	2.7	812,384.7	0.00	1.00
09/16/2024 14:00	-1	1.6	8.4	14.4	2.8	811,120.6	0.00	1.00
09/16/2024 15:00	-1	1.7	8.3	14.4	2.4	812,174.0	0.00	1.00
09/16/2024 16:00	-1	1.6	8.4	14.5	4.0	883,706.7	0.00	1.00
09/16/2024 17:00	-1	1.6	8.7	14.4	3.9	823,550.8	0.00	1.00
09/16/2024 18:00	-1	1.6	8.6	14.4	3.2	818,283.7	0.00	1.00
09/16/2024 19:00	-1	1.7	8.6	14.4	3.7	819,126.5	0.00	1.00
09/16/2024 20:00	-1	1.6	8.9	14.5	7.3	975,500.9	0.00	1.00
09/16/2024 21:00	-1	1.5	9.0	14.5	5.5	923,933.5	0.00	1.00
09/16/2024 22:00	-1	1.6	8.7	14.5	6.2	966,942.0	0.00	1.00
09/16/2024 23:00	-1	1.6	8.8	14.4	3.1	838,509.1	0.00	1.00
Average/Sum#:	-1	1.6	8.7	14.4	3.3	894,381.9	0.00 #	24.00 #
Minimum:	-1	1.4	8.3	14.3	0.0	804,848.1	0.00	1.00
Maximum:	0	1.7	9.7	14.6	7.4	1,055,761.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2024 00:00	-1	1.7	8.5	14.4	2.4	815,123.5	0.00	1.00
09/17/2024 01:00	-1	1.7	8.4	14.4	2.1	815,966.3	0.00	1.00
09/17/2024 02:00	-1	1.7	8.6	14.4	1.9	816,176.9	0.00	1.00
09/17/2024 03:00	-1	1.7	8.6	14.4	1.9	816,809.0	0.00	1.00
09/17/2024 04:00	-1	1.7	8.3	14.4	1.6	861,684.0	0.00	1.00
09/17/2024 05:00	-1	1.6	8.8	14.5	3.4	974,645.0	0.00	1.00
09/17/2024 06:00	0	1.5	9.2	14.3	2.0	848,005.7	0.00	1.00
09/17/2024 07:00	-1	1.7	8.9	14.3	1.0	808,790.3	0.00	1.00
09/17/2024 08:00	-1	1.7	8.9	14.4	3.1	822,286.7	0.00	1.00
09/17/2024 09:00	-1	1.7	9.0	14.4	3.3	822,076.0	0.00	1.00
09/17/2024 10:00	-1	1.7	8.9	14.4	3.1	819,969.2	0.00	1.00
09/17/2024 11:00	-1	1.7	8.5	14.4	2.4	818,915.8	0.00	1.00
09/17/2024 12:00	-1	1.6	8.4	14.4	2.5	821,865.3	0.00	1.00
09/17/2024 13:00	-1	1.7	8.4	14.5	2.8	831,925.3	0.00	1.00
09/17/2024 14:00	-1	1.6	8.4	14.5	2.4	829,999.6	0.00	1.00
09/17/2024 15:00	-1	1.6	8.4	14.5	2.3	830,213.5	0.00	1.00
09/17/2024 16:00	-1	1.7	8.5	14.5	3.1	829,571.6	0.00	1.00
09/17/2024 17:00	-1	1.6	8.5	14.5	3.2	829,571.6	0.00	1.00
09/17/2024 18:00	-1	1.7	8.4	14.4	2.8	817,019.7	0.00	1.00
09/17/2024 19:00	-1	1.7	8.4	14.4	2.8	818,283.7	0.00	1.00
09/17/2024 20:00	-1	1.7	8.3	14.4	2.3	817,862.4	0.00	1.00
09/17/2024 21:00	-1	1.7	8.4	14.4	2.8	818,283.7	0.00	1.00
09/17/2024 22:00	-1	1.7	8.4	14.4	2.5	818,494.4	0.00	1.00
09/17/2024 23:00	-1	1.7	8.5	14.4	2.2	818,705.1	0.00	1.00
Average/Sum#:	-1	1.7	8.6	14.4	2.5	830,093.5	0.00 #	24.00 #
Minimum:	-1	1.5	8.3	14.3	1.0	808,790.3	0.00	1.00
Maximum:	0	1.7	9.2	14.5	3.4	974,645.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/18/2024 00:00	-1	1.7	8.4	14.4	1.9	819,126.5	0.00	1.00
09/18/2024 01:00	-1	1.7	8.5	14.4	1.3	818,494.4	0.00	1.00
09/18/2024 02:00	-1	1.6	8.6	14.4	0.8	814,070.1	0.00	1.00
09/18/2024 03:00	-1	1.7	8.6	14.3	0.8	801,943.2	0.00	1.00
09/18/2024 04:00	-1	1.6	8.4	14.3	0.8	804,848.1	0.00	1.00
09/18/2024 05:00	-1	1.7	8.4	14.4	1.0	827,553.7	0.00	1.00
09/18/2024 06:00	0	1.6	8.5	14.4	2.2	871,164.6	0.00	1.00
09/18/2024 07:00	-1	1.7	8.4	14.3	0.7	804,433.1	0.00	1.00
09/18/2024 08:00	-1	1.6	8.3	14.4	1.2	814,912.8	0.00	1.00
09/18/2024 09:00	-1	1.7	8.3	14.4	1.4	815,544.9	0.00	1.00
09/18/2024 10:00	-1	1.7	8.3	14.4	1.8	814,912.8	0.00	1.00
09/18/2024 11:00	-1	1.7	8.4	14.4	1.9	814,491.5	0.00	1.00
09/18/2024 12:00	-1	1.7	8.3	14.5	2.5	827,859.8	0.00	1.00
09/18/2024 13:00	-1	1.6	8.4	14.5	3.2	828,715.7	0.00	1.00
09/18/2024 14:00	-1	1.6	8.4	14.5	2.7	827,645.9	0.00	1.00
09/18/2024 15:00	-1	1.7	8.4	14.5	2.7	828,073.8	0.00	1.00
09/18/2024 16:00	-1	1.6	8.5	14.6	5.2	930,339.1	0.00	1.00
09/18/2024 17:00	-1	1.6	8.7	14.5	4.8	922,649.7	0.00	1.00
09/18/2024 18:00	-1	1.6	8.5	14.4	2.3	813,227.4	0.00	1.00
09/18/2024 19:00	-1	1.7	8.1	14.4	2.0	813,438.1	0.00	1.00
09/18/2024 20:00	-1	1.6	8.7	14.6	7.8	1,044,892.5	0.00	1.00
09/18/2024 21:00	-1	1.6	9.2	14.6	8.3	1,056,630.5	0.00	1.00
09/18/2024 22:00	-1	1.6	9.2	14.6	8.1	1,056,630.5	0.00	1.00
09/18/2024 23:00	-1	1.6	8.7	14.6	6.6	1,052,935.2	0.00	1.00
Average/Sum#:	-1	1.6	8.5	14.5	3.0	867,688.9	0.00 #	24.00 #
Minimum:	-1	1.6	8.1	14.3	0.7	801,943.2	0.00	1.00
Maximum:	0	1.7	9.2	14.6	8.3	1,056,630.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/19/2024 00:00	-1	1.6	8.6	14.6	6.5	1,057,717.3	0.00	1.00
09/19/2024 01:00	-1	1.6	8.5	14.6	6.1	1,036,632.5	0.00	1.00
09/19/2024 02:00	-1	1.5	8.4	14.5	5.6	995,828.3	0.00	1.00
09/19/2024 03:00	-1	1.6	8.8	14.5	6.8	1,037,339.0	0.00	1.00
09/19/2024 04:00	-1	1.6	8.6	14.5	6.4	1,035,627.2	0.00	1.00
09/19/2024 05:00	-1	1.6	8.6	14.5	5.9	1,034,343.4	0.00	1.00
09/19/2024 06:00	-1	1.5	8.8	14.4	3.2	889,283.1	0.00	1.00
09/19/2024 07:00	-1	1.6	8.2	14.6	4.9	1,029,024.6	0.00	1.00
09/19/2024 08:00	-1	1.6	8.4	14.4	3.1	851,782.0	0.00	1.00
09/19/2024 09:00	-1	1.7	8.1	14.4	2.0	809,856.5	0.00	1.00
09/19/2024 10:00	-1	1.6	8.1	14.5	2.2	824,008.3	0.00	1.00
09/19/2024 11:00	-1	1.6	8.2	14.5	1.4	821,654.6	0.00	1.00
09/19/2024 12:00	-1	1.6	8.2	14.5	1.4	822,082.6	0.00	1.00
09/19/2024 13:00	-1	1.6	8.2	14.5	1.1	820,156.8	0.00	1.00
09/19/2024 14:00	-1	1.6	8.3	14.5	1.3	819,728.9	0.00	1.00
09/19/2024 15:00	-1	1.6	8.3	14.5	1.3	819,514.9	0.00	1.00
09/19/2024 16:00	-1	1.6	8.4	14.6	3.7	919,470.7	0.00	1.00
09/19/2024 17:00	-1	1.6	9.0	14.4	6.4	1,013,584.7	0.00	1.00
09/19/2024 18:00	0	2.1	13.0	12.9	16.2	1,039,393.1	0.00	1.00
09/19/2024 19:00	0	1.9	11.1	13.5	11.5	1,027,068.3	0.00	1.00
09/19/2024 20:00	-1	1.6	8.1	14.6	6.1	1,051,631.0	0.00	1.00
09/19/2024 21:00	-1	1.6	8.1	14.5	5.6	1,012,946.1	0.00	1.00
09/19/2024 22:00	-1	1.6	8.2	14.4	2.7	821,865.3	0.00	1.00
09/19/2024 23:00	-1	1.6	8.3	14.4	3.0	817,230.3	0.00	1.00
Average/Sum#:	-1	1.6	8.7	14.4	4.8	933,657.1	0.00 #	24.00 #
Minimum:	-1	1.5	8.1	12.9	1.1	809,856.5	0.00	1.00
Maximum:	0	2.1	13.0	14.6	16.2	1,057,717.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2024 00:00	-1	1.7	8.3	14.4	2.6	807,960.4	0.00	1.00
09/20/2024 01:00	-1	1.7	8.3	14.4	2.2	806,907.0	0.00	1.00
09/20/2024 02:00	-1	1.7	8.6	14.4	2.3	805,010.9	0.00	1.00
09/20/2024 03:00	-1	1.7	9.1	14.4	3.1	805,010.9	0.00	1.00
09/20/2024 04:00	-1	1.7	8.8	14.4	1.7	822,918.7	0.00	1.00
09/20/2024 05:00	-1	1.6	8.5	14.4	2.3	870,321.9	0.00	1.00
09/20/2024 06:00	-1	1.6	9.0	14.3	2.1	822,692.1	0.00	1.00
09/20/2024 07:00	-1	1.7	8.9	14.4	1.8	809,435.2	0.00	1.00
09/20/2024 08:00	-1	1.7	8.7	14.4	1.9	806,064.3	0.00	1.00
09/20/2024 09:00	-1	1.7	8.7	14.4	2.1	810,488.6	0.00	1.00
09/20/2024 10:00	-1	1.6	8.4	14.5	3.7	875,361.7	0.00	1.00
09/20/2024 11:00	-1	1.6	8.4	14.6	5.5	1,024,242.5	0.00	1.00
09/20/2024 12:00	-1	1.6	8.4	14.5	4.7	1,007,810.8	0.00	1.00
09/20/2024 13:00	0	1.6	8.1	14.5	3.0	917,728.3	0.00	1.00
09/20/2024 14:00	-1	1.6	8.1	14.5	2.6	902,750.2	0.00	1.00
09/20/2024 15:00	-1	1.6	8.1	14.6	1.1	826,654.1	0.00	1.00
09/20/2024 16:00	-1	1.6	8.0	14.6	2.0	870,562.6	0.00	1.00
09/20/2024 17:00	0	1.5	8.1	14.5	2.3	872,794.1	0.00	1.00
09/20/2024 18:00	-1	1.6	8.1	14.5	1.2	813,309.7	0.00	1.00
09/20/2024 19:00	-1	1.6	8.1	14.5	1.9	814,165.6	0.00	1.00
09/20/2024 20:00	-1	1.6	8.1	14.5	2.7	815,449.4	0.00	1.00
09/20/2024 21:00	-1	1.6	8.2	14.5	2.6	816,091.3	0.00	1.00
09/20/2024 22:00	-1	1.6	8.3	14.4	2.5	802,904.1	0.00	1.00
09/20/2024 23:00	-1	1.7	8.3	14.4	2.7	802,904.1	0.00	1.00
Average/Sum#:	-1	1.6	8.4	14.5	2.5	847,064.1	0.00 #	24.00 #
Minimum:	-1	1.5	8.0	14.3	1.1	802,904.1	0.00	1.00
Maximum:	0	1.7	9.1	14.6	5.5	1,024,242.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/21/2024 00:00	-1	1.7	8.4	14.4	2.5	803,957.5	0.00	1.00
09/21/2024 01:00	-1	1.7	8.3	14.4	2.5	804,378.8	0.00	1.00
09/21/2024 02:00	-1	1.7	8.7	14.4	2.3	809,013.8	0.00	1.00
09/21/2024 03:00	-1	1.7	8.5	14.5	2.9	868,728.6	0.00	1.00
09/21/2024 04:00	-1	1.6	8.9	14.5	4.9	920,723.9	0.00	1.00
09/21/2024 05:00	-1	1.6	8.7	14.4	2.3	821,443.9	0.00	1.00
09/21/2024 06:00	-1	1.6	8.6	14.4	3.0	865,897.6	0.00	1.00
09/21/2024 07:00	-1	1.7	8.3	14.4	1.8	810,277.9	0.00	1.00
09/21/2024 08:00	-1	1.7	8.4	14.4	2.3	809,013.8	0.00	1.00
09/21/2024 09:00	-1	1.7	8.3	14.4	1.9	805,853.6	0.00	1.00
09/21/2024 10:00	-1	1.6	8.4	14.5	2.6	818,231.1	0.00	1.00
09/21/2024 11:00	-1	1.6	8.2	14.5	2.9	889,697.9	0.00	1.00
09/21/2024 12:00	-1	1.6	8.2	14.5	4.0	946,400.6	0.00	1.00
09/21/2024 13:00	-1	1.6	8.5	14.5	4.8	1,014,229.9	0.00	1.00
09/21/2024 14:00	-1	1.6	8.3	14.5	4.1	1,003,745.3	0.00	1.00
09/21/2024 15:00	0	1.6	7.9	14.5	2.5	884,348.6	0.00	1.00
09/21/2024 16:00	0	2.0	11.7	13.3	12.8	1,021,662.7	0.00	1.00
09/21/2024 17:00	0	2.1	13.8	12.6	18.2	1,023,108.5	0.00	1.00
09/21/2024 18:00	0	1.9	11.4	13.4	11.6	1,025,607.6	0.00	1.00
09/21/2024 19:00	0	1.8	9.9	13.9	9.3	1,003,592.4	0.00	1.00
09/21/2024 20:00	-1	1.6	8.3	14.5	3.5	858,671.9	0.00	1.00
09/21/2024 21:00	-1	1.6	8.1	14.5	3.2	840,698.2	0.00	1.00
09/21/2024 22:00	-1	1.6	8.2	14.5	3.2	831,711.3	0.00	1.00
09/21/2024 23:00	-1	1.7	8.2	14.4	2.6	803,536.1	0.00	1.00
Average/Sum#:	-1	1.7	8.9	14.3	4.7	886,855.5	0.00 #	24.00 #
Minimum:	-1	1.6	7.9	12.6	1.8	803,536.1	0.00	1.00
Maximum:	0	2.1	13.8	14.5	18.2	1,025,607.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/22/2024 00:00	-1	1.7	8.3	14.4	2.5	807,960.4	0.00	1.00
09/22/2024 01:00	-1	1.7	8.2	14.4	2.4	804,800.2	0.00	1.00
09/22/2024 02:00	-1	1.7	8.5	14.4	2.2	804,378.8	0.00	1.00
09/22/2024 03:00	-1	1.7	8.4	14.4	2.1	803,957.5	0.00	1.00
09/22/2024 04:00	-1	1.7	8.4	14.4	2.0	804,168.1	0.00	1.00
09/22/2024 05:00	-1	1.7	8.4	14.4	1.8	804,589.5	0.00	1.00
09/22/2024 06:00	-1	1.7	8.4	14.4	2.1	805,642.9	0.00	1.00
09/22/2024 07:00	-1	1.7	8.4	14.4	1.9	809,224.5	0.00	1.00
09/22/2024 08:00	-1	1.7	8.4	14.4	2.4	809,013.8	0.00	1.00
09/22/2024 09:00	-1	1.6	8.3	14.5	2.3	819,087.0	0.00	1.00
09/22/2024 10:00	-1	1.6	8.4	14.5	1.9	818,231.1	0.00	1.00
09/22/2024 11:00	-1	1.6	8.2	14.5	1.2	816,947.2	0.00	1.00
09/22/2024 12:00	-1	1.6	8.3	14.5	1.4	815,877.4	0.00	1.00
09/22/2024 13:00	-1	1.7	8.3	14.6	5.7	1,003,375.1	0.00	1.00
09/22/2024 14:00	-1	1.6	8.1	14.5	2.9	895,047.2	0.00	1.00
09/22/2024 15:00	-1	1.7	7.8	14.4	0.8	803,114.7	0.00	1.00
09/22/2024 16:00	-1	1.7	7.8	14.5	3.6	885,846.4	0.00	1.00
09/22/2024 17:00	-1	1.6	8.3	14.5	2.1	816,091.3	0.00	1.00
09/22/2024 18:00	-1	1.6	8.2	14.5	1.9	811,383.9	0.00	1.00
09/22/2024 19:00	-1	1.6	8.3	14.5	2.3	812,239.8	0.00	1.00
09/22/2024 20:00	-1	1.6	8.3	14.5	2.5	808,602.3	0.00	1.00
09/22/2024 21:00	-1	1.6	8.2	14.5	2.9	809,030.2	0.00	1.00
09/22/2024 22:00	-1	1.6	8.3	14.5	3.0	812,239.8	0.00	1.00
09/22/2024 23:00	-1	1.6	8.2	14.4	2.4	803,536.1	0.00	1.00
Average/Sum#:	-1	1.7	8.3	14.5	2.3	824,349.4	0.00 #	24.00 #
Minimum:	-1	1.6	7.8	14.4	0.8	803,114.7	0.00	1.00
Maximum:	-1	1.7	8.5	14.6	5.7	1,003,375.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2024 00:00	-1	1.7	8.3	14.4	2.8	803,957.5	0.00	1.00
09/23/2024 01:00	-1	1.7	8.3	14.4	2.8	804,589.5	0.00	1.00
09/23/2024 02:00	-1	1.6	8.6	14.4	2.6	803,746.8	0.00	1.00
09/23/2024 03:00	-1	1.7	8.6	14.4	3.3	803,536.1	0.00	1.00
09/23/2024 04:00	-1	1.7	8.6	14.4	2.9	803,325.4	0.00	1.00
09/23/2024 05:00	-1	1.7	8.5	14.4	1.1	803,746.8	0.00	1.00
09/23/2024 06:00	-1	1.6	8.5	14.4	1.5	810,277.9	0.00	1.00
09/23/2024 07:00	-1	1.7	8.6	14.4	2.0	804,589.5	0.00	1.00
09/23/2024 08:00	-1	1.6	8.4	14.5	2.6	815,663.4	0.00	1.00
09/23/2024 09:00	-1	1.6	8.5	14.5	2.6	816,305.3	0.00	1.00
09/23/2024 10:00	-1	1.6	8.4	14.6	1.9	831,871.0	0.00	1.00
09/23/2024 11:00	-1	1.6	8.4	14.6	1.8	831,001.5	0.00	1.00
09/23/2024 12:00	-1	1.6	8.3	14.6	3.2	841,217.8	0.00	1.00
09/23/2024 13:00	-1	1.6	8.0	14.6	3.0	891,647.4	0.00	1.00
09/23/2024 14:00	-1	1.6	7.8	14.5	2.7	892,693.5	0.00	1.00
09/23/2024 15:00	-1	1.6	7.9	14.5	3.5	905,531.9	0.00	1.00
09/23/2024 16:00	0	1.9	10.1	13.7	10.4	981,420.8	0.00	1.00
09/23/2024 17:00	0	2.1	13.5	12.6	17.8	1,009,744.2	0.00	1.00
09/23/2024 18:00	0	2.0	12.3	13.0	14.5	1,014,934.1	0.00	1.00
09/23/2024 19:00	0	1.9	11.1	13.5	11.1	984,690.2	0.00	1.00
09/23/2024 20:00	-1	1.6	7.8	14.6	5.2	1,017,286.7	0.00	1.00
09/23/2024 21:00	-1	1.6	8.1	14.6	5.7	1,014,895.6	0.00	1.00
09/23/2024 22:00	-1	1.6	7.7	14.5	5.3	985,771.6	0.00	1.00
09/23/2024 23:00	-1	1.6	8.0	14.5	5.1	940,195.4	0.00	1.00
Average/Sum#:	-1	1.7	8.8	14.3	4.8	883,860.0	0.00 #	24.00 #
Minimum:	-1	1.6	7.7	12.6	1.1	803,325.4	0.00	1.00
Maximum:	0	2.1	13.5	14.6	17.8	1,017,286.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2024 00:00	-1	1.6	7.9	14.5	5.0	934,204.2	0.00	1.00
09/24/2024 01:00	-1	1.6	8.4	14.4	3.4	813,859.4	0.00	1.00
09/24/2024 02:00	-1	1.7	8.6	14.4	2.7	804,168.1	0.00	1.00
09/24/2024 03:00	-1	1.7	8.5	14.5	3.6	853,108.6	0.00	1.00
09/24/2024 04:00	-1	1.6	8.7	14.6	6.6	981,203.4	0.00	1.00
09/24/2024 05:00	-1	1.6	8.5	14.6	7.1	1,018,590.9	0.00	1.00
09/24/2024 06:00	-1	1.6	8.7	14.4	4.7	854,520.8	0.00	1.00
09/24/2024 07:00	-1	1.6	8.4	14.4	2.4	802,904.1	0.00	1.00
09/24/2024 08:00	-1	1.6	8.4	14.5	3.1	808,388.3	0.00	1.00
09/24/2024 09:00	-1	1.6	8.4	14.5	2.5	812,453.8	0.00	1.00
09/24/2024 10:00	-1	1.6	8.5	14.6	1.6	828,610.4	0.00	1.00
09/24/2024 11:00	-1	1.6	8.3	14.6	2.6	826,002.0	0.00	1.00
09/24/2024 12:00	-1	1.6	7.7	14.6	2.9	899,038.0	0.00	1.00
09/24/2024 13:00	-1	1.6	7.9	14.6	3.6	962,944.4	0.00	1.00
09/24/2024 14:00	-1	1.6	7.8	14.6	4.5	971,421.8	0.00	1.00
09/24/2024 15:00	-1	1.6	7.8	14.5	2.5	862,737.4	0.00	1.00
09/24/2024 16:00	0	1.7	8.6	14.2	6.4	887,673.1	0.00	1.00
09/24/2024 17:00	0	2.0	11.5	13.3	13.6	1,007,608.0	0.00	1.00
09/24/2024 18:00	0	1.7	9.4	14.0	7.2	926,048.4	0.00	1.00
09/24/2024 19:00	-1	1.6	8.0	14.6	2.5	826,871.5	0.00	1.00
09/24/2024 20:00	-1	1.6	8.2	14.5	2.6	815,449.4	0.00	1.00
09/24/2024 21:00	-1	1.6	8.2	14.5	3.5	815,663.4	0.00	1.00
09/24/2024 22:00	-1	1.6	8.2	14.5	3.5	814,165.6	0.00	1.00
09/24/2024 23:00	-1	1.6	8.3	14.5	3.5	816,947.2	0.00	1.00
Average/Sum#:	-1	1.6	8.5	14.4	4.2	872,690.9	0.00 #	24.00 #
Minimum:	-1	1.6	7.7	13.3	1.6	802,904.1	0.00	1.00
Maximum:	0	2.0	11.5	14.6	13.6	1,018,590.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/25/2024 00:00	-1	1.6	8.4	14.5	3.5	817,161.2	0.00	1.00
09/25/2024 01:00	-1	1.7	8.4	14.4	3.4	804,168.1	0.00	1.00
09/25/2024 02:00	-1	1.7	8.7	14.4	3.2	806,485.6	0.00	1.00
09/25/2024 03:00	-1	1.7	8.5	14.4	3.1	808,171.1	0.00	1.00
09/25/2024 04:00	-1	1.6	8.4	14.4	3.3	841,037.3	0.00	1.00
09/25/2024 05:00	-1	1.6	8.3	14.5	3.3	915,802.6	0.00	1.00
09/25/2024 06:00	-1	1.6	8.5	14.4	2.2	834,295.5	0.00	1.00
09/25/2024 07:00	-1	1.7	8.1	14.4	1.1	800,165.2	0.00	1.00
09/25/2024 08:00	-1	1.6	8.3	14.5	4.6	937,841.7	0.00	1.00
09/25/2024 09:00	-1	1.6	8.4	14.4	2.7	833,874.1	0.00	1.00
09/25/2024 10:00	-1	1.7	8.0	14.4	1.5	807,539.0	0.00	1.00
09/25/2024 11:00	-1	1.6	8.2	14.4	1.8	798,901.1	0.00	1.00
09/25/2024 12:00	-1	1.6	8.1	14.5	1.7	810,100.1	0.00	1.00
09/25/2024 13:00	-1	1.6	8.1	14.5	1.6	811,383.9	0.00	1.00
09/25/2024 14:00	-1	1.6	8.0	14.5	1.0	807,318.5	0.00	1.00
09/25/2024 15:00	-1	1.6	8.1	14.5	1.0	807,532.4	0.00	1.00
09/25/2024 16:00	-1	1.6	7.9	14.5	2.2	850,968.9	0.00	1.00
09/25/2024 17:00	-1	1.6	7.9	14.3	1.7	794,473.6	0.00	1.00
09/25/2024 18:00	-1	1.7	7.8	14.3	1.6	791,568.8	0.00	1.00
09/25/2024 19:00	-1	1.7	7.9	14.3	1.8	788,456.5	0.00	1.00
09/25/2024 20:00	-1	1.7	8.0	14.3	1.9	789,286.4	0.00	1.00
09/25/2024 21:00	-1	1.7	8.1	14.3	1.4	790,116.4	0.00	1.00
09/25/2024 22:00	-1	1.7	8.3	14.3	1.0	789,908.9	0.00	1.00
09/25/2024 23:00	-1	1.7	8.5	14.3	0.4	790,531.3	0.00	1.00
Average/Sum#:	-1	1.6	8.2	14.4	2.1	817,795.3	0.00 #	24.00 #
Minimum:	-1	1.6	7.8	14.3	0.4	788,456.5	0.00	1.00
Maximum:	-1	1.7	8.7	14.5	4.6	937,841.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/26/2024 00:00	0	1.6	8.5	14.3	0.1	790,738.8	0.00	1.00
09/26/2024 01:00	0	1.6	8.5	14.3	0.0	790,738.8	0.00	1.00
09/26/2024 02:00	0	1.6	8.9	14.3	0.1	791,361.3	0.00	1.00
09/26/2024 03:00	0	1.4	8.8	14.3	0.0	790,946.3	0.00	1.00
09/26/2024 04:00	0	1.5	8.9	14.3	0.0	791,361.3	0.00	1.00
09/26/2024 05:00	0	1.6	8.7	14.3	0.0	791,568.8	0.00	1.00
09/26/2024 06:00	0	1.6	8.7	14.3	0.0	792,191.3	0.00	1.00
09/26/2024 07:00	0	1.6	8.7	14.3	0.1	793,021.2	0.00	1.00
09/26/2024 08:00	0	1.5	8.6	14.3	0.1	793,228.7	0.00	1.00
09/26/2024 09:00	-1	1.7	8.5	14.4	1.2	803,325.4	0.00	1.00
09/26/2024 10:00	-1	1.7	8.6	14.4	1.8	800,797.2	0.00	1.00
09/26/2024 11:00	-1	1.7	8.2	14.4	2.6	800,375.9	0.00	1.00
09/26/2024 12:00	-1	1.6	8.1	14.5	2.7	816,519.3	0.00	1.00
09/26/2024 13:00	-1	1.6	8.1	14.5	2.1	814,807.5	0.00	1.00
09/26/2024 14:00	-1	1.6	8.1	14.5	2.1	813,095.7	0.00	1.00
09/26/2024 15:00	-1	1.6	8.2	14.5	2.0	811,170.0	0.00	1.00
09/26/2024 16:00	0	1.7	8.5	14.3	4.7	917,721.8	0.00	1.00
09/26/2024 17:00	0	2.0	11.6	13.3	12.7	1,025,446.6	0.00	1.00
09/26/2024 18:00	0	2.0	11.4	13.3	12.3	1,027,608.9	0.00	1.00
09/26/2024 19:00	0	1.9	11.2	13.5	12.3	1,043,353.3	0.00	1.00
09/26/2024 20:00	0	1.9	11.4	13.4	13.3	1,044,231.7	0.00	1.00
09/26/2024 21:00	0	1.7	9.5	14.1	7.6	965,242.8	0.00	1.00
09/26/2024 22:00	-1	1.6	8.1	14.4	3.9	879,170.5	0.00	1.00
09/26/2024 23:00	-1	1.6	8.4	14.4	3.0	813,016.7	0.00	1.00
Average/Sum#:	0	1.7	9.0	14.2	3.5	854,210.0	0.00 #	24.00 #
Minimum:	-1	1.4	8.1	13.3	0.0	790,738.8	0.00	1.00
Maximum:	0	2.0	11.6	14.5	13.3	1,044,231.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/27/2024 00:00	-1	1.7	8.3	14.4	2.7	798,901.1	0.00	1.00
09/27/2024 01:00	-1	1.7	8.3	14.4	2.5	799,533.2	0.00	1.00
09/27/2024 02:00	-1	1.7	8.8	14.4	2.6	799,533.2	0.00	1.00
09/27/2024 03:00	-1	1.7	8.6	14.4	2.4	800,797.2	0.00	1.00
09/27/2024 04:00	-1	1.7	8.5	14.5	3.4	924,789.4	0.00	1.00
09/27/2024 05:00	-1	1.5	8.7	14.5	3.2	972,719.3	0.00	1.00
09/27/2024 06:00	0	1.5	9.1	14.4	2.3	869,057.8	0.00	1.00
09/27/2024 07:00	-1	1.6	8.8	14.4	1.6	802,482.7	0.00	1.00
09/27/2024 08:00	-1	1.7	8.6	14.4	2.6	800,797.2	0.00	1.00
09/27/2024 09:00	-1	1.6	8.4	14.4	2.6	799,111.8	0.00	1.00
09/27/2024 10:00	-1	1.6	8.2	14.5	1.9	810,742.0	0.00	1.00
09/27/2024 11:00	-1	1.6	8.2	14.5	2.0	809,458.2	0.00	1.00
09/27/2024 12:00	-1	1.6	8.2	14.5	2.3	805,606.7	0.00	1.00
09/27/2024 13:00	-1	1.6	8.3	14.6	2.8	817,742.0	0.00	1.00
09/27/2024 14:00	-1	1.6	8.2	14.6	2.2	816,655.1	0.00	1.00
09/27/2024 15:00	-1	1.6	8.2	14.6	2.7	823,828.3	0.00	1.00
09/27/2024 16:00	0	1.6	8.7	14.2	5.5	906,681.6	0.00	1.00
09/27/2024 17:00	0	1.9	11.1	13.6	10.9	1,018,439.0	0.00	1.00
09/27/2024 18:00	-1	1.9	11.1	13.6	10.6	1,016,187.9	0.00	1.00
09/27/2024 19:00	-1	1.8	10.3	13.9	9.5	1,002,223.0	0.00	1.00
09/27/2024 20:00	-1	1.6	7.8	14.5	5.3	998,609.9	0.00	1.00
09/27/2024 21:00	-1	1.6	8.1	14.5	5.3	963,090.5	0.00	1.00
09/27/2024 22:00	-1	1.7	8.4	14.6	5.7	970,987.1	0.00	1.00
09/27/2024 23:00	-1	1.6	8.2	14.5	6.2	1,018,723.4	0.00	1.00
Average/Sum#:	-1	1.7	8.7	14.4	4.1	881,112.4	0.00 #	24.00 #
Minimum:	-1	1.5	7.8	13.6	1.6	798,901.1	0.00	1.00
Maximum:	0	1.9	11.1	14.6	10.9	1,018,723.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/28/2024 00:00	-1	1.6	8.4	14.5	6.1	982,776.0	0.00	1.00
09/28/2024 01:00	-1	1.6	8.6	14.4	4.4	857,049.0	0.00	1.00
09/28/2024 02:00	-1	1.7	9.1	14.4	4.1	797,847.7	0.00	1.00
09/28/2024 03:00	-1	1.6	9.2	14.4	4.3	798,479.8	0.00	1.00
09/28/2024 04:00	-1	1.7	9.2	14.4	4.4	800,375.9	0.00	1.00
09/28/2024 05:00	-1	1.7	9.0	14.4	3.5	805,010.9	0.00	1.00
09/28/2024 06:00	-1	1.7	8.7	14.4	1.7	802,272.0	0.00	1.00
09/28/2024 07:00	-1	1.7	8.6	14.4	2.8	799,111.8	0.00	1.00
09/28/2024 08:00	-1	1.6	8.6	14.5	3.2	809,458.2	0.00	1.00
09/28/2024 09:00	-1	1.6	8.6	14.5	2.6	807,318.5	0.00	1.00
09/28/2024 10:00	-1	1.6	8.6	14.5	2.0	806,034.6	0.00	1.00
09/28/2024 11:00	-1	1.6	8.5	14.6	1.8	817,307.3	0.00	1.00
09/28/2024 12:00	-1	1.6	8.2	14.6	2.5	816,872.5	0.00	1.00
09/28/2024 13:00	-1	1.6	8.1	14.6	1.6	822,741.5	0.00	1.00
09/28/2024 14:00	-1	1.6	8.1	14.6	2.5	863,172.1	0.00	1.00
09/28/2024 15:00	-1	1.6	7.8	14.5	2.1	872,366.1	0.00	1.00
09/28/2024 16:00	0	1.7	8.8	14.2	5.7	899,936.7	0.00	1.00
09/28/2024 17:00	-1	1.9	11.1	13.6	10.4	1,014,874.8	0.00	1.00
09/28/2024 18:00	-1	1.8	11.0	13.7	10.5	1,025,546.7	0.00	1.00
09/28/2024 19:00	-1	1.8	10.1	13.9	9.5	995,962.8	0.00	1.00
09/28/2024 20:00	-1	1.6	8.1	14.4	3.0	802,061.3	0.00	1.00
09/28/2024 21:00	-1	1.7	8.1	14.4	2.9	796,372.9	0.00	1.00
09/28/2024 22:00	-1	1.7	8.2	14.4	3.0	797,426.4	0.00	1.00
09/28/2024 23:00	-1	1.7	8.2	14.4	2.4	798,479.8	0.00	1.00
Average/Sum#:	-1	1.7	8.8	14.4	4.0	849,535.6	0.00 #	24.00 #
Minimum:	-1	1.6	7.8	13.6	1.6	796,372.9	0.00	1.00
Maximum:	0	1.9	11.1	14.6	10.5	1,025,546.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/29/2024 00:00	-1	1.7	8.2	14.4	1.7	798,901.1	0.00	1.00
09/29/2024 01:00	-1	1.7	8.3	14.4	1.0	800,165.2	0.00	1.00
09/29/2024 02:00	-1	1.7	8.5	14.3	0.4	788,456.5	0.00	1.00
09/29/2024 03:00	0	1.6	8.7	14.3	0.5	790,323.9	0.00	1.00
09/29/2024 04:00	0	1.5	8.9	14.3	0.2	790,946.3	0.00	1.00
09/29/2024 05:00	0	1.6	8.8	14.3	0.0	790,738.8	0.00	1.00
09/29/2024 06:00	0	1.5	8.8	14.3	0.0	790,946.3	0.00	1.00
09/29/2024 07:00	0	1.6	8.8	14.3	0.1	791,153.8	0.00	1.00
09/29/2024 08:00	-1	1.7	8.7	14.4	0.8	802,061.3	0.00	1.00
09/29/2024 09:00	-1	1.7	8.6	14.4	1.8	801,640.0	0.00	1.00
09/29/2024 10:00	-1	1.7	8.6	14.4	2.3	800,797.2	0.00	1.00
09/29/2024 11:00	-1	1.7	8.4	14.5	2.5	810,742.0	0.00	1.00
09/29/2024 12:00	-1	1.6	8.3	14.5	2.5	808,816.3	0.00	1.00
09/29/2024 13:00	-1	1.6	8.3	14.5	2.0	808,174.4	0.00	1.00
09/29/2024 14:00	-1	1.6	8.2	14.5	1.6	808,174.4	0.00	1.00
09/29/2024 15:00	-1	1.6	8.1	14.5	1.7	807,960.4	0.00	1.00
09/29/2024 16:00	-1	1.7	7.8	14.5	3.1	905,959.8	0.00	1.00
09/29/2024 17:00	-1	1.6	8.1	14.4	1.5	804,378.8	0.00	1.00
09/29/2024 18:00	-1	1.6	8.2	14.5	1.7	808,602.3	0.00	1.00
09/29/2024 19:00	-1	1.6	8.2	14.5	2.5	815,021.5	0.00	1.00
09/29/2024 20:00	-1	1.7	8.2	14.4	2.8	797,637.0	0.00	1.00
09/29/2024 21:00	-1	1.6	8.2	14.4	2.8	797,637.0	0.00	1.00
09/29/2024 22:00	-1	1.7	8.3	14.4	2.8	798,479.8	0.00	1.00
09/29/2024 23:00	-1	1.7	8.3	14.4	2.6	799,322.5	0.00	1.00
Average/Sum#:	-1	1.6	8.4	14.4	1.6	804,876.5	0.00 #	24.00 #
Minimum:	-1	1.5	7.8	14.3	0.0	788,456.5	0.00	1.00
Maximum:	0	1.7	8.9	14.5	3.1	905,959.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:28 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2024 00:00	-1	1.7	8.3	14.4	2.5	799,954.5	0.00	1.00
09/30/2024 01:00	-1	1.7	8.4	14.4	2.6	800,797.2	0.00	1.00
09/30/2024 02:00	-1	1.7	8.5	14.4	2.1	801,640.0	0.00	1.00
09/30/2024 03:00	-1	1.7	8.6	14.4	2.5	802,693.4	0.00	1.00
09/30/2024 04:00	-1	1.7	8.5	14.4	1.4	804,168.1	0.00	1.00
09/30/2024 05:00	0	1.6	8.4	14.4	0.1	813,648.8	0.00	1.00
09/30/2024 06:00	0	1.5	8.8	14.4	2.3	876,853.0	0.00	1.00
09/30/2024 07:00	-1	1.7	8.9	14.4	3.0	802,904.1	0.00	1.00
09/30/2024 08:00	-1	1.7	8.7	14.4	3.1	801,218.6	0.00	1.00
09/30/2024 09:00	-1	1.7	8.7	14.4	3.1	801,640.0	0.00	1.00
09/30/2024 10:00	-1	1.6	8.3	14.5	2.5	813,951.6	0.00	1.00
09/30/2024 11:00	-1	1.6	8.3	14.5	1.9	813,095.7	0.00	1.00
09/30/2024 12:00	-1	1.6	8.2	14.5	1.6	812,239.8	0.00	1.00
09/30/2024 13:00	-1	1.6	8.2	14.5	1.4	815,235.5	0.00	1.00
09/30/2024 14:00	-1	1.6	8.1	14.6	2.1	825,784.6	0.00	1.00
09/30/2024 15:00	0	1.7	8.5	14.2	5.2	916,492.4	0.00	1.00
09/30/2024 16:00	0	2.3	14.0	12.4	21.6	1,033,512.6	0.00	1.00
09/30/2024 17:00	0	2.1	14.6	12.5	20.0	1,034,730.5	0.00	1.00
09/30/2024 18:00	0	2.1	13.9	12.8	17.4	1,043,805.7	0.00	1.00
09/30/2024 19:00	0	2.1	14.0	12.7	18.9	1,037,756.5	0.00	1.00
09/30/2024 20:00	0	2.1	14.3	12.6	20.2	1,036,967.7	0.00	1.00
09/30/2024 21:00	0	2.1	14.0	12.7	19.3	1,045,605.6	0.00	1.00
09/30/2024 22:00	0	1.9	12.2	13.3	14.8	1,042,744.6	0.00	1.00
09/30/2024 23:00	-1	1.6	8.0	14.5	6.3	1,021,505.0	0.00	1.00
Average/Sum#:	-1	1.8	10.0	13.9	7.3	891,622.7	0.00 #	24.00 #
Minimum:	-1	1.5	8.0	12.4	0.1	799,954.5	0.00	1.00
Maximum:	0	2.3	14.6	14.6	21.6	1,045,605.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

AQ-54 thru 63 & 71

AQ54-63 & 71: Fuel use emission and operational data -
Hourly/Daily/Quarterly

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 06:50 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:						
	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	
	CO, Lb	NOx, Lb	SO2, Lb	PM10, Lb	VOC, Lb	
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	
07/01/2024	31.97	102.21	11.44	23.00	38.19	
07/02/2024	28.63	118.95	13.23	26.48	44.14	
07/03/2024	30.29	112.20	12.65	25.36	42.26	
07/04/2024	31.16	93.36	10.71	21.56	35.80	
07/05/2024	33.27	108.77	12.09	24.13	40.31	
07/06/2024	30.38	101.94	11.63	23.32	38.87	
07/07/2024	27.00	108.93	12.31	24.70	41.09	
07/08/2024	26.16	116.41	12.93	25.88	43.17	
07/09/2024	27.05	118.84	13.23	26.54	44.16	
07/10/2024	30.29	114.06	13.03	26.07	43.39	
07/11/2024	25.76	120.56	13.45	27.00	44.98	
07/12/2024	28.46	113.63	12.78	25.66	42.69	
07/13/2024	30.44	95.32	10.87	21.75	36.27	
07/14/2024	29.63	94.99	10.78	21.64	36.02	
07/15/2024	28.51	94.19	10.61	21.37	35.57	
07/16/2024	31.20	95.67	11.30	22.67	37.76	
07/17/2024	30.91	96.29	10.94	22.04	36.62	
07/18/2024	39.37	80.66	8.81	17.59	29.40	
07/19/2024	16.83	68.30	7.72	15.42	25.71	
07/20/2024	40.23	120.49	12.24	24.52	40.87	
07/21/2024	30.39	96.81	11.18	22.50	37.43	
07/22/2024	27.59	121.06	13.45	26.99	44.96	
07/23/2024	16.39	155.62	16.96	33.90	56.54	
07/24/2024	38.44	200.25	18.75	37.14	62.54	
07/25/2024	25.76	121.20	13.44	26.90	44.76	
07/26/2024	30.21	95.59	10.83	21.72	36.18	
07/27/2024	30.40	94.65	10.56	21.33	35.48	
07/28/2024	30.30	96.73	10.58	21.37	35.52	
07/29/2024	33.48	104.92	11.48	23.01	38.30	
07/30/2024	28.60	113.08	12.26	24.63	41.04	
07/31/2024	28.88	114.61	12.81	25.67	42.76	
Monthly Avg/Sum:	917.98 sum	3,390.29 sum	375.05 sum	751.86 sum	1,252.78 sum	
Daily Min:	16.39	68.30	7.72	15.42	25.71	
Daily Max:	40.23	200.25	18.75	37.14	62.54	
Jul 2024 - Jul 2024	917.98 sum	3,390.29 sum	375.05 sum	751.86 sum	1,252.78 sum	
QTD:	917.98 sum	3,390.29 sum	375.05 sum	751.86 sum	1,252.78 sum	
YTD 2024:	5,390.17 sum	12,804.09 sum	1,380.34 sum	2,760.44 sum	4,600.82 sum	

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 06:50 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Lb		NOx, Lb		SO2, Lb		PM10, Lb		VOC, Lb	
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
08/01/2024	70.69		113.14		11.57		23.14		38.64	
08/02/2024	32.47		122.24		14.45		28.87		48.13	
08/03/2024	30.41		85.20		11.50		23.15		38.47	
08/04/2024	30.62		89.43		11.55		23.24		38.67	
08/05/2024	31.50		81.20		11.32		22.66		37.78	
08/06/2024	32.57		81.39		11.45		23.06		38.29	
08/07/2024	31.71		81.29		10.75		21.60		35.92	
08/08/2024	28.86		73.06		10.65		21.45		35.65	
08/09/2024	28.92		73.96		10.65		21.45		35.70	
08/10/2024	28.88		71.83		10.61		21.34		35.58	
08/11/2024	32.43		94.69		11.87		23.87		39.78	
08/12/2024	31.40		82.78		11.12		22.23		37.03	
08/13/2024	32.36		82.91		11.04		22.18		36.98	
08/14/2024	31.37		88.95		11.71		23.57		39.21	
08/15/2024	33.28		85.71		11.80		23.71		39.49	
08/16/2024	32.59		78.02		10.90		21.84		36.45	
08/17/2024	30.52		68.59		10.65		21.39		35.69	
08/18/2024	31.44		80.02		10.49		21.06		35.12	
08/19/2024	32.77		85.43		10.73		21.57		35.95	
08/20/2024	31.32		88.43		10.58		21.30		35.46	
08/21/2024	31.68		92.96		10.58		21.16		35.27	
08/22/2024	31.53		93.29		10.58		21.19		35.37	
08/23/2024	33.18		94.75		10.59		21.38		35.62	
08/24/2024	34.45		94.57		10.64		21.42		35.67	
08/25/2024	36.47		96.81		11.03		22.03		36.68	
08/26/2024	34.30		95.06		10.98		21.94		36.54	
08/27/2024	34.96		93.47		10.68		21.52		35.81	
08/28/2024	34.96		92.35		10.69		21.51		35.74	
08/29/2024	34.75		95.67		11.01		22.21		36.88	
08/30/2024	34.32		92.99		10.61		21.37		35.49	
08/31/2024	34.28		105.42		11.97		24.08		40.09	
Monthly Avg/Sum:	1,040.99	sum	2,755.61	sum	344.75	sum	692.49	sum	1,153.15	sum
Daily Min:	28.86		68.59		10.49		21.06		35.12	
Daily Max:	70.69		122.24		14.45		28.87		48.13	
Jul 2024 - Aug 2024	1,958.97	sum	6,145.90	sum	719.80	sum	1,444.35	sum	2,405.93	sum
QTD:	1,958.97	sum	6,145.90	sum	719.80	sum	1,444.35	sum	2,405.93	sum
YTD 2024:	6,431.16	sum	15,559.70	sum	1,725.09	sum	3,452.93	sum	5,753.97	sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 06:50 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:						
	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	
	CO, Lb	NOx, Lb	SO2, Lb	PM10, Lb	VOC, Lb	
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	
09/01/2024	34.30	93.57	10.69	21.51	35.75	
09/02/2024	34.73	93.42	10.88	21.80	36.26	
09/03/2024	45.72	127.84	13.47	27.00	44.91	
09/04/2024	32.38	111.44	13.19	26.40	43.92	
09/05/2024	26.88	125.11	14.10	28.17	46.83	
09/06/2024	25.61	125.84	14.13	28.31	47.15	
09/07/2024	27.63	124.52	13.91	27.86	46.43	
09/08/2024	28.84	116.78	13.19	26.39	43.95	
09/09/2024	35.54	99.47	11.55	23.04	38.41	
09/10/2024	32.13	94.47	10.80	21.56	35.85	
09/11/2024	32.59	94.20	10.73	21.46	35.72	
09/12/2024	29.93	93.35	10.69	21.37	35.54	
09/13/2024	27.66	103.40	11.90	23.77	39.56	
09/14/2024	27.71	96.66	11.18	22.37	37.28	
09/15/2024	26.29	94.74	10.75	21.49	35.70	
09/16/2024	29.28	99.57	11.70	23.37	38.88	
09/17/2024	27.16	95.77	10.91	21.80	36.30	
09/18/2024	28.09	97.85	11.36	22.59	37.66	
09/19/2024	30.23	107.11	12.34	24.71	41.14	
09/20/2024	26.99	93.73	11.03	22.08	36.75	
09/21/2024	26.44	103.94	11.95	23.93	39.92	
09/22/2024	27.15	93.90	10.73	21.45	35.80	
09/23/2024	28.48	103.19	11.92	23.82	39.68	
09/24/2024	29.12	98.83	11.45	22.88	38.10	
09/25/2024	26.06	92.96	10.76	21.47	35.81	
09/26/2024	28.80	100.70	11.69	23.35	38.84	
09/27/2024	31.64	100.80	11.70	23.38	38.93	
09/28/2024	29.96	97.76	11.33	22.56	37.62	
09/29/2024	27.50	91.75	10.61	21.14	35.23	
09/30/2024	26.21	112.55	12.79	25.58	42.59	
Monthly Avg/Sum:	891.05 sum	3,085.22 sum	353.43 sum	706.61 sum	1,176.51 sum	
Daily Min:	25.61	91.75	10.61	21.14	35.23	
Daily Max:	45.72	127.84	14.13	28.31	47.15	
Jul 2024 - Sep 2024	2,850.02 sum	9,231.12 sum	1,073.23 sum	2,150.96 sum	3,582.44 sum	
QTD:	2,850.02 sum	9,231.12 sum	1,073.23 sum	2,150.96 sum	3,582.44 sum	
YTD 2024:	7,322.21 sum	18,644.92 sum	2,078.52 sum	4,159.54 sum	6,930.48 sum	

Monthly Summary By Day Report



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 06:51 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1		Unit CT2	
	CO_SUSD, LbPerHr		NOX_SUSD, LbPerHr	
	1 Hour(s)		1 Hour(s)	
07/01/2024	0.0	0.0	0.0	0.0
07/02/2024	0.0	0.0	0.2	0.4
07/03/2024	0.0	0.0	0.0	0.0
07/04/2024	0.0	0.0	0.0	0.0
07/05/2024	0.0	0.0	0.0	0.0
07/06/2024	0.0	0.0	0.0	0.0
07/07/2024	0.0	0.0	0.0	0.0
07/08/2024	0.0	0.0	0.0	0.0
07/09/2024	0.0	0.0	0.0	0.0
07/10/2024	0.0	0.0	0.0	0.0
07/11/2024	0.0	0.0	0.0	0.1
07/12/2024	0.0	0.0	0.0	0.0
07/13/2024	0.0	0.0	0.0	0.0
07/14/2024	0.0	0.0	0.0	0.0
07/15/2024	0.0	0.0	0.0	0.0
07/16/2024	0.0	0.0	0.7	2.7
07/17/2024	0.0	0.0	0.4	1.4
07/18/2024	0.0	0.0	13.4	13.1
07/19/2024	0.0	0.0	0.0	0.0
07/20/2024	0.0	0.0	15.8	12.9
07/21/2024	0.0	0.0	0.0	0.0
07/22/2024	0.0	0.0	0.0	0.0
07/23/2024	0.0	0.0	0.0	0.0
07/24/2024	0.0	0.0	0.0	0.0
07/25/2024	0.0	0.0	0.0	0.0
07/26/2024	0.0	0.0	0.0	0.0
07/27/2024	0.0	0.0	0.0	0.0
07/28/2024	0.0	0.0	0.0	0.0
07/29/2024	0.0	0.0	0.0	0.0
07/30/2024	0.0	0.0	0.0	0.0
07/31/2024	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	0.0 sum	0.0 sum	30.5 sum	30.6 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	15.8	13.1
Jul 2024 - Jul 2024	0.0 sum	0.0 sum	30.5 sum	30.6 sum
QTD:	0.0 sum	0.0 sum	30.5 sum	30.6 sum
YTD 2024:	1,016.2 sum	136.5 sum	626.7 sum	209.6 sum

Monthly Summary By Day Report



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 06:51 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1		Unit CT2	
	CO_SUSD, LbPerHr		NOX_SUSD, LbPerHr	
	1 Hour(s)		1 Hour(s)	
08/01/2024	0.0	0.0	34.0	13.3
08/02/2024	0.0	0.0	0.0	0.0
08/03/2024	0.0	0.0	0.0	0.0
08/04/2024	0.0	0.0	0.0	0.2
08/05/2024	0.0	0.0	0.0	0.0
08/06/2024	0.0	0.0	0.0	0.0
08/07/2024	0.0	0.0	0.0	0.0
08/08/2024	0.0	0.0	0.0	0.0
08/09/2024	0.0	0.0	0.0	0.0
08/10/2024	0.0	0.0	0.0	0.0
08/11/2024	0.0	0.0	0.0	0.0
08/12/2024	0.0	0.0	0.0	0.0
08/13/2024	0.0	0.0	0.0	0.0
08/14/2024	0.0	0.0	0.0	0.0
08/15/2024	0.0	0.0	0.0	0.0
08/16/2024	0.0	0.0	0.0	0.0
08/17/2024	0.0	0.0	0.0	0.0
08/18/2024	0.0	0.0	0.3	0.6
08/19/2024	0.0	0.0	0.0	0.0
08/20/2024	0.0	0.0	0.0	0.0
08/21/2024	0.0	0.0	0.0	0.0
08/22/2024	0.0	0.0	0.0	0.0
08/23/2024	0.0	0.0	0.0	0.0
08/24/2024	0.0	0.0	0.0	0.0
08/25/2024	0.0	0.0	0.0	0.0
08/26/2024	0.0	0.0	0.0	0.0
08/27/2024	0.0	0.0	0.0	0.0
08/28/2024	0.0	0.0	0.0	0.0
08/29/2024	0.0	0.0	0.0	0.0
08/30/2024	0.0	0.0	0.0	0.0
08/31/2024	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	0.0 sum	0.0 sum	34.3 sum	14.1 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	34.0	13.3
Jul 2024 - Aug 2024	0.0 sum	0.0 sum	64.8 sum	44.7 sum
QTD:	0.0 sum	0.0 sum	64.8 sum	44.7 sum
YTD 2024:	1,016.2 sum	136.5 sum	661.0 sum	223.7 sum

Monthly Summary By Day Report



From: 07/01/2024 00:00

To: 09/30/2024 23:59

Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 06:51

Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2024	0.0	0.0	0.0	0.0
09/02/2024	0.0	0.0	0.0	0.0
09/03/2024	0.0	0.0	0.0	0.0
09/04/2024	0.0	0.0	0.0	0.0
09/05/2024	0.0	0.0	0.0	0.0
09/06/2024	0.0	0.0	0.0	0.0
09/07/2024	0.0	0.0	0.0	0.0
09/08/2024	0.0	0.0	0.0	0.0
09/09/2024	0.0	0.0	0.0	0.0
09/10/2024	0.0	0.0	0.0	0.0
09/11/2024	0.0	0.0	0.0	0.0
09/12/2024	0.0	0.0	0.0	0.0
09/13/2024	0.0	0.0	0.0	0.0
09/14/2024	0.0	0.0	0.0	0.0
09/15/2024	0.0	0.0	0.0	0.0
09/16/2024	0.0	0.0	0.0	0.0
09/17/2024	0.0	0.0	0.0	0.0
09/18/2024	0.0	0.0	0.0	0.0
09/19/2024	0.0	0.0	0.0	0.0
09/20/2024	0.0	0.0	0.0	0.0
09/21/2024	0.0	0.0	0.0	0.0
09/22/2024	0.0	0.0	0.0	0.0
09/23/2024	0.0	0.0	0.0	0.0
09/24/2024	0.0	0.0	0.0	0.0
09/25/2024	0.0	0.0	0.0	0.0
09/26/2024	0.0	0.0	0.0	0.0
09/27/2024	0.0	0.0	0.0	0.0
09/28/2024	0.0	0.0	0.0	0.0
09/29/2024	0.0	0.0	0.0	0.0
09/30/2024	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	0.0 sum	0.0 sum	0.0 sum	0.0 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	0.0	0.0
Jul 2024 - Sep 2024	0.0 sum	0.0 sum	64.8 sum	44.7 sum
QTD:	0.0 sum	0.0 sum	64.8 sum	44.7 sum
YTD 2024:	1,016.2 sum	136.5 sum	661.0 sum	223.7 sum

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:24 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Jul 2024	0.4589	3.9373	1.6951	9.8201	0.3762	2.1164	0.1875	1.0584	0.6265	3.5273
Aug 2024	0.5206	3.9875	1.3777	9.5370	0.3463	2.1015	0.1724	1.0502	0.5763	3.5015
Sep 2024	0.4457	3.9688	1.5432	9.8108	0.3534	2.1779	0.1774	1.0890	0.5887	3.6283
Sum/Avg	3.9688		9.8108		2.1779		1.0890		3.6283	
Limit Value										

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/01/2024 00:00	0.7	1.4	1	0.42	0.21090	0.70
07/01/2024 01:00	0.8	1.4	1	0.42	0.21072	0.70
07/01/2024 02:00	0.8	1.5	1	0.42	0.21090	0.70
07/01/2024 03:00	0.9	1.5	1	0.42	0.21138	0.70
07/01/2024 04:00	0.9	1.4	1	0.42	0.21108	0.70
07/01/2024 05:00	1.0	1.4	1	0.42	0.21132	0.70
07/01/2024 06:00	0.9	1.4	1	0.42	0.21204	0.71
07/01/2024 07:00	0.8	1.4	1	0.43	0.21306	0.71
07/01/2024 08:00	0.7	1.4	1	0.43	0.21282	0.71
07/01/2024 09:00	0.7	1.4	1	0.43	0.21276	0.71
07/01/2024 10:00	0.7	1.4	1	0.43	0.21276	0.71
07/01/2024 11:00	0.7	1.2	0	0.43	0.21360	0.71
07/01/2024 12:00	0.7	1.3	0	0.43	0.21378	0.71
07/01/2024 13:00	0.7	1.3	0	0.43	0.21372	0.71
07/01/2024 14:00	0.7	1.3	0	0.43	0.21444	0.71
07/01/2024 15:00	0.7	1.4	0	0.43	0.21480	0.72
07/01/2024 16:00	0.7	1.3	1	0.43	0.21462	0.72
07/01/2024 17:00	0.7	1.3	0	0.46	0.22776	0.76
07/01/2024 18:00	0.5	1.5	1	0.63	0.31698	1.06
07/01/2024 19:00	0.3	1.5	2	0.77	0.38688	1.29
07/01/2024 20:00	0.5	1.4	1	0.68	0.34008	1.13
07/01/2024 21:00	0.9	1.4	1	0.46	0.22848	0.76
07/01/2024 22:00	0.8	1.4	1	0.42	0.21204	0.71
07/01/2024 23:00	0.9	1.4	1	0.42	0.21162	0.71
Average/Sum#:	0.7	1.4	1	0.46	0.23077	0.77
Minimum:	0.3	1.2	0	0.42	0.21072	0.70
Maximum:	1.0	1.5	2	0.77	0.38688	1.29
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/02/2024 00:00	0.9	1.4	1	0.42	0.21198	0.71
07/02/2024 01:00	1.0	1.4	1	0.42	0.21150	0.71
07/02/2024 02:00	0.9	1.4	1	0.42	0.21138	0.70
07/02/2024 03:00	0.9	1.4	1	0.42	0.21126	0.70
07/02/2024 04:00	0.8	1.4	1	0.42	0.21162	0.71
07/02/2024 05:00	0.8	1.3	1	0.46	0.23040	0.77
07/02/2024 06:00	0.8	1.3	1	0.43	0.21552	0.72
07/02/2024 07:00	0.8	1.4	1	0.43	0.21300	0.71
07/02/2024 08:00	0.7	1.4	1	0.42	0.21192	0.71
07/02/2024 09:00	0.7	1.3	0	0.42	0.21156	0.71
07/02/2024 10:00	0.7	1.3	0	0.42	0.21168	0.71
07/02/2024 11:00	0.7	1.3	0	0.43	0.21294	0.71
07/02/2024 12:00	0.7	1.3	0	0.43	0.21714	0.72
07/02/2024 13:00	1.0	1.4	0	0.51	0.25452	0.85
07/02/2024 14:00	0.3	1.5	1	0.69	0.34368	1.15
07/02/2024 15:00	0.3	1.5	1	0.73	0.36306	1.21
07/02/2024 16:00	0.2	1.5	2	0.74	0.37062	1.24
07/02/2024 17:00	0.3	1.5	2	0.76	0.38082	1.27
07/02/2024 18:00	0.3	1.5	2	0.76	0.37938	1.26
07/02/2024 19:00	0.3	1.5	2	0.75	0.37632	1.25
07/02/2024 20:00	0.3	1.5	2	0.75	0.37416	1.25
07/02/2024 21:00	0.4	1.5	1	0.71	0.35718	1.19
07/02/2024 22:00	0.9	1.3	1	0.49	0.24252	0.81
07/02/2024 23:00	0.9	1.4	1	0.43	0.21348	0.71
Average/Sum#:	0.7	1.4	1	0.54	0.26824	0.90
Minimum:	0.2	1.3	0	0.42	0.21126	0.70
Maximum:	1.0	1.5	2	0.76	0.38082	1.27
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/03/2024 00:00	0.9	1.4	1	0.43	0.21444	0.71
07/03/2024 01:00	1.1	1.4	1	0.42	0.21246	0.71
07/03/2024 02:00	1.1	1.4	1	0.42	0.21216	0.71
07/03/2024 03:00	1.1	1.4	1	0.42	0.21216	0.71
07/03/2024 04:00	1.0	1.4	1	0.42	0.21198	0.71
07/03/2024 05:00	0.9	1.4	1	0.42	0.21222	0.71
07/03/2024 06:00	0.8	1.4	1	0.42	0.21210	0.71
07/03/2024 07:00	0.8	1.4	1	0.43	0.21276	0.71
07/03/2024 08:00	0.8	1.4	1	0.42	0.21246	0.71
07/03/2024 09:00	0.7	1.3	0	0.42	0.21234	0.71
07/03/2024 10:00	0.7	1.2	0	0.42	0.21228	0.71
07/03/2024 11:00	0.7	1.1	0	0.43	0.21348	0.71
07/03/2024 12:00	0.7	1.1	0	0.43	0.21396	0.71
07/03/2024 13:00	0.7	1.2	0	0.44	0.21882	0.73
07/03/2024 14:00	0.6	1.4	1	0.61	0.30432	1.01
07/03/2024 15:00	0.4	1.4	1	0.68	0.33996	1.13
07/03/2024 16:00	0.3	1.5	1	0.73	0.36546	1.22
07/03/2024 17:00	0.2	1.5	2	0.76	0.37800	1.26
07/03/2024 18:00	0.2	1.5	2	0.75	0.37674	1.26
07/03/2024 19:00	0.2	1.5	2	0.75	0.37506	1.25
07/03/2024 20:00	0.3	1.5	1	0.70	0.35160	1.17
07/03/2024 21:00	0.9	1.4	1	0.48	0.24234	0.81
07/03/2024 22:00	0.9	1.3	0	0.42	0.21234	0.71
07/03/2024 23:00	0.9	1.4	1	0.43	0.21258	0.71
Average/Sum#:	0.7	1.4	1	0.51	0.25592	0.85
Minimum:	0.2	1.1	0	0.42	0.21198	0.71
Maximum:	1.1	1.5	2	0.76	0.37800	1.26
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/04/2024 00:00	0.9	1.4	1	0.43	0.21306	0.71
07/04/2024 01:00	0.8	1.4	1	0.43	0.21258	0.71
07/04/2024 02:00	0.8	1.5	1	0.42	0.21234	0.71
07/04/2024 03:00	0.9	1.4	1	0.42	0.21228	0.71
07/04/2024 04:00	0.8	1.4	1	0.42	0.21240	0.71
07/04/2024 05:00	0.8	1.4	1	0.43	0.21258	0.71
07/04/2024 06:00	0.8	1.4	1	0.43	0.21282	0.71
07/04/2024 07:00	0.8	1.3	1	0.43	0.21324	0.71
07/04/2024 08:00	0.7	1.2	0	0.43	0.21306	0.71
07/04/2024 09:00	0.7	1.3	0	0.43	0.21300	0.71
07/04/2024 10:00	0.7	1.3	0	0.43	0.21324	0.71
07/04/2024 11:00	0.7	1.3	0	0.43	0.21402	0.71
07/04/2024 12:00	0.7	1.3	0	0.43	0.21408	0.71
07/04/2024 13:00	0.7	1.3	0	0.43	0.21402	0.71
07/04/2024 14:00	0.7	1.4	0	0.43	0.21402	0.71
07/04/2024 15:00	0.7	1.2	0	0.43	0.21342	0.71
07/04/2024 16:00	0.7	1.3	0	0.48	0.24024	0.80
07/04/2024 17:00	0.7	1.3	1	0.45	0.22362	0.75
07/04/2024 18:00	0.7	1.3	0	0.49	0.24552	0.82
07/04/2024 19:00	0.7	1.3	0	0.43	0.21294	0.71
07/04/2024 20:00	0.7	1.3	0	0.42	0.21204	0.71
07/04/2024 21:00	0.8	1.3	0	0.42	0.21192	0.71
07/04/2024 22:00	0.8	1.4	1	0.42	0.21198	0.71
07/04/2024 23:00	0.8	1.4	1	0.43	0.21276	0.71
Average/Sum#:	0.8	1.3	0	0.43	0.21588	0.72
Minimum:	0.7	1.2	0	0.42	0.21192	0.71
Maximum:	0.9	1.5	1	0.49	0.24552	0.82
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/05/2024 00:00	0.7	1.3	0	0.50	0.24948	0.83
07/05/2024 01:00	0.7	1.3	0	0.50	0.24912	0.83
07/05/2024 02:00	0.7	1.4	0	0.50	0.24888	0.83
07/05/2024 03:00	0.8	1.4	1	0.42	0.21216	0.71
07/05/2024 04:00	0.8	1.4	1	0.42	0.21174	0.71
07/05/2024 05:00	0.8	1.4	1	0.42	0.21198	0.71
07/05/2024 06:00	0.8	1.3	1	0.42	0.21210	0.71
07/05/2024 07:00	0.8	1.4	1	0.43	0.21264	0.71
07/05/2024 08:00	0.7	1.3	1	0.42	0.21228	0.71
07/05/2024 09:00	0.7	1.3	0	0.42	0.21198	0.71
07/05/2024 10:00	0.7	1.3	0	0.42	0.21204	0.71
07/05/2024 11:00	0.7	1.2	0	0.43	0.21294	0.71
07/05/2024 12:00	0.7	1.3	0	0.43	0.21312	0.71
07/05/2024 13:00	0.7	1.3	0	0.43	0.21312	0.71
07/05/2024 14:00	0.7	1.2	0	0.43	0.21312	0.71
07/05/2024 15:00	0.7	1.3	0	0.43	0.21318	0.71
07/05/2024 16:00	0.8	1.3	0	0.43	0.21300	0.71
07/05/2024 17:00	1.0	1.3	0	0.50	0.24936	0.83
07/05/2024 18:00	0.3	1.5	1	0.72	0.36168	1.21
07/05/2024 19:00	0.5	1.4	1	0.63	0.31572	1.05
07/05/2024 20:00	0.8	1.3	1	0.48	0.24102	0.80
07/05/2024 21:00	0.8	1.3	0	0.42	0.21150	0.71
07/05/2024 22:00	0.8	1.3	0	0.42	0.21144	0.70
07/05/2024 23:00	0.8	1.3	0	0.42	0.21138	0.70
Average/Sum#:	0.7	1.3	0	0.46	0.23021	0.77
Minimum:	0.3	1.2	0	0.42	0.21138	0.70
Maximum:	1.0	1.5	1	0.72	0.36168	1.21
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/06/2024 00:00	0.8	1.3	0	0.42	0.21144	0.70
07/06/2024 01:00	0.8	1.4	1	0.42	0.21168	0.71
07/06/2024 02:00	0.8	1.5	1	0.42	0.21168	0.71
07/06/2024 03:00	0.9	1.4	1	0.42	0.21162	0.71
07/06/2024 04:00	0.8	1.4	1	0.42	0.21210	0.71
07/06/2024 05:00	0.8	1.3	1	0.42	0.21222	0.71
07/06/2024 06:00	0.8	1.4	1	0.42	0.21210	0.71
07/06/2024 07:00	0.8	1.4	1	0.43	0.21264	0.71
07/06/2024 08:00	0.7	1.3	0	0.43	0.21252	0.71
07/06/2024 09:00	0.7	1.3	0	0.42	0.21234	0.71
07/06/2024 10:00	0.7	1.2	0	0.42	0.21246	0.71
07/06/2024 11:00	0.7	1.2	0	0.43	0.21336	0.71
07/06/2024 12:00	0.7	1.4	1	0.43	0.21492	0.72
07/06/2024 13:00	0.7	1.4	1	0.43	0.21522	0.72
07/06/2024 14:00	0.7	1.3	0	0.47	0.23460	0.78
07/06/2024 15:00	0.7	1.4	1	0.43	0.21546	0.72
07/06/2024 16:00	0.7	1.3	0	0.45	0.22416	0.75
07/06/2024 17:00	0.6	1.4	1	0.53	0.26652	0.89
07/06/2024 18:00	0.2	1.5	1	0.72	0.35868	1.20
07/06/2024 19:00	0.3	1.4	1	0.67	0.33420	1.11
07/06/2024 20:00	0.7	1.4	1	0.58	0.29118	0.97
07/06/2024 21:00	0.7	1.3	0	0.51	0.25662	0.86
07/06/2024 22:00	0.8	1.4	0	0.50	0.25200	0.84
07/06/2024 23:00	0.8	1.3	0	0.44	0.21906	0.73
Average/Sum#:	0.7	1.4	1	0.47	0.23453	0.78
Minimum:	0.2	1.2	0	0.42	0.21144	0.70
Maximum:	0.9	1.5	1	0.72	0.35868	1.20
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/07/2024 00:00	0.8	1.3	0	0.42	0.21246	0.71
07/07/2024 01:00	0.8	1.4	1	0.42	0.21216	0.71
07/07/2024 02:00	0.8	1.6	1	0.42	0.21204	0.71
07/07/2024 03:00	0.8	1.4	1	0.42	0.21198	0.71
07/07/2024 04:00	0.8	1.4	1	0.42	0.21204	0.71
07/07/2024 05:00	0.7	1.4	1	0.42	0.21246	0.71
07/07/2024 06:00	0.7	1.4	1	0.43	0.21270	0.71
07/07/2024 07:00	0.7	1.4	1	0.43	0.21306	0.71
07/07/2024 08:00	0.7	1.4	0	0.43	0.21258	0.71
07/07/2024 09:00	0.7	1.2	0	0.43	0.21252	0.71
07/07/2024 10:00	0.7	1.3	0	0.43	0.21276	0.71
07/07/2024 11:00	0.7	1.2	0	0.43	0.21360	0.71
07/07/2024 12:00	0.7	1.3	0	0.45	0.22494	0.75
07/07/2024 13:00	0.7	1.3	0	0.45	0.22332	0.74
07/07/2024 14:00	0.7	1.3	0	0.48	0.24054	0.80
07/07/2024 15:00	1.0	1.4	0	0.46	0.22938	0.76
07/07/2024 16:00	0.3	1.5	1	0.71	0.35568	1.19
07/07/2024 17:00	0.2	1.5	1	0.73	0.36360	1.21
07/07/2024 18:00	0.2	1.5	1	0.73	0.36390	1.21
07/07/2024 19:00	0.2	1.5	1	0.72	0.36174	1.21
07/07/2024 20:00	0.2	1.5	1	0.72	0.35796	1.19
07/07/2024 21:00	0.7	1.3	1	0.53	0.26724	0.89
07/07/2024 22:00	0.7	1.4	1	0.43	0.21252	0.71
07/07/2024 23:00	0.7	1.4	1	0.42	0.21246	0.71
Average/Sum#:	0.6	1.4	1	0.50	0.24849	0.83
Minimum:	0.2	1.2	0	0.42	0.21198	0.71
Maximum:	1.0	1.6	1	0.73	0.36390	1.21
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/08/2024 00:00	0.7	1.4	1	0.42	0.21234	0.71
07/08/2024 01:00	0.7	1.4	1	0.42	0.21228	0.71
07/08/2024 02:00	0.7	1.5	1	0.42	0.21222	0.71
07/08/2024 03:00	0.8	1.5	1	0.42	0.21216	0.71
07/08/2024 04:00	0.8	1.4	1	0.42	0.21216	0.71
07/08/2024 05:00	0.8	1.4	1	0.42	0.21228	0.71
07/08/2024 06:00	0.8	1.4	1	0.43	0.21252	0.71
07/08/2024 07:00	0.7	1.4	1	0.43	0.21312	0.71
07/08/2024 08:00	0.7	1.4	1	0.43	0.21276	0.71
07/08/2024 09:00	0.7	1.4	1	0.43	0.21270	0.71
07/08/2024 10:00	0.7	1.3	0	0.43	0.21270	0.71
07/08/2024 11:00	0.7	1.4	0	0.43	0.21342	0.71
07/08/2024 12:00	0.7	1.4	1	0.43	0.21642	0.72
07/08/2024 13:00	0.7	1.3	0	0.44	0.22194	0.74
07/08/2024 14:00	0.7	1.3	0	0.52	0.25956	0.87
07/08/2024 15:00	0.7	1.4	0	0.47	0.23736	0.79
07/08/2024 16:00	0.6	1.4	1	0.56	0.28134	0.94
07/08/2024 17:00	0.2	1.5	1	0.74	0.37056	1.24
07/08/2024 18:00	0.2	1.5	2	0.75	0.37398	1.25
07/08/2024 19:00	0.2	1.5	1	0.72	0.36162	1.21
07/08/2024 20:00	0.2	1.5	1	0.72	0.35898	1.20
07/08/2024 21:00	0.3	1.5	1	0.70	0.34968	1.17
07/08/2024 22:00	0.3	1.5	1	0.70	0.34848	1.16
07/08/2024 23:00	0.5	1.5	1	0.66	0.33114	1.10
Average/Sum#:	0.6	1.4	1	0.52	0.26091	0.87
Minimum:	0.2	1.3	0	0.42	0.21216	0.71
Maximum:	0.8	1.5	2	0.75	0.37398	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/09/2024 00:00	0.9	1.4	1	0.53	0.26490	0.88
07/09/2024 01:00	0.8	1.4	1	0.43	0.21270	0.71
07/09/2024 02:00	0.8	1.4	1	0.43	0.21264	0.71
07/09/2024 03:00	0.9	1.4	1	0.43	0.21276	0.71
07/09/2024 04:00	0.8	1.4	1	0.43	0.21408	0.71
07/09/2024 05:00	0.7	1.4	1	0.43	0.21270	0.71
07/09/2024 06:00	0.8	1.4	1	0.43	0.21300	0.71
07/09/2024 07:00	0.7	1.4	1	0.43	0.21342	0.71
07/09/2024 08:00	0.7	1.4	1	0.43	0.21294	0.71
07/09/2024 09:00	0.7	1.4	1	0.43	0.21258	0.71
07/09/2024 10:00	0.7	1.3	1	0.43	0.21258	0.71
07/09/2024 11:00	0.7	1.4	1	0.43	0.21336	0.71
07/09/2024 12:00	0.7	1.2	0	0.43	0.21624	0.72
07/09/2024 13:00	0.6	1.4	0	0.53	0.26364	0.88
07/09/2024 14:00	0.7	1.4	0	0.51	0.25488	0.85
07/09/2024 15:00	0.8	1.4	0	0.50	0.25230	0.84
07/09/2024 16:00	0.3	1.5	1	0.72	0.35850	1.20
07/09/2024 17:00	0.2	1.5	1	0.73	0.36456	1.22
07/09/2024 18:00	0.2	1.5	2	0.75	0.37524	1.25
07/09/2024 19:00	0.2	1.5	1	0.73	0.36390	1.21
07/09/2024 20:00	0.2	1.5	1	0.71	0.35616	1.19
07/09/2024 21:00	0.2	1.5	1	0.71	0.35544	1.18
07/09/2024 22:00	0.3	1.5	1	0.70	0.35112	1.17
07/09/2024 23:00	0.9	1.4	1	0.58	0.29244	0.97
Average/Sum#:	0.6	1.4	1	0.54	0.26717	0.89
Minimum:	0.2	1.2	0	0.43	0.21258	0.71
Maximum:	0.9	1.5	2	0.75	0.37524	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/10/2024 00:00	0.7	1.4	0	0.52	0.26076	0.87
07/10/2024 01:00	0.7	1.3	0	0.52	0.25776	0.86
07/10/2024 02:00	0.7	1.3	0	0.53	0.26262	0.88
07/10/2024 03:00	0.8	1.4	0	0.51	0.25626	0.85
07/10/2024 04:00	0.7	1.3	0	0.53	0.26358	0.88
07/10/2024 05:00	0.7	1.4	1	0.49	0.24426	0.81
07/10/2024 06:00	0.8	1.4	1	0.43	0.21426	0.71
07/10/2024 07:00	0.8	1.4	1	0.43	0.21480	0.72
07/10/2024 08:00	0.8	1.3	1	0.43	0.21426	0.71
07/10/2024 09:00	0.8	1.4	1	0.43	0.21330	0.71
07/10/2024 10:00	0.7	1.3	0	0.43	0.21330	0.71
07/10/2024 11:00	0.7	1.2	0	0.43	0.21402	0.71
07/10/2024 12:00	0.7	1.3	0	0.43	0.21402	0.71
07/10/2024 13:00	0.7	1.3	0	0.47	0.23574	0.79
07/10/2024 14:00	0.7	1.3	0	0.50	0.25056	0.84
07/10/2024 15:00	0.7	1.3	0	0.47	0.23358	0.78
07/10/2024 16:00	0.7	1.2	0	0.47	0.23574	0.79
07/10/2024 17:00	0.4	1.5	1	0.69	0.34608	1.15
07/10/2024 18:00	0.2	1.5	2	0.74	0.37050	1.24
07/10/2024 19:00	0.2	1.5	1	0.74	0.36828	1.23
07/10/2024 20:00	0.3	1.5	1	0.71	0.35358	1.18
07/10/2024 21:00	0.5	1.4	1	0.65	0.32604	1.09
07/10/2024 22:00	0.8	1.4	1	0.58	0.28974	0.97
07/10/2024 23:00	0.9	1.4	0	0.48	0.23772	0.79
Average/Sum#:	0.7	1.4	1	0.53	0.26212	0.87
Minimum:	0.2	1.2	0	0.43	0.21330	0.71
Maximum:	0.9	1.5	2	0.74	0.37050	1.24
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/11/2024 00:00	0.9	1.4	1	0.43	0.21366	0.71
07/11/2024 01:00	0.8	1.4	1	0.43	0.21306	0.71
07/11/2024 02:00	0.8	1.5	1	0.43	0.21300	0.71
07/11/2024 03:00	0.9	1.3	0	0.43	0.21312	0.71
07/11/2024 04:00	0.8	1.4	1	0.43	0.21312	0.71
07/11/2024 05:00	0.9	1.4	1	0.43	0.21318	0.71
07/11/2024 06:00	1.0	1.3	1	0.43	0.21354	0.71
07/11/2024 07:00	0.8	1.4	1	0.43	0.21462	0.72
07/11/2024 08:00	0.8	1.4	1	0.43	0.21426	0.71
07/11/2024 09:00	0.8	1.3	1	0.43	0.21414	0.71
07/11/2024 10:00	0.8	1.3	1	0.43	0.21432	0.71
07/11/2024 11:00	0.7	1.3	0	0.43	0.21402	0.71
07/11/2024 12:00	0.7	1.3	0	0.46	0.22896	0.76
07/11/2024 13:00	0.7	1.3	0	0.52	0.25860	0.86
07/11/2024 14:00	0.4	1.5	1	0.70	0.34836	1.16
07/11/2024 15:00	0.1	1.5	2	0.74	0.36792	1.23
07/11/2024 16:00	0.1	1.5	2	0.73	0.36630	1.22
07/11/2024 17:00	0.1	1.5	2	0.74	0.36828	1.23
07/11/2024 18:00	0.1	1.5	2	0.74	0.36786	1.23
07/11/2024 19:00	0.1	1.5	2	0.73	0.36666	1.22
07/11/2024 20:00	0.2	1.5	1	0.73	0.36570	1.22
07/11/2024 21:00	0.2	1.5	1	0.73	0.36480	1.22
07/11/2024 22:00	0.5	1.4	1	0.62	0.31122	1.04
07/11/2024 23:00	0.8	1.3	0	0.51	0.25686	0.86
Average/Sum#:	0.6	1.4	1	0.55	0.27232	0.91
Minimum:	0.1	1.3	0	0.43	0.21300	0.71
Maximum:	1.0	1.5	2	0.74	0.36828	1.23
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/12/2024 00:00	0.8	1.3	1	0.45	0.22272	0.74
07/12/2024 01:00	0.8	1.4	1	0.43	0.21318	0.71
07/12/2024 02:00	0.8	1.5	1	0.43	0.21300	0.71
07/12/2024 03:00	0.9	1.4	1	0.43	0.21306	0.71
07/12/2024 04:00	0.8	1.3	1	0.43	0.21324	0.71
07/12/2024 05:00	0.8	1.4	1	0.43	0.21366	0.71
07/12/2024 06:00	0.8	1.4	0	0.45	0.22452	0.75
07/12/2024 07:00	0.8	1.4	1	0.43	0.21444	0.71
07/12/2024 08:00	0.8	1.4	0	0.43	0.21384	0.71
07/12/2024 09:00	0.7	1.3	1	0.43	0.21372	0.71
07/12/2024 10:00	0.7	1.4	1	0.43	0.21402	0.71
07/12/2024 11:00	0.7	1.3	0	0.48	0.23766	0.79
07/12/2024 12:00	0.7	1.3	0	0.52	0.25854	0.86
07/12/2024 13:00	0.7	1.3	0	0.52	0.25830	0.86
07/12/2024 14:00	0.7	1.3	1	0.55	0.27528	0.92
07/12/2024 15:00	0.6	1.4	1	0.62	0.30990	1.03
07/12/2024 16:00	0.4	1.4	1	0.65	0.32550	1.09
07/12/2024 17:00	0.2	1.5	2	0.74	0.36846	1.23
07/12/2024 18:00	0.2	1.5	2	0.74	0.36780	1.23
07/12/2024 19:00	0.2	1.5	1	0.70	0.35034	1.17
07/12/2024 20:00	0.3	1.5	1	0.68	0.34212	1.14
07/12/2024 21:00	0.7	1.3	0	0.51	0.25560	0.85
07/12/2024 22:00	0.7	1.4	0	0.51	0.25422	0.85
07/12/2024 23:00	0.8	1.3	1	0.44	0.21846	0.73
Average/Sum#:	0.7	1.4	1	0.52	0.25798	0.86
Minimum:	0.2	1.3	0	0.43	0.21300	0.71
Maximum:	0.9	1.5	2	0.74	0.36846	1.23
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/13/2024 00:00	0.8	1.4	1	0.42	0.21210	0.71
07/13/2024 01:00	0.8	1.3	1	0.42	0.21084	0.70
07/13/2024 02:00	0.7	1.4	1	0.43	0.21438	0.71
07/13/2024 03:00	0.8	1.4	1	0.44	0.21864	0.73
07/13/2024 04:00	0.7	1.4	1	0.42	0.21024	0.70
07/13/2024 05:00	0.8	1.4	1	0.42	0.21024	0.70
07/13/2024 06:00	0.8	1.4	1	0.42	0.21036	0.70
07/13/2024 07:00	0.7	1.4	1	0.42	0.21078	0.70
07/13/2024 08:00	0.6	1.4	1	0.49	0.24336	0.81
07/13/2024 09:00	0.8	1.3	1	0.45	0.22608	0.75
07/13/2024 10:00	0.7	1.4	1	0.43	0.21324	0.71
07/13/2024 11:00	0.8	1.4	1	0.43	0.21282	0.71
07/13/2024 12:00	0.7	1.3	0	0.43	0.21396	0.71
07/13/2024 13:00	0.7	1.3	0	0.43	0.21432	0.71
07/13/2024 14:00	0.7	1.3	0	0.43	0.21498	0.72
07/13/2024 15:00	0.7	1.3	0	0.43	0.21588	0.72
07/13/2024 16:00	0.7	1.3	0	0.44	0.21936	0.73
07/13/2024 17:00	0.9	1.4	0	0.46	0.22962	0.77
07/13/2024 18:00	0.7	1.3	0	0.50	0.25236	0.84
07/13/2024 19:00	0.7	1.4	1	0.43	0.21678	0.72
07/13/2024 20:00	0.7	1.4	0	0.45	0.22416	0.75
07/13/2024 21:00	0.7	1.4	1	0.44	0.21750	0.73
07/13/2024 22:00	0.7	1.4	1	0.43	0.21612	0.72
07/13/2024 23:00	0.7	1.4	1	0.43	0.21492	0.72
Average/Sum#:	0.7	1.4	1	0.44	0.21846	0.73
Minimum:	0.6	1.3	0	0.42	0.21024	0.70
Maximum:	0.9	1.4	1	0.50	0.25236	0.84
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/14/2024 00:00	0.7	1.4	1	0.43	0.21456	0.72
07/14/2024 01:00	0.7	1.4	1	0.43	0.21372	0.71
07/14/2024 02:00	0.7	1.4	1	0.43	0.21306	0.71
07/14/2024 03:00	0.8	1.4	1	0.42	0.21210	0.71
07/14/2024 04:00	0.7	1.4	1	0.42	0.21204	0.71
07/14/2024 05:00	0.7	1.4	1	0.42	0.21216	0.71
07/14/2024 06:00	0.7	1.4	1	0.42	0.21234	0.71
07/14/2024 07:00	0.7	1.4	1	0.42	0.21234	0.71
07/14/2024 08:00	0.7	1.4	1	0.43	0.21252	0.71
07/14/2024 09:00	0.7	1.4	1	0.43	0.21276	0.71
07/14/2024 10:00	0.7	1.4	1	0.43	0.21276	0.71
07/14/2024 11:00	0.7	1.4	1	0.43	0.21276	0.71
07/14/2024 12:00	0.7	1.3	0	0.43	0.21336	0.71
07/14/2024 13:00	0.7	1.3	0	0.43	0.21264	0.71
07/14/2024 14:00	0.7	1.3	0	0.45	0.22362	0.75
07/14/2024 15:00	0.7	1.3	0	0.43	0.21738	0.72
07/14/2024 16:00	0.7	1.4	0	0.43	0.21546	0.72
07/14/2024 17:00	0.7	1.3	0	0.44	0.21984	0.73
07/14/2024 18:00	0.7	1.3	0	0.46	0.23070	0.77
07/14/2024 19:00	0.8	1.3	0	0.46	0.22890	0.76
07/14/2024 20:00	0.7	1.4	0	0.46	0.22806	0.76
07/14/2024 21:00	0.7	1.4	1	0.48	0.23856	0.80
07/14/2024 22:00	0.7	1.3	1	0.43	0.21258	0.71
07/14/2024 23:00	0.7	1.4	1	0.42	0.21210	0.71
Average/Sum#:	0.7	1.4	1	0.43	0.21693	0.72
Minimum:	0.7	1.3	0	0.42	0.21204	0.71
Maximum:	0.8	1.4	1	0.48	0.23856	0.80
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/15/2024 00:00	0.7	1.4	1	0.42	0.21222	0.71
07/15/2024 01:00	0.7	1.4	1	0.42	0.21216	0.71
07/15/2024 02:00	0.7	1.4	1	0.42	0.21210	0.71
07/15/2024 03:00	0.8	1.4	1	0.45	0.22536	0.75
07/15/2024 04:00	0.7	1.4	1	0.42	0.21216	0.71
07/15/2024 05:00	0.7	1.4	1	0.42	0.21216	0.71
07/15/2024 06:00	0.7	1.4	1	0.42	0.21234	0.71
07/15/2024 07:00	0.7	1.4	1	0.43	0.21282	0.71
07/15/2024 08:00	0.7	1.4	1	0.43	0.21270	0.71
07/15/2024 09:00	0.7	1.4	1	0.43	0.21282	0.71
07/15/2024 10:00	0.7	1.3	1	0.43	0.21312	0.71
07/15/2024 11:00	0.7	1.4	1	0.43	0.21384	0.71
07/15/2024 12:00	0.6	1.3	0	0.43	0.21408	0.71
07/15/2024 13:00	0.6	1.3	0	0.43	0.21438	0.71
07/15/2024 14:00	0.6	1.3	0	0.43	0.21426	0.71
07/15/2024 15:00	0.7	1.3	0	0.44	0.21876	0.73
07/15/2024 16:00	0.7	1.3	0	0.43	0.21462	0.72
07/15/2024 17:00	0.7	1.3	0	0.43	0.21492	0.72
07/15/2024 18:00	0.6	1.3	0	0.43	0.21396	0.71
07/15/2024 19:00	0.7	1.4	1	0.43	0.21444	0.71
07/15/2024 20:00	0.7	1.4	1	0.43	0.21348	0.71
07/15/2024 21:00	0.7	1.3	1	0.43	0.21300	0.71
07/15/2024 22:00	0.7	1.4	1	0.43	0.21276	0.71
07/15/2024 23:00	0.7	1.4	1	0.43	0.21264	0.71
Average/Sum#:	0.7	1.4	1	0.43	0.21396	0.71
Minimum:	0.6	1.3	0	0.42	0.21210	0.71
Maximum:	0.8	1.4	1	0.45	0.22536	0.75
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/16/2024 00:00	0.7	1.4	1	0.43	0.21252	0.71
07/16/2024 01:00	0.7	1.4	1	0.42	0.21240	0.71
07/16/2024 02:00	0.7	1.5	1	0.42	0.21240	0.71
07/16/2024 03:00	0.8	1.4	1	0.42	0.21240	0.71
07/16/2024 04:00	0.7	1.4	0	0.46	0.22764	0.76
07/16/2024 05:00	0.7	1.4	1	0.49	0.24486	0.82
07/16/2024 06:00	0.8	1.4	1	0.43	0.21288	0.71
07/16/2024 07:00	0.8	1.4	1	0.43	0.21342	0.71
07/16/2024 08:00	0.8	1.4	1	0.43	0.21294	0.71
07/16/2024 09:00	0.7	1.4	1	0.43	0.21276	0.71
07/16/2024 10:00	0.7	1.4	1	0.43	0.21264	0.71
07/16/2024 11:00	0.7	1.4	1	0.43	0.21336	0.71
07/16/2024 12:00	0.0	0.0	0	0.43	0.21354	0.71
07/16/2024 13:00	0.0	0.0	0	0.43	0.21342	0.71
07/16/2024 14:00	0.7	0.3	0	0.44	0.22194	0.74
07/16/2024 15:00	0.7	1.3	0	0.51	0.25380	0.85
07/16/2024 16:00	0.7	1.3	0	0.43	0.21282	0.71
07/16/2024 17:00	0.8	1.4	0	0.52	0.26130	0.87
07/16/2024 18:00	0.7	1.4	1	0.63	0.31386	1.05
07/16/2024 19:00	1.0	1.4	1	0.61	0.30318	1.01
07/16/2024 20:00	0.9	1.4	1	0.62	0.31134	1.04
07/16/2024 21:00	1.0	1.5	0	0.54	0.27210	0.91
07/16/2024 22:00	0.7	1.3	1	0.46	0.23130	0.77
07/16/2024 23:00	0.8	1.4	1	0.43	0.21270	0.71
Average/Sum#:	0.8	1.3	1	0.47	0.23423	0.78
Minimum:	0.7	0.3	0	0.42	0.21240	0.71
Maximum:	1.0	1.5	1	0.63	0.31386	1.05
%SI	8.33	8.33	8.33	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/17/2024 00:00	0.8	1.4	1	0.43	0.21276	0.71
07/17/2024 01:00	0.8	1.4	1	0.43	0.21288	0.71
07/17/2024 02:00	0.8	1.3	1	0.43	0.21282	0.71
07/17/2024 03:00	0.9	1.4	1	0.43	0.21270	0.71
07/17/2024 04:00	0.8	1.4	1	0.43	0.21378	0.71
07/17/2024 05:00	0.7	1.3	1	0.47	0.23310	0.78
07/17/2024 06:00	0.8	1.4	1	0.43	0.21300	0.71
07/17/2024 07:00	0.8	1.4	1	0.43	0.21354	0.71
07/17/2024 08:00	0.8	1.4	1	0.43	0.21306	0.71
07/17/2024 09:00	0.8	1.4	1	0.43	0.21288	0.71
07/17/2024 10:00	0.7	1.4	1	0.43	0.21294	0.71
07/17/2024 11:00	0.7	1.4	1	0.43	0.21330	0.71
07/17/2024 12:00	0.7	1.4	0	0.43	0.21342	0.71
07/17/2024 13:00	0.7	1.4	1	0.43	0.21342	0.71
07/17/2024 14:00	0.7	1.3	0	0.43	0.21318	0.71
07/17/2024 15:00	0.7	1.3	0	0.43	0.21270	0.71
07/17/2024 16:00	0.7	1.2	0	0.43	0.21264	0.71
07/17/2024 17:00	0.7	1.3	0	0.46	0.23238	0.77
07/17/2024 18:00	0.7	1.2	0	0.47	0.23574	0.79
07/17/2024 19:00	0.7	1.3	0	0.52	0.25998	0.87
07/17/2024 20:00	0.7	1.4	0	0.53	0.26706	0.89
07/17/2024 21:00	0.7	1.3	0	0.53	0.26622	0.89
07/17/2024 22:00	0.7	1.4	0	0.48	0.23964	0.80
07/17/2024 23:00	0.8	1.4	1	0.43	0.21264	0.71
Average/Sum#:	0.7	1.4	1	0.45	0.22316	0.74
Minimum:	0.7	1.2	0	0.43	0.21264	0.71
Maximum:	0.9	1.4	1	0.53	0.26706	0.89
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/18/2024 00:00	0.8	1.4	1	0.42	0.21228	0.71
07/18/2024 01:00	0.8	1.4	1	0.42	0.21228	0.71
07/18/2024 02:00	0.8	1.4	1	0.42	0.21228	0.71
07/18/2024 03:00	0.9	1.4	1	0.42	0.21240	0.71
07/18/2024 04:00	0.8	1.3	0	0.45	0.22290	0.74
07/18/2024 05:00	0.8	1.4	1	0.43	0.21396	0.71
07/18/2024 06:00	0.9	1.4	1	0.43	0.21300	0.71
07/18/2024 07:00	0.8	1.4	1	0.43	0.21330	0.71
07/18/2024 08:00	0.9	1.4	1	0.43	0.21276	0.71
07/18/2024 09:00	0.8	1.4	0	0.42	0.21234	0.71
07/18/2024 10:00	0.8	1.4	0	0.42	0.21246	0.71
07/18/2024 11:00	0.7	1.3	0	0.45	0.22542	0.75
07/18/2024 12:00	0.7	1.2	0	0.47	0.23700	0.79
07/18/2024 13:00	0.7	1.3	0	0.47	0.23592	0.79
07/18/2024 14:00	0.7	1.3	0	0.51	0.25746	0.86
07/18/2024 15:00	0.7	1.4	0	0.52	0.26202	0.87
07/18/2024 16:00	0.7	1.4	1	0.54	0.26826	0.89
07/18/2024 17:00	0.3	1.5	2	0.77	0.38418	1.28
07/18/2024 18:00	0.3	1.5	2	0.77	0.38610	1.29
07/18/2024 19:00	0.3	1.5	2	0.77	0.38694	1.29
07/18/2024 20:00	0.3	1.5	2	0.77	0.38610	1.29
07/18/2024 21:00	0.5	1.4	1	0.66	0.33222	1.11
07/18/2024 22:00	0.6	1.4	1	0.64	0.32154	1.07
07/18/2024 23:00	0.7	1.4	1	0.63	0.31728	1.06
Average/Sum#:	0.7	1.4	1	0.53	0.26460	0.88
Minimum:	0.3	1.2	0	0.42	0.21228	0.71
Maximum:	0.9	1.5	2	0.77	0.38694	1.29
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/19/2024 00:00	0.8	1.4	1	0.63	0.31554	1.05
07/19/2024 01:00	0.9	1.4	1	0.63	0.31332	1.04
07/19/2024 02:00	0.9	1.4	1	0.62	0.31146	1.04
07/19/2024 03:00	1.0	1.5	1	0.62	0.31104	1.04
07/19/2024 04:00	1.0	1.4	1	0.62	0.31194	1.04
07/19/2024 05:00	0.8	1.5	1	0.63	0.31578	1.05
07/19/2024 06:00	1.1	1.4	1	0.62	0.30882	1.03
07/19/2024 07:00	1.2	1.4	1	0.59	0.29622	0.99
07/19/2024 08:00	0.9	1.4	1	0.44	0.21930	0.73
07/19/2024 09:00	0.8	1.3	0	0.43	0.21702	0.72
07/19/2024 10:00	0.8	1.3	0	0.43	0.21564	0.72
07/19/2024 11:00	0.8	1.3	0	0.45	0.22746	0.76
07/19/2024 12:00	0.6	1.4	1	0.65	0.32382	1.08
07/19/2024 13:00	0.5	1.4	1	0.66	0.32778	1.09
07/19/2024 14:00	0.3	1.5	1	0.72	0.35892	1.20
07/19/2024 15:00	0.3	1.5	2	0.76	0.38232	1.27
07/19/2024 16:00	0.3	1.5	2	0.77	0.38322	1.28
07/19/2024 17:00	0.3	1.5	2	0.77	0.38322	1.28
07/19/2024 18:00	0.3	1.5	2	0.77	0.38364	1.28
07/19/2024 19:00	0.3	1.5	2	0.76	0.37974	1.27
07/19/2024 20:00	0.3	1.5	1	0.70	0.35058	1.17
07/19/2024 21:00	0.3	1.5	1	0.72	0.35970	1.20
07/19/2024 22:00	0.3	1.5	1	0.73	0.36546	1.22
07/19/2024 23:00	0.3	1.5	1	0.70	0.34908	1.16
Average/Sum#:	0.6	1.4	1	0.64	0.32129	1.07
Minimum:	0.3	1.3	0	0.43	0.21564	0.72
Maximum:	1.2	1.5	2	0.77	0.38364	1.28
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/20/2024 00:00	0.5	1.4	1	0.66	0.33240	1.11
07/20/2024 01:00	0.8	1.4	1	0.63	0.31368	1.05
07/20/2024 02:00	0.8	1.4	0	0.63	0.31572	1.05
07/20/2024 03:00	0.8	1.4	0	0.64	0.31992	1.07
07/20/2024 04:00	0.9	1.5	0	0.63	0.31392	1.05
07/20/2024 05:00	1.0	1.4	0	0.63	0.31302	1.04
07/20/2024 06:00	1.0	1.4	0	0.61	0.30624	1.02
07/20/2024 07:00	0.8	1.3	0	0.50	0.24768	0.83
07/20/2024 08:00	0.8	1.4	0	0.44	0.21852	0.73
07/20/2024 09:00	0.7	1.4	0	0.43	0.21378	0.71
07/20/2024 10:00	0.7	1.4	0	0.43	0.21396	0.71
07/20/2024 11:00	0.9	1.3	0	0.46	0.23040	0.77
07/20/2024 12:00	0.7	1.3	0	0.48	0.24168	0.81
07/20/2024 13:00	0.7	1.3	0	0.52	0.25752	0.86
07/20/2024 14:00	0.7	1.4	0	0.52	0.26166	0.87
07/20/2024 15:00	0.6	1.4	0	0.63	0.31314	1.04
07/20/2024 16:00	0.5	1.4	0	0.63	0.31260	1.04
07/20/2024 17:00	0.3	1.5	0	0.68	0.34170	1.14
07/20/2024 18:00	0.2	1.5	0	0.72	0.36012	1.20
07/20/2024 19:00	0.2	1.5	0	0.71	0.35736	1.19
07/20/2024 20:00	0.2	1.5	0	0.71	0.35568	1.19
07/20/2024 21:00	0.2	1.5	0	0.71	0.35406	1.18
07/20/2024 22:00	0.3	1.5	0	0.70	0.35244	1.17
07/20/2024 23:00	0.4	1.5	0	0.70	0.34854	1.16
Average/Sum#:	0.6	1.4	1	0.60	0.29982	1.00
Minimum:	0.2	1.3	1	0.43	0.21378	0.71
Maximum:	1.0	1.5	1	0.72	0.36012	1.20
%SI	0.00	0.00	91.67	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/21/2024 00:00	1.0	1.4	0	0.54	0.27096	0.90
07/21/2024 01:00	0.7	1.4	0	0.43	0.21264	0.71
07/21/2024 02:00	0.7	1.3	0	0.43	0.21258	0.71
07/21/2024 03:00	0.8	1.5	0	0.43	0.21258	0.71
07/21/2024 04:00	0.7	1.4	0	0.43	0.21252	0.71
07/21/2024 05:00	0.7	1.4	0	0.43	0.21318	0.71
07/21/2024 06:00	0.0	0.0	0	0.43	0.21318	0.71
07/21/2024 07:00	0.7	1.5	1	0.43	0.21372	0.71
07/21/2024 08:00	0.7	1.4	1	0.43	0.21324	0.71
07/21/2024 09:00	0.7	1.4	1	0.43	0.21312	0.71
07/21/2024 10:00	0.7	1.4	1	0.43	0.21312	0.71
07/21/2024 11:00	0.7	1.4	1	0.43	0.21384	0.71
07/21/2024 12:00	0.7	1.3	0	0.43	0.21384	0.71
07/21/2024 13:00	0.7	1.4	0	0.43	0.21378	0.71
07/21/2024 14:00	0.7	1.3	0	0.43	0.21366	0.71
07/21/2024 15:00	0.7	1.3	0	0.43	0.21318	0.71
07/21/2024 16:00	0.7	1.3	0	0.43	0.21318	0.71
07/21/2024 17:00	0.7	1.2	0	0.47	0.23556	0.79
07/21/2024 18:00	0.7	1.3	0	0.51	0.25722	0.86
07/21/2024 19:00	0.7	1.4	0	0.50	0.25092	0.84
07/21/2024 20:00	0.7	1.4	0	0.51	0.25410	0.85
07/21/2024 21:00	0.7	1.4	0	0.51	0.25518	0.85
07/21/2024 22:00	0.8	1.3	1	0.45	0.22746	0.76
07/21/2024 23:00	0.7	1.3	1	0.49	0.24300	0.81
Average/Sum#:	0.7	1.4	0	0.45	0.22524	0.75
Minimum:	0.7	1.2	0	0.43	0.21252	0.71
Maximum:	1.0	1.5	1	0.54	0.27096	0.90
%SI	4.17	4.17	29.17	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/22/2024 00:00	0.8	1.4	1	0.46	0.23088	0.77
07/22/2024 01:00	0.8	1.4	1	0.42	0.21246	0.71
07/22/2024 02:00	0.7	1.6	0	0.51	0.25464	0.85
07/22/2024 03:00	0.8	1.3	1	0.51	0.25434	0.85
07/22/2024 04:00	0.7	1.4	0	0.53	0.26352	0.88
07/22/2024 05:00	0.7	1.4	1	0.50	0.24792	0.83
07/22/2024 06:00	0.8	1.4	1	0.43	0.21318	0.71
07/22/2024 07:00	0.7	1.4	1	0.43	0.21336	0.71
07/22/2024 08:00	0.7	1.4	1	0.43	0.21288	0.71
07/22/2024 09:00	0.7	1.4	1	0.43	0.21288	0.71
07/22/2024 10:00	0.7	1.3	0	0.43	0.21276	0.71
07/22/2024 11:00	0.7	1.2	0	0.45	0.22710	0.76
07/22/2024 12:00	0.7	1.4	0	0.51	0.25596	0.85
07/22/2024 13:00	0.7	1.3	0	0.52	0.25866	0.86
07/22/2024 14:00	0.7	1.3	0	0.52	0.25848	0.86
07/22/2024 15:00	0.4	1.5	1	0.69	0.34728	1.16
07/22/2024 16:00	0.2	1.5	2	0.73	0.36528	1.22
07/22/2024 17:00	0.2	1.5	2	0.74	0.36906	1.23
07/22/2024 18:00	0.2	1.5	2	0.73	0.36330	1.21
07/22/2024 19:00	0.2	1.5	1	0.72	0.36054	1.20
07/22/2024 20:00	0.4	1.5	1	0.66	0.33162	1.11
07/22/2024 21:00	0.5	1.4	1	0.66	0.32754	1.09
07/22/2024 22:00	0.7	1.3	1	0.55	0.27306	0.91
07/22/2024 23:00	0.7	1.3	0	0.51	0.25716	0.86
Average/Sum#:	0.6	1.4	1	0.54	0.27183	0.91
Minimum:	0.2	1.2	0	0.42	0.21246	0.71
Maximum:	0.8	1.6	2	0.74	0.36906	1.23
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/23/2024 00:00	0.7	1.3	0	0.50	0.24924	0.83
07/23/2024 01:00	0.7	1.3	0	0.51	0.25482	0.85
07/23/2024 02:00	0.7	1.5	0	0.49	0.24672	0.82
07/23/2024 03:00	1.0	1.4	1	0.49	0.24390	0.81
07/23/2024 04:00	0.4	1.5	1	0.70	0.34806	1.16
07/23/2024 05:00	0.3	1.5	1	0.71	0.35502	1.18
07/23/2024 06:00	0.3	1.5	1	0.71	0.35250	1.18
07/23/2024 07:00	0.3	1.5	1	0.71	0.35466	1.18
07/23/2024 08:00	0.2	1.5	1	0.71	0.35586	1.19
07/23/2024 09:00	0.2	1.5	1	0.71	0.35664	1.19
07/23/2024 10:00	0.2	1.5	1	0.71	0.35724	1.19
07/23/2024 11:00	0.2	1.5	1	0.72	0.35886	1.20
07/23/2024 12:00	0.2	1.5	2	0.73	0.36726	1.22
07/23/2024 13:00	0.2	1.5	2	0.75	0.37350	1.25
07/23/2024 14:00	0.2	1.5	2	0.74	0.37248	1.24
07/23/2024 15:00	0.2	1.5	2	0.74	0.37122	1.24
07/23/2024 16:00	0.1	1.5	2	0.74	0.37050	1.24
07/23/2024 17:00	0.1	1.5	2	0.74	0.37122	1.24
07/23/2024 18:00	0.1	1.5	2	0.74	0.37020	1.23
07/23/2024 19:00	0.1	1.5	2	0.74	0.36762	1.23
07/23/2024 20:00	0.1	1.5	1	0.73	0.36648	1.22
07/23/2024 21:00	0.2	1.5	1	0.73	0.36540	1.22
07/23/2024 22:00	0.2	1.5	1	0.73	0.36474	1.22
07/23/2024 23:00	0.3	1.5	1	0.71	0.35412	1.18
Average/Sum#:	0.3	1.5	1	0.69	0.34368	1.15
Minimum:	0.1	1.3	0	0.49	0.24390	0.81
Maximum:	1.0	1.5	2	0.75	0.37350	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/24/2024 00:00	0.8	1.4	1	0.61	0.30486	1.02
07/24/2024 01:00	0.9	1.4	1	0.49	0.24366	0.81
07/24/2024 02:00	0.8	1.3	1	0.43	0.21390	0.71
07/24/2024 03:00	0.8	1.4	1	0.45	0.22368	0.75
07/24/2024 04:00	0.7	1.4	1	0.60	0.29982	1.00
07/24/2024 05:00	0.6	1.5	1	0.66	0.32994	1.10
07/24/2024 06:00	1.1	1.4	1	0.52	0.25998	0.87
07/24/2024 07:00	0.7	1.4	0	0.48	0.24090	0.80
07/24/2024 08:00	0.7	1.3	0	0.44	0.21840	0.73
07/24/2024 09:00	0.8	1.3	0	0.51	0.25356	0.85
07/24/2024 10:00	0.8	1.4	0	0.52	0.25920	0.86
07/24/2024 11:00	0.4	1.5	1	0.67	0.33594	1.12
07/24/2024 12:00	0.1	1.5	1	0.73	0.36648	1.22
07/24/2024 13:00	0.1	1.5	2	0.73	0.36666	1.22
07/24/2024 14:00	0.1	1.5	2	0.74	0.37146	1.24
07/24/2024 15:00	0.1	1.5	2	0.74	0.37146	1.24
07/24/2024 16:00	0.2	1.5	2	0.74	0.36984	1.23
07/24/2024 17:00	0.2	1.5	1	0.92	0.46212	1.54
07/24/2024 18:00	0.2	1.5	1	0.94	0.46956	1.57
07/24/2024 19:00	0.1	1.5	1	0.93	0.46338	1.54
07/24/2024 20:00	0.2	1.5	1	0.82	0.41118	1.37
07/24/2024 21:00	0.2	1.5	1	0.73	0.36522	1.22
07/24/2024 22:00	0.7	1.4	1	0.63	0.31566	1.05
07/24/2024 23:00	0.8	1.4	1	0.60	0.30162	1.01
Average/Sum#:	0.5	1.4	1	0.65	0.32577	1.09
Minimum:	0.1	1.3	0	0.43	0.21390	0.71
Maximum:	1.1	1.5	2	0.94	0.46956	1.57
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/25/2024 00:00	0.7	1.4	0	0.50	0.24954	0.83
07/25/2024 01:00	0.7	1.4	1	0.46	0.22968	0.77
07/25/2024 02:00	0.7	1.5	1	0.43	0.21264	0.71
07/25/2024 03:00	0.8	1.4	1	0.43	0.21270	0.71
07/25/2024 04:00	0.7	1.3	1	0.46	0.22860	0.76
07/25/2024 05:00	0.7	1.3	0	0.50	0.24996	0.83
07/25/2024 06:00	0.8	1.3	1	0.45	0.22542	0.75
07/25/2024 07:00	0.7	1.4	1	0.43	0.21342	0.71
07/25/2024 08:00	0.7	1.4	1	0.43	0.21300	0.71
07/25/2024 09:00	0.7	1.4	1	0.43	0.21426	0.71
07/25/2024 10:00	0.7	1.4	1	0.43	0.21474	0.72
07/25/2024 11:00	0.7	1.4	1	0.43	0.21558	0.72
07/25/2024 12:00	0.7	1.3	0	0.49	0.24270	0.81
07/25/2024 13:00	0.6	1.5	1	0.63	0.31680	1.06
07/25/2024 14:00	0.3	1.5	1	0.69	0.34722	1.16
07/25/2024 15:00	0.2	1.4	1	0.70	0.34854	1.16
07/25/2024 16:00	0.3	1.5	1	0.70	0.34944	1.16
07/25/2024 17:00	0.2	1.5	1	0.72	0.36060	1.20
07/25/2024 18:00	0.2	1.5	1	0.73	0.36726	1.22
07/25/2024 19:00	0.2	1.5	1	0.73	0.36390	1.21
07/25/2024 20:00	0.2	1.5	1	0.72	0.36168	1.21
07/25/2024 21:00	0.7	1.4	1	0.61	0.30438	1.01
07/25/2024 22:00	0.7	1.4	1	0.49	0.24324	0.81
07/25/2024 23:00	0.7	1.4	1	0.43	0.21276	0.71
Average/Sum#:	0.6	1.4	1	0.54	0.27075	0.90
Minimum:	0.2	1.3	0	0.43	0.21264	0.71
Maximum:	0.8	1.5	1	0.73	0.36726	1.22
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/26/2024 00:00	0.7	1.4	1	0.42	0.21240	0.71
07/26/2024 01:00	0.7	1.4	1	0.42	0.21210	0.71
07/26/2024 02:00	0.8	1.5	1	0.42	0.21186	0.71
07/26/2024 03:00	0.9	1.4	1	0.42	0.21192	0.71
07/26/2024 04:00	0.8	1.4	1	0.42	0.21192	0.71
07/26/2024 05:00	0.8	1.4	1	0.42	0.21186	0.71
07/26/2024 06:00	0.8	1.4	1	0.42	0.21222	0.71
07/26/2024 07:00	0.8	1.4	1	0.43	0.21258	0.71
07/26/2024 08:00	0.8	1.4	1	0.42	0.21192	0.71
07/26/2024 09:00	0.7	1.4	1	0.42	0.21192	0.71
07/26/2024 10:00	0.7	1.3	0	0.42	0.21216	0.71
07/26/2024 11:00	0.7	1.4	0	0.43	0.21294	0.71
07/26/2024 12:00	0.7	1.3	0	0.43	0.21378	0.71
07/26/2024 13:00	0.8	1.4	0	0.43	0.21408	0.71
07/26/2024 14:00	0.7	1.3	0	0.43	0.21426	0.71
07/26/2024 15:00	0.7	1.3	0	0.43	0.21372	0.71
07/26/2024 16:00	0.7	1.3	0	0.43	0.21360	0.71
07/26/2024 17:00	0.7	1.3	0	0.44	0.22044	0.73
07/26/2024 18:00	0.8	1.4	1	0.53	0.26700	0.89
07/26/2024 19:00	0.7	1.3	0	0.51	0.25632	0.85
07/26/2024 20:00	0.7	1.4	1	0.47	0.23688	0.79
07/26/2024 21:00	0.7	1.4	1	0.42	0.21198	0.71
07/26/2024 22:00	0.8	1.4	1	0.42	0.21228	0.71
07/26/2024 23:00	0.8	1.4	1	0.42	0.21210	0.71
Average/Sum#:	0.8	1.4	1	0.43	0.21801	0.73
Minimum:	0.7	1.3	0	0.42	0.21186	0.71
Maximum:	0.9	1.5	1	0.53	0.26700	0.89
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/27/2024 00:00	0.8	1.4	1	0.42	0.21222	0.71
07/27/2024 01:00	0.8	1.4	1	0.42	0.21246	0.71
07/27/2024 02:00	0.8	1.4	1	0.42	0.21246	0.71
07/27/2024 03:00	0.9	1.5	1	0.43	0.21258	0.71
07/27/2024 04:00	0.8	1.4	1	0.43	0.21270	0.71
07/27/2024 05:00	0.8	1.4	1	0.43	0.21306	0.71
07/27/2024 06:00	0.8	1.4	1	0.43	0.21318	0.71
07/27/2024 07:00	0.8	1.4	1	0.43	0.21330	0.71
07/27/2024 08:00	0.8	1.4	1	0.43	0.21336	0.71
07/27/2024 09:00	0.8	1.4	1	0.43	0.21336	0.71
07/27/2024 10:00	0.8	1.4	1	0.43	0.21324	0.71
07/27/2024 11:00	0.8	1.4	1	0.43	0.21408	0.71
07/27/2024 12:00	0.8	1.3	1	0.43	0.21414	0.71
07/27/2024 13:00	0.7	1.4	1	0.43	0.21396	0.71
07/27/2024 14:00	0.7	1.3	1	0.43	0.21372	0.71
07/27/2024 15:00	0.7	1.4	1	0.43	0.21300	0.71
07/27/2024 16:00	0.7	1.4	1	0.43	0.21318	0.71
07/27/2024 17:00	0.7	1.3	1	0.43	0.21306	0.71
07/27/2024 18:00	0.7	1.4	1	0.43	0.21288	0.71
07/27/2024 19:00	0.7	1.4	1	0.43	0.21276	0.71
07/27/2024 20:00	0.7	1.4	1	0.43	0.21264	0.71
07/27/2024 21:00	0.8	1.4	1	0.43	0.21252	0.71
07/27/2024 22:00	0.8	1.4	1	0.43	0.21264	0.71
07/27/2024 23:00	0.8	1.4	1	0.43	0.21270	0.71
Average/Sum#:	0.8	1.4	1	0.43	0.21305	0.71
Minimum:	0.7	1.3	1	0.42	0.21222	0.71
Maximum:	0.9	1.5	1	0.43	0.21414	0.71
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/28/2024 00:00	0.8	1.4	1	0.43	0.21282	0.71
07/28/2024 01:00	0.8	1.4	1	0.43	0.21294	0.71
07/28/2024 02:00	0.8	1.5	1	0.43	0.21282	0.71
07/28/2024 03:00	0.9	1.4	1	0.43	0.21264	0.71
07/28/2024 04:00	0.8	1.4	1	0.43	0.21282	0.71
07/28/2024 05:00	0.8	1.4	1	0.43	0.21288	0.71
07/28/2024 06:00	0.8	1.5	1	0.43	0.21324	0.71
07/28/2024 07:00	0.8	1.5	1	0.43	0.21354	0.71
07/28/2024 08:00	0.8	1.5	1	0.43	0.21336	0.71
07/28/2024 09:00	0.8	1.5	1	0.43	0.21348	0.71
07/28/2024 10:00	0.8	1.5	1	0.43	0.21336	0.71
07/28/2024 11:00	0.8	1.4	1	0.43	0.21342	0.71
07/28/2024 12:00	0.7	1.5	1	0.43	0.21348	0.71
07/28/2024 13:00	0.7	1.4	1	0.43	0.21414	0.71
07/28/2024 14:00	0.7	1.4	1	0.43	0.21462	0.72
07/28/2024 15:00	0.7	1.4	1	0.43	0.21444	0.71
07/28/2024 16:00	0.7	1.5	1	0.43	0.21426	0.71
07/28/2024 17:00	0.7	1.4	1	0.44	0.21954	0.73
07/28/2024 18:00	0.7	1.4	0	0.43	0.21330	0.71
07/28/2024 19:00	0.7	1.5	1	0.42	0.21222	0.71
07/28/2024 20:00	0.7	1.4	1	0.43	0.21258	0.71
07/28/2024 21:00	0.8	1.5	1	0.43	0.21282	0.71
07/28/2024 22:00	0.8	1.5	1	0.43	0.21300	0.71
07/28/2024 23:00	0.8	1.5	1	0.43	0.21312	0.71
Average/Sum#:	0.8	1.5	1	0.43	0.21354	0.71
Minimum:	0.7	1.4	0	0.42	0.21222	0.71
Maximum:	0.9	1.5	1	0.44	0.21954	0.73
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/29/2024 00:00	0.8	1.4	1	0.43	0.21324	0.71
07/29/2024 01:00	0.8	1.5	1	0.43	0.21348	0.71
07/29/2024 02:00	0.8	1.4	1	0.43	0.21360	0.71
07/29/2024 03:00	0.9	1.5	1	0.43	0.21354	0.71
07/29/2024 04:00	0.8	1.5	1	0.43	0.21360	0.71
07/29/2024 05:00	0.8	1.5	1	0.43	0.21366	0.71
07/29/2024 06:00	0.8	1.5	1	0.43	0.21396	0.71
07/29/2024 07:00	0.8	1.4	1	0.43	0.21426	0.71
07/29/2024 08:00	0.8	1.5	1	0.43	0.21360	0.71
07/29/2024 09:00	0.8	1.5	1	0.43	0.21336	0.71
07/29/2024 10:00	0.8	1.5	1	0.43	0.21342	0.71
07/29/2024 11:00	0.8	1.5	1	0.43	0.21408	0.71
07/29/2024 12:00	0.7	1.4	1	0.43	0.21372	0.71
07/29/2024 13:00	0.7	1.5	1	0.43	0.21378	0.71
07/29/2024 14:00	0.7	1.4	1	0.43	0.21354	0.71
07/29/2024 15:00	0.7	1.4	0	0.43	0.21312	0.71
07/29/2024 16:00	0.7	1.4	0	0.44	0.22152	0.74
07/29/2024 17:00	0.7	1.4	1	0.55	0.27486	0.92
07/29/2024 18:00	0.5	1.6	1	0.67	0.33672	1.12
07/29/2024 19:00	1.0	1.5	1	0.60	0.30198	1.01
07/29/2024 20:00	1.1	1.5	1	0.60	0.30060	1.00
07/29/2024 21:00	1.0	1.5	1	0.53	0.26274	0.88
07/29/2024 22:00	0.8	1.5	1	0.43	0.21252	0.71
07/29/2024 23:00	0.8	1.5	1	0.42	0.21246	0.71
Average/Sum#:	0.8	1.5	1	0.46	0.23089	0.77
Minimum:	0.5	1.4	0	0.42	0.21246	0.71
Maximum:	1.1	1.6	1	0.67	0.33672	1.12
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/30/2024 00:00	0.8	1.5	1	0.43	0.21252	0.71
07/30/2024 01:00	0.8	1.5	1	0.42	0.21246	0.71
07/30/2024 02:00	0.8	1.4	1	0.42	0.21246	0.71
07/30/2024 03:00	0.9	1.5	1	0.42	0.21240	0.71
07/30/2024 04:00	0.8	1.5	1	0.43	0.21258	0.71
07/30/2024 05:00	0.8	1.4	1	0.46	0.23160	0.77
07/30/2024 06:00	0.8	1.5	1	0.43	0.21288	0.71
07/30/2024 07:00	0.8	1.5	1	0.43	0.21336	0.71
07/30/2024 08:00	0.8	1.4	1	0.43	0.21270	0.71
07/30/2024 09:00	0.8	1.5	1	0.43	0.21276	0.71
07/30/2024 10:00	0.7	1.5	1	0.43	0.21252	0.71
07/30/2024 11:00	0.7	1.4	1	0.43	0.21312	0.71
07/30/2024 12:00	0.7	1.4	1	0.43	0.21438	0.71
07/30/2024 13:00	0.7	1.4	0	0.43	0.21324	0.71
07/30/2024 14:00	0.7	1.4	0	0.43	0.21294	0.71
07/30/2024 15:00	0.9	1.4	0	0.49	0.24546	0.82
07/30/2024 16:00	0.5	1.5	1	0.66	0.33114	1.10
07/30/2024 17:00	0.2	1.5	1	0.72	0.36042	1.20
07/30/2024 18:00	0.2	1.6	1	0.73	0.36324	1.21
07/30/2024 19:00	0.2	1.6	1	0.71	0.35550	1.19
07/30/2024 20:00	0.4	1.5	1	0.69	0.34452	1.15
07/30/2024 21:00	0.7	1.5	1	0.59	0.29610	0.99
07/30/2024 22:00	0.8	1.4	1	0.43	0.21306	0.71
07/30/2024 23:00	0.8	1.4	1	0.44	0.21852	0.73
Average/Sum#:	0.7	1.5	1	0.50	0.24750	0.83
Minimum:	0.2	1.4	0	0.42	0.21240	0.71
Maximum:	0.9	1.6	1	0.73	0.36324	1.21
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/31/2024 00:00	0.8	1.5	1	0.42	0.21162	0.71
07/31/2024 01:00	0.8	1.5	1	0.42	0.21156	0.71
07/31/2024 02:00	0.8	1.4	1	0.42	0.21180	0.71
07/31/2024 03:00	0.8	1.5	1	0.43	0.21408	0.71
07/31/2024 04:00	0.7	1.3	0	0.48	0.24078	0.80
07/31/2024 05:00	0.7	1.4	1	0.49	0.24324	0.81
07/31/2024 06:00	0.8	1.4	1	0.43	0.21270	0.71
07/31/2024 07:00	0.8	1.4	1	0.43	0.21288	0.71
07/31/2024 08:00	0.8	1.4	1	0.42	0.21234	0.71
07/31/2024 09:00	0.8	1.3	1	0.42	0.21210	0.71
07/31/2024 10:00	0.7	1.4	1	0.42	0.21180	0.71
07/31/2024 11:00	0.7	1.3	1	0.43	0.21444	0.71
07/31/2024 12:00	0.7	1.3	0	0.44	0.22092	0.74
07/31/2024 13:00	0.7	1.3	0	0.43	0.21306	0.71
07/31/2024 14:00	0.7	1.3	0	0.45	0.22350	0.75
07/31/2024 15:00	0.8	1.4	0	0.49	0.24624	0.82
07/31/2024 16:00	0.4	1.4	1	0.68	0.33966	1.13
07/31/2024 17:00	0.4	1.4	1	0.67	0.33318	1.11
07/31/2024 18:00	0.2	1.4	1	0.71	0.35400	1.18
07/31/2024 19:00	0.5	1.4	1	0.66	0.32862	1.10
07/31/2024 20:00	0.3	1.5	1	0.70	0.35106	1.17
07/31/2024 21:00	0.4	1.5	1	0.68	0.34188	1.14
07/31/2024 22:00	0.5	1.5	1	0.67	0.33324	1.11
07/31/2024 23:00	0.7	1.4	1	0.60	0.30120	1.00
Average/Sum#:	0.6	1.4	1	0.52	0.25816	0.86
Minimum:	0.2	1.3	0	0.42	0.21156	0.71
Maximum:	0.8	1.5	1	0.71	0.35400	1.18
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/01/2024 00:00	0.7	1.3	0	0.49	0.24606	0.82
08/01/2024 01:00	0.8	1.4	1	0.44	0.21960	0.73
08/01/2024 02:00	0.8	1.3	1	0.43	0.21366	0.71
08/01/2024 03:00	0.8	1.4	1	0.44	0.21858	0.73
08/01/2024 04:00	0.7	1.3	1	0.46	0.22770	0.76
08/01/2024 05:00	0.7	1.4	0	0.51	0.25404	0.85
08/01/2024 06:00	0.8	1.3	1	0.43	0.21726	0.72
08/01/2024 07:00	0.7	1.3	1	0.45	0.22452	0.75
08/01/2024 08:00	0.8	1.4	1	0.44	0.21756	0.73
08/01/2024 09:00	0.7	1.4	1	0.44	0.21750	0.73
08/01/2024 10:00	0.7	1.3	0	0.44	0.21780	0.73
08/01/2024 11:00	0.7	1.4	0	0.50	0.24756	0.83
08/01/2024 12:00	0.7	1.3	0	0.47	0.23736	0.79
08/01/2024 13:00	0.7	1.4	0	0.53	0.26580	0.89
08/01/2024 14:00	0.7	1.3	1	0.51	0.25710	0.86
08/01/2024 15:00	0.7	1.2	1	0.50	0.24798	0.83
08/01/2024 16:00	0.2	1.4	1	0.72	0.35760	1.19
08/01/2024 17:00	0.2	1.4	1	0.70	0.35052	1.17
08/01/2024 18:00	0.1	1.4	1	0.72	0.36072	1.20
08/01/2024 19:00	0.3	1.4	1	0.68	0.34110	1.14
08/01/2024 20:00	0.2	1.4	1	0.72	0.35856	1.20
08/01/2024 21:00	0.2	1.4	1	0.71	0.35688	1.19
08/01/2024 22:00	0.4	1.4	1	0.68	0.34044	1.13
08/01/2024 23:00	1.1	1.3	1	0.60	0.30156	1.01
Average/Sum#:	0.6	1.4	1	0.54	0.27073	0.90
Minimum:	0.1	1.2	0	0.43	0.21366	0.71
Maximum:	1.1	1.4	1	0.72	0.36072	1.20
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/02/2024 00:00	0.8	1.2	0	0.50	0.25002	0.83
08/02/2024 01:00	0.8	1.3	1	0.45	0.22668	0.76
08/02/2024 02:00	0.8	1.3	1	0.43	0.21396	0.71
08/02/2024 03:00	0.9	1.2	0	0.45	0.22344	0.74
08/02/2024 04:00	0.8	1.3	0	0.51	0.25596	0.85
08/02/2024 05:00	0.7	1.2	0	0.51	0.25560	0.85
08/02/2024 06:00	0.7	1.3	0	0.51	0.25392	0.85
08/02/2024 07:00	0.7	1.3	0	0.51	0.25446	0.85
08/02/2024 08:00	0.7	1.3	0	0.52	0.25854	0.86
08/02/2024 09:00	1.0	1.4	1	0.56	0.28134	0.94
08/02/2024 10:00	0.2	1.4	1	0.72	0.36120	1.20
08/02/2024 11:00	0.2	1.4	1	0.73	0.36444	1.21
08/02/2024 12:00	0.2	1.4	1	0.73	0.36396	1.21
08/02/2024 13:00	0.2	1.4	1	0.73	0.36480	1.22
08/02/2024 14:00	0.2	1.4	1	0.72	0.35850	1.20
08/02/2024 15:00	0.3	1.4	1	0.68	0.34176	1.14
08/02/2024 16:00	0.7	1.3	1	0.61	0.30744	1.02
08/02/2024 17:00	0.6	1.3	1	0.63	0.31686	1.06
08/02/2024 18:00	0.4	1.4	1	0.67	0.33462	1.12
08/02/2024 19:00	0.9	1.4	1	0.61	0.30312	1.01
08/02/2024 20:00	0.9	1.3	1	0.61	0.30300	1.01
08/02/2024 21:00	0.9	1.3	1	0.58	0.28776	0.96
08/02/2024 22:00	0.7	1.3	0	0.51	0.25476	0.85
08/02/2024 23:00	0.7	1.3	0	0.50	0.25086	0.84
Average/Sum#:	0.6	1.3	1	0.58	0.29113	0.97
Minimum:	0.2	1.2	0	0.43	0.21396	0.71
Maximum:	1.0	1.4	1	0.73	0.36480	1.22
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/03/2024 00:00	0.7	1.3	0	0.48	0.23928	0.80
08/03/2024 01:00	0.8	1.3	1	0.44	0.21840	0.73
08/03/2024 02:00	0.8	1.2	1	0.43	0.21270	0.71
08/03/2024 03:00	0.9	1.3	1	0.43	0.21276	0.71
08/03/2024 04:00	0.8	1.4	1	0.43	0.21258	0.71
08/03/2024 05:00	0.8	1.4	1	0.43	0.21294	0.71
08/03/2024 06:00	0.8	1.4	1	0.43	0.21300	0.71
08/03/2024 07:00	0.8	1.4	1	0.43	0.21300	0.71
08/03/2024 08:00	0.8	1.4	1	0.43	0.21276	0.71
08/03/2024 09:00	0.8	1.3	1	0.43	0.21276	0.71
08/03/2024 10:00	0.7	1.4	0	0.43	0.21258	0.71
08/03/2024 11:00	0.7	1.2	0	0.43	0.21330	0.71
08/03/2024 12:00	0.7	1.3	0	0.43	0.21366	0.71
08/03/2024 13:00	0.7	1.2	0	0.43	0.21384	0.71
08/03/2024 14:00	0.7	1.3	0	0.43	0.21378	0.71
08/03/2024 15:00	0.7	1.3	0	0.43	0.21324	0.71
08/03/2024 16:00	0.7	1.2	0	0.43	0.21306	0.71
08/03/2024 17:00	0.8	1.2	0	0.48	0.24024	0.80
08/03/2024 18:00	0.2	1.4	1	0.71	0.35670	1.19
08/03/2024 19:00	0.4	1.4	1	0.67	0.33738	1.12
08/03/2024 20:00	0.7	1.4	1	0.54	0.27102	0.90
08/03/2024 21:00	0.7	1.3	0	0.48	0.23928	0.80
08/03/2024 22:00	0.7	1.3	0	0.49	0.24720	0.82
08/03/2024 23:00	0.8	1.3	1	0.44	0.22056	0.74
Average/Sum#:	0.7	1.3	1	0.47	0.23192	0.77
Minimum:	0.2	1.2	0	0.43	0.21258	0.71
Maximum:	0.9	1.4	1	0.71	0.35670	1.19
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/04/2024 00:00	0.8	1.4	1	0.42	0.21234	0.71
08/04/2024 01:00	0.8	1.3	1	0.42	0.21234	0.71
08/04/2024 02:00	0.8	1.3	1	0.43	0.21258	0.71
08/04/2024 03:00	0.8	1.4	1	0.43	0.21252	0.71
08/04/2024 04:00	0.8	1.3	1	0.43	0.21252	0.71
08/04/2024 05:00	0.8	1.3	1	0.43	0.21270	0.71
08/04/2024 06:00	0.7	1.4	1	0.43	0.21336	0.71
08/04/2024 07:00	0.7	1.3	1	0.43	0.21378	0.71
08/04/2024 08:00	0.7	1.3	1	0.43	0.21306	0.71
08/04/2024 09:00	0.7	1.4	1	0.43	0.21294	0.71
08/04/2024 10:00	0.7	1.3	1	0.43	0.21306	0.71
08/04/2024 11:00	0.7	1.3	0	0.43	0.21372	0.71
08/04/2024 12:00	0.7	1.3	0	0.43	0.21366	0.71
08/04/2024 13:00	0.7	1.4	0	0.43	0.21372	0.71
08/04/2024 14:00	0.7	1.3	0	0.43	0.21360	0.71
08/04/2024 15:00	0.7	1.3	0	0.43	0.21306	0.71
08/04/2024 16:00	0.7	1.2	0	0.43	0.21288	0.71
08/04/2024 17:00	0.7	1.3	1	0.54	0.26886	0.90
08/04/2024 18:00	0.2	1.5	1	0.71	0.35718	1.19
08/04/2024 19:00	0.6	1.4	1	0.63	0.31488	1.05
08/04/2024 20:00	0.8	1.4	1	0.61	0.30456	1.02
08/04/2024 21:00	0.7	1.3	0	0.51	0.25602	0.85
08/04/2024 22:00	0.7	1.3	0	0.50	0.25062	0.84
08/04/2024 23:00	0.7	1.4	1	0.47	0.23316	0.78
Average/Sum#:	0.7	1.3	1	0.47	0.23363	0.78
Minimum:	0.2	1.2	0	0.42	0.21234	0.71
Maximum:	0.8	1.5	1	0.71	0.35718	1.19
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/05/2024 00:00	0.8	1.3	1	0.44	0.21756	0.73
08/05/2024 01:00	0.8	1.4	1	0.42	0.21234	0.71
08/05/2024 02:00	0.8	1.3	1	0.42	0.21234	0.71
08/05/2024 03:00	0.9	1.4	1	0.42	0.21240	0.71
08/05/2024 04:00	0.7	1.3	0	0.48	0.24126	0.80
08/05/2024 05:00	0.7	1.3	1	0.49	0.24294	0.81
08/05/2024 06:00	0.8	1.3	1	0.46	0.22824	0.76
08/05/2024 07:00	0.8	1.4	1	0.43	0.21414	0.71
08/05/2024 08:00	0.7	1.3	1	0.43	0.21354	0.71
08/05/2024 09:00	0.7	1.4	1	0.43	0.21360	0.71
08/05/2024 10:00	0.7	1.3	1	0.43	0.21366	0.71
08/05/2024 11:00	0.7	1.4	1	0.43	0.21426	0.71
08/05/2024 12:00	0.7	1.2	0	0.48	0.24030	0.80
08/05/2024 13:00	0.7	1.3	1	0.43	0.21642	0.72
08/05/2024 14:00	0.7	1.3	0	0.47	0.23322	0.78
08/05/2024 15:00	0.7	1.3	1	0.43	0.21492	0.72
08/05/2024 16:00	0.7	1.3	1	0.43	0.21492	0.72
08/05/2024 17:00	0.7	1.3	0	0.46	0.22794	0.76
08/05/2024 18:00	0.7	1.4	1	0.61	0.30342	1.01
08/05/2024 19:00	0.7	1.4	1	0.49	0.24330	0.81
08/05/2024 20:00	0.8	1.3	1	0.46	0.22872	0.76
08/05/2024 21:00	0.8	1.4	0	0.48	0.24060	0.80
08/05/2024 22:00	0.7	1.3	1	0.48	0.24060	0.80
08/05/2024 23:00	0.8	1.4	1	0.43	0.21318	0.71
Average/Sum#:	0.7	1.3	1	0.46	0.22724	0.76
Minimum:	0.7	1.2	0	0.42	0.21234	0.71
Maximum:	0.9	1.4	1	0.61	0.30342	1.01
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/06/2024 00:00	0.8	1.3	1	0.43	0.21252	0.71
08/06/2024 01:00	0.8	1.3	1	0.43	0.21258	0.71
08/06/2024 02:00	0.8	1.4	1	0.43	0.21264	0.71
08/06/2024 03:00	0.9	1.5	1	0.43	0.21270	0.71
08/06/2024 04:00	0.8	1.4	1	0.43	0.21282	0.71
08/06/2024 05:00	0.8	1.3	1	0.43	0.21498	0.72
08/06/2024 06:00	0.8	1.4	1	0.43	0.21708	0.72
08/06/2024 07:00	0.8	1.3	1	0.43	0.21378	0.71
08/06/2024 08:00	0.8	1.3	1	0.43	0.21300	0.71
08/06/2024 09:00	0.8	1.3	1	0.43	0.21276	0.71
08/06/2024 10:00	0.8	1.4	1	0.43	0.21276	0.71
08/06/2024 11:00	0.8	1.2	0	0.43	0.21348	0.71
08/06/2024 12:00	0.7	1.3	0	0.43	0.21360	0.71
08/06/2024 13:00	0.7	1.3	0	0.43	0.21372	0.71
08/06/2024 14:00	0.7	1.3	0	0.43	0.21354	0.71
08/06/2024 15:00	0.7	1.3	0	0.43	0.21300	0.71
08/06/2024 16:00	0.7	1.3	0	0.45	0.22368	0.75
08/06/2024 17:00	0.8	1.3	1	0.49	0.24378	0.81
08/06/2024 18:00	0.2	1.4	1	0.71	0.35406	1.18
08/06/2024 19:00	0.8	1.4	1	0.61	0.30414	1.01
08/06/2024 20:00	0.9	1.3	1	0.53	0.26364	0.88
08/06/2024 21:00	0.7	1.3	0	0.51	0.25560	0.85
08/06/2024 22:00	0.8	1.3	1	0.50	0.24888	0.83
08/06/2024 23:00	0.8	1.2	1	0.46	0.22782	0.76
Average/Sum#:	0.8	1.3	1	0.46	0.23069	0.77
Minimum:	0.2	1.2	0	0.43	0.21252	0.71
Maximum:	0.9	1.5	1	0.71	0.35406	1.18
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/07/2024 00:00	0.8	1.4	1	0.42	0.21234	0.71
08/07/2024 01:00	0.8	1.3	1	0.42	0.21216	0.71
08/07/2024 02:00	0.8	1.3	1	0.42	0.21234	0.71
08/07/2024 03:00	0.9	1.4	1	0.42	0.21246	0.71
08/07/2024 04:00	0.8	1.3	1	0.42	0.21240	0.71
08/07/2024 05:00	0.8	1.4	1	0.43	0.21372	0.71
08/07/2024 06:00	0.9	1.4	1	0.45	0.22440	0.75
08/07/2024 07:00	0.9	1.4	1	0.43	0.21342	0.71
08/07/2024 08:00	0.8	1.4	1	0.43	0.21276	0.71
08/07/2024 09:00	0.7	1.3	1	0.43	0.21282	0.71
08/07/2024 10:00	0.8	1.2	0	0.43	0.21294	0.71
08/07/2024 11:00	0.7	1.3	0	0.43	0.21354	0.71
08/07/2024 12:00	0.7	1.4	0	0.43	0.21354	0.71
08/07/2024 13:00	0.7	1.3	0	0.43	0.21354	0.71
08/07/2024 14:00	0.7	1.3	0	0.43	0.21348	0.71
08/07/2024 15:00	0.7	1.3	0	0.43	0.21300	0.71
08/07/2024 16:00	0.7	1.3	0	0.43	0.21270	0.71
08/07/2024 17:00	0.7	1.3	0	0.45	0.22512	0.75
08/07/2024 18:00	0.7	1.2	0	0.46	0.22902	0.76
08/07/2024 19:00	0.7	1.3	1	0.47	0.23520	0.78
08/07/2024 20:00	0.8	1.2	0	0.45	0.22278	0.74
08/07/2024 21:00	0.8	1.4	1	0.43	0.21618	0.72
08/07/2024 22:00	0.8	1.4	1	0.43	0.21600	0.72
08/07/2024 23:00	0.8	1.4	1	0.43	0.21348	0.71
Average/Sum#:	0.8	1.3	1	0.43	0.21622	0.72
Minimum:	0.7	1.2	0	0.42	0.21216	0.71
Maximum:	0.9	1.4	1	0.47	0.23520	0.78
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/08/2024 00:00	0.8	1.3	1	0.43	0.21330	0.71
08/08/2024 01:00	0.8	1.4	1	0.43	0.21366	0.71
08/08/2024 02:00	0.8	1.3	1	0.43	0.21366	0.71
08/08/2024 03:00	0.9	1.4	1	0.43	0.21354	0.71
08/08/2024 04:00	0.8	1.4	1	0.43	0.21276	0.71
08/08/2024 05:00	0.8	1.4	1	0.43	0.21408	0.71
08/08/2024 06:00	0.8	1.4	1	0.45	0.22416	0.75
08/08/2024 07:00	0.8	1.3	1	0.43	0.21294	0.71
08/08/2024 08:00	0.8	1.3	1	0.43	0.21282	0.71
08/08/2024 09:00	0.7	1.4	1	0.43	0.21264	0.71
08/08/2024 10:00	0.0	0.0	0	0.43	0.21300	0.71
08/08/2024 11:00	0.6	1.4	1	0.43	0.21384	0.71
08/08/2024 12:00	0.6	1.3	0	0.43	0.21360	0.71
08/08/2024 13:00	0.6	1.3	0	0.43	0.21372	0.71
08/08/2024 14:00	0.6	1.4	0	0.43	0.21366	0.71
08/08/2024 15:00	0.6	1.2	0	0.43	0.21330	0.71
08/08/2024 16:00	0.7	1.3	0	0.43	0.21306	0.71
08/08/2024 17:00	0.7	1.3	0	0.43	0.21426	0.71
08/08/2024 18:00	0.6	1.3	0	0.43	0.21570	0.72
08/08/2024 19:00	0.6	1.3	0	0.42	0.21228	0.71
08/08/2024 20:00	0.7	1.4	1	0.45	0.22260	0.74
08/08/2024 21:00	0.7	1.3	1	0.44	0.22050	0.74
08/08/2024 22:00	0.7	1.4	1	0.42	0.21228	0.71
08/08/2024 23:00	0.7	1.3	1	0.43	0.21252	0.71
Average/Sum#:	0.7	1.3	1	0.43	0.21450	0.71
Minimum:	0.6	1.2	0	0.42	0.21228	0.71
Maximum:	0.9	1.4	1	0.45	0.22416	0.75
%SI	4.17	4.17	4.17	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/09/2024 00:00	0.7	1.4	1	0.42	0.21246	0.71
08/09/2024 01:00	0.7	1.3	1	0.43	0.21252	0.71
08/09/2024 02:00	0.7	1.4	1	0.42	0.21246	0.71
08/09/2024 03:00	0.8	1.4	1	0.43	0.21252	0.71
08/09/2024 04:00	0.7	1.4	1	0.42	0.21240	0.71
08/09/2024 05:00	0.7	1.4	1	0.43	0.21378	0.71
08/09/2024 06:00	0.7	1.3	1	0.47	0.23694	0.79
08/09/2024 07:00	0.7	1.3	1	0.43	0.21384	0.71
08/09/2024 08:00	0.7	1.3	1	0.43	0.21312	0.71
08/09/2024 09:00	0.7	1.3	1	0.43	0.21264	0.71
08/09/2024 10:00	0.7	1.3	1	0.43	0.21264	0.71
08/09/2024 11:00	0.6	1.3	1	0.43	0.21330	0.71
08/09/2024 12:00	0.6	1.3	0	0.43	0.21336	0.71
08/09/2024 13:00	0.6	1.3	0	0.43	0.21354	0.71
08/09/2024 14:00	0.7	1.2	0	0.43	0.21348	0.71
08/09/2024 15:00	0.7	1.2	0	0.43	0.21288	0.71
08/09/2024 16:00	0.7	1.3	0	0.43	0.21276	0.71
08/09/2024 17:00	0.6	1.3	1	0.45	0.22344	0.74
08/09/2024 18:00	0.6	1.4	1	0.44	0.21894	0.73
08/09/2024 19:00	0.7	1.3	1	0.43	0.21342	0.71
08/09/2024 20:00	0.7	1.4	1	0.43	0.21306	0.71
08/09/2024 21:00	0.7	1.4	1	0.42	0.21234	0.71
08/09/2024 22:00	0.7	1.4	1	0.42	0.21234	0.71
08/09/2024 23:00	0.7	1.4	1	0.42	0.21222	0.71
Average/Sum#:	0.7	1.3	1	0.43	0.21460	0.72
Minimum:	0.6	1.2	0	0.42	0.21222	0.71
Maximum:	0.8	1.4	1	0.47	0.23694	0.79
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/10/2024 00:00	0.7	1.4	1	0.43	0.21264	0.71
08/10/2024 01:00	0.7	1.4	1	0.43	0.21282	0.71
08/10/2024 02:00	0.7	1.4	1	0.43	0.21276	0.71
08/10/2024 03:00	0.8	1.4	1	0.42	0.21246	0.71
08/10/2024 04:00	0.7	1.4	1	0.42	0.21216	0.71
08/10/2024 05:00	0.7	1.4	1	0.42	0.21234	0.71
08/10/2024 06:00	0.7	1.4	1	0.43	0.21318	0.71
08/10/2024 07:00	0.7	1.4	1	0.43	0.21360	0.71
08/10/2024 08:00	0.7	1.4	1	0.43	0.21288	0.71
08/10/2024 09:00	0.7	1.4	1	0.43	0.21288	0.71
08/10/2024 10:00	0.7	1.4	1	0.43	0.21324	0.71
08/10/2024 11:00	0.6	1.4	1	0.43	0.21420	0.71
08/10/2024 12:00	0.6	1.4	1	0.43	0.21414	0.71
08/10/2024 13:00	0.6	1.3	0	0.44	0.22134	0.74
08/10/2024 14:00	0.6	1.3	0	0.43	0.21396	0.71
08/10/2024 15:00	0.6	1.2	0	0.43	0.21330	0.71
08/10/2024 16:00	0.6	1.2	0	0.43	0.21300	0.71
08/10/2024 17:00	0.6	1.3	0	0.45	0.22584	0.75
08/10/2024 18:00	0.7	1.3	1	0.43	0.21396	0.71
08/10/2024 19:00	0.7	1.2	0	0.42	0.21246	0.71
08/10/2024 20:00	0.7	1.2	1	0.42	0.21234	0.71
08/10/2024 21:00	0.7	1.4	1	0.42	0.21198	0.71
08/10/2024 22:00	0.7	1.3	1	0.42	0.21210	0.71
08/10/2024 23:00	0.7	1.4	1	0.42	0.21216	0.71
Average/Sum#:	0.7	1.3	1	0.43	0.21382	0.71
Minimum:	0.6	1.2	0	0.42	0.21198	0.71
Maximum:	0.8	1.4	1	0.45	0.22584	0.75
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/11/2024 00:00	0.7	1.3	1	0.42	0.21234	0.71
08/11/2024 01:00	0.7	1.3	1	0.42	0.21240	0.71
08/11/2024 02:00	0.7	1.3	0	0.43	0.21252	0.71
08/11/2024 03:00	0.8	1.4	1	0.43	0.21252	0.71
08/11/2024 04:00	0.8	1.4	1	0.43	0.21258	0.71
08/11/2024 05:00	0.7	1.4	1	0.43	0.21264	0.71
08/11/2024 06:00	0.7	1.4	1	0.43	0.21348	0.71
08/11/2024 07:00	0.7	1.4	1	0.43	0.21372	0.71
08/11/2024 08:00	0.7	1.3	1	0.43	0.21300	0.71
08/11/2024 09:00	0.7	1.4	1	0.43	0.21276	0.71
08/11/2024 10:00	0.7	1.4	1	0.43	0.21276	0.71
08/11/2024 11:00	0.6	1.3	1	0.43	0.21348	0.71
08/11/2024 12:00	0.6	1.3	0	0.47	0.23634	0.79
08/11/2024 13:00	0.6	1.4	0	0.52	0.26238	0.87
08/11/2024 14:00	0.6	1.3	0	0.53	0.26274	0.88
08/11/2024 15:00	0.6	1.2	0	0.52	0.26088	0.87
08/11/2024 16:00	0.6	1.3	0	0.51	0.25704	0.86
08/11/2024 17:00	0.6	1.3	0	0.49	0.24528	0.82
08/11/2024 18:00	0.7	1.4	1	0.53	0.26580	0.89
08/11/2024 19:00	0.8	1.4	1	0.61	0.30438	1.01
08/11/2024 20:00	0.5	1.4	1	0.67	0.33306	1.11
08/11/2024 21:00	1.0	1.4	1	0.60	0.29790	0.99
08/11/2024 22:00	1.1	1.4	1	0.57	0.28260	0.94
08/11/2024 23:00	0.8	1.4	1	0.46	0.22752	0.76
Average/Sum#:	0.7	1.4	1	0.48	0.24126	0.80
Minimum:	0.5	1.2	0	0.42	0.21234	0.71
Maximum:	1.1	1.4	1	0.67	0.33306	1.11
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/12/2024 00:00	0.7	1.4	1	0.43	0.21342	0.71
08/12/2024 01:00	0.7	1.4	1	0.43	0.21342	0.71
08/12/2024 02:00	0.7	1.5	1	0.43	0.21342	0.71
08/12/2024 03:00	0.8	1.5	1	0.43	0.21348	0.71
08/12/2024 04:00	0.7	1.3	1	0.45	0.22314	0.74
08/12/2024 05:00	0.7	1.3	1	0.46	0.23232	0.77
08/12/2024 06:00	0.7	1.3	1	0.43	0.21414	0.71
08/12/2024 07:00	0.7	1.3	1	0.43	0.21456	0.72
08/12/2024 08:00	0.7	1.4	1	0.43	0.21396	0.71
08/12/2024 09:00	0.7	1.3	1	0.43	0.21372	0.71
08/12/2024 10:00	0.7	1.4	1	0.43	0.21348	0.71
08/12/2024 11:00	0.6	1.4	1	0.43	0.21384	0.71
08/12/2024 12:00	0.6	1.3	1	0.43	0.21384	0.71
08/12/2024 13:00	0.6	1.3	0	0.43	0.21378	0.71
08/12/2024 14:00	0.6	1.3	0	0.43	0.21312	0.71
08/12/2024 15:00	0.6	1.3	0	0.43	0.21282	0.71
08/12/2024 16:00	0.6	1.3	0	0.43	0.21270	0.71
08/12/2024 17:00	0.7	1.3	1	0.49	0.24480	0.82
08/12/2024 18:00	0.8	1.4	1	0.61	0.30492	1.02
08/12/2024 19:00	0.9	1.4	1	0.56	0.28200	0.94
08/12/2024 20:00	0.7	1.4	1	0.44	0.21930	0.73
08/12/2024 21:00	0.7	1.4	1	0.42	0.21204	0.71
08/12/2024 22:00	0.7	1.4	1	0.42	0.21228	0.71
08/12/2024 23:00	0.7	1.4	1	0.42	0.21222	0.71
Average/Sum#:	0.7	1.4	1	0.45	0.22278	0.74
Minimum:	0.6	1.3	0	0.42	0.21204	0.71
Maximum:	0.9	1.5	1	0.61	0.30492	1.02
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/13/2024 00:00	0.7	1.4	1	0.42	0.21216	0.71
08/13/2024 01:00	0.7	1.4	1	0.42	0.21210	0.71
08/13/2024 02:00	0.7	1.4	1	0.42	0.21222	0.71
08/13/2024 03:00	0.8	1.4	1	0.42	0.21216	0.71
08/13/2024 04:00	0.7	1.4	1	0.42	0.21228	0.71
08/13/2024 05:00	0.7	1.4	1	0.43	0.21372	0.71
08/13/2024 06:00	0.7	1.3	1	0.43	0.21336	0.71
08/13/2024 07:00	0.7	1.4	1	0.43	0.21360	0.71
08/13/2024 08:00	0.7	1.4	1	0.43	0.21300	0.71
08/13/2024 09:00	0.7	1.4	1	0.43	0.21294	0.71
08/13/2024 10:00	0.7	1.4	1	0.43	0.21300	0.71
08/13/2024 11:00	0.6	1.4	1	0.43	0.21336	0.71
08/13/2024 12:00	0.6	1.4	1	0.43	0.21348	0.71
08/13/2024 13:00	0.6	1.4	1	0.43	0.21372	0.71
08/13/2024 14:00	0.6	1.3	1	0.43	0.21378	0.71
08/13/2024 15:00	0.6	1.4	1	0.43	0.21330	0.71
08/13/2024 16:00	0.6	1.3	0	0.43	0.21294	0.71
08/13/2024 17:00	0.7	1.4	1	0.55	0.27504	0.92
08/13/2024 18:00	0.6	1.4	1	0.65	0.32256	1.08
08/13/2024 19:00	0.8	1.3	1	0.53	0.26322	0.88
08/13/2024 20:00	0.7	1.3	1	0.43	0.21468	0.72
08/13/2024 21:00	0.7	1.4	1	0.43	0.21546	0.72
08/13/2024 22:00	0.7	1.3	1	0.42	0.21216	0.71
08/13/2024 23:00	0.7	1.4	1	0.42	0.21222	0.71
Average/Sum#:	0.7	1.4	1	0.45	0.22235	0.74
Minimum:	0.6	1.3	0	0.42	0.21210	0.71
Maximum:	0.8	1.4	1	0.65	0.32256	1.08
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/14/2024 00:00	0.7	1.4	1	0.42	0.21222	0.71
08/14/2024 01:00	0.7	1.4	1	0.43	0.21252	0.71
08/14/2024 02:00	0.7	1.3	1	0.43	0.21264	0.71
08/14/2024 03:00	0.8	1.3	1	0.43	0.21270	0.71
08/14/2024 04:00	0.7	1.4	1	0.43	0.21288	0.71
08/14/2024 05:00	0.7	1.4	1	0.43	0.21264	0.71
08/14/2024 06:00	0.7	1.4	1	0.43	0.21330	0.71
08/14/2024 07:00	0.7	1.3	1	0.43	0.21360	0.71
08/14/2024 08:00	0.7	1.3	1	0.43	0.21288	0.71
08/14/2024 09:00	0.7	1.4	1	0.43	0.21258	0.71
08/14/2024 10:00	0.7	1.4	1	0.43	0.21282	0.71
08/14/2024 11:00	0.6	1.4	1	0.43	0.21354	0.71
08/14/2024 12:00	0.6	1.3	1	0.43	0.21360	0.71
08/14/2024 13:00	0.6	1.3	0	0.43	0.21378	0.71
08/14/2024 14:00	0.6	1.3	0	0.43	0.21342	0.71
08/14/2024 15:00	0.6	1.4	0	0.43	0.21306	0.71
08/14/2024 16:00	0.6	1.3	0	0.43	0.21486	0.72
08/14/2024 17:00	0.6	1.4	1	0.61	0.30282	1.01
08/14/2024 18:00	0.1	1.5	1	0.73	0.36480	1.22
08/14/2024 19:00	0.1	1.5	1	0.73	0.36612	1.22
08/14/2024 20:00	0.6	1.4	1	0.60	0.30204	1.01
08/14/2024 21:00	0.7	1.3	0	0.49	0.24672	0.82
08/14/2024 22:00	0.7	1.4	1	0.43	0.21498	0.72
08/14/2024 23:00	0.7	1.3	1	0.49	0.24444	0.81
Average/Sum#:	0.6	1.4	1	0.47	0.23604	0.79
Minimum:	0.1	1.3	0	0.42	0.21222	0.71
Maximum:	0.8	1.5	1	0.73	0.36612	1.22
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/15/2024 00:00	0.8	1.4	1	0.42	0.21216	0.71
08/15/2024 01:00	0.8	1.3	1	0.42	0.21234	0.71
08/15/2024 02:00	0.7	1.5	1	0.43	0.21258	0.71
08/15/2024 03:00	0.8	1.4	1	0.43	0.21264	0.71
08/15/2024 04:00	0.7	1.4	1	0.44	0.22182	0.74
08/15/2024 05:00	0.7	1.3	1	0.47	0.23496	0.78
08/15/2024 06:00	0.8	1.4	1	0.43	0.21354	0.71
08/15/2024 07:00	0.8	1.3	1	0.43	0.21366	0.71
08/15/2024 08:00	0.8	1.4	1	0.43	0.21306	0.71
08/15/2024 09:00	0.7	1.4	1	0.43	0.21270	0.71
08/15/2024 10:00	0.7	1.3	1	0.43	0.21264	0.71
08/15/2024 11:00	0.7	1.3	1	0.43	0.21360	0.71
08/15/2024 12:00	0.6	1.3	1	0.43	0.21270	0.71
08/15/2024 13:00	0.6	1.4	1	0.43	0.21252	0.71
08/15/2024 14:00	0.6	1.3	0	0.43	0.21252	0.71
08/15/2024 15:00	0.7	1.3	0	0.49	0.24264	0.81
08/15/2024 16:00	0.6	1.4	1	0.62	0.30816	1.03
08/15/2024 17:00	0.3	1.4	1	0.68	0.33762	1.13
08/15/2024 18:00	0.1	1.4	1	0.71	0.35640	1.19
08/15/2024 19:00	0.3	1.4	1	0.68	0.34140	1.14
08/15/2024 20:00	0.7	1.3	1	0.52	0.26046	0.87
08/15/2024 21:00	0.7	1.4	1	0.43	0.21252	0.71
08/15/2024 22:00	0.7	1.3	1	0.42	0.21174	0.71
08/15/2024 23:00	0.7	1.3	1	0.43	0.21456	0.72
Average/Sum#:	0.7	1.4	1	0.48	0.23787	0.79
Minimum:	0.1	1.3	0	0.42	0.21174	0.71
Maximum:	0.8	1.5	1	0.71	0.35640	1.19
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/16/2024 00:00	0.7	1.3	1	0.42	0.21186	0.71
08/16/2024 01:00	0.7	1.3	1	0.42	0.21198	0.71
08/16/2024 02:00	0.7	1.3	1	0.42	0.21204	0.71
08/16/2024 03:00	0.8	1.4	1	0.42	0.21198	0.71
08/16/2024 04:00	0.7	1.3	1	0.46	0.22986	0.77
08/16/2024 05:00	0.6	1.4	1	0.48	0.23760	0.79
08/16/2024 06:00	0.7	1.4	1	0.43	0.21324	0.71
08/16/2024 07:00	0.8	1.3	1	0.43	0.21312	0.71
08/16/2024 08:00	0.8	1.4	1	0.42	0.21228	0.71
08/16/2024 09:00	0.7	1.4	1	0.42	0.21222	0.71
08/16/2024 10:00	0.6	1.4	1	0.42	0.21216	0.71
08/16/2024 11:00	0.6	1.4	1	0.43	0.21270	0.71
08/16/2024 12:00	0.6	1.3	0	0.43	0.21264	0.71
08/16/2024 13:00	0.6	1.3	0	0.43	0.21534	0.72
08/16/2024 14:00	0.6	1.2	0	0.43	0.21288	0.71
08/16/2024 15:00	0.6	1.4	0	0.42	0.21228	0.71
08/16/2024 16:00	0.6	1.3	0	0.42	0.21156	0.71
08/16/2024 17:00	0.6	1.3	0	0.43	0.21336	0.71
08/16/2024 18:00	0.6	1.4	0	0.42	0.21216	0.71
08/16/2024 19:00	0.6	1.3	1	0.43	0.21306	0.71
08/16/2024 20:00	0.6	1.3	1	0.42	0.21174	0.71
08/16/2024 21:00	0.6	1.3	0	0.51	0.25410	0.85
08/16/2024 22:00	0.6	1.4	0	0.50	0.24798	0.83
08/16/2024 23:00	0.6	1.3	1	0.48	0.24228	0.81
Average/Sum#:	0.7	1.3	1	0.44	0.21877	0.73
Minimum:	0.6	1.2	0	0.42	0.21156	0.71
Maximum:	0.8	1.4	1	0.51	0.25410	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/17/2024 00:00	0.6	1.3	1	0.47	0.23250	0.78
08/17/2024 01:00	0.6	1.3	1	0.42	0.21162	0.71
08/17/2024 02:00	0.6	1.3	1	0.42	0.21174	0.71
08/17/2024 03:00	0.7	1.5	1	0.42	0.21192	0.71
08/17/2024 04:00	0.7	1.3	1	0.42	0.21216	0.71
08/17/2024 05:00	0.6	1.3	1	0.47	0.23256	0.78
08/17/2024 06:00	0.6	1.4	1	0.43	0.21294	0.71
08/17/2024 07:00	0.6	1.4	1	0.43	0.21288	0.71
08/17/2024 08:00	0.6	1.3	1	0.42	0.21210	0.71
08/17/2024 09:00	0.6	1.4	1	0.42	0.21192	0.71
08/17/2024 10:00	0.6	1.4	1	0.42	0.21180	0.71
08/17/2024 11:00	0.6	1.4	1	0.43	0.21258	0.71
08/17/2024 12:00	0.6	1.4	1	0.43	0.21276	0.71
08/17/2024 13:00	0.6	1.3	1	0.43	0.21294	0.71
08/17/2024 14:00	0.6	1.3	1	0.43	0.21300	0.71
08/17/2024 15:00	0.6	1.4	1	0.43	0.21282	0.71
08/17/2024 16:00	0.6	1.3	1	0.42	0.21228	0.71
08/17/2024 17:00	0.6	1.4	1	0.43	0.21510	0.72
08/17/2024 18:00	0.6	1.3	1	0.43	0.21276	0.71
08/17/2024 19:00	0.6	1.3	1	0.42	0.21198	0.71
08/17/2024 20:00	0.6	1.4	1	0.42	0.21192	0.71
08/17/2024 21:00	0.6	1.4	1	0.42	0.21186	0.71
08/17/2024 22:00	0.7	1.4	1	0.42	0.21156	0.71
08/17/2024 23:00	0.7	1.3	1	0.42	0.21180	0.71
Average/Sum#:	0.6	1.4	1	0.43	0.21406	0.72
Minimum:	0.6	1.3	1	0.42	0.21156	0.71
Maximum:	0.7	1.5	1	0.47	0.23256	0.78
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/18/2024 00:00	0.7	1.4	1	0.42	0.21192	0.71
08/18/2024 01:00	0.7	1.3	1	0.42	0.21174	0.71
08/18/2024 02:00	0.7	1.3	1	0.42	0.21174	0.71
08/18/2024 03:00	0.8	1.4	1	0.42	0.21198	0.71
08/18/2024 04:00	0.7	1.4	1	0.42	0.21222	0.71
08/18/2024 05:00	0.7	1.3	1	0.42	0.21240	0.71
08/18/2024 06:00	0.7	1.3	1	0.43	0.21312	0.71
08/18/2024 07:00	0.7	1.3	1	0.43	0.21306	0.71
08/18/2024 08:00	0.7	1.3	1	0.43	0.21258	0.71
08/18/2024 09:00	0.7	1.3	1	0.42	0.21246	0.71
08/18/2024 10:00	0.7	1.3	1	0.42	0.21246	0.71
08/18/2024 11:00	0.6	1.4	1	0.43	0.21258	0.71
08/18/2024 12:00	0.6	1.4	1	0.43	0.21276	0.71
08/18/2024 13:00	0.6	1.4	1	0.43	0.21306	0.71
08/18/2024 14:00	0.6	1.3	1	0.43	0.21294	0.71
08/18/2024 15:00	0.6	1.4	1	0.43	0.21258	0.71
08/18/2024 16:00	0.6	1.3	1	0.43	0.21642	0.72
08/18/2024 17:00	0.6	1.3	1	0.43	0.21660	0.72
08/18/2024 18:00	0.6	1.4	1	0.43	0.21252	0.71
08/18/2024 19:00	0.6	1.3	1	0.42	0.21210	0.71
08/18/2024 20:00	0.6	1.4	1	0.42	0.21204	0.71
08/18/2024 21:00	0.7	1.3	1	0.43	0.21312	0.71
08/18/2024 22:00	0.7	1.4	1	0.42	0.21192	0.71
08/18/2024 23:00	0.7	1.3	1	0.43	0.21444	0.71
Average/Sum#:	0.7	1.3	1	0.43	0.21287	0.71
Minimum:	0.6	1.3	1	0.42	0.21174	0.71
Maximum:	0.8	1.4	1	0.43	0.21660	0.72
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/19/2024 00:00	0.7	1.4	1	0.42	0.21198	0.71
08/19/2024 01:00	0.7	1.3	1	0.42	0.21198	0.71
08/19/2024 02:00	0.7	1.4	1	0.42	0.21192	0.71
08/19/2024 03:00	0.8	1.4	1	0.42	0.21210	0.71
08/19/2024 04:00	0.6	1.4	1	0.48	0.23778	0.79
08/19/2024 05:00	0.7	1.3	1	0.48	0.24234	0.81
08/19/2024 06:00	0.8	1.3	1	0.43	0.21306	0.71
08/19/2024 07:00	0.8	1.3	1	0.43	0.21330	0.71
08/19/2024 08:00	0.7	1.4	1	0.43	0.21288	0.71
08/19/2024 09:00	0.7	1.3	1	0.43	0.21282	0.71
08/19/2024 10:00	0.7	1.3	1	0.43	0.21258	0.71
08/19/2024 11:00	0.6	1.4	1	0.43	0.21294	0.71
08/19/2024 12:00	0.6	1.3	1	0.43	0.21306	0.71
08/19/2024 13:00	0.6	1.3	1	0.43	0.21318	0.71
08/19/2024 14:00	0.6	1.3	1	0.43	0.21312	0.71
08/19/2024 15:00	0.6	1.3	1	0.43	0.21258	0.71
08/19/2024 16:00	0.6	1.3	0	0.42	0.21198	0.71
08/19/2024 17:00	0.6	1.3	1	0.42	0.21234	0.71
08/19/2024 18:00	0.6	1.4	1	0.42	0.21246	0.71
08/19/2024 19:00	0.6	1.3	1	0.42	0.21204	0.71
08/19/2024 20:00	0.7	1.4	1	0.42	0.21186	0.71
08/19/2024 21:00	0.7	1.2	1	0.47	0.23424	0.78
08/19/2024 22:00	0.7	1.3	1	0.42	0.21180	0.71
08/19/2024 23:00	0.7	1.4	1	0.42	0.21180	0.71
Average/Sum#:	0.7	1.3	1	0.43	0.21567	0.72
Minimum:	0.6	1.2	0	0.42	0.21180	0.71
Maximum:	0.8	1.4	1	0.48	0.24234	0.81
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/20/2024 00:00	0.7	1.3	1	0.42	0.21174	0.71
08/20/2024 01:00	0.7	1.4	1	0.42	0.21186	0.71
08/20/2024 02:00	0.7	1.4	1	0.42	0.21180	0.71
08/20/2024 03:00	0.8	1.3	1	0.42	0.21186	0.71
08/20/2024 04:00	0.8	1.4	1	0.42	0.21198	0.71
08/20/2024 05:00	0.8	1.3	1	0.42	0.21234	0.71
08/20/2024 06:00	0.8	1.3	1	0.43	0.21306	0.71
08/20/2024 07:00	0.8	1.4	1	0.43	0.21318	0.71
08/20/2024 08:00	0.8	1.4	1	0.43	0.21294	0.71
08/20/2024 09:00	0.8	1.3	1	0.43	0.21324	0.71
08/20/2024 10:00	0.7	1.3	1	0.43	0.21288	0.71
08/20/2024 11:00	0.6	1.3	1	0.43	0.21342	0.71
08/20/2024 12:00	0.6	1.4	1	0.43	0.21366	0.71
08/20/2024 13:00	0.6	1.3	1	0.43	0.21360	0.71
08/20/2024 14:00	0.6	1.2	0	0.43	0.21366	0.71
08/20/2024 15:00	0.6	1.3	0	0.43	0.21318	0.71
08/20/2024 16:00	0.6	1.2	0	0.43	0.21276	0.71
08/20/2024 17:00	0.6	1.2	0	0.45	0.22428	0.75
08/20/2024 18:00	0.6	1.2	1	0.43	0.21324	0.71
08/20/2024 19:00	0.6	1.3	1	0.43	0.21270	0.71
08/20/2024 20:00	0.7	1.3	1	0.42	0.21210	0.71
08/20/2024 21:00	0.7	1.3	1	0.42	0.21006	0.70
08/20/2024 22:00	0.7	1.3	1	0.42	0.21066	0.70
08/20/2024 23:00	0.7	1.4	1	0.42	0.21060	0.70
Average/Sum#:	0.7	1.3	1	0.43	0.21295	0.71
Minimum:	0.6	1.2	0	0.42	0.21006	0.70
Maximum:	0.8	1.4	1	0.45	0.22428	0.75
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/21/2024 00:00	0.7	1.4	1	0.42	0.21042	0.70
08/21/2024 01:00	0.7	1.3	1	0.42	0.21054	0.70
08/21/2024 02:00	0.7	1.4	1	0.42	0.21060	0.70
08/21/2024 03:00	0.8	1.4	1	0.42	0.21084	0.70
08/21/2024 04:00	0.7	1.4	1	0.42	0.21096	0.70
08/21/2024 05:00	0.7	1.4	1	0.42	0.21162	0.71
08/21/2024 06:00	0.8	1.3	1	0.42	0.21204	0.71
08/21/2024 07:00	0.7	1.3	1	0.43	0.21258	0.71
08/21/2024 08:00	0.7	1.4	1	0.42	0.21222	0.71
08/21/2024 09:00	0.7	1.4	1	0.42	0.21198	0.71
08/21/2024 10:00	0.7	1.4	1	0.42	0.21192	0.71
08/21/2024 11:00	0.7	1.4	1	0.42	0.21246	0.71
08/21/2024 12:00	0.6	1.4	1	0.43	0.21258	0.71
08/21/2024 13:00	0.6	1.4	1	0.43	0.21264	0.71
08/21/2024 14:00	0.6	1.2	0	0.42	0.21234	0.71
08/21/2024 15:00	0.6	1.4	0	0.42	0.21198	0.71
08/21/2024 16:00	0.6	1.4	0	0.43	0.21684	0.72
08/21/2024 17:00	0.6	1.2	1	0.43	0.21732	0.72
08/21/2024 18:00	0.6	1.3	1	0.42	0.21240	0.71
08/21/2024 19:00	0.6	1.3	1	0.42	0.21102	0.70
08/21/2024 20:00	0.7	1.3	1	0.42	0.20988	0.70
08/21/2024 21:00	0.7	1.3	1	0.42	0.21090	0.70
08/21/2024 22:00	0.7	1.3	1	0.42	0.20934	0.70
08/21/2024 23:00	0.7	1.3	1	0.42	0.20922	0.70
Average/Sum#:	0.7	1.3	1	0.42	0.21186	0.71
Minimum:	0.6	1.2	0	0.42	0.20922	0.70
Maximum:	0.8	1.4	1	0.43	0.21732	0.72
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/22/2024 00:00	0.7	1.4	1	0.42	0.20958	0.70
08/22/2024 01:00	0.7	1.4	1	0.42	0.21012	0.70
08/22/2024 02:00	0.7	1.3	1	0.42	0.21048	0.70
08/22/2024 03:00	0.8	1.4	1	0.42	0.21072	0.70
08/22/2024 04:00	0.7	1.3	1	0.42	0.21108	0.70
08/22/2024 05:00	0.8	1.3	1	0.44	0.21846	0.73
08/22/2024 06:00	0.8	1.3	1	0.42	0.21246	0.71
08/22/2024 07:00	0.7	1.3	1	0.43	0.21270	0.71
08/22/2024 08:00	0.7	1.3	1	0.42	0.21210	0.71
08/22/2024 09:00	0.7	1.3	1	0.42	0.21186	0.71
08/22/2024 10:00	0.7	1.3	1	0.42	0.21198	0.71
08/22/2024 11:00	0.7	1.4	1	0.43	0.21270	0.71
08/22/2024 12:00	0.6	1.3	1	0.43	0.21282	0.71
08/22/2024 13:00	0.6	1.3	1	0.43	0.21294	0.71
08/22/2024 14:00	0.6	1.3	1	0.43	0.21264	0.71
08/22/2024 15:00	0.6	1.3	1	0.42	0.21240	0.71
08/22/2024 16:00	0.6	1.4	1	0.42	0.21204	0.71
08/22/2024 17:00	0.6	1.3	1	0.42	0.21222	0.71
08/22/2024 18:00	0.6	1.3	1	0.42	0.21210	0.71
08/22/2024 19:00	0.7	1.3	1	0.42	0.21174	0.71
08/22/2024 20:00	0.7	1.4	1	0.42	0.21204	0.71
08/22/2024 21:00	0.7	1.3	1	0.42	0.21204	0.71
08/22/2024 22:00	0.7	1.4	1	0.42	0.21228	0.71
08/22/2024 23:00	0.7	1.4	1	0.42	0.21234	0.71
Average/Sum#:	0.7	1.3	1	0.42	0.21216	0.71
Minimum:	0.6	1.3	1	0.42	0.20958	0.70
Maximum:	0.8	1.4	1	0.44	0.21846	0.73
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/23/2024 00:00	0.7	1.3	1	0.42	0.21234	0.71
08/23/2024 01:00	0.7	1.4	1	0.43	0.21252	0.71
08/23/2024 02:00	0.7	1.4	1	0.42	0.21246	0.71
08/23/2024 03:00	0.8	1.4	1	0.42	0.21246	0.71
08/23/2024 04:00	0.8	1.4	1	0.43	0.21258	0.71
08/23/2024 05:00	0.8	1.3	1	0.43	0.21276	0.71
08/23/2024 06:00	0.8	1.3	1	0.43	0.21318	0.71
08/23/2024 07:00	0.8	1.4	1	0.43	0.21324	0.71
08/23/2024 08:00	0.8	1.4	1	0.43	0.21276	0.71
08/23/2024 09:00	0.7	1.3	1	0.43	0.21264	0.71
08/23/2024 10:00	0.7	1.4	1	0.43	0.21282	0.71
08/23/2024 11:00	0.7	1.4	1	0.43	0.21330	0.71
08/23/2024 12:00	0.7	1.4	1	0.43	0.21318	0.71
08/23/2024 13:00	0.7	1.4	1	0.43	0.21294	0.71
08/23/2024 14:00	0.7	1.4	1	0.43	0.21282	0.71
08/23/2024 15:00	0.7	1.4	1	0.43	0.21294	0.71
08/23/2024 16:00	0.7	1.4	1	0.43	0.21282	0.71
08/23/2024 17:00	0.7	1.4	1	0.43	0.21264	0.71
08/23/2024 18:00	0.7	1.3	1	0.43	0.21264	0.71
08/23/2024 19:00	0.7	1.4	1	0.43	0.21270	0.71
08/23/2024 20:00	0.7	1.4	1	0.43	0.21264	0.71
08/23/2024 21:00	0.7	1.4	1	0.43	0.21258	0.71
08/23/2024 22:00	0.8	1.4	1	0.43	0.21252	0.71
08/23/2024 23:00	0.7	1.4	1	0.45	0.22722	0.76
Average/Sum#:	0.7	1.4	1	0.43	0.21336	0.71
Minimum:	0.7	1.3	1	0.42	0.21234	0.71
Maximum:	0.8	1.4	1	0.45	0.22722	0.76
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/24/2024 00:00	0.7	1.4	1	0.42	0.21234	0.71
08/24/2024 01:00	0.7	1.3	1	0.43	0.21282	0.71
08/24/2024 02:00	0.8	1.5	1	0.43	0.21282	0.71
08/24/2024 03:00	0.8	1.4	1	0.43	0.21282	0.71
08/24/2024 04:00	0.8	1.4	1	0.43	0.21462	0.72
08/24/2024 05:00	0.7	1.4	1	0.45	0.22518	0.75
08/24/2024 06:00	0.8	1.3	0	0.44	0.21828	0.73
08/24/2024 07:00	0.8	1.4	0	0.43	0.21270	0.71
08/24/2024 08:00	0.8	1.3	0	0.43	0.21282	0.71
08/24/2024 09:00	0.8	1.3	0	0.43	0.21348	0.71
08/24/2024 10:00	0.7	1.3	0	0.43	0.21342	0.71
08/24/2024 11:00	0.7	1.3	0	0.43	0.21354	0.71
08/24/2024 12:00	0.7	1.3	0	0.43	0.21348	0.71
08/24/2024 13:00	0.8	1.4	1	0.43	0.21306	0.71
08/24/2024 14:00	0.8	1.4	1	0.43	0.21252	0.71
08/24/2024 15:00	0.8	1.4	1	0.43	0.21348	0.71
08/24/2024 16:00	0.7	1.4	1	0.43	0.21306	0.71
08/24/2024 17:00	0.8	1.4	1	0.43	0.21288	0.71
08/24/2024 18:00	0.8	1.4	1	0.43	0.21276	0.71
08/24/2024 19:00	0.8	1.3	1	0.42	0.21246	0.71
08/24/2024 20:00	0.9	1.3	1	0.43	0.21258	0.71
08/24/2024 21:00	0.8	1.4	1	0.43	0.21330	0.71
08/24/2024 22:00	1.0	1.4	1	0.43	0.21330	0.71
08/24/2024 23:00	1.0	1.3	1	0.43	0.21336	0.71
Average/Sum#:	0.8	1.4	1	0.43	0.21380	0.71
Minimum:	0.7	1.3	0	0.42	0.21234	0.71
Maximum:	1.0	1.5	1	0.45	0.22518	0.75
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/25/2024 00:00	1.0	1.4	1	0.43	0.21342	0.71
08/25/2024 01:00	1.0	1.4	1	0.43	0.21342	0.71
08/25/2024 02:00	1.0	1.3	1	0.43	0.21360	0.71
08/25/2024 03:00	1.0	1.4	1	0.43	0.21402	0.71
08/25/2024 04:00	0.9	1.4	1	0.43	0.21468	0.72
08/25/2024 05:00	0.9	1.4	1	0.43	0.21456	0.72
08/25/2024 06:00	0.9	1.3	1	0.43	0.21492	0.72
08/25/2024 07:00	1.0	1.4	1	0.43	0.21468	0.72
08/25/2024 08:00	0.9	1.4	1	0.43	0.21438	0.71
08/25/2024 09:00	0.8	1.4	1	0.43	0.21456	0.72
08/25/2024 10:00	0.8	1.4	1	0.43	0.21474	0.72
08/25/2024 11:00	0.7	1.4	1	0.43	0.21498	0.72
08/25/2024 12:00	0.7	1.3	1	0.43	0.21462	0.72
08/25/2024 13:00	0.7	1.3	1	0.43	0.21378	0.71
08/25/2024 14:00	0.7	1.4	1	0.43	0.21360	0.71
08/25/2024 15:00	0.6	1.4	1	0.43	0.21378	0.71
08/25/2024 16:00	0.6	1.3	1	0.43	0.21594	0.72
08/25/2024 17:00	0.6	1.3	0	0.48	0.23820	0.79
08/25/2024 18:00	0.6	1.4	0	0.51	0.25602	0.85
08/25/2024 19:00	0.7	1.3	0	0.51	0.25560	0.85
08/25/2024 20:00	0.7	1.3	1	0.49	0.24336	0.81
08/25/2024 21:00	0.7	1.4	1	0.43	0.21342	0.71
08/25/2024 22:00	0.8	1.3	1	0.43	0.21360	0.71
08/25/2024 23:00	0.8	1.3	1	0.43	0.21714	0.72
Average/Sum#:	0.8	1.4	1	0.44	0.22004	0.73
Minimum:	0.6	1.3	0	0.43	0.21342	0.71
Maximum:	1.0	1.4	1	0.51	0.25602	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/26/2024 00:00	0.8	1.3	1	0.43	0.21378	0.71
08/26/2024 01:00	0.8	1.4	1	0.43	0.21378	0.71
08/26/2024 02:00	0.8	1.4	1	0.43	0.21378	0.71
08/26/2024 03:00	0.8	1.5	1	0.43	0.21390	0.71
08/26/2024 04:00	0.7	1.3	0	0.47	0.23340	0.78
08/26/2024 05:00	0.7	1.4	0	0.51	0.25380	0.85
08/26/2024 06:00	0.8	1.3	1	0.44	0.21906	0.73
08/26/2024 07:00	0.8	1.3	1	0.43	0.21546	0.72
08/26/2024 08:00	0.8	1.3	1	0.43	0.21564	0.72
08/26/2024 09:00	0.7	1.4	1	0.43	0.21492	0.72
08/26/2024 10:00	0.7	1.3	1	0.43	0.21354	0.71
08/26/2024 11:00	0.6	1.4	1	0.43	0.21384	0.71
08/26/2024 12:00	0.6	1.4	1	0.43	0.21390	0.71
08/26/2024 13:00	0.6	1.4	1	0.43	0.21300	0.71
08/26/2024 14:00	0.6	1.2	1	0.43	0.21300	0.71
08/26/2024 15:00	0.6	1.2	0	0.43	0.21282	0.71
08/26/2024 16:00	0.7	1.2	0	0.45	0.22476	0.75
08/26/2024 17:00	0.6	1.3	0	0.48	0.23772	0.79
08/26/2024 18:00	0.7	1.3	0	0.49	0.24378	0.81
08/26/2024 19:00	0.7	1.3	1	0.44	0.22224	0.74
08/26/2024 20:00	0.7	1.3	1	0.44	0.21882	0.73
08/26/2024 21:00	0.8	1.3	1	0.42	0.21246	0.71
08/26/2024 22:00	0.8	1.4	1	0.42	0.21240	0.71
08/26/2024 23:00	0.8	1.3	1	0.42	0.21228	0.71
Average/Sum#:	0.7	1.3	1	0.44	0.21967	0.73
Minimum:	0.6	1.2	0	0.42	0.21228	0.71
Maximum:	0.8	1.5	1	0.51	0.25380	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/27/2024 00:00	0.8	1.4	1	0.43	0.21276	0.71
08/27/2024 01:00	0.8	1.4	1	0.43	0.21288	0.71
08/27/2024 02:00	0.8	1.2	0	0.43	0.21258	0.71
08/27/2024 03:00	0.9	1.4	1	0.42	0.21240	0.71
08/27/2024 04:00	0.8	1.3	1	0.43	0.21252	0.71
08/27/2024 05:00	0.8	1.4	1	0.43	0.21282	0.71
08/27/2024 06:00	0.9	1.4	1	0.43	0.21360	0.71
08/27/2024 07:00	0.9	1.3	1	0.43	0.21360	0.71
08/27/2024 08:00	0.8	1.4	1	0.43	0.21312	0.71
08/27/2024 09:00	0.8	1.3	1	0.43	0.21306	0.71
08/27/2024 10:00	0.7	1.4	1	0.43	0.21312	0.71
08/27/2024 11:00	0.7	1.3	0	0.43	0.21396	0.71
08/27/2024 12:00	0.7	1.2	0	0.43	0.21396	0.71
08/27/2024 13:00	0.7	1.3	0	0.43	0.21306	0.71
08/27/2024 14:00	0.7	1.3	0	0.43	0.21288	0.71
08/27/2024 15:00	0.6	1.3	0	0.43	0.21288	0.71
08/27/2024 16:00	0.7	1.3	0	0.43	0.21462	0.72
08/27/2024 17:00	0.6	1.2	0	0.46	0.23022	0.77
08/27/2024 18:00	0.6	1.3	1	0.49	0.24612	0.82
08/27/2024 19:00	0.7	1.2	0	0.42	0.21246	0.71
08/27/2024 20:00	0.8	1.3	1	0.43	0.21252	0.71
08/27/2024 21:00	0.8	1.3	1	0.43	0.21264	0.71
08/27/2024 22:00	0.8	1.3	1	0.42	0.21246	0.71
08/27/2024 23:00	0.8	1.3	1	0.43	0.21300	0.71
Average/Sum#:	0.8	1.3	1	0.43	0.21514	0.72
Minimum:	0.6	1.2	0	0.42	0.21240	0.71
Maximum:	0.9	1.4	1	0.49	0.24612	0.82
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/28/2024 00:00	0.8	1.3	1	0.43	0.21300	0.71
08/28/2024 01:00	0.8	1.4	1	0.43	0.21294	0.71
08/28/2024 02:00	0.8	1.3	1	0.43	0.21312	0.71
08/28/2024 03:00	0.9	1.4	1	0.43	0.21318	0.71
08/28/2024 04:00	0.8	1.3	1	0.43	0.21624	0.72
08/28/2024 05:00	0.8	1.3	0	0.48	0.23982	0.80
08/28/2024 06:00	1.0	1.3	0	0.44	0.22044	0.73
08/28/2024 07:00	0.9	1.3	0	0.43	0.21408	0.71
08/28/2024 08:00	0.9	1.2	0	0.43	0.21396	0.71
08/28/2024 09:00	0.8	1.4	1	0.43	0.21408	0.71
08/28/2024 10:00	0.8	1.4	1	0.43	0.21426	0.71
08/28/2024 11:00	0.7	1.2	0	0.43	0.21372	0.71
08/28/2024 12:00	0.7	1.3	0	0.43	0.21360	0.71
08/28/2024 13:00	0.7	1.2	0	0.43	0.21282	0.71
08/28/2024 14:00	0.7	1.2	0	0.43	0.21264	0.71
08/28/2024 15:00	0.7	1.2	0	0.43	0.21270	0.71
08/28/2024 16:00	0.7	1.2	0	0.43	0.21432	0.71
08/28/2024 17:00	0.7	1.2	0	0.43	0.21462	0.72
08/28/2024 18:00	0.7	1.2	0	0.43	0.21366	0.71
08/28/2024 19:00	0.7	1.4	0	0.43	0.21258	0.71
08/28/2024 20:00	0.7	1.4	1	0.43	0.21294	0.71
08/28/2024 21:00	0.7	1.3	1	0.43	0.21276	0.71
08/28/2024 22:00	0.7	1.3	1	0.43	0.21330	0.71
08/28/2024 23:00	0.7	1.4	1	0.43	0.21348	0.71
Average/Sum#:	0.8	1.3	0	0.43	0.21493	0.72
Minimum:	0.7	1.2	0	0.43	0.21258	0.71
Maximum:	1.0	1.4	1	0.48	0.23982	0.80
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/29/2024 00:00	0.8	1.3	1	0.43	0.21318	0.71
08/29/2024 01:00	0.8	1.4	1	0.43	0.21306	0.71
08/29/2024 02:00	0.8	1.3	1	0.43	0.21540	0.72
08/29/2024 03:00	0.9	1.3	1	0.43	0.21252	0.71
08/29/2024 04:00	0.8	1.3	1	0.43	0.21264	0.71
08/29/2024 05:00	0.8	1.4	1	0.43	0.21270	0.71
08/29/2024 06:00	0.6	1.3	0	0.54	0.27114	0.90
08/29/2024 07:00	0.7	1.3	1	0.55	0.27600	0.92
08/29/2024 08:00	0.6	1.3	1	0.55	0.27504	0.92
08/29/2024 09:00	0.7	1.3	1	0.47	0.23424	0.78
08/29/2024 10:00	0.7	1.4	1	0.43	0.21534	0.72
08/29/2024 11:00	0.7	1.4	1	0.43	0.21330	0.71
08/29/2024 12:00	0.7	1.3	0	0.43	0.21330	0.71
08/29/2024 13:00	0.7	1.3	0	0.43	0.21270	0.71
08/29/2024 14:00	0.7	1.3	0	0.43	0.21270	0.71
08/29/2024 15:00	0.7	1.3	0	0.43	0.21252	0.71
08/29/2024 16:00	0.6	1.1	0	0.42	0.21240	0.71
08/29/2024 17:00	0.7	1.2	0	0.43	0.21282	0.71
08/29/2024 18:00	0.7	1.4	0	0.43	0.21294	0.71
08/29/2024 19:00	0.7	1.3	1	0.43	0.21288	0.71
08/29/2024 20:00	0.7	1.3	1	0.43	0.21264	0.71
08/29/2024 21:00	0.7	1.4	1	0.43	0.21264	0.71
08/29/2024 22:00	0.7	1.3	1	0.43	0.21282	0.71
08/29/2024 23:00	0.7	1.3	1	0.43	0.21294	0.71
Average/Sum#:	0.7	1.3	1	0.45	0.22158	0.74
Minimum:	0.6	1.1	0	0.42	0.21240	0.71
Maximum:	0.9	1.4	1	0.55	0.27600	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/30/2024 00:00	0.7	1.3	1	0.43	0.21300	0.71
08/30/2024 01:00	0.7	1.3	1	0.43	0.21288	0.71
08/30/2024 02:00	0.8	1.4	1	0.43	0.21294	0.71
08/30/2024 03:00	0.9	1.4	1	0.43	0.21288	0.71
08/30/2024 04:00	0.8	1.4	1	0.43	0.21342	0.71
08/30/2024 05:00	0.8	1.3	1	0.43	0.21324	0.71
08/30/2024 06:00	0.8	1.3	1	0.43	0.21372	0.71
08/30/2024 07:00	0.8	1.4	1	0.43	0.21390	0.71
08/30/2024 08:00	0.8	1.3	1	0.43	0.21354	0.71
08/30/2024 09:00	0.8	1.3	1	0.43	0.21348	0.71
08/30/2024 10:00	0.8	1.4	1	0.43	0.21348	0.71
08/30/2024 11:00	0.7	1.3	1	0.43	0.21354	0.71
08/30/2024 12:00	0.7	1.3	0	0.43	0.21354	0.71
08/30/2024 13:00	0.7	1.2	0	0.43	0.21288	0.71
08/30/2024 14:00	0.7	1.1	0	0.43	0.21294	0.71
08/30/2024 15:00	0.7	1.3	0	0.43	0.21288	0.71
08/30/2024 16:00	0.7	1.3	0	0.43	0.21690	0.72
08/30/2024 17:00	0.7	1.4	0	0.43	0.21342	0.71
08/30/2024 18:00	0.7	1.4	0	0.43	0.21336	0.71
08/30/2024 19:00	0.7	1.3	1	0.43	0.21330	0.71
08/30/2024 20:00	0.8	1.4	1	0.43	0.21294	0.71
08/30/2024 21:00	0.8	1.3	1	0.43	0.21420	0.71
08/30/2024 22:00	0.8	1.3	1	0.43	0.21282	0.71
08/30/2024 23:00	0.8	1.4	1	0.43	0.21318	0.71
Average/Sum#:	0.8	1.3	1	0.43	0.21343	0.71
Minimum:	0.7	1.1	0	0.43	0.21282	0.71
Maximum:	0.9	1.4	1	0.43	0.21690	0.72
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/31/2024 00:00	0.8	1.4	1	0.43	0.21354	0.71
08/31/2024 01:00	0.8	1.3	1	0.43	0.21312	0.71
08/31/2024 02:00	0.8	1.4	1	0.43	0.21318	0.71
08/31/2024 03:00	0.9	1.4	1	0.43	0.21318	0.71
08/31/2024 04:00	0.8	1.4	1	0.43	0.21300	0.71
08/31/2024 05:00	0.8	1.4	1	0.43	0.21300	0.71
08/31/2024 06:00	0.8	1.4	1	0.43	0.21348	0.71
08/31/2024 07:00	0.8	1.3	1	0.43	0.21360	0.71
08/31/2024 08:00	0.8	1.4	1	0.43	0.21330	0.71
08/31/2024 09:00	0.8	1.3	1	0.43	0.21312	0.71
08/31/2024 10:00	0.7	1.3	1	0.43	0.21318	0.71
08/31/2024 11:00	0.7	1.3	1	0.43	0.21378	0.71
08/31/2024 12:00	0.7	1.2	0	0.43	0.21384	0.71
08/31/2024 13:00	0.7	1.2	0	0.43	0.21384	0.71
08/31/2024 14:00	0.7	1.2	0	0.43	0.21408	0.71
08/31/2024 15:00	0.7	1.3	0	0.44	0.21912	0.73
08/31/2024 16:00	0.7	1.3	0	0.50	0.25122	0.84
08/31/2024 17:00	0.2	1.4	1	0.71	0.35478	1.18
08/31/2024 18:00	0.2	1.4	1	0.70	0.35190	1.17
08/31/2024 19:00	0.2	1.4	1	0.71	0.35718	1.19
08/31/2024 20:00	0.7	1.4	1	0.61	0.30426	1.01
08/31/2024 21:00	0.7	1.3	0	0.51	0.25536	0.85
08/31/2024 22:00	0.7	1.3	0	0.51	0.25650	0.86
08/31/2024 23:00	0.7	1.4	0	0.49	0.24642	0.82
Average/Sum#:	0.7	1.3	1	0.48	0.24158	0.80
Minimum:	0.2	1.2	0	0.43	0.21300	0.71
Maximum:	0.9	1.4	1	0.71	0.35718	1.19
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/01/2024 00:00	0.8	1.3	1	0.43	0.21660	0.72
09/01/2024 01:00	0.8	1.4	1	0.43	0.21450	0.72
09/01/2024 02:00	0.8	1.3	1	0.43	0.21450	0.72
09/01/2024 03:00	0.9	1.4	1	0.43	0.21456	0.72
09/01/2024 04:00	0.8	1.4	1	0.43	0.21450	0.72
09/01/2024 05:00	0.8	1.3	1	0.43	0.21474	0.72
09/01/2024 06:00	0.8	1.3	1	0.43	0.21540	0.72
09/01/2024 07:00	0.8	1.4	1	0.43	0.21534	0.72
09/01/2024 08:00	0.8	1.3	1	0.43	0.21486	0.72
09/01/2024 09:00	0.8	1.3	1	0.43	0.21462	0.72
09/01/2024 10:00	0.7	1.4	1	0.43	0.21432	0.71
09/01/2024 11:00	0.7	1.4	1	0.43	0.21474	0.72
09/01/2024 12:00	0.7	1.4	1	0.43	0.21468	0.72
09/01/2024 13:00	0.7	1.2	0	0.43	0.21396	0.71
09/01/2024 14:00	0.7	1.3	0	0.43	0.21390	0.71
09/01/2024 15:00	0.7	1.3	0	0.43	0.21450	0.72
09/01/2024 16:00	0.7	1.3	0	0.45	0.22398	0.75
09/01/2024 17:00	0.7	1.3	0	0.47	0.23430	0.78
09/01/2024 18:00	0.7	1.3	1	0.43	0.21588	0.72
09/01/2024 19:00	0.7	1.4	1	0.43	0.21474	0.72
09/01/2024 20:00	0.7	1.3	1	0.43	0.21480	0.72
09/01/2024 21:00	0.8	1.3	1	0.44	0.21888	0.73
09/01/2024 22:00	0.8	1.3	1	0.43	0.21696	0.72
09/01/2024 23:00	0.8	1.3	1	0.44	0.21846	0.73
Average/Sum#:	0.8	1.3	1	0.43	0.21641	0.72
Minimum:	0.7	1.2	0	0.43	0.21390	0.71
Maximum:	0.9	1.4	1	0.47	0.23430	0.78
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/02/2024 00:00	0.7	1.3	1	0.44	0.22086	0.74
09/02/2024 01:00	0.8	1.4	1	0.43	0.21498	0.72
09/02/2024 02:00	0.8	1.3	1	0.43	0.21498	0.72
09/02/2024 03:00	0.9	1.4	1	0.43	0.21498	0.72
09/02/2024 04:00	0.8	1.3	1	0.43	0.21498	0.72
09/02/2024 05:00	0.8	1.4	1	0.43	0.21504	0.72
09/02/2024 06:00	0.8	1.4	1	0.43	0.21540	0.72
09/02/2024 07:00	0.8	1.3	1	0.43	0.21528	0.72
09/02/2024 08:00	0.8	1.4	1	0.43	0.21516	0.72
09/02/2024 09:00	0.8	1.4	1	0.43	0.21522	0.72
09/02/2024 10:00	0.8	1.4	1	0.43	0.21540	0.72
09/02/2024 11:00	0.8	1.4	1	0.43	0.21618	0.72
09/02/2024 12:00	0.7	1.4	1	0.43	0.21636	0.72
09/02/2024 13:00	0.7	1.4	1	0.43	0.21582	0.72
09/02/2024 14:00	0.7	1.3	0	0.45	0.22446	0.75
09/02/2024 15:00	0.7	1.3	0	0.44	0.21876	0.73
09/02/2024 16:00	0.7	1.3	0	0.47	0.23532	0.78
09/02/2024 17:00	0.6	1.3	0	0.48	0.23952	0.80
09/02/2024 18:00	0.6	1.2	0	0.48	0.24156	0.81
09/02/2024 19:00	0.7	1.3	1	0.45	0.22404	0.75
09/02/2024 20:00	0.8	1.3	1	0.44	0.22152	0.74
09/02/2024 21:00	0.8	1.4	1	0.43	0.21378	0.71
09/02/2024 22:00	0.8	1.3	1	0.43	0.21396	0.71
09/02/2024 23:00	0.8	1.4	1	0.43	0.21402	0.71
Average/Sum#:	0.8	1.3	1	0.44	0.21948	0.73
Minimum:	0.6	1.2	0	0.43	0.21378	0.71
Maximum:	0.9	1.4	1	0.48	0.24156	0.81
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/03/2024 00:00	0.8	1.4	1	0.43	0.21402	0.71
09/03/2024 01:00	0.8	1.3	1	0.43	0.21408	0.71
09/03/2024 02:00	1.0	1.3	1	0.43	0.21450	0.72
09/03/2024 03:00	1.2	1.3	1	0.43	0.21432	0.71
09/03/2024 04:00	1.1	1.3	1	0.43	0.21384	0.71
09/03/2024 05:00	1.0	1.4	1	0.46	0.22944	0.76
09/03/2024 06:00	1.0	1.3	1	0.44	0.22050	0.74
09/03/2024 07:00	0.9	1.3	1	0.45	0.22530	0.75
09/03/2024 08:00	0.9	1.3	1	0.43	0.21414	0.71
09/03/2024 09:00	0.8	1.3	1	0.43	0.21354	0.71
09/03/2024 10:00	0.7	1.4	1	0.43	0.21348	0.71
09/03/2024 11:00	0.7	1.4	1	0.43	0.21444	0.71
09/03/2024 12:00	0.7	1.2	0	0.43	0.21426	0.71
09/03/2024 13:00	0.6	1.3	0	0.47	0.23664	0.79
09/03/2024 14:00	0.6	1.3	0	0.49	0.24612	0.82
09/03/2024 15:00	0.6	1.3	0	0.48	0.23994	0.80
09/03/2024 16:00	0.6	1.3	1	0.55	0.27294	0.91
09/03/2024 17:00	0.2	1.5	1	0.72	0.35808	1.19
09/03/2024 18:00	0.1	1.5	1	0.72	0.36234	1.21
09/03/2024 19:00	0.7	1.4	1	0.63	0.31326	1.04
09/03/2024 20:00	0.6	1.3	0	0.53	0.26382	0.88
09/03/2024 21:00	0.7	1.3	0	0.53	0.26436	0.88
09/03/2024 22:00	0.7	1.3	1	0.47	0.23664	0.79
09/03/2024 23:00	0.8	1.3	0	0.52	0.25980	0.87
Average/Sum#:	0.7	1.3	1	0.49	0.24458	0.81
Minimum:	0.1	1.2	0	0.43	0.21348	0.71
Maximum:	1.2	1.5	1	0.72	0.36234	1.21
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/04/2024 00:00	0.8	1.4	0	0.47	0.23514	0.78
09/04/2024 01:00	0.9	1.3	1	0.47	0.23466	0.78
09/04/2024 02:00	0.9	1.3	1	0.43	0.21474	0.72
09/04/2024 03:00	0.9	1.3	0	0.49	0.24564	0.82
09/04/2024 04:00	0.9	1.2	0	0.50	0.24762	0.83
09/04/2024 05:00	0.9	1.4	0	0.52	0.26106	0.87
09/04/2024 06:00	1.1	1.4	1	0.45	0.22344	0.74
09/04/2024 07:00	1.0	1.4	1	0.43	0.21432	0.71
09/04/2024 08:00	0.9	1.4	1	0.43	0.21390	0.71
09/04/2024 09:00	0.8	1.3	1	0.43	0.21372	0.71
09/04/2024 10:00	0.7	1.2	0	0.43	0.21360	0.71
09/04/2024 11:00	0.7	1.1	0	0.43	0.21408	0.71
09/04/2024 12:00	0.0	0.0	0	0.43	0.21402	0.71
09/04/2024 13:00	0.0	0.0	0	0.47	0.23292	0.78
09/04/2024 14:00	0.6	0.8	0	0.49	0.24288	0.81
09/04/2024 15:00	0.6	1.3	0	0.43	0.21618	0.72
09/04/2024 16:00	0.5	1.4	0	0.54	0.27078	0.90
09/04/2024 17:00	0.0	1.5	1	0.75	0.37266	1.24
09/04/2024 18:00	0.0	1.5	1	0.73	0.36546	1.22
09/04/2024 19:00	0.0	1.5	1	0.72	0.35826	1.19
09/04/2024 20:00	0.1	1.5	1	0.72	0.35766	1.19
09/04/2024 21:00	0.1	1.5	1	0.71	0.35478	1.18
09/04/2024 22:00	0.2	1.4	1	0.69	0.34638	1.15
09/04/2024 23:00	0.6	1.3	1	0.60	0.30228	1.01
Average/Sum#:	0.6	1.3	1	0.53	0.26526	0.88
Minimum:	0.0	0.8	0	0.43	0.21360	0.71
Maximum:	1.1	1.5	1	0.75	0.37266	1.24
%SI	8.33	8.33	8.33	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/05/2024 00:00	0.6	1.3	0	0.47	0.23568	0.79
09/05/2024 01:00	0.7	1.4	1	0.44	0.21948	0.73
09/05/2024 02:00	0.6	1.3	1	0.43	0.21396	0.71
09/05/2024 03:00	0.7	1.4	1	0.43	0.21390	0.71
09/05/2024 04:00	0.6	1.3	0	0.46	0.23064	0.77
09/05/2024 05:00	0.6	1.3	0	0.51	0.25620	0.85
09/05/2024 06:00	0.6	1.3	1	0.46	0.22980	0.77
09/05/2024 07:00	0.6	1.4	1	0.43	0.21432	0.71
09/05/2024 08:00	0.6	1.4	1	0.43	0.21402	0.71
09/05/2024 09:00	0.6	1.3	0	0.44	0.22038	0.73
09/05/2024 10:00	0.5	1.2	0	0.49	0.24534	0.82
09/05/2024 11:00	0.6	1.2	0	0.46	0.22770	0.76
09/05/2024 12:00	0.5	1.4	0	0.52	0.25938	0.86
09/05/2024 13:00	0.5	1.3	1	0.56	0.27924	0.93
09/05/2024 14:00	0.0	1.5	1	0.74	0.37152	1.24
09/05/2024 15:00	0.1	1.5	1	0.71	0.35286	1.18
09/05/2024 16:00	0.0	1.5	1	0.72	0.35784	1.19
09/05/2024 17:00	0.0	1.5	2	0.74	0.36822	1.23
09/05/2024 18:00	0.0	1.5	1	0.73	0.36354	1.21
09/05/2024 19:00	0.0	1.5	1	0.72	0.35754	1.19
09/05/2024 20:00	0.1	1.5	1	0.71	0.35298	1.18
09/05/2024 21:00	0.1	1.5	1	0.70	0.34782	1.16
09/05/2024 22:00	0.3	1.4	1	0.68	0.33852	1.13
09/05/2024 23:00	0.5	1.4	1	0.65	0.32478	1.08
Average/Sum#:	0.4	1.4	1	0.57	0.28315	0.94
Minimum:	0.0	1.2	0	0.43	0.21390	0.71
Maximum:	0.7	1.5	2	0.74	0.37152	1.24
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/06/2024 00:00	0.7	1.3	1	0.47	0.23496	0.78
09/06/2024 01:00	0.6	1.3	1	0.43	0.21348	0.71
09/06/2024 02:00	0.6	1.4	0	0.43	0.21354	0.71
09/06/2024 03:00	0.7	1.3	0	0.43	0.21354	0.71
09/06/2024 04:00	0.6	1.3	0	0.46	0.22866	0.76
09/06/2024 05:00	0.6	1.3	0	0.51	0.25506	0.85
09/06/2024 06:00	0.6	1.3	1	0.48	0.24138	0.80
09/06/2024 07:00	0.7	1.3	1	0.47	0.23556	0.79
09/06/2024 08:00	0.7	1.4	1	0.43	0.21336	0.71
09/06/2024 09:00	0.7	1.3	1	0.43	0.21348	0.71
09/06/2024 10:00	0.6	1.2	0	0.43	0.21372	0.71
09/06/2024 11:00	0.6	1.3	0	0.44	0.22224	0.74
09/06/2024 12:00	0.5	1.3	0	0.50	0.25044	0.83
09/06/2024 13:00	0.5	1.4	1	0.57	0.28326	0.94
09/06/2024 14:00	0.0	1.5	1	0.73	0.36342	1.21
09/06/2024 15:00	0.0	1.5	2	0.74	0.37002	1.23
09/06/2024 16:00	0.1	1.4	1	0.70	0.35154	1.17
09/06/2024 17:00	0.0	1.5	2	0.74	0.36954	1.23
09/06/2024 18:00	0.0	1.5	2	0.75	0.37470	1.25
09/06/2024 19:00	0.1	1.5	1	0.71	0.35532	1.18
09/06/2024 20:00	0.1	1.5	1	0.71	0.35418	1.18
09/06/2024 21:00	0.1	1.5	1	0.72	0.36030	1.20
09/06/2024 22:00	0.1	1.4	1	0.71	0.35424	1.18
09/06/2024 23:00	0.1	1.5	1	0.72	0.35862	1.20
Average/Sum#:	0.4	1.4	1	0.57	0.28519	0.95
Minimum:	0.0	1.2	0	0.43	0.21336	0.71
Maximum:	0.7	1.5	2	0.75	0.37470	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/07/2024 00:00	0.1	1.5	1	0.70	0.35130	1.17
09/07/2024 01:00	0.6	1.4	1	0.60	0.29934	1.00
09/07/2024 02:00	0.6	1.3	1	0.43	0.21534	0.72
09/07/2024 03:00	0.7	1.4	1	0.43	0.21678	0.72
09/07/2024 04:00	0.6	1.4	1	0.43	0.21408	0.71
09/07/2024 05:00	0.6	1.3	1	0.43	0.21324	0.71
09/07/2024 06:00	0.6	1.3	1	0.43	0.21354	0.71
09/07/2024 07:00	0.6	1.4	1	0.43	0.21372	0.71
09/07/2024 08:00	0.6	1.4	1	0.43	0.21360	0.71
09/07/2024 09:00	0.6	1.3	0	0.43	0.21360	0.71
09/07/2024 10:00	0.6	1.4	0	0.43	0.21366	0.71
09/07/2024 11:00	0.5	1.4	0	0.43	0.21408	0.71
09/07/2024 12:00	0.5	1.3	0	0.49	0.24534	0.82
09/07/2024 13:00	0.5	1.3	0	0.53	0.26364	0.88
09/07/2024 14:00	0.3	1.4	1	0.65	0.32742	1.09
09/07/2024 15:00	0.3	1.4	1	0.65	0.32616	1.09
09/07/2024 16:00	0.4	1.4	1	0.63	0.31596	1.05
09/07/2024 17:00	0.1	1.5	1	0.71	0.35388	1.18
09/07/2024 18:00	0.0	1.5	1	0.71	0.35664	1.19
09/07/2024 19:00	0.1	1.5	1	0.70	0.34920	1.16
09/07/2024 20:00	0.1	1.5	1	0.71	0.35412	1.18
09/07/2024 21:00	0.1	1.5	1	0.71	0.35316	1.18
09/07/2024 22:00	0.1	1.5	1	0.71	0.35598	1.19
09/07/2024 23:00	0.4	1.5	1	0.67	0.33624	1.12
Average/Sum#:	0.4	1.4	1	0.56	0.28042	0.93
Minimum:	0.0	1.3	0	0.43	0.21324	0.71
Maximum:	0.7	1.5	1	0.71	0.35664	1.19
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/08/2024 00:00	0.7	1.2	1	0.49	0.24306	0.81
09/08/2024 01:00	0.6	1.4	1	0.43	0.21456	0.72
09/08/2024 02:00	0.6	1.2	1	0.43	0.21486	0.72
09/08/2024 03:00	0.7	1.4	1	0.43	0.21504	0.72
09/08/2024 04:00	0.6	1.4	1	0.43	0.21510	0.72
09/08/2024 05:00	0.6	1.4	1	0.43	0.21504	0.72
09/08/2024 06:00	0.6	1.4	1	0.43	0.21510	0.72
09/08/2024 07:00	0.6	1.4	1	0.43	0.21462	0.72
09/08/2024 08:00	0.6	1.4	1	0.43	0.21438	0.71
09/08/2024 09:00	0.6	1.4	1	0.43	0.21384	0.71
09/08/2024 10:00	0.6	1.4	1	0.43	0.21384	0.71
09/08/2024 11:00	0.6	1.2	0	0.43	0.21432	0.71
09/08/2024 12:00	0.5	1.2	0	0.44	0.21954	0.73
09/08/2024 13:00	0.6	1.4	0	0.51	0.25542	0.85
09/08/2024 14:00	0.2	1.4	1	0.67	0.33648	1.12
09/08/2024 15:00	0.1	1.4	1	0.70	0.34920	1.16
09/08/2024 16:00	0.0	1.5	2	0.74	0.36804	1.23
09/08/2024 17:00	0.0	1.5	2	0.75	0.37404	1.25
09/08/2024 18:00	0.0	1.5	1	0.73	0.36690	1.22
09/08/2024 19:00	0.1	1.5	1	0.73	0.36276	1.21
09/08/2024 20:00	0.1	1.5	1	0.72	0.36018	1.20
09/08/2024 21:00	0.5	1.4	1	0.60	0.29910	1.00
09/08/2024 22:00	0.6	1.2	0	0.49	0.24528	0.82
09/08/2024 23:00	0.6	1.3	1	0.46	0.22806	0.76
Average/Sum#:	0.4	1.4	1	0.53	0.26537	0.89
Minimum:	0.0	1.2	0	0.43	0.21384	0.71
Maximum:	0.7	1.5	2	0.75	0.37404	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/09/2024 00:00	0.6	1.3	1	0.43	0.21504	0.72
09/09/2024 01:00	0.7	1.4	1	0.43	0.21462	0.72
09/09/2024 02:00	0.8	1.4	1	0.43	0.21462	0.72
09/09/2024 03:00	0.9	1.4	1	0.43	0.21444	0.71
09/09/2024 04:00	1.0	1.4	0	0.46	0.22818	0.76
09/09/2024 05:00	0.8	1.4	0	0.50	0.25170	0.84
09/09/2024 06:00	0.9	1.3	1	0.44	0.22140	0.74
09/09/2024 07:00	0.9	1.3	1	0.43	0.21606	0.72
09/09/2024 08:00	0.8	1.3	1	0.43	0.21552	0.72
09/09/2024 09:00	0.7	1.4	1	0.43	0.21426	0.71
09/09/2024 10:00	0.6	1.3	0	0.43	0.21468	0.72
09/09/2024 11:00	0.6	1.3	0	0.43	0.21468	0.72
09/09/2024 12:00	0.5	1.3	0	0.45	0.22470	0.75
09/09/2024 13:00	0.5	1.2	0	0.45	0.22362	0.75
09/09/2024 14:00	0.6	1.3	0	0.43	0.21372	0.71
09/09/2024 15:00	0.5	1.3	0	0.45	0.22680	0.76
09/09/2024 16:00	0.5	1.2	0	0.49	0.24444	0.81
09/09/2024 17:00	0.5	1.3	1	0.54	0.26982	0.90
09/09/2024 18:00	0.2	1.4	1	0.68	0.33978	1.13
09/09/2024 19:00	0.6	1.3	1	0.54	0.26868	0.90
09/09/2024 20:00	0.6	1.2	1	0.45	0.22386	0.75
09/09/2024 21:00	0.6	1.3	0	0.44	0.21954	0.73
09/09/2024 22:00	0.6	1.3	1	0.43	0.21414	0.71
09/09/2024 23:00	0.6	1.2	0	0.48	0.24078	0.80
Average/Sum#:	0.7	1.3	1	0.46	0.23105	0.77
Minimum:	0.2	1.2	0	0.43	0.21372	0.71
Maximum:	1.0	1.4	1	0.68	0.33978	1.13
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/10/2024 00:00	0.6	1.3	1	0.45	0.22266	0.74
09/10/2024 01:00	0.6	1.4	1	0.43	0.21414	0.71
09/10/2024 02:00	0.6	1.2	0	0.43	0.21420	0.71
09/10/2024 03:00	0.7	1.4	1	0.43	0.21420	0.71
09/10/2024 04:00	0.6	1.4	1	0.43	0.21426	0.71
09/10/2024 05:00	0.6	1.3	0	0.47	0.23586	0.79
09/10/2024 06:00	0.6	1.4	1	0.44	0.21918	0.73
09/10/2024 07:00	0.6	1.4	1	0.43	0.21480	0.72
09/10/2024 08:00	0.6	1.4	1	0.43	0.21450	0.72
09/10/2024 09:00	0.6	1.4	1	0.43	0.21432	0.71
09/10/2024 10:00	0.6	1.4	1	0.43	0.21426	0.71
09/10/2024 11:00	0.6	1.4	1	0.43	0.21432	0.71
09/10/2024 12:00	0.6	1.3	1	0.43	0.21420	0.71
09/10/2024 13:00	0.6	1.4	1	0.43	0.21384	0.71
09/10/2024 14:00	0.6	1.4	1	0.43	0.21426	0.71
09/10/2024 15:00	0.6	1.3	1	0.43	0.21408	0.71
09/10/2024 16:00	0.6	1.3	1	0.43	0.21372	0.71
09/10/2024 17:00	0.6	1.3	1	0.43	0.21342	0.71
09/10/2024 18:00	0.6	1.3	1	0.43	0.21342	0.71
09/10/2024 19:00	0.6	1.3	1	0.43	0.21348	0.71
09/10/2024 20:00	0.6	1.4	1	0.43	0.21348	0.71
09/10/2024 21:00	0.6	1.4	1	0.43	0.21348	0.71
09/10/2024 22:00	0.6	1.4	1	0.43	0.21336	0.71
09/10/2024 23:00	0.6	1.3	1	0.43	0.21366	0.71
Average/Sum#:	0.6	1.4	1	0.43	0.21546	0.72
Minimum:	0.6	1.2	0	0.43	0.21336	0.71
Maximum:	0.7	1.4	1	0.47	0.23586	0.79
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/11/2024 00:00	0.6	1.4	1	0.43	0.21372	0.71
09/11/2024 01:00	0.6	1.4	1	0.43	0.21360	0.71
09/11/2024 02:00	0.6	1.4	1	0.43	0.21348	0.71
09/11/2024 03:00	0.7	1.4	1	0.43	0.21348	0.71
09/11/2024 04:00	0.7	1.4	1	0.43	0.21348	0.71
09/11/2024 05:00	0.6	1.3	0	0.46	0.23142	0.77
09/11/2024 06:00	0.7	1.4	1	0.44	0.22170	0.74
09/11/2024 07:00	0.7	1.4	1	0.43	0.21360	0.71
09/11/2024 08:00	0.6	1.4	1	0.43	0.21372	0.71
09/11/2024 09:00	0.6	1.3	1	0.43	0.21372	0.71
09/11/2024 10:00	0.6	1.4	1	0.43	0.21414	0.71
09/11/2024 11:00	0.6	1.3	1	0.43	0.21468	0.72
09/11/2024 12:00	0.6	1.4	1	0.43	0.21438	0.71
09/11/2024 13:00	0.6	1.4	1	0.43	0.21342	0.71
09/11/2024 14:00	0.6	1.3	1	0.43	0.21312	0.71
09/11/2024 15:00	0.6	1.4	1	0.43	0.21312	0.71
09/11/2024 16:00	0.6	1.3	1	0.43	0.21318	0.71
09/11/2024 17:00	0.6	1.3	1	0.43	0.21288	0.71
09/11/2024 18:00	0.6	1.3	1	0.43	0.21294	0.71
09/11/2024 19:00	0.6	1.3	1	0.43	0.21318	0.71
09/11/2024 20:00	0.6	1.4	1	0.43	0.21330	0.71
09/11/2024 21:00	0.6	1.4	1	0.43	0.21342	0.71
09/11/2024 22:00	0.6	1.3	1	0.43	0.21324	0.71
09/11/2024 23:00	0.6	1.3	1	0.43	0.21330	0.71
Average/Sum#:	0.6	1.4	1	0.43	0.21459	0.71
Minimum:	0.6	1.3	0	0.43	0.21288	0.71
Maximum:	0.7	1.4	1	0.46	0.23142	0.77
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/12/2024 00:00	0.6	1.4	1	0.43	0.21342	0.71
09/12/2024 01:00	0.6	1.4	1	0.43	0.21330	0.71
09/12/2024 02:00	0.6	1.4	1	0.43	0.21354	0.71
09/12/2024 03:00	0.8	1.4	1	0.43	0.21378	0.71
09/12/2024 04:00	0.7	1.3	1	0.43	0.21366	0.71
09/12/2024 05:00	0.9	1.4	1	0.43	0.21366	0.71
09/12/2024 06:00	1.1	1.4	1	0.43	0.21426	0.71
09/12/2024 07:00	0.8	1.3	1	0.43	0.21420	0.71
09/12/2024 08:00	0.7	1.4	1	0.43	0.21438	0.71
09/12/2024 09:00	0.6	1.2	0	0.43	0.21426	0.71
09/12/2024 10:00	0.5	1.4	1	0.43	0.21450	0.72
09/12/2024 11:00	0.5	1.3	1	0.43	0.21396	0.71
09/12/2024 12:00	0.5	1.3	1	0.43	0.21408	0.71
09/12/2024 13:00	0.5	1.4	1	0.43	0.21330	0.71
09/12/2024 14:00	0.5	1.3	1	0.43	0.21336	0.71
09/12/2024 15:00	0.5	1.4	1	0.43	0.21336	0.71
09/12/2024 16:00	0.5	1.3	1	0.43	0.21330	0.71
09/12/2024 17:00	0.5	1.4	1	0.43	0.21306	0.71
09/12/2024 18:00	0.5	1.4	1	0.43	0.21312	0.71
09/12/2024 19:00	0.5	1.3	1	0.43	0.21330	0.71
09/12/2024 20:00	0.5	1.4	1	0.43	0.21312	0.71
09/12/2024 21:00	0.5	1.3	1	0.43	0.21336	0.71
09/12/2024 22:00	0.6	1.3	1	0.43	0.21330	0.71
09/12/2024 23:00	0.6	1.3	1	0.43	0.21432	0.71
Average/Sum#:	0.6	1.4	1	0.43	0.21366	0.71
Minimum:	0.5	1.2	0	0.43	0.21306	0.71
Maximum:	1.1	1.4	1	0.43	0.21450	0.72
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/13/2024 00:00	0.6	1.3	1	0.43	0.21348	0.71
09/13/2024 01:00	0.6	1.3	1	0.43	0.21354	0.71
09/13/2024 02:00	0.6	1.2	1	0.43	0.21336	0.71
09/13/2024 03:00	0.6	1.3	1	0.43	0.21324	0.71
09/13/2024 04:00	0.6	1.3	1	0.43	0.21684	0.72
09/13/2024 05:00	0.6	1.3	0	0.49	0.24726	0.82
09/13/2024 06:00	0.6	1.3	1	0.47	0.23298	0.78
09/13/2024 07:00	0.6	1.4	1	0.43	0.21426	0.71
09/13/2024 08:00	0.6	1.4	1	0.43	0.21396	0.71
09/13/2024 09:00	0.5	1.4	1	0.43	0.21336	0.71
09/13/2024 10:00	0.5	1.4	1	0.43	0.21348	0.71
09/13/2024 11:00	0.6	1.3	1	0.43	0.21546	0.72
09/13/2024 12:00	0.5	1.3	0	0.44	0.22248	0.74
09/13/2024 13:00	0.5	1.3	0	0.49	0.24264	0.81
09/13/2024 14:00	0.5	1.3	0	0.49	0.24594	0.82
09/13/2024 15:00	0.5	1.2	1	0.49	0.24348	0.81
09/13/2024 16:00	0.6	1.3	0	0.53	0.26598	0.89
09/13/2024 17:00	0.1	1.5	2	0.76	0.37860	1.26
09/13/2024 18:00	0.1	1.4	2	0.74	0.36762	1.23
09/13/2024 19:00	0.6	1.3	1	0.50	0.24750	0.83
09/13/2024 20:00	0.6	1.3	1	0.43	0.21612	0.72
09/13/2024 21:00	0.6	1.4	1	0.43	0.21354	0.71
09/13/2024 22:00	0.6	1.3	1	0.44	0.21780	0.73
09/13/2024 23:00	0.6	1.3	0	0.47	0.23298	0.78
Average/Sum#:	0.5	1.3	1	0.48	0.23816	0.79
Minimum:	0.1	1.2	0	0.43	0.21324	0.71
Maximum:	0.6	1.5	2	0.76	0.37860	1.26
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/14/2024 00:00	0.6	1.3	0	0.47	0.23478	0.78
09/14/2024 01:00	0.6	1.3	1	0.43	0.21612	0.72
09/14/2024 02:00	0.6	1.3	1	0.43	0.21330	0.71
09/14/2024 03:00	0.6	1.4	0	0.51	0.25296	0.84
09/14/2024 04:00	0.6	1.3	1	0.50	0.25056	0.84
09/14/2024 05:00	0.6	1.3	1	0.54	0.26916	0.90
09/14/2024 06:00	0.6	1.4	1	0.45	0.22554	0.75
09/14/2024 07:00	0.5	1.3	1	0.43	0.21372	0.71
09/14/2024 08:00	0.5	1.3	1	0.43	0.21330	0.71
09/14/2024 09:00	0.6	1.4	1	0.43	0.21324	0.71
09/14/2024 10:00	0.6	1.4	1	0.43	0.21348	0.71
09/14/2024 11:00	0.5	1.3	1	0.43	0.21468	0.72
09/14/2024 12:00	0.5	1.2	0	0.43	0.21510	0.72
09/14/2024 13:00	0.5	1.3	0	0.43	0.21474	0.72
09/14/2024 14:00	0.5	1.2	0	0.43	0.21492	0.72
09/14/2024 15:00	0.5	1.2	0	0.43	0.21414	0.71
09/14/2024 16:00	0.5	1.3	0	0.45	0.22626	0.75
09/14/2024 17:00	0.4	1.2	0	0.50	0.25068	0.84
09/14/2024 18:00	0.5	1.3	1	0.48	0.24114	0.80
09/14/2024 19:00	0.5	1.3	1	0.43	0.21330	0.71
09/14/2024 20:00	0.5	1.3	1	0.43	0.21276	0.71
09/14/2024 21:00	0.5	1.4	1	0.43	0.21288	0.71
09/14/2024 22:00	0.5	1.3	1	0.43	0.21300	0.71
09/14/2024 23:00	0.5	1.3	1	0.43	0.21426	0.71
Average/Sum#:	0.5	1.3	1	0.45	0.22392	0.75
Minimum:	0.4	1.2	0	0.43	0.21276	0.71
Maximum:	0.6	1.4	1	0.54	0.26916	0.90
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/15/2024 00:00	0.5	1.4	1	0.43	0.21426	0.71
09/15/2024 01:00	0.5	1.3	1	0.43	0.21432	0.71
09/15/2024 02:00	0.5	1.4	1	0.43	0.21432	0.71
09/15/2024 03:00	0.6	1.4	1	0.43	0.21426	0.71
09/15/2024 04:00	0.5	1.4	1	0.43	0.21432	0.71
09/15/2024 05:00	0.5	1.3	1	0.43	0.21444	0.71
09/15/2024 06:00	0.5	1.3	1	0.43	0.21444	0.71
09/15/2024 07:00	0.5	1.3	1	0.43	0.21456	0.72
09/15/2024 08:00	0.5	1.4	1	0.43	0.21426	0.71
09/15/2024 09:00	0.5	1.3	1	0.43	0.21426	0.71
09/15/2024 10:00	0.5	1.3	1	0.43	0.21372	0.71
09/15/2024 11:00	0.5	1.4	1	0.43	0.21408	0.71
09/15/2024 12:00	0.5	1.4	1	0.43	0.21360	0.71
09/15/2024 13:00	0.5	1.3	1	0.43	0.21300	0.71
09/15/2024 14:00	0.5	1.3	1	0.43	0.21306	0.71
09/15/2024 15:00	0.5	1.3	1	0.43	0.21312	0.71
09/15/2024 16:00	0.5	1.4	0	0.46	0.22806	0.76
09/15/2024 17:00	0.5	1.3	1	0.43	0.21360	0.71
09/15/2024 18:00	0.5	1.4	1	0.43	0.21300	0.71
09/15/2024 19:00	0.5	1.3	1	0.43	0.21306	0.71
09/15/2024 20:00	0.5	1.3	1	0.43	0.21312	0.71
09/15/2024 21:00	0.5	1.3	1	0.43	0.21318	0.71
09/15/2024 22:00	0.6	1.4	1	0.43	0.21342	0.71
09/15/2024 23:00	0.6	1.3	1	0.43	0.21348	0.71
Average/Sum#:	0.5	1.3	1	0.43	0.21437	0.71
Minimum:	0.5	1.3	0	0.43	0.21300	0.71
Maximum:	0.6	1.4	1	0.46	0.22806	0.76
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/16/2024 00:00	0.6	1.4	1	0.43	0.21360	0.71
09/16/2024 01:00	0.6	1.4	1	0.43	0.21366	0.71
09/16/2024 02:00	0.6	1.3	1	0.43	0.21372	0.71
09/16/2024 03:00	0.7	1.4	1	0.43	0.21360	0.71
09/16/2024 04:00	0.6	1.4	1	0.43	0.21348	0.71
09/16/2024 05:00	0.6	1.3	1	0.47	0.23454	0.78
09/16/2024 06:00	0.6	1.3	1	0.47	0.23382	0.78
09/16/2024 07:00	0.5	1.3	0	0.52	0.25872	0.86
09/16/2024 08:00	0.8	1.4	1	0.55	0.27606	0.92
09/16/2024 09:00	0.6	1.3	0	0.54	0.26994	0.90
09/16/2024 10:00	0.4	1.4	0	0.54	0.26916	0.90
09/16/2024 11:00	0.4	1.3	0	0.54	0.26916	0.90
09/16/2024 12:00	0.5	1.2	1	0.48	0.24012	0.80
09/16/2024 13:00	0.5	1.4	1	0.43	0.21372	0.71
09/16/2024 14:00	0.5	1.3	1	0.43	0.21336	0.71
09/16/2024 15:00	0.5	1.4	1	0.43	0.21354	0.71
09/16/2024 16:00	0.5	1.4	1	0.46	0.22890	0.76
09/16/2024 17:00	0.5	1.3	1	0.43	0.21636	0.72
09/16/2024 18:00	0.5	1.3	1	0.43	0.21504	0.72
09/16/2024 19:00	0.5	1.3	1	0.43	0.21516	0.72
09/16/2024 20:00	0.5	1.3	0	0.50	0.25176	0.84
09/16/2024 21:00	0.5	1.3	1	0.48	0.23898	0.80
09/16/2024 22:00	0.5	1.3	0	0.50	0.24960	0.83
09/16/2024 23:00	0.5	1.3	1	0.44	0.22002	0.73
Average/Sum#:	0.5	1.3	1	0.47	0.23317	0.78
Minimum:	0.4	1.2	0	0.43	0.21336	0.71
Maximum:	0.8	1.4	1	0.55	0.27606	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/17/2024 00:00	0.5	1.3	1	0.43	0.21348	0.71
09/17/2024 01:00	0.5	1.3	1	0.43	0.21384	0.71
09/17/2024 02:00	0.5	1.5	1	0.43	0.21372	0.71
09/17/2024 03:00	0.6	1.3	1	0.43	0.21402	0.71
09/17/2024 04:00	0.6	1.3	0	0.45	0.22554	0.75
09/17/2024 05:00	0.5	1.3	0	0.50	0.25140	0.84
09/17/2024 06:00	0.6	1.4	1	0.45	0.22560	0.75
09/17/2024 07:00	0.6	1.4	1	0.43	0.21504	0.72
09/17/2024 08:00	0.6	1.3	1	0.43	0.21534	0.72
09/17/2024 09:00	0.5	1.4	1	0.43	0.21594	0.72
09/17/2024 10:00	0.5	1.3	1	0.43	0.21492	0.72
09/17/2024 11:00	0.5	1.4	1	0.43	0.21576	0.72
09/17/2024 12:00	0.5	1.3	1	0.43	0.21594	0.72
09/17/2024 13:00	0.5	1.4	1	0.43	0.21570	0.72
09/17/2024 14:00	0.5	1.3	1	0.43	0.21582	0.72
09/17/2024 15:00	0.5	1.4	1	0.43	0.21582	0.72
09/17/2024 16:00	0.5	1.4	1	0.43	0.21564	0.72
09/17/2024 17:00	0.5	1.3	1	0.43	0.21450	0.72
09/17/2024 18:00	0.5	1.4	1	0.43	0.21408	0.71
09/17/2024 19:00	0.5	1.3	1	0.43	0.21432	0.71
09/17/2024 20:00	0.5	1.3	1	0.43	0.21534	0.72
09/17/2024 21:00	0.5	1.4	1	0.43	0.21570	0.72
09/17/2024 22:00	0.5	1.3	1	0.43	0.21558	0.72
09/17/2024 23:00	0.5	1.3	1	0.43	0.21462	0.72
Average/Sum#:	0.5	1.3	1	0.43	0.21740	0.73
Minimum:	0.5	1.3	0	0.43	0.21348	0.71
Maximum:	0.6	1.5	1	0.50	0.25140	0.84
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/18/2024 00:00	0.5	1.3	1	0.43	0.21450	0.72
09/18/2024 01:00	0.5	1.3	1	0.43	0.21468	0.72
09/18/2024 02:00	0.5	1.2	1	0.43	0.21396	0.71
09/18/2024 03:00	0.6	1.3	1	0.43	0.21378	0.71
09/18/2024 04:00	0.5	1.4	1	0.43	0.21390	0.71
09/18/2024 05:00	0.6	1.4	1	0.43	0.21648	0.72
09/18/2024 06:00	0.6	1.3	1	0.46	0.22842	0.76
09/18/2024 07:00	0.6	1.4	1	0.43	0.21420	0.71
09/18/2024 08:00	0.6	1.3	1	0.43	0.21420	0.71
09/18/2024 09:00	0.6	1.3	1	0.43	0.21480	0.72
09/18/2024 10:00	0.6	1.3	1	0.43	0.21486	0.72
09/18/2024 11:00	0.5	1.3	1	0.43	0.21522	0.72
09/18/2024 12:00	0.5	1.3	1	0.43	0.21498	0.72
09/18/2024 13:00	0.5	1.3	1	0.43	0.21492	0.72
09/18/2024 14:00	0.5	1.3	1	0.43	0.21480	0.72
09/18/2024 15:00	0.5	1.4	1	0.43	0.21432	0.71
09/18/2024 16:00	0.5	1.2	0	0.48	0.23760	0.79
09/18/2024 17:00	0.5	1.2	0	0.48	0.23964	0.80
09/18/2024 18:00	0.5	1.3	1	0.43	0.21396	0.71
09/18/2024 19:00	0.5	1.4	1	0.43	0.21420	0.71
09/18/2024 20:00	0.5	1.3	0	0.53	0.26694	0.89
09/18/2024 21:00	0.5	1.3	0	0.54	0.26904	0.90
09/18/2024 22:00	0.6	1.3	0	0.54	0.26898	0.90
09/18/2024 23:00	0.6	1.4	0	0.53	0.26742	0.89
Average/Sum#:	0.5	1.3	1	0.45	0.22608	0.75
Minimum:	0.5	1.2	0	0.43	0.21378	0.71
Maximum:	0.6	1.4	1	0.54	0.26904	0.90
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/19/2024 00:00	0.6	1.3	0	0.54	0.26880	0.90
09/19/2024 01:00	0.6	1.3	0	0.53	0.26370	0.88
09/19/2024 02:00	0.6	1.4	0	0.51	0.25716	0.86
09/19/2024 03:00	0.6	1.4	0	0.54	0.26790	0.89
09/19/2024 04:00	0.6	1.4	0	0.54	0.26868	0.90
09/19/2024 05:00	0.6	1.3	0	0.53	0.26730	0.89
09/19/2024 06:00	0.7	1.3	1	0.47	0.23346	0.78
09/19/2024 07:00	0.6	1.3	0	0.52	0.26202	0.87
09/19/2024 08:00	0.6	1.3	1	0.45	0.22344	0.74
09/19/2024 09:00	0.6	1.3	1	0.43	0.21318	0.71
09/19/2024 10:00	0.5	1.3	1	0.43	0.21336	0.71
09/19/2024 11:00	0.5	1.3	1	0.43	0.21300	0.71
09/19/2024 12:00	0.5	1.4	1	0.43	0.21360	0.71
09/19/2024 13:00	0.6	1.3	1	0.43	0.21252	0.71
09/19/2024 14:00	0.6	1.4	1	0.42	0.21246	0.71
09/19/2024 15:00	0.5	1.3	1	0.43	0.21282	0.71
09/19/2024 16:00	0.5	1.3	0	0.47	0.23586	0.79
09/19/2024 17:00	0.6	1.3	0	0.54	0.26916	0.90
09/19/2024 18:00	0.2	1.4	1	0.69	0.34410	1.15
09/19/2024 19:00	0.5	1.4	1	0.63	0.31350	1.05
09/19/2024 20:00	0.5	1.3	0	0.54	0.26832	0.89
09/19/2024 21:00	0.5	1.4	0	0.53	0.26268	0.88
09/19/2024 22:00	0.5	1.3	1	0.43	0.21546	0.72
09/19/2024 23:00	0.6	1.3	1	0.43	0.21462	0.72
Average/Sum#:	0.6	1.3	1	0.50	0.24696	0.82
Minimum:	0.2	1.3	0	0.42	0.21246	0.71
Maximum:	0.7	1.4	1	0.69	0.34410	1.15
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/20/2024 00:00	0.5	1.4	1	0.42	0.21156	0.71
09/20/2024 01:00	0.5	1.3	1	0.42	0.21120	0.70
09/20/2024 02:00	0.6	1.4	1	0.42	0.21168	0.71
09/20/2024 03:00	0.7	1.4	1	0.42	0.21096	0.70
09/20/2024 04:00	0.6	1.3	1	0.43	0.21546	0.72
09/20/2024 05:00	0.6	1.4	0	0.46	0.22764	0.76
09/20/2024 06:00	0.6	1.4	0	0.44	0.21906	0.73
09/20/2024 07:00	0.0	0.0	0	0.42	0.21174	0.71
09/20/2024 08:00	0.6	1.2	0	0.42	0.21102	0.70
09/20/2024 09:00	0.5	1.4	1	0.43	0.21270	0.71
09/20/2024 10:00	0.5	1.3	0	0.45	0.22680	0.76
09/20/2024 11:00	0.5	1.4	0	0.52	0.26172	0.87
09/20/2024 12:00	0.5	1.3	0	0.53	0.26280	0.88
09/20/2024 13:00	0.5	1.3	0	0.48	0.23850	0.80
09/20/2024 14:00	0.5	1.4	0	0.47	0.23460	0.78
09/20/2024 15:00	0.5	1.3	0	0.42	0.21138	0.70
09/20/2024 16:00	0.5	1.3	0	0.45	0.22278	0.74
09/20/2024 17:00	0.5	1.2	0	0.45	0.22716	0.76
09/20/2024 18:00	0.6	1.3	1	0.42	0.21114	0.70
09/20/2024 19:00	0.6	1.4	1	0.42	0.21072	0.70
09/20/2024 20:00	0.5	1.3	1	0.42	0.21084	0.70
09/20/2024 21:00	0.5	1.3	1	0.42	0.21102	0.70
09/20/2024 22:00	0.5	1.3	1	0.42	0.21054	0.70
09/20/2024 23:00	0.5	1.3	1	0.42	0.21072	0.70
Average/Sum#:	0.5	1.3	1	0.44	0.22057	0.74
Minimum:	0.5	1.2	0	0.42	0.21054	0.70
Maximum:	0.7	1.4	1	0.53	0.26280	0.88
%SI	4.17	4.17	4.17	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/21/2024 00:00	0.5	1.3	1	0.42	0.21078	0.70
09/21/2024 01:00	0.5	1.4	1	0.42	0.21060	0.70
09/21/2024 02:00	0.5	1.5	1	0.42	0.21120	0.70
09/21/2024 03:00	0.6	1.1	1	0.45	0.22440	0.75
09/21/2024 04:00	0.5	1.3	1	0.48	0.23772	0.79
09/21/2024 05:00	0.5	1.3	1	0.43	0.21522	0.72
09/21/2024 06:00	0.5	1.3	1	0.45	0.22686	0.76
09/21/2024 07:00	0.5	1.4	1	0.42	0.21198	0.71
09/21/2024 08:00	0.5	1.3	1	0.42	0.21198	0.71
09/21/2024 09:00	0.5	1.3	1	0.42	0.21168	0.71
09/21/2024 10:00	0.5	1.3	1	0.42	0.21198	0.71
09/21/2024 11:00	0.5	1.3	0	0.46	0.23148	0.77
09/21/2024 12:00	0.4	1.3	0	0.49	0.24600	0.82
09/21/2024 13:00	0.4	1.3	0	0.53	0.26382	0.88
09/21/2024 14:00	0.4	1.2	0	0.52	0.26124	0.87
09/21/2024 15:00	0.5	1.3	0	0.46	0.23004	0.77
09/21/2024 16:00	0.4	1.4	1	0.64	0.31884	1.06
09/21/2024 17:00	0.0	1.4	1	0.70	0.35238	1.17
09/21/2024 18:00	0.4	1.4	1	0.63	0.31680	1.06
09/21/2024 19:00	0.6	1.3	1	0.57	0.28710	0.96
09/21/2024 20:00	0.5	1.3	1	0.45	0.22260	0.74
09/21/2024 21:00	0.6	1.3	0	0.44	0.21762	0.73
09/21/2024 22:00	0.6	1.3	1	0.43	0.21546	0.72
09/21/2024 23:00	0.6	1.3	1	0.42	0.21132	0.70
Average/Sum#:	0.5	1.3	1	0.48	0.23996	0.80
Minimum:	0.0	1.1	0	0.42	0.21060	0.70
Maximum:	0.6	1.5	1	0.70	0.35238	1.17
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/22/2024 00:00	0.6	1.4	1	0.42	0.21120	0.70
09/22/2024 01:00	0.6	1.3	1	0.42	0.21096	0.70
09/22/2024 02:00	0.6	1.3	1	0.42	0.21114	0.70
09/22/2024 03:00	0.6	1.4	1	0.42	0.21168	0.71
09/22/2024 04:00	0.5	1.4	1	0.42	0.21108	0.70
09/22/2024 05:00	0.5	1.3	1	0.42	0.21078	0.70
09/22/2024 06:00	0.6	1.3	1	0.42	0.21156	0.71
09/22/2024 07:00	0.5	1.4	1	0.42	0.21180	0.71
09/22/2024 08:00	0.6	1.4	1	0.42	0.21138	0.70
09/22/2024 09:00	0.5	1.4	1	0.42	0.21210	0.71
09/22/2024 10:00	0.6	1.4	1	0.42	0.21240	0.71
09/22/2024 11:00	0.5	1.3	1	0.42	0.21240	0.71
09/22/2024 12:00	0.5	1.3	0	0.42	0.21210	0.71
09/22/2024 13:00	0.4	1.3	0	0.51	0.25674	0.86
09/22/2024 14:00	0.5	1.4	0	0.47	0.23298	0.78
09/22/2024 15:00	0.5	1.2	1	0.42	0.21228	0.71
09/22/2024 16:00	0.5	1.3	0	0.46	0.23016	0.77
09/22/2024 17:00	0.5	1.3	0	0.42	0.21246	0.71
09/22/2024 18:00	0.5	1.2	0	0.42	0.21132	0.70
09/22/2024 19:00	0.6	1.3	1	0.42	0.21096	0.70
09/22/2024 20:00	0.6	1.3	1	0.42	0.20964	0.70
09/22/2024 21:00	0.6	1.3	1	0.42	0.21012	0.70
09/22/2024 22:00	0.6	1.3	1	0.42	0.21060	0.70
09/22/2024 23:00	0.6	1.3	1	0.42	0.21156	0.71
Average/Sum#:	0.5	1.3	1	0.43	0.21498	0.72
Minimum:	0.4	1.2	0	0.42	0.20964	0.70
Maximum:	0.6	1.4	1	0.51	0.25674	0.86
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/23/2024 00:00	0.6	1.3	1	0.42	0.21108	0.70
09/23/2024 01:00	0.5	1.4	1	0.42	0.21144	0.70
09/23/2024 02:00	0.6	1.1	0	0.42	0.21114	0.70
09/23/2024 03:00	0.6	1.4	1	0.42	0.21168	0.71
09/23/2024 04:00	0.6	1.3	1	0.42	0.21138	0.70
09/23/2024 05:00	0.7	1.3	1	0.42	0.21078	0.70
09/23/2024 06:00	0.8	1.3	1	0.42	0.21234	0.71
09/23/2024 07:00	0.7	1.4	1	0.42	0.21102	0.70
09/23/2024 08:00	0.6	1.4	1	0.42	0.21066	0.70
09/23/2024 09:00	0.6	1.3	1	0.42	0.21108	0.70
09/23/2024 10:00	0.6	1.3	0	0.42	0.21180	0.71
09/23/2024 11:00	0.5	1.2	0	0.42	0.21186	0.71
09/23/2024 12:00	0.5	1.2	0	0.43	0.21534	0.72
09/23/2024 13:00	0.5	1.2	0	0.46	0.22974	0.77
09/23/2024 14:00	0.4	1.3	0	0.47	0.23268	0.78
09/23/2024 15:00	0.8	1.3	0	0.47	0.23598	0.79
09/23/2024 16:00	0.9	1.4	1	0.58	0.29028	0.97
09/23/2024 17:00	0.0	1.4	1	0.70	0.34794	1.16
09/23/2024 18:00	0.1	1.4	1	0.66	0.33084	1.10
09/23/2024 19:00	0.4	1.4	1	0.60	0.29880	1.00
09/23/2024 20:00	0.6	1.3	0	0.52	0.25992	0.87
09/23/2024 21:00	0.6	1.2	0	0.52	0.25920	0.86
09/23/2024 22:00	0.6	1.3	0	0.51	0.25542	0.85
09/23/2024 23:00	0.6	1.3	0	0.49	0.24390	0.81
Average/Sum#:	0.6	1.3	1	0.48	0.23901	0.80
Minimum:	0.0	1.1	0	0.42	0.21066	0.70
Maximum:	0.9	1.4	1	0.70	0.34794	1.16
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/24/2024 00:00	0.6	1.2	0	0.48	0.24198	0.81
09/24/2024 01:00	0.6	1.4	1	0.43	0.21384	0.71
09/24/2024 02:00	0.6	1.3	1	0.42	0.21126	0.70
09/24/2024 03:00	0.7	1.2	1	0.44	0.22080	0.74
09/24/2024 04:00	0.6	1.3	0	0.50	0.25014	0.83
09/24/2024 05:00	0.7	1.3	0	0.52	0.25944	0.86
09/24/2024 06:00	0.7	1.3	1	0.45	0.22434	0.75
09/24/2024 07:00	0.6	1.3	1	0.42	0.21036	0.70
09/24/2024 08:00	0.6	1.4	1	0.42	0.20928	0.70
09/24/2024 09:00	0.6	1.4	1	0.42	0.21048	0.70
09/24/2024 10:00	0.6	1.4	0	0.42	0.21144	0.70
09/24/2024 11:00	0.5	1.2	0	0.42	0.21132	0.70
09/24/2024 12:00	0.5	1.3	0	0.46	0.23064	0.77
09/24/2024 13:00	0.5	1.2	0	0.49	0.24732	0.82
09/24/2024 14:00	0.4	1.3	0	0.50	0.24894	0.83
09/24/2024 15:00	0.5	1.3	0	0.45	0.22512	0.75
09/24/2024 16:00	0.5	1.3	1	0.49	0.24318	0.81
09/24/2024 17:00	0.3	1.4	1	0.63	0.31596	1.05
09/24/2024 18:00	0.5	1.4	1	0.52	0.26058	0.87
09/24/2024 19:00	0.6	1.3	0	0.42	0.21096	0.70
09/24/2024 20:00	0.6	1.4	1	0.42	0.21120	0.70
09/24/2024 21:00	0.6	1.3	1	0.42	0.21150	0.71
09/24/2024 22:00	0.5	1.3	1	0.42	0.21060	0.70
09/24/2024 23:00	0.5	1.4	0	0.42	0.21072	0.70
Average/Sum#:	0.6	1.3	1	0.46	0.22923	0.76
Minimum:	0.3	1.2	0	0.42	0.20928	0.70
Maximum:	0.7	1.4	1	0.63	0.31596	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/25/2024 00:00	0.5	1.3	1	0.42	0.21174	0.71
09/25/2024 01:00	0.5	1.3	1	0.42	0.21144	0.70
09/25/2024 02:00	0.5	1.5	1	0.42	0.21192	0.71
09/25/2024 03:00	0.6	1.3	1	0.42	0.21234	0.71
09/25/2024 04:00	0.5	1.3	0	0.44	0.22098	0.74
09/25/2024 05:00	0.5	1.3	0	0.47	0.23664	0.79
09/25/2024 06:00	0.5	1.3	1	0.44	0.21924	0.73
09/25/2024 07:00	0.5	1.3	1	0.42	0.21078	0.70
09/25/2024 08:00	0.5	1.4	0	0.48	0.24246	0.81
09/25/2024 09:00	0.5	1.4	1	0.44	0.21936	0.73
09/25/2024 10:00	0.5	1.3	1	0.42	0.21222	0.71
09/25/2024 11:00	0.5	1.3	1	0.42	0.21024	0.70
09/25/2024 12:00	0.5	1.3	1	0.42	0.20940	0.70
09/25/2024 13:00	0.5	1.3	1	0.42	0.21018	0.70
09/25/2024 14:00	0.5	1.3	1	0.42	0.20970	0.70
09/25/2024 15:00	0.5	1.4	0	0.42	0.21000	0.70
09/25/2024 16:00	0.5	1.3	0	0.44	0.22092	0.74
09/25/2024 17:00	0.5	1.3	1	0.42	0.21246	0.71
09/25/2024 18:00	0.5	1.4	0	0.42	0.21132	0.70
09/25/2024 19:00	0.5	1.4	1	0.42	0.21102	0.70
09/25/2024 20:00	0.5	1.3	1	0.42	0.21114	0.70
09/25/2024 21:00	0.5	1.4	1	0.42	0.21072	0.70
09/25/2024 22:00	0.5	1.3	1	0.42	0.21060	0.70
09/25/2024 23:00	0.5	1.4	1	0.42	0.21054	0.70
Average/Sum#:	0.5	1.3	1	0.43	0.21489	0.72
Minimum:	0.5	1.3	0	0.42	0.20940	0.70
Maximum:	0.6	1.5	1	0.48	0.24246	0.81
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/26/2024 00:00	0.5	1.3	1	0.42	0.21048	0.70
09/26/2024 01:00	0.5	1.3	1	0.42	0.21048	0.70
09/26/2024 02:00	0.5	1.2	0	0.42	0.21048	0.70
09/26/2024 03:00	0.6	1.4	1	0.42	0.21048	0.70
09/26/2024 04:00	0.5	1.3	1	0.42	0.21030	0.70
09/26/2024 05:00	0.5	1.3	1	0.42	0.21042	0.70
09/26/2024 06:00	0.6	1.4	1	0.42	0.21054	0.70
09/26/2024 07:00	0.7	1.4	1	0.42	0.21090	0.70
09/26/2024 08:00	0.6	1.3	1	0.42	0.21084	0.70
09/26/2024 09:00	0.6	1.3	1	0.42	0.21066	0.70
09/26/2024 10:00	0.5	1.4	1	0.42	0.21048	0.70
09/26/2024 11:00	0.5	1.3	1	0.42	0.21072	0.70
09/26/2024 12:00	0.5	1.3	1	0.42	0.21138	0.70
09/26/2024 13:00	0.5	1.4	1	0.42	0.21204	0.71
09/26/2024 14:00	0.5	1.3	1	0.42	0.21156	0.71
09/26/2024 15:00	0.5	1.3	1	0.42	0.21114	0.70
09/26/2024 16:00	0.7	1.2	0	0.49	0.24678	0.82
09/26/2024 17:00	0.4	1.4	1	0.64	0.32136	1.07
09/26/2024 18:00	0.4	1.4	1	0.64	0.32226	1.07
09/26/2024 19:00	0.5	1.4	1	0.63	0.31746	1.06
09/26/2024 20:00	0.5	1.4	1	0.65	0.32292	1.08
09/26/2024 21:00	0.7	1.3	1	0.54	0.26760	0.89
09/26/2024 22:00	0.6	1.2	1	0.46	0.23136	0.77
09/26/2024 23:00	0.7	1.3	1	0.43	0.21390	0.71
Average/Sum#:	0.5	1.3	1	0.47	0.23402	0.78
Minimum:	0.4	1.2	0	0.42	0.21030	0.70
Maximum:	0.7	1.4	1	0.65	0.32292	1.08
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/27/2024 00:00	0.7	1.3	1	0.42	0.21018	0.70
09/27/2024 01:00	0.7	1.4	1	0.42	0.21048	0.70
09/27/2024 02:00	0.6	1.3	1	0.42	0.21048	0.70
09/27/2024 03:00	0.9	1.4	1	0.42	0.21078	0.70
09/27/2024 04:00	0.7	1.3	1	0.48	0.23886	0.80
09/27/2024 05:00	0.6	1.2	0	0.50	0.25110	0.84
09/27/2024 06:00	0.7	1.3	1	0.46	0.22824	0.76
09/27/2024 07:00	0.7	1.3	1	0.42	0.21048	0.70
09/27/2024 08:00	0.6	1.4	1	0.42	0.21054	0.70
09/27/2024 09:00	0.5	1.3	1	0.42	0.21048	0.70
09/27/2024 10:00	0.5	1.3	1	0.42	0.21060	0.70
09/27/2024 11:00	0.5	1.3	1	0.42	0.21084	0.70
09/27/2024 12:00	0.5	1.3	1	0.42	0.20994	0.70
09/27/2024 13:00	0.5	1.2	0	0.42	0.20964	0.70
09/27/2024 14:00	0.5	1.3	0	0.42	0.20952	0.70
09/27/2024 15:00	0.5	1.3	0	0.42	0.21144	0.70
09/27/2024 16:00	0.7	1.3	0	0.50	0.24810	0.83
09/27/2024 17:00	0.5	1.4	1	0.61	0.30612	1.02
09/27/2024 18:00	0.5	1.4	1	0.61	0.30486	1.02
09/27/2024 19:00	0.7	1.3	1	0.57	0.28704	0.96
09/27/2024 20:00	0.6	1.3	0	0.52	0.25926	0.86
09/27/2024 21:00	0.6	1.3	0	0.50	0.24996	0.83
09/27/2024 22:00	0.7	1.3	0	0.50	0.24864	0.83
09/27/2024 23:00	0.6	1.3	0	0.53	0.26454	0.88
Average/Sum#:	0.6	1.3	1	0.47	0.23426	0.78
Minimum:	0.5	1.2	0	0.42	0.20952	0.70
Maximum:	0.9	1.4	1	0.61	0.30612	1.02
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/28/2024 00:00	0.5	1.3	0	0.51	0.25530	0.85
09/28/2024 01:00	0.6	1.3	1	0.45	0.22572	0.75
09/28/2024 02:00	0.6	1.4	1	0.42	0.20964	0.70
09/28/2024 03:00	0.7	1.4	1	0.42	0.21012	0.70
09/28/2024 04:00	0.6	1.3	1	0.42	0.21060	0.70
09/28/2024 05:00	0.7	1.3	1	0.42	0.21138	0.70
09/28/2024 06:00	0.7	1.4	1	0.42	0.21072	0.70
09/28/2024 07:00	0.6	1.3	1	0.42	0.20976	0.70
09/28/2024 08:00	0.6	1.4	1	0.42	0.20964	0.70
09/28/2024 09:00	0.6	1.4	1	0.42	0.20934	0.70
09/28/2024 10:00	0.5	1.3	1	0.42	0.20934	0.70
09/28/2024 11:00	0.5	1.2	0	0.42	0.20952	0.70
09/28/2024 12:00	0.5	1.2	0	0.42	0.20994	0.70
09/28/2024 13:00	0.5	1.2	0	0.42	0.21144	0.70
09/28/2024 14:00	0.5	1.2	0	0.44	0.22188	0.74
09/28/2024 15:00	0.5	1.2	0	0.46	0.22758	0.76
09/28/2024 16:00	0.7	1.3	1	0.49	0.24696	0.82
09/28/2024 17:00	0.5	1.3	1	0.61	0.30528	1.02
09/28/2024 18:00	0.6	1.4	1	0.61	0.30372	1.01
09/28/2024 19:00	0.7	1.4	0	0.57	0.28548	0.95
09/28/2024 20:00	0.5	1.3	1	0.42	0.21138	0.70
09/28/2024 21:00	0.5	1.3	1	0.42	0.20964	0.70
09/28/2024 22:00	0.5	1.3	1	0.42	0.20970	0.70
09/28/2024 23:00	0.5	1.4	1	0.42	0.20994	0.70
Average/Sum#:	0.6	1.3	1	0.45	0.22642	0.75
Minimum:	0.5	1.2	0	0.42	0.20934	0.70
Maximum:	0.7	1.4	1	0.61	0.30528	1.02
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/29/2024 00:00	0.5	1.3	1	0.42	0.21000	0.70
09/29/2024 01:00	0.5	1.3	1	0.42	0.21000	0.70
09/29/2024 02:00	0.6	1.4	1	0.42	0.21018	0.70
09/29/2024 03:00	0.6	1.4	1	0.42	0.21030	0.70
09/29/2024 04:00	0.6	1.3	1	0.42	0.21036	0.70
09/29/2024 05:00	0.6	1.3	1	0.42	0.21030	0.70
09/29/2024 06:00	0.6	1.4	1	0.42	0.21036	0.70
09/29/2024 07:00	0.6	1.3	1	0.42	0.21042	0.70
09/29/2024 08:00	0.6	1.4	1	0.42	0.21024	0.70
09/29/2024 09:00	0.5	1.3	1	0.42	0.21054	0.70
09/29/2024 10:00	0.5	1.3	1	0.42	0.21048	0.70
09/29/2024 11:00	0.5	1.4	1	0.42	0.21024	0.70
09/29/2024 12:00	0.5	1.4	1	0.42	0.21024	0.70
09/29/2024 13:00	0.5	1.4	1	0.42	0.20982	0.70
09/29/2024 14:00	0.5	1.3	1	0.42	0.21024	0.70
09/29/2024 15:00	0.5	1.4	1	0.42	0.21000	0.70
09/29/2024 16:00	0.5	1.2	0	0.47	0.23568	0.79
09/29/2024 17:00	0.5	1.3	1	0.43	0.21288	0.71
09/29/2024 18:00	0.6	1.3	0	0.42	0.21012	0.70
09/29/2024 19:00	0.6	1.3	1	0.42	0.21138	0.70
09/29/2024 20:00	0.6	1.4	1	0.42	0.20976	0.70
09/29/2024 21:00	0.6	1.4	1	0.42	0.20982	0.70
09/29/2024 22:00	0.7	1.3	1	0.42	0.20994	0.70
09/29/2024 23:00	0.7	1.3	1	0.42	0.21030	0.70
Average/Sum#:	0.6	1.3	1	0.42	0.21140	0.70
Minimum:	0.5	1.2	0	0.42	0.20976	0.70
Maximum:	0.7	1.4	1	0.47	0.23568	0.79
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/30/2024 00:00	0.6	1.3	1	0.42	0.21042	0.70
09/30/2024 01:00	0.6	1.3	1	0.42	0.21030	0.70
09/30/2024 02:00	0.6	1.3	1	0.42	0.21042	0.70
09/30/2024 03:00	0.7	1.4	1	0.42	0.21090	0.70
09/30/2024 04:00	0.8	1.4	1	0.42	0.21096	0.70
09/30/2024 05:00	0.7	1.4	1	0.43	0.21324	0.71
09/30/2024 06:00	0.7	1.3	1	0.46	0.23028	0.77
09/30/2024 07:00	0.7	1.3	1	0.42	0.21084	0.70
09/30/2024 08:00	0.6	1.4	1	0.42	0.21060	0.70
09/30/2024 09:00	0.6	1.4	1	0.42	0.21096	0.70
09/30/2024 10:00	0.5	1.3	1	0.42	0.21138	0.70
09/30/2024 11:00	0.6	1.2	1	0.42	0.21114	0.70
09/30/2024 12:00	0.6	1.3	1	0.42	0.21150	0.71
09/30/2024 13:00	0.5	1.2	0	0.42	0.21186	0.71
09/30/2024 14:00	0.5	1.3	0	0.42	0.21198	0.71
09/30/2024 15:00	1.0	1.3	0	0.50	0.25086	0.84
09/30/2024 16:00	0.1	1.5	1	0.73	0.36552	1.22
09/30/2024 17:00	0.0	1.5	1	0.72	0.36090	1.20
09/30/2024 18:00	0.1	1.4	1	0.70	0.35088	1.17
09/30/2024 19:00	0.1	1.5	1	0.71	0.35424	1.18
09/30/2024 20:00	0.1	1.4	1	0.72	0.35790	1.19
09/30/2024 21:00	0.1	1.4	1	0.71	0.35592	1.19
09/30/2024 22:00	0.5	1.4	1	0.65	0.32712	1.09
09/30/2024 23:00	0.6	1.2	0	0.53	0.26478	0.88
Average/Sum#:	0.5	1.4	1	0.51	0.25729	0.86
Minimum:	0.0	1.2	0	0.42	0.21030	0.70
Maximum:	1.0	1.5	1	0.73	0.36552	1.22
%SI	0.00	0.00	0.00	0.00	0.00	0.00