

DOCKETED

Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	259821-2
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2024 - Part 4 - searchable
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/30/2024 4:56:32 PM
Docketed Date:	10/30/2024

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/01/2024 00:00	0.8	1.4	0	0.46	0.22770	0.76
07/01/2024 01:00	0.8	1.4	0	0.46	0.22788	0.76
07/01/2024 02:00	0.8	1.5	0	0.46	0.22788	0.76
07/01/2024 03:00	0.9	1.5	0	0.46	0.22842	0.76
07/01/2024 04:00	1.0	1.4	0	0.46	0.22872	0.76
07/01/2024 05:00	1.0	1.4	0	0.46	0.22884	0.76
07/01/2024 06:00	1.0	1.4	0	0.46	0.22926	0.76
07/01/2024 07:00	0.9	1.4	-1	0.46	0.22926	0.76
07/01/2024 08:00	0.8	1.4	-1	0.46	0.22908	0.76
07/01/2024 09:00	0.8	1.4	-1	0.46	0.22884	0.76
07/01/2024 10:00	0.7	1.4	-1	0.46	0.22842	0.76
07/01/2024 11:00	0.8	1.2	-1	0.46	0.22818	0.76
07/01/2024 12:00	0.7	1.3	-1	0.46	0.22800	0.76
07/01/2024 13:00	0.7	1.3	-1	0.46	0.22752	0.76
07/01/2024 14:00	0.7	1.3	0	0.46	0.22836	0.76
07/01/2024 15:00	0.7	1.4	0	0.46	0.22920	0.76
07/01/2024 16:00	0.7	1.3	0	0.46	0.22884	0.76
07/01/2024 17:00	0.7	1.3	0	0.49	0.24342	0.81
07/01/2024 18:00	0.6	1.5	1	0.67	0.33552	1.12
07/01/2024 19:00	0.3	1.5	2	0.81	0.40500	1.35
07/01/2024 20:00	0.5	1.4	1	0.72	0.35910	1.20
07/01/2024 21:00	0.9	1.4	0	0.49	0.24456	0.82
07/01/2024 22:00	0.9	1.4	-1	0.46	0.22842	0.76
07/01/2024 23:00	1.0	1.4	-1	0.46	0.22824	0.76
Average/Sum#:	0.8	1.4	0	0.50	0.24703	0.82
Minimum:	0.3	1.2	-1	0.46	0.22752	0.76
Maximum:	1.0	1.5	2	0.81	0.40500	1.35
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/02/2024 00:00	1.0	1.4	-1	0.46	0.22842	0.76
07/02/2024 01:00	1.1	1.4	0	0.46	0.22860	0.76
07/02/2024 02:00	0.9	1.4	0	0.46	0.22842	0.76
07/02/2024 03:00	0.9	1.4	0	0.46	0.22836	0.76
07/02/2024 04:00	0.9	1.4	0	0.46	0.22890	0.76
07/02/2024 05:00	0.8	1.3	0	0.50	0.24876	0.83
07/02/2024 06:00	0.8	1.3	-1	0.47	0.23256	0.78
07/02/2024 07:00	0.8	1.4	-1	0.46	0.22932	0.76
07/02/2024 08:00	0.8	1.4	-1	0.46	0.22824	0.76
07/02/2024 09:00	0.7	1.3	-1	0.46	0.22776	0.76
07/02/2024 10:00	0.7	1.3	-1	0.45	0.22740	0.76
07/02/2024 11:00	0.8	1.3	0	0.45	0.22704	0.76
07/02/2024 12:00	0.7	1.3	0	0.46	0.23130	0.77
07/02/2024 13:00	1.1	1.4	0	0.54	0.26754	0.89
07/02/2024 14:00	0.3	1.5	1	0.72	0.36114	1.20
07/02/2024 15:00	0.2	1.5	1	0.76	0.38016	1.27
07/02/2024 16:00	0.1	1.5	1	0.77	0.38748	1.29
07/02/2024 17:00	0.2	1.5	2	0.79	0.39636	1.32
07/02/2024 18:00	0.2	1.5	2	0.80	0.39786	1.33
07/02/2024 19:00	0.2	1.5	1	0.79	0.39534	1.32
07/02/2024 20:00	0.2	1.5	1	0.79	0.39306	1.31
07/02/2024 21:00	0.3	1.5	1	0.75	0.37560	1.25
07/02/2024 22:00	0.9	1.3	0	0.52	0.25992	0.87
07/02/2024 23:00	1.0	1.4	-1	0.46	0.23040	0.77
Average/Sum#:	0.7	1.4	0	0.57	0.28500	0.95
Minimum:	0.1	1.3	-1	0.45	0.22704	0.76
Maximum:	1.1	1.5	2	0.80	0.39786	1.33
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/03/2024 00:00	0.9	1.4	-1	0.46	0.23040	0.77
07/03/2024 01:00	1.1	1.4	0	0.46	0.22902	0.76
07/03/2024 02:00	1.1	1.4	-1	0.46	0.22902	0.76
07/03/2024 03:00	1.1	1.4	0	0.46	0.22914	0.76
07/03/2024 04:00	1.0	1.4	0	0.46	0.22896	0.76
07/03/2024 05:00	1.0	1.4	0	0.46	0.22920	0.76
07/03/2024 06:00	0.9	1.4	0	0.46	0.22896	0.76
07/03/2024 07:00	0.8	1.4	-1	0.46	0.22866	0.76
07/03/2024 08:00	0.8	1.4	-1	0.46	0.22854	0.76
07/03/2024 09:00	0.8	1.3	-1	0.46	0.22824	0.76
07/03/2024 10:00	0.7	1.2	-1	0.46	0.22764	0.76
07/03/2024 11:00	0.7	1.1	-1	0.45	0.22746	0.76
07/03/2024 12:00	0.7	1.1	0	0.46	0.22776	0.76
07/03/2024 13:00	0.7	1.2	0	0.47	0.23286	0.78
07/03/2024 14:00	0.6	1.4	0	0.64	0.31980	1.07
07/03/2024 15:00	0.3	1.4	1	0.71	0.35742	1.19
07/03/2024 16:00	0.2	1.5	1	0.77	0.38292	1.28
07/03/2024 17:00	0.2	1.5	2	0.79	0.39480	1.32
07/03/2024 18:00	0.1	1.5	1	0.79	0.39438	1.31
07/03/2024 19:00	0.2	1.5	1	0.79	0.39300	1.31
07/03/2024 20:00	0.2	1.5	1	0.74	0.37056	1.24
07/03/2024 21:00	0.8	1.4	0	0.52	0.25866	0.86
07/03/2024 22:00	0.9	1.3	0	0.46	0.22878	0.76
07/03/2024 23:00	0.8	1.4	0	0.46	0.22908	0.76
Average/Sum#:	0.7	1.4	0	0.55	0.27230	0.91
Minimum:	0.1	1.1	-1	0.45	0.22746	0.76
Maximum:	1.1	1.5	2	0.79	0.39480	1.32
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/04/2024 00:00	0.8	1.4	0	0.46	0.22932	0.76
07/04/2024 01:00	0.8	1.4	-1	0.46	0.22920	0.76
07/04/2024 02:00	0.8	1.5	-1	0.46	0.22914	0.76
07/04/2024 03:00	0.8	1.4	0	0.46	0.22932	0.76
07/04/2024 04:00	0.8	1.4	0	0.46	0.22968	0.77
07/04/2024 05:00	0.8	1.4	0	0.46	0.22974	0.77
07/04/2024 06:00	0.8	1.4	0	0.46	0.22944	0.76
07/04/2024 07:00	0.8	1.3	-1	0.46	0.22920	0.76
07/04/2024 08:00	0.7	1.2	-1	0.46	0.22884	0.76
07/04/2024 09:00	0.7	1.3	-1	0.46	0.22866	0.76
07/04/2024 10:00	0.7	1.3	0	0.46	0.22830	0.76
07/04/2024 11:00	0.7	1.3	0	0.46	0.22830	0.76
07/04/2024 12:00	0.7	1.3	0	0.46	0.22788	0.76
07/04/2024 13:00	0.7	1.3	0	0.46	0.22764	0.76
07/04/2024 14:00	0.7	1.4	0	0.46	0.22770	0.76
07/04/2024 15:00	0.7	1.2	0	0.45	0.22734	0.76
07/04/2024 16:00	0.7	1.3	0	0.51	0.25668	0.86
07/04/2024 17:00	0.7	1.3	0	0.48	0.23874	0.80
07/04/2024 18:00	0.7	1.3	0	0.53	0.26292	0.88
07/04/2024 19:00	0.7	1.3	0	0.46	0.22830	0.76
07/04/2024 20:00	0.7	1.3	-1	0.46	0.22776	0.76
07/04/2024 21:00	0.7	1.3	-1	0.46	0.22788	0.76
07/04/2024 22:00	0.8	1.4	-1	0.46	0.22806	0.76
07/04/2024 23:00	0.7	1.4	0	0.46	0.22914	0.76
Average/Sum#:	0.7	1.3	0	0.47	0.23163	0.77
Minimum:	0.7	1.2	-1	0.45	0.22734	0.76
Maximum:	0.8	1.5	0	0.53	0.26292	0.88
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/05/2024 00:00	0.7	1.3	0	0.54	0.26892	0.90
07/05/2024 01:00	0.7	1.3	0	0.54	0.26862	0.90
07/05/2024 02:00	0.7	1.4	0	0.54	0.26838	0.89
07/05/2024 03:00	0.8	1.4	0	0.46	0.22914	0.76
07/05/2024 04:00	0.8	1.4	0	0.46	0.22914	0.76
07/05/2024 05:00	0.8	1.4	0	0.46	0.22914	0.76
07/05/2024 06:00	0.8	1.3	0	0.46	0.22890	0.76
07/05/2024 07:00	0.8	1.4	-1	0.46	0.22866	0.76
07/05/2024 08:00	0.7	1.3	-1	0.46	0.22818	0.76
07/05/2024 09:00	0.7	1.3	-1	0.46	0.22782	0.76
07/05/2024 10:00	0.8	1.3	-1	0.45	0.22740	0.76
07/05/2024 11:00	0.7	1.2	0	0.45	0.22722	0.76
07/05/2024 12:00	0.7	1.3	0	0.45	0.22698	0.76
07/05/2024 13:00	0.7	1.3	0	0.45	0.22680	0.76
07/05/2024 14:00	0.7	1.2	0	0.45	0.22662	0.76
07/05/2024 15:00	0.7	1.3	0	0.45	0.22662	0.76
07/05/2024 16:00	0.7	1.3	-1	0.45	0.22626	0.75
07/05/2024 17:00	0.9	1.3	0	0.53	0.26652	0.89
07/05/2024 18:00	0.2	1.5	1	0.76	0.38028	1.27
07/05/2024 19:00	0.5	1.4	0	0.67	0.33486	1.12
07/05/2024 20:00	0.7	1.3	0	0.52	0.25770	0.86
07/05/2024 21:00	0.7	1.3	0	0.46	0.22752	0.76
07/05/2024 22:00	0.7	1.3	0	0.46	0.22758	0.76
07/05/2024 23:00	0.8	1.3	-1	0.46	0.22782	0.76
Average/Sum#:	0.7	1.3	0	0.49	0.24655	0.82
Minimum:	0.2	1.2	-1	0.45	0.22626	0.75
Maximum:	0.9	1.5	1	0.76	0.38028	1.27
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/06/2024 00:00	0.8	1.3	-1	0.46	0.22812	0.76
07/06/2024 01:00	0.8	1.4	-1	0.46	0.22836	0.76
07/06/2024 02:00	0.8	1.5	-1	0.46	0.22842	0.76
07/06/2024 03:00	0.8	1.4	0	0.46	0.22854	0.76
07/06/2024 04:00	0.8	1.4	0	0.46	0.22902	0.76
07/06/2024 05:00	0.8	1.3	0	0.46	0.22932	0.76
07/06/2024 06:00	0.8	1.4	-1	0.46	0.22914	0.76
07/06/2024 07:00	0.8	1.4	-1	0.46	0.22866	0.76
07/06/2024 08:00	0.7	1.3	-1	0.46	0.22836	0.76
07/06/2024 09:00	0.7	1.3	-1	0.46	0.22794	0.76
07/06/2024 10:00	0.7	1.2	0	0.46	0.22782	0.76
07/06/2024 11:00	0.7	1.2	0	0.45	0.22746	0.76
07/06/2024 12:00	0.7	1.4	0	0.46	0.22878	0.76
07/06/2024 13:00	0.7	1.4	0	0.46	0.22890	0.76
07/06/2024 14:00	0.7	1.3	0	0.50	0.25050	0.84
07/06/2024 15:00	0.7	1.4	0	0.46	0.22920	0.76
07/06/2024 16:00	0.7	1.3	0	0.48	0.23892	0.80
07/06/2024 17:00	0.6	1.4	0	0.57	0.28512	0.95
07/06/2024 18:00	0.2	1.5	1	0.76	0.37824	1.26
07/06/2024 19:00	0.3	1.4	1	0.71	0.35394	1.18
07/06/2024 20:00	0.7	1.4	0	0.62	0.30984	1.03
07/06/2024 21:00	0.7	1.3	0	0.55	0.27558	0.92
07/06/2024 22:00	0.7	1.4	-1	0.54	0.27072	0.90
07/06/2024 23:00	0.8	1.3	0	0.47	0.23562	0.79
Average/Sum#:	0.7	1.4	0	0.50	0.25111	0.84
Minimum:	0.2	1.2	-1	0.45	0.22746	0.76
Maximum:	0.8	1.5	1	0.76	0.37824	1.26
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/07/2024 00:00	0.7	1.3	-1	0.46	0.22854	0.76
07/07/2024 01:00	0.8	1.4	-1	0.46	0.22860	0.76
07/07/2024 02:00	0.7	1.6	-1	0.46	0.22878	0.76
07/07/2024 03:00	0.8	1.4	0	0.46	0.22896	0.76
07/07/2024 04:00	0.7	1.4	0	0.46	0.22914	0.76
07/07/2024 05:00	0.7	1.4	0	0.46	0.22926	0.76
07/07/2024 06:00	0.7	1.4	-1	0.46	0.22926	0.76
07/07/2024 07:00	0.7	1.4	-1	0.46	0.22884	0.76
07/07/2024 08:00	0.7	1.4	0	0.46	0.22842	0.76
07/07/2024 09:00	0.7	1.2	-1	0.46	0.22824	0.76
07/07/2024 10:00	0.7	1.3	0	0.46	0.22818	0.76
07/07/2024 11:00	0.7	1.2	0	0.46	0.22794	0.76
07/07/2024 12:00	0.7	1.3	0	0.48	0.24000	0.80
07/07/2024 13:00	0.7	1.3	0	0.48	0.23850	0.80
07/07/2024 14:00	0.7	1.3	0	0.52	0.25752	0.86
07/07/2024 15:00	0.9	1.4	0	0.49	0.24558	0.82
07/07/2024 16:00	0.2	1.5	1	0.75	0.37602	1.25
07/07/2024 17:00	0.1	1.5	1	0.77	0.38376	1.28
07/07/2024 18:00	0.1	1.5	1	0.77	0.38262	1.28
07/07/2024 19:00	0.1	1.5	1	0.76	0.38106	1.27
07/07/2024 20:00	0.2	1.5	1	0.75	0.37734	1.26
07/07/2024 21:00	0.7	1.3	0	0.56	0.28188	0.94
07/07/2024 22:00	0.7	1.4	0	0.46	0.22908	0.76
07/07/2024 23:00	0.7	1.4	-1	0.46	0.22890	0.76
Average/Sum#:	0.6	1.4	0	0.53	0.26527	0.88
Minimum:	0.1	1.2	-1	0.46	0.22794	0.76
Maximum:	0.9	1.6	1	0.77	0.38376	1.28
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/08/2024 00:00	0.7	1.4	0	0.46	0.22902	0.76
07/08/2024 01:00	0.7	1.4	0	0.46	0.22920	0.76
07/08/2024 02:00	0.7	1.5	0	0.46	0.22938	0.76
07/08/2024 03:00	0.7	1.5	0	0.46	0.22950	0.77
07/08/2024 04:00	0.8	1.4	0	0.46	0.22962	0.77
07/08/2024 05:00	0.8	1.4	0	0.46	0.22956	0.77
07/08/2024 06:00	0.8	1.4	0	0.46	0.22968	0.77
07/08/2024 07:00	0.8	1.4	-1	0.46	0.22938	0.76
07/08/2024 08:00	0.7	1.4	-1	0.46	0.22920	0.76
07/08/2024 09:00	0.7	1.4	-1	0.46	0.22884	0.76
07/08/2024 10:00	0.7	1.3	0	0.46	0.22848	0.76
07/08/2024 11:00	0.7	1.4	0	0.46	0.22824	0.76
07/08/2024 12:00	0.7	1.4	0	0.46	0.23064	0.77
07/08/2024 13:00	0.7	1.3	0	0.47	0.23676	0.79
07/08/2024 14:00	0.7	1.3	0	0.55	0.27744	0.92
07/08/2024 15:00	0.7	1.4	0	0.51	0.25392	0.85
07/08/2024 16:00	0.6	1.4	0	0.60	0.30000	1.00
07/08/2024 17:00	0.1	1.5	1	0.78	0.38856	1.30
07/08/2024 18:00	0.1	1.5	1	0.78	0.39234	1.31
07/08/2024 19:00	0.1	1.5	1	0.76	0.38154	1.27
07/08/2024 20:00	0.2	1.5	1	0.76	0.37920	1.26
07/08/2024 21:00	0.3	1.5	1	0.74	0.37002	1.23
07/08/2024 22:00	0.3	1.5	1	0.74	0.36906	1.23
07/08/2024 23:00	0.5	1.5	1	0.70	0.35232	1.17
Average/Sum#:	0.6	1.4	0	0.56	0.27841	0.93
Minimum:	0.1	1.3	-1	0.46	0.22824	0.76
Maximum:	0.8	1.5	1	0.78	0.39234	1.31
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/09/2024 00:00	0.8	1.4	0	0.57	0.28314	0.94
07/09/2024 01:00	0.8	1.4	0	0.46	0.22986	0.77
07/09/2024 02:00	0.8	1.4	0	0.46	0.22992	0.77
07/09/2024 03:00	0.8	1.4	0	0.46	0.23016	0.77
07/09/2024 04:00	0.8	1.4	0	0.46	0.23172	0.77
07/09/2024 05:00	0.8	1.4	0	0.46	0.23016	0.77
07/09/2024 06:00	0.7	1.4	0	0.46	0.23016	0.77
07/09/2024 07:00	0.8	1.4	0	0.46	0.23004	0.77
07/09/2024 08:00	0.7	1.4	0	0.46	0.22980	0.77
07/09/2024 09:00	0.7	1.4	-1	0.46	0.22920	0.76
07/09/2024 10:00	0.7	1.3	-1	0.46	0.22878	0.76
07/09/2024 11:00	0.7	1.4	0	0.46	0.22854	0.76
07/09/2024 12:00	0.7	1.2	0	0.46	0.23106	0.77
07/09/2024 13:00	0.6	1.4	0	0.56	0.28158	0.94
07/09/2024 14:00	0.6	1.4	0	0.55	0.27270	0.91
07/09/2024 15:00	0.7	1.4	0	0.54	0.26880	0.90
07/09/2024 16:00	0.2	1.5	1	0.75	0.37632	1.25
07/09/2024 17:00	0.1	1.5	1	0.76	0.38208	1.27
07/09/2024 18:00	0.1	1.5	1	0.79	0.39336	1.31
07/09/2024 19:00	0.1	1.5	1	0.77	0.38316	1.28
07/09/2024 20:00	0.2	1.5	1	0.75	0.37590	1.25
07/09/2024 21:00	0.2	1.5	1	0.75	0.37626	1.25
07/09/2024 22:00	0.2	1.5	1	0.75	0.37254	1.24
07/09/2024 23:00	0.8	1.4	0	0.62	0.31182	1.04
Average/Sum#:	0.6	1.4	0	0.57	0.28488	0.95
Minimum:	0.1	1.2	-1	0.46	0.22854	0.76
Maximum:	0.8	1.5	1	0.79	0.39336	1.31
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/10/2024 00:00	0.6	1.4	0	0.56	0.28146	0.94
07/10/2024 01:00	0.7	1.3	0	0.56	0.27822	0.93
07/10/2024 02:00	0.7	1.3	0	0.57	0.28434	0.95
07/10/2024 03:00	0.7	1.4	0	0.55	0.27684	0.92
07/10/2024 04:00	0.7	1.3	0	0.57	0.28488	0.95
07/10/2024 05:00	0.7	1.4	0	0.53	0.26370	0.88
07/10/2024 06:00	0.8	1.4	0	0.46	0.23148	0.77
07/10/2024 07:00	0.8	1.4	-1	0.46	0.23148	0.77
07/10/2024 08:00	0.8	1.3	-1	0.46	0.23094	0.77
07/10/2024 09:00	0.7	1.4	-1	0.46	0.22956	0.77
07/10/2024 10:00	0.7	1.3	0	0.46	0.22926	0.76
07/10/2024 11:00	0.7	1.2	0	0.46	0.22902	0.76
07/10/2024 12:00	0.7	1.3	0	0.46	0.22824	0.76
07/10/2024 13:00	0.7	1.3	0	0.50	0.25212	0.84
07/10/2024 14:00	0.7	1.3	0	0.54	0.26796	0.89
07/10/2024 15:00	0.7	1.3	0	0.50	0.24924	0.83
07/10/2024 16:00	0.7	1.2	0	0.51	0.25266	0.84
07/10/2024 17:00	0.4	1.5	1	0.73	0.36534	1.22
07/10/2024 18:00	0.1	1.5	1	0.78	0.38958	1.30
07/10/2024 19:00	0.1	1.5	1	0.77	0.38730	1.29
07/10/2024 20:00	0.2	1.5	1	0.75	0.37338	1.24
07/10/2024 21:00	0.5	1.4	0	0.69	0.34596	1.15
07/10/2024 22:00	0.7	1.4	0	0.62	0.30858	1.03
07/10/2024 23:00	0.8	1.4	0	0.51	0.25638	0.85
Average/Sum#:	0.6	1.4	0	0.56	0.28033	0.93
Minimum:	0.1	1.2	-1	0.46	0.22824	0.76
Maximum:	0.8	1.5	1	0.78	0.38958	1.30
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/11/2024 00:00	0.8	1.4	0	0.46	0.23046	0.77
07/11/2024 01:00	0.8	1.4	0	0.46	0.22992	0.77
07/11/2024 02:00	0.7	1.5	0	0.46	0.22992	0.77
07/11/2024 03:00	0.8	1.3	0	0.46	0.22998	0.77
07/11/2024 04:00	0.8	1.4	0	0.46	0.23010	0.77
07/11/2024 05:00	0.8	1.4	0	0.46	0.23034	0.77
07/11/2024 06:00	0.9	1.3	0	0.46	0.23058	0.77
07/11/2024 07:00	0.8	1.4	0	0.46	0.23046	0.77
07/11/2024 08:00	0.8	1.4	0	0.46	0.23058	0.77
07/11/2024 09:00	0.8	1.3	0	0.46	0.23016	0.77
07/11/2024 10:00	0.8	1.3	0	0.46	0.22992	0.77
07/11/2024 11:00	0.7	1.3	0	0.46	0.22842	0.76
07/11/2024 12:00	0.7	1.3	0	0.49	0.24438	0.81
07/11/2024 13:00	0.7	1.3	0	0.56	0.27822	0.93
07/11/2024 14:00	0.4	1.5	1	0.74	0.36816	1.23
07/11/2024 15:00	0.2	1.5	1	0.77	0.38694	1.29
07/11/2024 16:00	0.1	1.5	1	0.77	0.38532	1.28
07/11/2024 17:00	0.1	1.5	1	0.77	0.38730	1.29
07/11/2024 18:00	0.1	1.5	1	0.77	0.38718	1.29
07/11/2024 19:00	0.1	1.5	1	0.77	0.38628	1.29
07/11/2024 20:00	0.2	1.5	1	0.77	0.38550	1.29
07/11/2024 21:00	0.1	1.5	1	0.77	0.38472	1.28
07/11/2024 22:00	0.5	1.4	0	0.66	0.33174	1.11
07/11/2024 23:00	0.7	1.3	0	0.55	0.27744	0.92
Average/Sum#:	0.6	1.4	0	0.58	0.29017	0.97
Minimum:	0.1	1.3	0	0.46	0.22842	0.76
Maximum:	0.9	1.5	1	0.77	0.38730	1.29
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/12/2024 00:00	0.7	1.3	0	0.48	0.24024	0.80
07/12/2024 01:00	0.8	1.4	0	0.46	0.22992	0.77
07/12/2024 02:00	0.7	1.5	-1	0.46	0.23004	0.77
07/12/2024 03:00	0.8	1.4	0	0.46	0.23034	0.77
07/12/2024 04:00	0.8	1.3	-1	0.46	0.23052	0.77
07/12/2024 05:00	0.8	1.4	-1	0.46	0.23094	0.77
07/12/2024 06:00	0.8	1.4	0	0.48	0.24198	0.81
07/12/2024 07:00	0.8	1.4	0	0.46	0.23064	0.77
07/12/2024 08:00	0.7	1.4	0	0.46	0.23052	0.77
07/12/2024 09:00	0.7	1.3	0	0.46	0.22950	0.77
07/12/2024 10:00	0.7	1.4	0	0.46	0.22914	0.76
07/12/2024 11:00	0.7	1.3	0	0.51	0.25416	0.85
07/12/2024 12:00	0.7	1.3	0	0.55	0.27546	0.92
07/12/2024 13:00	0.6	1.3	0	0.55	0.27600	0.92
07/12/2024 14:00	0.6	1.3	0	0.59	0.29334	0.98
07/12/2024 15:00	0.6	1.4	0	0.66	0.32868	1.10
07/12/2024 16:00	0.4	1.4	1	0.69	0.34476	1.15
07/12/2024 17:00	0.1	1.5	2	0.78	0.38844	1.29
07/12/2024 18:00	0.1	1.5	1	0.77	0.38748	1.29
07/12/2024 19:00	0.2	1.5	1	0.74	0.36966	1.23
07/12/2024 20:00	0.3	1.5	1	0.72	0.36144	1.20
07/12/2024 21:00	0.6	1.3	0	0.55	0.27438	0.91
07/12/2024 22:00	0.6	1.4	0	0.55	0.27312	0.91
07/12/2024 23:00	0.8	1.3	0	0.47	0.23544	0.78
Average/Sum#:	0.6	1.4	0	0.55	0.27567	0.92
Minimum:	0.1	1.3	-1	0.46	0.22914	0.76
Maximum:	0.8	1.5	2	0.78	0.38844	1.29
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/13/2024 00:00	0.7	1.4	-1	0.46	0.22860	0.76
07/13/2024 01:00	0.7	1.3	-1	0.46	0.22752	0.76
07/13/2024 02:00	0.7	1.4	0	0.46	0.23142	0.77
07/13/2024 03:00	0.8	1.4	0	0.47	0.23286	0.78
07/13/2024 04:00	0.7	1.4	0	0.45	0.22698	0.76
07/13/2024 05:00	0.7	1.4	0	0.45	0.22722	0.76
07/13/2024 06:00	0.7	1.4	0	0.45	0.22704	0.76
07/13/2024 07:00	0.7	1.4	0	0.45	0.22698	0.76
07/13/2024 08:00	0.7	1.4	0	0.52	0.25800	0.86
07/13/2024 09:00	0.7	1.3	0	0.48	0.24222	0.81
07/13/2024 10:00	0.7	1.4	0	0.46	0.22950	0.77
07/13/2024 11:00	0.7	1.4	0	0.46	0.22884	0.76
07/13/2024 12:00	0.7	1.3	-1	0.46	0.22848	0.76
07/13/2024 13:00	0.7	1.3	-1	0.46	0.22884	0.76
07/13/2024 14:00	0.7	1.3	0	0.46	0.22962	0.77
07/13/2024 15:00	0.7	1.3	0	0.46	0.23082	0.77
07/13/2024 16:00	0.7	1.3	0	0.47	0.23490	0.78
07/13/2024 17:00	0.9	1.4	0	0.49	0.24528	0.82
07/13/2024 18:00	0.7	1.3	0	0.54	0.27240	0.91
07/13/2024 19:00	0.7	1.4	0	0.47	0.23322	0.78
07/13/2024 20:00	0.7	1.4	0	0.48	0.24150	0.81
07/13/2024 21:00	0.7	1.4	0	0.47	0.23436	0.78
07/13/2024 22:00	0.7	1.4	0	0.47	0.23316	0.78
07/13/2024 23:00	0.7	1.4	0	0.46	0.23196	0.77
Average/Sum#:	0.7	1.4	0	0.47	0.23466	0.78
Minimum:	0.7	1.3	-1	0.45	0.22698	0.76
Maximum:	0.9	1.4	0	0.54	0.27240	0.91
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/14/2024 00:00	0.7	1.4	0	0.46	0.23142	0.77
07/14/2024 01:00	0.7	1.4	0	0.46	0.23112	0.77
07/14/2024 02:00	0.7	1.4	0	0.46	0.23022	0.77
07/14/2024 03:00	0.7	1.4	0	0.46	0.22908	0.76
07/14/2024 04:00	0.7	1.4	0	0.46	0.22914	0.76
07/14/2024 05:00	0.7	1.4	0	0.46	0.22932	0.76
07/14/2024 06:00	0.7	1.4	0	0.46	0.22938	0.76
07/14/2024 07:00	0.7	1.4	0	0.46	0.22944	0.76
07/14/2024 08:00	0.7	1.4	0	0.46	0.22938	0.76
07/14/2024 09:00	0.7	1.4	0	0.46	0.22944	0.76
07/14/2024 10:00	0.7	1.4	0	0.46	0.22902	0.76
07/14/2024 11:00	0.7	1.4	0	0.46	0.22866	0.76
07/14/2024 12:00	0.7	1.3	-1	0.46	0.22836	0.76
07/14/2024 13:00	0.7	1.3	-1	0.46	0.22812	0.76
07/14/2024 14:00	0.7	1.3	0	0.48	0.23892	0.80
07/14/2024 15:00	0.7	1.3	0	0.46	0.23244	0.77
07/14/2024 16:00	0.7	1.4	0	0.46	0.23016	0.77
07/14/2024 17:00	0.7	1.3	0	0.47	0.23502	0.78
07/14/2024 18:00	0.7	1.3	0	0.49	0.24732	0.82
07/14/2024 19:00	0.9	1.3	0	0.49	0.24600	0.82
07/14/2024 20:00	0.7	1.4	0	0.49	0.24552	0.82
07/14/2024 21:00	0.7	1.4	0	0.51	0.25716	0.86
07/14/2024 22:00	0.7	1.3	-1	0.46	0.22980	0.77
07/14/2024 23:00	0.7	1.4	0	0.46	0.22938	0.76
Average/Sum#:	0.7	1.4	0	0.47	0.23349	0.78
Minimum:	0.7	1.3	-1	0.46	0.22812	0.76
Maximum:	0.9	1.4	0	0.51	0.25716	0.86
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/15/2024 00:00	0.7	1.4	0	0.46	0.22950	0.77
07/15/2024 01:00	0.7	1.4	0	0.46	0.22950	0.77
07/15/2024 02:00	0.8	1.4	0	0.46	0.22944	0.76
07/15/2024 03:00	0.7	1.4	0	0.49	0.24378	0.81
07/15/2024 04:00	0.7	1.4	0	0.46	0.22962	0.77
07/15/2024 05:00	0.7	1.4	0	0.46	0.22950	0.77
07/15/2024 06:00	0.7	1.4	0	0.46	0.22968	0.77
07/15/2024 07:00	0.7	1.4	0	0.46	0.22938	0.76
07/15/2024 08:00	0.7	1.4	0	0.46	0.22974	0.77
07/15/2024 09:00	0.7	1.4	0	0.46	0.22950	0.77
07/15/2024 10:00	0.7	1.3	0	0.46	0.22944	0.76
07/15/2024 11:00	0.7	1.4	-1	0.46	0.22914	0.76
07/15/2024 12:00	0.7	1.3	-1	0.46	0.22902	0.76
07/15/2024 13:00	0.7	1.3	-1	0.46	0.22902	0.76
07/15/2024 14:00	0.7	1.3	-1	0.46	0.22890	0.76
07/15/2024 15:00	0.7	1.3	-1	0.47	0.23382	0.78
07/15/2024 16:00	0.7	1.3	-1	0.46	0.22944	0.76
07/15/2024 17:00	0.7	1.3	-1	0.46	0.22986	0.77
07/15/2024 18:00	0.7	1.3	-1	0.46	0.22962	0.77
07/15/2024 19:00	0.7	1.4	0	0.46	0.23100	0.77
07/15/2024 20:00	0.7	1.4	0	0.46	0.23028	0.77
07/15/2024 21:00	0.7	1.3	0	0.46	0.23004	0.77
07/15/2024 22:00	0.7	1.4	0	0.46	0.22980	0.77
07/15/2024 23:00	0.7	1.4	0	0.46	0.22992	0.77
Average/Sum#:	0.7	1.4	0	0.46	0.23037	0.77
Minimum:	0.7	1.3	-1	0.46	0.22890	0.76
Maximum:	0.8	1.4	0	0.49	0.24378	0.81
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/16/2024 00:00	0.7	1.4	0	0.46	0.22980	0.77
07/16/2024 01:00	0.7	1.4	0	0.46	0.22974	0.77
07/16/2024 02:00	0.7	1.5	0	0.46	0.22998	0.77
07/16/2024 03:00	0.8	1.4	0	0.46	0.23004	0.77
07/16/2024 04:00	0.7	1.4	0	0.49	0.24648	0.82
07/16/2024 05:00	0.7	1.4	0	0.53	0.26466	0.88
07/16/2024 06:00	0.8	1.4	0	0.46	0.23028	0.77
07/16/2024 07:00	0.8	1.4	0	0.46	0.23028	0.77
07/16/2024 08:00	0.8	1.4	0	0.46	0.22986	0.77
07/16/2024 09:00	0.7	1.4	0	0.46	0.22962	0.77
07/16/2024 10:00	0.7	1.4	-1	0.46	0.22914	0.76
07/16/2024 11:00	0.7	1.4	-1	0.46	0.22872	0.76
07/16/2024 12:00	0.7	0.0	-1	0.46	0.22848	0.76
07/16/2024 13:00	0.7	0.0	-1	0.46	0.22800	0.76
07/16/2024 14:00	0.7	0.3	-1	0.47	0.23724	0.79
07/16/2024 15:00	0.7	1.3	0	0.54	0.27186	0.91
07/16/2024 16:00	0.7	1.3	-1	0.46	0.22770	0.76
07/16/2024 17:00	0.8	1.4	0	0.56	0.27786	0.93
07/16/2024 18:00	0.8	1.4	0	0.67	0.33438	1.11
07/16/2024 19:00	0.9	1.4	0	0.65	0.32454	1.08
07/16/2024 20:00	0.7	1.4	0	0.63	0.31452	1.05
07/16/2024 21:00	0.6	1.5	0	0.54	0.27120	0.90
07/16/2024 22:00	0.7	1.3	0	0.50	0.25026	0.83
07/16/2024 23:00	0.8	1.4	0	0.46	0.23022	0.77
Average/Sum#:	0.7	1.3	0	0.50	0.25020	0.83
Minimum:	0.6	0.3	-1	0.46	0.22770	0.76
Maximum:	0.9	1.5	0	0.67	0.33438	1.11
%SI	0.00	8.33	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/17/2024 00:00	0.8	1.4	0	0.46	0.23064	0.77
07/17/2024 01:00	0.8	1.4	0	0.46	0.23082	0.77
07/17/2024 02:00	0.8	1.3	0	0.46	0.23076	0.77
07/17/2024 03:00	0.8	1.4	0	0.46	0.23082	0.77
07/17/2024 04:00	0.8	1.4	0	0.46	0.23226	0.77
07/17/2024 05:00	0.7	1.3	0	0.50	0.25248	0.84
07/17/2024 06:00	0.8	1.4	0	0.46	0.23070	0.77
07/17/2024 07:00	0.8	1.4	0	0.46	0.23058	0.77
07/17/2024 08:00	0.7	1.4	0	0.46	0.23022	0.77
07/17/2024 09:00	0.8	1.4	0	0.46	0.22998	0.77
07/17/2024 10:00	0.7	1.4	0	0.46	0.22956	0.77
07/17/2024 11:00	0.7	1.4	-1	0.46	0.22890	0.76
07/17/2024 12:00	0.7	1.4	-1	0.46	0.22872	0.76
07/17/2024 13:00	0.7	1.4	-1	0.46	0.22836	0.76
07/17/2024 14:00	0.7	1.3	0	0.46	0.22782	0.76
07/17/2024 15:00	0.7	1.3	-1	0.46	0.22770	0.76
07/17/2024 16:00	0.7	1.2	-1	0.46	0.22758	0.76
07/17/2024 17:00	0.7	1.3	0	0.50	0.24894	0.83
07/17/2024 18:00	0.7	1.2	0	0.51	0.25314	0.84
07/17/2024 19:00	0.6	1.3	0	0.56	0.28050	0.94
07/17/2024 20:00	0.7	1.4	0	0.58	0.28782	0.96
07/17/2024 21:00	0.6	1.3	0	0.58	0.28764	0.96
07/17/2024 22:00	0.7	1.4	0	0.52	0.25872	0.86
07/17/2024 23:00	0.8	1.4	-1	0.46	0.23016	0.77
Average/Sum#:	0.7	1.4	0	0.48	0.24062	0.80
Minimum:	0.6	1.2	-1	0.46	0.22758	0.76
Maximum:	0.8	1.4	0	0.58	0.28782	0.96
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/18/2024 00:00	0.7	1.4	0	0.46	0.22962	0.77
07/18/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
07/18/2024 02:00	0.7	1.4	0	0.46	0.22938	0.76
07/18/2024 03:00	0.0	1.4	0	0.46	0.23064	0.77
07/18/2024 04:00	0.9	1.3	1	0.46	0.23040	0.77
07/18/2024 05:00	0.8	1.4	0	0.46	0.23034	0.77
07/18/2024 06:00	0.9	1.4	0	0.46	0.23028	0.77
07/18/2024 07:00	0.8	1.4	-1	0.46	0.22992	0.77
07/18/2024 08:00	0.9	1.4	-1	0.46	0.22956	0.77
07/18/2024 09:00	0.8	1.4	-1	0.46	0.22902	0.76
07/18/2024 10:00	0.7	1.4	-1	0.46	0.22866	0.76
07/18/2024 11:00	0.7	1.3	0	0.48	0.24102	0.80
07/18/2024 12:00	0.7	1.2	0	0.51	0.25302	0.84
07/18/2024 13:00	0.7	1.3	0	0.50	0.25188	0.84
07/18/2024 14:00	0.6	1.3	0	0.55	0.27516	0.92
07/18/2024 15:00	0.6	1.4	0	0.44	0.21882	0.73
07/18/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
07/18/2024 17:00	0.0	1.5	0	0.00	0.00000	0.00
07/18/2024 18:00	0.0	1.5	0	0.00	0.00000	0.00
07/18/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
07/18/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
07/18/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
07/18/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
07/18/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.8	1.4	0	0.47	0.23585	0.79
Minimum:	0.6	1.2	-1	0.44	0.21882	0.73
Maximum:	0.9	1.5	1	0.55	0.27516	0.92
%SI	41.67	0.00	37.50	37.50	37.50	37.50

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/19/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
07/19/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
07/19/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
07/19/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
07/19/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
07/19/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
07/19/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
07/19/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
07/19/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
07/19/2024 09:00	0.0	1.3	0	0.00	0.00000	0.00
07/19/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
07/19/2024 11:00	0.0	1.3	0	0.00	0.00000	0.00
07/19/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
07/19/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
07/19/2024 14:00	0.0	1.5	0	0.00	0.00000	0.00
07/19/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
07/19/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
07/19/2024 17:00	0.0	1.5	0	0.00	0.00000	0.00
07/19/2024 18:00	0.0	1.5	0	0.00	0.00000	0.00
07/19/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
07/19/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
07/19/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
07/19/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
07/19/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/20/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
07/20/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
07/20/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
07/20/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
07/20/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
07/20/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
07/20/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
07/20/2024 07:00	0.0	1.3	0	0.28	0.13932	0.46
07/20/2024 08:00	0.8	1.4	0	0.47	0.23538	0.78
07/20/2024 09:00	0.7	1.4	0	0.46	0.22842	0.76
07/20/2024 10:00	0.7	1.4	-1	0.46	0.22818	0.76
07/20/2024 11:00	0.8	1.3	-1	0.47	0.23742	0.79
07/20/2024 12:00	0.7	1.3	0	0.49	0.24690	0.82
07/20/2024 13:00	0.7	1.3	0	0.55	0.27534	0.92
07/20/2024 14:00	0.6	1.4	0	0.57	0.28494	0.95
07/20/2024 15:00	0.5	1.4	0	0.66	0.33150	1.11
07/20/2024 16:00	0.5	1.4	0	0.66	0.33198	1.11
07/20/2024 17:00	0.3	1.5	1	0.72	0.36018	1.20
07/20/2024 18:00	0.1	1.5	1	0.76	0.37860	1.26
07/20/2024 19:00	0.1	1.5	1	0.75	0.37692	1.26
07/20/2024 20:00	0.2	1.5	1	0.75	0.37662	1.26
07/20/2024 21:00	0.2	1.5	1	0.75	0.37518	1.25
07/20/2024 22:00	0.2	1.5	1	0.75	0.37380	1.25
07/20/2024 23:00	0.3	1.5	1	0.74	0.36978	1.23
Average/Sum#:	0.4	1.4	0	0.61	0.30297	1.01
Minimum:	0.0	1.3	-1	0.28	0.13932	0.46
Maximum:	0.8	1.5	1	0.76	0.37860	1.26
%SI	29.17	0.00	33.33	29.17	29.17	29.17

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/21/2024 00:00	0.9	1.4	0	0.58	0.29064	0.97
07/21/2024 01:00	0.7	1.4	0	0.46	0.22986	0.77
07/21/2024 02:00	0.7	1.3	0	0.46	0.22986	0.77
07/21/2024 03:00	0.7	1.5	0	0.46	0.23016	0.77
07/21/2024 04:00	0.7	1.4	0	0.46	0.23022	0.77
07/21/2024 05:00	0.7	1.4	0	0.46	0.23070	0.77
07/21/2024 06:00	0.7	0.0	0	0.46	0.23046	0.77
07/21/2024 07:00	0.7	1.5	0	0.46	0.23052	0.77
07/21/2024 08:00	0.7	1.4	0	0.46	0.23022	0.77
07/21/2024 09:00	0.7	1.4	0	0.46	0.22992	0.77
07/21/2024 10:00	0.7	1.4	0	0.46	0.22956	0.77
07/21/2024 11:00	0.7	1.4	-1	0.46	0.22908	0.76
07/21/2024 12:00	0.7	1.3	-1	0.46	0.22872	0.76
07/21/2024 13:00	0.7	1.4	-1	0.46	0.22848	0.76
07/21/2024 14:00	0.7	1.3	-1	0.46	0.22818	0.76
07/21/2024 15:00	0.7	1.3	0	0.46	0.22812	0.76
07/21/2024 16:00	0.7	1.3	0	0.46	0.22794	0.76
07/21/2024 17:00	0.7	1.2	0	0.50	0.25218	0.84
07/21/2024 18:00	0.6	1.3	0	0.55	0.27606	0.92
07/21/2024 19:00	0.7	1.4	0	0.54	0.26970	0.90
07/21/2024 20:00	0.7	1.4	0	0.55	0.27282	0.91
07/21/2024 21:00	0.7	1.4	0	0.55	0.27468	0.92
07/21/2024 22:00	0.7	1.3	0	0.49	0.24558	0.82
07/21/2024 23:00	0.7	1.3	0	0.52	0.26232	0.87
Average/Sum#:	0.7	1.4	0	0.49	0.24233	0.81
Minimum:	0.6	1.2	-1	0.46	0.22794	0.76
Maximum:	0.9	1.5	0	0.58	0.29064	0.97
%SI	0.00	4.17	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/22/2024 00:00	0.7	1.4	0	0.50	0.24930	0.83
07/22/2024 01:00	0.8	1.4	0	0.46	0.22968	0.77
07/22/2024 02:00	0.7	1.6	0	0.55	0.27570	0.92
07/22/2024 03:00	0.7	1.3	0	0.55	0.27480	0.92
07/22/2024 04:00	0.7	1.4	0	0.57	0.28446	0.95
07/22/2024 05:00	0.7	1.4	0	0.54	0.26778	0.89
07/22/2024 06:00	0.8	1.4	0	0.46	0.23022	0.77
07/22/2024 07:00	0.7	1.4	0	0.46	0.22968	0.77
07/22/2024 08:00	0.7	1.4	-1	0.46	0.22926	0.76
07/22/2024 09:00	0.7	1.4	-1	0.46	0.22914	0.76
07/22/2024 10:00	0.7	1.3	0	0.46	0.22854	0.76
07/22/2024 11:00	0.7	1.2	0	0.49	0.24282	0.81
07/22/2024 12:00	0.7	1.4	0	0.55	0.27384	0.91
07/22/2024 13:00	0.7	1.3	0	0.55	0.27606	0.92
07/22/2024 14:00	0.7	1.3	0	0.55	0.27630	0.92
07/22/2024 15:00	0.1	1.5	2	0.73	0.36606	1.22
07/22/2024 16:00	0.1	1.5	1	0.77	0.38286	1.28
07/22/2024 17:00	0.1	1.5	1	0.77	0.38700	1.29
07/22/2024 18:00	0.1	1.5	1	0.76	0.38154	1.27
07/22/2024 19:00	0.1	1.5	1	0.76	0.37914	1.26
07/22/2024 20:00	0.4	1.5	0	0.70	0.35058	1.17
07/22/2024 21:00	0.4	1.4	0	0.69	0.34710	1.16
07/22/2024 22:00	0.7	1.3	0	0.58	0.29184	0.97
07/22/2024 23:00	0.7	1.3	0	0.55	0.27708	0.92
Average/Sum#:	0.6	1.4	0	0.58	0.29003	0.97
Minimum:	0.1	1.2	-1	0.46	0.22854	0.76
Maximum:	0.8	1.6	2	0.77	0.38700	1.29
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/23/2024 00:00	0.7	1.3	0	0.54	0.26832	0.89
07/23/2024 01:00	0.7	1.3	0	0.55	0.27444	0.91
07/23/2024 02:00	0.7	1.5	0	0.53	0.26556	0.89
07/23/2024 03:00	0.8	1.4	0	0.52	0.26196	0.87
07/23/2024 04:00	0.3	1.5	1	0.74	0.37014	1.23
07/23/2024 05:00	0.2	1.5	1	0.75	0.37686	1.26
07/23/2024 06:00	0.2	1.5	1	0.75	0.37296	1.24
07/23/2024 07:00	0.2	1.5	1	0.75	0.37416	1.25
07/23/2024 08:00	0.2	1.5	1	0.75	0.37542	1.25
07/23/2024 09:00	0.2	1.5	1	0.75	0.37602	1.25
07/23/2024 10:00	0.2	1.5	1	0.75	0.37542	1.25
07/23/2024 11:00	0.1	1.5	1	0.75	0.37632	1.25
07/23/2024 12:00	0.2	1.5	1	0.77	0.38466	1.28
07/23/2024 13:00	0.1	1.5	2	0.78	0.39198	1.31
07/23/2024 14:00	0.2	1.5	2	0.78	0.39162	1.31
07/23/2024 15:00	0.1	1.5	2	0.78	0.39066	1.30
07/23/2024 16:00	0.1	1.5	2	0.78	0.38988	1.30
07/23/2024 17:00	0.1	1.5	2	0.78	0.39066	1.30
07/23/2024 18:00	0.1	1.5	2	0.78	0.38958	1.30
07/23/2024 19:00	0.1	1.5	1	0.77	0.38670	1.29
07/23/2024 20:00	0.1	1.5	1	0.77	0.38532	1.28
07/23/2024 21:00	0.1	1.5	1	0.77	0.38490	1.28
07/23/2024 22:00	0.1	1.5	1	0.77	0.38580	1.29
07/23/2024 23:00	0.2	1.5	1	0.75	0.37578	1.25
Average/Sum#:	0.3	1.5	1	0.73	0.36313	1.21
Minimum:	0.1	1.3	0	0.52	0.26196	0.87
Maximum:	0.8	1.5	2	0.78	0.39198	1.31
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/24/2024 00:00	0.7	1.4	0	0.66	0.32790	1.09
07/24/2024 01:00	0.8	1.4	0	0.52	0.25914	0.86
07/24/2024 02:00	0.7	1.3	0	0.46	0.23082	0.77
07/24/2024 03:00	0.7	1.4	-1	0.48	0.24150	0.81
07/24/2024 04:00	0.7	1.4	1	0.64	0.32166	1.07
07/24/2024 05:00	0.5	1.5	0	0.70	0.35220	1.17
07/24/2024 06:00	0.8	1.4	0	0.50	0.25074	0.84
07/24/2024 07:00	0.7	1.4	0	0.52	0.25848	0.86
07/24/2024 08:00	0.7	1.3	0	0.47	0.23466	0.78
07/24/2024 09:00	0.7	1.3	0	0.54	0.27204	0.91
07/24/2024 10:00	0.7	1.4	0	0.56	0.27810	0.93
07/24/2024 11:00	0.3	1.5	1	0.71	0.35484	1.18
07/24/2024 12:00	0.1	1.5	1	0.77	0.38478	1.28
07/24/2024 13:00	0.1	1.5	1	0.77	0.38466	1.28
07/24/2024 14:00	0.1	1.5	1	0.78	0.38916	1.30
07/24/2024 15:00	0.1	1.5	2	0.78	0.38988	1.30
07/24/2024 16:00	0.1	1.5	1	0.78	0.38904	1.30
07/24/2024 17:00	0.1	1.5	2	0.79	0.39570	1.32
07/24/2024 18:00	0.1	1.5	1	0.79	0.39438	1.31
07/24/2024 19:00	0.1	1.5	1	0.78	0.39132	1.30
07/24/2024 20:00	0.1	1.5	1	0.78	0.39048	1.30
07/24/2024 21:00	0.2	1.5	1	0.78	0.38802	1.29
07/24/2024 22:00	0.6	1.4	0	0.68	0.33876	1.13
07/24/2024 23:00	0.7	1.4	0	0.63	0.31494	1.05
Average/Sum#:	0.4	1.4	1	0.66	0.33055	1.10
Minimum:	0.1	1.3	-1	0.46	0.23082	0.77
Maximum:	0.8	1.5	2	0.79	0.39570	1.32
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/25/2024 00:00	0.7	1.4	0	0.54	0.26874	0.90
07/25/2024 01:00	0.7	1.4	0	0.50	0.24762	0.83
07/25/2024 02:00	0.7	1.5	0	0.46	0.22938	0.76
07/25/2024 03:00	0.7	1.4	0	0.46	0.22950	0.77
07/25/2024 04:00	0.7	1.3	0	0.49	0.24678	0.82
07/25/2024 05:00	0.7	1.3	0	0.54	0.26982	0.90
07/25/2024 06:00	0.7	1.3	0	0.49	0.24270	0.81
07/25/2024 07:00	0.7	1.4	0	0.46	0.22956	0.77
07/25/2024 08:00	0.7	1.4	0	0.46	0.22944	0.76
07/25/2024 09:00	0.7	1.4	-1	0.46	0.23076	0.77
07/25/2024 10:00	0.7	1.4	-1	0.46	0.23070	0.77
07/25/2024 11:00	0.7	1.4	0	0.46	0.23052	0.77
07/25/2024 12:00	0.6	1.3	0	0.52	0.25944	0.86
07/25/2024 13:00	0.6	1.5	0	0.67	0.33294	1.11
07/25/2024 14:00	0.3	1.5	0	0.73	0.36612	1.22
07/25/2024 15:00	0.2	1.4	1	0.74	0.36840	1.23
07/25/2024 16:00	0.2	1.5	1	0.74	0.36888	1.23
07/25/2024 17:00	0.2	1.5	1	0.76	0.37980	1.27
07/25/2024 18:00	0.1	1.5	1	0.77	0.38658	1.29
07/25/2024 19:00	0.1	1.5	1	0.77	0.38400	1.28
07/25/2024 20:00	0.2	1.5	1	0.77	0.38310	1.28
07/25/2024 21:00	0.6	1.4	0	0.65	0.32490	1.08
07/25/2024 22:00	0.6	1.4	0	0.52	0.26226	0.87
07/25/2024 23:00	0.7	1.4	0	0.46	0.22944	0.76
Average/Sum#:	0.5	1.4	0	0.58	0.28881	0.96
Minimum:	0.1	1.3	-1	0.46	0.22938	0.76
Maximum:	0.7	1.5	1	0.77	0.38658	1.29
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/26/2024 00:00	0.7	1.4	0	0.46	0.22920	0.76
07/26/2024 01:00	0.7	1.4	0	0.46	0.22914	0.76
07/26/2024 02:00	0.7	1.5	0	0.46	0.22926	0.76
07/26/2024 03:00	0.8	1.4	0	0.46	0.22926	0.76
07/26/2024 04:00	0.7	1.4	0	0.46	0.22938	0.76
07/26/2024 05:00	0.7	1.4	0	0.46	0.22926	0.76
07/26/2024 06:00	0.7	1.4	0	0.46	0.22890	0.76
07/26/2024 07:00	0.7	1.4	0	0.46	0.22848	0.76
07/26/2024 08:00	0.7	1.4	0	0.46	0.22824	0.76
07/26/2024 09:00	0.7	1.4	0	0.46	0.22800	0.76
07/26/2024 10:00	0.7	1.3	0	0.46	0.22794	0.76
07/26/2024 11:00	0.7	1.4	-1	0.46	0.22776	0.76
07/26/2024 12:00	0.7	1.3	-1	0.46	0.22812	0.76
07/26/2024 13:00	0.7	1.4	-1	0.46	0.22800	0.76
07/26/2024 14:00	0.7	1.3	-1	0.46	0.22866	0.76
07/26/2024 15:00	0.7	1.3	-1	0.46	0.22860	0.76
07/26/2024 16:00	0.7	1.3	-1	0.46	0.22854	0.76
07/26/2024 17:00	0.7	1.3	-1	0.47	0.23520	0.78
07/26/2024 18:00	0.7	1.4	0	0.57	0.28464	0.95
07/26/2024 19:00	0.6	1.3	0	0.55	0.27612	0.92
07/26/2024 20:00	0.7	1.4	0	0.51	0.25542	0.85
07/26/2024 21:00	0.7	1.4	0	0.46	0.22902	0.76
07/26/2024 22:00	0.7	1.4	0	0.46	0.22956	0.77
07/26/2024 23:00	0.7	1.4	0	0.46	0.22998	0.77
Average/Sum#:	0.7	1.4	0	0.47	0.23445	0.78
Minimum:	0.6	1.3	-1	0.46	0.22776	0.76
Maximum:	0.8	1.5	0	0.57	0.28464	0.95
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/27/2024 00:00	0.7	1.4	0	0.46	0.23022	0.77
07/27/2024 01:00	0.7	1.4	0	0.46	0.23070	0.77
07/27/2024 02:00	0.8	1.4	0	0.46	0.23076	0.77
07/27/2024 03:00	0.8	1.5	0	0.46	0.23082	0.77
07/27/2024 04:00	0.8	1.4	0	0.46	0.23106	0.77
07/27/2024 05:00	0.8	1.4	0	0.46	0.23124	0.77
07/27/2024 06:00	0.8	1.4	0	0.46	0.23130	0.77
07/27/2024 07:00	0.7	1.4	0	0.46	0.23100	0.77
07/27/2024 08:00	0.8	1.4	0	0.46	0.23070	0.77
07/27/2024 09:00	0.7	1.4	0	0.46	0.23064	0.77
07/27/2024 10:00	0.8	1.4	0	0.46	0.23046	0.77
07/27/2024 11:00	0.8	1.4	0	0.46	0.23040	0.77
07/27/2024 12:00	0.7	1.3	0	0.46	0.23004	0.77
07/27/2024 13:00	0.7	1.4	0	0.46	0.22956	0.77
07/27/2024 14:00	0.7	1.3	0	0.46	0.22926	0.76
07/27/2024 15:00	0.7	1.4	0	0.46	0.22902	0.76
07/27/2024 16:00	0.7	1.4	0	0.46	0.22914	0.76
07/27/2024 17:00	0.7	1.3	0	0.46	0.22926	0.76
07/27/2024 18:00	0.7	1.4	0	0.46	0.22968	0.77
07/27/2024 19:00	0.7	1.4	0	0.46	0.22992	0.77
07/27/2024 20:00	0.7	1.4	0	0.46	0.23004	0.77
07/27/2024 21:00	0.7	1.4	0	0.46	0.23022	0.77
07/27/2024 22:00	0.7	1.4	0	0.46	0.23046	0.77
07/27/2024 23:00	0.7	1.4	0	0.46	0.23064	0.77
Average/Sum#:	0.7	1.4	0	0.46	0.23027	0.77
Minimum:	0.7	1.3	0	0.46	0.22902	0.76
Maximum:	0.8	1.5	0	0.46	0.23130	0.77
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/28/2024 00:00	0.7	1.4	0	0.46	0.23076	0.77
07/28/2024 01:00	0.7	1.4	0	0.46	0.23100	0.77
07/28/2024 02:00	0.8	1.5	0	0.46	0.23112	0.77
07/28/2024 03:00	0.8	1.4	0	0.46	0.23112	0.77
07/28/2024 04:00	0.8	1.4	0	0.46	0.23118	0.77
07/28/2024 05:00	0.8	1.4	0	0.46	0.23136	0.77
07/28/2024 06:00	0.8	1.5	0	0.46	0.23136	0.77
07/28/2024 07:00	0.8	1.5	0	0.46	0.23124	0.77
07/28/2024 08:00	0.8	1.5	0	0.46	0.23094	0.77
07/28/2024 09:00	0.7	1.5	0	0.46	0.23064	0.77
07/28/2024 10:00	0.7	1.5	0	0.46	0.23028	0.77
07/28/2024 11:00	0.7	1.4	0	0.46	0.22920	0.76
07/28/2024 12:00	0.7	1.5	0	0.46	0.22902	0.76
07/28/2024 13:00	0.7	1.4	-1	0.46	0.22938	0.76
07/28/2024 14:00	0.7	1.4	0	0.46	0.23010	0.77
07/28/2024 15:00	0.7	1.4	-1	0.46	0.23016	0.77
07/28/2024 16:00	0.7	1.5	0	0.46	0.22992	0.77
07/28/2024 17:00	0.7	1.4	-1	0.47	0.23568	0.79
07/28/2024 18:00	0.7	1.4	0	0.46	0.22908	0.76
07/28/2024 19:00	0.7	1.5	0	0.46	0.22896	0.76
07/28/2024 20:00	0.7	1.4	0	0.46	0.22974	0.77
07/28/2024 21:00	0.7	1.5	0	0.46	0.23034	0.77
07/28/2024 22:00	0.7	1.5	0	0.46	0.23064	0.77
07/28/2024 23:00	0.7	1.5	0	0.46	0.23082	0.77
Average/Sum#:	0.7	1.5	0	0.46	0.23059	0.77
Minimum:	0.7	1.4	-1	0.46	0.22896	0.76
Maximum:	0.8	1.5	0	0.47	0.23568	0.79
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/29/2024 00:00	0.7	1.4	0	0.46	0.23130	0.77
07/29/2024 01:00	0.7	1.5	0	0.46	0.23142	0.77
07/29/2024 02:00	0.8	1.4	0	0.46	0.23142	0.77
07/29/2024 03:00	0.7	1.5	0	0.46	0.23166	0.77
07/29/2024 04:00	0.7	1.5	0	0.46	0.23178	0.77
07/29/2024 05:00	0.8	1.5	0	0.46	0.23196	0.77
07/29/2024 06:00	0.8	1.5	0	0.46	0.23172	0.77
07/29/2024 07:00	0.7	1.4	0	0.46	0.23160	0.77
07/29/2024 08:00	0.8	1.5	0	0.46	0.23100	0.77
07/29/2024 09:00	0.8	1.5	0	0.46	0.23058	0.77
07/29/2024 10:00	0.7	1.5	0	0.46	0.23040	0.77
07/29/2024 11:00	0.7	1.5	0	0.46	0.22968	0.77
07/29/2024 12:00	0.7	1.4	-1	0.46	0.22908	0.76
07/29/2024 13:00	0.7	1.5	-1	0.46	0.22884	0.76
07/29/2024 14:00	0.7	1.4	-1	0.46	0.22860	0.76
07/29/2024 15:00	0.7	1.4	-1	0.46	0.22842	0.76
07/29/2024 16:00	0.7	1.4	0	0.47	0.23706	0.79
07/29/2024 17:00	0.7	1.4	0	0.57	0.28632	0.95
07/29/2024 18:00	0.6	1.6	0	0.71	0.35694	1.19
07/29/2024 19:00	0.9	1.5	0	0.65	0.32340	1.08
07/29/2024 20:00	0.9	1.5	0	0.65	0.32274	1.08
07/29/2024 21:00	0.9	1.5	0	0.56	0.28128	0.94
07/29/2024 22:00	0.7	1.5	0	0.46	0.23010	0.77
07/29/2024 23:00	0.8	1.5	0	0.46	0.23010	0.77
Average/Sum#:	0.7	1.5	0	0.50	0.24823	0.83
Minimum:	0.6	1.4	-1	0.46	0.22842	0.76
Maximum:	0.9	1.6	0	0.71	0.35694	1.19
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/30/2024 00:00	0.8	1.5	0	0.46	0.23028	0.77
07/30/2024 01:00	0.8	1.5	0	0.46	0.23028	0.77
07/30/2024 02:00	0.8	1.4	0	0.46	0.23040	0.77
07/30/2024 03:00	0.8	1.5	0	0.46	0.23034	0.77
07/30/2024 04:00	0.8	1.5	0	0.46	0.23076	0.77
07/30/2024 05:00	0.7	1.4	0	0.50	0.25098	0.84
07/30/2024 06:00	0.7	1.5	0	0.46	0.23034	0.77
07/30/2024 07:00	0.7	1.5	0	0.46	0.23040	0.77
07/30/2024 08:00	0.7	1.4	0	0.46	0.22998	0.77
07/30/2024 09:00	0.7	1.5	0	0.46	0.22968	0.77
07/30/2024 10:00	0.7	1.5	0	0.46	0.22902	0.76
07/30/2024 11:00	0.7	1.4	-1	0.46	0.22848	0.76
07/30/2024 12:00	0.7	1.4	0	0.46	0.22956	0.77
07/30/2024 13:00	0.7	1.4	-1	0.46	0.22806	0.76
07/30/2024 14:00	0.7	1.4	-1	0.46	0.22770	0.76
07/30/2024 15:00	0.8	1.4	0	0.52	0.26088	0.87
07/30/2024 16:00	0.5	1.5	0	0.70	0.34986	1.17
07/30/2024 17:00	0.2	1.5	1	0.76	0.37908	1.26
07/30/2024 18:00	0.2	1.6	1	0.76	0.38208	1.27
07/30/2024 19:00	0.2	1.6	1	0.75	0.37512	1.25
07/30/2024 20:00	0.3	1.5	1	0.73	0.36516	1.22
07/30/2024 21:00	0.6	1.5	0	0.63	0.31614	1.05
07/30/2024 22:00	0.7	1.4	0	0.46	0.23022	0.77
07/30/2024 23:00	0.7	1.4	0	0.47	0.23640	0.79
Average/Sum#:	0.6	1.5	0	0.53	0.26505	0.88
Minimum:	0.2	1.4	-1	0.46	0.22770	0.76
Maximum:	0.8	1.6	1	0.76	0.38208	1.27
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/31/2024 00:00	0.7	1.5	0	0.46	0.22926	0.76
07/31/2024 01:00	0.7	1.5	0	0.46	0.22938	0.76
07/31/2024 02:00	0.7	1.4	0	0.46	0.22956	0.77
07/31/2024 03:00	0.7	1.5	0	0.46	0.23220	0.77
07/31/2024 04:00	0.7	1.3	0	0.52	0.26010	0.87
07/31/2024 05:00	0.7	1.4	0	0.53	0.26358	0.88
07/31/2024 06:00	0.8	1.4	0	0.46	0.22980	0.77
07/31/2024 07:00	0.8	1.4	0	0.46	0.22974	0.77
07/31/2024 08:00	0.8	1.4	0	0.46	0.22932	0.76
07/31/2024 09:00	0.7	1.3	0	0.46	0.22878	0.76
07/31/2024 10:00	0.7	1.4	0	0.46	0.22824	0.76
07/31/2024 11:00	0.7	1.3	-1	0.46	0.23004	0.77
07/31/2024 12:00	0.7	1.3	0	0.47	0.23634	0.79
07/31/2024 13:00	0.7	1.3	-1	0.46	0.22770	0.76
07/31/2024 14:00	0.7	1.3	0	0.48	0.23874	0.80
07/31/2024 15:00	0.7	1.4	0	0.53	0.26316	0.88
07/31/2024 16:00	0.3	1.4	1	0.72	0.35802	1.19
07/31/2024 17:00	0.4	1.4	1	0.70	0.35172	1.17
07/31/2024 18:00	0.2	1.4	1	0.75	0.37272	1.24
07/31/2024 19:00	0.5	1.4	1	0.70	0.34830	1.16
07/31/2024 20:00	0.3	1.5	1	0.74	0.37128	1.24
07/31/2024 21:00	0.3	1.5	1	0.73	0.36306	1.21
07/31/2024 22:00	0.5	1.5	1	0.71	0.35586	1.19
07/31/2024 23:00	0.6	1.4	0	0.64	0.31860	1.06
Average/Sum#:	0.6	1.4	0	0.55	0.27606	0.92
Minimum:	0.2	1.3	-1	0.46	0.22770	0.76
Maximum:	0.8	1.5	1	0.75	0.37272	1.24
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/01/2024 00:00	0.7	1.3	0	0.53	0.26598	0.89
08/01/2024 01:00	0.7	1.4	0	0.47	0.23736	0.79
08/01/2024 02:00	0.7	1.3	0	0.46	0.23118	0.77
08/01/2024 03:00	0.7	1.4	0	0.47	0.23658	0.79
08/01/2024 04:00	0.7	1.3	0	0.49	0.24672	0.82
08/01/2024 05:00	0.7	1.4	0	0.55	0.27420	0.91
08/01/2024 06:00	0.7	1.3	0	0.47	0.23448	0.78
08/01/2024 07:00	0.7	1.3	0	0.40	0.19962	0.67
08/01/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
08/01/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
08/01/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
08/01/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
08/01/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
08/01/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
08/01/2024 14:00	0.0	1.3	0	0.23	0.11736	0.39
08/01/2024 15:00	1.1	1.2	0	0.53	0.26664	0.89
08/01/2024 16:00	0.2	1.4	1	0.75	0.37746	1.26
08/01/2024 17:00	0.2	1.4	0	0.74	0.37026	1.23
08/01/2024 18:00	0.2	1.4	1	0.76	0.38076	1.27
08/01/2024 19:00	0.3	1.4	0	0.72	0.36210	1.21
08/01/2024 20:00	0.2	1.4	0	0.76	0.37902	1.26
08/01/2024 21:00	0.2	1.4	0	0.75	0.37734	1.26
08/01/2024 22:00	0.3	1.4	0	0.72	0.36162	1.21
08/01/2024 23:00	0.9	1.3	0	0.65	0.32304	1.08
Average/Sum#:	0.5	1.4	0	0.58	0.29121	0.97
Minimum:	0.0	1.2	0	0.23	0.11736	0.39
Maximum:	1.1	1.4	1	0.76	0.38076	1.27
%SI	25.00	0.00	29.17	25.00	25.00	25.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/02/2024 00:00	0.7	1.2	0	0.54	0.26898	0.90
08/02/2024 01:00	0.8	1.3	0	0.49	0.24486	0.82
08/02/2024 02:00	0.8	1.3	0	0.46	0.23136	0.77
08/02/2024 03:00	0.8	1.2	0	0.48	0.24204	0.81
08/02/2024 04:00	0.7	1.3	0	0.55	0.27714	0.92
08/02/2024 05:00	0.7	1.2	0	0.55	0.27600	0.92
08/02/2024 06:00	0.7	1.3	0	0.55	0.27408	0.91
08/02/2024 07:00	0.7	1.3	0	0.55	0.27540	0.92
08/02/2024 08:00	0.7	1.3	0	0.56	0.27846	0.93
08/02/2024 09:00	1.2	1.4	0	0.59	0.29472	0.98
08/02/2024 10:00	0.2	1.4	1	0.76	0.38058	1.27
08/02/2024 11:00	0.2	1.4	0	0.77	0.38280	1.28
08/02/2024 12:00	0.1	1.4	1	0.77	0.38262	1.28
08/02/2024 13:00	0.2	1.4	1	0.77	0.38370	1.28
08/02/2024 14:00	0.2	1.4	0	0.75	0.37704	1.26
08/02/2024 15:00	0.3	1.4	0	0.72	0.36042	1.20
08/02/2024 16:00	0.6	1.3	0	0.65	0.32670	1.09
08/02/2024 17:00	0.6	1.3	0	0.67	0.33666	1.12
08/02/2024 18:00	0.6	1.4	0	0.71	0.35478	1.18
08/02/2024 19:00	0.8	1.4	0	0.65	0.32358	1.08
08/02/2024 20:00	0.8	1.3	0	0.65	0.32322	1.08
08/02/2024 21:00	0.8	1.3	0	0.61	0.30702	1.02
08/02/2024 22:00	0.7	1.3	0	0.55	0.27474	0.92
08/02/2024 23:00	0.7	1.3	0	0.54	0.27018	0.90
Average/Sum#:	0.6	1.3	0	0.62	0.31030	1.04
Minimum:	0.1	1.2	0	0.46	0.23136	0.77
Maximum:	1.2	1.4	1	0.77	0.38370	1.28
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/03/2024 00:00	0.7	1.3	0	0.52	0.25776	0.86
08/03/2024 01:00	0.7	1.3	0	0.47	0.23592	0.79
08/03/2024 02:00	0.7	1.2	0	0.46	0.22992	0.77
08/03/2024 03:00	0.8	1.3	0	0.46	0.22974	0.77
08/03/2024 04:00	0.8	1.4	0	0.46	0.22980	0.77
08/03/2024 05:00	0.8	1.4	0	0.46	0.23010	0.77
08/03/2024 06:00	0.8	1.4	0	0.46	0.23004	0.77
08/03/2024 07:00	0.8	1.4	0	0.46	0.22986	0.77
08/03/2024 08:00	0.7	1.4	0	0.46	0.22968	0.77
08/03/2024 09:00	0.7	1.3	0	0.46	0.22914	0.76
08/03/2024 10:00	0.8	1.4	0	0.46	0.22878	0.76
08/03/2024 11:00	0.7	1.2	0	0.46	0.22842	0.76
08/03/2024 12:00	0.7	1.3	0	0.46	0.22836	0.76
08/03/2024 13:00	0.7	1.2	0	0.46	0.22818	0.76
08/03/2024 14:00	0.7	1.3	0	0.46	0.22806	0.76
08/03/2024 15:00	0.7	1.3	0	0.46	0.22818	0.76
08/03/2024 16:00	0.7	1.2	0	0.46	0.22812	0.76
08/03/2024 17:00	0.8	1.2	0	0.51	0.25668	0.86
08/03/2024 18:00	0.2	1.4	1	0.75	0.37542	1.25
08/03/2024 19:00	0.3	1.4	0	0.71	0.35700	1.19
08/03/2024 20:00	0.7	1.4	0	0.58	0.28794	0.96
08/03/2024 21:00	0.7	1.3	0	0.52	0.25776	0.86
08/03/2024 22:00	0.7	1.3	0	0.53	0.26706	0.89
08/03/2024 23:00	0.7	1.3	0	0.48	0.23778	0.79
Average/Sum#:	0.7	1.3	0	0.50	0.24874	0.83
Minimum:	0.2	1.2	0	0.46	0.22806	0.76
Maximum:	0.8	1.4	1	0.75	0.37542	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/04/2024 00:00	0.7	1.4	0	0.46	0.22944	0.76
08/04/2024 01:00	0.8	1.3	0	0.46	0.22962	0.77
08/04/2024 02:00	0.8	1.3	0	0.46	0.22980	0.77
08/04/2024 03:00	0.7	1.4	0	0.46	0.22986	0.77
08/04/2024 04:00	0.7	1.3	0	0.46	0.23016	0.77
08/04/2024 05:00	0.7	1.3	0	0.46	0.23040	0.77
08/04/2024 06:00	0.7	1.4	0	0.46	0.23058	0.77
08/04/2024 07:00	0.7	1.3	0	0.46	0.23034	0.77
08/04/2024 08:00	0.7	1.3	0	0.46	0.23016	0.77
08/04/2024 09:00	0.7	1.4	0	0.46	0.22980	0.77
08/04/2024 10:00	0.7	1.3	0	0.46	0.22950	0.77
08/04/2024 11:00	0.7	1.3	0	0.46	0.22914	0.76
08/04/2024 12:00	0.7	1.3	0	0.46	0.22878	0.76
08/04/2024 13:00	0.7	1.4	0	0.46	0.22818	0.76
08/04/2024 14:00	0.7	1.3	0	0.46	0.22824	0.76
08/04/2024 15:00	0.7	1.3	0	0.46	0.22812	0.76
08/04/2024 16:00	0.7	1.2	0	0.46	0.22794	0.76
08/04/2024 17:00	0.6	1.3	0	0.57	0.28608	0.95
08/04/2024 18:00	0.2	1.5	1	0.75	0.37632	1.25
08/04/2024 19:00	0.6	1.4	0	0.67	0.33522	1.12
08/04/2024 20:00	0.8	1.4	0	0.65	0.32574	1.09
08/04/2024 21:00	0.7	1.3	0	0.55	0.27606	0.92
08/04/2024 22:00	0.7	1.3	0	0.54	0.27042	0.90
08/04/2024 23:00	0.7	1.4	0	0.50	0.25188	0.84
Average/Sum#:	0.7	1.3	0	0.50	0.25091	0.84
Minimum:	0.2	1.2	0	0.46	0.22794	0.76
Maximum:	0.8	1.5	1	0.75	0.37632	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/05/2024 00:00	0.8	1.3	0	0.47	0.23556	0.79
08/05/2024 01:00	0.7	1.4	0	0.46	0.23010	0.77
08/05/2024 02:00	0.8	1.3	0	0.46	0.23034	0.77
08/05/2024 03:00	0.8	1.4	0	0.46	0.23046	0.77
08/05/2024 04:00	0.7	1.3	0	0.52	0.26166	0.87
08/05/2024 05:00	0.7	1.3	0	0.53	0.26328	0.88
08/05/2024 06:00	0.8	1.3	0	0.49	0.24684	0.82
08/05/2024 07:00	0.8	1.4	0	0.46	0.23124	0.77
08/05/2024 08:00	0.7	1.3	0	0.46	0.23100	0.77
08/05/2024 09:00	0.7	1.4	0	0.46	0.23082	0.77
08/05/2024 10:00	0.8	1.3	0	0.46	0.23052	0.77
08/05/2024 11:00	0.7	1.4	0	0.46	0.23010	0.77
08/05/2024 12:00	0.7	1.2	0	0.51	0.25722	0.86
08/05/2024 13:00	0.7	1.3	0	0.46	0.23148	0.77
08/05/2024 14:00	0.7	1.3	0	0.50	0.24948	0.83
08/05/2024 15:00	0.7	1.3	0	0.46	0.23022	0.77
08/05/2024 16:00	0.7	1.3	0	0.46	0.23022	0.77
08/05/2024 17:00	0.7	1.3	0	0.49	0.24438	0.81
08/05/2024 18:00	0.6	1.4	0	0.65	0.32292	1.08
08/05/2024 19:00	0.7	1.4	0	0.52	0.26034	0.87
08/05/2024 20:00	0.7	1.3	0	0.49	0.24714	0.82
08/05/2024 21:00	0.7	1.4	0	0.52	0.25986	0.87
08/05/2024 22:00	0.7	1.3	0	0.52	0.26004	0.87
08/05/2024 23:00	0.7	1.4	0	0.46	0.23100	0.77
Average/Sum#:	0.7	1.3	0	0.49	0.24484	0.82
Minimum:	0.6	1.2	0	0.46	0.23010	0.77
Maximum:	0.8	1.4	0	0.65	0.32292	1.08
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/06/2024 00:00	0.8	1.3	0	0.46	0.23040	0.77
08/06/2024 01:00	0.8	1.3	0	0.46	0.23058	0.77
08/06/2024 02:00	0.8	1.4	0	0.46	0.23064	0.77
08/06/2024 03:00	0.8	1.5	0	0.46	0.23070	0.77
08/06/2024 04:00	0.8	1.4	0	0.46	0.23106	0.77
08/06/2024 05:00	0.8	1.3	0	0.47	0.23352	0.78
08/06/2024 06:00	0.8	1.4	0	0.47	0.23484	0.78
08/06/2024 07:00	0.8	1.3	0	0.46	0.23088	0.77
08/06/2024 08:00	0.8	1.3	0	0.46	0.23046	0.77
08/06/2024 09:00	0.7	1.3	0	0.46	0.22974	0.77
08/06/2024 10:00	0.8	1.4	0	0.46	0.22920	0.76
08/06/2024 11:00	0.8	1.2	0	0.46	0.22890	0.76
08/06/2024 12:00	0.8	1.3	0	0.46	0.22854	0.76
08/06/2024 13:00	0.7	1.3	0	0.46	0.22830	0.76
08/06/2024 14:00	0.7	1.3	0	0.46	0.22806	0.76
08/06/2024 15:00	0.7	1.3	0	0.46	0.22794	0.76
08/06/2024 16:00	0.7	1.3	0	0.48	0.23958	0.80
08/06/2024 17:00	0.8	1.3	0	0.52	0.26046	0.87
08/06/2024 18:00	0.2	1.4	0	0.75	0.37332	1.24
08/06/2024 19:00	0.7	1.4	0	0.65	0.32520	1.08
08/06/2024 20:00	0.8	1.3	0	0.56	0.28182	0.94
08/06/2024 21:00	0.7	1.3	0	0.55	0.27570	0.92
08/06/2024 22:00	0.7	1.3	0	0.54	0.26838	0.89
08/06/2024 23:00	0.8	1.2	0	0.49	0.24606	0.82
Average/Sum#:	0.7	1.3	0	0.50	0.24810	0.83
Minimum:	0.2	1.2	0	0.46	0.22794	0.76
Maximum:	0.8	1.5	0	0.75	0.37332	1.24
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/07/2024 00:00	0.7	1.4	0	0.46	0.22986	0.77
08/07/2024 01:00	0.8	1.3	0	0.46	0.22944	0.76
08/07/2024 02:00	0.8	1.3	0	0.46	0.22956	0.77
08/07/2024 03:00	0.8	1.4	0	0.46	0.22998	0.77
08/07/2024 04:00	0.8	1.3	0	0.46	0.23016	0.77
08/07/2024 05:00	0.8	1.4	0	0.46	0.23172	0.77
08/07/2024 06:00	0.8	1.4	0	0.48	0.24246	0.81
08/07/2024 07:00	0.9	1.4	0	0.46	0.22998	0.77
08/07/2024 08:00	0.9	1.4	0	0.46	0.22962	0.77
08/07/2024 09:00	0.7	1.3	0	0.46	0.22914	0.76
08/07/2024 10:00	0.8	1.2	0	0.46	0.22896	0.76
08/07/2024 11:00	0.8	1.3	0	0.46	0.22878	0.76
08/07/2024 12:00	0.8	1.4	0	0.46	0.22848	0.76
08/07/2024 13:00	0.7	1.3	0	0.46	0.22800	0.76
08/07/2024 14:00	0.7	1.3	0	0.46	0.22782	0.76
08/07/2024 15:00	0.7	1.3	0	0.46	0.22770	0.76
08/07/2024 16:00	0.7	1.3	0	0.46	0.22752	0.76
08/07/2024 17:00	0.7	1.3	0	0.48	0.24090	0.80
08/07/2024 18:00	0.7	1.2	0	0.49	0.24552	0.82
08/07/2024 19:00	0.7	1.3	0	0.51	0.25344	0.84
08/07/2024 20:00	0.7	1.2	0	0.48	0.24036	0.80
08/07/2024 21:00	0.7	1.4	0	0.47	0.23340	0.78
08/07/2024 22:00	0.7	1.4	0	0.47	0.23340	0.78
08/07/2024 23:00	0.7	1.4	0	0.46	0.23088	0.77
Average/Sum#:	0.8	1.3	0	0.47	0.23280	0.78
Minimum:	0.7	1.2	0	0.46	0.22752	0.76
Maximum:	0.9	1.4	0	0.51	0.25344	0.84
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/08/2024 00:00	0.7	1.3	0	0.46	0.23094	0.77
08/08/2024 01:00	0.7	1.4	0	0.46	0.23112	0.77
08/08/2024 02:00	0.7	1.3	0	0.46	0.23112	0.77
08/08/2024 03:00	0.8	1.4	0	0.46	0.23136	0.77
08/08/2024 04:00	0.8	1.4	0	0.46	0.23070	0.77
08/08/2024 05:00	0.8	1.4	0	0.46	0.23214	0.77
08/08/2024 06:00	0.7	1.4	0	0.48	0.24222	0.81
08/08/2024 07:00	0.7	1.3	0	0.46	0.23016	0.77
08/08/2024 08:00	0.7	1.3	0	0.46	0.22998	0.77
08/08/2024 09:00	0.7	1.4	0	0.46	0.22968	0.77
08/08/2024 10:00	0.7	0.0	0	0.46	0.22950	0.77
08/08/2024 11:00	0.7	1.4	0	0.46	0.22956	0.77
08/08/2024 12:00	0.7	1.3	0	0.46	0.22884	0.76
08/08/2024 13:00	0.7	1.3	0	0.46	0.22854	0.76
08/08/2024 14:00	0.7	1.4	0	0.46	0.22830	0.76
08/08/2024 15:00	0.7	1.2	0	0.46	0.22830	0.76
08/08/2024 16:00	0.7	1.3	0	0.46	0.22794	0.76
08/08/2024 17:00	0.7	1.3	0	0.46	0.22944	0.76
08/08/2024 18:00	0.7	1.3	0	0.46	0.23142	0.77
08/08/2024 19:00	0.7	1.3	0	0.46	0.22884	0.76
08/08/2024 20:00	0.7	1.4	0	0.48	0.24042	0.80
08/08/2024 21:00	0.7	1.3	0	0.48	0.23826	0.79
08/08/2024 22:00	0.7	1.4	0	0.46	0.22974	0.77
08/08/2024 23:00	0.7	1.3	0	0.46	0.22998	0.77
Average/Sum#:	0.7	1.3	0	0.46	0.23119	0.77
Minimum:	0.7	1.2	0	0.46	0.22794	0.76
Maximum:	0.8	1.4	0	0.48	0.24222	0.81
%SI	0.00	4.17	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/09/2024 00:00	0.8	1.4	0	0.46	0.23022	0.77
08/09/2024 01:00	0.7	1.3	0	0.46	0.23040	0.77
08/09/2024 02:00	0.7	1.4	0	0.46	0.23034	0.77
08/09/2024 03:00	0.7	1.4	0	0.46	0.23058	0.77
08/09/2024 04:00	0.8	1.4	0	0.46	0.23064	0.77
08/09/2024 05:00	0.8	1.4	0	0.46	0.23202	0.77
08/09/2024 06:00	0.7	1.3	0	0.51	0.25572	0.85
08/09/2024 07:00	0.8	1.3	0	0.46	0.23094	0.77
08/09/2024 08:00	0.8	1.3	0	0.46	0.23046	0.77
08/09/2024 09:00	0.7	1.3	0	0.46	0.22974	0.77
08/09/2024 10:00	0.7	1.3	0	0.46	0.22926	0.76
08/09/2024 11:00	0.7	1.3	0	0.46	0.22926	0.76
08/09/2024 12:00	0.7	1.3	0	0.46	0.22884	0.76
08/09/2024 13:00	0.7	1.3	0	0.46	0.22818	0.76
08/09/2024 14:00	0.7	1.2	0	0.46	0.22800	0.76
08/09/2024 15:00	0.7	1.2	0	0.46	0.22776	0.76
08/09/2024 16:00	0.7	1.3	0	0.46	0.22770	0.76
08/09/2024 17:00	0.7	1.3	0	0.48	0.23928	0.80
08/09/2024 18:00	0.7	1.4	0	0.47	0.23490	0.78
08/09/2024 19:00	0.7	1.3	0	0.46	0.23040	0.77
08/09/2024 20:00	0.7	1.4	0	0.46	0.23028	0.77
08/09/2024 21:00	0.7	1.4	0	0.46	0.22950	0.77
08/09/2024 22:00	0.7	1.4	0	0.46	0.22980	0.77
08/09/2024 23:00	0.7	1.4	0	0.46	0.22992	0.77
Average/Sum#:	0.7	1.3	0	0.46	0.23142	0.77
Minimum:	0.7	1.2	0	0.46	0.22770	0.76
Maximum:	0.8	1.4	0	0.51	0.25572	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/10/2024 00:00	0.8	1.4	0	0.46	0.23040	0.77
08/10/2024 01:00	0.7	1.4	0	0.46	0.23058	0.77
08/10/2024 02:00	0.7	1.4	0	0.46	0.23070	0.77
08/10/2024 03:00	0.7	1.4	0	0.46	0.23046	0.77
08/10/2024 04:00	0.7	1.4	0	0.46	0.23046	0.77
08/10/2024 05:00	0.7	1.4	0	0.46	0.23058	0.77
08/10/2024 06:00	0.8	1.4	0	0.46	0.23088	0.77
08/10/2024 07:00	0.8	1.4	0	0.46	0.23088	0.77
08/10/2024 08:00	0.7	1.4	0	0.46	0.23040	0.77
08/10/2024 09:00	0.8	1.4	0	0.46	0.23016	0.77
08/10/2024 10:00	0.7	1.4	0	0.46	0.23028	0.77
08/10/2024 11:00	0.7	1.4	0	0.46	0.23028	0.77
08/10/2024 12:00	0.7	1.4	0	0.46	0.22968	0.77
08/10/2024 13:00	0.7	1.3	0	0.47	0.23664	0.79
08/10/2024 14:00	0.7	1.3	0	0.46	0.22866	0.76
08/10/2024 15:00	0.7	1.2	0	0.46	0.22854	0.76
08/10/2024 16:00	0.7	1.2	0	0.46	0.22848	0.76
08/10/2024 17:00	0.7	1.3	0	0.48	0.24216	0.81
08/10/2024 18:00	0.7	1.3	0	0.46	0.22950	0.77
08/10/2024 19:00	0.7	1.2	0	0.46	0.22902	0.76
08/10/2024 20:00	0.7	1.2	0	0.46	0.22944	0.76
08/10/2024 21:00	0.7	1.4	0	0.46	0.22932	0.76
08/10/2024 22:00	0.7	1.3	0	0.46	0.22938	0.76
08/10/2024 23:00	0.8	1.4	0	0.46	0.22974	0.77
Average/Sum#:	0.7	1.3	0	0.46	0.23069	0.77
Minimum:	0.7	1.2	0	0.46	0.22848	0.76
Maximum:	0.8	1.4	0	0.48	0.24216	0.81
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/11/2024 00:00	0.8	1.3	0	0.46	0.22998	0.77
08/11/2024 01:00	0.7	1.3	0	0.46	0.23004	0.77
08/11/2024 02:00	0.8	1.3	0	0.46	0.23040	0.77
08/11/2024 03:00	0.7	1.4	0	0.46	0.23052	0.77
08/11/2024 04:00	0.8	1.4	0	0.46	0.23058	0.77
08/11/2024 05:00	0.8	1.4	0	0.46	0.23070	0.77
08/11/2024 06:00	0.8	1.4	0	0.46	0.23076	0.77
08/11/2024 07:00	0.7	1.4	0	0.46	0.23070	0.77
08/11/2024 08:00	0.7	1.3	0	0.46	0.23028	0.77
08/11/2024 09:00	0.7	1.4	0	0.46	0.23004	0.77
08/11/2024 10:00	0.7	1.4	0	0.46	0.22950	0.77
08/11/2024 11:00	0.7	1.3	0	0.46	0.22908	0.76
08/11/2024 12:00	0.7	1.3	0	0.51	0.25362	0.85
08/11/2024 13:00	0.7	1.4	0	0.56	0.28122	0.94
08/11/2024 14:00	0.6	1.3	0	0.56	0.28170	0.94
08/11/2024 15:00	0.7	1.2	0	0.56	0.28026	0.93
08/11/2024 16:00	0.6	1.3	0	0.55	0.27600	0.92
08/11/2024 17:00	0.7	1.3	0	0.53	0.26316	0.88
08/11/2024 18:00	0.8	1.4	0	0.57	0.28440	0.95
08/11/2024 19:00	0.9	1.4	0	0.65	0.32622	1.09
08/11/2024 20:00	0.5	1.4	0	0.71	0.35496	1.18
08/11/2024 21:00	0.9	1.4	0	0.61	0.30660	1.02
08/11/2024 22:00	0.8	1.4	0	0.46	0.23142	0.77
08/11/2024 23:00	0.8	1.4	0	0.46	0.23124	0.77
Average/Sum#:	0.7	1.4	0	0.51	0.25556	0.85
Minimum:	0.5	1.2	0	0.46	0.22908	0.76
Maximum:	0.9	1.4	0	0.71	0.35496	1.18
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/12/2024 00:00	0.8	1.4	0	0.46	0.23148	0.77
08/12/2024 01:00	0.8	1.4	0	0.46	0.23166	0.77
08/12/2024 02:00	0.8	1.5	0	0.46	0.23184	0.77
08/12/2024 03:00	0.8	1.5	0	0.46	0.23196	0.77
08/12/2024 04:00	0.8	1.3	0	0.49	0.24252	0.81
08/12/2024 05:00	0.8	1.3	0	0.50	0.25206	0.84
08/12/2024 06:00	0.8	1.3	0	0.46	0.23202	0.77
08/12/2024 07:00	0.8	1.3	0	0.46	0.23196	0.77
08/12/2024 08:00	0.8	1.4	0	0.46	0.23160	0.77
08/12/2024 09:00	0.8	1.3	0	0.46	0.23130	0.77
08/12/2024 10:00	0.7	1.4	0	0.46	0.23052	0.77
08/12/2024 11:00	0.7	1.4	0	0.46	0.22992	0.77
08/12/2024 12:00	0.7	1.3	0	0.46	0.22938	0.76
08/12/2024 13:00	0.7	1.3	0	0.46	0.22908	0.76
08/12/2024 14:00	0.7	1.3	0	0.46	0.22896	0.76
08/12/2024 15:00	0.7	1.3	0	0.46	0.22908	0.76
08/12/2024 16:00	0.7	1.3	0	0.46	0.22896	0.76
08/12/2024 17:00	0.8	1.3	0	0.52	0.26154	0.87
08/12/2024 18:00	0.8	1.4	0	0.65	0.32556	1.09
08/12/2024 19:00	1.0	1.4	0	0.60	0.30222	1.01
08/12/2024 20:00	0.7	1.4	0	0.47	0.23724	0.79
08/12/2024 21:00	0.7	1.4	0	0.46	0.22968	0.77
08/12/2024 22:00	0.8	1.4	0	0.46	0.22998	0.77
08/12/2024 23:00	0.7	1.4	0	0.46	0.23016	0.77
Average/Sum#:	0.8	1.4	0	0.48	0.24045	0.80
Minimum:	0.7	1.3	0	0.46	0.22896	0.76
Maximum:	1.0	1.5	0	0.65	0.32556	1.09
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/13/2024 00:00	0.8	1.4	0	0.46	0.23010	0.77
08/13/2024 01:00	0.7	1.4	0	0.46	0.23010	0.77
08/13/2024 02:00	0.8	1.4	0	0.46	0.23034	0.77
08/13/2024 03:00	0.8	1.4	0	0.46	0.23052	0.77
08/13/2024 04:00	0.8	1.4	0	0.46	0.23046	0.77
08/13/2024 05:00	0.8	1.4	0	0.46	0.23208	0.77
08/13/2024 06:00	0.8	1.3	0	0.46	0.23082	0.77
08/13/2024 07:00	0.7	1.4	0	0.46	0.23052	0.77
08/13/2024 08:00	0.7	1.4	0	0.46	0.23028	0.77
08/13/2024 09:00	0.9	1.4	0	0.46	0.23004	0.77
08/13/2024 10:00	0.9	1.4	0	0.46	0.22980	0.77
08/13/2024 11:00	0.9	1.4	0	0.46	0.22944	0.76
08/13/2024 12:00	0.8	1.4	0	0.46	0.22914	0.76
08/13/2024 13:00	0.9	1.4	0	0.46	0.22914	0.76
08/13/2024 14:00	0.9	1.3	0	0.46	0.22896	0.76
08/13/2024 15:00	0.8	1.4	0	0.46	0.22884	0.76
08/13/2024 16:00	0.9	1.3	0	0.46	0.22878	0.76
08/13/2024 17:00	0.8	1.4	0	0.58	0.29238	0.97
08/13/2024 18:00	0.9	1.4	0	0.68	0.34200	1.14
08/13/2024 19:00	1.0	1.3	0	0.56	0.28056	0.94
08/13/2024 20:00	0.9	1.3	0	0.46	0.23190	0.77
08/13/2024 21:00	0.9	1.4	0	0.47	0.23304	0.78
08/13/2024 22:00	0.9	1.3	0	0.46	0.22962	0.77
08/13/2024 23:00	0.9	1.4	0	0.46	0.22974	0.77
Average/Sum#:	0.8	1.4	0	0.48	0.23953	0.80
Minimum:	0.7	1.3	0	0.46	0.22878	0.76
Maximum:	1.0	1.4	0	0.68	0.34200	1.14
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/14/2024 00:00	0.9	1.4	0	0.46	0.22998	0.77
08/14/2024 01:00	0.9	1.4	0	0.46	0.23034	0.77
08/14/2024 02:00	0.9	1.3	0	0.46	0.23058	0.77
08/14/2024 03:00	0.9	1.3	0	0.46	0.23070	0.77
08/14/2024 04:00	0.9	1.4	0	0.46	0.23094	0.77
08/14/2024 05:00	0.9	1.4	0	0.46	0.23064	0.77
08/14/2024 06:00	0.9	1.4	0	0.46	0.23076	0.77
08/14/2024 07:00	0.9	1.3	0	0.46	0.23064	0.77
08/14/2024 08:00	0.9	1.3	0	0.46	0.23040	0.77
08/14/2024 09:00	0.9	1.4	0	0.46	0.22992	0.77
08/14/2024 10:00	0.9	1.4	0	0.46	0.22974	0.77
08/14/2024 11:00	0.9	1.4	0	0.46	0.22938	0.76
08/14/2024 12:00	0.9	1.3	0	0.46	0.22908	0.76
08/14/2024 13:00	0.9	1.3	0	0.46	0.22860	0.76
08/14/2024 14:00	0.9	1.3	0	0.46	0.22842	0.76
08/14/2024 15:00	0.8	1.4	0	0.46	0.22818	0.76
08/14/2024 16:00	0.8	1.3	0	0.46	0.23070	0.77
08/14/2024 17:00	0.8	1.4	0	0.66	0.32754	1.09
08/14/2024 18:00	0.3	1.5	1	0.77	0.38454	1.28
08/14/2024 19:00	0.3	1.5	1	0.77	0.38664	1.29
08/14/2024 20:00	0.8	1.4	0	0.64	0.32034	1.07
08/14/2024 21:00	0.9	1.3	-1	0.53	0.26664	0.89
08/14/2024 22:00	1.0	1.4	0	0.47	0.23280	0.78
08/14/2024 23:00	0.9	1.3	0	0.53	0.26448	0.88
Average/Sum#:	0.8	1.4	0	0.51	0.25383	0.85
Minimum:	0.3	1.3	-1	0.46	0.22818	0.76
Maximum:	1.0	1.5	1	0.77	0.38664	1.29
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/15/2024 00:00	1.0	1.4	0	0.46	0.22986	0.77
08/15/2024 01:00	1.0	1.3	0	0.46	0.23010	0.77
08/15/2024 02:00	1.0	1.5	0	0.46	0.23046	0.77
08/15/2024 03:00	1.0	1.4	0	0.46	0.23046	0.77
08/15/2024 04:00	0.9	1.4	0	0.48	0.24054	0.80
08/15/2024 05:00	0.9	1.3	0	0.51	0.25428	0.85
08/15/2024 06:00	1.0	1.4	0	0.46	0.23082	0.77
08/15/2024 07:00	1.0	1.3	0	0.46	0.23082	0.77
08/15/2024 08:00	1.0	1.4	0	0.46	0.23022	0.77
08/15/2024 09:00	0.9	1.4	0	0.46	0.22968	0.77
08/15/2024 10:00	0.9	1.3	0	0.46	0.22944	0.76
08/15/2024 11:00	0.9	1.3	0	0.46	0.22890	0.76
08/15/2024 12:00	0.9	1.3	0	0.46	0.22824	0.76
08/15/2024 13:00	0.9	1.4	0	0.46	0.22770	0.76
08/15/2024 14:00	0.9	1.3	0	0.45	0.22734	0.76
08/15/2024 15:00	1.0	1.3	0	0.51	0.25740	0.86
08/15/2024 16:00	0.9	1.4	0	0.66	0.32802	1.09
08/15/2024 17:00	0.5	1.4	0	0.71	0.35658	1.19
08/15/2024 18:00	0.4	1.4	0	0.75	0.37554	1.25
08/15/2024 19:00	0.5	1.4	0	0.72	0.36138	1.20
08/15/2024 20:00	0.9	1.3	0	0.56	0.27798	0.93
08/15/2024 21:00	0.9	1.4	0	0.46	0.22962	0.77
08/15/2024 22:00	0.9	1.3	0	0.46	0.22926	0.76
08/15/2024 23:00	0.9	1.3	0	0.46	0.23226	0.77
Average/Sum#:	0.9	1.4	0	0.51	0.25529	0.85
Minimum:	0.4	1.3	0	0.45	0.22734	0.76
Maximum:	1.0	1.5	0	0.75	0.37554	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/16/2024 00:00	1.0	1.3	0	0.46	0.22968	0.77
08/16/2024 01:00	0.9	1.3	0	0.46	0.22974	0.77
08/16/2024 02:00	0.9	1.3	0	0.46	0.23010	0.77
08/16/2024 03:00	0.9	1.4	0	0.46	0.23022	0.77
08/16/2024 04:00	0.9	1.3	0	0.50	0.24948	0.83
08/16/2024 05:00	0.9	1.4	0	0.51	0.25740	0.86
08/16/2024 06:00	1.0	1.4	0	0.46	0.23082	0.77
08/16/2024 07:00	1.0	1.3	0	0.46	0.23070	0.77
08/16/2024 08:00	0.9	1.4	0	0.46	0.23004	0.77
08/16/2024 09:00	0.9	1.4	0	0.46	0.22932	0.76
08/16/2024 10:00	0.9	1.4	0	0.46	0.22884	0.76
08/16/2024 11:00	0.9	1.4	0	0.46	0.22842	0.76
08/16/2024 12:00	0.9	1.3	0	0.46	0.22806	0.76
08/16/2024 13:00	0.9	1.3	0	0.46	0.23034	0.77
08/16/2024 14:00	0.9	1.2	0	0.46	0.22770	0.76
08/16/2024 15:00	0.9	1.4	0	0.46	0.22758	0.76
08/16/2024 16:00	0.9	1.3	0	0.45	0.22740	0.76
08/16/2024 17:00	0.9	1.3	0	0.46	0.22890	0.76
08/16/2024 18:00	0.9	1.4	0	0.46	0.22806	0.76
08/16/2024 19:00	0.9	1.3	0	0.46	0.22974	0.77
08/16/2024 20:00	0.9	1.3	0	0.46	0.22902	0.76
08/16/2024 21:00	0.8	1.3	0	0.55	0.27480	0.92
08/16/2024 22:00	0.9	1.4	0	0.54	0.26778	0.89
08/16/2024 23:00	0.8	1.3	0	0.52	0.26232	0.87
Average/Sum#:	0.9	1.3	0	0.47	0.23610	0.79
Minimum:	0.8	1.2	0	0.45	0.22740	0.76
Maximum:	1.0	1.4	0	0.55	0.27480	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/17/2024 00:00	0.9	1.3	0	0.50	0.25152	0.84
08/17/2024 01:00	0.9	1.3	0	0.46	0.22950	0.77
08/17/2024 02:00	0.9	1.3	0	0.46	0.22968	0.77
08/17/2024 03:00	0.9	1.5	0	0.46	0.22986	0.77
08/17/2024 04:00	0.9	1.3	0	0.46	0.23028	0.77
08/17/2024 05:00	0.9	1.3	0	0.50	0.25194	0.84
08/17/2024 06:00	0.9	1.4	0	0.46	0.22998	0.77
08/17/2024 07:00	0.9	1.4	0	0.46	0.22998	0.77
08/17/2024 08:00	0.9	1.3	0	0.46	0.22980	0.77
08/17/2024 09:00	0.9	1.4	0	0.46	0.22944	0.76
08/17/2024 10:00	0.9	1.4	0	0.46	0.22890	0.76
08/17/2024 11:00	0.9	1.4	0	0.46	0.22848	0.76
08/17/2024 12:00	0.8	1.4	0	0.46	0.22836	0.76
08/17/2024 13:00	0.9	1.3	0	0.46	0.22818	0.76
08/17/2024 14:00	0.8	1.3	0	0.46	0.22848	0.76
08/17/2024 15:00	0.8	1.4	0	0.46	0.22854	0.76
08/17/2024 16:00	0.8	1.3	0	0.46	0.22848	0.76
08/17/2024 17:00	0.8	1.4	0	0.46	0.23148	0.77
08/17/2024 18:00	0.8	1.3	0	0.46	0.22914	0.76
08/17/2024 19:00	0.8	1.3	0	0.46	0.22926	0.76
08/17/2024 20:00	0.9	1.4	0	0.46	0.22932	0.76
08/17/2024 21:00	0.9	1.4	0	0.46	0.22944	0.76
08/17/2024 22:00	0.9	1.4	0	0.46	0.22962	0.77
08/17/2024 23:00	0.9	1.3	0	0.46	0.22974	0.77
Average/Sum#:	0.9	1.4	0	0.46	0.23123	0.77
Minimum:	0.8	1.3	0	0.46	0.22818	0.76
Maximum:	0.9	1.5	0	0.50	0.25194	0.84
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/18/2024 00:00	0.9	1.4	0	0.46	0.23010	0.77
08/18/2024 01:00	0.9	1.3	0	0.46	0.23022	0.77
08/18/2024 02:00	0.9	1.3	0	0.46	0.23022	0.77
08/18/2024 03:00	0.9	1.4	0	0.46	0.23034	0.77
08/18/2024 04:00	0.9	1.4	0	0.46	0.23058	0.77
08/18/2024 05:00	0.9	1.3	0	0.46	0.23070	0.77
08/18/2024 06:00	0.9	1.3	0	0.46	0.23052	0.77
08/18/2024 07:00	0.9	1.3	0	0.46	0.23046	0.77
08/18/2024 08:00	0.9	1.3	0	0.46	0.23034	0.77
08/18/2024 09:00	0.9	1.3	0	0.46	0.22986	0.77
08/18/2024 10:00	0.9	1.3	0	0.46	0.22944	0.76
08/18/2024 11:00	0.9	1.4	0	0.46	0.22902	0.76
08/18/2024 12:00	0.9	1.4	0	0.46	0.22878	0.76
08/18/2024 13:00	0.9	1.4	0	0.46	0.22872	0.76
08/18/2024 14:00	0.9	1.3	0	0.46	0.22854	0.76
08/18/2024 15:00	0.9	1.4	0	0.46	0.22842	0.76
08/18/2024 16:00	0.9	1.3	0	0.47	0.23322	0.78
08/18/2024 17:00	0.9	1.3	0	0.47	0.23292	0.78
08/18/2024 18:00	0.9	1.4	0	0.46	0.22872	0.76
08/18/2024 19:00	0.9	1.3	0	0.46	0.22914	0.76
08/18/2024 20:00	0.9	1.4	0	0.46	0.22974	0.77
08/18/2024 21:00	0.9	1.3	0	0.46	0.23118	0.77
08/18/2024 22:00	0.9	1.4	0	0.46	0.22968	0.77
08/18/2024 23:00	0.9	1.3	0	0.47	0.23262	0.78
Average/Sum#:	0.9	1.3	0	0.46	0.23015	0.77
Minimum:	0.9	1.3	0	0.46	0.22842	0.76
Maximum:	0.9	1.4	0	0.47	0.23322	0.78
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/19/2024 00:00	0.9	1.4	0	0.46	0.23028	0.77
08/19/2024 01:00	0.9	1.3	0	0.46	0.23022	0.77
08/19/2024 02:00	0.9	1.4	0	0.46	0.23034	0.77
08/19/2024 03:00	1.0	1.4	0	0.46	0.23040	0.77
08/19/2024 04:00	0.9	1.4	0	0.52	0.25782	0.86
08/19/2024 05:00	0.9	1.3	0	0.53	0.26262	0.88
08/19/2024 06:00	1.0	1.3	0	0.46	0.23076	0.77
08/19/2024 07:00	1.0	1.3	0	0.46	0.23070	0.77
08/19/2024 08:00	1.0	1.4	0	0.46	0.23046	0.77
08/19/2024 09:00	0.9	1.3	0	0.46	0.23028	0.77
08/19/2024 10:00	0.9	1.3	0	0.46	0.22962	0.77
08/19/2024 11:00	0.9	1.4	-1	0.46	0.22902	0.76
08/19/2024 12:00	0.9	1.3	-1	0.46	0.22890	0.76
08/19/2024 13:00	0.9	1.3	-1	0.46	0.22842	0.76
08/19/2024 14:00	0.8	1.3	-1	0.46	0.22830	0.76
08/19/2024 15:00	0.9	1.3	-1	0.46	0.22824	0.76
08/19/2024 16:00	0.9	1.3	-1	0.46	0.22818	0.76
08/19/2024 17:00	0.9	1.3	-1	0.46	0.22824	0.76
08/19/2024 18:00	0.9	1.4	-1	0.46	0.22866	0.76
08/19/2024 19:00	0.9	1.3	-1	0.46	0.22890	0.76
08/19/2024 20:00	0.9	1.4	-1	0.46	0.22920	0.76
08/19/2024 21:00	0.9	1.2	-1	0.51	0.25368	0.85
08/19/2024 22:00	0.9	1.3	-1	0.46	0.22956	0.77
08/19/2024 23:00	0.9	1.4	-1	0.46	0.22962	0.77
Average/Sum#:	0.9	1.3	-1	0.47	0.23302	0.78
Minimum:	0.8	1.2	-1	0.46	0.22818	0.76
Maximum:	1.0	1.4	0	0.53	0.26262	0.88
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/20/2024 00:00	0.9	1.3	-1	0.46	0.22980	0.77
08/20/2024 01:00	1.0	1.4	-1	0.46	0.22992	0.77
08/20/2024 02:00	1.0	1.4	-1	0.46	0.22986	0.77
08/20/2024 03:00	0.9	1.3	-1	0.46	0.23010	0.77
08/20/2024 04:00	1.0	1.4	-1	0.46	0.23028	0.77
08/20/2024 05:00	1.0	1.3	-1	0.46	0.23040	0.77
08/20/2024 06:00	1.0	1.3	-1	0.46	0.23034	0.77
08/20/2024 07:00	0.9	1.4	-1	0.46	0.23022	0.77
08/20/2024 08:00	1.0	1.4	-1	0.46	0.23010	0.77
08/20/2024 09:00	0.9	1.3	-1	0.46	0.23016	0.77
08/20/2024 10:00	0.9	1.3	-1	0.46	0.22986	0.77
08/20/2024 11:00	0.9	1.3	-1	0.46	0.22962	0.77
08/20/2024 12:00	0.0	1.4	0	0.46	0.22944	0.76
08/20/2024 13:00	0.0	1.3	0	0.46	0.22920	0.76
08/20/2024 14:00	0.9	1.2	0	0.46	0.22896	0.76
08/20/2024 15:00	0.9	1.3	-1	0.46	0.22914	0.76
08/20/2024 16:00	0.9	1.2	-1	0.46	0.22890	0.76
08/20/2024 17:00	0.9	1.2	-1	0.48	0.24054	0.80
08/20/2024 18:00	0.9	1.2	-1	0.46	0.22932	0.76
08/20/2024 19:00	0.9	1.3	-1	0.46	0.22962	0.77
08/20/2024 20:00	0.9	1.3	-1	0.46	0.22938	0.76
08/20/2024 21:00	0.9	1.3	-1	0.46	0.22752	0.76
08/20/2024 22:00	0.9	1.3	-1	0.46	0.22818	0.76
08/20/2024 23:00	0.9	1.4	-1	0.46	0.22812	0.76
Average/Sum#:	0.9	1.3	-1	0.46	0.22996	0.77
Minimum:	0.9	1.2	-1	0.46	0.22752	0.76
Maximum:	1.0	1.4	0	0.48	0.24054	0.80
%SI	8.33	0.00	8.33	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/21/2024 00:00	0.9	1.4	-1	0.46	0.22806	0.76
08/21/2024 01:00	0.9	1.3	-1	0.46	0.22830	0.76
08/21/2024 02:00	0.9	1.4	-1	0.46	0.22848	0.76
08/21/2024 03:00	0.9	1.4	-1	0.46	0.22878	0.76
08/21/2024 04:00	1.0	1.4	-1	0.46	0.22896	0.76
08/21/2024 05:00	0.9	1.4	-1	0.46	0.22974	0.77
08/21/2024 06:00	0.9	1.3	-1	0.46	0.22938	0.76
08/21/2024 07:00	0.9	1.3	-1	0.46	0.22980	0.77
08/21/2024 08:00	0.9	1.4	-1	0.46	0.22974	0.77
08/21/2024 09:00	0.9	1.4	-1	0.46	0.22944	0.76
08/21/2024 10:00	0.9	1.4	-1	0.46	0.22884	0.76
08/21/2024 11:00	0.9	1.4	-1	0.46	0.22842	0.76
08/21/2024 12:00	0.9	1.4	-1	0.46	0.22830	0.76
08/21/2024 13:00	0.9	1.4	-1	0.46	0.22812	0.76
08/21/2024 14:00	0.8	1.2	-1	0.46	0.22776	0.76
08/21/2024 15:00	0.8	1.4	-1	0.46	0.22782	0.76
08/21/2024 16:00	0.8	1.4	-1	0.47	0.23358	0.78
08/21/2024 17:00	0.9	1.2	-1	0.47	0.23352	0.78
08/21/2024 18:00	0.8	1.3	-1	0.46	0.22860	0.76
08/21/2024 19:00	0.8	1.3	-1	0.46	0.22830	0.76
08/21/2024 20:00	0.9	1.3	-1	0.45	0.22734	0.76
08/21/2024 21:00	0.9	1.3	-1	0.46	0.22860	0.76
08/21/2024 22:00	0.9	1.3	-1	0.45	0.22704	0.76
08/21/2024 23:00	0.9	1.3	-1	0.45	0.22698	0.76
Average/Sum#:	0.9	1.3	-1	0.46	0.22891	0.76
Minimum:	0.8	1.2	-1	0.45	0.22698	0.76
Maximum:	1.0	1.4	-1	0.47	0.23358	0.78
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/22/2024 00:00	0.9	1.4	-1	0.45	0.22746	0.76
08/22/2024 01:00	0.9	1.4	-1	0.46	0.22806	0.76
08/22/2024 02:00	0.9	1.3	-1	0.46	0.22860	0.76
08/22/2024 03:00	0.9	1.4	-1	0.46	0.22902	0.76
08/22/2024 04:00	0.9	1.3	-1	0.46	0.22926	0.76
08/22/2024 05:00	0.9	1.3	-1	0.47	0.23736	0.79
08/22/2024 06:00	0.9	1.3	-1	0.46	0.23040	0.77
08/22/2024 07:00	0.9	1.3	-1	0.46	0.23046	0.77
08/22/2024 08:00	0.9	1.3	-1	0.46	0.23010	0.77
08/22/2024 09:00	0.9	1.3	-1	0.46	0.22968	0.77
08/22/2024 10:00	0.9	1.3	-1	0.46	0.22944	0.76
08/22/2024 11:00	0.9	1.4	-1	0.46	0.22920	0.76
08/22/2024 12:00	0.9	1.3	-1	0.46	0.22884	0.76
08/22/2024 13:00	0.9	1.3	-1	0.46	0.22872	0.76
08/22/2024 14:00	0.8	1.3	-1	0.46	0.22872	0.76
08/22/2024 15:00	0.8	1.3	-1	0.46	0.22872	0.76
08/22/2024 16:00	0.8	1.4	-1	0.46	0.22884	0.76
08/22/2024 17:00	0.8	1.3	-1	0.46	0.22896	0.76
08/22/2024 18:00	0.8	1.3	-1	0.46	0.22932	0.76
08/22/2024 19:00	0.9	1.3	-1	0.46	0.22968	0.77
08/22/2024 20:00	0.9	1.4	-1	0.46	0.22998	0.77
08/22/2024 21:00	0.9	1.3	-1	0.46	0.23010	0.77
08/22/2024 22:00	0.9	1.4	-1	0.46	0.23028	0.77
08/22/2024 23:00	0.9	1.4	-1	0.46	0.23040	0.77
Average/Sum#:	0.9	1.3	-1	0.46	0.22965	0.77
Minimum:	0.8	1.3	-1	0.45	0.22746	0.76
Maximum:	0.9	1.4	-1	0.47	0.23736	0.79
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/23/2024 00:00	0.9	1.3	-1	0.46	0.23040	0.77
08/23/2024 01:00	0.9	1.4	-1	0.46	0.23052	0.77
08/23/2024 02:00	0.9	1.4	-1	0.46	0.23058	0.77
08/23/2024 03:00	0.9	1.4	-1	0.46	0.23082	0.77
08/23/2024 04:00	1.0	1.4	-1	0.46	0.23112	0.77
08/23/2024 05:00	1.0	1.3	-1	0.46	0.23136	0.77
08/23/2024 06:00	1.0	1.3	-1	0.46	0.23136	0.77
08/23/2024 07:00	0.9	1.4	-1	0.46	0.23100	0.77
08/23/2024 08:00	0.9	1.4	-1	0.46	0.23076	0.77
08/23/2024 09:00	0.9	1.3	-1	0.46	0.23046	0.77
08/23/2024 10:00	0.9	1.4	-1	0.46	0.23022	0.77
08/23/2024 11:00	0.9	1.4	-1	0.46	0.22998	0.77
08/23/2024 12:00	0.9	1.4	-1	0.46	0.22992	0.77
08/23/2024 13:00	0.9	1.4	-1	0.46	0.22992	0.77
08/23/2024 14:00	0.9	1.4	-1	0.46	0.22998	0.77
08/23/2024 15:00	0.9	1.4	-1	0.46	0.22980	0.77
08/23/2024 16:00	0.9	1.4	-1	0.46	0.22980	0.77
08/23/2024 17:00	0.9	1.4	-1	0.46	0.22962	0.77
08/23/2024 18:00	0.9	1.3	-1	0.46	0.22962	0.77
08/23/2024 19:00	0.9	1.4	-1	0.46	0.22986	0.77
08/23/2024 20:00	0.9	1.4	-1	0.46	0.22986	0.77
08/23/2024 21:00	0.9	1.4	-1	0.46	0.22986	0.77
08/23/2024 22:00	0.9	1.4	-1	0.46	0.23010	0.77
08/23/2024 23:00	0.9	1.4	-1	0.49	0.24636	0.82
Average/Sum#:	0.9	1.4	-1	0.46	0.23097	0.77
Minimum:	0.9	1.3	-1	0.46	0.22962	0.77
Maximum:	1.0	1.4	-1	0.49	0.24636	0.82
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/24/2024 00:00	0.9	1.4	-1	0.46	0.23040	0.77
08/24/2024 01:00	0.9	1.3	-1	0.46	0.23070	0.77
08/24/2024 02:00	0.9	1.5	-1	0.46	0.23064	0.77
08/24/2024 03:00	0.9	1.4	-1	0.46	0.23076	0.77
08/24/2024 04:00	0.9	1.4	-1	0.47	0.23322	0.78
08/24/2024 05:00	0.9	1.4	-1	0.49	0.24480	0.82
08/24/2024 06:00	0.9	1.3	-1	0.47	0.23712	0.79
08/24/2024 07:00	0.9	1.4	-1	0.46	0.23142	0.77
08/24/2024 08:00	1.0	1.3	-1	0.46	0.23130	0.77
08/24/2024 09:00	0.9	1.3	-1	0.46	0.23106	0.77
08/24/2024 10:00	0.9	1.3	-1	0.46	0.23082	0.77
08/24/2024 11:00	0.9	1.3	-1	0.46	0.23058	0.77
08/24/2024 12:00	0.9	1.3	-1	0.46	0.23034	0.77
08/24/2024 13:00	0.9	1.4	-1	0.46	0.23034	0.77
08/24/2024 14:00	0.9	1.4	-1	0.46	0.23106	0.77
08/24/2024 15:00	0.9	1.4	-1	0.46	0.23076	0.77
08/24/2024 16:00	0.9	1.4	-1	0.46	0.23022	0.77
08/24/2024 17:00	0.9	1.4	-1	0.46	0.23022	0.77
08/24/2024 18:00	0.9	1.4	-1	0.46	0.23028	0.77
08/24/2024 19:00	0.9	1.3	-1	0.46	0.23040	0.77
08/24/2024 20:00	1.0	1.3	-1	0.46	0.23070	0.77
08/24/2024 21:00	1.0	1.4	-1	0.46	0.23124	0.77
08/24/2024 22:00	1.1	1.4	-1	0.46	0.23178	0.77
08/24/2024 23:00	1.1	1.3	-1	0.46	0.23178	0.77
Average/Sum#:	0.9	1.4	-1	0.46	0.23175	0.77
Minimum:	0.9	1.3	-1	0.46	0.23022	0.77
Maximum:	1.1	1.5	-1	0.49	0.24480	0.82
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/25/2024 00:00	1.1	1.4	-1	0.46	0.23202	0.77
08/25/2024 01:00	1.2	1.4	-1	0.46	0.23220	0.77
08/25/2024 02:00	1.2	1.3	0	0.47	0.23250	0.78
08/25/2024 03:00	1.2	1.4	-1	0.47	0.23274	0.78
08/25/2024 04:00	1.1	1.4	-1	0.47	0.23310	0.78
08/25/2024 05:00	1.1	1.4	-1	0.47	0.23322	0.78
08/25/2024 06:00	1.1	1.3	-1	0.47	0.23310	0.78
08/25/2024 07:00	1.1	1.4	-1	0.47	0.23304	0.78
08/25/2024 08:00	1.0	1.4	-1	0.47	0.23256	0.78
08/25/2024 09:00	1.0	1.4	-1	0.47	0.23256	0.78
08/25/2024 10:00	0.9	1.4	-1	0.46	0.23244	0.77
08/25/2024 11:00	0.9	1.4	-1	0.46	0.23130	0.77
08/25/2024 12:00	0.9	1.3	-1	0.46	0.23052	0.77
08/25/2024 13:00	0.9	1.3	-1	0.46	0.23052	0.77
08/25/2024 14:00	0.9	1.4	-1	0.46	0.23010	0.77
08/25/2024 15:00	0.9	1.4	-1	0.46	0.23022	0.77
08/25/2024 16:00	0.8	1.3	-1	0.47	0.23262	0.78
08/25/2024 17:00	0.9	1.3	-1	0.51	0.25692	0.86
08/25/2024 18:00	0.9	1.4	-1	0.55	0.27672	0.92
08/25/2024 19:00	0.9	1.3	-1	0.55	0.27636	0.92
08/25/2024 20:00	0.9	1.3	-1	0.53	0.26292	0.88
08/25/2024 21:00	0.9	1.4	-1	0.46	0.23100	0.77
08/25/2024 22:00	1.0	1.3	-1	0.46	0.23142	0.77
08/25/2024 23:00	1.0	1.3	-1	0.47	0.23538	0.78
Average/Sum#:	1.0	1.4	-1	0.48	0.23815	0.80
Minimum:	0.8	1.3	-1	0.46	0.23010	0.77
Maximum:	1.2	1.4	0	0.55	0.27672	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/26/2024 00:00	1.0	1.3	-1	0.46	0.23166	0.77
08/26/2024 01:00	1.0	1.4	-1	0.46	0.23178	0.77
08/26/2024 02:00	0.9	1.4	-1	0.46	0.23178	0.77
08/26/2024 03:00	1.0	1.5	-1	0.46	0.23190	0.77
08/26/2024 04:00	0.9	1.3	-1	0.51	0.25320	0.84
08/26/2024 05:00	0.9	1.4	-1	0.55	0.27504	0.92
08/26/2024 06:00	1.0	1.3	-1	0.47	0.23694	0.79
08/26/2024 07:00	1.0	1.3	-1	0.47	0.23328	0.78
08/26/2024 08:00	1.0	1.3	-1	0.47	0.23304	0.78
08/26/2024 09:00	0.9	1.4	-1	0.46	0.23208	0.77
08/26/2024 10:00	0.9	1.3	-1	0.46	0.23040	0.77
08/26/2024 11:00	0.9	1.4	-1	0.46	0.22998	0.77
08/26/2024 12:00	0.9	1.4	-1	0.46	0.22962	0.77
08/26/2024 13:00	0.9	1.4	-1	0.46	0.22944	0.76
08/26/2024 14:00	0.9	1.2	-1	0.46	0.22908	0.76
08/26/2024 15:00	0.9	1.2	-1	0.46	0.22896	0.76
08/26/2024 16:00	0.9	1.2	-1	0.48	0.24066	0.80
08/26/2024 17:00	0.8	1.3	-1	0.51	0.25566	0.85
08/26/2024 18:00	0.9	1.3	-1	0.52	0.26220	0.87
08/26/2024 19:00	0.9	1.3	-1	0.48	0.24030	0.80
08/26/2024 20:00	0.9	1.3	-1	0.47	0.23640	0.79
08/26/2024 21:00	1.0	1.3	-1	0.46	0.22998	0.77
08/26/2024 22:00	1.0	1.4	-1	0.46	0.22998	0.77
08/26/2024 23:00	1.0	1.3	-1	0.46	0.23028	0.77
Average/Sum#:	0.9	1.3	-1	0.47	0.23724	0.79
Minimum:	0.8	1.2	-1	0.46	0.22896	0.76
Maximum:	1.0	1.5	-1	0.55	0.27504	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/27/2024 00:00	1.0	1.4	-1	0.46	0.23040	0.77
08/27/2024 01:00	0.9	1.4	-1	0.46	0.23058	0.77
08/27/2024 02:00	0.9	1.2	-1	0.46	0.23058	0.77
08/27/2024 03:00	1.0	1.4	-1	0.46	0.23064	0.77
08/27/2024 04:00	1.0	1.3	-1	0.46	0.23070	0.77
08/27/2024 05:00	1.0	1.4	-1	0.46	0.23088	0.77
08/27/2024 06:00	1.0	1.4	-1	0.46	0.23124	0.77
08/27/2024 07:00	1.1	1.3	-1	0.46	0.23094	0.77
08/27/2024 08:00	1.0	1.4	-1	0.46	0.23058	0.77
08/27/2024 09:00	1.0	1.3	-1	0.46	0.23034	0.77
08/27/2024 10:00	0.9	1.4	-1	0.46	0.23004	0.77
08/27/2024 11:00	0.9	1.3	-1	0.46	0.22956	0.77
08/27/2024 12:00	0.9	1.2	-1	0.46	0.22938	0.76
08/27/2024 13:00	0.9	1.3	-1	0.46	0.22908	0.76
08/27/2024 14:00	0.9	1.3	-1	0.46	0.22884	0.76
08/27/2024 15:00	0.9	1.3	-1	0.46	0.22884	0.76
08/27/2024 16:00	0.9	1.3	-1	0.46	0.23040	0.77
08/27/2024 17:00	0.9	1.2	-1	0.49	0.24630	0.82
08/27/2024 18:00	0.9	1.3	-1	0.53	0.26448	0.88
08/27/2024 19:00	0.9	1.2	-1	0.46	0.22944	0.76
08/27/2024 20:00	1.0	1.3	-1	0.46	0.22986	0.77
08/27/2024 21:00	1.0	1.3	-1	0.46	0.22986	0.77
08/27/2024 22:00	1.0	1.3	-1	0.46	0.23022	0.77
08/27/2024 23:00	1.0	1.3	-1	0.46	0.23064	0.77
Average/Sum#:	1.0	1.3	-1	0.46	0.23224	0.77
Minimum:	0.9	1.2	-1	0.46	0.22884	0.76
Maximum:	1.1	1.4	-1	0.53	0.26448	0.88
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/28/2024 00:00	1.0	1.3	-1	0.46	0.23088	0.77
08/28/2024 01:00	0.9	1.4	-1	0.46	0.23094	0.77
08/28/2024 02:00	0.9	1.3	-1	0.46	0.23100	0.77
08/28/2024 03:00	1.0	1.4	-1	0.46	0.23106	0.77
08/28/2024 04:00	0.9	1.3	-1	0.47	0.23418	0.78
08/28/2024 05:00	1.0	1.3	-1	0.52	0.25986	0.87
08/28/2024 06:00	1.1	1.3	-1	0.48	0.23868	0.80
08/28/2024 07:00	1.1	1.3	-1	0.46	0.23148	0.77
08/28/2024 08:00	1.0	1.2	-1	0.46	0.23142	0.77
08/28/2024 09:00	1.0	1.4	-1	0.46	0.23112	0.77
08/28/2024 10:00	1.0	1.4	-1	0.46	0.23118	0.77
08/28/2024 11:00	1.0	1.2	-1	0.46	0.22950	0.77
08/28/2024 12:00	0.9	1.3	-1	0.46	0.22908	0.76
08/28/2024 13:00	0.9	1.2	-1	0.46	0.22896	0.76
08/28/2024 14:00	0.9	1.2	-1	0.46	0.22860	0.76
08/28/2024 15:00	0.9	1.2	-1	0.46	0.22860	0.76
08/28/2024 16:00	0.9	1.2	-1	0.46	0.23010	0.77
08/28/2024 17:00	0.9	1.2	-1	0.46	0.23004	0.77
08/28/2024 18:00	0.9	1.2	-1	0.46	0.22962	0.77
08/28/2024 19:00	0.9	1.4	-1	0.46	0.22890	0.76
08/28/2024 20:00	0.9	1.4	-1	0.46	0.22968	0.77
08/28/2024 21:00	1.0	1.3	-1	0.46	0.23040	0.77
08/28/2024 22:00	0.9	1.3	-1	0.46	0.23106	0.77
08/28/2024 23:00	0.9	1.4	-1	0.46	0.23124	0.77
Average/Sum#:	1.0	1.3	-1	0.46	0.23198	0.77
Minimum:	0.9	1.2	-1	0.46	0.22860	0.76
Maximum:	1.1	1.4	-1	0.52	0.25986	0.87
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/29/2024 00:00	1.0	1.3	-1	0.46	0.23124	0.77
08/29/2024 01:00	1.0	1.4	-1	0.46	0.23106	0.77
08/29/2024 02:00	1.0	1.3	-1	0.47	0.23322	0.78
08/29/2024 03:00	1.0	1.3	-1	0.46	0.23070	0.77
08/29/2024 04:00	1.0	1.3	-1	0.46	0.23070	0.77
08/29/2024 05:00	0.9	1.4	-1	0.46	0.23100	0.77
08/29/2024 06:00	0.9	1.3	-1	0.59	0.29346	0.98
08/29/2024 07:00	0.9	1.3	-1	0.60	0.29832	0.99
08/29/2024 08:00	0.9	1.3	-1	0.59	0.29700	0.99
08/29/2024 09:00	0.9	1.3	-1	0.51	0.25290	0.84
08/29/2024 10:00	0.9	1.4	-1	0.47	0.23256	0.78
08/29/2024 11:00	0.9	1.4	-1	0.46	0.22932	0.76
08/29/2024 12:00	0.9	1.3	-1	0.46	0.22914	0.76
08/29/2024 13:00	0.9	1.3	-1	0.46	0.22902	0.76
08/29/2024 14:00	0.9	1.3	-1	0.46	0.22878	0.76
08/29/2024 15:00	0.9	1.3	-1	0.46	0.22854	0.76
08/29/2024 16:00	0.9	1.1	-1	0.46	0.22830	0.76
08/29/2024 17:00	0.9	1.2	-1	0.46	0.22854	0.76
08/29/2024 18:00	0.9	1.4	-1	0.46	0.22908	0.76
08/29/2024 19:00	0.9	1.3	-1	0.46	0.22962	0.77
08/29/2024 20:00	0.9	1.3	-1	0.46	0.23004	0.77
08/29/2024 21:00	1.0	1.4	-1	0.46	0.23040	0.77
08/29/2024 22:00	0.9	1.3	-1	0.46	0.23070	0.77
08/29/2024 23:00	0.9	1.3	-1	0.46	0.23088	0.77
Average/Sum#:	0.9	1.3	-1	0.48	0.23936	0.80
Minimum:	0.9	1.1	-1	0.46	0.22830	0.76
Maximum:	1.0	1.4	-1	0.60	0.29832	0.99
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/30/2024 00:00	0.9	1.3	-1	0.46	0.23100	0.77
08/30/2024 01:00	1.0	1.3	-1	0.46	0.23118	0.77
08/30/2024 02:00	1.0	1.4	-1	0.46	0.23130	0.77
08/30/2024 03:00	1.0	1.4	-1	0.46	0.23142	0.77
08/30/2024 04:00	1.0	1.4	-1	0.46	0.23196	0.77
08/30/2024 05:00	1.0	1.3	-1	0.46	0.23148	0.77
08/30/2024 06:00	1.0	1.3	-1	0.46	0.23154	0.77
08/30/2024 07:00	1.0	1.4	-1	0.46	0.23142	0.77
08/30/2024 08:00	0.9	1.3	-1	0.46	0.23106	0.77
08/30/2024 09:00	0.9	1.3	-1	0.46	0.23070	0.77
08/30/2024 10:00	0.9	1.4	-1	0.46	0.23040	0.77
08/30/2024 11:00	0.9	1.3	-1	0.46	0.22986	0.77
08/30/2024 12:00	0.9	1.3	-1	0.46	0.22944	0.76
08/30/2024 13:00	0.9	1.2	-1	0.46	0.22932	0.76
08/30/2024 14:00	0.9	1.1	-1	0.46	0.22908	0.76
08/30/2024 15:00	0.9	1.3	-1	0.46	0.22896	0.76
08/30/2024 16:00	0.9	1.3	-1	0.47	0.23274	0.78
08/30/2024 17:00	0.9	1.4	-1	0.46	0.22920	0.76
08/30/2024 18:00	0.9	1.4	-1	0.46	0.22950	0.77
08/30/2024 19:00	0.9	1.3	-1	0.46	0.23004	0.77
08/30/2024 20:00	0.9	1.4	-1	0.46	0.23034	0.77
08/30/2024 21:00	0.9	1.3	-1	0.46	0.23202	0.77
08/30/2024 22:00	1.0	1.3	-1	0.46	0.23076	0.77
08/30/2024 23:00	1.0	1.4	-1	0.46	0.23118	0.77
Average/Sum#:	0.9	1.3	-1	0.46	0.23066	0.77
Minimum:	0.9	1.1	-1	0.46	0.22896	0.76
Maximum:	1.0	1.4	-1	0.47	0.23274	0.78
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/31/2024 00:00	1.0	1.4	-1	0.46	0.23160	0.77
08/31/2024 01:00	1.0	1.3	-1	0.46	0.23112	0.77
08/31/2024 02:00	1.0	1.4	-1	0.46	0.23130	0.77
08/31/2024 03:00	1.0	1.4	-1	0.46	0.23124	0.77
08/31/2024 04:00	1.0	1.4	-1	0.46	0.23142	0.77
08/31/2024 05:00	1.0	1.4	-1	0.46	0.23136	0.77
08/31/2024 06:00	1.0	1.4	-1	0.46	0.23136	0.77
08/31/2024 07:00	1.0	1.3	-1	0.46	0.23130	0.77
08/31/2024 08:00	0.9	1.4	-1	0.46	0.23094	0.77
08/31/2024 09:00	1.0	1.3	-1	0.46	0.23064	0.77
08/31/2024 10:00	0.9	1.3	-1	0.46	0.23028	0.77
08/31/2024 11:00	0.9	1.3	-1	0.46	0.23010	0.77
08/31/2024 12:00	0.9	1.2	-1	0.46	0.23004	0.77
08/31/2024 13:00	0.9	1.2	-1	0.46	0.23034	0.77
08/31/2024 14:00	0.9	1.2	-1	0.46	0.23022	0.77
08/31/2024 15:00	0.9	1.3	-1	0.47	0.23544	0.78
08/31/2024 16:00	0.9	1.3	0	0.54	0.26772	0.89
08/31/2024 17:00	0.4	1.4	0	0.75	0.37458	1.25
08/31/2024 18:00	0.4	1.4	0	0.74	0.37158	1.24
08/31/2024 19:00	0.4	1.4	0	0.76	0.37782	1.26
08/31/2024 20:00	0.8	1.4	0	0.64	0.31986	1.07
08/31/2024 21:00	0.9	1.3	-1	0.55	0.27612	0.92
08/31/2024 22:00	0.9	1.3	-1	0.55	0.27714	0.92
08/31/2024 23:00	1.2	1.4	0	0.55	0.27396	0.91
Average/Sum#:	0.9	1.3	-1	0.52	0.25990	0.87
Minimum:	0.4	1.2	-1	0.46	0.23004	0.77
Maximum:	1.2	1.4	0	0.76	0.37782	1.26
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/01/2024 00:00	0.9	1.3	-1	0.47	0.23358	0.78
09/01/2024 01:00	1.0	1.4	-1	0.46	0.23130	0.77
09/01/2024 02:00	1.0	1.3	-1	0.46	0.23136	0.77
09/01/2024 03:00	1.0	1.4	-1	0.46	0.23166	0.77
09/01/2024 04:00	1.0	1.4	-1	0.46	0.23166	0.77
09/01/2024 05:00	1.0	1.3	-1	0.46	0.23190	0.77
09/01/2024 06:00	0.9	1.3	-1	0.46	0.23178	0.77
09/01/2024 07:00	0.9	1.4	-1	0.46	0.23160	0.77
09/01/2024 08:00	1.0	1.3	-1	0.46	0.23136	0.77
09/01/2024 09:00	0.9	1.3	-1	0.46	0.23070	0.77
09/01/2024 10:00	0.9	1.4	-1	0.46	0.23034	0.77
09/01/2024 11:00	0.9	1.4	-1	0.46	0.22980	0.77
09/01/2024 12:00	0.9	1.4	-1	0.46	0.22944	0.76
09/01/2024 13:00	0.9	1.2	-1	0.46	0.22914	0.76
09/01/2024 14:00	0.9	1.3	-1	0.46	0.22896	0.76
09/01/2024 15:00	0.9	1.3	-1	0.46	0.22944	0.76
09/01/2024 16:00	0.9	1.3	-1	0.47	0.23742	0.79
09/01/2024 17:00	0.9	1.3	-1	0.49	0.24582	0.82
09/01/2024 18:00	0.9	1.3	-1	0.46	0.22986	0.77
09/01/2024 19:00	0.9	1.4	-1	0.46	0.22956	0.77
09/01/2024 20:00	0.9	1.3	-1	0.46	0.23010	0.77
09/01/2024 21:00	1.0	1.3	-1	0.47	0.23448	0.78
09/01/2024 22:00	0.9	1.3	-1	0.47	0.23268	0.78
09/01/2024 23:00	1.0	1.3	-1	0.47	0.23460	0.78
Average/Sum#:	0.9	1.3	-1	0.46	0.23202	0.77
Minimum:	0.9	1.2	-1	0.46	0.22896	0.76
Maximum:	1.0	1.4	-1	0.49	0.24582	0.82
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/02/2024 00:00	1.0	1.3	-1	0.47	0.23730	0.79
09/02/2024 01:00	1.0	1.4	-1	0.46	0.23094	0.77
09/02/2024 02:00	0.9	1.3	0	0.46	0.23124	0.77
09/02/2024 03:00	1.0	1.4	0	0.46	0.23136	0.77
09/02/2024 04:00	1.0	1.3	0	0.46	0.23142	0.77
09/02/2024 05:00	1.0	1.4	0	0.46	0.23172	0.77
09/02/2024 06:00	1.0	1.4	0	0.46	0.23172	0.77
09/02/2024 07:00	1.0	1.3	-1	0.46	0.23136	0.77
09/02/2024 08:00	1.0	1.4	-1	0.46	0.23154	0.77
09/02/2024 09:00	1.0	1.4	-1	0.46	0.23112	0.77
09/02/2024 10:00	0.9	1.4	-1	0.46	0.23052	0.77
09/02/2024 11:00	0.9	1.4	-1	0.46	0.22986	0.77
09/02/2024 12:00	0.9	1.4	0	0.46	0.22974	0.77
09/02/2024 13:00	0.9	1.4	0	0.46	0.22950	0.77
09/02/2024 14:00	0.9	1.3	-1	0.48	0.23898	0.80
09/02/2024 15:00	0.9	1.3	-1	0.47	0.23448	0.78
09/02/2024 16:00	0.9	1.3	-1	0.50	0.25152	0.84
09/02/2024 17:00	0.9	1.3	-1	0.51	0.25638	0.85
09/02/2024 18:00	0.9	1.2	-1	0.52	0.25866	0.86
09/02/2024 19:00	0.9	1.3	-1	0.48	0.24072	0.80
09/02/2024 20:00	0.9	1.3	-1	0.48	0.23826	0.79
09/02/2024 21:00	1.0	1.4	-1	0.46	0.23052	0.77
09/02/2024 22:00	0.9	1.3	-1	0.46	0.23070	0.77
09/02/2024 23:00	1.0	1.4	-1	0.46	0.23088	0.77
Average/Sum#:	0.9	1.3	-1	0.47	0.23544	0.78
Minimum:	0.9	1.2	-1	0.46	0.22950	0.77
Maximum:	1.0	1.4	0	0.52	0.25866	0.86
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/03/2024 00:00	1.0	1.4	-1	0.46	0.23106	0.77
09/03/2024 01:00	1.0	1.3	-1	0.46	0.23094	0.77
09/03/2024 02:00	1.1	1.3	-1	0.46	0.23142	0.77
09/03/2024 03:00	1.2	1.3	-1	0.46	0.23136	0.77
09/03/2024 04:00	1.1	1.3	-1	0.46	0.23118	0.77
09/03/2024 05:00	1.1	1.4	-1	0.50	0.24816	0.83
09/03/2024 06:00	1.1	1.3	0	0.48	0.23778	0.79
09/03/2024 07:00	1.0	1.3	-1	0.48	0.24240	0.81
09/03/2024 08:00	1.0	1.3	-1	0.46	0.23058	0.77
09/03/2024 09:00	1.0	1.3	-1	0.46	0.22980	0.77
09/03/2024 10:00	1.0	1.4	-1	0.46	0.22944	0.76
09/03/2024 11:00	1.0	1.4	-1	0.46	0.22914	0.76
09/03/2024 12:00	0.9	1.2	-1	0.46	0.22860	0.76
09/03/2024 13:00	0.9	1.3	-1	0.51	0.25338	0.84
09/03/2024 14:00	0.9	1.3	-1	0.53	0.26484	0.88
09/03/2024 15:00	0.9	1.3	-1	0.52	0.25824	0.86
09/03/2024 16:00	0.9	1.3	0	0.58	0.29124	0.97
09/03/2024 17:00	0.4	1.5	0	0.76	0.37812	1.26
09/03/2024 18:00	0.4	1.5	0	0.76	0.38124	1.27
09/03/2024 19:00	0.8	1.4	-1	0.64	0.32100	1.07
09/03/2024 20:00	0.9	1.3	-1	0.57	0.28494	0.95
09/03/2024 21:00	0.9	1.3	-1	0.57	0.28506	0.95
09/03/2024 22:00	1.0	1.3	-1	0.51	0.25548	0.85
09/03/2024 23:00	1.0	1.3	-1	0.56	0.27984	0.93
Average/Sum#:	0.9	1.3	-1	0.52	0.26189	0.87
Minimum:	0.4	1.2	-1	0.46	0.22860	0.76
Maximum:	1.2	1.5	0	0.76	0.38124	1.27
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/04/2024 00:00	1.1	1.4	-1	0.51	0.25416	0.85
09/04/2024 01:00	1.1	1.3	-1	0.51	0.25434	0.85
09/04/2024 02:00	1.2	1.3	-1	0.47	0.23292	0.78
09/04/2024 03:00	1.1	1.3	-1	0.53	0.26592	0.89
09/04/2024 04:00	1.2	1.2	-1	0.54	0.26832	0.89
09/04/2024 05:00	1.2	1.4	-1	0.57	0.28278	0.94
09/04/2024 06:00	1.3	1.4	-1	0.48	0.24198	0.81
09/04/2024 07:00	1.3	1.4	-1	0.46	0.23196	0.77
09/04/2024 08:00	1.1	1.4	-1	0.46	0.23136	0.77
09/04/2024 09:00	1.0	1.3	-1	0.46	0.23076	0.77
09/04/2024 10:00	0.9	1.2	-1	0.46	0.23016	0.77
09/04/2024 11:00	0.9	1.1	-1	0.46	0.22986	0.77
09/04/2024 12:00	0.9	0.0	-1	0.46	0.22962	0.77
09/04/2024 13:00	0.9	0.0	-1	0.50	0.25020	0.83
09/04/2024 14:00	0.9	0.8	0	0.52	0.26100	0.87
09/04/2024 15:00	0.9	1.3	-1	0.46	0.23220	0.77
09/04/2024 16:00	0.8	1.4	0	0.58	0.28848	0.96
09/04/2024 17:00	0.3	1.5	1	0.78	0.39204	1.31
09/04/2024 18:00	0.3	1.5	0	0.77	0.38490	1.28
09/04/2024 19:00	0.4	1.5	0	0.76	0.37848	1.26
09/04/2024 20:00	0.4	1.5	0	0.76	0.37836	1.26
09/04/2024 21:00	0.4	1.5	0	0.75	0.37626	1.25
09/04/2024 22:00	0.5	1.4	0	0.74	0.36936	1.23
09/04/2024 23:00	0.8	1.3	0	0.65	0.32280	1.08
Average/Sum#:	0.9	1.3	-1	0.57	0.28409	0.95
Minimum:	0.3	0.8	-1	0.46	0.22962	0.77
Maximum:	1.3	1.5	1	0.78	0.39204	1.31
%SI	0.00	8.33	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/05/2024 00:00	1.0	1.3	-1	0.51	0.25476	0.85
09/05/2024 01:00	1.0	1.4	-1	0.48	0.23766	0.79
09/05/2024 02:00	1.0	1.3	-1	0.46	0.23184	0.77
09/05/2024 03:00	1.0	1.4	-1	0.46	0.23184	0.77
09/05/2024 04:00	1.0	1.3	-1	0.50	0.25008	0.83
09/05/2024 05:00	0.9	1.3	-1	0.56	0.27762	0.93
09/05/2024 06:00	1.0	1.3	-1	0.50	0.24852	0.83
09/05/2024 07:00	1.0	1.4	-1	0.46	0.23178	0.77
09/05/2024 08:00	0.9	1.4	-1	0.46	0.23148	0.77
09/05/2024 09:00	0.9	1.3	-1	0.48	0.23784	0.79
09/05/2024 10:00	0.9	1.2	0	0.53	0.26418	0.88
09/05/2024 11:00	0.9	1.2	-1	0.49	0.24474	0.82
09/05/2024 12:00	0.8	1.4	-1	0.56	0.27834	0.93
09/05/2024 13:00	0.8	1.3	0	0.60	0.29820	0.99
09/05/2024 14:00	0.3	1.5	1	0.78	0.39096	1.30
09/05/2024 15:00	0.4	1.5	0	0.74	0.37236	1.24
09/05/2024 16:00	0.4	1.5	0	0.75	0.37746	1.26
09/05/2024 17:00	0.3	1.5	1	0.78	0.38754	1.29
09/05/2024 18:00	0.4	1.5	0	0.77	0.38400	1.28
09/05/2024 19:00	0.4	1.5	0	0.76	0.37800	1.26
09/05/2024 20:00	0.4	1.5	0	0.75	0.37410	1.25
09/05/2024 21:00	0.4	1.5	0	0.74	0.36930	1.23
09/05/2024 22:00	0.5	1.4	0	0.72	0.36126	1.20
09/05/2024 23:00	0.7	1.4	0	0.70	0.34830	1.16
Average/Sum#:	0.7	1.4	0	0.61	0.30259	1.01
Minimum:	0.3	1.2	-1	0.46	0.23148	0.77
Maximum:	1.0	1.5	1	0.78	0.39096	1.30
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/06/2024 00:00	1.0	1.3	-1	0.51	0.25386	0.85
09/06/2024 01:00	1.0	1.3	-1	0.46	0.23130	0.77
09/06/2024 02:00	0.9	1.4	-1	0.46	0.23124	0.77
09/06/2024 03:00	1.0	1.3	-1	0.46	0.23154	0.77
09/06/2024 04:00	0.9	1.3	-1	0.50	0.24780	0.83
09/06/2024 05:00	0.9	1.3	-1	0.55	0.27612	0.92
09/06/2024 06:00	0.9	1.3	-1	0.52	0.26088	0.87
09/06/2024 07:00	1.0	1.3	-1	0.51	0.25482	0.85
09/06/2024 08:00	1.0	1.4	-1	0.46	0.23112	0.77
09/06/2024 09:00	1.0	1.3	-1	0.46	0.23058	0.77
09/06/2024 10:00	1.0	1.2	-1	0.46	0.23028	0.77
09/06/2024 11:00	0.9	1.3	-1	0.48	0.23784	0.79
09/06/2024 12:00	0.8	1.3	-1	0.54	0.26850	0.90
09/06/2024 13:00	0.8	1.4	0	0.60	0.30138	1.00
09/06/2024 14:00	0.3	1.5	0	0.77	0.38274	1.28
09/06/2024 15:00	0.3	1.5	1	0.78	0.38880	1.30
09/06/2024 16:00	0.4	1.4	0	0.74	0.37080	1.24
09/06/2024 17:00	0.3	1.5	1	0.78	0.38868	1.30
09/06/2024 18:00	0.3	1.5	1	0.79	0.39450	1.32
09/06/2024 19:00	0.4	1.5	0	0.75	0.37572	1.25
09/06/2024 20:00	0.4	1.5	0	0.75	0.37500	1.25
09/06/2024 21:00	0.4	1.5	0	0.76	0.38226	1.27
09/06/2024 22:00	0.4	1.4	0	0.75	0.37734	1.26
09/06/2024 23:00	0.4	1.5	0	0.76	0.38244	1.27
Average/Sum#:	0.7	1.4	0	0.61	0.30440	1.02
Minimum:	0.3	1.2	-1	0.46	0.23028	0.77
Maximum:	1.0	1.5	1	0.79	0.39450	1.32
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/07/2024 00:00	0.5	1.5	0	0.75	0.37506	1.25
09/07/2024 01:00	0.9	1.4	0	0.64	0.31860	1.06
09/07/2024 02:00	1.0	1.3	0	0.47	0.23292	0.78
09/07/2024 03:00	1.0	1.4	-1	0.47	0.23472	0.78
09/07/2024 04:00	1.0	1.4	-1	0.46	0.23202	0.77
09/07/2024 05:00	0.9	1.3	-1	0.46	0.23106	0.77
09/07/2024 06:00	1.0	1.3	-1	0.46	0.23100	0.77
09/07/2024 07:00	1.0	1.4	-1	0.46	0.23112	0.77
09/07/2024 08:00	0.9	1.4	-1	0.46	0.23070	0.77
09/07/2024 09:00	0.9	1.3	-1	0.46	0.23034	0.77
09/07/2024 10:00	0.9	1.4	-1	0.46	0.22998	0.77
09/07/2024 11:00	0.9	1.4	-1	0.46	0.22980	0.77
09/07/2024 12:00	0.9	1.3	-1	0.52	0.26064	0.87
09/07/2024 13:00	0.8	1.3	-1	0.57	0.28440	0.95
09/07/2024 14:00	0.7	1.4	0	0.70	0.34758	1.16
09/07/2024 15:00	0.6	1.4	0	0.69	0.34602	1.15
09/07/2024 16:00	0.7	1.4	0	0.67	0.33618	1.12
09/07/2024 17:00	0.4	1.5	0	0.75	0.37416	1.25
09/07/2024 18:00	0.4	1.5	0	0.76	0.37782	1.26
09/07/2024 19:00	0.4	1.5	0	0.74	0.37224	1.24
09/07/2024 20:00	0.4	1.5	0	0.75	0.37722	1.26
09/07/2024 21:00	0.4	1.5	0	0.75	0.37698	1.26
09/07/2024 22:00	0.4	1.5	0	0.76	0.37860	1.26
09/07/2024 23:00	0.7	1.5	0	0.72	0.35988	1.20
Average/Sum#:	0.7	1.4	0	0.60	0.29996	1.00
Minimum:	0.4	1.3	-1	0.46	0.22980	0.77
Maximum:	1.0	1.5	0	0.76	0.37860	1.26
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/08/2024 00:00	1.0	1.2	-1	0.52	0.25980	0.87
09/08/2024 01:00	1.1	1.4	-1	0.47	0.23274	0.78
09/08/2024 02:00	1.1	1.2	-1	0.47	0.23304	0.78
09/08/2024 03:00	1.1	1.4	-1	0.47	0.23322	0.78
09/08/2024 04:00	1.0	1.4	-1	0.47	0.23334	0.78
09/08/2024 05:00	1.0	1.4	-1	0.47	0.23346	0.78
09/08/2024 06:00	1.0	1.4	-1	0.47	0.23316	0.78
09/08/2024 07:00	1.1	1.4	-1	0.46	0.23232	0.77
09/08/2024 08:00	1.0	1.4	-1	0.46	0.23184	0.77
09/08/2024 09:00	1.0	1.4	-1	0.46	0.23112	0.77
09/08/2024 10:00	0.9	1.4	-1	0.46	0.23058	0.77
09/08/2024 11:00	0.9	1.2	-1	0.46	0.23028	0.77
09/08/2024 12:00	0.9	1.2	-1	0.47	0.23580	0.79
09/08/2024 13:00	0.9	1.4	-1	0.55	0.27336	0.91
09/08/2024 14:00	0.6	1.4	0	0.71	0.35712	1.19
09/08/2024 15:00	0.4	1.4	0	0.74	0.36936	1.23
09/08/2024 16:00	0.3	1.5	1	0.78	0.38760	1.29
09/08/2024 17:00	0.3	1.5	1	0.79	0.39342	1.31
09/08/2024 18:00	0.3	1.5	0	0.77	0.38664	1.29
09/08/2024 19:00	0.4	1.5	0	0.76	0.38232	1.27
09/08/2024 20:00	0.4	1.5	0	0.76	0.38016	1.27
09/08/2024 21:00	0.9	1.4	0	0.64	0.31860	1.06
09/08/2024 22:00	1.0	1.2	-1	0.53	0.26454	0.88
09/08/2024 23:00	1.0	1.3	-1	0.49	0.24594	0.82
Average/Sum#:	0.8	1.4	-1	0.57	0.28374	0.95
Minimum:	0.3	1.2	-1	0.46	0.23028	0.77
Maximum:	1.1	1.5	1	0.79	0.39342	1.31
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/09/2024 00:00	1.1	1.3	-1	0.47	0.23280	0.78
09/09/2024 01:00	1.1	1.4	-1	0.46	0.23238	0.77
09/09/2024 02:00	1.2	1.4	-1	0.47	0.23292	0.78
09/09/2024 03:00	1.3	1.4	-1	0.47	0.23268	0.78
09/09/2024 04:00	1.4	1.4	-1	0.49	0.24708	0.82
09/09/2024 05:00	1.2	1.4	-1	0.55	0.27252	0.91
09/09/2024 06:00	1.3	1.3	-1	0.48	0.23916	0.80
09/09/2024 07:00	1.3	1.3	-1	0.47	0.23388	0.78
09/09/2024 08:00	1.1	1.3	-1	0.47	0.23328	0.78
09/09/2024 09:00	1.0	1.4	-1	0.46	0.23148	0.77
09/09/2024 10:00	1.0	1.3	-1	0.46	0.23160	0.77
09/09/2024 11:00	0.9	1.3	-1	0.46	0.23058	0.77
09/09/2024 12:00	0.9	1.3	-1	0.48	0.24060	0.80
09/09/2024 13:00	0.9	1.2	-1	0.48	0.24066	0.80
09/09/2024 14:00	0.9	1.3	-1	0.46	0.22980	0.77
09/09/2024 15:00	0.9	1.3	-1	0.49	0.24414	0.81
09/09/2024 16:00	0.9	1.2	-1	0.52	0.26232	0.87
09/09/2024 17:00	0.8	1.3	0	0.58	0.28854	0.96
09/09/2024 18:00	0.5	1.4	0	0.72	0.36054	1.20
09/09/2024 19:00	0.9	1.3	0	0.57	0.28590	0.95
09/09/2024 20:00	1.0	1.2	-1	0.48	0.24186	0.81
09/09/2024 21:00	1.0	1.3	-1	0.47	0.23718	0.79
09/09/2024 22:00	1.0	1.3	-1	0.46	0.23196	0.77
09/09/2024 23:00	0.9	1.2	-1	0.52	0.26046	0.87
Average/Sum#:	1.0	1.3	-1	0.50	0.24893	0.83
Minimum:	0.5	1.2	-1	0.46	0.22980	0.77
Maximum:	1.4	1.4	0	0.72	0.36054	1.20
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/10/2024 00:00	1.0	1.3	0	0.48	0.24108	0.80
09/10/2024 01:00	1.0	1.4	-1	0.46	0.23226	0.77
09/10/2024 02:00	1.0	1.2	-1	0.46	0.23244	0.77
09/10/2024 03:00	1.0	1.4	-1	0.47	0.23250	0.78
09/10/2024 04:00	1.0	1.4	-1	0.47	0.23268	0.78
09/10/2024 05:00	1.0	1.3	-1	0.51	0.25614	0.85
09/10/2024 06:00	1.0	1.4	-1	0.47	0.23748	0.79
09/10/2024 07:00	1.0	1.4	-1	0.47	0.23298	0.78
09/10/2024 08:00	1.0	1.4	-1	0.47	0.23280	0.78
09/10/2024 09:00	1.0	1.4	-1	0.47	0.23256	0.78
09/10/2024 10:00	1.0	1.4	-1	0.46	0.23172	0.77
09/10/2024 11:00	0.9	1.4	-1	0.46	0.23100	0.77
09/10/2024 12:00	1.0	1.3	-1	0.46	0.23070	0.77
09/10/2024 13:00	1.0	1.4	-1	0.46	0.23082	0.77
09/10/2024 14:00	0.9	1.4	-1	0.46	0.23094	0.77
09/10/2024 15:00	0.9	1.3	-1	0.46	0.23076	0.77
09/10/2024 16:00	1.0	1.3	-1	0.46	0.23028	0.77
09/10/2024 17:00	0.9	1.3	-1	0.46	0.23022	0.77
09/10/2024 18:00	0.9	1.3	-1	0.46	0.23088	0.77
09/10/2024 19:00	1.0	1.3	-1	0.46	0.23154	0.77
09/10/2024 20:00	1.0	1.4	-1	0.46	0.23166	0.77
09/10/2024 21:00	1.0	1.4	-1	0.46	0.23172	0.77
09/10/2024 22:00	1.0	1.4	-1	0.46	0.23166	0.77
09/10/2024 23:00	1.0	1.3	-1	0.46	0.23184	0.77
Average/Sum#:	1.0	1.4	-1	0.47	0.23328	0.78
Minimum:	0.9	1.2	-1	0.46	0.23022	0.77
Maximum:	1.0	1.4	0	0.51	0.25614	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/11/2024 00:00	1.0	1.4	0	0.46	0.23190	0.77
09/11/2024 01:00	1.0	1.4	0	0.46	0.23196	0.77
09/11/2024 02:00	1.0	1.4	-1	0.46	0.23184	0.77
09/11/2024 03:00	1.0	1.4	-1	0.46	0.23178	0.77
09/11/2024 04:00	1.0	1.4	-1	0.46	0.23190	0.77
09/11/2024 05:00	0.9	1.3	-1	0.50	0.25134	0.84
09/11/2024 06:00	1.0	1.4	-1	0.48	0.24048	0.80
09/11/2024 07:00	1.0	1.4	-1	0.46	0.23184	0.77
09/11/2024 08:00	1.0	1.4	-1	0.46	0.23196	0.77
09/11/2024 09:00	1.1	1.3	-1	0.46	0.23178	0.77
09/11/2024 10:00	1.0	1.4	-1	0.46	0.23172	0.77
09/11/2024 11:00	1.0	1.3	-1	0.46	0.23142	0.77
09/11/2024 12:00	1.0	1.4	0	0.46	0.23106	0.77
09/11/2024 13:00	1.0	1.4	0	0.46	0.23046	0.77
09/11/2024 14:00	0.9	1.3	-1	0.46	0.22992	0.77
09/11/2024 15:00	1.0	1.4	-1	0.46	0.22986	0.77
09/11/2024 16:00	1.0	1.3	-1	0.46	0.23004	0.77
09/11/2024 17:00	1.0	1.3	-1	0.46	0.23004	0.77
09/11/2024 18:00	1.0	1.3	-1	0.46	0.23052	0.77
09/11/2024 19:00	1.0	1.3	-1	0.46	0.23076	0.77
09/11/2024 20:00	1.0	1.4	-1	0.46	0.23100	0.77
09/11/2024 21:00	1.0	1.4	-1	0.46	0.23112	0.77
09/11/2024 22:00	1.0	1.3	-1	0.46	0.23136	0.77
09/11/2024 23:00	1.0	1.3	-1	0.46	0.23154	0.77
Average/Sum#:	1.0	1.4	-1	0.46	0.23240	0.77
Minimum:	0.9	1.3	-1	0.46	0.22986	0.77
Maximum:	1.1	1.4	0	0.50	0.25134	0.84
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/12/2024 00:00	1.0	1.4	-1	0.46	0.23178	0.77
09/12/2024 01:00	1.0	1.4	-1	0.46	0.23178	0.77
09/12/2024 02:00	1.0	1.4	-1	0.46	0.23196	0.77
09/12/2024 03:00	1.0	1.4	-1	0.46	0.23202	0.77
09/12/2024 04:00	1.0	1.3	-1	0.46	0.23214	0.77
09/12/2024 05:00	1.1	1.4	0	0.46	0.23226	0.77
09/12/2024 06:00	1.5	1.4	0	0.46	0.23244	0.77
09/12/2024 07:00	0.8	1.3	0	0.46	0.23238	0.77
09/12/2024 08:00	0.8	1.4	-1	0.46	0.23244	0.77
09/12/2024 09:00	0.8	1.2	-1	0.46	0.23244	0.77
09/12/2024 10:00	0.8	1.4	-1	0.46	0.23220	0.77
09/12/2024 11:00	0.7	1.3	-1	0.46	0.23058	0.77
09/12/2024 12:00	0.7	1.3	-1	0.46	0.23058	0.77
09/12/2024 13:00	0.7	1.4	-1	0.46	0.23046	0.77
09/12/2024 14:00	0.7	1.3	-1	0.46	0.23034	0.77
09/12/2024 15:00	0.7	1.4	-1	0.46	0.23028	0.77
09/12/2024 16:00	0.7	1.3	-1	0.46	0.23022	0.77
09/12/2024 17:00	0.7	1.4	-1	0.46	0.23016	0.77
09/12/2024 18:00	0.7	1.4	0	0.46	0.23028	0.77
09/12/2024 19:00	0.7	1.3	-1	0.46	0.23052	0.77
09/12/2024 20:00	0.8	1.4	-1	0.46	0.23088	0.77
09/12/2024 21:00	0.8	1.3	-1	0.46	0.23142	0.77
09/12/2024 22:00	0.9	1.3	-1	0.46	0.23190	0.77
09/12/2024 23:00	0.9	1.3	-1	0.47	0.23286	0.78
Average/Sum#:	0.9	1.4	-1	0.46	0.23143	0.77
Minimum:	0.7	1.2	-1	0.46	0.23016	0.77
Maximum:	1.5	1.4	0	0.47	0.23286	0.78
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/13/2024 00:00	0.9	1.3	-1	0.46	0.23178	0.77
09/13/2024 01:00	0.8	1.3	-1	0.46	0.23160	0.77
09/13/2024 02:00	0.8	1.2	-1	0.46	0.23166	0.77
09/13/2024 03:00	0.8	1.3	-1	0.46	0.23160	0.77
09/13/2024 04:00	0.7	1.3	-1	0.47	0.23562	0.79
09/13/2024 05:00	0.8	1.3	-1	0.54	0.26844	0.89
09/13/2024 06:00	0.8	1.3	-1	0.51	0.25278	0.84
09/13/2024 07:00	0.8	1.4	-1	0.46	0.23214	0.77
09/13/2024 08:00	0.8	1.4	-1	0.46	0.23202	0.77
09/13/2024 09:00	0.8	1.4	-1	0.46	0.23118	0.77
09/13/2024 10:00	0.7	1.4	-1	0.46	0.23064	0.77
09/13/2024 11:00	0.7	1.3	-1	0.46	0.23178	0.77
09/13/2024 12:00	0.7	1.3	0	0.48	0.23946	0.80
09/13/2024 13:00	0.7	1.3	-1	0.52	0.26142	0.87
09/13/2024 14:00	0.7	1.3	-1	0.53	0.26526	0.88
09/13/2024 15:00	0.7	1.2	0	0.53	0.26286	0.88
09/13/2024 16:00	0.8	1.3	-1	0.57	0.28572	0.95
09/13/2024 17:00	0.2	1.5	0	0.80	0.39894	1.33
09/13/2024 18:00	0.3	1.4	0	0.78	0.38826	1.29
09/13/2024 19:00	0.8	1.3	0	0.53	0.26472	0.88
09/13/2024 20:00	0.8	1.3	-1	0.47	0.23406	0.78
09/13/2024 21:00	0.8	1.4	-1	0.46	0.23154	0.77
09/13/2024 22:00	0.8	1.3	-1	0.47	0.23604	0.79
09/13/2024 23:00	0.8	1.3	-1	0.50	0.25236	0.84
Average/Sum#:	0.7	1.3	-1	0.51	0.25675	0.85
Minimum:	0.2	1.2	-1	0.46	0.23064	0.77
Maximum:	0.9	1.5	0	0.80	0.39894	1.33
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/14/2024 00:00	0.8	1.3	-1	0.51	0.25440	0.85
09/14/2024 01:00	0.8	1.3	-1	0.47	0.23418	0.78
09/14/2024 02:00	0.8	1.3	-1	0.46	0.23136	0.77
09/14/2024 03:00	0.7	1.4	-1	0.55	0.27462	0.92
09/14/2024 04:00	0.8	1.3	-1	0.54	0.27198	0.91
09/14/2024 05:00	0.8	1.3	-1	0.58	0.29232	0.97
09/14/2024 06:00	0.8	1.4	-1	0.49	0.24444	0.81
09/14/2024 07:00	0.8	1.3	-1	0.46	0.23172	0.77
09/14/2024 08:00	0.8	1.3	-1	0.46	0.23130	0.77
09/14/2024 09:00	0.8	1.4	-1	0.46	0.23100	0.77
09/14/2024 10:00	0.8	1.4	-1	0.46	0.23070	0.77
09/14/2024 11:00	0.7	1.3	-1	0.46	0.23040	0.77
09/14/2024 12:00	0.7	1.2	-1	0.46	0.23106	0.77
09/14/2024 13:00	0.7	1.3	-1	0.46	0.23118	0.77
09/14/2024 14:00	0.7	1.2	-1	0.46	0.23124	0.77
09/14/2024 15:00	0.8	1.2	-1	0.46	0.23028	0.77
09/14/2024 16:00	0.7	1.3	-1	0.49	0.24348	0.81
09/14/2024 17:00	0.7	1.2	-1	0.54	0.27054	0.90
09/14/2024 18:00	0.7	1.3	-1	0.52	0.26028	0.87
09/14/2024 19:00	0.7	1.3	-1	0.46	0.23094	0.77
09/14/2024 20:00	0.8	1.3	-1	0.46	0.23058	0.77
09/14/2024 21:00	0.7	1.4	-1	0.46	0.23130	0.77
09/14/2024 22:00	0.8	1.3	-1	0.46	0.23202	0.77
09/14/2024 23:00	0.7	1.3	-1	0.46	0.23214	0.77
Average/Sum#:	0.8	1.3	-1	0.48	0.24223	0.81
Minimum:	0.7	1.2	-1	0.46	0.23028	0.77
Maximum:	0.8	1.4	-1	0.58	0.29232	0.97
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/15/2024 00:00	0.8	1.4	-1	0.46	0.23226	0.77
09/15/2024 01:00	0.8	1.3	-1	0.46	0.23232	0.77
09/15/2024 02:00	0.7	1.4	-1	0.47	0.23250	0.78
09/15/2024 03:00	0.8	1.4	-1	0.47	0.23262	0.78
09/15/2024 04:00	0.8	1.4	-1	0.47	0.23274	0.78
09/15/2024 05:00	0.8	1.3	-1	0.47	0.23292	0.78
09/15/2024 06:00	0.8	1.3	-1	0.47	0.23280	0.78
09/15/2024 07:00	0.7	1.3	-1	0.47	0.23274	0.78
09/15/2024 08:00	0.8	1.4	-1	0.47	0.23256	0.78
09/15/2024 09:00	0.7	1.3	-1	0.46	0.23220	0.77
09/15/2024 10:00	0.7	1.3	-1	0.46	0.23148	0.77
09/15/2024 11:00	0.7	1.4	-1	0.46	0.23082	0.77
09/15/2024 12:00	0.7	1.4	-1	0.46	0.23070	0.77
09/15/2024 13:00	0.7	1.3	-1	0.46	0.23064	0.77
09/15/2024 14:00	0.7	1.3	-1	0.46	0.23040	0.77
09/15/2024 15:00	0.7	1.3	-1	0.46	0.23064	0.77
09/15/2024 16:00	0.7	1.4	-1	0.49	0.24696	0.82
09/15/2024 17:00	0.7	1.3	-1	0.46	0.23142	0.77
09/15/2024 18:00	0.7	1.4	-1	0.46	0.23100	0.77
09/15/2024 19:00	0.7	1.3	-1	0.46	0.23130	0.77
09/15/2024 20:00	0.7	1.3	-1	0.46	0.23196	0.77
09/15/2024 21:00	0.7	1.3	-1	0.46	0.23166	0.77
09/15/2024 22:00	0.8	1.4	-1	0.46	0.23172	0.77
09/15/2024 23:00	0.7	1.3	0	0.46	0.23184	0.77
Average/Sum#:	0.7	1.3	-1	0.46	0.23243	0.78
Minimum:	0.7	1.3	-1	0.46	0.23040	0.77
Maximum:	0.8	1.4	0	0.49	0.24696	0.82
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/16/2024 00:00	0.8	1.4	0	0.46	0.23202	0.77
09/16/2024 01:00	0.8	1.4	0	0.46	0.23220	0.77
09/16/2024 02:00	0.8	1.3	0	0.47	0.23250	0.78
09/16/2024 03:00	0.8	1.4	0	0.47	0.23274	0.78
09/16/2024 04:00	0.9	1.4	0	0.47	0.23346	0.78
09/16/2024 05:00	0.8	1.3	0	0.51	0.25590	0.85
09/16/2024 06:00	0.8	1.3	0	0.51	0.25410	0.85
09/16/2024 07:00	0.7	1.3	-1	0.56	0.28086	0.94
09/16/2024 08:00	1.4	1.4	-1	0.60	0.30090	1.00
09/16/2024 09:00	0.8	1.3	-1	0.58	0.29070	0.97
09/16/2024 10:00	0.7	1.4	-1	0.58	0.29142	0.97
09/16/2024 11:00	0.7	1.3	-1	0.58	0.29112	0.97
09/16/2024 12:00	0.8	1.2	-1	0.52	0.25932	0.86
09/16/2024 13:00	0.8	1.4	-1	0.46	0.23136	0.77
09/16/2024 14:00	0.8	1.3	-1	0.46	0.23100	0.77
09/16/2024 15:00	0.7	1.4	-1	0.46	0.23130	0.77
09/16/2024 16:00	0.7	1.4	-1	0.50	0.24780	0.83
09/16/2024 17:00	0.7	1.3	-1	0.47	0.23454	0.78
09/16/2024 18:00	0.7	1.3	-1	0.47	0.23304	0.78
09/16/2024 19:00	0.7	1.3	-1	0.47	0.23328	0.78
09/16/2024 20:00	0.7	1.3	-1	0.55	0.27354	0.91
09/16/2024 21:00	0.8	1.3	-1	0.52	0.25908	0.86
09/16/2024 22:00	0.7	1.3	-1	0.54	0.27114	0.90
09/16/2024 23:00	0.8	1.3	-1	0.48	0.23880	0.80
Average/Sum#:	0.8	1.3	-1	0.51	0.25301	0.84
Minimum:	0.7	1.2	-1	0.46	0.23100	0.77
Maximum:	1.4	1.4	0	0.60	0.30090	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/17/2024 00:00	0.8	1.3	-1	0.46	0.23214	0.77
09/17/2024 01:00	0.8	1.3	-1	0.46	0.23238	0.77
09/17/2024 02:00	0.8	1.5	-1	0.46	0.23244	0.77
09/17/2024 03:00	0.8	1.3	-1	0.47	0.23262	0.78
09/17/2024 04:00	0.7	1.3	-1	0.49	0.24540	0.82
09/17/2024 05:00	0.7	1.3	-1	0.55	0.27330	0.91
09/17/2024 06:00	0.8	1.4	0	0.49	0.24522	0.82
09/17/2024 07:00	0.8	1.4	-1	0.47	0.23388	0.78
09/17/2024 08:00	0.8	1.3	-1	0.47	0.23418	0.78
09/17/2024 09:00	0.8	1.4	-1	0.47	0.23412	0.78
09/17/2024 10:00	0.8	1.3	-1	0.47	0.23352	0.78
09/17/2024 11:00	0.8	1.4	-1	0.47	0.23322	0.78
09/17/2024 12:00	0.7	1.3	-1	0.47	0.23406	0.78
09/17/2024 13:00	0.7	1.4	-1	0.47	0.23328	0.78
09/17/2024 14:00	0.7	1.3	-1	0.47	0.23274	0.78
09/17/2024 15:00	0.7	1.4	-1	0.47	0.23280	0.78
09/17/2024 16:00	0.7	1.4	-1	0.47	0.23262	0.78
09/17/2024 17:00	0.7	1.3	-1	0.47	0.23262	0.78
09/17/2024 18:00	0.7	1.4	-1	0.47	0.23268	0.78
09/17/2024 19:00	0.8	1.3	-1	0.47	0.23304	0.78
09/17/2024 20:00	0.8	1.3	-1	0.47	0.23292	0.78
09/17/2024 21:00	0.8	1.4	-1	0.47	0.23304	0.78
09/17/2024 22:00	0.8	1.3	-1	0.47	0.23310	0.78
09/17/2024 23:00	0.8	1.3	-1	0.47	0.23316	0.78
Average/Sum#:	0.8	1.3	-1	0.47	0.23577	0.79
Minimum:	0.7	1.3	-1	0.46	0.23214	0.77
Maximum:	0.8	1.5	0	0.55	0.27330	0.91
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/18/2024 00:00	0.8	1.3	-1	0.47	0.23328	0.78
09/18/2024 01:00	0.7	1.3	-1	0.47	0.23310	0.78
09/18/2024 02:00	0.8	1.2	-1	0.46	0.23184	0.77
09/18/2024 03:00	0.8	1.3	-1	0.46	0.23190	0.77
09/18/2024 04:00	0.8	1.4	-1	0.47	0.23274	0.78
09/18/2024 05:00	0.8	1.4	-1	0.47	0.23568	0.79
09/18/2024 06:00	0.8	1.3	0	0.50	0.24810	0.83
09/18/2024 07:00	0.8	1.4	-1	0.47	0.23262	0.78
09/18/2024 08:00	0.8	1.3	-1	0.46	0.23208	0.77
09/18/2024 09:00	0.8	1.3	-1	0.46	0.23226	0.77
09/18/2024 10:00	0.8	1.3	-1	0.46	0.23208	0.77
09/18/2024 11:00	0.7	1.3	-1	0.46	0.23196	0.77
09/18/2024 12:00	0.7	1.3	-1	0.46	0.23214	0.77
09/18/2024 13:00	0.7	1.3	-1	0.46	0.23238	0.77
09/18/2024 14:00	0.7	1.3	-1	0.46	0.23208	0.77
09/18/2024 15:00	0.8	1.4	-1	0.46	0.23220	0.77
09/18/2024 16:00	0.7	1.2	-1	0.51	0.25680	0.86
09/18/2024 17:00	0.7	1.2	-1	0.52	0.25872	0.86
09/18/2024 18:00	0.8	1.3	-1	0.46	0.23160	0.77
09/18/2024 19:00	0.7	1.4	-1	0.46	0.23166	0.77
09/18/2024 20:00	0.7	1.3	-1	0.58	0.28842	0.96
09/18/2024 21:00	0.7	1.3	-1	0.58	0.29166	0.97
09/18/2024 22:00	0.7	1.3	-1	0.58	0.29166	0.97
09/18/2024 23:00	0.7	1.4	-1	0.58	0.29064	0.97
Average/Sum#:	0.8	1.3	-1	0.49	0.24490	0.82
Minimum:	0.7	1.2	-1	0.46	0.23160	0.77
Maximum:	0.8	1.4	0	0.58	0.29166	0.97
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/19/2024 00:00	0.7	1.3	-1	0.58	0.29196	0.97
09/19/2024 01:00	0.8	1.3	-1	0.57	0.28614	0.95
09/19/2024 02:00	0.8	1.4	-1	0.56	0.27924	0.93
09/19/2024 03:00	0.8	1.4	-1	0.58	0.29088	0.97
09/19/2024 04:00	0.8	1.4	-1	0.58	0.29040	0.97
09/19/2024 05:00	0.8	1.3	-1	0.58	0.29004	0.97
09/19/2024 06:00	1.0	1.3	-1	0.51	0.25326	0.84
09/19/2024 07:00	0.7	1.3	-1	0.57	0.28404	0.95
09/19/2024 08:00	0.8	1.3	-1	0.49	0.24258	0.81
09/19/2024 09:00	0.8	1.3	-1	0.46	0.23064	0.77
09/19/2024 10:00	0.8	1.3	-1	0.46	0.23106	0.77
09/19/2024 11:00	0.7	1.3	-1	0.46	0.23040	0.77
09/19/2024 12:00	0.7	1.4	-1	0.46	0.23052	0.77
09/19/2024 13:00	0.7	1.3	-1	0.46	0.22998	0.77
09/19/2024 14:00	0.7	1.4	-1	0.46	0.22986	0.77
09/19/2024 15:00	0.7	1.3	-1	0.46	0.22980	0.77
09/19/2024 16:00	0.7	1.3	-1	0.51	0.25380	0.85
09/19/2024 17:00	0.8	1.3	-1	0.58	0.28866	0.96
09/19/2024 18:00	0.4	1.4	0	0.73	0.36432	1.21
09/19/2024 19:00	0.7	1.4	0	0.67	0.33300	1.11
09/19/2024 20:00	0.7	1.3	-1	0.58	0.29028	0.97
09/19/2024 21:00	0.7	1.4	-1	0.57	0.28404	0.95
09/19/2024 22:00	0.8	1.3	-1	0.47	0.23406	0.78
09/19/2024 23:00	0.8	1.3	-1	0.47	0.23274	0.78
Average/Sum#:	0.7	1.3	-1	0.53	0.26674	0.89
Minimum:	0.4	1.3	-1	0.46	0.22980	0.77
Maximum:	1.0	1.4	0	0.73	0.36432	1.21
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/20/2024 00:00	0.7	1.4	-1	0.46	0.23010	0.77
09/20/2024 01:00	0.8	1.3	-1	0.46	0.22980	0.77
09/20/2024 02:00	0.8	1.4	-1	0.46	0.22926	0.76
09/20/2024 03:00	0.8	1.4	-1	0.46	0.22926	0.76
09/20/2024 04:00	0.8	1.3	-1	0.47	0.23436	0.78
09/20/2024 05:00	0.8	1.4	-1	0.50	0.24786	0.83
09/20/2024 06:00	0.8	1.4	-1	0.48	0.23790	0.79
09/20/2024 07:00	0.9	0.0	-1	0.46	0.23052	0.77
09/20/2024 08:00	0.8	1.2	-1	0.46	0.22956	0.77
09/20/2024 09:00	0.8	1.4	-1	0.46	0.23082	0.77
09/20/2024 10:00	0.7	1.3	-1	0.49	0.24546	0.82
09/20/2024 11:00	0.7	1.4	-1	0.57	0.28272	0.94
09/20/2024 12:00	0.7	1.3	-1	0.57	0.28260	0.94
09/20/2024 13:00	0.7	1.3	0	0.51	0.25734	0.86
09/20/2024 14:00	0.7	1.4	-1	0.51	0.25314	0.84
09/20/2024 15:00	0.7	1.3	-1	0.46	0.22818	0.76
09/20/2024 16:00	0.7	1.3	-1	0.48	0.24030	0.80
09/20/2024 17:00	0.7	1.2	0	0.49	0.24474	0.82
09/20/2024 18:00	0.7	1.3	-1	0.46	0.22806	0.76
09/20/2024 19:00	0.8	1.4	-1	0.46	0.22830	0.76
09/20/2024 20:00	0.8	1.3	-1	0.46	0.22866	0.76
09/20/2024 21:00	0.7	1.3	-1	0.46	0.22884	0.76
09/20/2024 22:00	0.8	1.3	-1	0.46	0.22866	0.76
09/20/2024 23:00	0.8	1.3	-1	0.46	0.22866	0.76
Average/Sum#:	0.8	1.3	-1	0.48	0.23896	0.80
Minimum:	0.7	1.2	-1	0.46	0.22806	0.76
Maximum:	0.9	1.4	0	0.57	0.28272	0.94
%SI	0.00	4.17	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/21/2024 00:00	0.7	1.3	-1	0.46	0.22896	0.76
09/21/2024 01:00	0.8	1.4	-1	0.46	0.22908	0.76
09/21/2024 02:00	0.7	1.5	-1	0.46	0.23040	0.77
09/21/2024 03:00	0.8	1.1	-1	0.49	0.24360	0.81
09/21/2024 04:00	0.7	1.3	-1	0.52	0.25818	0.86
09/21/2024 05:00	0.8	1.3	-1	0.47	0.23394	0.78
09/21/2024 06:00	0.8	1.3	-1	0.49	0.24660	0.82
09/21/2024 07:00	0.8	1.4	-1	0.46	0.23076	0.77
09/21/2024 08:00	0.8	1.3	-1	0.46	0.23040	0.77
09/21/2024 09:00	0.7	1.3	-1	0.46	0.22950	0.77
09/21/2024 10:00	0.7	1.3	-1	0.46	0.22944	0.76
09/21/2024 11:00	0.7	1.3	-1	0.50	0.24948	0.83
09/21/2024 12:00	0.7	1.3	-1	0.53	0.26538	0.88
09/21/2024 13:00	0.7	1.3	-1	0.57	0.28440	0.95
09/21/2024 14:00	0.7	1.2	-1	0.56	0.28146	0.94
09/21/2024 15:00	0.7	1.3	0	0.50	0.24798	0.83
09/21/2024 16:00	0.6	1.4	0	0.68	0.34020	1.13
09/21/2024 17:00	0.2	1.4	0	0.74	0.37206	1.24
09/21/2024 18:00	0.6	1.4	0	0.67	0.33702	1.12
09/21/2024 19:00	0.8	1.3	0	0.62	0.30780	1.03
09/21/2024 20:00	0.8	1.3	-1	0.48	0.24078	0.80
09/21/2024 21:00	0.8	1.3	-1	0.47	0.23574	0.79
09/21/2024 22:00	0.8	1.3	-1	0.47	0.23322	0.78
09/21/2024 23:00	0.8	1.3	-1	0.46	0.22884	0.76
Average/Sum#:	0.7	1.3	-1	0.52	0.25897	0.86
Minimum:	0.2	1.1	-1	0.46	0.22884	0.76
Maximum:	0.8	1.5	0	0.74	0.37206	1.24
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/22/2024 00:00	0.8	1.4	-1	0.46	0.23010	0.77
09/22/2024 01:00	0.9	1.3	-1	0.46	0.22920	0.76
09/22/2024 02:00	0.9	1.3	-1	0.46	0.22908	0.76
09/22/2024 03:00	0.8	1.4	-1	0.46	0.22896	0.76
09/22/2024 04:00	0.8	1.4	-1	0.46	0.22902	0.76
09/22/2024 05:00	0.8	1.3	-1	0.46	0.22914	0.76
09/22/2024 06:00	0.8	1.3	-1	0.46	0.22944	0.76
09/22/2024 07:00	0.8	1.4	-1	0.46	0.23046	0.77
09/22/2024 08:00	0.8	1.4	-1	0.46	0.23040	0.77
09/22/2024 09:00	0.8	1.4	-1	0.46	0.22968	0.77
09/22/2024 10:00	0.7	1.4	-1	0.46	0.22944	0.76
09/22/2024 11:00	0.7	1.3	-1	0.46	0.22908	0.76
09/22/2024 12:00	0.7	1.3	-1	0.46	0.22878	0.76
09/22/2024 13:00	0.7	1.3	-1	0.55	0.27696	0.92
09/22/2024 14:00	0.7	1.4	-1	0.50	0.25098	0.84
09/22/2024 15:00	0.7	1.2	-1	0.46	0.22872	0.76
09/22/2024 16:00	0.7	1.3	-1	0.50	0.24840	0.83
09/22/2024 17:00	0.7	1.3	-1	0.46	0.22884	0.76
09/22/2024 18:00	0.7	1.2	-1	0.46	0.22752	0.76
09/22/2024 19:00	0.8	1.3	-1	0.46	0.22776	0.76
09/22/2024 20:00	0.8	1.3	-1	0.45	0.22674	0.76
09/22/2024 21:00	0.9	1.3	-1	0.45	0.22686	0.76
09/22/2024 22:00	0.8	1.3	-1	0.46	0.22776	0.76
09/22/2024 23:00	0.8	1.3	-1	0.46	0.22884	0.76
Average/Sum#:	0.8	1.3	-1	0.47	0.23259	0.77
Minimum:	0.7	1.2	-1	0.45	0.22674	0.76
Maximum:	0.9	1.4	-1	0.55	0.27696	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/23/2024 00:00	0.8	1.3	-1	0.46	0.22896	0.76
09/23/2024 01:00	0.8	1.4	-1	0.46	0.22914	0.76
09/23/2024 02:00	0.8	1.1	-1	0.46	0.22890	0.76
09/23/2024 03:00	0.8	1.4	-1	0.46	0.22884	0.76
09/23/2024 04:00	0.9	1.3	-1	0.46	0.22878	0.76
09/23/2024 05:00	1.0	1.3	-1	0.46	0.22890	0.76
09/23/2024 06:00	0.9	1.3	-1	0.46	0.23076	0.77
09/23/2024 07:00	0.9	1.4	-1	0.46	0.22914	0.76
09/23/2024 08:00	0.8	1.4	-1	0.46	0.22872	0.76
09/23/2024 09:00	0.8	1.3	-1	0.46	0.22890	0.76
09/23/2024 10:00	0.7	1.3	-1	0.46	0.22962	0.77
09/23/2024 11:00	0.7	1.2	-1	0.46	0.22938	0.76
09/23/2024 12:00	0.7	1.2	-1	0.46	0.23220	0.77
09/23/2024 13:00	0.7	1.2	-1	0.49	0.24612	0.82
09/23/2024 14:00	0.7	1.3	-1	0.50	0.25032	0.83
09/23/2024 15:00	0.9	1.3	-1	0.51	0.25392	0.85
09/23/2024 16:00	0.9	1.4	0	0.62	0.30960	1.03
09/23/2024 17:00	0.2	1.4	0	0.73	0.36720	1.22
09/23/2024 18:00	0.3	1.4	0	0.70	0.35130	1.17
09/23/2024 19:00	0.5	1.4	0	0.64	0.31926	1.06
09/23/2024 20:00	0.8	1.3	-1	0.56	0.28080	0.94
09/23/2024 21:00	0.8	1.2	-1	0.56	0.28014	0.93
09/23/2024 22:00	0.8	1.3	-1	0.55	0.27642	0.92
09/23/2024 23:00	0.8	1.3	-1	0.53	0.26364	0.88
Average/Sum#:	0.8	1.3	-1	0.52	0.25754	0.86
Minimum:	0.2	1.1	-1	0.46	0.22872	0.76
Maximum:	1.0	1.4	0	0.73	0.36720	1.22
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/24/2024 00:00	0.9	1.2	-1	0.52	0.26196	0.87
09/24/2024 01:00	0.9	1.4	-1	0.46	0.23178	0.77
09/24/2024 02:00	0.9	1.3	-1	0.46	0.22902	0.76
09/24/2024 03:00	0.8	1.2	-1	0.48	0.23922	0.80
09/24/2024 04:00	0.8	1.3	-1	0.54	0.27084	0.90
09/24/2024 05:00	1.0	1.3	-1	0.56	0.28116	0.94
09/24/2024 06:00	0.9	1.3	-1	0.49	0.24336	0.81
09/24/2024 07:00	0.9	1.3	-1	0.46	0.22866	0.76
09/24/2024 08:00	0.8	1.4	-1	0.45	0.22668	0.76
09/24/2024 09:00	0.8	1.4	-1	0.46	0.22782	0.76
09/24/2024 10:00	0.8	1.4	-1	0.46	0.22872	0.76
09/24/2024 11:00	0.7	1.2	-1	0.46	0.22800	0.76
09/24/2024 12:00	0.7	1.3	-1	0.50	0.24816	0.83
09/24/2024 13:00	0.7	1.2	-1	0.53	0.26580	0.89
09/24/2024 14:00	0.7	1.3	-1	0.54	0.26814	0.89
09/24/2024 15:00	0.7	1.3	-1	0.48	0.24192	0.81
09/24/2024 16:00	0.8	1.3	0	0.52	0.26058	0.87
09/24/2024 17:00	0.5	1.4	0	0.67	0.33552	1.12
09/24/2024 18:00	0.7	1.4	0	0.56	0.27996	0.93
09/24/2024 19:00	0.8	1.3	-1	0.46	0.22824	0.76
09/24/2024 20:00	0.8	1.4	-1	0.46	0.22866	0.76
09/24/2024 21:00	0.8	1.3	-1	0.46	0.22872	0.76
09/24/2024 22:00	0.8	1.3	-1	0.46	0.22830	0.76
09/24/2024 23:00	0.8	1.4	-1	0.46	0.22908	0.76
Average/Sum#:	0.8	1.3	-1	0.50	0.24751	0.82
Minimum:	0.5	1.2	-1	0.45	0.22668	0.76
Maximum:	1.0	1.4	0	0.67	0.33552	1.12
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/25/2024 00:00	0.8	1.3	-1	0.46	0.22914	0.76
09/25/2024 01:00	0.8	1.3	-1	0.46	0.22902	0.76
09/25/2024 02:00	0.8	1.5	-1	0.46	0.22968	0.77
09/25/2024 03:00	0.8	1.3	-1	0.46	0.23016	0.77
09/25/2024 04:00	0.8	1.3	-1	0.48	0.23952	0.80
09/25/2024 05:00	0.7	1.3	-1	0.51	0.25680	0.86
09/25/2024 06:00	0.8	1.3	-1	0.48	0.23760	0.79
09/25/2024 07:00	0.8	1.3	-1	0.46	0.22788	0.76
09/25/2024 08:00	0.7	1.4	-1	0.53	0.26298	0.88
09/25/2024 09:00	0.7	1.4	-1	0.47	0.23748	0.79
09/25/2024 10:00	0.7	1.3	-1	0.46	0.22998	0.77
09/25/2024 11:00	0.8	1.3	-1	0.46	0.22752	0.76
09/25/2024 12:00	0.7	1.3	-1	0.45	0.22716	0.76
09/25/2024 13:00	0.7	1.3	-1	0.46	0.22752	0.76
09/25/2024 14:00	0.7	1.3	-1	0.45	0.22638	0.75
09/25/2024 15:00	0.7	1.4	-1	0.45	0.22644	0.75
09/25/2024 16:00	0.7	1.3	-1	0.48	0.23862	0.80
09/25/2024 17:00	0.7	1.3	-1	0.46	0.22974	0.77
09/25/2024 18:00	0.8	1.4	-1	0.46	0.22890	0.76
09/25/2024 19:00	0.8	1.4	-1	0.46	0.22800	0.76
09/25/2024 20:00	0.8	1.3	-1	0.46	0.22824	0.76
09/25/2024 21:00	0.7	1.4	-1	0.46	0.22848	0.76
09/25/2024 22:00	0.7	1.3	-1	0.46	0.22842	0.76
09/25/2024 23:00	0.8	1.4	-1	0.46	0.22860	0.76
Average/Sum#:	0.8	1.3	-1	0.47	0.23268	0.78
Minimum:	0.7	1.3	-1	0.45	0.22638	0.75
Maximum:	0.8	1.5	-1	0.53	0.26298	0.88
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/26/2024 00:00	0.8	1.3	0	0.46	0.22866	0.76
09/26/2024 01:00	0.8	1.3	0	0.46	0.22866	0.76
09/26/2024 02:00	0.8	1.2	0	0.46	0.22884	0.76
09/26/2024 03:00	0.8	1.4	0	0.46	0.22872	0.76
09/26/2024 04:00	0.8	1.3	0	0.46	0.22884	0.76
09/26/2024 05:00	0.8	1.3	0	0.46	0.22890	0.76
09/26/2024 06:00	0.8	1.4	0	0.46	0.22908	0.76
09/26/2024 07:00	1.0	1.4	0	0.46	0.22932	0.76
09/26/2024 08:00	0.8	1.3	0	0.46	0.22938	0.76
09/26/2024 09:00	0.8	1.3	-1	0.46	0.22878	0.76
09/26/2024 10:00	0.8	1.4	-1	0.46	0.22806	0.76
09/26/2024 11:00	0.8	1.3	-1	0.46	0.22794	0.76
09/26/2024 12:00	0.7	1.3	-1	0.46	0.22896	0.76
09/26/2024 13:00	0.7	1.4	-1	0.46	0.22848	0.76
09/26/2024 14:00	0.7	1.3	-1	0.46	0.22800	0.76
09/26/2024 15:00	0.7	1.3	-1	0.45	0.22746	0.76
09/26/2024 16:00	0.9	1.2	0	0.53	0.26538	0.88
09/26/2024 17:00	0.5	1.4	0	0.68	0.34146	1.14
09/26/2024 18:00	0.5	1.4	0	0.68	0.34218	1.14
09/26/2024 19:00	0.6	1.4	0	0.68	0.33828	1.13
09/26/2024 20:00	0.6	1.4	0	0.69	0.34314	1.14
09/26/2024 21:00	0.9	1.3	0	0.58	0.28758	0.96
09/26/2024 22:00	0.8	1.2	-1	0.50	0.25038	0.83
09/26/2024 23:00	0.9	1.3	-1	0.46	0.23154	0.77
Average/Sum#:	0.8	1.3	0	0.51	0.25242	0.84
Minimum:	0.5	1.2	-1	0.45	0.22746	0.76
Maximum:	1.0	1.4	0	0.69	0.34314	1.14
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/27/2024 00:00	0.8	1.3	-1	0.46	0.22752	0.76
09/27/2024 01:00	0.8	1.4	-1	0.46	0.22770	0.76
09/27/2024 02:00	0.8	1.3	-1	0.46	0.22770	0.76
09/27/2024 03:00	1.0	1.4	-1	0.46	0.22806	0.76
09/27/2024 04:00	0.8	1.3	-1	0.52	0.25932	0.86
09/27/2024 05:00	0.9	1.2	-1	0.55	0.27276	0.91
09/27/2024 06:00	1.0	1.3	0	0.50	0.24750	0.83
09/27/2024 07:00	1.0	1.3	-1	0.46	0.22854	0.76
09/27/2024 08:00	0.9	1.4	-1	0.46	0.22806	0.76
09/27/2024 09:00	0.8	1.3	-1	0.46	0.22758	0.76
09/27/2024 10:00	0.8	1.3	-1	0.45	0.22734	0.76
09/27/2024 11:00	0.7	1.3	-1	0.45	0.22698	0.76
09/27/2024 12:00	0.7	1.3	-1	0.45	0.22590	0.75
09/27/2024 13:00	0.8	1.2	-1	0.45	0.22572	0.75
09/27/2024 14:00	0.7	1.3	-1	0.45	0.22542	0.75
09/27/2024 15:00	0.8	1.3	-1	0.45	0.22740	0.76
09/27/2024 16:00	1.0	1.3	0	0.53	0.26616	0.89
09/27/2024 17:00	0.7	1.4	0	0.65	0.32574	1.09
09/27/2024 18:00	0.8	1.4	-1	0.65	0.32502	1.08
09/27/2024 19:00	0.9	1.3	-1	0.61	0.30738	1.02
09/27/2024 20:00	0.8	1.3	-1	0.56	0.28002	0.93
09/27/2024 21:00	0.8	1.3	-1	0.54	0.27006	0.90
09/27/2024 22:00	0.8	1.3	-1	0.54	0.26802	0.89
09/27/2024 23:00	0.7	1.3	-1	0.57	0.28566	0.95
Average/Sum#:	0.8	1.3	-1	0.51	0.25257	0.84
Minimum:	0.7	1.2	-1	0.45	0.22542	0.75
Maximum:	1.0	1.4	0	0.65	0.32574	1.09
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/28/2024 00:00	0.7	1.3	-1	0.55	0.27558	0.92
09/28/2024 01:00	0.9	1.3	-1	0.49	0.24408	0.81
09/28/2024 02:00	0.9	1.4	-1	0.45	0.22722	0.76
09/28/2024 03:00	0.9	1.4	-1	0.45	0.22740	0.76
09/28/2024 04:00	0.9	1.3	-1	0.46	0.22794	0.76
09/28/2024 05:00	0.9	1.3	-1	0.46	0.22926	0.76
09/28/2024 06:00	0.9	1.4	-1	0.46	0.22848	0.76
09/28/2024 07:00	0.9	1.3	-1	0.46	0.22758	0.76
09/28/2024 08:00	0.9	1.4	-1	0.45	0.22698	0.76
09/28/2024 09:00	0.8	1.4	-1	0.45	0.22638	0.75
09/28/2024 10:00	0.8	1.3	-1	0.45	0.22602	0.75
09/28/2024 11:00	0.7	1.2	-1	0.45	0.22560	0.75
09/28/2024 12:00	0.7	1.2	-1	0.45	0.22548	0.75
09/28/2024 13:00	0.7	1.2	-1	0.45	0.22710	0.76
09/28/2024 14:00	0.7	1.2	-1	0.48	0.23826	0.79
09/28/2024 15:00	0.7	1.2	-1	0.49	0.24462	0.82
09/28/2024 16:00	1.0	1.3	0	0.53	0.26418	0.88
09/28/2024 17:00	0.7	1.3	-1	0.65	0.32460	1.08
09/28/2024 18:00	0.8	1.4	-1	0.65	0.32352	1.08
09/28/2024 19:00	0.9	1.4	-1	0.61	0.30546	1.02
09/28/2024 20:00	0.8	1.3	-1	0.46	0.22842	0.76
09/28/2024 21:00	0.8	1.3	-1	0.45	0.22680	0.76
09/28/2024 22:00	0.8	1.3	-1	0.45	0.22710	0.76
09/28/2024 23:00	0.8	1.4	-1	0.45	0.22740	0.76
Average/Sum#:	0.8	1.3	-1	0.49	0.24398	0.81
Minimum:	0.7	1.2	-1	0.45	0.22548	0.75
Maximum:	1.0	1.4	0	0.65	0.32460	1.08
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/29/2024 00:00	0.8	1.3	-1	0.46	0.22752	0.76
09/29/2024 01:00	0.8	1.3	-1	0.46	0.22788	0.76
09/29/2024 02:00	0.8	1.4	-1	0.46	0.22800	0.76
09/29/2024 03:00	0.8	1.4	0	0.46	0.22854	0.76
09/29/2024 04:00	0.8	1.3	0	0.46	0.22872	0.76
09/29/2024 05:00	0.8	1.3	0	0.46	0.22866	0.76
09/29/2024 06:00	0.8	1.4	0	0.46	0.22872	0.76
09/29/2024 07:00	0.8	1.3	0	0.46	0.22878	0.76
09/29/2024 08:00	0.8	1.4	-1	0.46	0.22842	0.76
09/29/2024 09:00	0.8	1.3	-1	0.46	0.22830	0.76
09/29/2024 10:00	0.8	1.3	-1	0.46	0.22806	0.76
09/29/2024 11:00	0.8	1.4	-1	0.45	0.22734	0.76
09/29/2024 12:00	0.8	1.4	-1	0.45	0.22680	0.76
09/29/2024 13:00	0.7	1.4	-1	0.45	0.22662	0.76
09/29/2024 14:00	0.7	1.3	-1	0.45	0.22662	0.76
09/29/2024 15:00	0.7	1.4	-1	0.45	0.22656	0.76
09/29/2024 16:00	0.7	1.2	-1	0.51	0.25404	0.85
09/29/2024 17:00	0.8	1.3	-1	0.46	0.22908	0.76
09/29/2024 18:00	0.8	1.3	-1	0.45	0.22674	0.76
09/29/2024 19:00	0.8	1.3	-1	0.46	0.22854	0.76
09/29/2024 20:00	0.9	1.4	-1	0.45	0.22716	0.76
09/29/2024 21:00	0.8	1.4	-1	0.45	0.22716	0.76
09/29/2024 22:00	0.9	1.3	-1	0.45	0.22740	0.76
09/29/2024 23:00	0.9	1.3	-1	0.46	0.22764	0.76
Average/Sum#:	0.8	1.3	-1	0.46	0.22889	0.76
Minimum:	0.7	1.2	-1	0.45	0.22656	0.76
Maximum:	0.9	1.4	0	0.51	0.25404	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:24 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/30/2024 00:00	0.8	1.3	-1	0.46	0.22782	0.76
09/30/2024 01:00	0.8	1.3	-1	0.46	0.22806	0.76
09/30/2024 02:00	0.8	1.3	-1	0.46	0.22830	0.76
09/30/2024 03:00	0.9	1.4	-1	0.46	0.22860	0.76
09/30/2024 04:00	1.0	1.4	-1	0.46	0.22902	0.76
09/30/2024 05:00	0.9	1.4	0	0.46	0.23172	0.77
09/30/2024 06:00	0.9	1.3	0	0.50	0.24972	0.83
09/30/2024 07:00	1.0	1.3	-1	0.46	0.22866	0.76
09/30/2024 08:00	0.9	1.4	-1	0.46	0.22818	0.76
09/30/2024 09:00	0.8	1.4	-1	0.46	0.22830	0.76
09/30/2024 10:00	0.8	1.3	-1	0.46	0.22824	0.76
09/30/2024 11:00	0.8	1.2	-1	0.46	0.22800	0.76
09/30/2024 12:00	0.8	1.3	-1	0.46	0.22776	0.76
09/30/2024 13:00	0.7	1.2	-1	0.46	0.22860	0.76
09/30/2024 14:00	0.8	1.3	-1	0.46	0.22794	0.76
09/30/2024 15:00	1.1	1.3	0	0.54	0.26904	0.90
09/30/2024 16:00	0.3	1.5	0	0.77	0.38490	1.28
09/30/2024 17:00	0.2	1.5	0	0.76	0.38082	1.27
09/30/2024 18:00	0.3	1.4	0	0.74	0.37044	1.23
09/30/2024 19:00	0.3	1.5	0	0.75	0.37284	1.24
09/30/2024 20:00	0.3	1.4	0	0.75	0.37710	1.26
09/30/2024 21:00	0.3	1.4	0	0.75	0.37566	1.25
09/30/2024 22:00	0.7	1.4	0	0.69	0.34722	1.16
09/30/2024 23:00	0.8	1.2	-1	0.57	0.28644	0.95
Average/Sum#:	0.7	1.4	-1	0.55	0.27556	0.92
Minimum:	0.2	1.2	-1	0.46	0.22776	0.76
Maximum:	1.1	1.5	0	0.77	0.38490	1.28
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
09/16/24 8:52	434087			1			1.48			1.05			2.68			0		
09/16/24 8:53	433827.2			1			1.48			1.05			2.68			0		
09/16/24 8:54	433607.7			1			1.48			1.05			2.68			0		
09/16/24 8:55	432943.4			1			1.48			1.05			2.68			0		
09/16/24 8:56	433399.7			1			1.48			1.05			2.68			0		
09/16/24 8:57	438731.1			0.9			1.45			1.05			2.66			1		
09/16/24 8:58	432706.5			0.9			1.62			1.01			2.88			0		
09/16/24 8:59	432273.3			1			1.32			1.04			2.33			0		
09/16/24 9:00	433434.3			1.1			1.32			1.14			2.34			0		
09/16/24 9:01	435057.4			1.1			1.23			1.14			2.19			0		
09/16/24 9:02	434283.5			1.1			1.23			1.23			2.19			0		

Monthly Summary By Day Report

Unit CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:53 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
07/01/2024	15.23	47.55	5.2	11.08	18.45
07/02/2024	13.95	56.14	6.4	12.86	21.48
07/03/2024	14.79	52.28	6.0	12.25	20.49
07/04/2024	15.25	42.14	4.8	10.39	17.28
07/05/2024	15.33	44.98	5.1	11.04	18.43
07/06/2024	14.82	46.75	5.5	11.23	18.80
07/07/2024	13.40	50.72	5.9	11.93	19.89
07/08/2024	12.82	54.83	6.1	12.51	20.91
07/09/2024	13.37	55.77	6.7	12.86	21.37
07/10/2024	15.05	52.79	6.3	12.61	20.98
07/11/2024	12.69	56.54	6.6	13.11	21.78
07/12/2024	14.17	52.62	6.2	12.43	20.63
07/13/2024	14.93	43.46	4.9	10.49	17.47
07/14/2024	14.30	43.29	4.8	10.43	17.38
07/15/2024	13.52	42.95	4.8	10.29	17.12
07/16/2024	15.26	43.13	5.4	11.27	18.76
07/17/2024	15.21	44.30	5.1	10.77	17.86
07/18/2024	14.95	54.48	6.2	12.66	21.18
07/19/2024	16.83	68.30	7.7	15.42	25.71
07/20/2024	15.83	62.75	7.1	14.40	23.99
07/21/2024	14.58	43.12	5.3	10.86	18.02
07/22/2024	13.91	56.35	6.7	13.07	21.76
07/23/2024	8.61	74.83	8.8	16.49	27.51
07/24/2024	13.18	69.79	8.0	15.63	26.07
07/25/2024	12.93	56.99	6.2	13.02	21.65
07/26/2024	15.11	43.62	5.0	10.42	17.46
07/27/2024	14.98	42.88	4.8	10.29	17.04
07/28/2024	14.93	45.09	4.8	10.32	17.07
07/29/2024	16.64	49.67	5.3	11.12	18.45
07/30/2024	14.40	53.93	5.7	11.91	19.81
07/31/2024	14.43	53.12	5.8	12.39	20.67
Monthly Avg/Sum:	445.40 sum	1,605.16 sum	183.2 sum	375.55 sum	625.47 sum
Daily Min:	8.61	42.14	4.8	10.29	17.04
Daily Max:	16.83	74.83	8.8	16.49	27.51
Jul 2024 - Jul 2024	445.40 sum	1,605.16 sum	183.2 sum	375.55 sum	625.47 sum
QTD:	445.40 sum	1,605.16 sum	183.2 sum	375.55 sum	625.47 sum
YTD 2024:	2,864.13 sum	7,155.77 sum	765.4 sum	1,590.15 sum	2,649.32 sum

Monthly Summary By Day Report

Unit CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:53 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
08/01/2024	13.67	54.49	6.4	13.01	21.69
08/02/2024	16.03	57.26	7.4	13.98	23.29
08/03/2024	14.95	45.04	5.2	11.18	18.55
08/04/2024	14.99	46.57	5.5	11.26	18.70
08/05/2024	15.26	44.53	4.9	10.93	18.17
08/06/2024	15.82	45.58	5.3	11.14	18.45
08/07/2024	15.38	41.79	4.8	10.40	17.29
08/08/2024	13.49	40.54	4.8	10.35	17.15
08/09/2024	13.45	42.09	4.8	10.33	17.17
08/10/2024	13.44	42.11	4.8	10.27	17.11
08/11/2024	15.56	47.88	5.7	11.62	19.31
08/12/2024	14.37	44.30	5.0	10.72	17.81
08/13/2024	13.88	44.35	5.1	10.69	17.81
08/14/2024	12.90	47.54	5.4	11.38	18.89
08/15/2024	13.78	47.88	5.4	11.46	19.06
08/16/2024	13.25	43.38	4.9	10.49	17.55
08/17/2024	12.32	42.55	4.8	10.27	17.19
08/18/2024	13.07	41.61	4.8	10.21	17.06
08/19/2024	13.49	42.11	4.8	10.35	17.29
08/20/2024	13.64	41.38	4.8	10.24	17.05
08/21/2024	13.27	41.78	4.8	10.13	16.96
08/22/2024	13.36	41.77	4.8	10.15	17.01
08/23/2024	14.26	42.77	4.8	10.31	17.09
08/24/2024	15.24	42.40	4.8	10.33	17.11
08/25/2024	15.63	44.12	5.0	10.59	17.60
08/26/2024	14.35	42.79	4.9	10.57	17.57
08/27/2024	14.96	41.99	4.8	10.38	17.22
08/28/2024	14.96	40.81	4.8	10.38	17.17
08/29/2024	14.64	42.57	5.1	10.70	17.74
08/30/2024	14.82	41.82	4.8	10.32	17.05
08/31/2024	14.33	47.91	5.8	11.63	19.30
Monthly Avg/Sum:	442.56 sum	1,373.71 sum	159.0 sum	335.77 sum	558.41 sum
Daily Min:	12.32	40.54	4.8	10.13	16.96
Daily Max:	16.03	57.26	7.4	13.98	23.29
Jul 2024 - Aug 2024	887.96 sum	2,978.87 sum	342.2 sum	711.32 sum	1,183.88 sum
QTD:	887.96 sum	2,978.87 sum	342.2 sum	711.32 sum	1,183.88 sum
YTD 2024:	3,306.69 sum	8,529.48 sum	924.4 sum	1,925.92 sum	3,207.73 sum

Monthly Summary By Day Report

Unit CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:53 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:					
	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
09/01/2024	14.87	42.30	4.8	10.40	17.36
09/02/2024	15.00	43.04	4.8	10.53	17.59
09/03/2024	15.86	48.29	5.7	11.76	19.54
09/04/2024	11.67	48.69	6.2	12.76	21.19
09/05/2024	8.65	57.97	6.8	13.63	22.64
09/06/2024	8.04	58.62	7.1	13.71	22.78
09/07/2024	8.87	57.32	6.7	13.47	22.42
09/08/2024	9.55	53.93	6.2	12.76	21.24
09/09/2024	13.02	44.56	5.2	11.10	18.50
09/10/2024	11.77	42.27	4.8	10.39	17.19
09/11/2024	11.97	42.94	4.8	10.36	17.14
09/12/2024	11.83	42.26	4.8	10.32	17.05
09/13/2024	10.89	46.88	5.3	11.47	19.05
09/14/2024	10.65	43.20	5.2	10.78	17.91
09/15/2024	10.51	42.44	4.8	10.35	17.10
09/16/2024	11.16	45.64	5.4	11.22	18.64
09/17/2024	10.62	42.95	4.9	10.43	17.40
09/18/2024	11.03	43.58	5.2	10.87	18.09
09/19/2024	12.02	49.06	6.0	11.89	19.78
09/20/2024	10.19	41.09	5.0	10.57	17.64
09/21/2024	10.01	46.59	5.5	11.49	19.21
09/22/2024	10.47	42.11	4.9	10.26	17.21
09/23/2024	11.26	46.17	5.5	11.45	19.12
09/24/2024	11.34	44.45	5.2	10.98	18.31
09/25/2024	9.99	41.70	4.8	10.27	17.19
09/26/2024	11.39	46.17	5.3	11.20	18.69
09/27/2024	12.61	45.14	5.5	11.24	18.73
09/28/2024	11.68	43.68	5.2	10.86	18.10
09/29/2024	10.82	41.55	4.8	10.14	16.90
09/30/2024	10.02	51.41	6.3	12.32	20.57
Monthly Avg/Sum:	337.76 sum	1,386.00 sum	162.7 sum	338.98 sum	564.28 sum
Daily Min:	8.04	41.09	4.8	10.14	16.90
Daily Max:	15.86	58.62	7.1	13.71	22.78
Jul 2024 - Sep 2024	1,225.72 sum	4,364.87 sum	504.9 sum	1,050.30 sum	1,748.16 sum
QTD:	1,225.72 sum	4,364.87 sum	504.9 sum	1,050.30 sum	1,748.16 sum
YTD 2024:	3,644.45 sum	9,915.48 sum	1,087.1 sum	2,264.90 sum	3,772.01 sum

Startup / Shutdown Events

CT1



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 06:46 **Location:** Roseville, CA

No source downtime records found.

Startup / Shutdown Events

CT1



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 06:46 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	09/16/2024 08:57	09/16/2024 08:57	Shutdown	1

Startup / Shutdown Events

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 06:46 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	0		0.00
Warm Startup	0		0.00
Shutdown	1	1	0.00
Total Process Events:	1	1	0

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	2,208.00 Hour(s)
Total Startup Time:	0 Minute(s)
Total Shutdown Time:	1 Minute(s)
Total Startup/Shutdown Time:	1 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.00 %

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
07/18/24 15:06	439129.6			0.6			1.48			0.67			2.51			0		
07/18/24 15:07	437876.2			0.6			1.48			0.66			2.5			0		
07/18/24 15:08	439251			0.6			1.48			0.67			2.51			0		
07/18/24 15:09	439539.8			0.6			1.48			0.67			2.51			0		
07/18/24 15:10	440648.8			0.7			1.5			0.78			2.56			0		
07/18/24 15:11	439349.2			0.6			1.48			0.67			2.5			1		
07/18/24 15:12	427300			0.6			1.48			0.55			2.43			1		
07/18/24 15:13	404732.4			0.6			1.57			0.61			2.45			1		
07/18/24 15:14	382020.4			0.6			2			0.57			2.95			1		
07/18/24 15:15	359094.7			0.6			2.32			0.53			3.22			1		
07/18/24 15:16	335308.3			0.7			2.41			0.56			3.13			1		
07/18/24 15:17	310851.8			0.8			2.68			0.59			3.23			1		
07/18/24 15:18	286216.4			0.8			3.5			0.56			3.87			1		
07/18/24 15:19	262406.9			0.7			4.38			0.41			4.43			1		
07/18/24 15:20	236720.1			0.5			8.26			0.27			7.55			1		
07/18/24 15:21	213430.5			0.4			24.13			0.21			19.87			1		
07/18/24 15:22	187096.8			3.9			34.15			1.7			24.74			1		
07/18/24 15:23	164211.5			118.4			40.78			45.74			25.93			1		
07/18/24 15:24	143642.5			627			44.99			212.92			25.14			1		
07/18/24 15:25	98039.4			1370.4			47.72			320.25			18.35			1		
07/18/24 15:26	0			0			54.75			4.93			0.26			0		
07/18/24 15:27	0			0			41.3			8.85			0.12			0		
07/18/24 15:28	0			0			0.3			0			0			0		
07/18/24 15:29	0			0			0.3			0			0			0		
07/18/24 15:30	0			0			0.2			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
07/20/24 7:32	0			0			0			0			0			0		
07/20/24 7:33	0			0			0			0			0			0		
07/20/24 7:34	0			0			0			0			0			0		
07/20/24 7:35	0			0			0			0			0			0		
07/20/24 7:36	0			0			0			0			0			0		
07/20/24 7:37	0			-0.1			0			0			0			1		
07/20/24 7:38	16063.6			-0.1			0			0			0			1		
07/20/24 7:39	31566.9			1233.1			41.3			91.09			5.02			1		
07/20/24 7:40	44719.3			1195.2			18.19			124.95			3.13			1		
07/20/24 7:41	56110			807.6			19.99			105.94			4.32			1		
07/20/24 7:42	68245.8			499.7			25.96			79.76			6.82			1		
07/20/24 7:43	100344.1			329.9			30.57			77.38			11.8			1		
07/20/24 7:44	144872.8			197.8			39.88			66.94			22.22			1		
07/20/24 7:45	174198.6			132.8			56.64			54.05			37.96			1		
07/20/24 7:46	200335.9			518			62.2			242.58			47.94			1		
07/20/24 7:47	216278.2			104.6			60.1			52.85			49.99			1		
07/20/24 7:48	239071.1			21			58			11.71			53.33			1		
07/20/24 7:49	263123.2			1.5			57.87			0.91			58.56			1		
07/20/24 7:50	292766.6			1			51.75			0.71			58.29			1		
07/20/24 7:51	317939.3			1			24.82			0.77			30.34			1		
07/20/24 7:52	339530.7			1.2			16.38			0.98			21.39			1		
07/20/24 7:53	360400.1			1.5			13.97			1.24			19.37			1		
07/20/24 7:54	374753.9			1.6			12.67			1.37			18.27			1		
07/20/24 7:55	375672.4			1.5			9.69			1.31			14			1		
07/20/24 7:56	376278.8			1.3			9.69			1.16			14.02			1		
07/20/24 7:57	375077.5			1.2			9.25			1.08			13.34			1		
07/20/24 7:58	374933			1.2			8.85			1.02			12.76			1		
07/20/24 7:59	373956.8			1.2			8.22			1.02			11.83			1		
07/20/24 8:00	373708.5			1.1			8.05			0.94			11.57			1		
07/20/24 8:01	380894			0.9			7.87			0.8			11.52			1		
07/20/24 8:02	401336			0.9			6.81			0.85			10.51			1		
07/20/24 8:03	417977.3			0.8			6.36			0.81			10.24			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
07/20/24 8:04	415170			0.8			6.27			0.82			10.02			1		
07/20/24 8:05	412998.1			0.8			6.27			0.81			9.98			1		
07/20/24 8:06	411409.7			0.8			6.37			0.81			10.08			1		
07/20/24 8:07	409434.3			0.7			6.46			0.72			10.17			1		
07/20/24 8:08	407978.6			0.7			6.56			0.72			10.3			1		
07/20/24 8:09	390910			0.7			6.56			0.68			9.86			1		
07/20/24 8:10	381142.4			0.8			7.19			0.74			10.54			1		
07/20/24 8:11	383718.6			0.8			7.17			0.73			10.58			1		
07/20/24 8:12	380264.5			0.8			6.64			0.74			9.71			1		
07/20/24 8:13	375701.3			0.8			6.73			0.73			9.72			1		
07/20/24 8:14	374586.5			0.8			6.99			0.72			10.07			1		
07/20/24 8:15	373829.8			0.8			5.17			0.71			7.44			1		
07/20/24 8:16	374771.3			0.8			2.86			0.73			4.12			1		
07/20/24 8:17	374413.1			0.8			2.67			0.73			3.85			1		
07/20/24 8:18	373593			0.8			3.32			0.72			4.77			1		
07/20/24 8:19	372564.8			0.8			3.5			0.72			5.02			1		
07/20/24 8:20	373604.5			0.8			3.96			0.72			5.7			1		
07/20/24 8:21	372495.5			0.8			4.15			0.72			5.94			1		
07/20/24 8:22	370889.7			0.8			3.96			0.72			5.65			1		
07/20/24 8:23	370912.8			0.8			3.04			0.72			4.34			1		
07/20/24 8:24	369982.8			0.8			2.77			0.72			3.94			1		
07/20/24 8:25	370733.7			0.7			2.77			0.64			3.94			1		
07/20/24 8:26	369168.3			0.7			2.77			0.64			3.93			1		
07/20/24 8:27	369018.2			0.7			2.77			0.64			3.93			1		
07/20/24 8:28	369584.3			0.8			2.77			0.72			3.93			1		
07/20/24 8:29	370063.7			0.8			2.67			0.72			3.8			1		
07/20/24 8:30	368856.5			0.9			2.49			0.79			3.53			1		
07/20/24 8:31	367961.2			0.7			2.21			0.63			3.13			1		
07/20/24 8:32	367949.6			0.6			1.94			0.56			2.75			1		
07/20/24 8:33	369451.4			0.6			1.84			0.56			2.63			1		
07/20/24 8:34	369341.6			0.7			1.84			0.64			2.62			1		
07/20/24 8:35	369191.5			0.7			1.75			0.64			2.5			1		
07/20/24 8:36	369532.3			0.7			1.84			0.64			2.63			1		
07/20/24 8:37	368429			0.8			1.84			0.72			2.62			1		
07/20/24 8:38	368821.8			0.8			1.84			0.72			2.62			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
07/20/24 8:39	369093.3			0.8			1.84			0.72			2.62			1		
07/20/24 8:40	368873.8			0.7			1.82			0.63			2.58			1		
07/20/24 8:41	369884.6			0.7			1.72			0.63			2.46			1		
07/20/24 8:42	367759			0.7			1.75			0.63			2.48			1		
07/20/24 8:43	369260.8			0.8			1.66			0.72			2.36			0		
07/20/24 8:44	369630.5			0.8			1.57			0.72			2.23			0		
07/20/24 8:45	368608.1			0.8			1.57			0.72			2.22			0		
07/20/24 8:46	368244.2			0.7			1.57			0.64			2.23			0		
07/20/24 8:47	368902.7			0.7			1.59			0.65			2.26			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/01/24 7:16	366829			0.7			1.54			0.63			2.19			0		
08/01/24 7:17	365408.1			0.8			1.54			0.7			2.18			0		
08/01/24 7:18	365263.7			0.7			1.45			0.62			2.05			0		
08/01/24 7:19	365968.3			0.7			1.45			0.62			2.05			0		
08/01/24 7:20	365858.6			0.7			1.45			0.62			2.05			0		
08/01/24 7:21	362652.8			0.7			1.45			0.62			2.04			1		
08/01/24 7:22	346554.5			0.8			1.45			0.66			1.94			1		
08/01/24 7:23	323241.8			0.8			1.52			0.61			1.9			1		
08/01/24 7:24	299657.6			0.7			2.45			0.51			2.84			1		
08/01/24 7:25	275368.7			0.7			2.72			0.48			2.89			1		
08/01/24 7:26	250831.4			0.6			4.47			0.34			4.34			1		
08/01/24 7:27	228044.3			0.4			12.9			0.21			11.37			1		
08/01/24 7:28	200746			1.1			27.94			0.52			21.68			1		
08/01/24 7:29	175729.3			61.7			31.84			25.46			21.61			1		
08/01/24 7:30	156887.3			490.1			37.23			180.59			22.57			1		
08/01/24 7:31	138744.3			1227			40.66			399.64			21.8			1		
08/01/24 7:32	22452.1			1611.3			42.59			85.12			3.7			1		
08/01/24 7:33	0			0			55.07			0			0			0		
08/01/24 7:34	0			0			11.8			0			0			0		
08/01/24 7:35	0			0			11.8			0			0			0		
08/01/24 7:36	0			0			0.2			0			0			0		
08/01/24 7:37	0			0			5.9			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/01/24 14:16	0			0			0			0			0			0		
08/01/24 14:17	0			0			0			0			0			0		
08/01/24 14:18	0			0			0			0			0			0		
08/01/24 14:19	0			0			0			0			0			0		
08/01/24 14:20	0			0			0			0			0			0		
08/01/24 14:21	0			-0.2			0			0			0			1		
08/01/24 14:22	0			-0.2			0			0			0			1		
08/01/24 14:23	0			0			0			0			0			0		
08/01/24 14:24	0			0			0			0			0			0		
08/01/24 14:25	0			0			5.9			0			0			0		
08/01/24 14:26	0			0			5.9			0			0			0		
08/01/24 14:27	0			0			0			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/01/24 14:16	0			0			0			0			0			0		
08/01/24 14:17	0			0			0			0			0			0		
08/01/24 14:18	0			0			0			0			0			0		
08/01/24 14:19	0			0			0			0			0			0		
08/01/24 14:20	0			0			0			0			0			0		
08/01/24 14:21	0			-0.2			0			0			0			1		
08/01/24 14:22	0			-0.2			0			0			0			1		
08/01/24 14:23	0			0			0			0			0			0		
08/01/24 14:24	0			0			0			0			0			0		
08/01/24 14:25	0			0			5.9			0			0			0		
08/01/24 14:26	0			0			5.9			0			0			0		
08/01/24 14:27	0			0			0			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/01/24 14:33	0			0			0			0			0			0		
08/01/24 14:34	0			0			0			0			0			0		
08/01/24 14:35	0			0			0			0			0			0		
08/01/24 14:36	0			0			0			0			0			0		
08/01/24 14:37	0			0			0			0			0			0		
08/01/24 14:38	0			-0.1			0			0			0			1		
08/01/24 14:39	7867.2			-0.1			0			0			0			1		
08/01/24 14:40	27471.6			1038.4			47.2			76.47			5.72			1		
08/01/24 14:41	41455.8			1019.3			16.79			110.89			3.01			1		
08/01/24 14:42	53695.5			674.9			20.98			92.61			4.74			1		
08/01/24 14:43	65958.4			323.4			25			53.71			6.84			1		
08/01/24 14:44	95642.3			170.8			28.22			39.28			10.68			1		
08/01/24 14:45	141025.9			97.7			40.59			32.63			22.31			1		
08/01/24 14:46	146397.8			66.8			56.53			23.1			32.17			1		
08/01/24 14:47	165990.6			947.6			53.1			371.22			34.23			1		
08/01/24 14:48	189234			898.6			56.54			399.28			41.35			1		
08/01/24 14:49	216468.8			193.1			59.14			98.17			49.48			1		
08/01/24 14:50	241693.5			11.7			59.25			6.62			55.33			1		
08/01/24 14:51	266918.1			1.3			59.67			0.84			61.55			1		
08/01/24 14:52	294672.7			0.9			41.1			0.62			46.8			1		
08/01/24 14:53	318488			1			18.62			0.76			22.92			1		
08/01/24 14:54	340079.4			1.2			11.44			0.93			15.04			1		
08/01/24 14:55	360943			1.2			8.72			1.04			12.16			1		
08/01/24 14:56	374043.5			1.1			8.72			1.01			12.6			1		
08/01/24 14:57	375464.4			1.1			8.1			1.01			11.76			1		
08/01/24 14:58	375250.7			1			8.37			0.85			12.13			1		
08/01/24 14:59	375712.8			1			7.66			0.85			11.12			1		
08/01/24 15:00	374551.8			1			7.38			0.84			10.67			1		
08/01/24 15:01	373893.3			0.8			7.38			0.69			10.66			1		
08/01/24 15:02	373153.9			0.7			7.31			0.62			10.54			1		
08/01/24 15:03	372813.1			0.7			7.22			0.62			10.4			1		
08/01/24 15:04	372564.8			0.8			7.04			0.69			10.14			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/01/24 15:05	372766.9			0.9			6.96			0.77			10.02			1		
08/01/24 15:06	371652.1			0.8			6.88			0.7			9.89			1		
08/01/24 15:07	371068.7			0.8			6.6			0.69			9.47			1		
08/01/24 15:08	369474.5			0.7			4.65			0.62			6.64			1		
08/01/24 15:09	370676			0.8			3.22			0.7			4.61			1		
08/01/24 15:10	369670.9			0.8			3.22			0.7			4.6			1		
08/01/24 15:11	369682.5			0.8			3.49			0.7			4.98			1		
08/01/24 15:12	370392.9			0.7			3.93			0.62			5.63			1		
08/01/24 15:13	368400.1			0.6			3.93			0.54			5.6			1		
08/01/24 15:14	369341.7			0.6			4.02			0.54			5.74			1		
08/01/24 15:15	368677.4			0.6			3.75			0.54			5.35			1		
08/01/24 15:16	368943.1			0.6			2.95			0.54			4.21			1		
08/01/24 15:17	367764.8			0.7			2.68			0.62			3.81			1		
08/01/24 15:18	377220.4			0.7			2.59			0.63			3.78			1		
08/01/24 15:19	397188.7			0.7			2.54			0.68			3.9			1		
08/01/24 15:20	418000.3			0.6			2.58			0.63			4.17			1		
08/01/24 15:21	424123			0.6			2.49			0.55			4.08			1		
08/01/24 15:22	424157.8			0.6			2.53			0.56			4.14			1		
08/01/24 15:23	430442.3			0.6			2.03			0.65			3.37			1		
08/01/24 15:24	440787.4			0.7			1.4			0.68			2.39			1		
08/01/24 15:25	444022.1			0.6			1.29			0.67			2.21			1		
08/01/24 15:26	444362.9			0.7			1.4			0.68			2.41			1		
08/01/24 15:27	444455.3			0.6			1.5			0.59			2.57			1		
08/01/24 15:28	444611.3			0.6			1.78			0.59			3.06			1		
08/01/24 15:29	442820.7			0.6			1.97			0.58			3.37			1		
08/01/24 15:30	440735.5			0.6			2.15			0.58			3.67			1		
08/01/24 15:31	441359.3			0.6			2.25			0.58			3.83			1		
08/01/24 15:32	440336.9			0.6			2.15			0.58			3.67			1		
08/01/24 15:33	440152			0.6			1.97			0.58			3.35			1		
08/01/24 15:34	438500			0.6			1.66			0.66			2.81			1		
08/01/24 15:35	438217			0.6			1.48			0.66			2.5			1		
08/01/24 15:36	438563.6			0.6			1.4			0.58			2.38			1		
08/01/24 15:37	437674.1			0.6			1.38			0.57			2.34			1		
08/01/24 15:38	439043.1			0.6			1.5			0.58			2.54			1		
08/01/24 15:39	438858.2			0.6			1.59			0.58			2.7			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/01/24 15:40	438453.8			0.6			1.66			0.66			2.81			1		
08/01/24 15:41	437633.6			0.6			1.66			0.66			2.81			1		
08/01/24 15:42	438829.3			0.6			1.69			0.58			2.86			1		
08/01/24 15:43	447256.8			0.6			1.38			0.58			2.39			1		
08/01/24 15:44	458329.8			0.6			1.22			0.6			2.16			0		
08/01/24 15:45	455066.2			0.6			1.01			0.59			1.78			0		
08/01/24 15:46	456013.5			0.6			1.01			0.69			1.79			0		
08/01/24 15:47	454794.7			0.7			1.03			0.72			1.85			0		
08/01/24 15:48	453772.3			1.7			0.92			1.84			1.69			0		

Monthly Summary By Day Report

Unit CT2

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:53 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
07/01/2024	16.74	54.66	5.3	11.92	19.74
07/02/2024	14.68	62.81	6.6	13.62	22.66
07/03/2024	15.50	59.92	6.2	13.11	21.77
07/04/2024	15.91	51.22	5.0	11.17	18.52
07/05/2024	15.94	54.12	5.6	11.85	19.74
07/06/2024	15.56	55.19	5.7	12.09	20.07
07/07/2024	13.60	58.21	6.0	12.77	21.20
07/08/2024	13.34	61.58	6.5	13.37	22.26
07/09/2024	13.68	63.07	6.7	13.68	22.79
07/10/2024	15.24	61.27	6.8	13.46	22.41
07/11/2024	13.07	64.02	6.7	13.89	23.20
07/12/2024	14.29	61.01	6.4	13.23	22.06
07/13/2024	15.51	51.86	5.0	11.26	18.80
07/14/2024	15.33	51.70	4.9	11.21	18.64
07/15/2024	14.99	51.24	4.8	11.08	18.45
07/16/2024	15.94	52.54	5.4	11.40	19.00
07/17/2024	15.70	51.99	5.3	11.27	18.76
07/18/2024	24.42	26.18	2.3	4.93	8.22
07/19/2024	0.00	0.00	0.0	0.00	0.00
07/20/2024	24.40	57.74	5.1	10.12	16.88
07/21/2024	15.81	53.69	5.5	11.64	19.41
07/22/2024	13.68	64.71	7.0	13.92	23.20
07/23/2024	7.78	80.79	9.2	17.41	29.03
07/24/2024	11.91	72.44	8.1	15.87	26.43
07/25/2024	12.83	64.21	6.8	13.88	23.11
07/26/2024	15.10	51.97	5.1	11.30	18.72
07/27/2024	15.42	51.77	4.8	11.04	18.44
07/28/2024	15.37	51.64	4.8	11.05	18.45
07/29/2024	16.84	55.25	5.4	11.89	19.85
07/30/2024	14.20	59.15	6.0	12.72	21.23
07/31/2024	14.45	61.49	6.5	13.28	22.09
Monthly Avg/Sum:	457.23 sum	1,717.44 sum	175.5 sum	369.43 sum	615.13 sum
Daily Min:	7.78	26.18	2.3	4.93	8.22
Daily Max:	24.42	80.79	9.2	17.41	29.03
Jul 2024 - Jul 2024	457.23 sum	1,717.44 sum	175.5 sum	369.43 sum	615.13 sum
QTD:	457.23 sum	1,717.44 sum	175.5 sum	369.43 sum	615.13 sum
YTD 2024:	2,440.63 sum	5,452.72 sum	546.1 sum	1,151.39 sum	1,917.71 sum

Monthly Summary By Day Report

Unit CT2

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:53 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
08/01/2024	57.02	58.65	5.1	10.13	16.95
08/02/2024	16.44	64.98	7.6	14.89	24.84
08/03/2024	15.46	40.16	5.7	11.97	19.92
08/04/2024	15.63	42.86	5.6	11.98	19.97
08/05/2024	16.24	36.67	5.5	11.73	19.61
08/06/2024	16.75	35.81	5.5	11.92	19.84
08/07/2024	16.33	39.50	4.9	11.20	18.63
08/08/2024	15.37	32.52	4.8	11.10	18.50
08/09/2024	15.47	31.87	4.9	11.12	18.53
08/10/2024	15.44	29.72	4.8	11.07	18.47
08/11/2024	16.87	46.81	5.9	12.25	20.47
08/12/2024	17.03	38.48	5.2	11.51	19.22
08/13/2024	18.48	38.56	5.1	11.49	19.17
08/14/2024	18.47	41.41	5.6	12.19	20.32
08/15/2024	19.50	37.83	5.8	12.25	20.43
08/16/2024	19.34	34.64	5.2	11.35	18.90
08/17/2024	18.20	26.04	5.0	11.12	18.50
08/18/2024	18.37	38.41	4.8	10.85	18.06
08/19/2024	19.28	43.32	5.1	11.22	18.66
08/20/2024	17.68	47.05	4.8	11.06	18.41
08/21/2024	18.41	51.18	4.8	11.03	18.31
08/22/2024	18.17	51.52	4.8	11.04	18.36
08/23/2024	18.92	51.98	4.8	11.07	18.53
08/24/2024	19.21	52.17	4.8	11.09	18.56
08/25/2024	20.84	52.69	5.2	11.44	19.08
08/26/2024	19.95	52.27	5.2	11.37	18.97
08/27/2024	20.00	51.48	4.9	11.14	18.59
08/28/2024	20.00	51.54	4.9	11.13	18.57
08/29/2024	20.11	53.10	5.2	11.51	19.14
08/30/2024	19.50	51.17	4.8	11.05	18.44
08/31/2024	19.95	57.51	5.9	12.45	20.79
Monthly Avg/Sum:	598.43 sum	1,381.90 sum	162.2 sum	356.72 sum	594.74 sum
Daily Min:	15.37	26.04	4.8	10.13	16.95
Daily Max:	57.02	64.98	7.6	14.89	24.84
Jul 2024 - Aug 2024	1,055.66 sum	3,099.34 sum	337.7 sum	726.15 sum	1,209.87 sum
QTD:	1,055.66 sum	3,099.34 sum	337.7 sum	726.15 sum	1,209.87 sum
YTD 2024:	3,039.06 sum	6,834.62 sum	708.3 sum	1,508.11 sum	2,512.45 sum

Monthly Summary By Day Report

Unit CT2

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:53 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
09/01/2024	19.62	51.80	4.8	11.21	18.70
09/02/2024	19.96	50.88	5.1	11.37	18.96
09/03/2024	21.37	57.20	6.1	12.61	21.01
09/04/2024	20.71	62.75	6.9	13.64	22.73
09/05/2024	18.23	67.14	7.3	14.54	24.19
09/06/2024	17.57	67.22	7.4	14.60	24.37
09/07/2024	18.76	67.20	7.0	14.39	24.01
09/08/2024	19.29	62.85	6.6	13.63	22.71
09/09/2024	22.52	54.91	5.5	11.94	19.91
09/10/2024	20.36	52.20	4.9	11.17	18.66
09/11/2024	20.62	51.26	4.9	11.10	18.58
09/12/2024	18.10	51.09	4.8	11.05	18.49
09/13/2024	16.77	56.52	6.0	12.30	20.51
09/14/2024	17.06	53.46	5.4	11.59	19.37
09/15/2024	15.78	52.30	4.8	11.14	18.60
09/16/2024	18.12	53.93	5.9	12.15	20.24
09/17/2024	16.54	52.82	4.9	11.37	18.90
09/18/2024	17.06	54.27	5.4	11.72	19.57
09/19/2024	18.21	58.05	6.3	12.82	21.36
09/20/2024	16.80	52.64	5.2	11.51	19.11
09/21/2024	16.43	57.35	5.7	12.44	20.71
09/22/2024	16.68	51.79	5.0	11.19	18.59
09/23/2024	17.22	57.02	6.0	12.37	20.56
09/24/2024	17.78	54.38	5.6	11.90	19.79
09/25/2024	16.07	51.26	5.0	11.20	18.62
09/26/2024	17.41	54.53	5.5	12.15	20.15
09/27/2024	19.03	55.66	5.8	12.14	20.20
09/28/2024	18.28	54.08	5.3	11.70	19.52
09/29/2024	16.68	50.20	4.9	11.00	18.33
09/30/2024	16.19	61.14	6.3	13.26	22.02
Monthly Avg/Sum:	545.22 sum	1,677.90 sum	170.3 sum	365.20 sum	608.47 sum
Daily Min:	15.78	50.20	4.8	11.00	18.33
Daily Max:	22.52	67.22	7.4	14.60	24.37
Jul 2024 - Sep 2024	1,600.88 sum	4,777.24 sum	508.0 sum	1,091.35 sum	1,818.34 sum
QTD:	1,600.88 sum	4,777.24 sum	508.0 sum	1,091.35 sum	1,818.34 sum
YTD 2024:	3,584.28 sum	8,512.52 sum	878.6 sum	1,873.31 sum	3,120.92 sum

Startup / Shutdown Events

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 06:48 Location: Roseville, CA

Unit offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
07/18/2024 01:00	07/18/2024 01:00	1
07/18/2024 16:00	07/20/2024 06:00	39
08/01/2024 08:00	08/01/2024 13:00	6

Startup / Shutdown Events

CT2



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 06:48 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	46.00 Hour(s)
Offline Percentage:	2.08 %
Total Online:	2,162.00 Hour(s)
Online Percentage:	97.92 %

Startup / Shutdown Events

CT2



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 06:48 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	07/18/2024 15:11	07/18/2024 15:25	Shutdown	15
2	07/20/2024 07:37	07/20/2024 08:42	cold Startup	66
3	08/01/2024 07:21	08/01/2024 07:32	Shutdown	12
4	08/01/2024 14:21	08/01/2024 14:22	warm Startup	2
5	08/01/2024 14:21	08/01/2024 14:22	Shutdown	2
6	08/01/2024 14:38	08/01/2024 15:43	cold Startup	66

Startup / Shutdown Events

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 06:48 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	2	132	0.10
Warm Startup	1	2	0.00
Shutdown	3	29	0.02
Total Process Events:	6	163	0.13

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	2,152.83 Hour(s)
Total Startup Time:	134 Minute(s)
Total Shutdown Time:	29 Minute(s)
Total Startup/Shutdown Time:	163 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.13 %

Replace the dates with the ones you need

7/1/2024 0:00
9/30/2024 0:00

1D

TOWER AVG.

519-AIT-9504-1 5138

7/1/24 0:00	4720.7
7/2/24 0:00	4404.7
7/3/24 0:00	4945.3
7/4/24 0:00	5076.5
7/5/24 0:00	4889.5
7/6/24 0:00	5064.6
7/7/24 0:00	5481.1
7/8/24 0:00	5619.4
7/9/24 0:00	5199.0
7/10/24 0:00	5395.2
7/11/24 0:00	5686.1
7/12/24 0:00	5044.5
7/13/24 0:00	5583.0
7/14/24 0:00	5654.3
7/15/24 0:00	5313.1
7/16/24 0:00	4851.0
7/17/24 0:00	4783.5
7/18/24 0:00	5080.4
7/19/24 0:00	5120.9
7/20/24 0:00	5511.4
7/21/24 0:00	5129.3
7/22/24 0:00	5895.4
7/23/24 0:00	5227.9
7/24/24 0:00	5153.7
7/25/24 0:00	4937.0
7/26/24 0:00	4655.4
7/27/24 0:00	4826.7
7/28/24 0:00	4533.1
7/29/24 0:00	5068.4
7/30/24 0:00	4863.9
7/31/24 0:00	4707.2
8/1/24 0:00	5189.6
8/2/24 0:00	5368.4
8/3/24 0:00	5367.9
8/4/24 0:00	5180.8
8/5/24 0:00	5933.0
8/6/24 0:00	5599.0
8/7/24 0:00	5461.5
8/8/24 0:00	6024.6
8/9/24 0:00	5659.3
8/10/24 0:00	5298.1
8/11/24 0:00	5966.6
8/12/24 0:00	5428.0
8/13/24 0:00	5016.7
8/14/24 0:00	5739.2
8/15/24 0:00	5585.9
8/16/24 0:00	5336.4
8/17/24 0:00	5424.5
8/18/24 0:00	5400.2

8/19/24 0:00	5050.2
8/20/24 0:00	5323.3
8/21/24 0:00	5145.7
8/22/24 0:00	5144.8
8/23/24 0:00	4847.3
8/24/24 0:00	5267.8
8/25/24 0:00	4698.3
8/26/24 0:00	5522.4
8/27/24 0:00	4600.7
8/28/24 0:00	4737.5
8/29/24 0:00	4367.0
8/30/24 0:00	4756.8
8/31/24 0:00	4690.8
9/1/24 0:00	4782.3
9/2/24 0:00	5036.9
9/3/24 0:00	5045.0
9/4/24 0:00	5443.2
9/5/24 0:00	5132.8
9/6/24 0:00	5214.0
9/7/24 0:00	4865.1
9/8/24 0:00	5059.8
9/9/24 0:00	6009.0
9/10/24 0:00	5900.6
9/11/24 0:00	5214.4
9/12/24 0:00	5233.6
9/13/24 0:00	5546.0
9/14/24 0:00	5350.7
9/15/24 0:00	5224.4
9/16/24 0:00	5270.0
9/17/24 0:00	5115.3
9/18/24 0:00	4930.6
9/19/24 0:00	5462.6
9/20/24 0:00	4467.7
9/21/24 0:00	4619.8
9/22/24 0:00	4601.0
9/23/24 0:00	4950.9
9/24/24 0:00	4338.7
9/25/24 0:00	4575.9
9/26/24 0:00	4593.3
9/27/24 0:00	4581.0
9/28/24 0:00	4285.2

Resize to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	5138	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00328832	

<u>Design drift rate</u>	0.005%
--------------------------	---------------

PM-10 pounds per day	10.61
----------------------	--------------

92	Days in quarter
----	-----------------

PM-10 pounds this quarter	976	3Q24
---------------------------	------------	-------------

fill only these

AQ-70

AQ-70 PM-10 emission rates from the cooling tower shall not exceed the following limits

Cooling Tower Emissions Limitations					
Pollutant	Lbs/day	Quarter 1	Quarter 2	Quarter 3	Quarter 4
PM 10	16.3	1471	1487	1504	1504

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

III. Emissions Deviations

AQ-34

AQ-34 the Project owner shall maintain the following records: occurrence, duration, and type of any startup, shutdown, or malfunction: performance testing, evaluations, calibrations, check, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any continuous emission monitor; emission measurements, total daily and rolling twelve month averages hours of operation, hourly quantity of fuel used and gross three hour average operating load.

Verification; The Project owner shall submit to the CPM all data identified in this condition as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

CO Ppmvdc EDS/CMS Summary Report



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59

Generated: 10/11/2024 08:31

Facility Name: ROSEVILLE ENERGY

Location: Roseville, CA

Description: Electric Utility

CMS Data from:

EDS Data from:

Emission Limitation:

No Value Exclusions Allowed

Monitor Manufacturer and Model No.:

Date of Latest CMS Certification or Audit:

Process Unit(s) Description:

Operating time for EDS:

Operating time for CMS:

CT1_CO_Ppmvdc_1H, CT1_UnitOn_TF_1H

CT1_CO_Ppmvdc_3H, CT1_UnitOn_TF_1H

4

TELEDYNE MONITOR LABS INC, TML30

04/09/2006 14:00

2,208.00 Hour(s)

2,208.00 Hour(s)

Emission Data Summary		CMS Performance Summary	
1. Duration of excess emission in reporting period due to:		1. CMS downtime in reporting period due to:	
a. Startup/shutdown	0	a. Monitor equipment malfunctions	0
b. Control equipment problems	0	b. Non-Monitor equipment malfunctions	0
c. Process Problems	0	c. Quality assurance calibration	0
d. Other known causes	0	d. Other known causes	0
e. Unknown causes	0	e. Unknown causes	7
2. Upset Conditions	0	2. Total CMS Downtime	7
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0	3. Total Downtime as a percentage of operating time	0.32
4. Time of Excess Emission as a percentage of operating time	0.00	4. Total Availability as a percentage of operating time	99.68
5. Time in compliance as percentage of operating time	100.00		

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Lb/Hr EDS/CMS Summary Report

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59

Generated: 10/11/2024 08:32

Facility Name: ROSEVILLE ENERGY

Location: Roseville, CA

Description: Electric Utility

CMS Data from:

EDS Data from:

Emission Limitation:

No Value Exclusions Allowed

Monitor Manufacturer and Model No.:

Date of Latest CMS Certification or Audit:

Process Unit(s) Description:

Operating time for EDS:

Operating time for CMS:

CT1_CO_3Hr_LbPerHr_1H, CT1_UnitOn_TF_1H

CT1_CO_3Hr_LbPerHr_1H, CT1_UnitOn_TF_1H

6.2

TELEDYNE MONITOR LABS INC, TML30

04/09/2006 14:00

2,208.00 Hour(s)

2,208.00 Hour(s)

Emission Data Summary		CMS Performance Summary	
1. Duration of excess emission in reporting period due to:		1. CMS downtime in reporting period due to:	
a. Startup/shutdown	0	a. Monitor equipment malfunctions	0
b. Control equipment problems	0	b. Non-Monitor equipment malfunctions	0
c. Process Problems	0	c. Quality assurance calibration	0
d. Other known causes	0	d. Other known causes	0
e. Unknown causes	0	e. Unknown causes	7
2. Upset Conditions	0	2. Total CMS Downtime	7
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0	3. Total Downtime as a percentage of operating time	0.32
4. Time of Excess Emission as a percentage of operating time	0.00	4. Total Availability as a percentage of operating time	99.68
5. Time in compliance as percentage of operating time	100.00		

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO SUSD Lb/Hr EDS/CMS Summary Report



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:32 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_CO_SUSD_LbPerHr_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_CO_SUSD_LbPerHr_1H, CT1_UnitOn_TF_1H
Emission Limitation: 89.5
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 2,208.00 Hour(s)
Operating time for CMS: 2,208.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	114
2. Total CMS Downtime	114
3. Total Downtime as a percentage of operating time	5.16
4. Total Availability as a percentage of operating time	94.84

NOx Ppmvdc EDS/CMS Summary Report



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:34 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_NOx_Ppmvdc_1H, CT1_UnitOn_TF_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 2,208.00 Hour(s)
Operating time for CMS: 2,208.00 Hour(s)

Emission Data Summary	
-----------------------	--

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
-------------------------	--

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	7
2. Total CMS Downtime	7
3. Total Downtime as a percentage of operating time	0.32
4. Total Availability as a percentage of operating time	99.68

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Lb/Hr EDS/CMS Summary Report



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:34 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Norm_LbPerHr_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_NOx_Norm_LbPerHr_1H, CT1_UnitOn_TF_1H
Emission Limitation: 5.1
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 2,208.00 Hour(s)
Operating time for CMS: 2,208.00 Hour(s)

Emission Data Summary	
-----------------------	--

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
-------------------------	--

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	3
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	0.14
4. Total Availability as a percentage of operating time	99.86

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx SUSD Lb/Hr EDS/CMS Summary Report



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59

Generated: 10/11/2024 08:36

Facility Name: ROSEVILLE ENERGY

Location: Roseville, CA

Description: Electric Utility

CMS Data from:

EDS Data from:

Emission Limitation:

No Value Exclusions Allowed

Monitor Manufacturer and Model No.:

Date of Latest CMS Certification or Audit:

Process Unit(s) Description:

Operating time for EDS:

Operating time for CMS:

CT1_NOx_SUSD_LbPerHr_1H, CT1_UnitOn_TF_1H

CT1_NOx_SUSD_LbPerHr_1H, CT1_UnitOn_TF_1H

37.1

TELEDYNE MONITOR LABS INC, TML41-02

04/09/2006 14:00

2,208.00 Hour(s)

2,208.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	114
2. Total CMS Downtime	114
3. Total Downtime as a percentage of operating time	5.16
4. Total Availability as a percentage of operating time	94.84

CO Ppmvdc EDS/CMS Summary Report

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59

Generated: 10/11/2024 08:36

Facility Name: ROSEVILLE ENERGY

Location: Roseville, CA

Description: Electric Utility

CMS Data from:

EDS Data from:

Emission Limitation:

No Value Exclusions Allowed

Monitor Manufacturer and Model No.:

Date of Latest CMS Certification or Audit:

Process Unit(s) Description:

Operating time for EDS:

Operating time for CMS:

CT2_CO_Ppmvdc_1H, CT2_UnitOn_TF_1H

CT2_CO_Ppmvdc_3H, CT2_UnitOn_TF_1H

4

TELEDYNE MONITOR LABS INC, TML30

04/10/2006 07:00

2,162.00 Hour(s)

2,162.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	3
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	0.14
4. Total Availability as a percentage of operating time	99.86

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Lb/Hr EDS/CMS Summary Report

CT2

From: 07/01/2024 00:00 To: 09/30/2024 23:59
Generated: 10/11/2024 08:37

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA
Description: Electric Utility



CMS Data from: CT2_CO_3Hr_LbPerHr_1H, CT2_UnitOn_TF_1H
EDS Data from: CT2_CO_3Hr_LbPerHr_1H, CT2_UnitOn_TF_1H
Emission Limitation: 6.2
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 2,162.00 Hour(s)
Operating time for CMS: 2,162.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	11
2. Total CMS Downtime	11
3. Total Downtime as a percentage of operating time	0.51
4. Total Availability as a percentage of operating time	99.49

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO SUSD Lb/Hr EDS/CMS Summary Report



CT2

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:37 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT2_CO_SUSD_LbPerHr_1H, CT2_UnitOn_TF_1H
EDS Data from: CT2_CO_SUSD_LbPerHr_1H, CT2_UnitOn_TF_1H
Emission Limitation: 89.5
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 2,162.00 Hour(s)
Operating time for CMS: 2,162.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	187
2. Total CMS Downtime	187
3. Total Downtime as a percentage of operating time	8.65
4. Total Availability as a percentage of operating time	91.35

NOx Ppmvdc EDS/CMS Summary Report



CT2

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:38 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H, CT2_UnitOn_TF_1H
EDS Data from: CT2_NOx_Ppmvdc_1H, CT2_UnitOn_TF_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 2,162.00 Hour(s)
Operating time for CMS: 2,162.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	3
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	0.14
4. Total Availability as a percentage of operating time	99.86

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Lb/Hr EDS/CMS Summary Report

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59

Generated: 10/11/2024 08:38

Facility Name: ROSEVILLE ENERGY

Location: Roseville, CA

Description: Electric Utility

CMS Data from:

EDS Data from:

Emission Limitation:

No Value Exclusions Allowed

Monitor Manufacturer and Model No.:

Date of Latest CMS Certification or Audit:

Process Unit(s) Description:

Operating time for EDS:

Operating time for CMS:

CT2_NOx_Norm_LbPerHr_1H, CT2_UnitOn_TF_1H

CT2_NOx_Norm_LbPerHr_1H, CT2_UnitOn_TF_1H

5.1

TELEDYNE MONITOR LABS INC, TML41-O2

04/10/2006 07:00

2,162.00 Hour(s)

2,162.00 Hour(s)

Emission Data Summary		CMS Performance Summary	
1. Duration of excess emission in reporting period due to:		1. CMS downtime in reporting period due to:	
a. Startup/shutdown	0	a. Monitor equipment malfunctions	0
b. Control equipment problems	0	b. Non-Monitor equipment malfunctions	0
c. Process Problems	0	c. Quality assurance calibration	0
d. Other known causes	0	d. Other known causes	0
e. Unknown causes	0	e. Unknown causes	3
2. Upset Conditions	0	2. Total CMS Downtime	3
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0	3. Total Downtime as a percentage of operating time	0.14
4. Time of Excess Emission as a percentage of operating time	0.00	4. Total Availability as a percentage of operating time	99.86
5. Time in compliance as percentage of operating time	100.00		

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx SUSD Lb/Hr EDS/CMS Summary Report



CT2

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:39 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT2_NOx_SUSD_LbPerHr_1H, CT2_UnitOn_TF_1H
EDS Data from: CT2_NOx_SUSD_LbPerHr_1H, CT2_UnitOn_TF_1H
Emission Limitation: 37.1
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 2,162.00 Hour(s)
Operating time for CMS: 2,162.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	187
2. Total CMS Downtime	187
3. Total Downtime as a percentage of operating time	8.65
4. Total Availability as a percentage of operating time	91.35

CO Invalid Data

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:40 Location: Roseville, CA

Tag Name: CT1_CO_Ppm_1H
Total Operating Time: 2,208.00 Hour(s)
Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/16/2024 12:00	07/16/2024 13:59	2	4 - Other known causes	35 - Monthly Maintenance
2	07/21/2024 06:00	07/21/2024 06:59	1		
3	08/08/2024 10:00	08/08/2024 10:59	1	23 - Maintenance	35 - Monthly Maintenance
4	09/04/2024 12:00	09/04/2024 13:59	2	46 - HIGH PMT REPAIR	
5	09/20/2024 07:00	09/20/2024 07:59	1	3 - Quality assurance calibration	

Total Operating Time:	2,208.00 Hour(s)
Total Monitor Downtime (Online only):	7.00 Hour(s)
Percent Monitor Availability:	99.68 %
Percent Monitor Downtime:	0.32 %

Report Code	Type	Text	Duration	Duration Percent
46	Reason	HIGH PMT REPAIR	2	28.57
23	Reason	Maintenance	1	14.29
4	Reason	Other known causes	2	28.57
3	Reason	Quality assurance calibration	1	14.29
35	Action	Monthly Maintenance	3	42.86

NOx Invalid Data

CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:41 Location: Roseville, CA



Tag Name: CT1_NOx_Ppm_1H
Total Operating Time: 2,208.00 Hour(s)
Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/16/2024 12:00	07/16/2024 12:59	1	4 - Other known causes	
2	07/16/2024 13:00	07/16/2024 13:59	1	4 - Other known causes	
3	07/21/2024 06:00	07/21/2024 06:59	1		
4	08/08/2024 10:00	08/08/2024 10:59	1	23 - Maintenance	35 - Monthly Maintenance
5	09/04/2024 12:00	09/04/2024 12:59	1	45 - HIGH PMT REPAIR	
6	09/04/2024 13:00	09/04/2024 13:59	1	49 - HIGH PMT REPAIR	
7	09/20/2024 07:00	09/20/2024 07:59	1	3 - Quality assurance calibration	

Total Operating Time:	2,208.00 Hour(s)
Total Monitor Downtime (Online only):	7.00 Hour(s)
Percent Monitor Availability:	99.68 %
Percent Monitor Downtime:	0.32 %

Report Code	Type	Text	Duration	Duration Percent
45	Reason	HIGH PMT REPAIR	1	14.29
49	Reason	HIGH PMT REPAIR	1	14.29
23	Reason	Maintenance	1	14.29
4	Reason	Other known causes	2	28.57
3	Reason	Quality assurance calibration	1	14.29
35	Action	Monthly Maintenance	1	14.29

NOx SCR Invalid Data



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:42 Location: Roseville, CA

Tag Name: CT1_NOx_SCR_Ppm_1H
Total Operating Time: 2,208.00 Hour(s)
Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/20/2024 02:00	07/20/2024 02:59	1	3 - Quality assurance calibration	
2	07/20/2024 03:00	07/20/2024 03:59	1		
3	07/20/2024 04:00	07/20/2024 04:59	1		
4	07/20/2024 05:00	07/20/2024 05:59	1		
5	07/20/2024 06:00	07/20/2024 06:59	1		
6	07/20/2024 07:00	07/20/2024 07:59	1		
7	07/20/2024 08:00	07/20/2024 08:59	1		
8	07/20/2024 09:00	07/20/2024 09:59	1		
9	07/20/2024 10:00	07/20/2024 10:59	1		
10	07/20/2024 11:00	07/20/2024 11:59	1		
11	07/20/2024 12:00	07/20/2024 12:59	1		
12	07/20/2024 13:00	07/20/2024 13:59	1		
13	07/20/2024 14:00	07/20/2024 14:59	1		
14	07/20/2024 15:00	07/20/2024 15:59	1		
15	07/20/2024 16:00	07/20/2024 16:59	1		
16	07/20/2024 17:00	07/20/2024 17:59	1		
17	07/20/2024 18:00	07/20/2024 18:59	1		
18	07/20/2024 19:00	07/20/2024 19:59	1		
19	07/20/2024 20:00	07/20/2024 20:59	1		
20	07/20/2024 21:00	07/20/2024 21:59	1		
21	07/20/2024 22:00	07/20/2024 22:59	1		
22	07/20/2024 23:00	07/20/2024 23:59	1		
23	07/21/2024 00:00	07/21/2024 00:59	1		
24	07/21/2024 01:00	07/21/2024 01:59	1		
25	07/21/2024 02:00	07/21/2024 02:59	1	3 - Quality assurance calibration	
26	07/21/2024 03:00	07/21/2024 03:59	1		

NOx SCR Invalid Data



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:42 Location: Roseville, CA

Tag Name: CT1_NOx_SCR_Ppm_1H
Total Operating Time: 2,208.00 Hour(s)
Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
27	07/21/2024 04:00	07/21/2024 04:59	1	3 - Quality assurance calibration	
28	07/21/2024 05:00	07/21/2024 05:59	1		
29	07/21/2024 06:00	07/21/2024 06:59	1	3 - Quality assurance calibration	
30	08/08/2024 10:00	08/08/2024 10:59	1	23 - Maintenance	35 - Monthly Maintenance
31	09/04/2024 12:00	09/04/2024 12:59	1	44 - HIGH PMT REPAIR	
32	09/20/2024 07:00	09/20/2024 07:59	1		

Total Operating Time:	2,208.00 Hour(s)
Total Monitor Downtime (Online only):	32.00 Hour(s)
Percent Monitor Availability:	98.55 %
Percent Monitor Downtime:	1.45 %

Report Code	Type	Text	Duration	Duration Percent
44	Reason	HIGH PMT REPAIR	1	3.13
23	Reason	Maintenance	1	3.13
3	Reason	Quality assurance calibration	4	12.50
35	Action	Monthly Maintenance	1	3.13

02 Invalid Data

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:42 Location: Roseville, CA

Tag Name: CT1_O2Dry_Pct_1H
Total Operating Time: 2,208.00 Hour(s)
Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/16/2024 12:00	07/16/2024 12:59	1	4 - Other known causes	35 - Monthly Maintenance
2	07/16/2024 13:00	07/16/2024 13:59	1	4 - Other known causes	
3	07/21/2024 06:00	07/21/2024 06:59	1		
4	08/08/2024 10:00	08/08/2024 10:59	1	23 - Maintenance	35 - Monthly Maintenance
5	09/04/2024 12:00	09/04/2024 12:59	1	43 - HIGH PMT REPAIR	
6	09/04/2024 13:00	09/04/2024 13:59	1	50 - HIGH PMT REPAIR	
7	09/20/2024 07:00	09/20/2024 07:59	1	3 - Quality assurance calibration	

Total Operating Time:	2,208.00 Hour(s)
Total Monitor Downtime (Online only):	7.00 Hour(s)
Percent Monitor Availability:	99.68 %
Percent Monitor Downtime:	0.32 %

Report Code	Type	Text	Duration	Duration Percent
43	Reason	HIGH PMT REPAIR	1	14.29
50	Reason	HIGH PMT REPAIR	1	14.29
23	Reason	Maintenance	1	14.29
4	Reason	Other known causes	2	28.57
3	Reason	Quality assurance calibration	1	14.29
35	Action	Monthly Maintenance	2	28.57

CO Invalid Data

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:43 Location: Roseville, CA

Tag Name: CT2_CO_Ppm_1H
Total Operating Time: 2,162.00 Hour(s)
Non-Operating Time: 46.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/18/2024 03:00	07/18/2024 03:59	1	3 - Quality assurance calibration	
2	08/20/2024 12:00	08/20/2024 12:59	1	3 - Quality assurance calibration	
3	08/20/2024 13:00	08/20/2024 13:59	1	3 - Quality assurance calibration	

Total Operating Time:	2,162.00 Hour(s)
Total Monitor Downtime (Online only):	3.00 Hour(s)
Percent Monitor Availability:	99.86 %
Percent Monitor Downtime:	0.14 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	3	100.00

NOx Invalid Data

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:44 Location: Roseville, CA

Tag Name: CT2_NOx_Ppm_1H
Total Operating Time: 2,162.00 Hour(s)
Non-Operating Time: 46.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/18/2024 03:00	07/18/2024 03:59	1	3 - Quality assurance calibration	
2	08/20/2024 12:00	08/20/2024 12:59	1	3 - Quality assurance calibration	
3	08/20/2024 13:00	08/20/2024 13:59	1	3 - Quality assurance calibration	

Total Operating Time:	2,162.00 Hour(s)
Total Monitor Downtime (Online only):	3.00 Hour(s)
Percent Monitor Availability:	99.86 %
Percent Monitor Downtime:	0.14 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	3	100.00

NOx SCR Invalid Data



CT2

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:44 Location: Roseville, CA

Tag Name: CT2_NOx_SCR_Ppm_1H
Total Operating Time: 2,162.00 Hour(s)
Non-Operating Time: 46.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	2,162.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

02 Invalid Data

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:45 Location: Roseville, CA

Tag Name: CT2_O2Dry_Pct_1H
Total Operating Time: 2,162.00 Hour(s)
Non-Operating Time: 46.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/18/2024 03:00	07/18/2024 03:59	1	3 - Quality assurance calibration	
2	08/20/2024 12:00	08/20/2024 12:59	1	3 - Quality assurance calibration	
3	08/20/2024 13:00	08/20/2024 13:59	1	3 - Quality assurance calibration	

Total Operating Time:	2,162.00 Hour(s)
Total Monitor Downtime (Online only):	3.00 Hour(s)
Percent Monitor Availability:	99.86 %
Percent Monitor Downtime:	0.14 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	3	100.00