

DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	259821-4
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2024 - Part 6 - searchable
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/30/2024 4:56:32 PM
Docketed Date:	10/30/2024

RegPerfect CEMS Logs

Log Time	Operator	Initials	Description	Tags	Files
09/26/2024 13:39	cro-operator	JB	CHANGED OUT CT-1 O2 CYLINDER. CYL# 213608054, 18.00% - O2, EXP. 07/04/32		
09/19/2024 16:08	cro-operator	RC	CHANGED OUT O2 BOTTLE CT-2 18.09PPM ID#EB0155825 EXP02-06-2031		
09/15/2024 10:19	cro-operator	DWN	CHANGED UNIT 2 HIGH NOX / CO BOTTLE. CC7336. NOX 179.7 / CO 177.3. EXP. 8/12/32		
09/15/2024 10:12	cro-operator	DWN	CHANGED UNIT 1 HIGH NOX / CO BOTTLE. CC50094. NOX 182.0 / CO 182.7. EXP 4/3/31		
09/12/2024 10:26	cro-operator	SM	UNIT 1 CEMS MONTHLY MAINTENANCE. REPLACED ALL 3 ANALYZER PARTICULATE FILTERS. REPLACED CO PUMP DIAPHRAGM. SPANNED GAS. RECORDED TST DATA		
09/12/2024 10:25	cro-operator	SM	HANDS FREE CAL UNIT 2		
09/12/2024 09:09	cro-operator	DWN	CHANGED UNIT 1 30 PPM NOX BOTTLE. CC53521. 21.34 PPM. EXP 7/9/27		
09/12/2024 08:42	cro-operator	BRB	REBUILT CT2 CO PUMP AS PM, STEVE ALSO CHANGED OUT PART FILTER +SPANNED GASSES.		
09/07/2024 14:47	cro-operator	DWN	CHANGED UNIT 2 30 PPM NOX BOTTLE. CC118014. 21.19 PPM. EXP 4/9/27		
09/06/2024 00:58	cro-operator	RC	CHANGED LOW NOX CEMS BOTTLE UNIT-1 CYLINDER EB0144535 NOX-9.615 CO-9.046		
09/04/2024 14:26	cro-operator	SM	A/C FAILED. SWAPPED LAG UNIT TO LEAD UNIT. ALSO FOUND INLET NOX ANALYZER FAN FAILED. REPLACED FAN. PERFORMED MANUAL CAL AND STARTED HANDS FREE.		
09/03/2024 15:28	cro-operator	CMC	GCV VALUES UPDATED FOR CT1, CT2, CT5, CT6 AS WELL AS THE GENERAL VALUE FROM 104900 TO 105505		
09/03/2024 12:47	cro-operator	RG	PERFORMED LINEARITY TESTING ON CT6. PASSED.		
08/29/2024 15:47	cro-operator	SM	CT6 PERFORMED MANUAL CAL, HANDS FREE AND CGA TESTING		
08/24/2024 08:07	cro-operator	LH	UNIT 1 O2 BOTTLE SWAPPED 17.94 PPM ID# 225104095 EXP 8/6/32		
08/21/2024 14:55	cro-operator	SM	CT6 CEMS MAINTENANCE. REPLACED ALL 3 ANALYZERS PARTICULATE FILTERS. REPLACED NOX ANALYZERS DFU FILTERS. SPANNED GAS. RECORDED TST DATA. STARTED HANDS FREE CAL		

RegPerfect CEMS Logs

Log Time	Operator	Initials	Description	Tags	Files
08/21/2024 09:46	cro-operator	SM	CT5 REPLACED PARTICULATE FILTER, PERFORMED MANUAL CAL AND RECORDED TST DATA		
08/20/2024 13:53	cro-operator	RG	CT2-PERFORMED LINEARITY/CGA TESTING		
08/20/2024 12:50	cro-operator	JB	CHANGED CT2 HIGH NOX CYLINDER# CC117116, EXP 4/12/31 NOX - 181.8 PPM, CO - 178.8 PPM		
08/17/2024 23:50	cro-operator	KRB	CHANGE OUT CT2 O2 CYCLINDER 225701001 O2 17.95		
08/17/2024 23:48	cro-operator	KRB	CHANGED OUT CT 2 HIGH NOX /CO CYCLINDER 225701149 NOX 181.7, CO178.7		
08/15/2024 10:07	cro-operator	DWN	CHANGED UNIT 2 9 PPM NOX/CO. CYLINDER EB0004641. EXP. 2/26/27. NOX 9.721 / CO 8.984		
08/14/2024 05:13	cro-operator	KRB	CHANGE CT 2 HIGH NOX CYCLINDER EB0037675 180.0 NOX 179.2 CO		
08/09/2024 20:47	cro-operator	LH	UNIT 2 INLET LOW NOX BOTTLE CHANGED 21.47 PPM NOX EXP 7/16/27 CYLINDER# 225702028		
08/08/2024 12:01	cro-operator	SM	CORRECTION TO PREVIOUS LOG 8-8-24 11:59. PM WAS FOR UNIT 1. MONTHLY CEMS MAINTENANCE, SPANNED ALL 3 ANALYZERS		
08/08/2024 11:59	cro-operator	SM	MONTHLY CEMS PM AND SPANNED GAS ON ALL 3 ANALYZERS		
08/07/2024 01:28	cro-operator	DWN	GCV UPDATED FOR CT1/CT2/CT5/CT6. 104,900		
08/01/2024 15:51	cro-operator	KRB	REP UNIT 2 HIGH NOX CYCLINDER CHANGE OUT181.8 CYCLINDER 225701149		
07/30/2024 14:02	cro-operator	GAB	CHANGED UNIT 2 O2 BOTTLE 18.02, CYLINDER # ALM016181 EXP 6/10/32		
07/30/2024 07:00	cro-operator	SM	ADJUSTED AMONIA BIAS FACTOR FROM RATA FOR CT5 TO 0.339 AND CT6 TO 0.183		
07/26/2024 23:26	cro-operator	EO	CHANGED CT2 LOW NOX BOTTLE. CYLINDER # EB0102296, EXP. DATE 02/09/27, CONC. 9.567		
07/23/2024 08:48	cro-operator	BRB	STARTED RATA ON CT2 7:00 am		
07/22/2024 16:20	cro-operator	BRB	CT2 SPANNED GAS, HANDS OFF CAL		
07/22/2024 05:57	cro-operator	BRB	CHANGED INLET NOX PUMP, SPANNED GAS, HANDS OFF CAL CT1 INLET.		
07/21/2024 13:14	cro-operator	DWN	CHANGED UNIT 1 O2 BOTTLE. CYLINDER 225701002. CONCENTRATION 18.09%. EXPIRATION 2/4/32		
07/19/2024 14:06	cro-operator	BRB	7-18-2024. PERFORMED MANUAL CAL, THEN HANDS OFF CAL ON INLET NOX ANALYZER CT1.		
07/17/2024 07:28	cro-operator	RG	REPLACED LINEARITY BOTTLE. O2 LOW. NEW BOTTLE 5.011%.		

RegPerfect CEMS Logs

Log Time	Operator	Initials	Description	Tags	Files
07/16/2024 16:09	cro-operator	SM	PERFORMED CGA AND LINEARITY ON CT1 CEMS. ALL PASSED		
07/15/2024 01:49	cro-operator	DE	REPLACE UNIT 2 HIGH SPAN NOX/CO DAILY CALIBRATION BOTTLE. CYLINDER # CC150850. NOX 179.7, CO 179.6.		
07/11/2024 03:26	cro-operator	RC	SCR INLET NOX BOTTLE CHANGED UNIT-1 ID: CC362946 21.21PPM		
07/10/2024 13:52	cro-operator	CMC	Updated GCV for CT1, CT2, CT5, CT6 and the general GCV		
07/10/2024 05:16	cro-operator	LH	UNIT 2 LOW 30 BOTTLE CHANGED 21.17 NOX, 19.83 CO #225104098 EXP 2/9/27 UNIT 2 O2 BOTTLE CHANGED 18.08% #225104102 EXP2/4/32		
07/02/2024 08:38	cro-operator	KRB	CT 5 CYCLINDER CHANGE OUT CC749717 HIGH CO 910.9		

Cylinder Gas Audit

10/11/2024

Page 1

Facility:	ROSEVILLE ENERGY	Instrument Name:	CT1_CODualRg_P_Instrum
Unit/Stack:	CT1	Test Date:	07/16/2024
Parameter/Scale:	CO / High	Test Result:	Pass
		Performance Spec:	15 Pct
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct	Span
07/16/2024	11:44	L	200	49.800	47.200	24.9	%
07/16/2024	11:49	M	200	109.200	108.200	54.6	%
07/16/2024	12:01	L	200	49.800	47.200	24.9	%
07/16/2024	12:06	M	200	109.200	107.100	54.6	%
07/16/2024	12:18	L	200	49.800	46.400	24.9	%
07/16/2024	12:23	M	200	109.200	106.300	54.6	%

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.800	46.933	Std	5.8
M	109.200	107.200	Std	1.8

Cylinder Gas Audit

10/11/2024

Page 2

Facility: ROSEVILLE ENERGY

Instrument Name: CT1_CODualRg_P_Instrum

Unit/Stack: CT1

Test Date: 07/16/2024

Performance Spec: 15 Pct

Parameter/Scale: CO / Low

Test Result: **Pass**

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/16/2024	13:44	L	10	2.400	2.300	24.0 %
07/16/2024	13:49	M	10	5.700	5.700	57.0 %
07/16/2024	13:56	L	10	2.400	2.300	24.0 %
07/16/2024	14:01	M	10	5.700	5.700	57.0 %
07/16/2024	14:08	L	10	2.400	2.300	24.0 %
07/16/2024	14:13	M	10	5.700	5.700	57.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.400		2.300	Std	4.2
M	5.700		5.700	Std	0.0

Cylinder Gas Audit

10/11/2024

Page 3

Facility: ROSEVILLE ENERGY

Instrument Name: CT2_CODualRg_P_Instrum

Unit/Stack: CT2

Test Date: 08/20/2024

Performance Spec: 15 Pct

Parameter/Scale: CO / High

Test Result: **Pass**

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/20/2024	11:51	L	200	49.900	50.400	25.0 %
08/20/2024	11:56	M	200	109.100	115.100	54.6 %
08/20/2024	12:08	L	200	49.900	50.400	25.0 %
08/20/2024	12:13	M	200	109.100	113.800	54.6 %
08/20/2024	12:25	L	200	49.900	51.000	25.0 %
08/20/2024	12:30	M	200	109.100	112.700	54.6 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.900	50.600	Std	1.4
M	109.100	113.867	Std	4.4

Cylinder Gas Audit

10/11/2024

Page 4

Facility: ROSEVILLE ENERGY

Instrument Name: CT2_CODualRg_P_Instrum

Unit/Stack: CT2

Test Date: 08/20/2024

Performance Spec: 15 Pct

Parameter/Scale: CO / Low

Test Result: **Pass**

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/20/2024	13:42	L	10	2.600	2.400	26.0 %
08/20/2024	13:47	M	10	5.600	5.700	56.0 %
08/20/2024	13:54	L	10	2.600	2.400	26.0 %
08/20/2024	13:59	M	10	5.600	5.900	56.0 %
08/20/2024	14:06	L	10	2.600	2.400	26.0 %
08/20/2024	14:11	M	10	5.600	5.700	56.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.600		2.400	Std	7.7
M	5.600		5.767	Std	3.0

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2024 00:00	3,366.5	73.4	3,366.5	104,400.0	351.5	0.43	0.2	0.7
07/01/2024 01:00	3,364.2	68.9	3,364.2	104,400.0	351.2	0.43	0.2	0.7
07/01/2024 02:00	3,366.8	67.9	3,366.8	104,400.0	351.5	0.43	0.2	0.7
07/01/2024 03:00	3,374.7	70.9	3,374.7	104,400.0	352.3	0.43	0.2	0.7
07/01/2024 04:00	3,369.6	73.6	3,369.6	104,400.0	351.8	0.43	0.2	0.7
07/01/2024 05:00	3,373.3	56.9	3,373.3	104,400.0	352.2	0.43	0.2	0.7
07/01/2024 06:00	3,385.4	50.5	3,385.4	104,400.0	353.4	0.43	0.2	0.7
07/01/2024 07:00	3,401.5	48.0	3,401.5	104,400.0	355.1	0.43	0.2	0.7
07/01/2024 08:00	3,397.5	66.1	3,397.5	104,400.0	354.7	0.43	0.2	0.7
07/01/2024 09:00	3,396.1	72.0	3,396.1	104,400.0	354.6	0.43	0.2	0.7
07/01/2024 10:00	3,396.6	57.8	3,396.6	104,400.0	354.6	0.43	0.2	0.7
07/01/2024 11:00	3,409.9	13.1	3,409.9	104,400.0	356.0	0.43	0.2	0.7
07/01/2024 12:00	3,412.5	10.9	3,412.5	104,400.0	356.3	0.43	0.2	0.7
07/01/2024 13:00	3,411.7	63.9	3,411.7	104,400.0	356.2	0.44	0.2	0.7
07/01/2024 14:00	3,423.5	63.6	3,423.5	104,400.0	357.4	0.44	0.2	0.7
07/01/2024 15:00	3,428.9	58.4	3,428.9	104,400.0	358.0	0.44	0.2	0.7
07/01/2024 16:00	3,426.4	52.0	3,426.4	104,400.0	357.7	0.44	0.2	0.7
07/01/2024 17:00	3,636.2	41.5	3,636.2	104,400.0	379.6	0.46	0.2	0.8
07/01/2024 18:00	4,212.0	1,087.3	5,060.1	104,400.0	528.3	0.66	0.3	1.1
07/01/2024 19:00	4,212.0	1,964.0	6,176.0	104,400.0	644.8	0.77	0.4	1.3
07/01/2024 20:00	4,235.7	1,193.4	5,429.1	104,400.0	566.8	0.68	0.3	1.1
07/01/2024 21:00	3,640.5	83.0	3,647.1	104,400.0	380.8	0.47	0.2	0.8
07/01/2024 22:00	3,385.4	77.8	3,385.4	104,400.0	353.4	0.43	0.2	0.7
07/01/2024 23:00	3,378.5	68.9	3,378.5	104,400.0	352.7	0.43	0.2	0.7
Average/Sum#:	3,516.9	228.5	3,684.1	104,400.0	384.6	0.47	0.2	0.8
Minimum:	3,364.2	10.9	3,364.2	104,400.0	351.2	0.43	0.2	0.7
Maximum:	4,235.7	1,964.0	6,176.0	104,400.0	644.8	0.77	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/02/2024 00:00	3,383.7	74.1	3,383.7	104,400.0	353.3	0.43	0.2	0.7
07/02/2024 01:00	3,376.7	78.1	3,376.7	104,400.0	352.5	0.43	0.2	0.7
07/02/2024 02:00	3,374.2	70.9	3,374.2	104,400.0	352.3	0.43	0.2	0.7
07/02/2024 03:00	3,372.7	71.5	3,372.7	104,400.0	352.1	0.43	0.2	0.7
07/02/2024 04:00	3,378.8	70.8	3,378.8	104,400.0	352.7	0.43	0.2	0.7
07/02/2024 05:00	3,678.0	57.6	3,678.0	104,400.0	384.0	0.47	0.2	0.8
07/02/2024 06:00	3,440.4	48.6	3,440.4	104,400.0	359.2	0.44	0.2	0.7
07/02/2024 07:00	3,400.3	60.4	3,400.3	104,400.0	355.0	0.43	0.2	0.7
07/02/2024 08:00	3,383.4	64.3	3,383.4	104,400.0	353.2	0.43	0.2	0.7
07/02/2024 09:00	3,377.7	65.9	3,377.7	104,400.0	352.6	0.43	0.2	0.7
07/02/2024 10:00	3,379.2	63.0	3,379.2	104,400.0	352.8	0.43	0.2	0.7
07/02/2024 11:00	3,399.2	34.3	3,399.2	104,400.0	354.9	0.43	0.2	0.7
07/02/2024 12:00	3,466.0	54.0	3,466.0	104,400.0	361.9	0.44	0.2	0.7
07/02/2024 13:00	3,925.2	306.9	4,063.3	104,400.0	424.2	0.53	0.3	0.9
07/02/2024 14:00	4,181.4	1,305.0	5,486.4	104,400.0	572.8	0.69	0.3	1.1
07/02/2024 15:00	4,171.1	1,625.3	5,796.4	104,400.0	605.1	0.73	0.4	1.2
07/02/2024 16:00	4,174.1	1,742.1	5,916.2	104,400.0	617.7	0.74	0.4	1.2
07/02/2024 17:00	4,170.1	1,909.4	6,079.5	104,400.0	634.7	0.76	0.4	1.3
07/02/2024 18:00	4,177.0	1,879.7	6,056.7	104,400.0	632.3	0.76	0.4	1.3
07/02/2024 19:00	4,176.3	1,831.4	6,007.7	104,400.0	627.2	0.75	0.4	1.3
07/02/2024 20:00	4,213.6	1,759.3	5,972.9	104,400.0	623.6	0.75	0.4	1.2
07/02/2024 21:00	4,224.1	1,478.1	5,702.2	104,400.0	595.3	0.71	0.4	1.2
07/02/2024 22:00	3,865.4	90.8	3,871.8	104,400.0	404.2	0.50	0.2	0.8
07/02/2024 23:00	3,408.4	76.3	3,408.4	104,400.0	355.8	0.44	0.2	0.7
Average/Sum#:	3,712.4	617.4	4,282.2	104,400.0	447.1	0.54	0.3	0.9
Minimum:	3,372.7	34.3	3,372.7	104,400.0	352.1	0.43	0.2	0.7
Maximum:	4,224.1	1,909.4	6,079.5	104,400.0	634.7	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/03/2024 00:00	3,422.9	74.6	3,422.9	104,400.0	357.4	0.44	0.2	0.7
07/03/2024 01:00	3,391.8	80.5	3,391.8	104,400.0	354.1	0.44	0.2	0.7
07/03/2024 02:00	3,386.9	79.7	3,386.9	104,400.0	353.6	0.43	0.2	0.7
07/03/2024 03:00	3,386.5	76.3	3,386.5	104,400.0	353.6	0.43	0.2	0.7
07/03/2024 04:00	3,384.5	73.7	3,384.5	104,400.0	353.3	0.43	0.2	0.7
07/03/2024 05:00	3,388.0	64.6	3,388.0	104,400.0	353.7	0.43	0.2	0.7
07/03/2024 06:00	3,386.0	59.3	3,386.0	104,400.0	353.5	0.43	0.2	0.7
07/03/2024 07:00	3,396.3	64.7	3,396.3	104,400.0	354.6	0.43	0.2	0.7
07/03/2024 08:00	3,391.3	68.4	3,391.3	104,400.0	354.1	0.43	0.2	0.7
07/03/2024 09:00	3,389.4	71.1	3,389.4	104,400.0	353.9	0.43	0.2	0.7
07/03/2024 10:00	3,388.6	70.0	3,388.6	104,400.0	353.8	0.43	0.2	0.7
07/03/2024 11:00	3,408.2	64.9	3,408.2	104,400.0	355.8	0.44	0.2	0.7
07/03/2024 12:00	3,415.4	62.2	3,415.4	104,400.0	356.6	0.44	0.2	0.7
07/03/2024 13:00	3,493.7	70.6	3,493.7	104,400.0	364.7	0.45	0.2	0.7
07/03/2024 14:00	4,196.0	798.2	4,858.5	104,400.0	507.2	0.63	0.3	1.0
07/03/2024 15:00	4,187.2	1,239.6	5,426.8	104,400.0	566.6	0.68	0.3	1.1
07/03/2024 16:00	4,176.4	1,657.8	5,834.2	104,400.0	609.1	0.73	0.4	1.2
07/03/2024 17:00	4,173.7	1,860.7	6,034.4	104,400.0	630.0	0.76	0.4	1.3
07/03/2024 18:00	4,179.6	1,835.0	6,014.6	104,400.0	627.9	0.75	0.4	1.3
07/03/2024 19:00	4,173.7	1,813.4	5,987.1	104,400.0	625.1	0.75	0.4	1.3
07/03/2024 20:00	4,206.8	1,406.2	5,613.0	104,400.0	586.0	0.70	0.4	1.2
07/03/2024 21:00	3,800.1	229.6	3,869.0	104,400.0	403.9	0.51	0.3	0.8
07/03/2024 22:00	3,389.7	80.4	3,389.7	104,400.0	353.9	0.43	0.2	0.7
07/03/2024 23:00	3,393.2	75.0	3,393.2	104,400.0	354.3	0.43	0.2	0.7
Average/Sum#:	3,646.1	499.0	4,085.4	104,400.0	426.5	0.52	0.3	0.9
Minimum:	3,384.5	59.3	3,384.5	104,400.0	353.3	0.43	0.2	0.7
Maximum:	4,206.8	1,860.7	6,034.4	104,400.0	630.0	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/04/2024 00:00	3,401.0	74.1	3,401.0	104,400.0	355.1	0.44	0.2	0.7
07/04/2024 01:00	3,393.9	75.8	3,393.9	104,400.0	354.3	0.43	0.2	0.7
07/04/2024 02:00	3,390.2	77.5	3,390.2	104,400.0	353.9	0.43	0.2	0.7
07/04/2024 03:00	3,389.1	81.1	3,389.1	104,400.0	353.8	0.43	0.2	0.7
07/04/2024 04:00	3,390.8	82.4	3,390.8	104,400.0	354.0	0.44	0.2	0.7
07/04/2024 05:00	3,393.5	69.8	3,393.5	104,400.0	354.3	0.43	0.2	0.7
07/04/2024 06:00	3,397.3	57.7	3,397.3	104,400.0	354.7	0.43	0.2	0.7
07/04/2024 07:00	3,404.5	63.2	3,404.5	104,400.0	355.4	0.43	0.2	0.7
07/04/2024 08:00	3,401.2	66.7	3,401.2	104,400.0	355.1	0.43	0.2	0.7
07/04/2024 09:00	3,400.5	76.5	3,400.5	104,400.0	355.0	0.44	0.2	0.7
07/04/2024 10:00	3,403.8	72.1	3,403.8	104,400.0	355.4	0.44	0.2	0.7
07/04/2024 11:00	3,416.7	57.0	3,416.7	104,400.0	356.7	0.44	0.2	0.7
07/04/2024 12:00	3,418.0	52.9	3,418.0	104,400.0	356.8	0.44	0.2	0.7
07/04/2024 13:00	3,416.4	58.7	3,416.4	104,400.0	356.7	0.44	0.2	0.7
07/04/2024 14:00	3,416.4	69.3	3,416.4	104,400.0	356.7	0.44	0.2	0.7
07/04/2024 15:00	3,407.5	58.8	3,407.5	104,400.0	355.7	0.43	0.2	0.7
07/04/2024 16:00	3,835.1	53.3	3,835.1	104,400.0	400.4	0.49	0.2	0.8
07/04/2024 17:00	3,570.4	56.9	3,570.4	104,400.0	372.7	0.46	0.2	0.8
07/04/2024 18:00	3,919.9	64.1	3,919.9	104,400.0	409.2	0.50	0.2	0.8
07/04/2024 19:00	3,399.7	70.9	3,399.7	104,400.0	354.9	0.43	0.2	0.7
07/04/2024 20:00	3,385.1	70.9	3,385.1	104,400.0	353.4	0.43	0.2	0.7
07/04/2024 21:00	3,383.0	72.5	3,383.0	104,400.0	353.2	0.43	0.2	0.7
07/04/2024 22:00	3,383.9	71.4	3,383.9	104,400.0	353.3	0.43	0.2	0.7
07/04/2024 23:00	3,397.0	72.8	3,397.0	104,400.0	354.6	0.43	0.2	0.7
Average/Sum#:	3,446.5	67.8	3,446.5	104,400.0	359.8	0.44	0.2	0.7
Minimum:	3,383.0	52.9	3,383.0	104,400.0	353.2	0.43	0.2	0.7
Maximum:	3,919.9	82.4	3,919.9	104,400.0	409.2	0.50	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/05/2024 00:00	3,983.1	75.4	3,983.1	104,400.0	415.8	0.51	0.3	0.8
07/05/2024 01:00	3,977.1	77.9	3,977.1	104,400.0	415.2	0.51	0.3	0.8
07/05/2024 02:00	3,973.4	78.6	3,973.4	104,400.0	414.8	0.51	0.3	0.8
07/05/2024 03:00	3,386.9	82.9	3,386.9	104,400.0	353.6	0.43	0.2	0.7
07/05/2024 04:00	3,380.1	84.0	3,380.1	104,400.0	352.9	0.43	0.2	0.7
07/05/2024 05:00	3,384.2	72.5	3,384.2	104,400.0	353.3	0.43	0.2	0.7
07/05/2024 06:00	3,386.0	57.6	3,386.0	104,400.0	353.5	0.43	0.2	0.7
07/05/2024 07:00	3,394.3	63.8	3,394.3	104,400.0	354.4	0.43	0.2	0.7
07/05/2024 08:00	3,389.3	65.7	3,389.3	104,400.0	353.8	0.43	0.2	0.7
07/05/2024 09:00	3,384.1	81.8	3,384.1	104,400.0	353.3	0.43	0.2	0.7
07/05/2024 10:00	3,385.4	74.3	3,385.4	104,400.0	353.4	0.43	0.2	0.7
07/05/2024 11:00	3,399.2	66.7	3,399.2	104,400.0	354.9	0.43	0.2	0.7
07/05/2024 12:00	3,402.2	66.7	3,402.2	104,400.0	355.2	0.43	0.2	0.7
07/05/2024 13:00	3,401.9	71.3	3,401.9	104,400.0	355.2	0.44	0.2	0.7
07/05/2024 14:00	3,402.5	72.5	3,402.5	104,400.0	355.2	0.44	0.2	0.7
07/05/2024 15:00	3,403.6	62.0	3,403.6	104,400.0	355.3	0.43	0.2	0.7
07/05/2024 16:00	3,400.8	52.7	3,400.8	104,400.0	355.0	0.43	0.2	0.7
07/05/2024 17:00	3,854.2	294.5	3,980.8	104,400.0	415.6	0.52	0.3	0.9
07/05/2024 18:00	4,142.5	1,631.1	5,773.6	104,400.0	602.8	0.72	0.4	1.2
07/05/2024 19:00	4,141.2	899.2	5,040.4	104,400.0	526.2	0.63	0.3	1.1
07/05/2024 20:00	3,772.7	249.1	3,847.4	104,400.0	401.7	0.50	0.3	0.8
07/05/2024 21:00	3,376.9	76.4	3,376.9	104,400.0	352.5	0.43	0.2	0.7
07/05/2024 22:00	3,375.8	73.8	3,375.8	104,400.0	352.4	0.43	0.2	0.7
07/05/2024 23:00	3,374.4	72.4	3,374.4	104,400.0	352.3	0.43	0.2	0.7
Average/Sum#:	3,561.3	187.6	3,675.1	104,400.0	383.7	0.47	0.2	0.8
Minimum:	3,374.4	52.7	3,374.4	104,400.0	352.3	0.43	0.2	0.7
Maximum:	4,142.5	1,631.1	5,773.6	104,400.0	602.8	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/06/2024 00:00	3,375.3	75.5	3,375.3	104,400.0	352.4	0.43	0.2	0.7
07/06/2024 01:00	3,379.1	75.6	3,379.1	104,400.0	352.8	0.43	0.2	0.7
07/06/2024 02:00	3,379.4	77.0	3,379.4	104,400.0	352.8	0.43	0.2	0.7
07/06/2024 03:00	3,378.8	77.1	3,378.8	104,400.0	352.7	0.43	0.2	0.7
07/06/2024 04:00	3,385.9	80.5	3,385.9	104,400.0	353.5	0.43	0.2	0.7
07/06/2024 05:00	3,388.1	75.5	3,388.1	104,400.0	353.7	0.43	0.2	0.7
07/06/2024 06:00	3,386.2	56.1	3,386.2	104,400.0	353.5	0.43	0.2	0.7
07/06/2024 07:00	3,394.9	60.6	3,394.9	104,400.0	354.4	0.43	0.2	0.7
07/06/2024 08:00	3,392.9	68.6	3,392.9	104,400.0	354.2	0.43	0.2	0.7
07/06/2024 09:00	3,390.3	78.5	3,390.3	104,400.0	353.9	0.43	0.2	0.7
07/06/2024 10:00	3,391.5	80.3	3,391.5	104,400.0	354.1	0.43	0.2	0.7
07/06/2024 11:00	3,406.0	69.1	3,406.0	104,400.0	355.6	0.44	0.2	0.7
07/06/2024 12:00	3,431.3	66.8	3,431.3	104,400.0	358.2	0.44	0.2	0.7
07/06/2024 13:00	3,435.9	74.4	3,435.9	104,400.0	358.7	0.44	0.2	0.7
07/06/2024 14:00	3,745.1	71.3	3,745.1	104,400.0	391.0	0.48	0.2	0.8
07/06/2024 15:00	3,439.6	62.1	3,439.6	104,400.0	359.1	0.44	0.2	0.7
07/06/2024 16:00	3,578.9	57.0	3,578.9	104,400.0	373.6	0.46	0.2	0.8
07/06/2024 17:00	3,986.9	558.2	4,254.8	104,400.0	444.2	0.57	0.3	0.9
07/06/2024 18:00	4,126.8	1,599.7	5,726.5	104,400.0	597.8	0.72	0.4	1.2
07/06/2024 19:00	4,119.3	1,216.2	5,335.5	104,400.0	557.0	0.67	0.3	1.1
07/06/2024 20:00	4,123.7	639.5	4,648.1	104,400.0	485.3	0.60	0.3	1.0
07/06/2024 21:00	4,096.9	82.8	4,096.9	104,400.0	427.7	0.52	0.3	0.9
07/06/2024 22:00	4,022.8	80.0	4,022.8	104,400.0	420.0	0.51	0.3	0.9
07/06/2024 23:00	3,497.3	77.9	3,497.3	104,400.0	365.1	0.45	0.2	0.7
Average/Sum#:	3,593.9	227.5	3,744.2	104,400.0	390.9	0.48	0.2	0.8
Minimum:	3,375.3	56.1	3,375.3	104,400.0	352.4	0.43	0.2	0.7
Maximum:	4,126.8	1,599.7	5,726.5	104,400.0	597.8	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2024 00:00	3,391.8	78.7	3,391.8	104,400.0	354.1	0.43	0.2	0.7
07/07/2024 01:00	3,386.5	81.1	3,386.5	104,400.0	353.6	0.43	0.2	0.7
07/07/2024 02:00	3,384.8	79.8	3,384.8	104,400.0	353.4	0.43	0.2	0.7
07/07/2024 03:00	3,384.2	84.8	3,384.2	104,400.0	353.3	0.43	0.2	0.7
07/07/2024 04:00	3,384.9	84.8	3,384.9	104,400.0	353.4	0.43	0.2	0.7
07/07/2024 05:00	3,391.9	78.3	3,391.9	104,400.0	354.1	0.43	0.2	0.7
07/07/2024 06:00	3,395.4	68.3	3,395.4	104,400.0	354.5	0.43	0.2	0.7
07/07/2024 07:00	3,401.1	75.2	3,401.1	104,400.0	355.1	0.44	0.2	0.7
07/07/2024 08:00	3,394.1	75.1	3,394.1	104,400.0	354.3	0.43	0.2	0.7
07/07/2024 09:00	3,393.1	82.2	3,393.1	104,400.0	354.2	0.44	0.2	0.7
07/07/2024 10:00	3,397.0	84.2	3,397.0	104,400.0	354.6	0.44	0.2	0.7
07/07/2024 11:00	3,410.1	76.4	3,410.1	104,400.0	356.0	0.44	0.2	0.7
07/07/2024 12:00	3,591.2	76.6	3,591.2	104,400.0	374.9	0.46	0.2	0.8
07/07/2024 13:00	3,565.5	79.9	3,565.5	104,400.0	372.2	0.46	0.2	0.8
07/07/2024 14:00	3,840.5	79.6	3,840.5	104,400.0	400.9	0.49	0.2	0.8
07/07/2024 15:00	3,643.6	103.0	3,662.1	104,400.0	382.3	0.47	0.2	0.8
07/07/2024 16:00	4,057.4	1,620.6	5,678.0	104,400.0	592.8	0.71	0.4	1.2
07/07/2024 17:00	4,074.3	1,730.6	5,804.9	104,400.0	606.0	0.73	0.4	1.2
07/07/2024 18:00	4,145.8	1,663.5	5,809.3	104,400.0	606.5	0.73	0.4	1.2
07/07/2024 19:00	4,159.7	1,615.0	5,774.7	104,400.0	602.9	0.72	0.4	1.2
07/07/2024 20:00	4,193.3	1,521.0	5,714.3	104,400.0	596.6	0.72	0.4	1.2
07/07/2024 21:00	3,997.5	447.5	4,266.0	104,400.0	445.4	0.56	0.3	0.9
07/07/2024 22:00	3,393.1	87.0	3,393.1	104,400.0	354.2	0.44	0.2	0.7
07/07/2024 23:00	3,392.2	87.0	3,392.2	104,400.0	354.1	0.44	0.2	0.7
Average/Sum#:	3,615.4	419.2	3,966.9	104,400.0	414.1	0.51	0.2	0.8
Minimum:	3,384.2	68.3	3,384.2	104,400.0	353.3	0.43	0.2	0.7
Maximum:	4,193.3	1,730.6	5,809.3	104,400.0	606.5	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2024 00:00	3,389.7	87.6	3,389.7	104,400.0	353.9	0.44	0.2	0.7
07/08/2024 01:00	3,389.0	88.0	3,389.0	104,400.0	353.8	0.44	0.2	0.7
07/08/2024 02:00	3,388.3	89.0	3,388.3	104,400.0	353.7	0.44	0.2	0.7
07/08/2024 03:00	3,386.6	89.6	3,386.6	104,400.0	353.6	0.44	0.2	0.7
07/08/2024 04:00	3,387.4	89.1	3,387.4	104,400.0	353.6	0.44	0.2	0.7
07/08/2024 05:00	3,388.8	84.2	3,388.8	104,400.0	353.8	0.44	0.2	0.7
07/08/2024 06:00	3,392.5	75.7	3,392.5	104,400.0	354.2	0.43	0.2	0.7
07/08/2024 07:00	3,402.2	78.6	3,402.2	104,400.0	355.2	0.44	0.2	0.7
07/08/2024 08:00	3,397.0	76.0	3,397.0	104,400.0	354.6	0.44	0.2	0.7
07/08/2024 09:00	3,395.2	84.0	3,395.2	104,400.0	354.5	0.44	0.2	0.7
07/08/2024 10:00	3,395.6	82.6	3,395.6	104,400.0	354.5	0.44	0.2	0.7
07/08/2024 11:00	3,407.5	70.8	3,407.5	104,400.0	355.7	0.44	0.2	0.7
07/08/2024 12:00	3,455.1	69.5	3,455.1	104,400.0	360.7	0.44	0.2	0.7
07/08/2024 13:00	3,543.0	78.6	3,543.0	104,400.0	369.9	0.45	0.2	0.8
07/08/2024 14:00	4,143.5	75.8	4,143.5	104,400.0	432.6	0.53	0.3	0.9
07/08/2024 15:00	3,789.3	70.7	3,789.3	104,400.0	395.6	0.49	0.2	0.8
07/08/2024 16:00	4,168.2	610.6	4,491.8	104,400.0	468.9	0.60	0.3	1.0
07/08/2024 17:00	4,181.6	1,733.8	5,915.4	104,400.0	617.6	0.74	0.4	1.2
07/08/2024 18:00	4,190.1	1,780.1	5,970.2	104,400.0	623.3	0.75	0.4	1.2
07/08/2024 19:00	4,193.1	1,580.0	5,773.1	104,400.0	602.7	0.72	0.4	1.2
07/08/2024 20:00	4,200.5	1,530.2	5,730.7	104,400.0	598.3	0.72	0.4	1.2
07/08/2024 21:00	4,239.3	1,343.1	5,582.4	104,400.0	582.8	0.70	0.3	1.2
07/08/2024 22:00	4,274.6	1,289.0	5,563.6	104,400.0	580.8	0.70	0.3	1.2
07/08/2024 23:00	4,308.0	978.4	5,286.4	104,400.0	551.9	0.66	0.3	1.1
Average/Sum#:	3,725.3	505.6	4,165.2	104,400.0	434.8	0.53	0.3	0.9
Minimum:	3,386.6	69.5	3,386.6	104,400.0	353.6	0.43	0.2	0.7
Maximum:	4,308.0	1,780.1	5,970.2	104,400.0	623.3	0.75	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/09/2024 00:00	4,052.4	332.8	4,228.8	104,400.0	441.5	0.55	0.3	0.9
07/09/2024 01:00	3,395.4	90.1	3,395.4	104,400.0	354.5	0.44	0.2	0.7
07/09/2024 02:00	3,394.7	89.0	3,394.7	104,400.0	354.4	0.44	0.2	0.7
07/09/2024 03:00	3,396.8	88.5	3,396.8	104,400.0	354.6	0.44	0.2	0.7
07/09/2024 04:00	3,417.5	89.6	3,417.5	104,400.0	356.8	0.44	0.2	0.7
07/09/2024 05:00	3,395.4	84.9	3,395.4	104,400.0	354.5	0.44	0.2	0.7
07/09/2024 06:00	3,400.7	73.6	3,400.7	104,400.0	355.0	0.44	0.2	0.7
07/09/2024 07:00	3,407.3	77.9	3,407.3	104,400.0	355.7	0.44	0.2	0.7
07/09/2024 08:00	3,399.5	81.0	3,399.5	104,400.0	354.9	0.44	0.2	0.7
07/09/2024 09:00	3,393.5	85.3	3,393.5	104,400.0	354.3	0.44	0.2	0.7
07/09/2024 10:00	3,393.6	80.4	3,393.6	104,400.0	354.3	0.44	0.2	0.7
07/09/2024 11:00	3,406.0	72.6	3,406.0	104,400.0	355.6	0.44	0.2	0.7
07/09/2024 12:00	3,452.1	71.7	3,452.1	104,400.0	360.4	0.44	0.2	0.7
07/09/2024 13:00	4,208.9	81.8	4,208.9	104,400.0	439.4	0.54	0.3	0.9
07/09/2024 14:00	4,068.6	81.1	4,068.6	104,400.0	424.8	0.52	0.3	0.9
07/09/2024 15:00	3,956.0	255.1	4,027.4	104,400.0	420.5	0.53	0.3	0.9
07/09/2024 16:00	4,196.8	1,526.3	5,723.1	104,400.0	597.5	0.72	0.4	1.2
07/09/2024 17:00	4,205.3	1,614.5	5,819.8	104,400.0	607.6	0.73	0.4	1.2
07/09/2024 18:00	4,221.3	1,768.7	5,990.0	104,400.0	625.4	0.75	0.4	1.3
07/09/2024 19:00	4,245.8	1,563.7	5,809.5	104,400.0	606.5	0.73	0.4	1.2
07/09/2024 20:00	4,279.2	1,406.7	5,685.9	104,400.0	593.6	0.71	0.4	1.2
07/09/2024 21:00	4,278.8	1,395.4	5,674.2	104,400.0	592.4	0.71	0.4	1.2
07/09/2024 22:00	4,283.0	1,322.5	5,605.5	104,400.0	585.2	0.70	0.4	1.2
07/09/2024 23:00	4,275.4	491.9	4,668.9	104,400.0	487.4	0.60	0.3	1.0
Average/Sum#:	3,796.8	534.4	4,265.1	104,400.0	445.3	0.54	0.3	0.9
Minimum:	3,393.5	71.7	3,393.5	104,400.0	354.3	0.44	0.2	0.7
Maximum:	4,283.0	1,768.7	5,990.0	104,400.0	625.4	0.75	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2024 00:00	4,162.7	92.2	4,162.7	104,400.0	434.6	0.54	0.3	0.9
07/10/2024 01:00	4,114.9	91.5	4,114.9	104,400.0	429.6	0.53	0.3	0.9
07/10/2024 02:00	4,192.6	90.5	4,192.6	104,400.0	437.7	0.54	0.3	0.9
07/10/2024 03:00	4,090.9	90.6	4,090.9	104,400.0	427.1	0.52	0.3	0.9
07/10/2024 04:00	4,208.3	92.1	4,208.3	104,400.0	439.3	0.54	0.3	0.9
07/10/2024 05:00	3,899.3	88.1	3,899.3	104,400.0	407.1	0.50	0.2	0.8
07/10/2024 06:00	3,420.6	85.3	3,420.6	104,400.0	357.1	0.44	0.2	0.7
07/10/2024 07:00	3,429.2	84.6	3,429.2	104,400.0	358.0	0.44	0.2	0.7
07/10/2024 08:00	3,420.6	81.2	3,420.6	104,400.0	357.1	0.44	0.2	0.7
07/10/2024 09:00	3,405.0	88.4	3,405.0	104,400.0	355.5	0.44	0.2	0.7
07/10/2024 10:00	3,405.6	81.0	3,405.6	104,400.0	355.5	0.44	0.2	0.7
07/10/2024 11:00	3,416.9	79.3	3,416.9	104,400.0	356.7	0.44	0.2	0.7
07/10/2024 12:00	3,416.2	73.6	3,416.2	104,400.0	356.7	0.44	0.2	0.7
07/10/2024 13:00	3,763.3	82.1	3,763.3	104,400.0	392.9	0.48	0.2	0.8
07/10/2024 14:00	3,999.6	78.5	3,999.6	104,400.0	417.6	0.51	0.3	0.9
07/10/2024 15:00	3,728.5	74.4	3,728.5	104,400.0	389.3	0.48	0.2	0.8
07/10/2024 16:00	3,763.5	63.0	3,763.5	104,400.0	392.9	0.48	0.2	0.8
07/10/2024 17:00	4,134.7	1,418.3	5,524.6	104,400.0	576.8	0.69	0.3	1.2
07/10/2024 18:00	4,131.0	1,783.7	5,914.7	104,400.0	617.5	0.74	0.4	1.2
07/10/2024 19:00	4,164.3	1,715.1	5,879.4	104,400.0	613.8	0.74	0.4	1.2
07/10/2024 20:00	4,194.2	1,450.1	5,644.3	104,400.0	589.3	0.71	0.4	1.2
07/10/2024 21:00	4,198.2	1,006.4	5,204.6	104,400.0	543.4	0.65	0.3	1.1
07/10/2024 22:00	4,202.3	548.9	4,625.0	104,400.0	482.9	0.59	0.3	1.0
07/10/2024 23:00	3,794.9	89.5	3,794.9	104,400.0	396.2	0.49	0.2	0.8
Average/Sum#:	3,860.7	392.9	4,184.4	104,400.0	436.9	0.53	0.3	0.9
Minimum:	3,405.0	63.0	3,405.0	104,400.0	355.5	0.44	0.2	0.7
Maximum:	4,208.3	1,783.7	5,914.7	104,400.0	617.5	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2024 00:00	3,410.5	88.0	3,410.5	104,400.0	356.1	0.44	0.2	0.7
07/11/2024 01:00	3,401.4	89.2	3,401.4	104,400.0	355.1	0.44	0.2	0.7
07/11/2024 02:00	3,400.4	89.0	3,400.4	104,400.0	355.0	0.44	0.2	0.7
07/11/2024 03:00	3,402.0	87.2	3,402.0	104,400.0	355.2	0.44	0.2	0.7
07/11/2024 04:00	3,402.0	92.0	3,402.0	104,400.0	355.2	0.44	0.2	0.7
07/11/2024 05:00	3,403.6	72.7	3,403.6	104,400.0	355.3	0.44	0.2	0.7
07/11/2024 06:00	3,409.2	58.4	3,409.2	104,400.0	355.9	0.43	0.2	0.7
07/11/2024 07:00	3,426.0	68.1	3,426.0	104,400.0	357.7	0.44	0.2	0.7
07/11/2024 08:00	3,420.3	72.2	3,420.3	104,400.0	357.1	0.44	0.2	0.7
07/11/2024 09:00	3,418.9	70.7	3,418.9	104,400.0	356.9	0.44	0.2	0.7
07/11/2024 10:00	3,421.3	65.7	3,421.3	104,400.0	357.2	0.44	0.2	0.7
07/11/2024 11:00	3,416.6	56.7	3,416.6	104,400.0	356.7	0.44	0.2	0.7
07/11/2024 12:00	3,655.1	58.8	3,655.1	104,400.0	381.6	0.47	0.2	0.8
07/11/2024 13:00	4,128.3	64.0	4,128.3	104,400.0	431.0	0.53	0.3	0.9
07/11/2024 14:00	4,126.0	1,464.2	5,560.9	104,400.0	580.6	0.70	0.4	1.2
07/11/2024 15:00	4,146.5	1,727.2	5,873.7	104,400.0	613.2	0.74	0.4	1.2
07/11/2024 16:00	4,158.6	1,689.5	5,848.1	104,400.0	610.5	0.73	0.4	1.2
07/11/2024 17:00	4,151.7	1,727.6	5,879.3	104,400.0	613.8	0.74	0.4	1.2
07/11/2024 18:00	4,148.2	1,724.3	5,872.5	104,400.0	613.1	0.74	0.4	1.2
07/11/2024 19:00	4,152.2	1,701.6	5,853.8	104,400.0	611.1	0.73	0.4	1.2
07/11/2024 20:00	4,173.1	1,665.2	5,838.3	104,400.0	609.5	0.73	0.4	1.2
07/11/2024 21:00	4,188.3	1,635.0	5,823.3	104,400.0	608.0	0.73	0.4	1.2
07/11/2024 22:00	4,199.0	938.4	4,968.5	104,400.0	518.7	0.64	0.3	1.1
07/11/2024 23:00	4,100.8	87.0	4,100.8	104,400.0	428.1	0.52	0.3	0.9
Average/Sum#:	3,760.8	641.4	4,347.3	104,400.0	453.9	0.55	0.3	0.9
Minimum:	3,400.4	56.7	3,400.4	104,400.0	355.0	0.43	0.2	0.7
Maximum:	4,199.0	1,727.6	5,879.3	104,400.0	613.8	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2024 00:00	3,555.5	84.4	3,555.5	104,400.0	371.2	0.46	0.2	0.8
07/12/2024 01:00	3,403.0	84.7	3,403.0	104,400.0	355.3	0.44	0.2	0.7
07/12/2024 02:00	3,400.8	86.3	3,400.8	104,400.0	355.0	0.44	0.2	0.7
07/12/2024 03:00	3,401.3	88.2	3,401.3	104,400.0	355.1	0.44	0.2	0.7
07/12/2024 04:00	3,404.4	86.7	3,404.4	104,400.0	355.4	0.44	0.2	0.7
07/12/2024 05:00	3,411.2	85.2	3,411.2	104,400.0	356.1	0.44	0.2	0.7
07/12/2024 06:00	3,584.1	79.4	3,584.1	104,400.0	374.2	0.46	0.2	0.8
07/12/2024 07:00	3,423.1	81.0	3,423.1	104,400.0	357.4	0.44	0.2	0.7
07/12/2024 08:00	3,413.4	83.5	3,413.4	104,400.0	356.4	0.44	0.2	0.7
07/12/2024 09:00	3,411.6	85.4	3,411.6	104,400.0	356.2	0.44	0.2	0.7
07/12/2024 10:00	3,416.6	81.8	3,416.6	104,400.0	356.7	0.44	0.2	0.7
07/12/2024 11:00	3,793.7	75.0	3,793.7	104,400.0	396.1	0.49	0.2	0.8
07/12/2024 12:00	4,127.0	76.2	4,127.0	104,400.0	430.9	0.53	0.3	0.9
07/12/2024 13:00	4,123.2	81.1	4,123.2	104,400.0	430.5	0.53	0.3	0.9
07/12/2024 14:00	4,119.2	519.0	4,394.3	104,400.0	458.8	0.58	0.3	1.0
07/12/2024 15:00	4,116.7	830.9	4,947.6	104,400.0	516.5	0.62	0.3	1.0
07/12/2024 16:00	4,098.2	1,097.8	5,196.0	104,400.0	542.5	0.65	0.3	1.1
07/12/2024 17:00	4,068.1	1,814.5	5,882.6	104,400.0	614.1	0.74	0.4	1.2
07/12/2024 18:00	4,093.5	1,778.0	5,871.5	104,400.0	613.0	0.74	0.4	1.2
07/12/2024 19:00	4,153.6	1,439.0	5,592.6	104,400.0	583.9	0.70	0.4	1.2
07/12/2024 20:00	4,175.6	1,285.9	5,461.5	104,400.0	570.2	0.68	0.3	1.1
07/12/2024 21:00	4,040.4	236.5	4,080.6	104,400.0	426.0	0.54	0.3	0.9
07/12/2024 22:00	4,058.8	83.1	4,058.8	104,400.0	423.7	0.52	0.3	0.9
07/12/2024 23:00	3,487.2	82.7	3,487.2	104,400.0	364.1	0.45	0.2	0.7
Average/Sum#:	3,761.7	430.3	4,118.4	104,400.0	430.0	0.53	0.3	0.9
Minimum:	3,400.8	75.0	3,400.8	104,400.0	355.0	0.44	0.2	0.7
Maximum:	4,175.6	1,814.5	5,882.6	104,400.0	614.1	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2024 00:00	3,385.9	83.5	3,385.9	104,400.0	353.5	0.43	0.2	0.7
07/13/2024 01:00	3,365.5	85.6	3,365.5	104,400.0	351.4	0.43	0.2	0.7
07/13/2024 02:00	3,422.2	88.5	3,422.2	104,400.0	357.3	0.44	0.2	0.7
07/13/2024 03:00	3,490.7	87.2	3,490.7	104,400.0	364.4	0.45	0.2	0.7
07/13/2024 04:00	3,356.4	85.3	3,356.4	104,400.0	350.4	0.43	0.2	0.7
07/13/2024 05:00	3,356.3	87.3	3,356.3	104,400.0	350.4	0.43	0.2	0.7
07/13/2024 06:00	3,358.7	82.7	3,358.7	104,400.0	350.6	0.43	0.2	0.7
07/13/2024 07:00	3,364.7	74.2	3,364.7	104,400.0	351.3	0.43	0.2	0.7
07/13/2024 08:00	3,687.2	564.0	3,884.6	104,400.0	405.6	0.53	0.3	0.9
07/13/2024 09:00	3,599.5	99.5	3,609.5	104,400.0	376.8	0.46	0.2	0.8
07/13/2024 10:00	3,403.9	83.4	3,403.9	104,400.0	355.4	0.44	0.2	0.7
07/13/2024 11:00	3,397.6	78.3	3,397.6	104,400.0	354.7	0.44	0.2	0.7
07/13/2024 12:00	3,415.7	70.6	3,415.7	104,400.0	356.6	0.44	0.2	0.7
07/13/2024 13:00	3,421.1	80.6	3,421.1	104,400.0	357.2	0.44	0.2	0.7
07/13/2024 14:00	3,432.0	80.8	3,432.0	104,400.0	358.3	0.44	0.2	0.7
07/13/2024 15:00	3,446.2	76.4	3,446.2	104,400.0	359.8	0.44	0.2	0.7
07/13/2024 16:00	3,483.0	127.5	3,502.1	104,400.0	365.6	0.45	0.2	0.8
07/13/2024 17:00	3,631.1	127.1	3,665.4	104,400.0	382.7	0.47	0.2	0.8
07/13/2024 18:00	4,028.3	84.1	4,028.3	104,400.0	420.6	0.52	0.3	0.9
07/13/2024 19:00	3,460.4	86.5	3,460.4	104,400.0	361.3	0.44	0.2	0.7
07/13/2024 20:00	3,578.3	89.4	3,578.3	104,400.0	373.6	0.46	0.2	0.8
07/13/2024 21:00	3,472.1	88.6	3,472.1	104,400.0	362.5	0.44	0.2	0.7
07/13/2024 22:00	3,450.2	87.4	3,450.2	104,400.0	360.2	0.44	0.2	0.7
07/13/2024 23:00	3,430.6	88.8	3,430.6	104,400.0	358.2	0.44	0.2	0.7
Average/Sum#:	3,476.6	107.8	3,487.4	104,400.0	364.1	0.45	0.2	0.7
Minimum:	3,356.3	70.6	3,356.3	104,400.0	350.4	0.43	0.2	0.7
Maximum:	4,028.3	564.0	4,028.3	104,400.0	420.6	0.53	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2024 00:00	3,425.6	89.9	3,425.6	104,400.0	357.6	0.44	0.2	0.7
07/14/2024 01:00	3,411.9	91.3	3,411.9	104,400.0	356.2	0.44	0.2	0.7
07/14/2024 02:00	3,401.2	91.5	3,401.2	104,400.0	355.1	0.44	0.2	0.7
07/14/2024 03:00	3,385.6	89.4	3,385.6	104,400.0	353.5	0.44	0.2	0.7
07/14/2024 04:00	3,384.9	91.3	3,384.9	104,400.0	353.4	0.44	0.2	0.7
07/14/2024 05:00	3,386.6	89.7	3,386.6	104,400.0	353.6	0.44	0.2	0.7
07/14/2024 06:00	3,389.8	90.6	3,389.8	104,400.0	353.9	0.44	0.2	0.7
07/14/2024 07:00	3,390.2	89.0	3,390.2	104,400.0	353.9	0.44	0.2	0.7
07/14/2024 08:00	3,393.0	87.6	3,393.0	104,400.0	354.2	0.44	0.2	0.7
07/14/2024 09:00	3,396.8	82.3	3,396.8	104,400.0	354.6	0.44	0.2	0.7
07/14/2024 10:00	3,396.7	84.5	3,396.7	104,400.0	354.6	0.44	0.2	0.7
07/14/2024 11:00	3,396.7	81.4	3,396.7	104,400.0	354.6	0.44	0.2	0.7
07/14/2024 12:00	3,405.7	80.4	3,405.7	104,400.0	355.6	0.44	0.2	0.7
07/14/2024 13:00	3,394.7	81.5	3,394.7	104,400.0	354.4	0.44	0.2	0.7
07/14/2024 14:00	3,569.5	78.1	3,569.5	104,400.0	372.7	0.46	0.2	0.8
07/14/2024 15:00	3,470.7	83.3	3,470.7	104,400.0	362.3	0.44	0.2	0.7
07/14/2024 16:00	3,440.1	82.0	3,440.1	104,400.0	359.1	0.44	0.2	0.7
07/14/2024 17:00	3,510.0	79.8	3,510.0	104,400.0	366.4	0.45	0.2	0.7
07/14/2024 18:00	3,680.4	85.9	3,683.0	104,400.0	384.5	0.47	0.2	0.8
07/14/2024 19:00	3,652.6	88.5	3,654.4	104,400.0	381.5	0.47	0.2	0.8
07/14/2024 20:00	3,641.2	91.6	3,641.2	104,400.0	380.1	0.47	0.2	0.8
07/14/2024 21:00	3,808.5	92.6	3,808.5	104,400.0	397.6	0.49	0.2	0.8
07/14/2024 22:00	3,394.0	92.3	3,394.0	104,400.0	354.3	0.44	0.2	0.7
07/14/2024 23:00	3,385.6	90.8	3,385.6	104,400.0	353.5	0.44	0.2	0.7
Average/Sum#:	3,463.0	86.9	3,463.2	104,400.0	361.6	0.45	0.2	0.7
Minimum:	3,384.9	78.1	3,384.9	104,400.0	353.4	0.44	0.2	0.7
Maximum:	3,808.5	92.6	3,808.5	104,400.0	397.6	0.49	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2024 00:00	3,387.6	92.0	3,387.6	104,400.0	353.7	0.44	0.2	0.7
07/15/2024 01:00	3,387.4	93.1	3,387.4	104,400.0	353.6	0.44	0.2	0.7
07/15/2024 02:00	3,385.7	92.6	3,385.7	104,400.0	353.5	0.44	0.2	0.7
07/15/2024 03:00	3,597.8	91.5	3,597.8	104,400.0	375.6	0.46	0.2	0.8
07/15/2024 04:00	3,386.6	92.3	3,386.6	104,400.0	353.6	0.44	0.2	0.7
07/15/2024 05:00	3,386.6	90.1	3,386.6	104,400.0	353.6	0.44	0.2	0.7
07/15/2024 06:00	3,390.3	87.4	3,390.3	104,400.0	353.9	0.44	0.2	0.7
07/15/2024 07:00	3,397.3	93.3	3,397.3	104,400.0	354.7	0.44	0.2	0.7
07/15/2024 08:00	3,395.4	94.3	3,395.4	104,400.0	354.5	0.44	0.2	0.7
07/15/2024 09:00	3,397.7	96.1	3,397.7	104,400.0	354.7	0.44	0.2	0.7
07/15/2024 10:00	3,401.9	89.7	3,401.9	104,400.0	355.2	0.44	0.2	0.7
07/15/2024 11:00	3,414.0	83.7	3,414.0	104,400.0	356.4	0.44	0.2	0.7
07/15/2024 12:00	3,418.0	85.1	3,418.0	104,400.0	356.8	0.44	0.2	0.7
07/15/2024 13:00	3,422.0	90.5	3,422.0	104,400.0	357.3	0.44	0.2	0.7
07/15/2024 14:00	3,420.6	90.4	3,420.6	104,400.0	357.1	0.44	0.2	0.7
07/15/2024 15:00	3,492.4	87.7	3,492.4	104,400.0	364.6	0.45	0.2	0.7
07/15/2024 16:00	3,426.2	83.7	3,426.2	104,400.0	357.7	0.44	0.2	0.7
07/15/2024 17:00	3,431.0	82.0	3,431.0	104,400.0	358.2	0.44	0.2	0.7
07/15/2024 18:00	3,415.5	89.9	3,415.5	104,400.0	356.6	0.44	0.2	0.7
07/15/2024 19:00	3,423.4	92.2	3,423.4	104,400.0	357.4	0.44	0.2	0.7
07/15/2024 20:00	3,408.5	92.8	3,408.5	104,400.0	355.8	0.44	0.2	0.7
07/15/2024 21:00	3,400.1	92.5	3,400.1	104,400.0	355.0	0.44	0.2	0.7
07/15/2024 22:00	3,396.2	93.0	3,396.2	104,400.0	354.6	0.44	0.2	0.7
07/15/2024 23:00	3,394.3	93.9	3,394.3	104,400.0	354.4	0.44	0.2	0.7
Average/Sum#:	3,415.7	90.4	3,415.7	104,400.0	356.6	0.44	0.2	0.7
Minimum:	3,385.7	82.0	3,385.7	104,400.0	353.5	0.44	0.2	0.7
Maximum:	3,597.8	96.1	3,597.8	104,400.0	375.6	0.46	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2024 00:00	3,392.8	93.4	3,392.8	104,400.0	354.2	0.44	0.2	0.7
07/16/2024 01:00	3,390.4	92.5	3,390.4	104,400.0	354.0	0.44	0.2	0.7
07/16/2024 02:00	3,391.0	93.3	3,391.0	104,400.0	354.0	0.44	0.2	0.7
07/16/2024 03:00	3,390.9	93.2	3,390.9	104,400.0	354.0	0.44	0.2	0.7
07/16/2024 04:00	3,633.8	93.6	3,633.8	104,400.0	379.4	0.47	0.2	0.8
07/16/2024 05:00	3,908.8	85.4	3,908.8	104,400.0	408.1	0.50	0.3	0.8
07/16/2024 06:00	3,398.3	77.1	3,398.3	104,400.0	354.8	0.44	0.2	0.7
07/16/2024 07:00	3,407.3	80.8	3,407.3	104,400.0	355.7	0.44	0.2	0.7
07/16/2024 08:00	3,399.9	84.5	3,399.9	104,400.0	354.9	0.44	0.2	0.7
07/16/2024 09:00	3,396.7	86.7	3,396.7	104,400.0	354.6	0.44	0.2	0.7
07/16/2024 10:00	3,394.5	74.2	3,394.5	104,400.0	354.4	0.43	0.2	0.7
07/16/2024 11:00	3,406.0	73.1	3,406.0	104,400.0	355.6	0.44	0.2	0.7
07/16/2024 12:00	3,408.7	74.2	3,408.7	104,400.0	355.9	0.44	0.2	0.7
07/16/2024 13:00	3,406.9	79.2	3,406.9	104,400.0	355.7	0.44	0.2	0.7
07/16/2024 14:00	3,543.0	79.7	3,543.0	104,400.0	369.9	0.46	0.2	0.8
07/16/2024 15:00	4,051.9	75.0	4,051.9	104,400.0	423.0	0.52	0.3	0.9
07/16/2024 16:00	3,397.8	75.1	3,397.8	104,400.0	354.7	0.44	0.2	0.7
07/16/2024 17:00	4,051.8	283.9	4,171.0	104,400.0	435.5	0.54	0.3	0.9
07/16/2024 18:00	4,305.5	704.7	5,010.2	104,400.0	523.1	0.63	0.3	1.0
07/16/2024 19:00	4,321.0	519.3	4,840.3	104,400.0	505.3	0.61	0.3	1.0
07/16/2024 20:00	4,364.6	606.0	4,970.6	104,400.0	518.9	0.62	0.3	1.0
07/16/2024 21:00	4,252.1	157.4	4,343.4	104,400.0	453.5	0.55	0.3	0.9
07/16/2024 22:00	3,692.3	83.9	3,692.3	104,400.0	385.5	0.48	0.2	0.8
07/16/2024 23:00	3,395.2	85.0	3,395.2	104,400.0	354.5	0.44	0.2	0.7
Average/Sum#:	3,654.2	160.5	3,739.2	104,400.0	390.4	0.48	0.2	0.8
Minimum:	3,390.4	73.1	3,390.4	104,400.0	354.0	0.43	0.2	0.7
Maximum:	4,364.6	704.7	5,010.2	104,400.0	523.1	0.63	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2024 00:00	3,397.0	86.3	3,397.0	104,400.0	354.6	0.44	0.2	0.7
07/17/2024 01:00	3,398.8	86.4	3,398.8	104,400.0	354.8	0.44	0.2	0.7
07/17/2024 02:00	3,397.5	85.7	3,397.5	104,400.0	354.7	0.44	0.2	0.7
07/17/2024 03:00	3,396.0	86.4	3,396.0	104,400.0	354.5	0.44	0.2	0.7
07/17/2024 04:00	3,413.3	86.7	3,413.3	104,400.0	356.3	0.44	0.2	0.7
07/17/2024 05:00	3,721.1	81.5	3,721.1	104,400.0	388.5	0.48	0.2	0.8
07/17/2024 06:00	3,400.1	77.2	3,400.1	104,400.0	355.0	0.44	0.2	0.7
07/17/2024 07:00	3,409.0	84.9	3,409.0	104,400.0	355.9	0.44	0.2	0.7
07/17/2024 08:00	3,401.1	88.4	3,401.1	104,400.0	355.1	0.44	0.2	0.7
07/17/2024 09:00	3,398.8	86.8	3,398.8	104,400.0	354.8	0.44	0.2	0.7
07/17/2024 10:00	3,399.2	78.5	3,399.2	104,400.0	354.9	0.44	0.2	0.7
07/17/2024 11:00	3,405.2	71.9	3,405.2	104,400.0	355.5	0.44	0.2	0.7
07/17/2024 12:00	3,407.1	71.9	3,407.1	104,400.0	355.7	0.44	0.2	0.7
07/17/2024 13:00	3,407.4	78.4	3,407.4	104,400.0	355.7	0.44	0.2	0.7
07/17/2024 14:00	3,402.8	89.7	3,402.8	104,400.0	355.3	0.44	0.2	0.7
07/17/2024 15:00	3,395.9	88.1	3,395.9	104,400.0	354.5	0.44	0.2	0.7
07/17/2024 16:00	3,394.3	84.8	3,394.3	104,400.0	354.4	0.44	0.2	0.7
07/17/2024 17:00	3,710.2	87.4	3,710.2	104,400.0	387.3	0.48	0.2	0.8
07/17/2024 18:00	3,763.6	86.9	3,763.6	104,400.0	392.9	0.48	0.2	0.8
07/17/2024 19:00	4,150.5	90.5	4,150.5	104,400.0	433.3	0.53	0.3	0.9
07/17/2024 20:00	4,263.8	91.9	4,263.8	104,400.0	445.1	0.55	0.3	0.9
07/17/2024 21:00	4,249.6	94.1	4,249.6	104,400.0	443.7	0.54	0.3	0.9
07/17/2024 22:00	3,826.0	93.2	3,826.0	104,400.0	399.4	0.49	0.2	0.8
07/17/2024 23:00	3,394.9	90.1	3,394.9	104,400.0	354.4	0.44	0.2	0.7
Average/Sum#:	3,562.6	85.3	3,562.6	104,400.0	371.9	0.46	0.2	0.7
Minimum:	3,394.3	71.9	3,394.3	104,400.0	354.4	0.44	0.2	0.7
Maximum:	4,263.8	94.1	4,263.8	104,400.0	445.1	0.55	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2024 00:00	3,388.5	92.4	3,388.5	104,400.0	353.8	0.44	0.2	0.7
07/18/2024 01:00	3,389.0	93.7	3,389.0	104,400.0	353.8	0.44	0.2	0.7
07/18/2024 02:00	3,389.0	93.2	3,389.0	104,400.0	353.8	0.44	0.2	0.7
07/18/2024 03:00	3,391.1	94.9	3,391.1	104,400.0	354.0	0.44	0.2	0.7
07/18/2024 04:00	3,558.3	95.9	3,558.3	104,400.0	371.5	0.46	0.2	0.8
07/18/2024 05:00	3,415.8	91.9	3,415.8	104,400.0	356.6	0.44	0.2	0.7
07/18/2024 06:00	3,400.1	86.1	3,400.1	104,400.0	355.0	0.44	0.2	0.7
07/18/2024 07:00	3,404.8	87.1	3,404.8	104,400.0	355.5	0.44	0.2	0.7
07/18/2024 08:00	3,396.3	96.9	3,396.3	104,400.0	354.6	0.44	0.2	0.7
07/18/2024 09:00	3,389.7	99.2	3,389.7	104,400.0	353.9	0.44	0.2	0.7
07/18/2024 10:00	3,391.6	88.8	3,391.6	104,400.0	354.1	0.44	0.2	0.7
07/18/2024 11:00	3,598.7	82.2	3,598.7	104,400.0	375.7	0.46	0.2	0.8
07/18/2024 12:00	3,783.5	83.5	3,783.5	104,400.0	395.0	0.48	0.2	0.8
07/18/2024 13:00	3,766.5	93.4	3,766.5	104,400.0	393.2	0.48	0.2	0.8
07/18/2024 14:00	4,110.6	90.6	4,110.6	104,400.0	429.1	0.53	0.3	0.9
07/18/2024 15:00	4,183.1	88.5	4,183.1	104,400.0	436.7	0.54	0.3	0.9
07/18/2024 16:00	4,192.4	323.0	4,282.8	104,400.0	447.1	0.57	0.3	0.9
07/18/2024 17:00	4,197.3	1,936.1	6,133.4	104,400.0	640.3	0.77	0.4	1.3
07/18/2024 18:00	4,184.2	1,979.2	6,163.4	104,400.0	643.5	0.77	0.4	1.3
07/18/2024 19:00	4,199.8	1,977.4	6,177.2	104,400.0	644.9	0.77	0.4	1.3
07/18/2024 20:00	4,238.8	1,925.2	6,164.0	104,400.0	643.5	0.77	0.4	1.3
07/18/2024 21:00	4,249.3	1,054.6	5,303.9	104,400.0	553.7	0.67	0.3	1.1
07/18/2024 22:00	4,265.4	868.2	5,133.6	104,400.0	535.9	0.64	0.3	1.1
07/18/2024 23:00	4,284.0	780.9	5,064.9	104,400.0	528.8	0.63	0.3	1.1
Average/Sum#:	3,782.0	512.6	4,224.2	104,400.0	441.0	0.54	0.3	0.9
Minimum:	3,388.5	82.2	3,388.5	104,400.0	353.8	0.44	0.2	0.7
Maximum:	4,284.0	1,979.2	6,177.2	104,400.0	644.9	0.77	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2024 00:00	4,306.2	731.1	5,037.3	104,400.0	525.9	0.63	0.3	1.1
07/19/2024 01:00	4,336.1	665.4	5,001.5	104,400.0	522.2	0.63	0.3	1.0
07/19/2024 02:00	4,355.3	617.2	4,972.5	104,400.0	519.1	0.62	0.3	1.0
07/19/2024 03:00	4,354.8	610.3	4,965.1	104,400.0	518.4	0.62	0.3	1.0
07/19/2024 04:00	4,340.5	639.6	4,980.1	104,400.0	519.9	0.62	0.3	1.0
07/19/2024 05:00	4,294.4	747.0	5,041.4	104,400.0	526.3	0.63	0.3	1.1
07/19/2024 06:00	4,370.1	560.2	4,930.3	104,400.0	514.7	0.62	0.3	1.0
07/19/2024 07:00	4,320.9	463.8	4,729.0	104,400.0	493.7	0.60	0.3	1.0
07/19/2024 08:00	3,500.5	92.0	3,500.5	104,400.0	365.5	0.45	0.2	0.8
07/19/2024 09:00	3,465.0	90.7	3,465.0	104,400.0	361.7	0.45	0.2	0.7
07/19/2024 10:00	3,442.1	87.6	3,442.1	104,400.0	359.4	0.44	0.2	0.7
07/19/2024 11:00	3,631.7	85.2	3,631.7	104,400.0	379.1	0.46	0.2	0.8
07/19/2024 12:00	4,203.1	985.7	5,169.1	104,400.0	539.7	0.65	0.3	1.1
07/19/2024 13:00	4,191.5	1,041.6	5,233.1	104,400.0	546.3	0.66	0.3	1.1
07/19/2024 14:00	4,165.8	1,564.5	5,730.3	104,400.0	598.2	0.72	0.4	1.2
07/19/2024 15:00	4,148.5	1,954.6	6,103.1	104,400.0	637.2	0.77	0.4	1.3
07/19/2024 16:00	4,153.8	1,964.2	6,118.0	104,400.0	638.7	0.77	0.4	1.3
07/19/2024 17:00	4,160.2	1,958.0	6,118.2	104,400.0	638.7	0.77	0.4	1.3
07/19/2024 18:00	4,157.1	1,967.3	6,124.4	104,400.0	639.4	0.77	0.4	1.3
07/19/2024 19:00	4,183.3	1,878.9	6,062.2	104,400.0	632.9	0.76	0.4	1.3
07/19/2024 20:00	4,232.0	1,364.6	5,596.6	104,400.0	584.3	0.70	0.4	1.2
07/19/2024 21:00	4,235.6	1,506.8	5,742.4	104,400.0	599.5	0.72	0.4	1.2
07/19/2024 22:00	4,231.9	1,602.5	5,834.4	104,400.0	609.1	0.73	0.4	1.2
07/19/2024 23:00	4,262.6	1,310.2	5,572.8	104,400.0	581.8	0.70	0.3	1.2
Average/Sum#:	4,126.8	1,020.4	5,129.2	104,400.0	535.5	0.65	0.3	1.1
Minimum:	3,442.1	85.2	3,442.1	104,400.0	359.4	0.44	0.2	0.7
Maximum:	4,370.1	1,967.3	6,124.4	104,400.0	639.4	0.77	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2024 00:00	4,279.0	1,027.2	5,306.2	104,400.0	554.0	0.67	0.3	1.1
07/20/2024 01:00	4,278.8	728.4	5,007.2	104,400.0	522.8	0.63	0.3	1.0
07/20/2024 02:00	4,307.5	732.9	5,040.4	104,400.0	526.2	0.63	0.3	1.1
07/20/2024 03:00	4,323.5	784.2	5,107.7	104,400.0	533.2	0.64	0.3	1.1
07/20/2024 04:00	4,331.5	679.7	5,011.2	104,400.0	523.2	0.63	0.3	1.0
07/20/2024 05:00	4,344.0	653.1	4,997.1	104,400.0	521.7	0.63	0.3	1.0
07/20/2024 06:00	4,325.8	563.0	4,888.8	104,400.0	510.4	0.61	0.3	1.0
07/20/2024 07:00	3,954.0	88.4	3,954.0	104,400.0	412.8	0.51	0.3	0.8
07/20/2024 08:00	3,488.6	92.8	3,488.6	104,400.0	364.2	0.45	0.2	0.7
07/20/2024 09:00	3,412.6	94.3	3,412.6	104,400.0	356.3	0.44	0.2	0.7
07/20/2024 10:00	3,415.8	90.5	3,415.8	104,400.0	356.6	0.44	0.2	0.7
07/20/2024 11:00	3,670.1	103.6	3,678.4	104,400.0	384.0	0.47	0.2	0.8
07/20/2024 12:00	3,858.1	89.5	3,858.1	104,400.0	402.8	0.50	0.2	0.8
07/20/2024 13:00	4,110.8	93.6	4,110.8	104,400.0	429.2	0.53	0.3	0.9
07/20/2024 14:00	4,125.0	235.7	4,176.9	104,400.0	436.1	0.55	0.3	0.9
07/20/2024 15:00	4,157.9	841.4	4,999.3	104,400.0	521.9	0.63	0.3	1.0
07/20/2024 16:00	4,120.1	870.3	4,990.4	104,400.0	521.0	0.63	0.3	1.0
07/20/2024 17:00	4,147.0	1,308.0	5,455.0	104,400.0	569.5	0.68	0.3	1.1
07/20/2024 18:00	4,172.7	1,576.2	5,748.9	104,400.0	600.2	0.72	0.4	1.2
07/20/2024 19:00	4,198.5	1,506.9	5,705.4	104,400.0	595.6	0.71	0.4	1.2
07/20/2024 20:00	4,210.3	1,467.5	5,677.8	104,400.0	592.8	0.71	0.4	1.2
07/20/2024 21:00	4,240.9	1,411.4	5,652.3	104,400.0	590.1	0.71	0.4	1.2
07/20/2024 22:00	4,267.8	1,358.2	5,626.0	104,400.0	587.4	0.71	0.4	1.2
07/20/2024 23:00	4,285.0	1,279.6	5,564.6	104,400.0	580.9	0.70	0.3	1.2
Average/Sum#:	4,084.4	736.5	4,786.4	104,400.0	499.7	0.61	0.3	1.0
Minimum:	3,412.6	88.4	3,412.6	104,400.0	356.3	0.44	0.2	0.7
Maximum:	4,344.0	1,576.2	5,748.9	104,400.0	600.2	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2024 00:00	4,095.4	338.3	4,325.4	104,400.0	451.6	0.55	0.3	0.9
07/21/2024 01:00	3,394.8	100.4	3,394.8	104,400.0	354.4	0.44	0.2	0.7
07/21/2024 02:00	3,393.6	100.8	3,393.6	104,400.0	354.3	0.44	0.2	0.7
07/21/2024 03:00	3,393.4	100.3	3,393.4	104,400.0	354.3	0.44	0.2	0.7
07/21/2024 04:00	3,392.4	100.0	3,392.4	104,400.0	354.2	0.44	0.2	0.7
07/21/2024 05:00	3,403.3	95.9	3,403.3	104,400.0	355.3	0.44	0.2	0.7
07/21/2024 06:00	3,403.0	92.2	3,403.0	104,400.0	355.3	0.44	0.2	0.7
07/21/2024 07:00	3,412.1	97.6	3,412.1	104,400.0	356.2	0.44	0.2	0.7
07/21/2024 08:00	3,404.5	103.4	3,404.5	104,400.0	355.4	0.44	0.2	0.7
07/21/2024 09:00	3,402.4	102.1	3,402.4	104,400.0	355.2	0.44	0.2	0.7
07/21/2024 10:00	3,402.7	92.9	3,402.7	104,400.0	355.2	0.44	0.2	0.7
07/21/2024 11:00	3,413.7	89.5	3,413.7	104,400.0	356.4	0.44	0.2	0.7
07/21/2024 12:00	3,413.7	92.4	3,413.7	104,400.0	356.4	0.44	0.2	0.7
07/21/2024 13:00	3,413.3	97.0	3,413.3	104,400.0	356.3	0.44	0.2	0.7
07/21/2024 14:00	3,410.5	92.0	3,410.5	104,400.0	356.1	0.44	0.2	0.7
07/21/2024 15:00	3,403.4	91.8	3,403.4	104,400.0	355.3	0.44	0.2	0.7
07/21/2024 16:00	3,402.9	91.4	3,402.9	104,400.0	355.3	0.44	0.2	0.7
07/21/2024 17:00	3,760.9	90.6	3,760.9	104,400.0	392.6	0.48	0.2	0.8
07/21/2024 18:00	4,106.3	92.6	4,106.3	104,400.0	428.7	0.53	0.3	0.9
07/21/2024 19:00	4,005.5	95.0	4,005.5	104,400.0	418.2	0.51	0.3	0.9
07/21/2024 20:00	4,056.1	97.3	4,056.1	104,400.0	423.5	0.52	0.3	0.9
07/21/2024 21:00	4,074.1	96.5	4,074.1	104,400.0	425.3	0.52	0.3	0.9
07/21/2024 22:00	3,631.3	96.2	3,631.3	104,400.0	379.1	0.47	0.2	0.8
07/21/2024 23:00	3,878.9	94.2	3,878.9	104,400.0	405.0	0.50	0.2	0.8
Average/Sum#:	3,586.2	105.9	3,595.8	104,400.0	375.4	0.46	0.2	0.8
Minimum:	3,392.4	89.5	3,392.4	104,400.0	354.2	0.44	0.2	0.7
Maximum:	4,106.3	338.3	4,325.4	104,400.0	451.6	0.55	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2024 00:00	3,685.8	93.9	3,685.8	104,400.0	384.8	0.48	0.2	0.8
07/22/2024 01:00	3,391.9	94.3	3,391.9	104,400.0	354.1	0.44	0.2	0.7
07/22/2024 02:00	4,065.4	94.3	4,065.4	104,400.0	424.4	0.52	0.3	0.9
07/22/2024 03:00	4,060.3	98.1	4,060.3	104,400.0	423.9	0.52	0.3	0.9
07/22/2024 04:00	4,206.8	97.1	4,206.8	104,400.0	439.2	0.54	0.3	0.9
07/22/2024 05:00	3,958.0	94.5	3,958.0	104,400.0	413.2	0.51	0.3	0.8
07/22/2024 06:00	3,402.8	88.5	3,402.8	104,400.0	355.3	0.44	0.2	0.7
07/22/2024 07:00	3,405.7	94.5	3,405.7	104,400.0	355.6	0.44	0.2	0.7
07/22/2024 08:00	3,398.7	99.6	3,398.7	104,400.0	354.8	0.44	0.2	0.7
07/22/2024 09:00	3,398.7	98.0	3,398.7	104,400.0	354.8	0.44	0.2	0.7
07/22/2024 10:00	3,396.8	93.7	3,396.8	104,400.0	354.6	0.44	0.2	0.7
07/22/2024 11:00	3,625.4	89.1	3,625.4	104,400.0	378.5	0.47	0.2	0.8
07/22/2024 12:00	4,085.8	91.4	4,085.8	104,400.0	426.6	0.52	0.3	0.9
07/22/2024 13:00	4,129.4	95.4	4,129.4	104,400.0	431.1	0.53	0.3	0.9
07/22/2024 14:00	4,126.6	92.6	4,126.6	104,400.0	430.8	0.53	0.3	0.9
07/22/2024 15:00	4,142.0	1,431.0	5,544.4	104,400.0	578.8	0.70	0.3	1.2
07/22/2024 16:00	4,140.3	1,691.4	5,831.7	104,400.0	608.8	0.73	0.4	1.2
07/22/2024 17:00	4,157.5	1,734.2	5,891.7	104,400.0	615.1	0.74	0.4	1.2
07/22/2024 18:00	4,153.4	1,646.1	5,799.5	104,400.0	605.5	0.73	0.4	1.2
07/22/2024 19:00	4,158.1	1,597.8	5,755.9	104,400.0	600.9	0.72	0.4	1.2
07/22/2024 20:00	4,182.3	1,112.0	5,294.3	104,400.0	552.7	0.66	0.3	1.1
07/22/2024 21:00	4,199.5	1,029.4	5,228.9	104,400.0	545.9	0.66	0.3	1.1
07/22/2024 22:00	4,144.2	413.0	4,359.0	104,400.0	455.1	0.57	0.3	1.0
07/22/2024 23:00	4,105.7	98.3	4,105.7	104,400.0	428.6	0.53	0.3	0.9
Average/Sum#:	3,905.0	507.0	4,339.6	104,400.0	453.0	0.55	0.3	0.9
Minimum:	3,391.9	88.5	3,391.9	104,400.0	354.1	0.44	0.2	0.7
Maximum:	4,206.8	1,734.2	5,891.7	104,400.0	615.1	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2024 00:00	3,979.4	96.7	3,979.4	104,400.0	415.4	0.51	0.3	0.9
07/23/2024 01:00	4,067.8	95.3	4,067.8	104,400.0	424.7	0.52	0.3	0.9
07/23/2024 02:00	3,938.5	94.8	3,938.5	104,400.0	411.2	0.51	0.3	0.8
07/23/2024 03:00	3,846.2	205.3	3,893.4	104,400.0	406.5	0.51	0.3	0.8
07/23/2024 04:00	4,279.9	1,276.5	5,556.4	104,400.0	580.1	0.70	0.3	1.2
07/23/2024 05:00	4,291.2	1,376.8	5,668.0	104,400.0	591.7	0.71	0.4	1.2
07/23/2024 06:00	4,291.1	1,336.5	5,627.6	104,400.0	587.5	0.70	0.4	1.2
07/23/2024 07:00	4,280.5	1,381.6	5,662.1	104,400.0	591.1	0.71	0.4	1.2
07/23/2024 08:00	4,239.1	1,441.7	5,680.8	104,400.0	593.1	0.71	0.4	1.2
07/23/2024 09:00	4,219.2	1,474.3	5,693.5	104,400.0	594.4	0.71	0.4	1.2
07/23/2024 10:00	4,217.0	1,486.4	5,703.4	104,400.0	595.4	0.71	0.4	1.2
07/23/2024 11:00	4,189.3	1,540.1	5,729.4	104,400.0	598.1	0.72	0.4	1.2
07/23/2024 12:00	4,149.6	1,713.1	5,862.7	104,400.0	612.1	0.73	0.4	1.2
07/23/2024 13:00	4,113.6	1,848.9	5,962.5	104,400.0	622.5	0.75	0.4	1.2
07/23/2024 14:00	4,095.4	1,850.8	5,946.2	104,400.0	620.8	0.75	0.4	1.2
07/23/2024 15:00	4,108.5	1,817.3	5,925.8	104,400.0	618.7	0.74	0.4	1.2
07/23/2024 16:00	4,113.8	1,800.7	5,914.5	104,400.0	617.5	0.74	0.4	1.2
07/23/2024 17:00	4,105.1	1,821.1	5,926.2	104,400.0	618.7	0.74	0.4	1.2
07/23/2024 18:00	4,129.8	1,780.2	5,910.0	104,400.0	617.0	0.74	0.4	1.2
07/23/2024 19:00	4,178.7	1,690.4	5,869.1	104,400.0	612.7	0.74	0.4	1.2
07/23/2024 20:00	4,215.8	1,634.6	5,850.4	104,400.0	610.8	0.73	0.4	1.2
07/23/2024 21:00	4,229.3	1,604.2	5,833.5	104,400.0	609.0	0.73	0.4	1.2
07/23/2024 22:00	4,221.6	1,601.1	5,822.7	104,400.0	607.9	0.73	0.4	1.2
07/23/2024 23:00	4,225.6	1,427.4	5,653.0	104,400.0	590.2	0.71	0.4	1.2
Average/Sum#:	4,155.3	1,349.8	5,486.5	104,400.0	572.8	0.69	0.4	1.1
Minimum:	3,846.2	94.8	3,893.4	104,400.0	406.5	0.51	0.3	0.8
Maximum:	4,291.2	1,850.8	5,962.5	104,400.0	622.5	0.75	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2024 00:00	4,232.6	634.7	4,867.3	104,400.0	508.1	0.61	0.3	1.0
07/24/2024 01:00	3,786.7	258.9	3,890.3	104,400.0	406.1	0.51	0.3	0.8
07/24/2024 02:00	3,414.4	100.6	3,414.4	104,400.0	356.5	0.44	0.2	0.7
07/24/2024 03:00	3,570.5	99.2	3,570.5	104,400.0	372.8	0.46	0.2	0.8
07/24/2024 04:00	4,256.7	756.1	4,786.0	104,400.0	499.7	0.63	0.3	1.0
07/24/2024 05:00	4,334.1	933.2	5,267.3	104,400.0	549.9	0.66	0.3	1.1
07/24/2024 06:00	4,044.4	167.7	4,150.1	104,400.0	433.3	0.53	0.3	0.9
07/24/2024 07:00	3,845.9	96.5	3,845.9	104,400.0	401.5	0.49	0.2	0.8
07/24/2024 08:00	3,486.7	99.4	3,486.7	104,400.0	364.0	0.45	0.2	0.7
07/24/2024 09:00	4,040.4	111.5	4,048.2	104,400.0	422.6	0.52	0.3	0.9
07/24/2024 10:00	4,093.5	200.9	4,137.7	104,400.0	432.0	0.54	0.3	0.9
07/24/2024 11:00	4,237.2	1,125.9	5,363.1	104,400.0	559.9	0.67	0.3	1.1
07/24/2024 12:00	4,219.4	1,631.5	5,850.9	104,400.0	610.8	0.73	0.4	1.2
07/24/2024 13:00	4,197.7	1,655.8	5,853.5	104,400.0	611.1	0.73	0.4	1.2
07/24/2024 14:00	4,174.8	1,754.9	5,929.7	104,400.0	619.1	0.74	0.4	1.2
07/24/2024 15:00	4,154.8	1,775.3	5,930.1	104,400.0	619.1	0.74	0.4	1.2
07/24/2024 16:00	4,141.9	1,762.3	5,904.2	104,400.0	616.4	0.74	0.4	1.2
07/24/2024 17:00	5,528.5	1,849.2	7,377.7	104,400.0	770.2	0.92	0.5	1.5
07/24/2024 18:00	5,713.4	1,782.4	7,495.8	104,400.0	782.6	0.94	0.5	1.6
07/24/2024 19:00	5,713.4	1,684.5	7,397.9	104,400.0	772.3	0.93	0.5	1.5
07/24/2024 20:00	4,935.5	1,628.9	6,564.4	104,400.0	685.3	0.82	0.4	1.4
07/24/2024 21:00	4,261.3	1,569.1	5,830.4	104,400.0	608.7	0.73	0.4	1.2
07/24/2024 22:00	4,285.0	754.7	5,039.7	104,400.0	526.1	0.63	0.3	1.1
07/24/2024 23:00	4,284.7	603.0	4,815.3	104,400.0	502.7	0.61	0.3	1.0
Average/Sum#:	4,289.7	959.8	5,200.7	104,400.0	543.0	0.66	0.3	1.1
Minimum:	3,414.4	96.5	3,414.4	104,400.0	356.5	0.44	0.2	0.7
Maximum:	5,713.4	1,849.2	7,495.8	104,400.0	782.6	0.94	0.5	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2024 00:00	3,983.7	101.8	3,983.7	104,400.0	415.9	0.51	0.3	0.9
07/25/2024 01:00	3,666.8	99.8	3,666.8	104,400.0	382.8	0.47	0.2	0.8
07/25/2024 02:00	3,394.5	99.3	3,394.5	104,400.0	354.4	0.44	0.2	0.7
07/25/2024 03:00	3,395.5	99.4	3,395.5	104,400.0	354.5	0.44	0.2	0.7
07/25/2024 04:00	3,649.3	98.9	3,649.3	104,400.0	381.0	0.47	0.2	0.8
07/25/2024 05:00	3,990.1	96.6	3,990.1	104,400.0	416.6	0.51	0.3	0.9
07/25/2024 06:00	3,598.6	96.6	3,598.6	104,400.0	375.7	0.46	0.2	0.8
07/25/2024 07:00	3,406.9	103.7	3,406.9	104,400.0	355.7	0.44	0.2	0.7
07/25/2024 08:00	3,400.7	105.6	3,400.7	104,400.0	355.0	0.44	0.2	0.7
07/25/2024 09:00	3,420.9	103.8	3,420.9	104,400.0	357.1	0.44	0.2	0.7
07/25/2024 10:00	3,427.7	94.1	3,427.7	104,400.0	357.9	0.44	0.2	0.7
07/25/2024 11:00	3,442.0	92.2	3,442.0	104,400.0	359.3	0.44	0.2	0.7
07/25/2024 12:00	3,874.7	95.9	3,874.7	104,400.0	404.5	0.50	0.2	0.8
07/25/2024 13:00	4,258.4	868.5	5,057.4	104,400.0	528.0	0.64	0.3	1.1
07/25/2024 14:00	4,274.6	1,268.7	5,543.3	104,400.0	578.7	0.70	0.3	1.2
07/25/2024 15:00	4,243.1	1,321.5	5,564.6	104,400.0	580.9	0.70	0.3	1.2
07/25/2024 16:00	4,230.7	1,347.6	5,578.3	104,400.0	582.4	0.70	0.3	1.2
07/25/2024 17:00	4,229.1	1,527.3	5,756.4	104,400.0	601.0	0.72	0.4	1.2
07/25/2024 18:00	4,240.2	1,622.7	5,862.9	104,400.0	612.1	0.73	0.4	1.2
07/25/2024 19:00	4,251.2	1,558.0	5,809.2	104,400.0	606.5	0.73	0.4	1.2
07/25/2024 20:00	4,265.2	1,509.1	5,774.3	104,400.0	602.8	0.73	0.4	1.2
07/25/2024 21:00	4,249.5	701.1	4,859.5	104,400.0	507.3	0.62	0.3	1.0
07/25/2024 22:00	3,882.7	102.0	3,882.7	104,400.0	405.4	0.50	0.2	0.8
07/25/2024 23:00	3,396.3	100.6	3,396.3	104,400.0	354.6	0.44	0.2	0.7
Average/Sum#:	3,840.5	550.6	4,322.3	104,400.0	451.3	0.55	0.3	0.9
Minimum:	3,394.5	92.2	3,394.5	104,400.0	354.4	0.44	0.2	0.7
Maximum:	4,274.6	1,622.7	5,862.9	104,400.0	612.1	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2024 00:00	3,390.5	100.4	3,390.5	104,400.0	354.0	0.44	0.2	0.7
07/26/2024 01:00	3,385.8	100.4	3,385.8	104,400.0	353.5	0.44	0.2	0.7
07/26/2024 02:00	3,382.6	100.6	3,382.6	104,400.0	353.1	0.44	0.2	0.7
07/26/2024 03:00	3,383.5	100.7	3,383.5	104,400.0	353.2	0.44	0.2	0.7
07/26/2024 04:00	3,382.8	100.8	3,382.8	104,400.0	353.2	0.44	0.2	0.7
07/26/2024 05:00	3,381.9	97.0	3,381.9	104,400.0	353.1	0.44	0.2	0.7
07/26/2024 06:00	3,388.4	95.9	3,388.4	104,400.0	353.7	0.44	0.2	0.7
07/26/2024 07:00	3,393.6	98.5	3,393.6	104,400.0	354.3	0.44	0.2	0.7
07/26/2024 08:00	3,382.8	102.7	3,382.8	104,400.0	353.2	0.44	0.2	0.7
07/26/2024 09:00	3,383.3	101.6	3,383.3	104,400.0	353.2	0.44	0.2	0.7
07/26/2024 10:00	3,387.3	91.8	3,387.3	104,400.0	353.6	0.44	0.2	0.7
07/26/2024 11:00	3,399.2	92.1	3,399.2	104,400.0	354.9	0.44	0.2	0.7
07/26/2024 12:00	3,413.1	96.2	3,413.1	104,400.0	356.3	0.44	0.2	0.7
07/26/2024 13:00	3,417.2	101.9	3,417.2	104,400.0	356.8	0.44	0.2	0.7
07/26/2024 14:00	3,420.4	99.5	3,420.4	104,400.0	357.1	0.44	0.2	0.7
07/26/2024 15:00	3,411.7	95.7	3,411.7	104,400.0	356.2	0.44	0.2	0.7
07/26/2024 16:00	3,410.2	92.0	3,410.2	104,400.0	356.0	0.44	0.2	0.7
07/26/2024 17:00	3,510.7	116.1	3,518.8	104,400.0	367.4	0.46	0.2	0.8
07/26/2024 18:00	4,187.2	251.0	4,262.5	104,400.0	445.0	0.56	0.3	0.9
07/26/2024 19:00	4,091.8	102.6	4,091.8	104,400.0	427.2	0.52	0.3	0.9
07/26/2024 20:00	3,781.7	101.1	3,781.7	104,400.0	394.8	0.49	0.2	0.8
07/26/2024 21:00	3,383.8	102.4	3,383.8	104,400.0	353.3	0.44	0.2	0.7
07/26/2024 22:00	3,389.0	101.8	3,389.0	104,400.0	353.8	0.44	0.2	0.7
07/26/2024 23:00	3,385.8	98.5	3,385.8	104,400.0	353.5	0.44	0.2	0.7
Average/Sum#:	3,476.8	105.9	3,480.3	104,400.0	363.4	0.45	0.2	0.7
Minimum:	3,381.9	91.8	3,381.9	104,400.0	353.1	0.44	0.2	0.7
Maximum:	4,187.2	251.0	4,262.5	104,400.0	445.0	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2024 00:00	3,387.8	94.4	3,387.8	104,400.0	353.7	0.44	0.2	0.7
07/27/2024 01:00	3,392.1	94.9	3,392.1	104,400.0	354.1	0.44	0.2	0.7
07/27/2024 02:00	3,392.2	93.9	3,392.2	104,400.0	354.1	0.44	0.2	0.7
07/27/2024 03:00	3,394.1	95.2	3,394.1	104,400.0	354.3	0.44	0.2	0.7
07/27/2024 04:00	3,395.6	95.2	3,395.6	104,400.0	354.5	0.44	0.2	0.7
07/27/2024 05:00	3,401.5	91.6	3,401.5	104,400.0	355.1	0.44	0.2	0.7
07/27/2024 06:00	3,402.9	88.9	3,402.9	104,400.0	355.3	0.44	0.2	0.7
07/27/2024 07:00	3,404.7	85.2	3,404.7	104,400.0	355.5	0.44	0.2	0.7
07/27/2024 08:00	3,406.1	85.8	3,406.1	104,400.0	355.6	0.44	0.2	0.7
07/27/2024 09:00	3,405.7	90.5	3,405.7	104,400.0	355.6	0.44	0.2	0.7
07/27/2024 10:00	3,404.5	88.4	3,404.5	104,400.0	355.4	0.44	0.2	0.7
07/27/2024 11:00	3,417.6	81.7	3,417.6	104,400.0	356.8	0.44	0.2	0.7
07/27/2024 12:00	3,419.0	87.9	3,419.0	104,400.0	356.9	0.44	0.2	0.7
07/27/2024 13:00	3,415.6	91.7	3,415.6	104,400.0	356.6	0.44	0.2	0.7
07/27/2024 14:00	3,411.8	93.0	3,411.8	104,400.0	356.2	0.44	0.2	0.7
07/27/2024 15:00	3,400.4	86.0	3,400.4	104,400.0	355.0	0.44	0.2	0.7
07/27/2024 16:00	3,403.0	82.2	3,403.0	104,400.0	355.3	0.44	0.2	0.7
07/27/2024 17:00	3,401.8	83.4	3,401.8	104,400.0	355.1	0.44	0.2	0.7
07/27/2024 18:00	3,398.1	89.7	3,398.1	104,400.0	354.8	0.44	0.2	0.7
07/27/2024 19:00	3,396.3	90.4	3,396.3	104,400.0	354.6	0.44	0.2	0.7
07/27/2024 20:00	3,394.8	94.3	3,394.8	104,400.0	354.4	0.44	0.2	0.7
07/27/2024 21:00	3,392.9	93.8	3,392.9	104,400.0	354.2	0.44	0.2	0.7
07/27/2024 22:00	3,394.7	93.1	3,394.7	104,400.0	354.4	0.44	0.2	0.7
07/27/2024 23:00	3,395.9	92.2	3,395.9	104,400.0	354.5	0.44	0.2	0.7
Average/Sum#:	3,401.2	90.1	3,401.2	104,400.0	355.1	0.44	0.2	0.7
Minimum:	3,387.8	81.7	3,387.8	104,400.0	353.7	0.44	0.2	0.7
Maximum:	3,419.0	95.2	3,419.0	104,400.0	356.9	0.44	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2024 00:00	3,397.8	92.4	3,397.8	104,400.0	354.7	0.44	0.2	0.7
07/28/2024 01:00	3,399.1	92.4	3,399.1	104,400.0	354.9	0.44	0.2	0.7
07/28/2024 02:00	3,397.4	93.1	3,397.4	104,400.0	354.7	0.44	0.2	0.7
07/28/2024 03:00	3,394.5	93.6	3,394.5	104,400.0	354.4	0.44	0.2	0.7
07/28/2024 04:00	3,397.2	93.8	3,397.2	104,400.0	354.7	0.44	0.2	0.7
07/28/2024 05:00	3,398.5	92.9	3,398.5	104,400.0	354.8	0.44	0.2	0.7
07/28/2024 06:00	3,403.8	89.0	3,403.8	104,400.0	355.4	0.44	0.2	0.7
07/28/2024 07:00	3,409.2	85.9	3,409.2	104,400.0	355.9	0.44	0.2	0.7
07/28/2024 08:00	3,406.0	90.9	3,406.0	104,400.0	355.6	0.44	0.2	0.7
07/28/2024 09:00	3,408.5	89.5	3,408.5	104,400.0	355.8	0.44	0.2	0.7
07/28/2024 10:00	3,405.7	84.1	3,405.7	104,400.0	355.6	0.44	0.2	0.7
07/28/2024 11:00	3,407.4	84.8	3,407.4	104,400.0	355.7	0.44	0.2	0.7
07/28/2024 12:00	3,408.3	85.6	3,408.3	104,400.0	355.8	0.44	0.2	0.7
07/28/2024 13:00	3,418.5	88.7	3,418.5	104,400.0	356.9	0.44	0.2	0.7
07/28/2024 14:00	3,426.6	88.0	3,426.6	104,400.0	357.7	0.44	0.2	0.7
07/28/2024 15:00	3,423.4	87.2	3,423.4	104,400.0	357.4	0.44	0.2	0.7
07/28/2024 16:00	3,420.6	81.6	3,420.6	104,400.0	357.1	0.44	0.2	0.7
07/28/2024 17:00	3,505.2	83.3	3,505.2	104,400.0	365.9	0.45	0.2	0.7
07/28/2024 18:00	3,405.0	88.8	3,405.0	104,400.0	355.5	0.44	0.2	0.7
07/28/2024 19:00	3,388.1	91.0	3,388.1	104,400.0	353.7	0.44	0.2	0.7
07/28/2024 20:00	3,394.0	92.9	3,394.0	104,400.0	354.3	0.44	0.2	0.7
07/28/2024 21:00	3,397.7	93.1	3,397.7	104,400.0	354.7	0.44	0.2	0.7
07/28/2024 22:00	3,400.4	93.6	3,400.4	104,400.0	355.0	0.44	0.2	0.7
07/28/2024 23:00	3,402.3	93.7	3,402.3	104,400.0	355.2	0.44	0.2	0.7
Average/Sum#:	3,409.0	89.6	3,409.0	104,400.0	355.9	0.44	0.2	0.7
Minimum:	3,388.1	81.6	3,388.1	104,400.0	353.7	0.44	0.2	0.7
Maximum:	3,505.2	93.8	3,505.2	104,400.0	365.9	0.45	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2024 00:00	3,403.9	94.0	3,403.9	104,400.0	355.4	0.44	0.2	0.7
07/29/2024 01:00	3,408.5	95.2	3,408.5	104,400.0	355.8	0.44	0.2	0.7
07/29/2024 02:00	3,410.0	94.7	3,410.0	104,400.0	356.0	0.44	0.2	0.7
07/29/2024 03:00	3,409.4	94.6	3,409.4	104,400.0	355.9	0.44	0.2	0.7
07/29/2024 04:00	3,410.1	94.7	3,410.1	104,400.0	356.0	0.44	0.2	0.7
07/29/2024 05:00	3,411.2	93.2	3,411.2	104,400.0	356.1	0.44	0.2	0.7
07/29/2024 06:00	3,415.7	88.4	3,415.7	104,400.0	356.6	0.44	0.2	0.7
07/29/2024 07:00	3,420.7	90.7	3,420.7	104,400.0	357.1	0.44	0.2	0.7
07/29/2024 08:00	3,409.6	97.3	3,409.6	104,400.0	356.0	0.44	0.2	0.7
07/29/2024 09:00	3,406.2	95.6	3,406.2	104,400.0	355.6	0.44	0.2	0.7
07/29/2024 10:00	3,407.4	89.7	3,407.4	104,400.0	355.7	0.44	0.2	0.7
07/29/2024 11:00	3,417.2	83.7	3,417.2	104,400.0	356.8	0.44	0.2	0.7
07/29/2024 12:00	3,411.5	90.1	3,411.5	104,400.0	356.2	0.44	0.2	0.7
07/29/2024 13:00	3,412.5	90.5	3,412.5	104,400.0	356.3	0.44	0.2	0.7
07/29/2024 14:00	3,409.4	99.0	3,409.4	104,400.0	355.9	0.44	0.2	0.7
07/29/2024 15:00	3,402.7	98.3	3,402.7	104,400.0	355.2	0.44	0.2	0.7
07/29/2024 16:00	3,536.2	94.6	3,536.2	104,400.0	369.2	0.46	0.2	0.8
07/29/2024 17:00	4,093.0	555.9	4,387.6	104,400.0	458.1	0.58	0.3	1.0
07/29/2024 18:00	4,292.4	1,082.7	5,375.1	104,400.0	561.2	0.67	0.3	1.1
07/29/2024 19:00	4,306.1	515.1	4,821.2	104,400.0	503.3	0.60	0.3	1.0
07/29/2024 20:00	4,316.3	482.5	4,798.8	104,400.0	501.0	0.60	0.3	1.0
07/29/2024 21:00	4,049.0	274.3	4,194.4	104,400.0	437.9	0.54	0.3	0.9
07/29/2024 22:00	3,392.7	102.6	3,392.7	104,400.0	354.2	0.44	0.2	0.7
07/29/2024 23:00	3,391.4	102.7	3,391.4	104,400.0	354.1	0.44	0.2	0.7
Average/Sum#:	3,581.0	195.8	3,686.0	104,400.0	384.8	0.47	0.2	0.8
Minimum:	3,391.4	83.7	3,391.4	104,400.0	354.1	0.44	0.2	0.7
Maximum:	4,316.3	1,082.7	5,375.1	104,400.0	561.2	0.67	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2024 00:00	3,392.8	101.7	3,392.8	104,400.0	354.2	0.44	0.2	0.7
07/30/2024 01:00	3,392.1	101.5	3,392.1	104,400.0	354.1	0.44	0.2	0.7
07/30/2024 02:00	3,391.6	101.5	3,391.6	104,400.0	354.1	0.44	0.2	0.7
07/30/2024 03:00	3,390.6	102.0	3,390.6	104,400.0	354.0	0.44	0.2	0.7
07/30/2024 04:00	3,393.9	101.9	3,393.9	104,400.0	354.3	0.44	0.2	0.7
07/30/2024 05:00	3,697.2	99.9	3,697.2	104,400.0	386.0	0.48	0.2	0.8
07/30/2024 06:00	3,398.3	96.4	3,398.3	104,400.0	354.8	0.44	0.2	0.7
07/30/2024 07:00	3,406.6	104.4	3,406.6	104,400.0	355.6	0.44	0.2	0.7
07/30/2024 08:00	3,395.7	106.3	3,395.7	104,400.0	354.5	0.44	0.2	0.7
07/30/2024 09:00	3,396.3	108.0	3,396.3	104,400.0	354.6	0.44	0.2	0.7
07/30/2024 10:00	3,392.4	98.3	3,392.4	104,400.0	354.2	0.44	0.2	0.7
07/30/2024 11:00	3,401.9	96.2	3,401.9	104,400.0	355.2	0.44	0.2	0.7
07/30/2024 12:00	3,422.7	99.8	3,422.7	104,400.0	357.3	0.44	0.2	0.7
07/30/2024 13:00	3,404.1	100.9	3,404.1	104,400.0	355.4	0.44	0.2	0.7
07/30/2024 14:00	3,399.1	98.1	3,399.1	104,400.0	354.9	0.44	0.2	0.7
07/30/2024 15:00	3,853.0	234.1	3,918.5	104,400.0	409.1	0.51	0.3	0.9
07/30/2024 16:00	4,244.4	1,042.0	5,286.4	104,400.0	551.9	0.66	0.3	1.1
07/30/2024 17:00	4,235.5	1,518.7	5,754.2	104,400.0	600.7	0.72	0.4	1.2
07/30/2024 18:00	4,243.2	1,555.5	5,798.7	104,400.0	605.4	0.73	0.4	1.2
07/30/2024 19:00	4,262.8	1,412.3	5,675.1	104,400.0	592.5	0.71	0.4	1.2
07/30/2024 20:00	4,281.9	1,218.5	5,500.4	104,400.0	574.2	0.69	0.3	1.1
07/30/2024 21:00	4,233.5	640.7	4,726.8	104,400.0	493.5	0.61	0.3	1.0
07/30/2024 22:00	3,401.5	104.1	3,401.5	104,400.0	355.1	0.44	0.2	0.7
07/30/2024 23:00	3,488.7	103.3	3,488.7	104,400.0	364.2	0.45	0.2	0.8
Average/Sum#:	3,646.7	389.4	3,951.1	104,400.0	412.5	0.51	0.2	0.8
Minimum:	3,390.6	96.2	3,390.6	104,400.0	354.0	0.44	0.2	0.7
Maximum:	4,281.9	1,555.5	5,798.7	104,400.0	605.4	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2024 00:00	3,378.3	103.0	3,378.3	104,400.0	352.7	0.44	0.2	0.7
07/31/2024 01:00	3,377.8	102.0	3,377.8	104,400.0	352.6	0.44	0.2	0.7
07/31/2024 02:00	3,380.8	101.8	3,380.8	104,400.0	353.0	0.44	0.2	0.7
07/31/2024 03:00	3,417.5	102.6	3,417.5	104,400.0	356.8	0.44	0.2	0.7
07/31/2024 04:00	3,843.5	102.0	3,843.5	104,400.0	401.3	0.49	0.2	0.8
07/31/2024 05:00	3,882.9	100.2	3,882.9	104,400.0	405.4	0.50	0.2	0.8
07/31/2024 06:00	3,395.6	93.6	3,395.6	104,400.0	354.5	0.44	0.2	0.7
07/31/2024 07:00	3,398.1	102.5	3,398.1	104,400.0	354.8	0.44	0.2	0.7
07/31/2024 08:00	3,389.7	104.0	3,389.7	104,400.0	353.9	0.44	0.2	0.7
07/31/2024 09:00	3,385.8	104.2	3,385.8	104,400.0	353.5	0.44	0.2	0.7
07/31/2024 10:00	3,381.7	97.6	3,381.7	104,400.0	353.0	0.44	0.2	0.7
07/31/2024 11:00	3,423.5	92.7	3,423.5	104,400.0	357.4	0.44	0.2	0.7
07/31/2024 12:00	3,527.1	98.9	3,527.1	104,400.0	368.2	0.46	0.2	0.8
07/31/2024 13:00	3,401.5	98.6	3,401.5	104,400.0	355.1	0.44	0.2	0.7
07/31/2024 14:00	3,568.1	93.2	3,568.1	104,400.0	372.5	0.46	0.2	0.8
07/31/2024 15:00	3,880.9	218.3	3,931.1	104,400.0	410.4	0.51	0.3	0.9
07/31/2024 16:00	4,191.9	1,230.4	5,422.3	104,400.0	566.1	0.68	0.3	1.1
07/31/2024 17:00	4,193.4	1,126.0	5,319.4	104,400.0	555.3	0.67	0.3	1.1
07/31/2024 18:00	4,211.1	1,440.0	5,651.1	104,400.0	590.0	0.71	0.4	1.2
07/31/2024 19:00	4,248.1	997.9	5,246.0	104,400.0	547.7	0.66	0.3	1.1
07/31/2024 20:00	4,255.3	1,349.0	5,604.3	104,400.0	585.1	0.70	0.4	1.2
07/31/2024 21:00	4,245.0	1,212.8	5,457.8	104,400.0	569.8	0.68	0.3	1.1
07/31/2024 22:00	4,245.7	1,074.7	5,320.4	104,400.0	555.4	0.67	0.3	1.1
07/31/2024 23:00	4,239.7	693.0	4,808.0	104,400.0	502.0	0.62	0.3	1.0
Average/Sum#:	3,744.3	451.6	4,121.3	104,400.0	430.3	0.53	0.2	0.9
Minimum:	3,377.8	92.7	3,377.8	104,400.0	352.6	0.44	0.2	0.7
Maximum:	4,255.3	1,440.0	5,651.1	104,400.0	590.0	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2024 00:00	3,909.7	100.3	3,909.7	104,900.0	410.1	0.50	0.3	0.8
08/01/2024 01:00	3,489.1	102.2	3,489.1	104,900.0	366.0	0.45	0.2	0.8
08/01/2024 02:00	3,394.6	102.9	3,394.6	104,900.0	356.1	0.44	0.2	0.7
08/01/2024 03:00	3,472.5	103.2	3,472.5	104,900.0	364.3	0.45	0.2	0.7
08/01/2024 04:00	3,618.0	103.1	3,618.0	104,900.0	379.5	0.47	0.2	0.8
08/01/2024 05:00	4,035.8	101.4	4,035.8	104,900.0	423.4	0.52	0.3	0.9
08/01/2024 06:00	3,452.2	95.7	3,452.2	104,900.0	362.1	0.45	0.2	0.7
08/01/2024 07:00	3,567.1	101.2	3,567.1	104,900.0	374.2	0.46	0.2	0.8
08/01/2024 08:00	3,456.5	104.8	3,456.5	104,900.0	362.6	0.45	0.2	0.7
08/01/2024 09:00	3,455.8	105.5	3,455.8	104,900.0	362.5	0.45	0.2	0.7
08/01/2024 10:00	3,460.1	98.2	3,460.1	104,900.0	363.0	0.45	0.2	0.7
08/01/2024 11:00	3,933.7	93.1	3,933.7	104,900.0	412.6	0.51	0.3	0.8
08/01/2024 12:00	3,771.2	96.7	3,771.2	104,900.0	395.6	0.49	0.2	0.8
08/01/2024 13:00	4,223.3	96.9	4,223.3	104,900.0	443.0	0.55	0.3	0.9
08/01/2024 14:00	4,084.6	89.3	4,084.6	104,900.0	428.5	0.52	0.3	0.9
08/01/2024 15:00	3,894.4	205.4	3,939.6	104,900.0	413.3	0.52	0.3	0.9
08/01/2024 16:00	4,228.5	1,453.3	5,681.8	104,900.0	596.0	0.72	0.4	1.2
08/01/2024 17:00	4,228.2	1,341.3	5,569.5	104,900.0	584.2	0.70	0.4	1.2
08/01/2024 18:00	4,226.9	1,504.6	5,731.5	104,900.0	601.2	0.72	0.4	1.2
08/01/2024 19:00	4,226.7	1,192.3	5,419.0	104,900.0	568.5	0.68	0.3	1.1
08/01/2024 20:00	4,260.6	1,436.7	5,697.3	104,900.0	597.6	0.72	0.4	1.2
08/01/2024 21:00	4,276.1	1,393.9	5,670.0	104,900.0	594.8	0.72	0.4	1.2
08/01/2024 22:00	4,268.9	1,140.0	5,408.9	104,900.0	567.4	0.68	0.3	1.1
08/01/2024 23:00	4,285.1	506.4	4,791.5	104,900.0	502.6	0.60	0.3	1.0
Average/Sum#:	3,884.2	486.2	4,301.4	104,900.0	451.2	0.55	0.3	0.9
Minimum:	3,394.6	89.3	3,394.6	104,900.0	356.1	0.44	0.2	0.7
Maximum:	4,285.1	1,504.6	5,731.5	104,900.0	601.2	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2024 00:00	3,967.1	103.5	3,972.3	104,900.0	416.7	0.51	0.3	0.9
08/02/2024 01:00	3,602.0	99.2	3,602.0	104,900.0	377.8	0.47	0.2	0.8
08/02/2024 02:00	3,399.3	99.1	3,399.3	104,900.0	356.6	0.44	0.2	0.7
08/02/2024 03:00	3,549.6	99.0	3,549.6	104,900.0	372.4	0.46	0.2	0.8
08/02/2024 04:00	4,067.0	99.7	4,067.0	104,900.0	426.6	0.52	0.3	0.9
08/02/2024 05:00	4,060.7	99.6	4,060.7	104,900.0	426.0	0.52	0.3	0.9
08/02/2024 06:00	4,034.6	97.6	4,034.6	104,900.0	423.2	0.52	0.3	0.9
08/02/2024 07:00	4,043.0	96.1	4,043.0	104,900.0	424.1	0.52	0.3	0.9
08/02/2024 08:00	4,107.3	98.1	4,107.3	104,900.0	430.9	0.53	0.3	0.9
08/02/2024 09:00	4,235.3	345.5	4,470.2	104,900.0	468.9	0.58	0.3	1.0
08/02/2024 10:00	4,268.7	1,469.9	5,738.6	104,900.0	602.0	0.72	0.4	1.2
08/02/2024 11:00	4,259.2	1,530.6	5,789.8	104,900.0	607.4	0.73	0.4	1.2
08/02/2024 12:00	4,232.2	1,550.2	5,782.4	104,900.0	606.6	0.73	0.4	1.2
08/02/2024 13:00	4,221.9	1,574.5	5,796.4	104,900.0	608.0	0.73	0.4	1.2
08/02/2024 14:00	4,228.4	1,467.5	5,695.9	104,900.0	597.5	0.72	0.4	1.2
08/02/2024 15:00	4,225.7	1,204.3	5,430.0	104,900.0	569.6	0.68	0.3	1.1
08/02/2024 16:00	4,213.1	671.2	4,884.3	104,900.0	512.4	0.61	0.3	1.0
08/02/2024 17:00	4,205.7	829.0	5,034.7	104,900.0	528.1	0.63	0.3	1.1
08/02/2024 18:00	4,246.6	1,070.0	5,316.6	104,900.0	557.7	0.67	0.3	1.1
08/02/2024 19:00	4,271.6	544.4	4,816.0	104,900.0	505.2	0.61	0.3	1.0
08/02/2024 20:00	4,269.5	544.2	4,813.7	104,900.0	505.0	0.61	0.3	1.0
08/02/2024 21:00	4,216.5	455.2	4,571.6	104,900.0	479.6	0.59	0.3	1.0
08/02/2024 22:00	4,047.7	99.0	4,047.7	104,900.0	424.6	0.52	0.3	0.9
08/02/2024 23:00	3,985.9	101.4	3,985.9	104,900.0	418.1	0.51	0.3	0.9
Average/Sum#:	4,081.6	597.9	4,625.4	104,900.0	485.2	0.59	0.3	1.0
Minimum:	3,399.3	96.1	3,399.3	104,900.0	356.6	0.44	0.2	0.7
Maximum:	4,271.6	1,574.5	5,796.4	104,900.0	608.0	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2024 00:00	3,801.6	98.9	3,801.6	104,900.0	398.8	0.49	0.2	0.8
08/03/2024 01:00	3,470.3	101.8	3,470.3	104,900.0	364.0	0.45	0.2	0.7
08/03/2024 02:00	3,379.6	100.0	3,379.6	104,900.0	354.5	0.44	0.2	0.7
08/03/2024 03:00	3,380.5	100.1	3,380.5	104,900.0	354.6	0.44	0.2	0.7
08/03/2024 04:00	3,377.6	99.8	3,377.6	104,900.0	354.3	0.44	0.2	0.7
08/03/2024 05:00	3,383.6	99.9	3,383.6	104,900.0	354.9	0.44	0.2	0.7
08/03/2024 06:00	3,384.6	102.2	3,384.6	104,900.0	355.0	0.44	0.2	0.7
08/03/2024 07:00	3,384.0	99.7	3,384.0	104,900.0	355.0	0.44	0.2	0.7
08/03/2024 08:00	3,380.3	97.4	3,380.3	104,900.0	354.6	0.44	0.2	0.7
08/03/2024 09:00	3,380.1	97.3	3,380.1	104,900.0	354.6	0.44	0.2	0.7
08/03/2024 10:00	3,377.3	97.1	3,377.3	104,900.0	354.3	0.44	0.2	0.7
08/03/2024 11:00	3,389.3	94.7	3,389.3	104,900.0	355.5	0.44	0.2	0.7
08/03/2024 12:00	3,394.6	97.7	3,394.6	104,900.0	356.1	0.44	0.2	0.7
08/03/2024 13:00	3,397.1	104.3	3,397.1	104,900.0	356.4	0.44	0.2	0.7
08/03/2024 14:00	3,396.2	94.2	3,396.2	104,900.0	356.3	0.44	0.2	0.7
08/03/2024 15:00	3,387.8	92.2	3,387.8	104,900.0	355.4	0.44	0.2	0.7
08/03/2024 16:00	3,385.4	95.1	3,385.4	104,900.0	355.1	0.44	0.2	0.7
08/03/2024 17:00	3,796.4	159.0	3,817.1	104,900.0	400.4	0.50	0.2	0.8
08/03/2024 18:00	4,191.2	1,476.3	5,667.5	104,900.0	594.5	0.71	0.4	1.2
08/03/2024 19:00	4,221.5	1,138.4	5,359.9	104,900.0	562.3	0.68	0.3	1.1
08/03/2024 20:00	4,052.6	460.6	4,305.9	104,900.0	451.7	0.57	0.3	0.9
08/03/2024 21:00	3,802.0	100.7	3,802.0	104,900.0	398.8	0.49	0.2	0.8
08/03/2024 22:00	3,927.1	101.2	3,927.1	104,900.0	412.0	0.51	0.3	0.8
08/03/2024 23:00	3,504.1	100.6	3,504.1	104,900.0	367.6	0.46	0.2	0.8
Average/Sum#:	3,564.4	217.1	3,684.7	104,900.0	386.5	0.48	0.2	0.8
Minimum:	3,377.3	92.2	3,377.3	104,900.0	354.3	0.44	0.2	0.7
Maximum:	4,221.5	1,476.3	5,667.5	104,900.0	594.5	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2024 00:00	3,373.9	101.2	3,373.9	104,900.0	353.9	0.44	0.2	0.7
08/04/2024 01:00	3,373.5	101.4	3,373.5	104,900.0	353.9	0.44	0.2	0.7
08/04/2024 02:00	3,377.6	101.1	3,377.6	104,900.0	354.3	0.44	0.2	0.7
08/04/2024 03:00	3,376.2	101.8	3,376.2	104,900.0	354.2	0.44	0.2	0.7
08/04/2024 04:00	3,376.7	102.3	3,376.7	104,900.0	354.2	0.44	0.2	0.7
08/04/2024 05:00	3,379.4	101.6	3,379.4	104,900.0	354.5	0.44	0.2	0.7
08/04/2024 06:00	3,389.9	98.9	3,389.9	104,900.0	355.6	0.44	0.2	0.7
08/04/2024 07:00	3,396.5	104.5	3,396.5	104,900.0	356.3	0.44	0.2	0.7
08/04/2024 08:00	3,384.9	109.9	3,384.9	104,900.0	355.1	0.44	0.2	0.7
08/04/2024 09:00	3,383.1	106.2	3,383.1	104,900.0	354.9	0.44	0.2	0.7
08/04/2024 10:00	3,385.2	97.7	3,385.2	104,900.0	355.1	0.44	0.2	0.7
08/04/2024 11:00	3,395.4	96.0	3,395.4	104,900.0	356.2	0.44	0.2	0.7
08/04/2024 12:00	3,394.3	97.6	3,394.3	104,900.0	356.1	0.44	0.2	0.7
08/04/2024 13:00	3,395.4	100.9	3,395.4	104,900.0	356.2	0.44	0.2	0.7
08/04/2024 14:00	3,394.0	88.6	3,394.0	104,900.0	356.0	0.44	0.2	0.7
08/04/2024 15:00	3,385.1	84.2	3,385.1	104,900.0	355.1	0.44	0.2	0.7
08/04/2024 16:00	3,382.2	82.0	3,382.2	104,900.0	354.8	0.44	0.2	0.7
08/04/2024 17:00	4,020.2	523.1	4,271.3	104,900.0	448.1	0.57	0.3	1.0
08/04/2024 18:00	4,216.7	1,458.4	5,675.1	104,900.0	595.3	0.71	0.4	1.2
08/04/2024 19:00	4,232.1	770.7	5,002.8	104,900.0	524.8	0.63	0.3	1.1
08/04/2024 20:00	4,234.3	604.4	4,838.7	104,900.0	507.6	0.61	0.3	1.0
08/04/2024 21:00	4,065.9	98.0	4,067.9	104,900.0	426.7	0.52	0.3	0.9
08/04/2024 22:00	3,982.0	96.2	3,982.0	104,900.0	417.7	0.51	0.3	0.9
08/04/2024 23:00	3,704.6	95.9	3,704.6	104,900.0	388.6	0.48	0.2	0.8
Average/Sum#:	3,583.3	221.8	3,711.9	104,900.0	389.4	0.48	0.2	0.8
Minimum:	3,373.5	82.0	3,373.5	104,900.0	353.9	0.44	0.2	0.7
Maximum:	4,234.3	1,458.4	5,675.1	104,900.0	595.3	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2024 00:00	3,457.0	96.8	3,457.0	104,900.0	362.6	0.45	0.2	0.7
08/05/2024 01:00	3,373.7	100.5	3,373.7	104,900.0	353.9	0.44	0.2	0.7
08/05/2024 02:00	3,373.8	101.5	3,373.8	104,900.0	353.9	0.44	0.2	0.7
08/05/2024 03:00	3,374.9	101.2	3,374.9	104,900.0	354.0	0.44	0.2	0.7
08/05/2024 04:00	3,833.5	102.3	3,833.5	104,900.0	402.1	0.50	0.2	0.8
08/05/2024 05:00	3,860.3	102.0	3,860.3	104,900.0	404.9	0.50	0.2	0.8
08/05/2024 06:00	3,625.9	98.7	3,625.9	104,900.0	380.4	0.47	0.2	0.8
08/05/2024 07:00	3,402.4	103.2	3,402.4	104,900.0	356.9	0.44	0.2	0.7
08/05/2024 08:00	3,393.0	108.6	3,393.0	104,900.0	355.9	0.44	0.2	0.7
08/05/2024 09:00	3,393.6	104.6	3,393.6	104,900.0	356.0	0.44	0.2	0.7
08/05/2024 10:00	3,395.0	98.3	3,395.0	104,900.0	356.1	0.44	0.2	0.7
08/05/2024 11:00	3,403.9	96.8	3,403.9	104,900.0	357.1	0.44	0.2	0.7
08/05/2024 12:00	3,817.9	98.5	3,817.9	104,900.0	400.5	0.49	0.2	0.8
08/05/2024 13:00	3,438.5	101.4	3,438.5	104,900.0	360.7	0.44	0.2	0.7
08/05/2024 14:00	3,705.9	95.0	3,705.9	104,900.0	388.7	0.48	0.2	0.8
08/05/2024 15:00	3,415.1	92.5	3,415.1	104,900.0	358.2	0.44	0.2	0.7
08/05/2024 16:00	3,414.9	90.8	3,414.9	104,900.0	358.2	0.44	0.2	0.7
08/05/2024 17:00	3,621.5	88.5	3,621.5	104,900.0	379.9	0.47	0.2	0.8
08/05/2024 18:00	4,257.5	722.3	4,820.9	104,900.0	505.7	0.63	0.3	1.0
08/05/2024 19:00	3,785.9	295.7	3,865.7	104,900.0	405.5	0.51	0.3	0.9
08/05/2024 20:00	3,634.1	102.4	3,634.1	104,900.0	381.2	0.47	0.2	0.8
08/05/2024 21:00	3,822.9	100.8	3,822.9	104,900.0	401.0	0.49	0.2	0.8
08/05/2024 22:00	3,822.5	101.0	3,822.5	104,900.0	401.0	0.49	0.2	0.8
08/05/2024 23:00	3,387.0	101.0	3,387.0	104,900.0	355.3	0.44	0.2	0.7
Average/Sum#:	3,583.8	133.5	3,610.6	104,900.0	378.7	0.47	0.2	0.8
Minimum:	3,373.7	88.5	3,373.7	104,900.0	353.9	0.44	0.2	0.7
Maximum:	4,257.5	722.3	4,820.9	104,900.0	505.7	0.63	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2024 00:00	3,376.2	100.9	3,376.2	104,900.0	354.2	0.44	0.2	0.7
08/06/2024 01:00	3,377.6	101.7	3,377.6	104,900.0	354.3	0.44	0.2	0.7
08/06/2024 02:00	3,378.4	103.1	3,378.4	104,900.0	354.4	0.44	0.2	0.7
08/06/2024 03:00	3,379.2	104.0	3,379.2	104,900.0	354.5	0.44	0.2	0.7
08/06/2024 04:00	3,381.2	102.7	3,381.2	104,900.0	354.7	0.44	0.2	0.7
08/06/2024 05:00	3,415.5	102.1	3,415.5	104,900.0	358.3	0.44	0.2	0.7
08/06/2024 06:00	3,449.2	100.1	3,449.2	104,900.0	361.8	0.45	0.2	0.7
08/06/2024 07:00	3,397.0	102.6	3,397.0	104,900.0	356.3	0.44	0.2	0.7
08/06/2024 08:00	3,384.4	106.3	3,384.4	104,900.0	355.0	0.44	0.2	0.7
08/06/2024 09:00	3,380.4	106.8	3,380.4	104,900.0	354.6	0.44	0.2	0.7
08/06/2024 10:00	3,379.9	95.2	3,379.9	104,900.0	354.6	0.44	0.2	0.7
08/06/2024 11:00	3,391.9	98.3	3,391.9	104,900.0	355.8	0.44	0.2	0.7
08/06/2024 12:00	3,393.5	99.4	3,393.5	104,900.0	356.0	0.44	0.2	0.7
08/06/2024 13:00	3,395.2	105.4	3,395.2	104,900.0	356.2	0.44	0.2	0.7
08/06/2024 14:00	3,392.6	98.8	3,392.6	104,900.0	355.9	0.44	0.2	0.7
08/06/2024 15:00	3,384.2	94.5	3,384.2	104,900.0	355.0	0.44	0.2	0.7
08/06/2024 16:00	3,553.8	93.3	3,553.8	104,900.0	372.8	0.46	0.2	0.8
08/06/2024 17:00	3,825.2	220.2	3,873.6	104,900.0	406.3	0.51	0.3	0.8
08/06/2024 18:00	4,226.1	1,398.8	5,624.9	104,900.0	590.1	0.71	0.4	1.2
08/06/2024 19:00	4,230.6	601.4	4,832.0	104,900.0	506.9	0.61	0.3	1.0
08/06/2024 20:00	4,015.2	333.5	4,188.6	104,900.0	439.4	0.55	0.3	0.9
08/06/2024 21:00	4,061.3	100.5	4,061.3	104,900.0	426.0	0.52	0.3	0.9
08/06/2024 22:00	3,954.7	100.2	3,954.7	104,900.0	414.8	0.51	0.3	0.9
08/06/2024 23:00	3,619.8	100.3	3,619.8	104,900.0	379.7	0.47	0.2	0.8
Average/Sum#:	3,572.6	190.4	3,665.2	104,900.0	384.5	0.47	0.2	0.8
Minimum:	3,376.2	93.3	3,376.2	104,900.0	354.2	0.44	0.2	0.7
Maximum:	4,230.6	1,398.8	5,624.9	104,900.0	590.1	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2024 00:00	3,373.3	101.9	3,373.3	104,900.0	353.9	0.44	0.2	0.7
08/07/2024 01:00	3,371.2	102.7	3,371.2	104,900.0	353.6	0.44	0.2	0.7
08/07/2024 02:00	3,374.0	102.8	3,374.0	104,900.0	353.9	0.44	0.2	0.7
08/07/2024 03:00	3,375.4	103.3	3,375.4	104,900.0	354.1	0.44	0.2	0.7
08/07/2024 04:00	3,374.5	104.7	3,374.5	104,900.0	354.0	0.44	0.2	0.7
08/07/2024 05:00	3,395.5	104.8	3,395.5	104,900.0	356.2	0.44	0.2	0.7
08/07/2024 06:00	3,564.9	99.1	3,564.9	104,900.0	374.0	0.46	0.2	0.8
08/07/2024 07:00	3,391.3	103.3	3,391.3	104,900.0	355.7	0.44	0.2	0.7
08/07/2024 08:00	3,380.1	107.8	3,380.1	104,900.0	354.6	0.44	0.2	0.7
08/07/2024 09:00	3,381.5	104.5	3,381.5	104,900.0	354.7	0.44	0.2	0.7
08/07/2024 10:00	3,383.0	97.0	3,383.0	104,900.0	354.9	0.44	0.2	0.7
08/07/2024 11:00	3,392.8	96.5	3,392.8	104,900.0	355.9	0.44	0.2	0.7
08/07/2024 12:00	3,393.2	99.8	3,393.2	104,900.0	355.9	0.44	0.2	0.7
08/07/2024 13:00	3,392.8	100.8	3,392.8	104,900.0	355.9	0.44	0.2	0.7
08/07/2024 14:00	3,391.6	89.3	3,391.6	104,900.0	355.8	0.44	0.2	0.7
08/07/2024 15:00	3,384.0	84.8	3,384.0	104,900.0	355.0	0.44	0.2	0.7
08/07/2024 16:00	3,379.6	86.8	3,379.6	104,900.0	354.5	0.44	0.2	0.7
08/07/2024 17:00	3,576.8	84.6	3,576.8	104,900.0	375.2	0.46	0.2	0.8
08/07/2024 18:00	3,639.1	95.2	3,639.1	104,900.0	381.7	0.47	0.2	0.8
08/07/2024 19:00	3,736.6	96.3	3,736.6	104,900.0	392.0	0.48	0.2	0.8
08/07/2024 20:00	3,539.4	95.5	3,539.4	104,900.0	371.3	0.46	0.2	0.8
08/07/2024 21:00	3,434.3	95.5	3,434.3	104,900.0	360.3	0.45	0.2	0.7
08/07/2024 22:00	3,431.5	94.8	3,431.5	104,900.0	360.0	0.44	0.2	0.7
08/07/2024 23:00	3,391.4	96.3	3,391.4	104,900.0	355.8	0.44	0.2	0.7
Average/Sum#:	3,435.3	97.8	3,435.3	104,900.0	360.4	0.45	0.2	0.7
Minimum:	3,371.2	84.6	3,371.2	104,900.0	353.6	0.44	0.2	0.7
Maximum:	3,736.6	107.8	3,736.6	104,900.0	392.0	0.48	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2024 00:00	3,389.3	96.7	3,389.3	104,900.0	355.5	0.44	0.2	0.7
08/08/2024 01:00	3,395.1	96.4	3,395.1	104,900.0	356.1	0.44	0.2	0.7
08/08/2024 02:00	3,395.0	98.1	3,395.0	104,900.0	356.1	0.44	0.2	0.7
08/08/2024 03:00	3,393.2	101.0	3,393.2	104,900.0	355.9	0.44	0.2	0.7
08/08/2024 04:00	3,380.6	100.0	3,380.6	104,900.0	354.6	0.44	0.2	0.7
08/08/2024 05:00	3,401.7	99.4	3,401.7	104,900.0	356.8	0.44	0.2	0.7
08/08/2024 06:00	3,561.3	100.4	3,561.3	104,900.0	373.6	0.46	0.2	0.8
08/08/2024 07:00	3,383.0	101.3	3,383.0	104,900.0	354.9	0.44	0.2	0.7
08/08/2024 08:00	3,381.5	104.6	3,381.5	104,900.0	354.7	0.44	0.2	0.7
08/08/2024 09:00	3,378.8	103.7	3,378.8	104,900.0	354.4	0.44	0.2	0.7
08/08/2024 10:00	3,384.2	98.6	3,384.2	104,900.0	355.0	0.44	0.2	0.7
08/08/2024 11:00	3,397.4	100.3	3,397.4	104,900.0	356.4	0.44	0.2	0.7
08/08/2024 12:00	3,394.0	104.5	3,394.0	104,900.0	356.0	0.44	0.2	0.7
08/08/2024 13:00	3,395.4	101.9	3,395.4	104,900.0	356.2	0.44	0.2	0.7
08/08/2024 14:00	3,394.9	92.2	3,394.9	104,900.0	356.1	0.44	0.2	0.7
08/08/2024 15:00	3,388.9	88.9	3,388.9	104,900.0	355.5	0.44	0.2	0.7
08/08/2024 16:00	3,384.8	86.8	3,384.8	104,900.0	355.1	0.44	0.2	0.7
08/08/2024 17:00	3,404.6	85.3	3,404.6	104,900.0	357.1	0.44	0.2	0.7
08/08/2024 18:00	3,426.8	95.8	3,426.8	104,900.0	359.5	0.45	0.2	0.7
08/08/2024 19:00	3,373.0	95.7	3,373.0	104,900.0	353.8	0.44	0.2	0.7
08/08/2024 20:00	3,537.1	95.8	3,537.1	104,900.0	371.0	0.46	0.2	0.8
08/08/2024 21:00	3,502.9	97.0	3,502.9	104,900.0	367.5	0.46	0.2	0.8
08/08/2024 22:00	3,373.1	96.8	3,373.1	104,900.0	353.8	0.44	0.2	0.7
08/08/2024 23:00	3,377.0	97.2	3,377.0	104,900.0	354.2	0.44	0.2	0.7
Average/Sum#:	3,408.1	97.4	3,408.1	104,900.0	357.5	0.44	0.2	0.7
Minimum:	3,373.0	85.3	3,373.0	104,900.0	353.8	0.44	0.2	0.7
Maximum:	3,561.3	104.6	3,561.3	104,900.0	373.6	0.46	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2024 00:00	3,375.6	97.9	3,375.6	104,900.0	354.1	0.44	0.2	0.7
08/09/2024 01:00	3,376.2	98.9	3,376.2	104,900.0	354.2	0.44	0.2	0.7
08/09/2024 02:00	3,375.9	97.1	3,375.9	104,900.0	354.1	0.44	0.2	0.7
08/09/2024 03:00	3,376.7	96.8	3,376.7	104,900.0	354.2	0.44	0.2	0.7
08/09/2024 04:00	3,374.6	99.1	3,374.6	104,900.0	354.0	0.44	0.2	0.7
08/09/2024 05:00	3,396.8	100.8	3,396.8	104,900.0	356.3	0.44	0.2	0.7
08/09/2024 06:00	3,764.8	102.4	3,764.8	104,900.0	394.9	0.49	0.2	0.8
08/09/2024 07:00	3,397.6	104.8	3,397.6	104,900.0	356.4	0.44	0.2	0.7
08/09/2024 08:00	3,385.7	112.0	3,385.7	104,900.0	355.2	0.44	0.2	0.7
08/09/2024 09:00	3,378.9	106.8	3,378.9	104,900.0	354.4	0.44	0.2	0.7
08/09/2024 10:00	3,378.8	98.3	3,378.8	104,900.0	354.4	0.44	0.2	0.7
08/09/2024 11:00	3,389.3	100.1	3,389.3	104,900.0	355.5	0.44	0.2	0.7
08/09/2024 12:00	3,390.2	104.5	3,390.2	104,900.0	355.6	0.44	0.2	0.7
08/09/2024 13:00	3,392.3	106.3	3,392.3	104,900.0	355.9	0.44	0.2	0.7
08/09/2024 14:00	3,391.7	93.7	3,391.7	104,900.0	355.8	0.44	0.2	0.7
08/09/2024 15:00	3,382.6	90.3	3,382.6	104,900.0	354.8	0.44	0.2	0.7
08/09/2024 16:00	3,380.4	87.6	3,380.4	104,900.0	354.6	0.44	0.2	0.7
08/09/2024 17:00	3,549.6	91.0	3,549.6	104,900.0	372.4	0.46	0.2	0.8
08/09/2024 18:00	3,478.7	95.8	3,478.7	104,900.0	364.9	0.45	0.2	0.7
08/09/2024 19:00	3,391.0	97.6	3,391.0	104,900.0	355.7	0.44	0.2	0.7
08/09/2024 20:00	3,384.8	96.5	3,384.8	104,900.0	355.1	0.44	0.2	0.7
08/09/2024 21:00	3,373.7	98.2	3,373.7	104,900.0	353.9	0.44	0.2	0.7
08/09/2024 22:00	3,373.3	98.3	3,373.3	104,900.0	353.9	0.44	0.2	0.7
08/09/2024 23:00	3,371.7	98.9	3,371.7	104,900.0	353.7	0.44	0.2	0.7
Average/Sum#:	3,409.6	98.9	3,409.6	104,900.0	357.7	0.44	0.2	0.7
Minimum:	3,371.7	87.6	3,371.7	104,900.0	353.7	0.44	0.2	0.7
Maximum:	3,764.8	112.0	3,764.8	104,900.0	394.9	0.49	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2024 00:00	3,378.7	99.3	3,378.7	104,900.0	354.4	0.44	0.2	0.7
08/10/2024 01:00	3,381.4	99.2	3,381.4	104,900.0	354.7	0.44	0.2	0.7
08/10/2024 02:00	3,379.9	99.4	3,379.9	104,900.0	354.6	0.44	0.2	0.7
08/10/2024 03:00	3,376.0	103.6	3,376.0	104,900.0	354.1	0.44	0.2	0.7
08/10/2024 04:00	3,370.9	105.1	3,370.9	104,900.0	353.6	0.44	0.2	0.7
08/10/2024 05:00	3,373.9	103.7	3,373.9	104,900.0	353.9	0.44	0.2	0.7
08/10/2024 06:00	3,387.3	100.9	3,387.3	104,900.0	355.3	0.44	0.2	0.7
08/10/2024 07:00	3,393.9	108.2	3,393.9	104,900.0	356.0	0.44	0.2	0.7
08/10/2024 08:00	3,382.6	111.0	3,382.6	104,900.0	354.8	0.44	0.2	0.7
08/10/2024 09:00	3,381.9	105.9	3,381.9	104,900.0	354.8	0.44	0.2	0.7
08/10/2024 10:00	3,388.0	97.9	3,388.0	104,900.0	355.4	0.44	0.2	0.7
08/10/2024 11:00	3,403.1	103.3	3,403.1	104,900.0	357.0	0.44	0.2	0.7
08/10/2024 12:00	3,402.7	105.0	3,402.7	104,900.0	356.9	0.44	0.2	0.7
08/10/2024 13:00	3,516.5	105.8	3,516.5	104,900.0	368.9	0.46	0.2	0.8
08/10/2024 14:00	3,399.2	91.7	3,399.2	104,900.0	356.6	0.44	0.2	0.7
08/10/2024 15:00	3,388.9	91.0	3,388.9	104,900.0	355.5	0.44	0.2	0.7
08/10/2024 16:00	3,383.9	87.6	3,383.9	104,900.0	355.0	0.44	0.2	0.7
08/10/2024 17:00	3,588.0	85.2	3,588.0	104,900.0	376.4	0.47	0.2	0.8
08/10/2024 18:00	3,399.0	94.4	3,399.0	104,900.0	356.6	0.44	0.2	0.7
08/10/2024 19:00	3,375.9	96.3	3,375.9	104,900.0	354.1	0.44	0.2	0.7
08/10/2024 20:00	3,373.7	96.1	3,373.7	104,900.0	353.9	0.44	0.2	0.7
08/10/2024 21:00	3,368.4	96.6	3,368.4	104,900.0	353.3	0.44	0.2	0.7
08/10/2024 22:00	3,370.2	97.8	3,370.2	104,900.0	353.5	0.44	0.2	0.7
08/10/2024 23:00	3,370.9	97.6	3,370.9	104,900.0	353.6	0.44	0.2	0.7
Average/Sum#:	3,397.3	99.3	3,397.3	104,900.0	356.4	0.44	0.2	0.7
Minimum:	3,368.4	85.2	3,368.4	104,900.0	353.3	0.44	0.2	0.7
Maximum:	3,588.0	111.0	3,588.0	104,900.0	376.4	0.47	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2024 00:00	3,373.8	98.0	3,373.8	104,900.0	353.9	0.44	0.2	0.7
08/11/2024 01:00	3,374.4	99.2	3,374.4	104,900.0	354.0	0.44	0.2	0.7
08/11/2024 02:00	3,376.1	98.5	3,376.1	104,900.0	354.2	0.44	0.2	0.7
08/11/2024 03:00	3,376.3	99.4	3,376.3	104,900.0	354.2	0.44	0.2	0.7
08/11/2024 04:00	3,377.5	99.3	3,377.5	104,900.0	354.3	0.44	0.2	0.7
08/11/2024 05:00	3,378.4	98.7	3,378.4	104,900.0	354.4	0.44	0.2	0.7
08/11/2024 06:00	3,391.8	104.0	3,391.8	104,900.0	355.8	0.44	0.2	0.7
08/11/2024 07:00	3,395.8	107.7	3,395.8	104,900.0	356.2	0.44	0.2	0.7
08/11/2024 08:00	3,384.4	113.9	3,384.4	104,900.0	355.0	0.44	0.2	0.7
08/11/2024 09:00	3,380.5	106.1	3,380.5	104,900.0	354.6	0.44	0.2	0.7
08/11/2024 10:00	3,380.8	97.8	3,380.8	104,900.0	354.6	0.44	0.2	0.7
08/11/2024 11:00	3,392.0	100.4	3,392.0	104,900.0	355.8	0.44	0.2	0.7
08/11/2024 12:00	3,754.9	101.0	3,754.9	104,900.0	393.9	0.49	0.2	0.8
08/11/2024 13:00	4,168.3	103.0	4,168.3	104,900.0	437.3	0.54	0.3	0.9
08/11/2024 14:00	4,174.6	97.4	4,174.6	104,900.0	437.9	0.54	0.3	0.9
08/11/2024 15:00	4,144.7	99.7	4,144.7	104,900.0	434.8	0.53	0.3	0.9
08/11/2024 16:00	4,084.3	100.4	4,084.3	104,900.0	428.4	0.52	0.3	0.9
08/11/2024 17:00	3,897.3	101.7	3,897.3	104,900.0	408.8	0.50	0.3	0.8
08/11/2024 18:00	4,176.8	202.6	4,223.4	104,900.0	443.0	0.55	0.3	0.9
08/11/2024 19:00	4,249.1	587.4	4,836.5	104,900.0	507.3	0.61	0.3	1.0
08/11/2024 20:00	4,274.7	1,017.2	5,291.9	104,900.0	555.1	0.67	0.3	1.1
08/11/2024 21:00	4,307.5	425.3	4,732.8	104,900.0	496.5	0.59	0.3	1.0
08/11/2024 22:00	4,270.4	219.2	4,489.6	104,900.0	471.0	0.56	0.3	0.9
08/11/2024 23:00	3,585.6	131.1	3,614.4	104,900.0	379.2	0.47	0.2	0.8
Average/Sum#:	3,736.3	183.7	3,833.1	104,900.0	402.1	0.49	0.2	0.8
Minimum:	3,373.8	97.4	3,373.8	104,900.0	353.9	0.44	0.2	0.7
Maximum:	4,307.5	1,017.2	5,291.9	104,900.0	555.1	0.67	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2024 00:00	3,391.1	107.9	3,391.1	104,900.0	355.7	0.44	0.2	0.7
08/12/2024 01:00	3,391.0	106.8	3,391.0	104,900.0	355.7	0.44	0.2	0.7
08/12/2024 02:00	3,391.2	106.6	3,391.2	104,900.0	355.7	0.44	0.2	0.7
08/12/2024 03:00	3,391.7	106.2	3,391.7	104,900.0	355.8	0.44	0.2	0.7
08/12/2024 04:00	3,545.4	106.1	3,545.4	104,900.0	371.9	0.46	0.2	0.8
08/12/2024 05:00	3,691.5	105.2	3,691.5	104,900.0	387.2	0.48	0.2	0.8
08/12/2024 06:00	3,402.0	101.6	3,402.0	104,900.0	356.9	0.44	0.2	0.7
08/12/2024 07:00	3,409.1	109.4	3,409.1	104,900.0	357.6	0.44	0.2	0.7
08/12/2024 08:00	3,399.4	114.9	3,399.4	104,900.0	356.6	0.44	0.2	0.7
08/12/2024 09:00	3,395.3	106.5	3,395.3	104,900.0	356.2	0.44	0.2	0.7
08/12/2024 10:00	3,392.0	99.0	3,392.0	104,900.0	355.8	0.44	0.2	0.7
08/12/2024 11:00	3,397.2	102.5	3,397.2	104,900.0	356.4	0.44	0.2	0.7
08/12/2024 12:00	3,397.3	104.9	3,397.3	104,900.0	356.4	0.44	0.2	0.7
08/12/2024 13:00	3,396.7	109.3	3,396.7	104,900.0	356.3	0.44	0.2	0.7
08/12/2024 14:00	3,385.9	99.1	3,385.9	104,900.0	355.2	0.44	0.2	0.7
08/12/2024 15:00	3,381.7	98.8	3,381.7	104,900.0	354.7	0.44	0.2	0.7
08/12/2024 16:00	3,379.7	97.2	3,379.7	104,900.0	354.5	0.44	0.2	0.7
08/12/2024 17:00	3,841.6	208.3	3,889.5	104,900.0	408.0	0.51	0.3	0.9
08/12/2024 18:00	4,278.0	566.8	4,844.8	104,900.0	508.2	0.61	0.3	1.0
08/12/2024 19:00	4,207.5	363.6	4,480.2	104,900.0	470.0	0.57	0.3	1.0
08/12/2024 20:00	3,483.8	105.8	3,483.8	104,900.0	365.5	0.45	0.2	0.8
08/12/2024 21:00	3,369.1	105.9	3,369.1	104,900.0	353.4	0.44	0.2	0.7
08/12/2024 22:00	3,373.1	104.7	3,373.1	104,900.0	353.8	0.44	0.2	0.7
08/12/2024 23:00	3,372.1	104.8	3,372.1	104,900.0	353.7	0.44	0.2	0.7
Average/Sum#:	3,502.6	139.2	3,539.6	104,900.0	371.3	0.46	0.2	0.7
Minimum:	3,369.1	97.2	3,369.1	104,900.0	353.4	0.44	0.2	0.7
Maximum:	4,278.0	566.8	4,844.8	104,900.0	508.2	0.61	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2024 00:00	3,371.3	104.6	3,371.3	104,900.0	353.6	0.44	0.2	0.7
08/13/2024 01:00	3,370.1	105.5	3,370.1	104,900.0	353.5	0.44	0.2	0.7
08/13/2024 02:00	3,371.4	105.7	3,371.4	104,900.0	353.7	0.44	0.2	0.7
08/13/2024 03:00	3,370.9	105.8	3,370.9	104,900.0	353.6	0.44	0.2	0.7
08/13/2024 04:00	3,372.9	105.2	3,372.9	104,900.0	353.8	0.44	0.2	0.7
08/13/2024 05:00	3,395.6	105.0	3,395.6	104,900.0	356.2	0.44	0.2	0.7
08/13/2024 06:00	3,389.5	102.8	3,389.5	104,900.0	355.6	0.44	0.2	0.7
08/13/2024 07:00	3,393.6	110.2	3,393.6	104,900.0	356.0	0.44	0.2	0.7
08/13/2024 08:00	3,383.8	114.8	3,383.8	104,900.0	355.0	0.44	0.2	0.7
08/13/2024 09:00	3,383.4	104.4	3,383.4	104,900.0	354.9	0.44	0.2	0.7
08/13/2024 10:00	3,384.2	100.3	3,384.2	104,900.0	355.0	0.44	0.2	0.7
08/13/2024 11:00	3,389.5	104.6	3,389.5	104,900.0	355.6	0.44	0.2	0.7
08/13/2024 12:00	3,391.5	105.0	3,391.5	104,900.0	355.8	0.44	0.2	0.7
08/13/2024 13:00	3,395.8	107.7	3,395.8	104,900.0	356.2	0.44	0.2	0.7
08/13/2024 14:00	3,396.4	94.6	3,396.4	104,900.0	356.3	0.44	0.2	0.7
08/13/2024 15:00	3,388.8	92.4	3,388.8	104,900.0	355.5	0.44	0.2	0.7
08/13/2024 16:00	3,383.1	90.9	3,383.1	104,900.0	354.9	0.44	0.2	0.7
08/13/2024 17:00	4,078.9	548.8	4,369.8	104,900.0	458.4	0.58	0.3	1.0
08/13/2024 18:00	4,279.2	845.5	5,124.7	104,900.0	537.6	0.65	0.3	1.1
08/13/2024 19:00	4,019.8	305.4	4,181.7	104,900.0	438.7	0.54	0.3	0.9
08/13/2024 20:00	3,411.0	100.2	3,411.0	104,900.0	357.8	0.44	0.2	0.7
08/13/2024 21:00	3,423.7	98.2	3,423.7	104,900.0	359.1	0.45	0.2	0.7
08/13/2024 22:00	3,370.6	98.3	3,370.6	104,900.0	353.6	0.44	0.2	0.7
08/13/2024 23:00	3,371.7	99.4	3,371.7	104,900.0	353.7	0.44	0.2	0.7
Average/Sum#:	3,478.6	160.6	3,532.7	104,900.0	370.6	0.46	0.2	0.7
Minimum:	3,370.1	90.9	3,370.1	104,900.0	353.5	0.44	0.2	0.7
Maximum:	4,279.2	845.5	5,124.7	104,900.0	537.6	0.65	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2024 00:00	3,372.1	99.6	3,372.1	104,900.0	353.7	0.44	0.2	0.7
08/14/2024 01:00	3,377.0	100.3	3,377.0	104,900.0	354.2	0.44	0.2	0.7
08/14/2024 02:00	3,378.8	99.9	3,378.8	104,900.0	354.4	0.44	0.2	0.7
08/14/2024 03:00	3,379.7	100.1	3,379.7	104,900.0	354.5	0.44	0.2	0.7
08/14/2024 04:00	3,381.8	100.8	3,381.8	104,900.0	354.8	0.44	0.2	0.7
08/14/2024 05:00	3,378.2	101.3	3,378.2	104,900.0	354.4	0.44	0.2	0.7
08/14/2024 06:00	3,388.9	101.4	3,388.9	104,900.0	355.5	0.44	0.2	0.7
08/14/2024 07:00	3,393.9	110.0	3,393.9	104,900.0	356.0	0.44	0.2	0.7
08/14/2024 08:00	3,382.7	113.4	3,382.7	104,900.0	354.8	0.44	0.2	0.7
08/14/2024 09:00	3,377.6	104.7	3,377.6	104,900.0	354.3	0.44	0.2	0.7
08/14/2024 10:00	3,381.6	99.3	3,381.6	104,900.0	354.7	0.44	0.2	0.7
08/14/2024 11:00	3,392.3	106.0	3,392.3	104,900.0	355.9	0.44	0.2	0.7
08/14/2024 12:00	3,393.8	104.8	3,393.8	104,900.0	356.0	0.44	0.2	0.7
08/14/2024 13:00	3,396.1	105.7	3,396.1	104,900.0	356.3	0.44	0.2	0.7
08/14/2024 14:00	3,391.1	96.1	3,391.1	104,900.0	355.7	0.44	0.2	0.7
08/14/2024 15:00	3,385.3	94.4	3,385.3	104,900.0	355.1	0.44	0.2	0.7
08/14/2024 16:00	3,414.2	89.7	3,414.2	104,900.0	358.1	0.44	0.2	0.7
08/14/2024 17:00	4,169.1	822.9	4,811.0	104,900.0	504.7	0.63	0.3	1.0
08/14/2024 18:00	4,219.5	1,576.5	5,796.0	104,900.0	608.0	0.73	0.4	1.2
08/14/2024 19:00	4,234.9	1,581.6	5,816.5	104,900.0	610.2	0.73	0.4	1.2
08/14/2024 20:00	4,220.5	722.8	4,798.7	104,900.0	503.4	0.62	0.3	1.0
08/14/2024 21:00	3,919.6	102.4	3,919.6	104,900.0	411.2	0.51	0.3	0.8
08/14/2024 22:00	3,415.4	101.6	3,415.4	104,900.0	358.3	0.45	0.2	0.7
08/14/2024 23:00	3,883.9	100.8	3,883.9	104,900.0	407.4	0.50	0.3	0.8
Average/Sum#:	3,567.8	280.7	3,750.3	104,900.0	393.4	0.49	0.2	0.8
Minimum:	3,372.1	89.7	3,372.1	104,900.0	353.7	0.44	0.2	0.7
Maximum:	4,234.9	1,581.6	5,816.5	104,900.0	610.2	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2024 00:00	3,371.3	101.3	3,371.3	104,900.0	353.6	0.44	0.2	0.7
08/15/2024 01:00	3,373.7	101.2	3,373.7	104,900.0	353.9	0.44	0.2	0.7
08/15/2024 02:00	3,377.5	100.7	3,377.5	104,900.0	354.3	0.44	0.2	0.7
08/15/2024 03:00	3,378.2	101.5	3,378.2	104,900.0	354.4	0.44	0.2	0.7
08/15/2024 04:00	3,524.2	100.7	3,524.2	104,900.0	369.7	0.46	0.2	0.8
08/15/2024 05:00	3,733.0	99.8	3,733.0	104,900.0	391.6	0.48	0.2	0.8
08/15/2024 06:00	3,392.7	103.8	3,392.7	104,900.0	355.9	0.44	0.2	0.7
08/15/2024 07:00	3,394.5	109.3	3,394.5	104,900.0	356.1	0.44	0.2	0.7
08/15/2024 08:00	3,385.0	113.2	3,385.0	104,900.0	355.1	0.44	0.2	0.7
08/15/2024 09:00	3,379.7	104.8	3,379.7	104,900.0	354.5	0.44	0.2	0.7
08/15/2024 10:00	3,378.4	98.2	3,378.4	104,900.0	354.4	0.44	0.2	0.7
08/15/2024 11:00	3,393.9	101.9	3,393.9	104,900.0	356.0	0.44	0.2	0.7
08/15/2024 12:00	3,379.7	103.8	3,379.7	104,900.0	354.5	0.44	0.2	0.7
08/15/2024 13:00	3,377.0	104.0	3,377.0	104,900.0	354.2	0.44	0.2	0.7
08/15/2024 14:00	3,376.3	95.8	3,376.3	104,900.0	354.2	0.44	0.2	0.7
08/15/2024 15:00	3,788.8	235.2	3,854.7	104,900.0	404.4	0.51	0.3	0.8
08/15/2024 16:00	4,215.3	680.6	4,895.9	104,900.0	513.6	0.62	0.3	1.0
08/15/2024 17:00	4,215.6	1,148.5	5,364.1	104,900.0	562.7	0.67	0.3	1.1
08/15/2024 18:00	4,221.4	1,441.6	5,663.0	104,900.0	594.0	0.71	0.4	1.2
08/15/2024 19:00	4,246.8	1,177.2	5,424.0	104,900.0	569.0	0.68	0.3	1.1
08/15/2024 20:00	3,962.1	352.2	4,138.2	104,900.0	434.1	0.54	0.3	0.9
08/15/2024 21:00	3,376.4	101.3	3,376.4	104,900.0	354.2	0.44	0.2	0.7
08/15/2024 22:00	3,364.0	99.8	3,364.0	104,900.0	352.9	0.44	0.2	0.7
08/15/2024 23:00	3,408.5	100.0	3,408.5	104,900.0	357.6	0.44	0.2	0.7
Average/Sum#:	3,583.9	286.5	3,779.3	104,900.0	396.5	0.49	0.2	0.8
Minimum:	3,364.0	95.8	3,364.0	104,900.0	352.9	0.44	0.2	0.7
Maximum:	4,246.8	1,441.6	5,663.0	104,900.0	594.0	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2024 00:00	3,366.3	100.4	3,366.3	104,900.0	353.1	0.44	0.2	0.7
08/16/2024 01:00	3,367.5	100.6	3,367.5	104,900.0	353.3	0.44	0.2	0.7
08/16/2024 02:00	3,368.8	100.5	3,368.8	104,900.0	353.4	0.44	0.2	0.7
08/16/2024 03:00	3,368.2	101.0	3,368.2	104,900.0	353.3	0.44	0.2	0.7
08/16/2024 04:00	3,652.0	101.5	3,652.0	104,900.0	383.1	0.47	0.2	0.8
08/16/2024 05:00	3,775.4	99.8	3,775.4	104,900.0	396.0	0.49	0.2	0.8
08/16/2024 06:00	3,387.9	102.4	3,387.9	104,900.0	355.4	0.44	0.2	0.7
08/16/2024 07:00	3,386.1	108.1	3,386.1	104,900.0	355.2	0.44	0.2	0.7
08/16/2024 08:00	3,372.3	108.2	3,372.3	104,900.0	353.8	0.44	0.2	0.7
08/16/2024 09:00	3,371.8	103.6	3,371.8	104,900.0	353.7	0.44	0.2	0.7
08/16/2024 10:00	3,371.3	99.3	3,371.3	104,900.0	353.6	0.44	0.2	0.7
08/16/2024 11:00	3,379.3	103.1	3,379.3	104,900.0	354.5	0.44	0.2	0.7
08/16/2024 12:00	3,378.6	101.1	3,378.6	104,900.0	354.4	0.44	0.2	0.7
08/16/2024 13:00	3,420.9	103.0	3,420.9	104,900.0	358.9	0.44	0.2	0.7
08/16/2024 14:00	3,382.4	98.6	3,382.4	104,900.0	354.8	0.44	0.2	0.7
08/16/2024 15:00	3,372.8	92.1	3,372.8	104,900.0	353.8	0.44	0.2	0.7
08/16/2024 16:00	3,361.0	90.3	3,361.0	104,900.0	352.6	0.43	0.2	0.7
08/16/2024 17:00	3,390.2	90.2	3,390.2	104,900.0	355.6	0.44	0.2	0.7
08/16/2024 18:00	3,370.7	94.6	3,370.7	104,900.0	353.6	0.44	0.2	0.7
08/16/2024 19:00	3,384.9	97.7	3,384.9	104,900.0	355.1	0.44	0.2	0.7
08/16/2024 20:00	3,364.4	100.8	3,364.4	104,900.0	352.9	0.44	0.2	0.7
08/16/2024 21:00	4,037.2	99.0	4,037.2	104,900.0	423.5	0.52	0.3	0.9
08/16/2024 22:00	3,939.6	98.3	3,939.6	104,900.0	413.3	0.51	0.3	0.8
08/16/2024 23:00	3,849.7	99.5	3,849.7	104,900.0	403.8	0.50	0.2	0.8
Average/Sum#:	3,475.8	99.7	3,475.8	104,900.0	364.6	0.45	0.2	0.7
Minimum:	3,361.0	90.2	3,361.0	104,900.0	352.6	0.43	0.2	0.7
Maximum:	4,037.2	108.2	4,037.2	104,900.0	423.5	0.52	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2024 00:00	3,693.8	99.7	3,693.8	104,900.0	387.5	0.48	0.2	0.8
08/17/2024 01:00	3,361.8	99.9	3,361.8	104,900.0	352.7	0.44	0.2	0.7
08/17/2024 02:00	3,364.4	99.6	3,364.4	104,900.0	352.9	0.44	0.2	0.7
08/17/2024 03:00	3,366.9	100.5	3,366.9	104,900.0	353.2	0.44	0.2	0.7
08/17/2024 04:00	3,370.7	100.5	3,370.7	104,900.0	353.6	0.44	0.2	0.7
08/17/2024 05:00	3,695.2	99.8	3,695.2	104,900.0	387.6	0.48	0.2	0.8
08/17/2024 06:00	3,383.5	102.5	3,383.5	104,900.0	354.9	0.44	0.2	0.7
08/17/2024 07:00	3,382.0	110.1	3,382.0	104,900.0	354.8	0.44	0.2	0.7
08/17/2024 08:00	3,369.7	113.2	3,369.7	104,900.0	353.5	0.44	0.2	0.7
08/17/2024 09:00	3,366.6	104.2	3,366.6	104,900.0	353.2	0.44	0.2	0.7
08/17/2024 10:00	3,364.7	99.8	3,364.7	104,900.0	353.0	0.44	0.2	0.7
08/17/2024 11:00	3,377.3	105.0	3,377.3	104,900.0	354.3	0.44	0.2	0.7
08/17/2024 12:00	3,380.8	103.2	3,380.8	104,900.0	354.6	0.44	0.2	0.7
08/17/2024 13:00	3,383.6	108.8	3,383.6	104,900.0	354.9	0.44	0.2	0.7
08/17/2024 14:00	3,383.7	100.0	3,383.7	104,900.0	355.0	0.44	0.2	0.7
08/17/2024 15:00	3,381.3	96.7	3,381.3	104,900.0	354.7	0.44	0.2	0.7
08/17/2024 16:00	3,372.4	93.0	3,372.4	104,900.0	353.8	0.44	0.2	0.7
08/17/2024 17:00	3,417.1	93.3	3,417.1	104,900.0	358.5	0.44	0.2	0.7
08/17/2024 18:00	3,380.0	97.4	3,380.0	104,900.0	354.6	0.44	0.2	0.7
08/17/2024 19:00	3,368.1	96.9	3,368.1	104,900.0	353.3	0.44	0.2	0.7
08/17/2024 20:00	3,367.0	99.1	3,367.0	104,900.0	353.2	0.44	0.2	0.7
08/17/2024 21:00	3,365.6	100.3	3,365.6	104,900.0	353.1	0.44	0.2	0.7
08/17/2024 22:00	3,361.5	100.6	3,361.5	104,900.0	352.6	0.44	0.2	0.7
08/17/2024 23:00	3,364.9	100.1	3,364.9	104,900.0	353.0	0.44	0.2	0.7
Average/Sum#:	3,400.9	101.0	3,400.9	104,900.0	356.8	0.44	0.2	0.7
Minimum:	3,361.5	93.0	3,361.5	104,900.0	352.6	0.44	0.2	0.7
Maximum:	3,695.2	113.2	3,695.2	104,900.0	387.6	0.48	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2024 00:00	3,367.3	101.1	3,367.3	104,900.0	353.2	0.44	0.2	0.7
08/18/2024 01:00	3,364.0	101.7	3,364.0	104,900.0	352.9	0.44	0.2	0.7
08/18/2024 02:00	3,364.6	102.4	3,364.6	104,900.0	352.9	0.44	0.2	0.7
08/18/2024 03:00	3,367.6	102.7	3,367.6	104,900.0	353.3	0.44	0.2	0.7
08/18/2024 04:00	3,372.1	103.1	3,372.1	104,900.0	353.7	0.44	0.2	0.7
08/18/2024 05:00	3,375.1	102.6	3,375.1	104,900.0	354.0	0.44	0.2	0.7
08/18/2024 06:00	3,386.1	102.5	3,386.1	104,900.0	355.2	0.44	0.2	0.7
08/18/2024 07:00	3,385.2	111.5	3,385.2	104,900.0	355.1	0.44	0.2	0.7
08/18/2024 08:00	3,377.9	113.6	3,377.9	104,900.0	354.3	0.44	0.2	0.7
08/18/2024 09:00	3,375.2	105.8	3,375.2	104,900.0	354.1	0.44	0.2	0.7
08/18/2024 10:00	3,375.8	102.2	3,375.8	104,900.0	354.1	0.44	0.2	0.7
08/18/2024 11:00	3,377.9	103.0	3,377.9	104,900.0	354.3	0.44	0.2	0.7
08/18/2024 12:00	3,380.4	106.7	3,380.4	104,900.0	354.6	0.44	0.2	0.7
08/18/2024 13:00	3,385.1	106.5	3,385.1	104,900.0	355.1	0.44	0.2	0.7
08/18/2024 14:00	3,383.3	103.6	3,383.3	104,900.0	354.9	0.44	0.2	0.7
08/18/2024 15:00	3,377.3	99.4	3,377.3	104,900.0	354.3	0.44	0.2	0.7
08/18/2024 16:00	3,438.9	94.0	3,438.9	104,900.0	360.7	0.45	0.2	0.7
08/18/2024 17:00	3,441.1	95.5	3,441.1	104,900.0	361.0	0.45	0.2	0.7
08/18/2024 18:00	3,376.2	99.1	3,376.2	104,900.0	354.2	0.44	0.2	0.7
08/18/2024 19:00	3,369.4	102.0	3,369.4	104,900.0	353.5	0.44	0.2	0.7
08/18/2024 20:00	3,369.1	103.6	3,369.1	104,900.0	353.4	0.44	0.2	0.7
08/18/2024 21:00	3,386.4	102.1	3,386.4	104,900.0	355.2	0.44	0.2	0.7
08/18/2024 22:00	3,366.8	102.3	3,366.8	104,900.0	353.2	0.44	0.2	0.7
08/18/2024 23:00	3,406.9	102.6	3,406.9	104,900.0	357.4	0.44	0.2	0.7
Average/Sum#:	3,382.1	102.9	3,382.1	104,900.0	354.8	0.44	0.2	0.7
Minimum:	3,364.0	94.0	3,364.0	104,900.0	352.9	0.44	0.2	0.7
Maximum:	3,441.1	113.6	3,441.1	104,900.0	361.0	0.45	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2024 00:00	3,368.3	102.0	3,368.3	104,900.0	353.3	0.44	0.2	0.7
08/19/2024 01:00	3,367.8	102.3	3,367.8	104,900.0	353.3	0.44	0.2	0.7
08/19/2024 02:00	3,367.0	102.3	3,367.0	104,900.0	353.2	0.44	0.2	0.7
08/19/2024 03:00	3,370.0	102.4	3,370.0	104,900.0	353.5	0.44	0.2	0.7
08/19/2024 04:00	3,777.5	103.2	3,777.5	104,900.0	396.3	0.49	0.2	0.8
08/19/2024 05:00	3,850.8	102.4	3,850.8	104,900.0	403.9	0.50	0.2	0.8
08/19/2024 06:00	3,385.5	102.2	3,385.5	104,900.0	355.1	0.44	0.2	0.7
08/19/2024 07:00	3,388.7	109.6	3,388.7	104,900.0	355.5	0.44	0.2	0.7
08/19/2024 08:00	3,382.4	110.9	3,382.4	104,900.0	354.8	0.44	0.2	0.7
08/19/2024 09:00	3,381.6	103.8	3,381.6	104,900.0	354.7	0.44	0.2	0.7
08/19/2024 10:00	3,377.2	101.6	3,377.2	104,900.0	354.3	0.44	0.2	0.7
08/19/2024 11:00	3,383.1	95.8	3,383.1	104,900.0	354.9	0.44	0.2	0.7
08/19/2024 12:00	3,384.7	103.6	3,384.7	104,900.0	355.1	0.44	0.2	0.7
08/19/2024 13:00	3,387.3	109.7	3,387.3	104,900.0	355.3	0.44	0.2	0.7
08/19/2024 14:00	3,385.9	100.3	3,385.9	104,900.0	355.2	0.44	0.2	0.7
08/19/2024 15:00	3,377.2	96.8	3,377.2	104,900.0	354.3	0.44	0.2	0.7
08/19/2024 16:00	3,367.6	93.8	3,367.6	104,900.0	353.3	0.44	0.2	0.7
08/19/2024 17:00	3,373.3	96.0	3,373.3	104,900.0	353.9	0.44	0.2	0.7
08/19/2024 18:00	3,375.9	98.7	3,375.9	104,900.0	354.1	0.44	0.2	0.7
08/19/2024 19:00	3,368.6	102.3	3,368.6	104,900.0	353.4	0.44	0.2	0.7
08/19/2024 20:00	3,366.4	102.9	3,366.4	104,900.0	353.1	0.44	0.2	0.7
08/19/2024 21:00	3,721.5	101.9	3,721.5	104,900.0	390.4	0.48	0.2	0.8
08/19/2024 22:00	3,365.1	101.5	3,365.1	104,900.0	353.0	0.44	0.2	0.7
08/19/2024 23:00	3,365.4	102.6	3,365.4	104,900.0	353.0	0.44	0.2	0.7
Average/Sum#:	3,426.6	102.0	3,426.6	104,900.0	359.5	0.45	0.2	0.7
Minimum:	3,365.1	93.8	3,365.1	104,900.0	353.0	0.44	0.2	0.7
Maximum:	3,850.8	110.9	3,850.8	104,900.0	403.9	0.50	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2024 00:00	3,364.4	102.2	3,364.4	104,900.0	352.9	0.44	0.2	0.7
08/20/2024 01:00	3,366.2	101.8	3,366.2	104,900.0	353.1	0.44	0.2	0.7
08/20/2024 02:00	3,364.8	102.1	3,364.8	104,900.0	353.0	0.44	0.2	0.7
08/20/2024 03:00	3,366.3	102.6	3,366.3	104,900.0	353.1	0.44	0.2	0.7
08/20/2024 04:00	3,367.9	105.3	3,367.9	104,900.0	353.3	0.44	0.2	0.7
08/20/2024 05:00	3,374.0	104.1	3,374.0	104,900.0	353.9	0.44	0.2	0.7
08/20/2024 06:00	3,385.0	100.1	3,385.0	104,900.0	355.1	0.44	0.2	0.7
08/20/2024 07:00	3,386.6	111.2	3,386.6	104,900.0	355.3	0.44	0.2	0.7
08/20/2024 08:00	3,383.5	111.5	3,383.5	104,900.0	354.9	0.44	0.2	0.7
08/20/2024 09:00	3,387.6	103.2	3,387.6	104,900.0	355.4	0.44	0.2	0.7
08/20/2024 10:00	3,381.8	100.2	3,381.8	104,900.0	354.8	0.44	0.2	0.7
08/20/2024 11:00	3,391.2	94.2	3,391.2	104,900.0	355.7	0.44	0.2	0.7
08/20/2024 12:00	3,394.3	101.9	3,394.3	104,900.0	356.1	0.44	0.2	0.7
08/20/2024 13:00	3,394.1	108.0	3,394.1	104,900.0	356.0	0.44	0.2	0.7
08/20/2024 14:00	3,394.3	99.3	3,394.3	104,900.0	356.1	0.44	0.2	0.7
08/20/2024 15:00	3,387.1	97.0	3,387.1	104,900.0	355.3	0.44	0.2	0.7
08/20/2024 16:00	3,380.7	92.9	3,380.7	104,900.0	354.6	0.44	0.2	0.7
08/20/2024 17:00	3,563.6	94.5	3,563.6	104,900.0	373.8	0.46	0.2	0.8
08/20/2024 18:00	3,387.7	98.1	3,387.7	104,900.0	355.4	0.44	0.2	0.7
08/20/2024 19:00	3,379.2	101.9	3,379.2	104,900.0	354.5	0.44	0.2	0.7
08/20/2024 20:00	3,370.0	101.6	3,370.0	104,900.0	353.5	0.44	0.2	0.7
08/20/2024 21:00	3,337.4	100.9	3,337.4	104,900.0	350.1	0.43	0.2	0.7
08/20/2024 22:00	3,347.0	100.8	3,347.0	104,900.0	351.1	0.43	0.2	0.7
08/20/2024 23:00	3,346.2	101.7	3,346.2	104,900.0	351.0	0.43	0.2	0.7
Average/Sum#:	3,383.4	101.5	3,383.4	104,900.0	354.9	0.44	0.2	0.7
Minimum:	3,337.4	92.9	3,337.4	104,900.0	350.1	0.43	0.2	0.7
Maximum:	3,563.6	111.5	3,563.6	104,900.0	373.8	0.46	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2024 00:00	3,343.2	101.7	3,343.2	104,900.0	350.7	0.43	0.2	0.7
08/21/2024 01:00	3,344.8	101.3	3,344.8	104,900.0	350.9	0.43	0.2	0.7
08/21/2024 02:00	3,346.5	101.6	3,346.5	104,900.0	351.0	0.43	0.2	0.7
08/21/2024 03:00	3,350.3	102.0	3,350.3	104,900.0	351.4	0.43	0.2	0.7
08/21/2024 04:00	3,351.7	101.5	3,351.7	104,900.0	351.6	0.43	0.2	0.7
08/21/2024 05:00	3,361.9	101.5	3,361.9	104,900.0	352.7	0.44	0.2	0.7
08/21/2024 06:00	3,369.1	103.2	3,369.1	104,900.0	353.4	0.44	0.2	0.7
08/21/2024 07:00	3,377.4	112.2	3,377.4	104,900.0	354.3	0.44	0.2	0.7
08/21/2024 08:00	3,371.5	110.0	3,371.5	104,900.0	353.7	0.44	0.2	0.7
08/21/2024 09:00	3,367.8	103.8	3,367.8	104,900.0	353.3	0.44	0.2	0.7
08/21/2024 10:00	3,367.0	102.3	3,367.0	104,900.0	353.2	0.44	0.2	0.7
08/21/2024 11:00	3,375.3	96.9	3,375.3	104,900.0	354.1	0.44	0.2	0.7
08/21/2024 12:00	3,377.2	103.2	3,377.2	104,900.0	354.3	0.44	0.2	0.7
08/21/2024 13:00	3,378.3	106.9	3,378.3	104,900.0	354.4	0.44	0.2	0.7
08/21/2024 14:00	3,373.9	102.9	3,373.9	104,900.0	353.9	0.44	0.2	0.7
08/21/2024 15:00	3,367.6	97.7	3,367.6	104,900.0	353.3	0.44	0.2	0.7
08/21/2024 16:00	3,445.0	94.3	3,445.0	104,900.0	361.4	0.45	0.2	0.7
08/21/2024 17:00	3,452.7	96.0	3,452.7	104,900.0	362.2	0.45	0.2	0.7
08/21/2024 18:00	3,374.7	103.1	3,374.7	104,900.0	354.0	0.44	0.2	0.7
08/21/2024 19:00	3,352.3	102.1	3,352.3	104,900.0	351.7	0.43	0.2	0.7
08/21/2024 20:00	3,334.6	102.0	3,334.6	104,900.0	349.8	0.43	0.2	0.7
08/21/2024 21:00	3,350.6	102.3	3,350.6	104,900.0	351.5	0.43	0.2	0.7
08/21/2024 22:00	3,326.2	102.1	3,326.2	104,900.0	348.9	0.43	0.2	0.7
08/21/2024 23:00	3,323.8	102.3	3,323.8	104,900.0	348.7	0.43	0.2	0.7
Average/Sum#:	3,366.0	102.2	3,366.0	104,900.0	353.1	0.44	0.2	0.7
Minimum:	3,323.8	94.3	3,323.8	104,900.0	348.7	0.43	0.2	0.7
Maximum:	3,452.7	112.2	3,452.7	104,900.0	362.2	0.45	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2024 00:00	3,329.6	102.4	3,329.6	104,900.0	349.3	0.43	0.2	0.7
08/22/2024 01:00	3,338.2	102.7	3,338.2	104,900.0	350.2	0.43	0.2	0.7
08/22/2024 02:00	3,344.2	103.2	3,344.2	104,900.0	350.8	0.43	0.2	0.7
08/22/2024 03:00	3,348.2	103.2	3,348.2	104,900.0	351.2	0.43	0.2	0.7
08/22/2024 04:00	3,353.4	103.4	3,353.4	104,900.0	351.8	0.44	0.2	0.7
08/22/2024 05:00	3,470.6	103.3	3,470.6	104,900.0	364.1	0.45	0.2	0.8
08/22/2024 06:00	3,375.6	104.9	3,375.6	104,900.0	354.1	0.44	0.2	0.7
08/22/2024 07:00	3,379.0	113.7	3,379.0	104,900.0	354.5	0.44	0.2	0.7
08/22/2024 08:00	3,370.2	115.1	3,370.2	104,900.0	353.5	0.44	0.2	0.7
08/22/2024 09:00	3,366.5	105.4	3,366.5	104,900.0	353.1	0.44	0.2	0.7
08/22/2024 10:00	3,368.3	106.5	3,368.3	104,900.0	353.3	0.44	0.2	0.7
08/22/2024 11:00	3,379.4	101.0	3,379.4	104,900.0	354.5	0.44	0.2	0.7
08/22/2024 12:00	3,381.0	103.6	3,381.0	104,900.0	354.7	0.44	0.2	0.7
08/22/2024 13:00	3,382.8	112.7	3,382.8	104,900.0	354.9	0.44	0.2	0.7
08/22/2024 14:00	3,378.7	102.2	3,378.7	104,900.0	354.4	0.44	0.2	0.7
08/22/2024 15:00	3,374.2	99.4	3,374.2	104,900.0	354.0	0.44	0.2	0.7
08/22/2024 16:00	3,368.8	99.1	3,368.8	104,900.0	353.4	0.44	0.2	0.7
08/22/2024 17:00	3,371.7	100.7	3,371.7	104,900.0	353.7	0.44	0.2	0.7
08/22/2024 18:00	3,369.7	103.1	3,369.7	104,900.0	353.5	0.44	0.2	0.7
08/22/2024 19:00	3,364.4	103.6	3,364.4	104,900.0	352.9	0.44	0.2	0.7
08/22/2024 20:00	3,368.6	103.1	3,368.6	104,900.0	353.4	0.44	0.2	0.7
08/22/2024 21:00	3,369.0	102.1	3,369.0	104,900.0	353.4	0.44	0.2	0.7
08/22/2024 22:00	3,373.0	102.4	3,373.0	104,900.0	353.8	0.44	0.2	0.7
08/22/2024 23:00	3,373.3	102.6	3,373.3	104,900.0	353.9	0.44	0.2	0.7
Average/Sum#:	3,370.8	104.1	3,370.8	104,900.0	353.6	0.44	0.2	0.7
Minimum:	3,329.6	99.1	3,329.6	104,900.0	349.3	0.43	0.2	0.7
Maximum:	3,470.6	115.1	3,470.6	104,900.0	364.1	0.45	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2024 00:00	3,374.1	103.1	3,374.1	104,900.0	353.9	0.44	0.2	0.7
08/23/2024 01:00	3,376.1	103.9	3,376.1	104,900.0	354.2	0.44	0.2	0.7
08/23/2024 02:00	3,375.9	104.0	3,375.9	104,900.0	354.1	0.44	0.2	0.7
08/23/2024 03:00	3,376.0	104.9	3,376.0	104,900.0	354.1	0.44	0.2	0.7
08/23/2024 04:00	3,377.2	105.6	3,377.2	104,900.0	354.3	0.44	0.2	0.7
08/23/2024 05:00	3,380.4	105.3	3,380.4	104,900.0	354.6	0.44	0.2	0.7
08/23/2024 06:00	3,387.0	104.0	3,387.0	104,900.0	355.3	0.44	0.2	0.7
08/23/2024 07:00	3,387.9	110.0	3,387.9	104,900.0	355.4	0.44	0.2	0.7
08/23/2024 08:00	3,380.0	113.5	3,380.0	104,900.0	354.6	0.44	0.2	0.7
08/23/2024 09:00	3,378.4	104.9	3,378.4	104,900.0	354.4	0.44	0.2	0.7
08/23/2024 10:00	3,380.9	104.3	3,380.9	104,900.0	354.7	0.44	0.2	0.7
08/23/2024 11:00	3,388.7	97.7	3,388.7	104,900.0	355.5	0.44	0.2	0.7
08/23/2024 12:00	3,387.3	98.4	3,387.3	104,900.0	355.3	0.44	0.2	0.7
08/23/2024 13:00	3,383.1	99.8	3,383.1	104,900.0	354.9	0.44	0.2	0.7
08/23/2024 14:00	3,381.1	100.6	3,381.1	104,900.0	354.7	0.44	0.2	0.7
08/23/2024 15:00	3,382.9	99.8	3,382.9	104,900.0	354.9	0.44	0.2	0.7
08/23/2024 16:00	3,380.9	99.6	3,380.9	104,900.0	354.7	0.44	0.2	0.7
08/23/2024 17:00	3,378.2	102.9	3,378.2	104,900.0	354.4	0.44	0.2	0.7
08/23/2024 18:00	3,378.5	105.3	3,378.5	104,900.0	354.4	0.44	0.2	0.7
08/23/2024 19:00	3,379.1	103.8	3,379.1	104,900.0	354.5	0.44	0.2	0.7
08/23/2024 20:00	3,378.1	105.3	3,378.1	104,900.0	354.4	0.44	0.2	0.7
08/23/2024 21:00	3,377.3	105.7	3,377.3	104,900.0	354.3	0.44	0.2	0.7
08/23/2024 22:00	3,376.6	104.8	3,376.6	104,900.0	354.2	0.44	0.2	0.7
08/23/2024 23:00	3,610.3	105.4	3,610.3	104,900.0	378.7	0.47	0.2	0.8
Average/Sum#:	3,389.8	103.9	3,389.8	104,900.0	355.6	0.44	0.2	0.7
Minimum:	3,374.1	97.7	3,374.1	104,900.0	353.9	0.44	0.2	0.7
Maximum:	3,610.3	113.5	3,610.3	104,900.0	378.7	0.47	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/24/2024 00:00	3,374.0	106.2	3,374.0	104,900.0	353.9	0.44	0.2	0.7
08/24/2024 01:00	3,381.0	106.0	3,381.0	104,900.0	354.7	0.44	0.2	0.7
08/24/2024 02:00	3,381.0	105.9	3,381.0	104,900.0	354.7	0.44	0.2	0.7
08/24/2024 03:00	3,381.4	107.5	3,381.4	104,900.0	354.7	0.44	0.2	0.7
08/24/2024 04:00	3,409.8	107.7	3,409.8	104,900.0	357.7	0.44	0.2	0.7
08/24/2024 05:00	3,578.0	107.4	3,578.0	104,900.0	375.3	0.46	0.2	0.8
08/24/2024 06:00	3,468.4	105.4	3,468.4	104,900.0	363.8	0.45	0.2	0.7
08/24/2024 07:00	3,379.6	108.9	3,379.6	104,900.0	354.5	0.44	0.2	0.7
08/24/2024 08:00	3,381.7	102.9	3,381.7	104,900.0	354.7	0.44	0.2	0.7
08/24/2024 09:00	3,391.5	100.9	3,391.5	104,900.0	355.8	0.44	0.2	0.7
08/24/2024 10:00	3,390.5	102.9	3,390.5	104,900.0	355.7	0.44	0.2	0.7
08/24/2024 11:00	3,393.2	98.9	3,393.2	104,900.0	355.9	0.44	0.2	0.7
08/24/2024 12:00	3,391.8	102.8	3,391.8	104,900.0	355.8	0.44	0.2	0.7
08/24/2024 13:00	3,385.0	104.9	3,385.0	104,900.0	355.1	0.44	0.2	0.7
08/24/2024 14:00	3,376.8	107.6	3,376.8	104,900.0	354.2	0.44	0.2	0.7
08/24/2024 15:00	3,391.9	99.7	3,391.9	104,900.0	355.8	0.44	0.2	0.7
08/24/2024 16:00	3,385.0	102.5	3,385.0	104,900.0	355.1	0.44	0.2	0.7
08/24/2024 17:00	3,382.0	103.9	3,382.0	104,900.0	354.8	0.44	0.2	0.7
08/24/2024 18:00	3,380.4	106.5	3,380.4	104,900.0	354.6	0.44	0.2	0.7
08/24/2024 19:00	3,375.4	106.4	3,375.4	104,900.0	354.1	0.44	0.2	0.7
08/24/2024 20:00	3,377.1	107.5	3,377.1	104,900.0	354.3	0.44	0.2	0.7
08/24/2024 21:00	3,389.1	106.6	3,389.1	104,900.0	355.5	0.44	0.2	0.7
08/24/2024 22:00	3,389.0	109.5	3,389.0	104,900.0	355.5	0.44	0.2	0.7
08/24/2024 23:00	3,389.6	110.3	3,389.6	104,900.0	355.6	0.44	0.2	0.7
Average/Sum#:	3,396.8	105.4	3,396.8	104,900.0	356.3	0.44	0.2	0.7
Minimum:	3,374.0	98.9	3,374.0	104,900.0	353.9	0.44	0.2	0.7
Maximum:	3,578.0	110.3	3,578.0	104,900.0	375.3	0.46	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr		
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2024 00:00	3,390.6	110.5	3,390.6	104,900.0	355.7	0.44	0.2	0.7		
08/25/2024 01:00	3,390.4	109.4	3,390.4	104,900.0	355.7	0.44	0.2	0.7		
08/25/2024 02:00	3,394.1	109.7	3,394.1	104,900.0	356.0	0.44	0.2	0.7		
08/25/2024 03:00	3,400.8	110.5	3,400.8	104,900.0	356.7	0.44	0.2	0.7		
08/25/2024 04:00	3,411.2	111.1	3,411.2	104,900.0	357.8	0.44	0.2	0.7		
08/25/2024 05:00	3,408.5	110.3	3,408.5	104,900.0	357.6	0.44	0.2	0.7		
08/25/2024 06:00	3,414.3	105.9	3,414.3	104,900.0	358.2	0.44	0.2	0.7		
08/25/2024 07:00	3,410.8	110.8	3,410.8	104,900.0	357.8	0.44	0.2	0.7		
08/25/2024 08:00	3,406.5	114.9	3,406.5	104,900.0	357.3	0.44	0.2	0.7		
08/25/2024 09:00	3,409.0	105.1	3,409.0	104,900.0	357.6	0.44	0.2	0.7		
08/25/2024 10:00	3,411.6	106.6	3,411.6	104,900.0	357.9	0.44	0.2	0.7		
08/25/2024 11:00	3,415.7	99.1	3,415.7	104,900.0	358.3	0.44	0.2	0.7		
08/25/2024 12:00	3,409.5	103.2	3,409.5	104,900.0	357.7	0.44	0.2	0.7		
08/25/2024 13:00	3,396.1	113.7	3,396.1	104,900.0	356.3	0.44	0.2	0.7		
08/25/2024 14:00	3,393.3	100.1	3,393.3	104,900.0	356.0	0.44	0.2	0.7		
08/25/2024 15:00	3,396.3	99.9	3,396.3	104,900.0	356.3	0.44	0.2	0.7		
08/25/2024 16:00	3,430.6	98.3	3,430.6	104,900.0	359.9	0.44	0.2	0.7		
08/25/2024 17:00	3,784.3	94.9	3,784.3	104,900.0	397.0	0.49	0.2	0.8		
08/25/2024 18:00	4,067.9	99.7	4,067.9	104,900.0	426.7	0.52	0.3	0.9		
08/25/2024 19:00	4,060.8	103.1	4,060.8	104,900.0	426.0	0.52	0.3	0.9		
08/25/2024 20:00	3,866.2	105.2	3,866.2	104,900.0	405.6	0.50	0.2	0.8		
08/25/2024 21:00	3,391.2	103.1	3,391.2	104,900.0	355.7	0.44	0.2	0.7		
08/25/2024 22:00	3,393.6	103.5	3,393.6	104,900.0	356.0	0.44	0.2	0.7		
08/25/2024 23:00	3,450.1	102.7	3,450.1	104,900.0	361.9	0.45	0.2	0.7		
Average/Sum#:	3,496.0	105.5	3,496.0	104,900.0	366.7	0.45	0.2	0.7		
Minimum:	3,390.4	94.9	3,390.4	104,900.0	355.7	0.44	0.2	0.7		
Maximum:	4,067.9	114.9	4,067.9	104,900.0	426.7	0.52	0.3	0.9		
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2024 00:00	3,396.3	101.9	3,396.3	104,900.0	356.3	0.44	0.2	0.7
08/26/2024 01:00	3,396.4	102.5	3,396.4	104,900.0	356.3	0.44	0.2	0.7
08/26/2024 02:00	3,396.4	103.2	3,396.4	104,900.0	356.3	0.44	0.2	0.7
08/26/2024 03:00	3,398.0	104.2	3,398.0	104,900.0	356.5	0.44	0.2	0.7
08/26/2024 04:00	3,708.4	104.3	3,708.4	104,900.0	389.0	0.48	0.2	0.8
08/26/2024 05:00	4,032.4	103.9	4,032.4	104,900.0	423.0	0.52	0.3	0.9
08/26/2024 06:00	3,480.5	103.1	3,480.5	104,900.0	365.1	0.45	0.2	0.8
08/26/2024 07:00	3,423.4	107.2	3,423.4	104,900.0	359.1	0.44	0.2	0.7
08/26/2024 08:00	3,425.9	109.4	3,425.9	104,900.0	359.4	0.44	0.2	0.7
08/26/2024 09:00	3,414.9	99.8	3,414.9	104,900.0	358.2	0.44	0.2	0.7
08/26/2024 10:00	3,393.1	98.1	3,393.1	104,900.0	355.9	0.44	0.2	0.7
08/26/2024 11:00	3,397.9	94.1	3,397.9	104,900.0	356.4	0.44	0.2	0.7
08/26/2024 12:00	3,398.3	100.2	3,398.3	104,900.0	356.5	0.44	0.2	0.7
08/26/2024 13:00	3,384.6	106.4	3,384.6	104,900.0	355.0	0.44	0.2	0.7
08/26/2024 14:00	3,383.8	101.0	3,383.8	104,900.0	355.0	0.44	0.2	0.7
08/26/2024 15:00	3,381.2	101.4	3,381.2	104,900.0	354.7	0.44	0.2	0.7
08/26/2024 16:00	3,571.0	98.9	3,571.0	104,900.0	374.6	0.46	0.2	0.8
08/26/2024 17:00	3,776.8	98.6	3,776.8	104,900.0	396.2	0.49	0.2	0.8
08/26/2024 18:00	3,873.1	100.4	3,873.1	104,900.0	406.3	0.50	0.3	0.8
08/26/2024 19:00	3,530.6	102.9	3,530.6	104,900.0	370.4	0.46	0.2	0.8
08/26/2024 20:00	3,477.0	102.3	3,477.0	104,900.0	364.7	0.45	0.2	0.8
08/26/2024 21:00	3,376.0	102.2	3,376.0	104,900.0	354.1	0.44	0.2	0.7
08/26/2024 22:00	3,375.1	102.4	3,375.1	104,900.0	354.0	0.44	0.2	0.7
08/26/2024 23:00	3,372.9	101.4	3,372.9	104,900.0	353.8	0.44	0.2	0.7
Average/Sum#:	3,490.2	102.1	3,490.2	104,900.0	366.1	0.45	0.2	0.7
Minimum:	3,372.9	94.1	3,372.9	104,900.0	353.8	0.44	0.2	0.7
Maximum:	4,032.4	109.4	4,032.4	104,900.0	423.0	0.52	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2024 00:00	3,380.1	101.0	3,380.1	104,900.0	354.6	0.44	0.2	0.7
08/27/2024 01:00	3,382.1	101.3	3,382.1	104,900.0	354.8	0.44	0.2	0.7
08/27/2024 02:00	3,377.6	102.0	3,377.6	104,900.0	354.3	0.44	0.2	0.7
08/27/2024 03:00	3,374.9	101.3	3,374.9	104,900.0	354.0	0.44	0.2	0.7
08/27/2024 04:00	3,376.9	102.8	3,376.9	104,900.0	354.2	0.44	0.2	0.7
08/27/2024 05:00	3,380.9	104.7	3,380.9	104,900.0	354.7	0.44	0.2	0.7
08/27/2024 06:00	3,394.0	103.5	3,394.0	104,900.0	356.0	0.44	0.2	0.7
08/27/2024 07:00	3,393.5	110.7	3,393.5	104,900.0	356.0	0.44	0.2	0.7
08/27/2024 08:00	3,385.9	112.5	3,385.9	104,900.0	355.2	0.44	0.2	0.7
08/27/2024 09:00	3,385.1	102.8	3,385.1	104,900.0	355.1	0.44	0.2	0.7
08/27/2024 10:00	3,386.5	100.5	3,386.5	104,900.0	355.2	0.44	0.2	0.7
08/27/2024 11:00	3,399.4	97.2	3,399.4	104,900.0	356.6	0.44	0.2	0.7
08/27/2024 12:00	3,399.2	100.2	3,399.2	104,900.0	356.6	0.44	0.2	0.7
08/27/2024 13:00	3,385.1	104.4	3,385.1	104,900.0	355.1	0.44	0.2	0.7
08/27/2024 14:00	3,381.9	97.7	3,381.9	104,900.0	354.8	0.44	0.2	0.7
08/27/2024 15:00	3,381.8	92.7	3,381.8	104,900.0	354.8	0.44	0.2	0.7
08/27/2024 16:00	3,410.3	93.0	3,410.3	104,900.0	357.7	0.44	0.2	0.7
08/27/2024 17:00	3,657.6	93.0	3,657.6	104,900.0	383.7	0.47	0.2	0.8
08/27/2024 18:00	3,910.6	97.4	3,910.6	104,900.0	410.2	0.51	0.3	0.8
08/27/2024 19:00	3,375.7	103.1	3,375.7	104,900.0	354.1	0.44	0.2	0.7
08/27/2024 20:00	3,377.0	100.6	3,377.0	104,900.0	354.2	0.44	0.2	0.7
08/27/2024 21:00	3,378.4	99.4	3,378.4	104,900.0	354.4	0.44	0.2	0.7
08/27/2024 22:00	3,375.6	98.3	3,375.6	104,900.0	354.1	0.44	0.2	0.7
08/27/2024 23:00	3,384.0	97.9	3,384.0	104,900.0	355.0	0.44	0.2	0.7
Average/Sum#:	3,418.1	100.8	3,418.1	104,900.0	358.6	0.44	0.2	0.7
Minimum:	3,374.9	92.7	3,374.9	104,900.0	354.0	0.44	0.2	0.7
Maximum:	3,910.6	112.5	3,910.6	104,900.0	410.2	0.51	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2024 00:00	3,384.4	99.5	3,384.4	104,900.0	355.0	0.44	0.2	0.7
08/28/2024 01:00	3,383.4	100.1	3,383.4	104,900.0	354.9	0.44	0.2	0.7
08/28/2024 02:00	3,386.0	99.1	3,386.0	104,900.0	355.2	0.44	0.2	0.7
08/28/2024 03:00	3,386.9	100.6	3,386.9	104,900.0	355.3	0.44	0.2	0.7
08/28/2024 04:00	3,435.3	101.2	3,435.3	104,900.0	360.4	0.45	0.2	0.7
08/28/2024 05:00	3,810.0	103.8	3,810.0	104,900.0	399.7	0.49	0.2	0.8
08/28/2024 06:00	3,502.6	100.8	3,502.6	104,900.0	367.4	0.45	0.2	0.8
08/28/2024 07:00	3,401.3	109.3	3,401.3	104,900.0	356.8	0.44	0.2	0.7
08/28/2024 08:00	3,399.6	110.4	3,399.6	104,900.0	356.6	0.44	0.2	0.7
08/28/2024 09:00	3,401.0	102.0	3,401.0	104,900.0	356.8	0.44	0.2	0.7
08/28/2024 10:00	3,404.2	99.0	3,404.2	104,900.0	357.1	0.44	0.2	0.7
08/28/2024 11:00	3,395.6	97.2	3,395.6	104,900.0	356.2	0.44	0.2	0.7
08/28/2024 12:00	3,393.6	99.4	3,393.6	104,900.0	356.0	0.44	0.2	0.7
08/28/2024 13:00	3,381.1	108.0	3,381.1	104,900.0	354.7	0.44	0.2	0.7
08/28/2024 14:00	3,378.6	97.2	3,378.6	104,900.0	354.4	0.44	0.2	0.7
08/28/2024 15:00	3,379.1	92.5	3,379.1	104,900.0	354.5	0.44	0.2	0.7
08/28/2024 16:00	3,405.4	92.1	3,405.4	104,900.0	357.2	0.44	0.2	0.7
08/28/2024 17:00	3,410.1	93.2	3,410.1	104,900.0	357.7	0.44	0.2	0.7
08/28/2024 18:00	3,394.8	96.3	3,394.8	104,900.0	356.1	0.44	0.2	0.7
08/28/2024 19:00	3,377.2	97.0	3,377.2	104,900.0	354.3	0.44	0.2	0.7
08/28/2024 20:00	3,383.6	99.4	3,383.6	104,900.0	354.9	0.44	0.2	0.7
08/28/2024 21:00	3,380.7	100.9	3,380.7	104,900.0	354.6	0.44	0.2	0.7
08/28/2024 22:00	3,388.7	99.4	3,388.7	104,900.0	355.5	0.44	0.2	0.7
08/28/2024 23:00	3,392.2	100.4	3,392.2	104,900.0	355.8	0.44	0.2	0.7
Average/Sum#:	3,414.8	100.0	3,414.8	104,900.0	358.2	0.44	0.2	0.7
Minimum:	3,377.2	92.1	3,377.2	104,900.0	354.3	0.44	0.2	0.7
Maximum:	3,810.0	110.4	3,810.0	104,900.0	399.7	0.49	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2024 00:00	3,386.9	101.6	3,386.9	104,900.0	355.3	0.44	0.2	0.7
08/29/2024 01:00	3,384.9	101.6	3,384.9	104,900.0	355.1	0.44	0.2	0.7
08/29/2024 02:00	3,422.6	100.9	3,422.6	104,900.0	359.0	0.44	0.2	0.7
08/29/2024 03:00	3,376.6	101.7	3,376.6	104,900.0	354.2	0.44	0.2	0.7
08/29/2024 04:00	3,378.2	102.1	3,378.2	104,900.0	354.4	0.44	0.2	0.7
08/29/2024 05:00	3,379.2	103.1	3,379.2	104,900.0	354.5	0.44	0.2	0.7
08/29/2024 06:00	4,307.9	103.3	4,307.9	104,900.0	451.9	0.56	0.3	0.9
08/29/2024 07:00	4,384.8	107.9	4,384.8	104,900.0	460.0	0.57	0.3	0.9
08/29/2024 08:00	4,370.1	106.9	4,370.1	104,900.0	458.4	0.56	0.3	0.9
08/29/2024 09:00	3,721.2	101.9	3,721.2	104,900.0	390.4	0.48	0.2	0.8
08/29/2024 10:00	3,421.3	99.7	3,421.3	104,900.0	358.9	0.44	0.2	0.7
08/29/2024 11:00	3,389.1	96.2	3,389.1	104,900.0	355.5	0.44	0.2	0.7
08/29/2024 12:00	3,389.3	101.8	3,389.3	104,900.0	355.5	0.44	0.2	0.7
08/29/2024 13:00	3,379.1	106.8	3,379.1	104,900.0	354.5	0.44	0.2	0.7
08/29/2024 14:00	3,379.3	96.2	3,379.3	104,900.0	354.5	0.44	0.2	0.7
08/29/2024 15:00	3,376.4	93.4	3,376.4	104,900.0	354.2	0.44	0.2	0.7
08/29/2024 16:00	3,375.1	93.9	3,375.1	104,900.0	354.0	0.44	0.2	0.7
08/29/2024 17:00	3,380.9	94.6	3,380.9	104,900.0	354.7	0.44	0.2	0.7
08/29/2024 18:00	3,382.8	100.3	3,382.8	104,900.0	354.9	0.44	0.2	0.7
08/29/2024 19:00	3,382.1	101.1	3,382.1	104,900.0	354.8	0.44	0.2	0.7
08/29/2024 20:00	3,378.6	103.2	3,378.6	104,900.0	354.4	0.44	0.2	0.7
08/29/2024 21:00	3,378.7	102.0	3,378.7	104,900.0	354.4	0.44	0.2	0.7
08/29/2024 22:00	3,381.2	102.1	3,381.2	104,900.0	354.7	0.44	0.2	0.7
08/29/2024 23:00	3,383.3	103.0	3,383.3	104,900.0	354.9	0.44	0.2	0.7
Average/Sum#:	3,520.4	101.1	3,520.4	104,900.0	369.3	0.46	0.2	0.7
Minimum:	3,375.1	93.4	3,375.1	104,900.0	354.0	0.44	0.2	0.7
Maximum:	4,384.8	107.9	4,384.8	104,900.0	460.0	0.57	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2024 00:00	3,384.2	103.3	3,384.2	104,900.0	355.0	0.44	0.2	0.7
08/30/2024 01:00	3,382.6	103.4	3,382.6	104,900.0	354.8	0.44	0.2	0.7
08/30/2024 02:00	3,383.4	103.2	3,383.4	104,900.0	354.9	0.44	0.2	0.7
08/30/2024 03:00	3,382.6	104.0	3,382.6	104,900.0	354.8	0.44	0.2	0.7
08/30/2024 04:00	3,391.3	104.2	3,391.3	104,900.0	355.7	0.44	0.2	0.7
08/30/2024 05:00	3,387.9	104.2	3,387.9	104,900.0	355.4	0.44	0.2	0.7
08/30/2024 06:00	3,395.6	105.7	3,395.6	104,900.0	356.2	0.44	0.2	0.7
08/30/2024 07:00	3,398.5	110.8	3,398.5	104,900.0	356.5	0.44	0.2	0.7
08/30/2024 08:00	3,392.7	110.8	3,392.7	104,900.0	355.9	0.44	0.2	0.7
08/30/2024 09:00	3,391.7	101.5	3,391.7	104,900.0	355.8	0.44	0.2	0.7
08/30/2024 10:00	3,391.7	97.5	3,391.7	104,900.0	355.8	0.44	0.2	0.7
08/30/2024 11:00	3,393.2	97.6	3,393.2	104,900.0	355.9	0.44	0.2	0.7
08/30/2024 12:00	3,392.6	101.2	3,392.6	104,900.0	355.9	0.44	0.2	0.7
08/30/2024 13:00	3,382.6	107.0	3,382.6	104,900.0	354.8	0.44	0.2	0.7
08/30/2024 14:00	3,382.9	93.5	3,382.9	104,900.0	354.9	0.44	0.2	0.7
08/30/2024 15:00	3,382.5	93.5	3,382.5	104,900.0	354.8	0.44	0.2	0.7
08/30/2024 16:00	3,445.7	92.3	3,445.7	104,900.0	361.5	0.45	0.2	0.7
08/30/2024 17:00	3,390.7	94.0	3,390.7	104,900.0	355.7	0.44	0.2	0.7
08/30/2024 18:00	3,390.0	99.9	3,390.0	104,900.0	355.6	0.44	0.2	0.7
08/30/2024 19:00	3,388.6	100.8	3,388.6	104,900.0	355.5	0.44	0.2	0.7
08/30/2024 20:00	3,383.2	102.3	3,383.2	104,900.0	354.9	0.44	0.2	0.7
08/30/2024 21:00	3,403.6	101.6	3,403.6	104,900.0	357.0	0.44	0.2	0.7
08/30/2024 22:00	3,381.5	101.9	3,381.5	104,900.0	354.7	0.44	0.2	0.7
08/30/2024 23:00	3,386.7	102.1	3,386.7	104,900.0	355.3	0.44	0.2	0.7
Average/Sum#:	3,391.1	101.5	3,391.1	104,900.0	355.7	0.44	0.2	0.7
Minimum:	3,381.5	92.3	3,381.5	104,900.0	354.7	0.44	0.2	0.7
Maximum:	3,445.7	110.8	3,445.7	104,900.0	361.5	0.45	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2024 00:00	3,393.0	102.7	3,393.0	104,900.0	355.9	0.44	0.2	0.7
08/31/2024 01:00	3,385.8	103.0	3,385.8	104,900.0	355.2	0.44	0.2	0.7
08/31/2024 02:00	3,387.2	102.5	3,387.2	104,900.0	355.3	0.44	0.2	0.7
08/31/2024 03:00	3,387.1	103.3	3,387.1	104,900.0	355.3	0.44	0.2	0.7
08/31/2024 04:00	3,384.4	104.2	3,384.4	104,900.0	355.0	0.44	0.2	0.7
08/31/2024 05:00	3,383.9	104.0	3,383.9	104,900.0	355.0	0.44	0.2	0.7
08/31/2024 06:00	3,391.9	105.1	3,391.9	104,900.0	355.8	0.44	0.2	0.7
08/31/2024 07:00	3,393.8	111.5	3,393.8	104,900.0	356.0	0.44	0.2	0.7
08/31/2024 08:00	3,388.6	110.7	3,388.6	104,900.0	355.5	0.44	0.2	0.7
08/31/2024 09:00	3,385.7	102.2	3,385.7	104,900.0	355.2	0.44	0.2	0.7
08/31/2024 10:00	3,387.1	98.4	3,387.1	104,900.0	355.3	0.44	0.2	0.7
08/31/2024 11:00	3,396.2	97.8	3,396.2	104,900.0	356.3	0.44	0.2	0.7
08/31/2024 12:00	3,397.2	101.2	3,397.2	104,900.0	356.4	0.44	0.2	0.7
08/31/2024 13:00	3,397.5	105.7	3,397.5	104,900.0	356.4	0.44	0.2	0.7
08/31/2024 14:00	3,401.1	98.5	3,401.1	104,900.0	356.8	0.44	0.2	0.7
08/31/2024 15:00	3,481.8	96.6	3,481.8	104,900.0	365.2	0.45	0.2	0.7
08/31/2024 16:00	3,916.4	267.2	3,991.2	104,900.0	418.7	0.53	0.3	0.9
08/31/2024 17:00	4,226.2	1,410.6	5,636.8	104,900.0	591.3	0.71	0.4	1.2
08/31/2024 18:00	4,259.8	1,331.1	5,590.9	104,900.0	586.5	0.70	0.4	1.2
08/31/2024 19:00	4,277.8	1,397.4	5,675.2	104,900.0	595.3	0.71	0.4	1.2
08/31/2024 20:00	4,254.7	698.6	4,834.5	104,900.0	507.1	0.62	0.3	1.0
08/31/2024 21:00	4,057.1	105.3	4,057.1	104,900.0	425.6	0.52	0.3	0.9
08/31/2024 22:00	4,075.6	104.2	4,075.6	104,900.0	427.5	0.53	0.3	0.9
08/31/2024 23:00	3,913.2	105.1	3,915.3	104,900.0	410.7	0.51	0.3	0.8
Average/Sum#:	3,638.5	294.5	3,838.3	104,900.0	402.6	0.50	0.2	0.8
Minimum:	3,383.9	96.6	3,383.9	104,900.0	355.0	0.44	0.2	0.7
Maximum:	4,277.8	1,410.6	5,675.2	104,900.0	595.3	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2024 00:00	3,421.9	103.6	3,421.9	105,505.0	361.0	0.44	0.2	0.7
09/01/2024 01:00	3,388.3	103.2	3,388.3	105,505.0	357.5	0.44	0.2	0.7
09/01/2024 02:00	3,388.0	103.5	3,388.0	105,505.0	357.5	0.44	0.2	0.7
09/01/2024 03:00	3,389.2	104.1	3,389.2	105,505.0	357.6	0.44	0.2	0.7
09/01/2024 04:00	3,388.6	104.4	3,388.6	105,505.0	357.5	0.44	0.2	0.7
09/01/2024 05:00	3,391.9	104.2	3,391.9	105,505.0	357.9	0.44	0.2	0.7
09/01/2024 06:00	3,402.4	106.9	3,402.4	105,505.0	359.0	0.44	0.2	0.7
09/01/2024 07:00	3,401.5	112.2	3,401.5	105,505.0	358.9	0.44	0.2	0.7
09/01/2024 08:00	3,393.7	110.5	3,393.7	105,505.0	358.1	0.44	0.2	0.7
09/01/2024 09:00	3,390.3	103.6	3,390.3	105,505.0	357.7	0.44	0.2	0.7
09/01/2024 10:00	3,385.9	99.6	3,385.9	105,505.0	357.2	0.44	0.2	0.7
09/01/2024 11:00	3,392.5	98.5	3,392.5	105,505.0	357.9	0.44	0.2	0.7
09/01/2024 12:00	3,391.1	101.0	3,391.1	105,505.0	357.8	0.44	0.2	0.7
09/01/2024 13:00	3,380.4	108.1	3,380.4	105,505.0	356.6	0.44	0.2	0.7
09/01/2024 14:00	3,379.0	100.5	3,379.0	105,505.0	356.5	0.44	0.2	0.7
09/01/2024 15:00	3,388.3	96.7	3,388.3	105,505.0	357.5	0.44	0.2	0.7
09/01/2024 16:00	3,537.8	96.5	3,537.8	105,505.0	373.3	0.46	0.2	0.8
09/01/2024 17:00	3,701.6	98.7	3,701.6	105,505.0	390.5	0.48	0.2	0.8
09/01/2024 18:00	3,410.7	102.3	3,410.7	105,505.0	359.8	0.44	0.2	0.7
09/01/2024 19:00	3,392.2	103.4	3,392.2	105,505.0	357.9	0.44	0.2	0.7
09/01/2024 20:00	3,393.6	103.4	3,393.6	105,505.0	358.0	0.44	0.2	0.7
09/01/2024 21:00	3,457.9	103.2	3,457.9	105,505.0	364.8	0.45	0.2	0.7
09/01/2024 22:00	3,427.4	103.6	3,427.4	105,505.0	361.6	0.44	0.2	0.7
09/01/2024 23:00	3,450.6	103.3	3,450.6	105,505.0	364.1	0.45	0.2	0.7
Average/Sum#:	3,418.5	103.1	3,418.5	105,505.0	360.7	0.44	0.2	0.7
Minimum:	3,379.0	96.5	3,379.0	105,505.0	356.5	0.44	0.2	0.7
Maximum:	3,701.6	112.2	3,701.6	105,505.0	390.5	0.48	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/02/2024 00:00	3,489.1	103.5	3,489.1	105,505.0	368.1	0.45	0.2	0.8
09/02/2024 01:00	3,396.4	104.7	3,396.4	105,505.0	358.3	0.44	0.2	0.7
09/02/2024 02:00	3,396.0	104.6	3,396.0	105,505.0	358.3	0.44	0.2	0.7
09/02/2024 03:00	3,396.5	104.1	3,396.5	105,505.0	358.3	0.44	0.2	0.7
09/02/2024 04:00	3,395.9	104.8	3,395.9	105,505.0	358.3	0.44	0.2	0.7
09/02/2024 05:00	3,397.0	104.8	3,397.0	105,505.0	358.4	0.44	0.2	0.7
09/02/2024 06:00	3,402.6	106.0	3,402.6	105,505.0	359.0	0.44	0.2	0.7
09/02/2024 07:00	3,401.0	114.2	3,401.0	105,505.0	358.8	0.44	0.2	0.7
09/02/2024 08:00	3,398.7	112.3	3,398.7	105,505.0	358.6	0.44	0.2	0.7
09/02/2024 09:00	3,400.1	104.3	3,400.1	105,505.0	358.7	0.44	0.2	0.7
09/02/2024 10:00	3,402.5	101.3	3,402.5	105,505.0	359.0	0.44	0.2	0.7
09/02/2024 11:00	3,415.2	99.6	3,415.2	105,505.0	360.3	0.44	0.2	0.7
09/02/2024 12:00	3,417.6	102.3	3,417.6	105,505.0	360.6	0.44	0.2	0.7
09/02/2024 13:00	3,409.0	111.7	3,409.0	105,505.0	359.7	0.44	0.2	0.7
09/02/2024 14:00	3,546.0	106.7	3,546.0	105,505.0	374.1	0.46	0.2	0.8
09/02/2024 15:00	3,456.1	100.7	3,456.1	105,505.0	364.6	0.45	0.2	0.7
09/02/2024 16:00	3,717.1	95.2	3,717.1	105,505.0	392.2	0.48	0.2	0.8
09/02/2024 17:00	3,783.3	96.1	3,783.3	105,505.0	399.2	0.49	0.2	0.8
09/02/2024 18:00	3,815.9	101.5	3,815.9	105,505.0	402.6	0.49	0.2	0.8
09/02/2024 19:00	3,539.1	101.4	3,539.1	105,505.0	373.4	0.46	0.2	0.8
09/02/2024 20:00	3,499.8	104.6	3,499.8	105,505.0	369.2	0.45	0.2	0.8
09/02/2024 21:00	3,377.1	104.5	3,377.1	105,505.0	356.3	0.44	0.2	0.7
09/02/2024 22:00	3,380.4	104.3	3,380.4	105,505.0	356.6	0.44	0.2	0.7
09/02/2024 23:00	3,380.5	104.7	3,380.5	105,505.0	356.7	0.44	0.2	0.7
Average/Sum#:	3,467.2	104.1	3,467.2	105,505.0	365.8	0.45	0.2	0.7
Minimum:	3,377.1	95.2	3,377.1	105,505.0	356.3	0.44	0.2	0.7
Maximum:	3,815.9	114.2	3,815.9	105,505.0	402.6	0.49	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2024 00:00	3,381.3	106.3	3,381.3	105,505.0	356.7	0.44	0.2	0.7
09/03/2024 01:00	3,382.0	105.8	3,382.0	105,505.0	356.8	0.44	0.2	0.7
09/03/2024 02:00	3,388.9	107.3	3,388.9	105,505.0	357.5	0.44	0.2	0.7
09/03/2024 03:00	3,385.6	106.5	3,385.6	105,505.0	357.2	0.44	0.2	0.7
09/03/2024 04:00	3,377.8	106.6	3,377.8	105,505.0	356.4	0.44	0.2	0.7
09/03/2024 05:00	3,624.4	107.4	3,624.4	105,505.0	382.4	0.47	0.2	0.8
09/03/2024 06:00	3,483.0	106.6	3,483.0	105,505.0	367.5	0.45	0.2	0.8
09/03/2024 07:00	3,559.2	113.4	3,559.2	105,505.0	375.5	0.46	0.2	0.8
09/03/2024 08:00	3,382.9	112.6	3,382.9	105,505.0	356.9	0.44	0.2	0.7
09/03/2024 09:00	3,373.4	101.8	3,373.4	105,505.0	355.9	0.44	0.2	0.7
09/03/2024 10:00	3,371.9	99.5	3,371.9	105,505.0	355.8	0.44	0.2	0.7
09/03/2024 11:00	3,387.1	98.6	3,387.1	105,505.0	357.4	0.44	0.2	0.7
09/03/2024 12:00	3,385.0	101.5	3,385.0	105,505.0	357.1	0.44	0.2	0.7
09/03/2024 13:00	3,738.6	106.4	3,738.6	105,505.0	394.4	0.49	0.2	0.8
09/03/2024 14:00	3,888.2	103.5	3,888.2	105,505.0	410.2	0.51	0.3	0.8
09/03/2024 15:00	3,790.0	96.0	3,790.0	105,505.0	399.9	0.49	0.2	0.8
09/03/2024 16:00	4,080.8	481.1	4,311.7	105,505.0	454.9	0.58	0.3	1.0
09/03/2024 17:00	4,217.4	1,439.5	5,656.9	105,505.0	596.8	0.72	0.4	1.2
09/03/2024 18:00	4,229.4	1,494.2	5,723.6	105,505.0	603.9	0.73	0.4	1.2
09/03/2024 19:00	4,230.2	756.0	4,948.4	105,505.0	522.1	0.63	0.3	1.1
09/03/2024 20:00	4,168.0	105.5	4,168.0	105,505.0	439.7	0.54	0.3	0.9
09/03/2024 21:00	4,176.5	101.9	4,176.5	105,505.0	440.6	0.54	0.3	0.9
09/03/2024 22:00	3,738.4	103.4	3,738.4	105,505.0	394.4	0.49	0.2	0.8
09/03/2024 23:00	4,104.1	103.1	4,104.1	105,505.0	433.0	0.53	0.3	0.9
Average/Sum#:	3,701.8	261.0	3,863.6	105,505.0	407.6	0.50	0.2	0.8
Minimum:	3,371.9	96.0	3,371.9	105,505.0	355.8	0.44	0.2	0.7
Maximum:	4,230.2	1,494.2	5,723.6	105,505.0	603.9	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2024 00:00	3,714.5	102.6	3,714.5	105,505.0	391.9	0.48	0.2	0.8
09/04/2024 01:00	3,706.8	103.7	3,706.8	105,505.0	391.1	0.48	0.2	0.8
09/04/2024 02:00	3,392.2	103.9	3,392.2	105,505.0	357.9	0.44	0.2	0.7
09/04/2024 03:00	3,880.8	101.8	3,880.8	105,505.0	409.4	0.51	0.3	0.8
09/04/2024 04:00	3,911.9	103.2	3,911.9	105,505.0	412.7	0.51	0.3	0.8
09/04/2024 05:00	4,124.4	103.2	4,124.4	105,505.0	435.1	0.54	0.3	0.9
09/04/2024 06:00	3,529.8	103.6	3,529.8	105,505.0	372.4	0.46	0.2	0.8
09/04/2024 07:00	3,385.6	108.3	3,385.6	105,505.0	357.2	0.44	0.2	0.7
09/04/2024 08:00	3,379.0	105.1	3,379.0	105,505.0	356.5	0.44	0.2	0.7
09/04/2024 09:00	3,375.8	101.4	3,375.8	105,505.0	356.2	0.44	0.2	0.7
09/04/2024 10:00	3,374.5	98.2	3,374.5	105,505.0	356.0	0.44	0.2	0.7
09/04/2024 11:00	3,382.0	97.4	3,382.0	105,505.0	356.8	0.44	0.2	0.7
09/04/2024 12:00	3,380.8	100.5	3,380.8	105,505.0	356.7	0.44	0.2	0.7
09/04/2024 13:00	3,679.5	105.5	3,679.5	105,505.0	388.2	0.48	0.2	0.8
09/04/2024 14:00	3,836.8	96.9	3,836.8	105,505.0	404.8	0.50	0.2	0.8
09/04/2024 15:00	3,415.1	90.5	3,415.1	105,505.0	360.3	0.44	0.2	0.7
09/04/2024 16:00	4,007.8	562.0	4,277.6	105,505.0	451.3	0.58	0.3	1.0
09/04/2024 17:00	4,186.5	1,700.5	5,887.0	105,505.0	621.1	0.74	0.4	1.2
09/04/2024 18:00	4,211.0	1,562.4	5,773.4	105,505.0	609.1	0.73	0.4	1.2
09/04/2024 19:00	4,234.9	1,424.1	5,659.0	105,505.0	597.1	0.72	0.4	1.2
09/04/2024 20:00	4,268.8	1,381.5	5,650.3	105,505.0	596.1	0.71	0.4	1.2
09/04/2024 21:00	4,264.5	1,340.1	5,604.6	105,505.0	591.3	0.71	0.4	1.2
09/04/2024 22:00	4,260.7	1,211.0	5,471.7	105,505.0	577.3	0.69	0.3	1.2
09/04/2024 23:00	4,239.7	685.9	4,774.7	105,505.0	503.8	0.63	0.3	1.0
Average/Sum#:	3,797.6	478.9	4,190.3	105,505.0	442.1	0.54	0.3	0.9
Minimum:	3,374.5	90.5	3,374.5	105,505.0	356.0	0.44	0.2	0.7
Maximum:	4,268.8	1,700.5	5,887.0	105,505.0	621.1	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2024 00:00	3,723.1	102.6	3,723.1	105,505.0	392.8	0.48	0.2	0.8
09/05/2024 01:00	3,466.9	102.4	3,466.9	105,505.0	365.8	0.45	0.2	0.8
09/05/2024 02:00	3,379.6	101.7	3,379.6	105,505.0	356.6	0.44	0.2	0.7
09/05/2024 03:00	3,378.8	102.0	3,378.8	105,505.0	356.5	0.44	0.2	0.7
09/05/2024 04:00	3,643.7	101.7	3,643.7	105,505.0	384.4	0.48	0.2	0.8
09/05/2024 05:00	4,047.0	103.0	4,047.0	105,505.0	427.0	0.53	0.3	0.9
09/05/2024 06:00	3,630.3	103.4	3,630.3	105,505.0	383.0	0.47	0.2	0.8
09/05/2024 07:00	3,386.0	111.9	3,386.0	105,505.0	357.2	0.44	0.2	0.7
09/05/2024 08:00	3,380.7	110.4	3,380.7	105,505.0	356.7	0.44	0.2	0.7
09/05/2024 09:00	3,481.2	101.3	3,481.2	105,505.0	367.3	0.45	0.2	0.8
09/05/2024 10:00	3,876.0	98.4	3,876.0	105,505.0	408.9	0.50	0.3	0.8
09/05/2024 11:00	3,597.0	99.3	3,597.0	105,505.0	379.5	0.47	0.2	0.8
09/05/2024 12:00	4,097.5	100.7	4,097.5	105,505.0	432.3	0.53	0.3	0.9
09/05/2024 13:00	4,138.6	568.8	4,411.6	105,505.0	465.4	0.60	0.3	1.0
09/05/2024 14:00	4,174.1	1,694.6	5,868.7	105,505.0	619.2	0.74	0.4	1.2
09/05/2024 15:00	4,175.5	1,398.2	5,573.7	105,505.0	588.1	0.71	0.4	1.2
09/05/2024 16:00	4,187.1	1,465.9	5,653.0	105,505.0	596.4	0.72	0.4	1.2
09/05/2024 17:00	4,193.4	1,623.6	5,817.0	105,505.0	613.7	0.74	0.4	1.2
09/05/2024 18:00	4,201.8	1,540.9	5,742.7	105,505.0	605.9	0.73	0.4	1.2
09/05/2024 19:00	4,237.7	1,410.5	5,648.2	105,505.0	595.9	0.71	0.4	1.2
09/05/2024 20:00	4,274.3	1,301.7	5,576.0	105,505.0	588.3	0.71	0.4	1.2
09/05/2024 21:00	4,269.4	1,225.3	5,494.7	105,505.0	579.7	0.70	0.3	1.2
09/05/2024 22:00	4,264.8	1,082.8	5,347.6	105,505.0	564.2	0.68	0.3	1.1
09/05/2024 23:00	4,275.3	855.5	5,130.8	105,505.0	541.3	0.65	0.3	1.1
Average/Sum#:	3,895.0	646.1	4,473.0	105,505.0	471.9	0.58	0.3	1.0
Minimum:	3,378.8	98.4	3,378.8	105,505.0	356.5	0.44	0.2	0.7
Maximum:	4,275.3	1,694.6	5,868.7	105,505.0	619.2	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2024 00:00	3,709.1	106.4	3,711.2	105,505.0	391.6	0.48	0.2	0.8
09/06/2024 01:00	3,372.5	105.0	3,372.5	105,505.0	355.8	0.44	0.2	0.7
09/06/2024 02:00	3,373.3	104.5	3,373.3	105,505.0	355.9	0.44	0.2	0.7
09/06/2024 03:00	3,372.9	103.8	3,372.9	105,505.0	355.9	0.44	0.2	0.7
09/06/2024 04:00	3,612.4	103.6	3,612.4	105,505.0	381.1	0.47	0.2	0.8
09/06/2024 05:00	4,028.9	104.0	4,028.9	105,505.0	425.1	0.52	0.3	0.9
09/06/2024 06:00	3,813.3	106.8	3,813.3	105,505.0	402.3	0.49	0.2	0.8
09/06/2024 07:00	3,720.9	115.0	3,720.9	105,505.0	392.6	0.49	0.2	0.8
09/06/2024 08:00	3,370.5	109.5	3,370.5	105,505.0	355.6	0.44	0.2	0.7
09/06/2024 09:00	3,372.4	100.9	3,372.4	105,505.0	355.8	0.44	0.2	0.7
09/06/2024 10:00	3,376.2	98.5	3,376.2	105,505.0	356.2	0.44	0.2	0.7
09/06/2024 11:00	3,510.9	100.0	3,510.9	105,505.0	370.4	0.46	0.2	0.8
09/06/2024 12:00	3,956.6	100.8	3,956.6	105,505.0	417.4	0.51	0.3	0.9
09/06/2024 13:00	4,139.1	633.1	4,474.6	105,505.0	472.1	0.60	0.3	1.0
09/06/2024 14:00	4,171.8	1,569.6	5,741.4	105,505.0	605.7	0.73	0.4	1.2
09/06/2024 15:00	4,162.9	1,681.9	5,844.8	105,505.0	616.7	0.74	0.4	1.2
09/06/2024 16:00	4,160.5	1,392.8	5,553.3	105,505.0	585.9	0.70	0.4	1.2
09/06/2024 17:00	4,163.1	1,674.7	5,837.8	105,505.0	615.9	0.74	0.4	1.2
09/06/2024 18:00	4,175.5	1,744.1	5,919.6	105,505.0	624.5	0.75	0.4	1.2
09/06/2024 19:00	4,205.5	1,407.1	5,612.6	105,505.0	592.2	0.71	0.4	1.2
09/06/2024 20:00	4,233.1	1,361.7	5,594.8	105,505.0	590.3	0.71	0.4	1.2
09/06/2024 21:00	4,222.5	1,469.2	5,691.7	105,505.0	600.5	0.72	0.4	1.2
09/06/2024 22:00	4,228.9	1,366.9	5,595.8	105,505.0	590.4	0.71	0.4	1.2
09/06/2024 23:00	4,241.1	1,424.2	5,665.3	105,505.0	597.7	0.72	0.4	1.2
Average/Sum#:	3,862.2	711.8	4,505.2	105,505.0	475.3	0.58	0.3	1.0
Minimum:	3,370.5	98.5	3,370.5	105,505.0	355.6	0.44	0.2	0.7
Maximum:	4,241.1	1,744.1	5,919.6	105,505.0	624.5	0.75	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2024 00:00	4,256.5	1,293.4	5,549.9	105,505.0	585.5	0.70	0.4	1.2
09/07/2024 01:00	4,225.5	628.6	4,728.4	105,505.0	498.9	0.62	0.3	1.0
09/07/2024 02:00	3,401.8	103.1	3,401.8	105,505.0	358.9	0.44	0.2	0.7
09/07/2024 03:00	3,424.5	103.7	3,424.5	105,505.0	361.3	0.45	0.2	0.7
09/07/2024 04:00	3,381.7	103.2	3,381.7	105,505.0	356.8	0.44	0.2	0.7
09/07/2024 05:00	3,368.3	102.2	3,368.3	105,505.0	355.4	0.44	0.2	0.7
09/07/2024 06:00	3,373.0	105.2	3,373.0	105,505.0	355.9	0.44	0.2	0.7
09/07/2024 07:00	3,376.1	112.6	3,376.1	105,505.0	356.2	0.44	0.2	0.7
09/07/2024 08:00	3,374.3	109.5	3,374.3	105,505.0	356.0	0.44	0.2	0.7
09/07/2024 09:00	3,374.3	99.8	3,374.3	105,505.0	356.0	0.44	0.2	0.7
09/07/2024 10:00	3,375.6	96.5	3,375.6	105,505.0	356.1	0.44	0.2	0.7
09/07/2024 11:00	3,382.1	97.1	3,382.1	105,505.0	356.8	0.44	0.2	0.7
09/07/2024 12:00	3,875.3	97.8	3,875.3	105,505.0	408.9	0.50	0.3	0.8
09/07/2024 13:00	4,161.6	107.7	4,164.8	105,505.0	439.4	0.54	0.3	0.9
09/07/2024 14:00	4,179.3	993.0	5,172.3	105,505.0	545.7	0.65	0.3	1.1
09/07/2024 15:00	4,188.7	963.5	5,152.2	105,505.0	543.6	0.65	0.3	1.1
09/07/2024 16:00	4,200.9	790.5	4,991.4	105,505.0	526.6	0.63	0.3	1.1
09/07/2024 17:00	4,219.1	1,371.1	5,590.2	105,505.0	589.8	0.71	0.4	1.2
09/07/2024 18:00	4,227.9	1,405.5	5,633.4	105,505.0	594.4	0.71	0.4	1.2
09/07/2024 19:00	4,221.2	1,295.3	5,516.5	105,505.0	582.0	0.70	0.3	1.2
09/07/2024 20:00	4,245.8	1,348.2	5,594.0	105,505.0	590.2	0.71	0.4	1.2
09/07/2024 21:00	4,259.9	1,318.9	5,578.8	105,505.0	588.6	0.71	0.4	1.2
09/07/2024 22:00	4,302.1	1,320.9	5,623.0	105,505.0	593.3	0.71	0.4	1.2
09/07/2024 23:00	4,303.0	1,008.6	5,311.6	105,505.0	560.4	0.67	0.3	1.1
Average/Sum#:	3,862.4	624.0	4,429.7	105,505.0	467.4	0.57	0.3	0.9
Minimum:	3,368.3	96.5	3,368.3	105,505.0	355.4	0.44	0.2	0.7
Maximum:	4,303.0	1,405.5	5,633.4	105,505.0	594.4	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2024 00:00	3,827.9	118.2	3,839.7	105,505.0	405.1	0.50	0.2	0.8
09/08/2024 01:00	3,389.7	106.1	3,389.7	105,505.0	357.6	0.44	0.2	0.7
09/08/2024 02:00	3,394.3	104.6	3,394.3	105,505.0	358.1	0.44	0.2	0.7
09/08/2024 03:00	3,397.0	105.1	3,397.0	105,505.0	358.4	0.44	0.2	0.7
09/08/2024 04:00	3,398.2	105.3	3,398.2	105,505.0	358.5	0.44	0.2	0.7
09/08/2024 05:00	3,396.7	106.4	3,396.7	105,505.0	358.4	0.44	0.2	0.7
09/08/2024 06:00	3,398.3	107.3	3,398.3	105,505.0	358.5	0.44	0.2	0.7
09/08/2024 07:00	3,390.5	115.7	3,390.5	105,505.0	357.7	0.44	0.2	0.7
09/08/2024 08:00	3,386.7	110.9	3,386.7	105,505.0	357.3	0.44	0.2	0.7
09/08/2024 09:00	3,378.4	103.6	3,378.4	105,505.0	356.4	0.44	0.2	0.7
09/08/2024 10:00	3,377.7	100.0	3,377.7	105,505.0	356.4	0.44	0.2	0.7
09/08/2024 11:00	3,385.6	99.6	3,385.6	105,505.0	357.2	0.44	0.2	0.7
09/08/2024 12:00	3,468.0	101.4	3,468.0	105,505.0	365.9	0.45	0.2	0.8
09/08/2024 13:00	3,961.1	263.5	4,034.9	105,505.0	425.7	0.54	0.3	0.9
09/08/2024 14:00	4,184.2	1,130.9	5,315.1	105,505.0	560.8	0.67	0.3	1.1
09/08/2024 15:00	4,184.4	1,332.4	5,516.8	105,505.0	582.0	0.70	0.3	1.2
09/08/2024 16:00	4,181.4	1,632.7	5,814.1	105,505.0	613.4	0.73	0.4	1.2
09/08/2024 17:00	4,191.2	1,717.9	5,909.1	105,505.0	623.4	0.75	0.4	1.2
09/08/2024 18:00	4,208.1	1,588.1	5,796.2	105,505.0	611.5	0.73	0.4	1.2
09/08/2024 19:00	4,245.3	1,485.3	5,730.6	105,505.0	604.6	0.72	0.4	1.2
09/08/2024 20:00	4,268.0	1,421.7	5,689.7	105,505.0	600.3	0.72	0.4	1.2
09/08/2024 21:00	4,193.1	709.4	4,725.2	105,505.0	498.5	0.62	0.3	1.0
09/08/2024 22:00	3,875.1	106.4	3,875.1	105,505.0	408.8	0.50	0.3	0.8
09/08/2024 23:00	3,603.0	104.8	3,603.0	105,505.0	380.1	0.47	0.2	0.8
Average/Sum#:	3,736.8	536.6	4,192.1	105,505.0	442.3	0.54	0.3	0.9
Minimum:	3,377.7	99.6	3,377.7	105,505.0	356.4	0.44	0.2	0.7
Maximum:	4,268.0	1,717.9	5,909.1	105,505.0	623.4	0.75	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2024 00:00	3,397.4	106.2	3,397.4	105,505.0	358.4	0.44	0.2	0.7
09/09/2024 01:00	3,390.3	104.6	3,390.3	105,505.0	357.7	0.44	0.2	0.7
09/09/2024 02:00	3,390.4	104.1	3,390.4	105,505.0	357.7	0.44	0.2	0.7
09/09/2024 03:00	3,387.2	102.5	3,387.2	105,505.0	357.4	0.44	0.2	0.7
09/09/2024 04:00	3,604.2	105.5	3,604.2	105,505.0	380.3	0.47	0.2	0.8
09/09/2024 05:00	3,975.9	104.7	3,975.9	105,505.0	419.5	0.52	0.3	0.9
09/09/2024 06:00	3,497.8	104.1	3,497.8	105,505.0	369.0	0.46	0.2	0.8
09/09/2024 07:00	3,413.2	110.1	3,413.2	105,505.0	360.1	0.45	0.2	0.7
09/09/2024 08:00	3,405.0	107.2	3,405.0	105,505.0	359.2	0.44	0.2	0.7
09/09/2024 09:00	3,384.6	99.7	3,384.6	105,505.0	357.1	0.44	0.2	0.7
09/09/2024 10:00	3,391.6	99.6	3,391.6	105,505.0	357.8	0.44	0.2	0.7
09/09/2024 11:00	3,391.7	99.2	3,391.7	105,505.0	357.8	0.44	0.2	0.7
09/09/2024 12:00	3,549.7	99.5	3,549.7	105,505.0	374.5	0.46	0.2	0.8
09/09/2024 13:00	3,532.8	105.9	3,532.8	105,505.0	372.7	0.46	0.2	0.8
09/09/2024 14:00	3,375.8	99.2	3,375.8	105,505.0	356.2	0.44	0.2	0.7
09/09/2024 15:00	3,582.3	98.5	3,582.3	105,505.0	378.0	0.47	0.2	0.8
09/09/2024 16:00	3,861.1	94.6	3,861.1	105,505.0	407.4	0.50	0.3	0.8
09/09/2024 17:00	4,012.7	530.2	4,261.9	105,505.0	449.7	0.58	0.3	1.0
09/09/2024 18:00	4,220.2	1,147.7	5,367.9	105,505.0	566.3	0.68	0.3	1.1
09/09/2024 19:00	4,014.5	418.5	4,244.7	105,505.0	447.8	0.56	0.3	0.9
09/09/2024 20:00	3,536.1	106.6	3,536.1	105,505.0	373.1	0.46	0.2	0.8
09/09/2024 21:00	3,468.4	102.0	3,468.4	105,505.0	365.9	0.45	0.2	0.8
09/09/2024 22:00	3,383.1	104.1	3,383.1	105,505.0	356.9	0.44	0.2	0.7
09/09/2024 23:00	3,803.8	104.9	3,803.8	105,505.0	401.3	0.49	0.2	0.8
Average/Sum#:	3,582.1	177.5	3,649.9	105,505.0	385.1	0.48	0.2	0.8
Minimum:	3,375.8	94.6	3,375.8	105,505.0	356.2	0.44	0.2	0.7
Maximum:	4,220.2	1,147.7	5,367.9	105,505.0	566.3	0.68	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2024 00:00	3,517.5	105.2	3,517.5	105,505.0	371.1	0.46	0.2	0.8
09/10/2024 01:00	3,382.8	105.2	3,382.8	105,505.0	356.9	0.44	0.2	0.7
09/10/2024 02:00	3,384.1	104.7	3,384.1	105,505.0	357.0	0.44	0.2	0.7
09/10/2024 03:00	3,383.5	106.0	3,383.5	105,505.0	357.0	0.44	0.2	0.7
09/10/2024 04:00	3,385.1	106.1	3,385.1	105,505.0	357.1	0.44	0.2	0.7
09/10/2024 05:00	3,725.5	106.0	3,725.5	105,505.0	393.1	0.48	0.2	0.8
09/10/2024 06:00	3,462.1	107.8	3,462.1	105,505.0	365.3	0.45	0.2	0.8
09/10/2024 07:00	3,393.0	114.0	3,393.0	105,505.0	358.0	0.44	0.2	0.7
09/10/2024 08:00	3,388.0	112.6	3,388.0	105,505.0	357.5	0.44	0.2	0.7
09/10/2024 09:00	3,385.5	105.2	3,385.5	105,505.0	357.2	0.44	0.2	0.7
09/10/2024 10:00	3,384.7	102.8	3,384.7	105,505.0	357.1	0.44	0.2	0.7
09/10/2024 11:00	3,385.8	101.8	3,385.8	105,505.0	357.2	0.44	0.2	0.7
09/10/2024 12:00	3,383.3	103.3	3,383.3	105,505.0	357.0	0.44	0.2	0.7
09/10/2024 13:00	3,378.0	114.0	3,378.0	105,505.0	356.4	0.44	0.2	0.7
09/10/2024 14:00	3,384.9	109.5	3,384.9	105,505.0	357.1	0.44	0.2	0.7
09/10/2024 15:00	3,382.3	104.5	3,382.3	105,505.0	356.8	0.44	0.2	0.7
09/10/2024 16:00	3,376.2	103.5	3,376.2	105,505.0	356.2	0.44	0.2	0.7
09/10/2024 17:00	3,371.2	106.4	3,371.2	105,505.0	355.7	0.44	0.2	0.7
09/10/2024 18:00	3,371.5	109.2	3,371.5	105,505.0	355.7	0.44	0.2	0.7
09/10/2024 19:00	3,372.6	109.3	3,372.6	105,505.0	355.8	0.44	0.2	0.7
09/10/2024 20:00	3,372.1	108.9	3,372.1	105,505.0	355.8	0.44	0.2	0.7
09/10/2024 21:00	3,371.9	109.8	3,371.9	105,505.0	355.8	0.44	0.2	0.7
09/10/2024 22:00	3,370.7	109.0	3,370.7	105,505.0	355.6	0.44	0.2	0.7
09/10/2024 23:00	3,375.1	108.8	3,375.1	105,505.0	356.1	0.44	0.2	0.7
Average/Sum#:	3,403.6	107.2	3,403.6	105,505.0	359.1	0.44	0.2	0.7
Minimum:	3,370.7	101.8	3,370.7	105,505.0	355.6	0.44	0.2	0.7
Maximum:	3,725.5	114.0	3,725.5	105,505.0	393.1	0.48	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2024 00:00	3,375.9	108.3	3,375.9	105,505.0	356.2	0.44	0.2	0.7
09/11/2024 01:00	3,374.7	108.2	3,374.7	105,505.0	356.0	0.44	0.2	0.7
09/11/2024 02:00	3,372.7	107.7	3,372.7	105,505.0	355.8	0.44	0.2	0.7
09/11/2024 03:00	3,372.1	108.5	3,372.1	105,505.0	355.8	0.44	0.2	0.7
09/11/2024 04:00	3,372.6	108.6	3,372.6	105,505.0	355.8	0.44	0.2	0.7
09/11/2024 05:00	3,656.1	109.9	3,656.1	105,505.0	385.7	0.48	0.2	0.8
09/11/2024 06:00	3,502.3	108.8	3,502.3	105,505.0	369.5	0.46	0.2	0.8
09/11/2024 07:00	3,374.3	115.9	3,374.3	105,505.0	356.0	0.44	0.2	0.7
09/11/2024 08:00	3,376.5	112.3	3,376.5	105,505.0	356.2	0.44	0.2	0.7
09/11/2024 09:00	3,376.1	105.9	3,376.1	105,505.0	356.2	0.44	0.2	0.7
09/11/2024 10:00	3,382.4	103.2	3,382.4	105,505.0	356.9	0.44	0.2	0.7
09/11/2024 11:00	3,391.6	102.8	3,391.6	105,505.0	357.8	0.44	0.2	0.7
09/11/2024 12:00	3,386.5	104.4	3,386.5	105,505.0	357.3	0.44	0.2	0.7
09/11/2024 13:00	3,371.5	112.7	3,371.5	105,505.0	355.7	0.44	0.2	0.7
09/11/2024 14:00	3,367.1	109.4	3,367.1	105,505.0	355.2	0.44	0.2	0.7
09/11/2024 15:00	3,366.2	103.5	3,366.2	105,505.0	355.2	0.44	0.2	0.7
09/11/2024 16:00	3,368.0	102.9	3,368.0	105,505.0	355.3	0.44	0.2	0.7
09/11/2024 17:00	3,362.8	103.6	3,362.8	105,505.0	354.8	0.44	0.2	0.7
09/11/2024 18:00	3,364.2	106.3	3,364.2	105,505.0	354.9	0.44	0.2	0.7
09/11/2024 19:00	3,367.7	106.9	3,367.7	105,505.0	355.3	0.44	0.2	0.7
09/11/2024 20:00	3,369.8	108.4	3,369.8	105,505.0	355.5	0.44	0.2	0.7
09/11/2024 21:00	3,371.4	108.8	3,371.4	105,505.0	355.7	0.44	0.2	0.7
09/11/2024 22:00	3,368.9	109.0	3,368.9	105,505.0	355.4	0.44	0.2	0.7
09/11/2024 23:00	3,369.7	109.4	3,369.7	105,505.0	355.5	0.44	0.2	0.7
Average/Sum#:	3,390.0	107.7	3,390.0	105,505.0	357.7	0.44	0.2	0.7
Minimum:	3,362.8	102.8	3,362.8	105,505.0	354.8	0.44	0.2	0.7
Maximum:	3,656.1	115.9	3,656.1	105,505.0	385.7	0.48	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/12/2024 00:00	3,371.3	109.7	3,371.3	105,505.0	355.7	0.44	0.2	0.7
09/12/2024 01:00	3,369.6	110.4	3,369.6	105,505.0	355.5	0.44	0.2	0.7
09/12/2024 02:00	3,373.4	109.4	3,373.4	105,505.0	355.9	0.44	0.2	0.7
09/12/2024 03:00	3,377.2	111.4	3,377.2	105,505.0	356.3	0.44	0.2	0.7
09/12/2024 04:00	3,375.0	112.5	3,375.0	105,505.0	356.1	0.44	0.2	0.7
09/12/2024 05:00	3,375.5	112.5	3,375.5	105,505.0	356.1	0.44	0.2	0.7
09/12/2024 06:00	3,384.3	111.2	3,384.3	105,505.0	357.1	0.44	0.2	0.7
09/12/2024 07:00	3,383.6	117.4	3,383.6	105,505.0	357.0	0.44	0.2	0.7
09/12/2024 08:00	3,386.3	113.4	3,386.3	105,505.0	357.3	0.44	0.2	0.7
09/12/2024 09:00	3,384.4	107.1	3,384.4	105,505.0	357.1	0.44	0.2	0.7
09/12/2024 10:00	3,388.0	103.7	3,388.0	105,505.0	357.5	0.44	0.2	0.7
09/12/2024 11:00	3,380.0	103.4	3,380.0	105,505.0	356.6	0.44	0.2	0.7
09/12/2024 12:00	3,381.7	103.8	3,381.7	105,505.0	356.8	0.44	0.2	0.7
09/12/2024 13:00	3,369.4	109.2	3,369.4	105,505.0	355.5	0.44	0.2	0.7
09/12/2024 14:00	3,370.0	106.6	3,370.0	105,505.0	355.6	0.44	0.2	0.7
09/12/2024 15:00	3,370.1	98.9	3,370.1	105,505.0	355.6	0.44	0.2	0.7
09/12/2024 16:00	3,369.7	99.6	3,369.7	105,505.0	355.5	0.44	0.2	0.7
09/12/2024 17:00	3,366.0	99.5	3,366.0	105,505.0	355.1	0.44	0.2	0.7
09/12/2024 18:00	3,367.0	104.0	3,367.0	105,505.0	355.2	0.44	0.2	0.7
09/12/2024 19:00	3,369.6	105.5	3,369.6	105,505.0	355.5	0.44	0.2	0.7
09/12/2024 20:00	3,366.4	108.8	3,366.4	105,505.0	355.2	0.44	0.2	0.7
09/12/2024 21:00	3,370.6	107.9	3,370.6	105,505.0	355.6	0.44	0.2	0.7
09/12/2024 22:00	3,369.3	107.4	3,369.3	105,505.0	355.5	0.44	0.2	0.7
09/12/2024 23:00	3,385.8	106.4	3,385.8	105,505.0	357.2	0.44	0.2	0.7
Average/Sum#:	3,375.2	107.5	3,375.2	105,505.0	356.1	0.44	0.2	0.7
Minimum:	3,366.0	98.9	3,366.0	105,505.0	355.1	0.44	0.2	0.7
Maximum:	3,388.0	117.4	3,388.0	105,505.0	357.5	0.44	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2024 00:00	3,372.1	104.8	3,372.1	105,505.0	355.8	0.44	0.2	0.7
09/13/2024 01:00	3,373.1	105.9	3,373.1	105,505.0	355.9	0.44	0.2	0.7
09/13/2024 02:00	3,370.3	107.0	3,370.3	105,505.0	355.6	0.44	0.2	0.7
09/13/2024 03:00	3,368.4	108.0	3,368.4	105,505.0	355.4	0.44	0.2	0.7
09/13/2024 04:00	3,425.4	106.7	3,425.4	105,505.0	361.4	0.45	0.2	0.7
09/13/2024 05:00	3,906.4	107.8	3,906.4	105,505.0	412.1	0.51	0.3	0.8
09/13/2024 06:00	3,680.7	108.7	3,680.7	105,505.0	388.3	0.48	0.2	0.8
09/13/2024 07:00	3,384.8	114.7	3,384.8	105,505.0	357.1	0.44	0.2	0.7
09/13/2024 08:00	3,379.6	112.4	3,379.6	105,505.0	356.6	0.44	0.2	0.7
09/13/2024 09:00	3,370.4	104.9	3,370.4	105,505.0	355.6	0.44	0.2	0.7
09/13/2024 10:00	3,372.3	103.0	3,372.3	105,505.0	355.8	0.44	0.2	0.7
09/13/2024 11:00	3,403.5	102.1	3,403.5	105,505.0	359.1	0.44	0.2	0.7
09/13/2024 12:00	3,514.3	103.2	3,514.3	105,505.0	370.8	0.46	0.2	0.8
09/13/2024 13:00	3,832.6	108.5	3,832.6	105,505.0	404.4	0.50	0.2	0.8
09/13/2024 14:00	3,885.5	102.7	3,885.5	105,505.0	409.9	0.51	0.3	0.8
09/13/2024 15:00	3,846.3	101.0	3,846.3	105,505.0	405.8	0.50	0.2	0.8
09/13/2024 16:00	4,153.5	208.9	4,201.5	105,505.0	443.3	0.55	0.3	0.9
09/13/2024 17:00	4,228.0	1,753.1	5,981.1	105,505.0	631.0	0.76	0.4	1.3
09/13/2024 18:00	4,246.1	1,560.9	5,807.0	105,505.0	612.7	0.74	0.4	1.2
09/13/2024 19:00	3,842.3	223.5	3,909.4	105,505.0	412.5	0.51	0.3	0.9
09/13/2024 20:00	3,414.3	108.3	3,414.3	105,505.0	360.2	0.44	0.2	0.7
09/13/2024 21:00	3,373.1	107.7	3,373.1	105,505.0	355.9	0.44	0.2	0.7
09/13/2024 22:00	3,441.0	102.8	3,441.0	105,505.0	363.0	0.45	0.2	0.7
09/13/2024 23:00	3,680.2	104.8	3,680.2	105,505.0	388.3	0.48	0.2	0.8
Average/Sum#:	3,619.3	244.6	3,762.2	105,505.0	396.9	0.49	0.2	0.8
Minimum:	3,368.4	101.0	3,368.4	105,505.0	355.4	0.44	0.2	0.7
Maximum:	4,246.1	1,753.1	5,981.1	105,505.0	631.0	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2024 00:00	3,708.7	105.4	3,708.7	105,505.0	391.3	0.48	0.2	0.8
09/14/2024 01:00	3,414.0	105.6	3,414.0	105,505.0	360.2	0.45	0.2	0.7
09/14/2024 02:00	3,369.5	106.0	3,369.5	105,505.0	355.5	0.44	0.2	0.7
09/14/2024 03:00	3,996.4	106.5	3,996.4	105,505.0	421.6	0.52	0.3	0.9
09/14/2024 04:00	3,958.4	109.7	3,958.4	105,505.0	417.6	0.51	0.3	0.9
09/14/2024 05:00	4,252.1	108.0	4,252.1	105,505.0	448.6	0.55	0.3	0.9
09/14/2024 06:00	3,563.3	107.1	3,563.3	105,505.0	375.9	0.46	0.2	0.8
09/14/2024 07:00	3,376.4	116.0	3,376.4	105,505.0	356.2	0.44	0.2	0.7
09/14/2024 08:00	3,369.1	108.1	3,369.1	105,505.0	355.5	0.44	0.2	0.7
09/14/2024 09:00	3,368.1	101.1	3,368.1	105,505.0	355.4	0.44	0.2	0.7
09/14/2024 10:00	3,372.6	98.8	3,372.6	105,505.0	355.8	0.44	0.2	0.7
09/14/2024 11:00	3,391.5	98.3	3,391.5	105,505.0	357.8	0.44	0.2	0.7
09/14/2024 12:00	3,398.3	99.2	3,398.3	105,505.0	358.5	0.44	0.2	0.7
09/14/2024 13:00	3,392.0	105.9	3,392.0	105,505.0	357.9	0.44	0.2	0.7
09/14/2024 14:00	3,395.5	100.9	3,395.5	105,505.0	358.2	0.44	0.2	0.7
09/14/2024 15:00	3,382.4	100.8	3,382.4	105,505.0	356.9	0.44	0.2	0.7
09/14/2024 16:00	3,574.7	99.3	3,574.7	105,505.0	377.1	0.46	0.2	0.8
09/14/2024 17:00	3,959.7	100.2	3,959.7	105,505.0	417.8	0.51	0.3	0.9
09/14/2024 18:00	3,809.4	105.0	3,809.4	105,505.0	401.9	0.49	0.2	0.8
09/14/2024 19:00	3,369.9	106.1	3,369.9	105,505.0	355.5	0.44	0.2	0.7
09/14/2024 20:00	3,360.9	105.2	3,360.9	105,505.0	354.6	0.44	0.2	0.7
09/14/2024 21:00	3,362.8	106.2	3,362.8	105,505.0	354.8	0.44	0.2	0.7
09/14/2024 22:00	3,364.9	105.4	3,364.9	105,505.0	355.0	0.44	0.2	0.7
09/14/2024 23:00	3,384.2	106.1	3,384.2	105,505.0	357.1	0.44	0.2	0.7
Average/Sum#:	3,537.3	104.6	3,537.3	105,505.0	373.2	0.46	0.2	0.8
Minimum:	3,360.9	98.3	3,360.9	105,505.0	354.6	0.44	0.2	0.7
Maximum:	4,252.1	116.0	4,252.1	105,505.0	448.6	0.55	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2024 00:00	3,384.3	106.3	3,384.3	105,505.0	357.1	0.44	0.2	0.7
09/15/2024 01:00	3,386.0	106.0	3,386.0	105,505.0	357.2	0.44	0.2	0.7
09/15/2024 02:00	3,386.0	106.4	3,386.0	105,505.0	357.2	0.44	0.2	0.7
09/15/2024 03:00	3,384.2	106.6	3,384.2	105,505.0	357.1	0.44	0.2	0.7
09/15/2024 04:00	3,385.2	107.3	3,385.2	105,505.0	357.2	0.44	0.2	0.7
09/15/2024 05:00	3,387.1	106.9	3,387.1	105,505.0	357.4	0.44	0.2	0.7
09/15/2024 06:00	3,387.4	108.1	3,387.4	105,505.0	357.4	0.44	0.2	0.7
09/15/2024 07:00	3,389.0	113.7	3,389.0	105,505.0	357.6	0.44	0.2	0.7
09/15/2024 08:00	3,385.0	108.1	3,385.0	105,505.0	357.1	0.44	0.2	0.7
09/15/2024 09:00	3,384.8	102.6	3,384.8	105,505.0	357.1	0.44	0.2	0.7
09/15/2024 10:00	3,375.9	102.3	3,375.9	105,505.0	356.2	0.44	0.2	0.7
09/15/2024 11:00	3,382.1	101.0	3,382.1	105,505.0	356.8	0.44	0.2	0.7
09/15/2024 12:00	3,374.7	103.9	3,374.7	105,505.0	356.0	0.44	0.2	0.7
09/15/2024 13:00	3,364.3	110.4	3,364.3	105,505.0	355.0	0.44	0.2	0.7
09/15/2024 14:00	3,366.0	104.0	3,366.0	105,505.0	355.1	0.44	0.2	0.7
09/15/2024 15:00	3,367.0	102.6	3,367.0	105,505.0	355.2	0.44	0.2	0.7
09/15/2024 16:00	3,603.1	102.8	3,603.1	105,505.0	380.1	0.47	0.2	0.8
09/15/2024 17:00	3,374.6	105.9	3,374.6	105,505.0	356.0	0.44	0.2	0.7
09/15/2024 18:00	3,364.5	107.2	3,364.5	105,505.0	355.0	0.44	0.2	0.7
09/15/2024 19:00	3,365.3	106.7	3,365.3	105,505.0	355.1	0.44	0.2	0.7
09/15/2024 20:00	3,366.6	107.3	3,366.6	105,505.0	355.2	0.44	0.2	0.7
09/15/2024 21:00	3,367.6	107.3	3,367.6	105,505.0	355.3	0.44	0.2	0.7
09/15/2024 22:00	3,371.3	106.9	3,371.3	105,505.0	355.7	0.44	0.2	0.7
09/15/2024 23:00	3,372.3	107.0	3,372.3	105,505.0	355.8	0.44	0.2	0.7
Average/Sum#:	3,386.4	106.1	3,386.4	105,505.0	357.3	0.44	0.2	0.7
Minimum:	3,364.3	101.0	3,364.3	105,505.0	355.0	0.44	0.2	0.7
Maximum:	3,603.1	113.7	3,603.1	105,505.0	380.1	0.47	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2024 00:00	3,374.4	106.7	3,374.4	105,505.0	356.0	0.44	0.2	0.7
09/16/2024 01:00	3,375.3	110.0	3,375.3	105,505.0	356.1	0.44	0.2	0.7
09/16/2024 02:00	3,376.1	110.1	3,376.1	105,505.0	356.2	0.44	0.2	0.7
09/16/2024 03:00	3,374.2	110.0	3,374.2	105,505.0	356.0	0.44	0.2	0.7
09/16/2024 04:00	3,372.6	108.1	3,372.6	105,505.0	355.8	0.44	0.2	0.7
09/16/2024 05:00	3,705.5	107.9	3,705.5	105,505.0	390.9	0.48	0.2	0.8
09/16/2024 06:00	3,694.0	106.7	3,694.0	105,505.0	389.7	0.48	0.2	0.8
09/16/2024 07:00	4,087.1	103.5	4,087.1	105,505.0	431.2	0.53	0.3	0.9
09/16/2024 08:00	4,286.0	186.2	4,360.5	105,505.0	460.1	0.56	0.3	0.9
09/16/2024 09:00	4,253.1	112.2	4,264.3	105,505.0	449.9	0.55	0.3	0.9
09/16/2024 10:00	4,251.5	101.3	4,251.5	105,505.0	448.6	0.55	0.3	0.9
09/16/2024 11:00	4,251.7	98.9	4,251.7	105,505.0	448.6	0.55	0.3	0.9
09/16/2024 12:00	3,793.0	103.2	3,793.0	105,505.0	400.2	0.49	0.2	0.8
09/16/2024 13:00	3,376.0	108.2	3,376.0	105,505.0	356.2	0.44	0.2	0.7
09/16/2024 14:00	3,370.8	104.5	3,370.8	105,505.0	355.6	0.44	0.2	0.7
09/16/2024 15:00	3,373.3	100.8	3,373.3	105,505.0	355.9	0.44	0.2	0.7
09/16/2024 16:00	3,615.8	101.6	3,615.8	105,505.0	381.5	0.47	0.2	0.8
09/16/2024 17:00	3,417.6	102.8	3,417.6	105,505.0	360.6	0.45	0.2	0.7
09/16/2024 18:00	3,396.6	105.9	3,396.6	105,505.0	358.4	0.44	0.2	0.7
09/16/2024 19:00	3,398.9	108.6	3,398.9	105,505.0	358.6	0.44	0.2	0.7
09/16/2024 20:00	3,977.0	105.4	3,977.0	105,505.0	419.6	0.52	0.3	0.9
09/16/2024 21:00	3,775.3	105.5	3,775.3	105,505.0	398.3	0.49	0.2	0.8
09/16/2024 22:00	3,942.9	106.6	3,942.9	105,505.0	416.0	0.51	0.3	0.9
09/16/2024 23:00	3,475.4	105.5	3,475.4	105,505.0	366.7	0.45	0.2	0.8
Average/Sum#:	3,679.8	109.2	3,683.3	105,505.0	388.6	0.48	0.2	0.8
Minimum:	3,370.8	98.9	3,370.8	105,505.0	355.6	0.44	0.2	0.7
Maximum:	4,286.0	186.2	4,360.5	105,505.0	460.1	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2024 00:00	3,372.7	104.4	3,372.7	105,505.0	355.8	0.44	0.2	0.7
09/17/2024 01:00	3,377.6	105.5	3,377.6	105,505.0	356.4	0.44	0.2	0.7
09/17/2024 02:00	3,376.1	106.8	3,376.1	105,505.0	356.2	0.44	0.2	0.7
09/17/2024 03:00	3,381.1	106.6	3,381.1	105,505.0	356.7	0.44	0.2	0.7
09/17/2024 04:00	3,563.3	107.8	3,563.3	105,505.0	375.9	0.46	0.2	0.8
09/17/2024 05:00	3,971.7	107.7	3,971.7	105,505.0	419.0	0.52	0.3	0.9
09/17/2024 06:00	3,564.1	108.7	3,564.1	105,505.0	376.0	0.46	0.2	0.8
09/17/2024 07:00	3,396.6	108.9	3,396.6	105,505.0	358.4	0.44	0.2	0.7
09/17/2024 08:00	3,401.6	104.9	3,401.6	105,505.0	358.9	0.44	0.2	0.7
09/17/2024 09:00	3,411.3	102.9	3,411.3	105,505.0	359.9	0.45	0.2	0.7
09/17/2024 10:00	3,395.5	102.0	3,395.5	105,505.0	358.2	0.44	0.2	0.7
09/17/2024 11:00	3,408.6	101.8	3,408.6	105,505.0	359.6	0.44	0.2	0.7
09/17/2024 12:00	3,410.9	102.0	3,410.9	105,505.0	359.9	0.44	0.2	0.7
09/17/2024 13:00	3,407.1	108.7	3,407.1	105,505.0	359.5	0.45	0.2	0.7
09/17/2024 14:00	3,409.2	103.7	3,409.2	105,505.0	359.7	0.44	0.2	0.7
09/17/2024 15:00	3,409.7	102.2	3,409.7	105,505.0	359.7	0.44	0.2	0.7
09/17/2024 16:00	3,406.8	102.6	3,406.8	105,505.0	359.4	0.44	0.2	0.7
09/17/2024 17:00	3,388.2	101.7	3,388.2	105,505.0	357.5	0.44	0.2	0.7
09/17/2024 18:00	3,381.4	104.7	3,381.4	105,505.0	356.8	0.44	0.2	0.7
09/17/2024 19:00	3,385.3	104.1	3,385.3	105,505.0	357.2	0.44	0.2	0.7
09/17/2024 20:00	3,401.3	106.9	3,401.3	105,505.0	358.9	0.44	0.2	0.7
09/17/2024 21:00	3,407.7	104.5	3,407.7	105,505.0	359.5	0.44	0.2	0.7
09/17/2024 22:00	3,405.3	108.5	3,405.3	105,505.0	359.3	0.44	0.2	0.7
09/17/2024 23:00	3,389.9	107.5	3,389.9	105,505.0	357.7	0.44	0.2	0.7
Average/Sum#:	3,434.3	105.2	3,434.3	105,505.0	362.3	0.45	0.2	0.7
Minimum:	3,372.7	101.7	3,372.7	105,505.0	355.8	0.44	0.2	0.7
Maximum:	3,971.7	108.9	3,971.7	105,505.0	419.0	0.52	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/18/2024 00:00	3,388.8	107.2	3,388.8	105,505.0	357.5	0.44	0.2	0.7
09/18/2024 01:00	3,391.0	106.5	3,391.0	105,505.0	357.8	0.44	0.2	0.7
09/18/2024 02:00	3,380.2	107.0	3,380.2	105,505.0	356.6	0.44	0.2	0.7
09/18/2024 03:00	3,376.9	107.3	3,376.9	105,505.0	356.3	0.44	0.2	0.7
09/18/2024 04:00	3,378.8	106.9	3,378.8	105,505.0	356.5	0.44	0.2	0.7
09/18/2024 05:00	3,419.3	107.5	3,419.3	105,505.0	360.8	0.45	0.2	0.7
09/18/2024 06:00	3,607.9	106.0	3,607.9	105,505.0	380.7	0.47	0.2	0.8
09/18/2024 07:00	3,383.3	103.5	3,383.3	105,505.0	357.0	0.44	0.2	0.7
09/18/2024 08:00	3,383.6	102.3	3,383.6	105,505.0	357.0	0.44	0.2	0.7
09/18/2024 09:00	3,393.6	103.2	3,393.6	105,505.0	358.0	0.44	0.2	0.7
09/18/2024 10:00	3,394.4	102.6	3,394.4	105,505.0	358.1	0.44	0.2	0.7
09/18/2024 11:00	3,399.7	100.2	3,399.7	105,505.0	358.7	0.44	0.2	0.7
09/18/2024 12:00	3,395.9	100.6	3,395.9	105,505.0	358.3	0.44	0.2	0.7
09/18/2024 13:00	3,395.0	104.5	3,395.0	105,505.0	358.2	0.44	0.2	0.7
09/18/2024 14:00	3,392.8	102.5	3,392.8	105,505.0	358.0	0.44	0.2	0.7
09/18/2024 15:00	3,385.6	100.8	3,385.6	105,505.0	357.2	0.44	0.2	0.7
09/18/2024 16:00	3,753.5	100.8	3,753.5	105,505.0	396.0	0.49	0.2	0.8
09/18/2024 17:00	3,785.6	100.2	3,785.6	105,505.0	399.4	0.49	0.2	0.8
09/18/2024 18:00	3,380.3	104.2	3,380.3	105,505.0	356.6	0.44	0.2	0.7
09/18/2024 19:00	3,383.9	104.0	3,383.9	105,505.0	357.0	0.44	0.2	0.7
09/18/2024 20:00	4,217.2	107.9	4,217.2	105,505.0	444.9	0.55	0.3	0.9
09/18/2024 21:00	4,250.5	107.0	4,250.5	105,505.0	448.4	0.55	0.3	0.9
09/18/2024 22:00	4,249.5	107.9	4,249.5	105,505.0	448.3	0.55	0.3	0.9
09/18/2024 23:00	4,224.1	107.5	4,224.1	105,505.0	445.7	0.55	0.3	0.9
Average/Sum#:	3,571.3	104.5	3,571.3	105,505.0	376.8	0.46	0.2	0.7
Minimum:	3,376.9	100.2	3,376.9	105,505.0	356.3	0.44	0.2	0.7
Maximum:	4,250.5	107.9	4,250.5	105,505.0	448.4	0.55	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/19/2024 00:00	4,246.7	107.5	4,246.7	105,505.0	448.0	0.55	0.3	0.9
09/19/2024 01:00	4,165.8	107.1	4,165.8	105,505.0	439.5	0.54	0.3	0.9
09/19/2024 02:00	4,062.8	109.2	4,062.8	105,505.0	428.6	0.53	0.3	0.9
09/19/2024 03:00	4,232.3	108.4	4,232.3	105,505.0	446.5	0.55	0.3	0.9
09/19/2024 04:00	4,244.5	106.7	4,244.5	105,505.0	447.8	0.55	0.3	0.9
09/19/2024 05:00	4,222.7	109.6	4,222.7	105,505.0	445.5	0.55	0.3	0.9
09/19/2024 06:00	3,687.7	105.8	3,687.7	105,505.0	389.1	0.48	0.2	0.8
09/19/2024 07:00	4,139.4	105.5	4,139.4	105,505.0	436.7	0.54	0.3	0.9
09/19/2024 08:00	3,529.8	102.0	3,529.8	105,505.0	372.4	0.46	0.2	0.8
09/19/2024 09:00	3,367.5	100.5	3,367.5	105,505.0	355.3	0.44	0.2	0.7
09/19/2024 10:00	3,370.6	101.0	3,370.6	105,505.0	355.6	0.44	0.2	0.7
09/19/2024 11:00	3,364.9	99.6	3,364.9	105,505.0	355.0	0.44	0.2	0.7
09/19/2024 12:00	3,374.2	100.1	3,374.2	105,505.0	356.0	0.44	0.2	0.7
09/19/2024 13:00	3,357.3	107.1	3,357.3	105,505.0	354.2	0.44	0.2	0.7
09/19/2024 14:00	3,356.0	107.1	3,356.0	105,505.0	354.1	0.44	0.2	0.7
09/19/2024 15:00	3,362.3	99.8	3,362.3	105,505.0	354.7	0.44	0.2	0.7
09/19/2024 16:00	3,726.0	97.4	3,726.0	105,505.0	393.1	0.49	0.2	0.8
09/19/2024 17:00	4,203.4	210.9	4,251.9	105,505.0	448.6	0.56	0.3	0.9
09/19/2024 18:00	4,252.7	1,183.4	5,436.1	105,505.0	573.5	0.69	0.3	1.1
09/19/2024 19:00	4,258.4	715.4	4,952.3	105,505.0	522.5	0.63	0.3	1.0
09/19/2024 20:00	4,238.7	105.6	4,238.7	105,505.0	447.2	0.55	0.3	0.9
09/19/2024 21:00	4,150.0	105.7	4,150.0	105,505.0	437.8	0.54	0.3	0.9
09/19/2024 22:00	3,403.4	106.7	3,403.4	105,505.0	359.1	0.45	0.2	0.7
09/19/2024 23:00	3,390.0	106.8	3,390.0	105,505.0	357.7	0.44	0.2	0.7
Average/Sum#:	3,821.1	179.5	3,901.4	105,505.0	411.6	0.51	0.3	0.8
Minimum:	3,356.0	97.4	3,356.0	105,505.0	354.1	0.44	0.2	0.7
Maximum:	4,258.4	1,183.4	5,436.1	105,505.0	573.5	0.69	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2024 00:00	3,342.3	107.0	3,342.3	105,505.0	352.6	0.44	0.2	0.7
09/20/2024 01:00	3,336.2	107.4	3,336.2	105,505.0	352.0	0.44	0.2	0.7
09/20/2024 02:00	3,344.1	105.4	3,344.1	105,505.0	352.8	0.44	0.2	0.7
09/20/2024 03:00	3,332.1	109.7	3,332.1	105,505.0	351.6	0.44	0.2	0.7
09/20/2024 04:00	3,403.5	109.6	3,403.5	105,505.0	359.1	0.45	0.2	0.7
09/20/2024 05:00	3,595.6	110.0	3,595.6	105,505.0	379.4	0.47	0.2	0.8
09/20/2024 06:00	3,460.2	68.7	3,460.2	105,505.0	365.1	0.45	0.2	0.7
09/20/2024 07:00	3,344.4	3.2	3,344.4	105,505.0	352.9	0.42	0.2	0.7
09/20/2024 08:00	3,333.9	0.0	3,333.9	105,505.0	351.7	0.42	0.2	0.7
09/20/2024 09:00	3,360.1	0.0	3,360.1	105,505.0	354.5	0.43	0.2	0.7
09/20/2024 10:00	3,582.9	0.0	3,582.9	105,505.0	378.0	0.45	0.2	0.8
09/20/2024 11:00	4,134.0	0.0	4,134.0	105,505.0	436.2	0.52	0.3	0.9
09/20/2024 12:00	4,151.2	1.6	4,151.2	105,505.0	438.0	0.52	0.3	0.9
09/20/2024 13:00	3,767.4	7.0	3,767.4	105,505.0	397.5	0.48	0.2	0.8
09/20/2024 14:00	3,706.4	7.5	3,706.4	105,505.0	391.0	0.47	0.2	0.8
09/20/2024 15:00	3,338.9	0.0	3,338.9	105,505.0	352.3	0.42	0.2	0.7
09/20/2024 16:00	3,518.9	0.0	3,518.9	105,505.0	371.3	0.44	0.2	0.7
09/20/2024 17:00	3,588.7	0.0	3,588.7	105,505.0	378.6	0.46	0.2	0.8
09/20/2024 18:00	3,335.0	0.0	3,335.0	105,505.0	351.9	0.42	0.2	0.7
09/20/2024 19:00	3,329.1	0.0	3,329.1	105,505.0	351.2	0.42	0.2	0.7
09/20/2024 20:00	3,330.7	0.0	3,330.7	105,505.0	351.4	0.42	0.2	0.7
09/20/2024 21:00	3,333.2	0.1	3,333.2	105,505.0	351.7	0.42	0.2	0.7
09/20/2024 22:00	3,326.2	0.1	3,326.2	105,505.0	350.9	0.42	0.2	0.7
09/20/2024 23:00	3,329.0	0.0	3,329.0	105,505.0	351.2	0.42	0.2	0.7
Average/Sum#:	3,484.3	30.7	3,484.3	105,505.0	367.6	0.45	0.2	0.7
Minimum:	3,326.2	0.0	3,326.2	105,505.0	350.9	0.42	0.2	0.7
Maximum:	4,151.2	110.0	4,151.2	105,505.0	438.0	0.52	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/21/2024 00:00	3,329.6	0.1	3,329.6	105,505.0	351.3	0.42	0.2	0.7
09/21/2024 01:00	3,327.2	0.2	3,327.2	105,505.0	351.0	0.42	0.2	0.7
09/21/2024 02:00	3,336.4	0.1	3,336.4	105,505.0	352.0	0.42	0.2	0.7
09/21/2024 03:00	3,545.1	0.0	3,545.1	105,505.0	374.0	0.45	0.2	0.7
09/21/2024 04:00	3,755.1	0.0	3,755.1	105,505.0	396.2	0.47	0.2	0.8
09/21/2024 05:00	3,399.7	0.0	3,399.7	105,505.0	358.7	0.43	0.2	0.7
09/21/2024 06:00	3,583.8	0.3	3,583.8	105,505.0	378.1	0.45	0.2	0.8
09/21/2024 07:00	3,349.0	5.5	3,349.0	105,505.0	353.3	0.42	0.2	0.7
09/21/2024 08:00	3,348.2	0.0	3,348.2	105,505.0	353.3	0.42	0.2	0.7
09/21/2024 09:00	3,344.3	0.0	3,344.3	105,505.0	352.8	0.42	0.2	0.7
09/21/2024 10:00	3,348.8	0.0	3,348.8	105,505.0	353.3	0.42	0.2	0.7
09/21/2024 11:00	3,657.0	0.0	3,657.0	105,505.0	385.8	0.46	0.2	0.8
09/21/2024 12:00	3,886.5	2.7	3,886.5	105,505.0	410.0	0.49	0.2	0.8
09/21/2024 13:00	4,167.6	7.4	4,167.6	105,505.0	439.7	0.53	0.3	0.9
09/21/2024 14:00	4,127.0	8.1	4,127.0	105,505.0	435.4	0.52	0.3	0.9
09/21/2024 15:00	3,633.9	0.0	3,633.9	105,505.0	383.4	0.46	0.2	0.8
09/21/2024 16:00	4,155.0	909.2	5,036.9	105,505.0	531.4	0.64	0.3	1.1
09/21/2024 17:00	4,163.9	1,402.4	5,566.3	105,505.0	587.3	0.70	0.4	1.2
09/21/2024 18:00	4,174.2	830.1	5,004.3	105,505.0	528.0	0.63	0.3	1.1
09/21/2024 19:00	4,175.4	461.2	4,535.1	105,505.0	478.5	0.59	0.3	1.0
09/21/2024 20:00	3,516.8	0.0	3,516.8	105,505.0	371.0	0.44	0.2	0.7
09/21/2024 21:00	3,437.3	0.3	3,437.3	105,505.0	362.7	0.44	0.2	0.7
09/21/2024 22:00	3,404.0	0.0	3,404.0	105,505.0	359.1	0.43	0.2	0.7
09/21/2024 23:00	3,338.2	0.0	3,338.2	105,505.0	352.2	0.42	0.2	0.7
Average/Sum#:	3,646.0	151.2	3,790.8	105,505.0	399.9	0.48	0.2	0.8
Minimum:	3,327.2	0.0	3,327.2	105,505.0	351.0	0.42	0.2	0.7
Maximum:	4,175.4	1,402.4	5,566.3	105,505.0	587.3	0.70	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/22/2024 00:00	3,336.5	0.0	3,336.5	105,505.0	352.0	0.42	0.2	0.7
09/22/2024 01:00	3,332.1	0.0	3,332.1	105,505.0	351.6	0.42	0.2	0.7
09/22/2024 02:00	3,335.3	0.0	3,335.3	105,505.0	351.9	0.42	0.2	0.7
09/22/2024 03:00	3,344.3	0.0	3,344.3	105,505.0	352.8	0.42	0.2	0.7
09/22/2024 04:00	3,334.7	0.1	3,334.7	105,505.0	351.8	0.42	0.2	0.7
09/22/2024 05:00	3,329.6	0.2	3,329.6	105,505.0	351.3	0.42	0.2	0.7
09/22/2024 06:00	3,341.8	0.2	3,341.8	105,505.0	352.6	0.42	0.2	0.7
09/22/2024 07:00	3,346.2	8.2	3,346.2	105,505.0	353.0	0.42	0.2	0.7
09/22/2024 08:00	3,339.0	0.0	3,339.0	105,505.0	352.3	0.42	0.2	0.7
09/22/2024 09:00	3,350.7	0.0	3,350.7	105,505.0	353.5	0.42	0.2	0.7
09/22/2024 10:00	3,355.2	0.0	3,355.2	105,505.0	354.0	0.42	0.2	0.7
09/22/2024 11:00	3,355.4	0.0	3,355.4	105,505.0	354.0	0.42	0.2	0.7
09/22/2024 12:00	3,350.2	0.0	3,350.2	105,505.0	353.5	0.42	0.2	0.7
09/22/2024 13:00	4,056.1	6.0	4,056.1	105,505.0	427.9	0.51	0.3	0.9
09/22/2024 14:00	3,680.6	3.4	3,680.6	105,505.0	388.3	0.47	0.2	0.8
09/22/2024 15:00	3,353.8	0.0	3,353.8	105,505.0	353.8	0.42	0.2	0.7
09/22/2024 16:00	3,635.6	0.0	3,635.6	105,505.0	383.6	0.46	0.2	0.8
09/22/2024 17:00	3,356.5	0.0	3,356.5	105,505.0	354.1	0.42	0.2	0.7
09/22/2024 18:00	3,338.5	0.3	3,338.5	105,505.0	352.2	0.42	0.2	0.7
09/22/2024 19:00	3,332.6	0.9	3,332.6	105,505.0	351.6	0.42	0.2	0.7
09/22/2024 20:00	3,311.5	0.0	3,311.5	105,505.0	349.4	0.42	0.2	0.7
09/22/2024 21:00	3,318.9	0.3	3,318.9	105,505.0	350.2	0.42	0.2	0.7
09/22/2024 22:00	3,327.2	0.0	3,327.2	105,505.0	351.0	0.42	0.2	0.7
09/22/2024 23:00	3,341.9	0.2	3,341.9	105,505.0	352.6	0.42	0.2	0.7
Average/Sum#:	3,396.0	0.8	3,396.0	105,505.0	358.3	0.43	0.2	0.7
Minimum:	3,311.5	0.0	3,311.5	105,505.0	349.4	0.42	0.2	0.7
Maximum:	4,056.1	8.2	4,056.1	105,505.0	427.9	0.51	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2024 00:00	3,334.7	0.1	3,334.7	105,505.0	351.8	0.42	0.2	0.7
09/23/2024 01:00	3,340.1	0.1	3,340.1	105,505.0	352.4	0.42	0.2	0.7
09/23/2024 02:00	3,335.8	0.0	3,335.8	105,505.0	351.9	0.42	0.2	0.7
09/23/2024 03:00	3,343.5	1.0	3,343.5	105,505.0	352.8	0.42	0.2	0.7
09/23/2024 04:00	3,338.8	0.1	3,338.8	105,505.0	352.3	0.42	0.2	0.7
09/23/2024 05:00	3,329.9	0.0	3,329.9	105,505.0	351.3	0.42	0.2	0.7
09/23/2024 06:00	3,354.2	0.0	3,354.2	105,505.0	353.9	0.42	0.2	0.7
09/23/2024 07:00	3,333.4	1.0	3,333.4	105,505.0	351.7	0.42	0.2	0.7
09/23/2024 08:00	3,328.1	0.1	3,328.1	105,505.0	351.1	0.42	0.2	0.7
09/23/2024 09:00	3,334.6	0.0	3,334.6	105,505.0	351.8	0.42	0.2	0.7
09/23/2024 10:00	3,345.9	0.0	3,345.9	105,505.0	353.0	0.42	0.2	0.7
09/23/2024 11:00	3,346.3	0.0	3,346.3	105,505.0	353.1	0.42	0.2	0.7
09/23/2024 12:00	3,402.2	1.0	3,402.2	105,505.0	358.9	0.43	0.2	0.7
09/23/2024 13:00	3,628.8	6.6	3,628.8	105,505.0	382.9	0.46	0.2	0.8
09/23/2024 14:00	3,676.0	1.4	3,676.0	105,505.0	387.8	0.46	0.2	0.8
09/23/2024 15:00	3,723.0	29.3	3,728.0	105,505.0	393.3	0.47	0.2	0.8
09/23/2024 16:00	4,084.9	610.8	4,585.8	105,505.0	483.8	0.59	0.3	1.0
09/23/2024 17:00	4,097.2	1,399.4	5,496.6	105,505.0	579.9	0.70	0.3	1.2
09/23/2024 18:00	4,108.8	1,117.4	5,226.2	105,505.0	551.4	0.66	0.3	1.1
09/23/2024 19:00	4,125.0	762.6	4,719.8	105,505.0	498.0	0.62	0.3	1.0
09/23/2024 20:00	4,105.5	0.1	4,105.5	105,505.0	433.2	0.52	0.3	0.9
09/23/2024 21:00	4,094.9	0.0	4,094.9	105,505.0	432.0	0.52	0.3	0.9
09/23/2024 22:00	4,035.2	0.0	4,035.2	105,505.0	425.7	0.51	0.3	0.9
09/23/2024 23:00	3,852.9	0.0	3,852.9	105,505.0	406.5	0.49	0.2	0.8
Average/Sum#:	3,625.0	163.8	3,775.7	105,505.0	398.4	0.48	0.2	0.8
Minimum:	3,328.1	0.0	3,328.1	105,505.0	351.1	0.42	0.2	0.7
Maximum:	4,125.0	1,399.4	5,496.6	105,505.0	579.9	0.70	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2024 00:00	3,822.1	0.4	3,822.1	105,505.0	403.3	0.48	0.2	0.8
09/24/2024 01:00	3,377.9	0.0	3,377.9	105,505.0	356.4	0.43	0.2	0.7
09/24/2024 02:00	3,337.2	0.0	3,337.2	105,505.0	352.1	0.42	0.2	0.7
09/24/2024 03:00	3,487.7	0.0	3,487.7	105,505.0	368.0	0.44	0.2	0.7
09/24/2024 04:00	3,951.6	0.0	3,951.6	105,505.0	416.9	0.50	0.3	0.8
09/24/2024 05:00	4,098.7	1.0	4,098.7	105,505.0	432.4	0.52	0.3	0.9
09/24/2024 06:00	3,543.9	0.1	3,543.9	105,505.0	373.9	0.45	0.2	0.7
09/24/2024 07:00	3,323.3	0.9	3,323.3	105,505.0	350.6	0.42	0.2	0.7
09/24/2024 08:00	3,306.2	0.3	3,306.2	105,505.0	348.8	0.42	0.2	0.7
09/24/2024 09:00	3,324.5	0.0	3,324.5	105,505.0	350.8	0.42	0.2	0.7
09/24/2024 10:00	3,340.1	0.0	3,340.1	105,505.0	352.4	0.42	0.2	0.7
09/24/2024 11:00	3,338.7	0.0	3,338.7	105,505.0	352.2	0.42	0.2	0.7
09/24/2024 12:00	3,643.2	0.1	3,643.2	105,505.0	384.4	0.46	0.2	0.8
09/24/2024 13:00	3,906.5	4.6	3,906.5	105,505.0	412.2	0.49	0.2	0.8
09/24/2024 14:00	3,932.2	4.1	3,932.2	105,505.0	414.9	0.50	0.2	0.8
09/24/2024 15:00	3,556.2	0.0	3,556.2	105,505.0	375.2	0.45	0.2	0.8
09/24/2024 16:00	3,765.4	254.4	3,841.7	105,505.0	405.3	0.51	0.3	0.8
09/24/2024 17:00	4,083.3	908.2	4,991.5	105,505.0	526.6	0.63	0.3	1.1
09/24/2024 18:00	3,910.5	389.3	4,116.8	105,505.0	434.3	0.54	0.3	0.9
09/24/2024 19:00	3,332.1	1.5	3,332.1	105,505.0	351.6	0.42	0.2	0.7
09/24/2024 20:00	3,336.1	0.0	3,336.1	105,505.0	352.0	0.42	0.2	0.7
09/24/2024 21:00	3,340.9	0.0	3,340.9	105,505.0	352.5	0.42	0.2	0.7
09/24/2024 22:00	3,326.5	0.0	3,326.5	105,505.0	351.0	0.42	0.2	0.7
09/24/2024 23:00	3,329.2	0.0	3,329.2	105,505.0	351.2	0.42	0.2	0.7
Average/Sum#:	3,571.4	65.2	3,621.0	105,505.0	382.0	0.46	0.2	0.8
Minimum:	3,306.2	0.0	3,306.2	105,505.0	348.8	0.42	0.2	0.7
Maximum:	4,098.7	908.2	4,991.5	105,505.0	526.6	0.63	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/25/2024 00:00	3,344.5	0.0	3,344.5	105,505.0	352.9	0.42	0.2	0.7
09/25/2024 01:00	3,339.9	0.0	3,339.9	105,505.0	352.4	0.42	0.2	0.7
09/25/2024 02:00	3,347.7	0.0	3,347.7	105,505.0	353.2	0.42	0.2	0.7
09/25/2024 03:00	3,353.9	0.1	3,353.9	105,505.0	353.9	0.42	0.2	0.7
09/25/2024 04:00	3,490.9	0.0	3,490.9	105,505.0	368.3	0.44	0.2	0.7
09/25/2024 05:00	3,738.2	0.0	3,738.2	105,505.0	394.4	0.47	0.2	0.8
09/25/2024 06:00	3,463.7	0.0	3,463.7	105,505.0	365.4	0.44	0.2	0.7
09/25/2024 07:00	3,329.9	17.2	3,329.9	105,505.0	351.3	0.42	0.2	0.7
09/25/2024 08:00	3,830.5	0.1	3,830.5	105,505.0	404.1	0.49	0.2	0.8
09/25/2024 09:00	3,465.1	0.0	3,465.1	105,505.0	365.6	0.44	0.2	0.7
09/25/2024 10:00	3,352.8	0.0	3,352.8	105,505.0	353.7	0.43	0.2	0.7
09/25/2024 11:00	3,320.7	0.0	3,320.7	105,505.0	350.4	0.42	0.2	0.7
09/25/2024 12:00	3,307.7	0.0	3,307.7	105,505.0	349.0	0.42	0.2	0.7
09/25/2024 13:00	3,320.6	6.1	3,320.6	105,505.0	350.3	0.42	0.2	0.7
09/25/2024 14:00	3,312.8	12.2	3,312.8	105,505.0	349.5	0.42	0.2	0.7
09/25/2024 15:00	3,317.7	0.0	3,317.7	105,505.0	350.0	0.42	0.2	0.7
09/25/2024 16:00	3,490.0	0.1	3,490.0	105,505.0	368.2	0.44	0.2	0.7
09/25/2024 17:00	3,356.2	0.4	3,356.2	105,505.0	354.1	0.42	0.2	0.7
09/25/2024 18:00	3,338.6	1.1	3,338.6	105,505.0	352.2	0.42	0.2	0.7
09/25/2024 19:00	3,333.2	2.1	3,333.2	105,505.0	351.7	0.42	0.2	0.7
09/25/2024 20:00	3,335.0	0.5	3,335.0	105,505.0	351.9	0.42	0.2	0.7
09/25/2024 21:00	3,328.7	1.4	3,328.7	105,505.0	351.2	0.42	0.2	0.7
09/25/2024 22:00	3,326.6	2.0	3,326.6	105,505.0	351.0	0.42	0.2	0.7
09/25/2024 23:00	3,326.2	0.5	3,326.2	105,505.0	350.9	0.42	0.2	0.7
Average/Sum#:	3,394.6	1.8	3,394.6	105,505.0	358.2	0.43	0.2	0.7
Minimum:	3,307.7	0.0	3,307.7	105,505.0	349.0	0.42	0.2	0.7
Maximum:	3,830.5	17.2	3,830.5	105,505.0	404.1	0.49	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/26/2024 00:00	3,324.7	0.2	3,324.7	105,505.0	350.8	0.42	0.2	0.7
09/26/2024 01:00	3,325.1	1.0	3,325.1	105,505.0	350.8	0.42	0.2	0.7
09/26/2024 02:00	3,324.8	1.1	3,324.8	105,505.0	350.8	0.42	0.2	0.7
09/26/2024 03:00	3,324.7	3.2	3,324.7	105,505.0	350.8	0.42	0.2	0.7
09/26/2024 04:00	3,322.1	3.6	3,322.1	105,505.0	350.5	0.42	0.2	0.7
09/26/2024 05:00	3,323.6	8.1	3,323.6	105,505.0	350.7	0.42	0.2	0.7
09/26/2024 06:00	3,326.2	4.5	3,326.2	105,505.0	350.9	0.42	0.2	0.7
09/26/2024 07:00	3,331.5	0.4	3,331.5	105,505.0	351.5	0.42	0.2	0.7
09/26/2024 08:00	3,331.1	0.9	3,331.1	105,505.0	351.4	0.42	0.2	0.7
09/26/2024 09:00	3,327.7	0.1	3,327.7	105,505.0	351.1	0.42	0.2	0.7
09/26/2024 10:00	3,325.3	0.0	3,325.3	105,505.0	350.8	0.42	0.2	0.7
09/26/2024 11:00	3,328.4	0.0	3,328.4	105,505.0	351.2	0.42	0.2	0.7
09/26/2024 12:00	3,339.3	0.0	3,339.3	105,505.0	352.3	0.42	0.2	0.7
09/26/2024 13:00	3,349.5	5.6	3,349.5	105,505.0	353.4	0.42	0.2	0.7
09/26/2024 14:00	3,342.2	12.1	3,342.2	105,505.0	352.6	0.42	0.2	0.7
09/26/2024 15:00	3,335.5	0.1	3,335.5	105,505.0	351.9	0.42	0.2	0.7
09/26/2024 16:00	3,847.1	181.9	3,898.0	105,505.0	411.3	0.51	0.3	0.8
09/26/2024 17:00	4,192.3	883.8	5,076.1	105,505.0	535.6	0.64	0.3	1.1
09/26/2024 18:00	4,222.5	867.8	5,090.3	105,505.0	537.1	0.65	0.3	1.1
09/26/2024 19:00	4,239.1	775.7	5,014.8	105,505.0	529.1	0.64	0.3	1.1
09/26/2024 20:00	4,254.1	847.2	5,101.3	105,505.0	538.2	0.65	0.3	1.1
09/26/2024 21:00	4,076.3	285.1	4,227.4	105,505.0	446.0	0.55	0.3	0.9
09/26/2024 22:00	3,654.4	4.8	3,654.4	105,505.0	385.6	0.46	0.2	0.8
09/26/2024 23:00	3,378.7	3.3	3,378.7	105,505.0	356.5	0.43	0.2	0.7
Average/Sum#:	3,547.8	162.1	3,696.8	105,505.0	390.0	0.47	0.2	0.8
Minimum:	3,322.1	0.0	3,322.1	105,505.0	350.5	0.42	0.2	0.7
Maximum:	4,254.1	883.8	5,101.3	105,505.0	538.2	0.65	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/27/2024 00:00	3,320.3	1.1	3,320.3	105,505.0	350.3	0.42	0.2	0.7
09/27/2024 01:00	3,324.5	3.3	3,324.5	105,505.0	350.8	0.42	0.2	0.7
09/27/2024 02:00	3,324.6	1.2	3,324.6	105,505.0	350.8	0.42	0.2	0.7
09/27/2024 03:00	3,329.5	6.0	3,329.5	105,505.0	351.3	0.42	0.2	0.7
09/27/2024 04:00	3,772.9	7.8	3,772.9	105,505.0	398.1	0.48	0.2	0.8
09/27/2024 05:00	3,966.3	9.5	3,966.3	105,505.0	418.5	0.50	0.3	0.8
09/27/2024 06:00	3,605.1	4.5	3,605.1	105,505.0	380.4	0.46	0.2	0.8
09/27/2024 07:00	3,325.2	1.6	3,325.2	105,505.0	350.8	0.42	0.2	0.7
09/27/2024 08:00	3,326.2	0.0	3,326.2	105,505.0	350.9	0.42	0.2	0.7
09/27/2024 09:00	3,325.1	0.0	3,325.1	105,505.0	350.8	0.42	0.2	0.7
09/27/2024 10:00	3,326.7	0.0	3,326.7	105,505.0	351.0	0.42	0.2	0.7
09/27/2024 11:00	3,330.9	0.0	3,330.9	105,505.0	351.4	0.42	0.2	0.7
09/27/2024 12:00	3,316.5	0.0	3,316.5	105,505.0	349.9	0.42	0.2	0.7
09/27/2024 13:00	3,311.3	6.4	3,311.3	105,505.0	349.4	0.42	0.2	0.7
09/27/2024 14:00	3,309.5	7.6	3,309.5	105,505.0	349.2	0.42	0.2	0.7
09/27/2024 15:00	3,340.0	0.0	3,340.0	105,505.0	352.4	0.42	0.2	0.7
09/27/2024 16:00	3,823.7	211.4	3,918.8	105,505.0	413.5	0.51	0.3	0.9
09/27/2024 17:00	4,159.6	675.8	4,835.4	105,505.0	510.2	0.61	0.3	1.0
09/27/2024 18:00	4,168.9	647.0	4,815.9	105,505.0	508.1	0.61	0.3	1.0
09/27/2024 19:00	4,181.8	451.8	4,534.2	105,505.0	478.4	0.59	0.3	1.0
09/27/2024 20:00	4,095.4	0.0	4,095.4	105,505.0	432.1	0.52	0.3	0.9
09/27/2024 21:00	3,948.3	0.0	3,948.3	105,505.0	416.6	0.50	0.2	0.8
09/27/2024 22:00	3,927.8	0.0	3,927.8	105,505.0	414.4	0.50	0.2	0.8
09/27/2024 23:00	4,178.5	0.0	4,178.5	105,505.0	440.9	0.53	0.3	0.9
Average/Sum#:	3,626.6	84.8	3,700.4	105,505.0	390.4	0.47	0.2	0.8
Minimum:	3,309.5	0.0	3,309.5	105,505.0	349.2	0.42	0.2	0.7
Maximum:	4,181.8	675.8	4,835.4	105,505.0	510.2	0.61	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/28/2024 00:00	4,033.4	0.0	4,033.4	105,505.0	425.5	0.51	0.3	0.9
09/28/2024 01:00	3,566.0	0.0	3,566.0	105,505.0	376.2	0.45	0.2	0.8
09/28/2024 02:00	3,311.4	0.1	3,311.4	105,505.0	349.4	0.42	0.2	0.7
09/28/2024 03:00	3,319.6	2.5	3,319.6	105,505.0	350.2	0.42	0.2	0.7
09/28/2024 04:00	3,327.1	0.1	3,327.1	105,505.0	351.0	0.42	0.2	0.7
09/28/2024 05:00	3,339.4	1.5	3,339.4	105,505.0	352.3	0.42	0.2	0.7
09/28/2024 06:00	3,328.8	3.9	3,328.8	105,505.0	351.2	0.42	0.2	0.7
09/28/2024 07:00	3,313.7	0.1	3,313.7	105,505.0	349.6	0.42	0.2	0.7
09/28/2024 08:00	3,311.8	0.0	3,311.8	105,505.0	349.4	0.42	0.2	0.7
09/28/2024 09:00	3,307.0	0.0	3,307.0	105,505.0	348.9	0.42	0.2	0.7
09/28/2024 10:00	3,306.7	0.0	3,306.7	105,505.0	348.9	0.42	0.2	0.7
09/28/2024 11:00	3,309.9	0.0	3,309.9	105,505.0	349.2	0.42	0.2	0.7
09/28/2024 12:00	3,316.5	0.0	3,316.5	105,505.0	349.9	0.42	0.2	0.7
09/28/2024 13:00	3,340.5	10.0	3,340.5	105,505.0	352.4	0.42	0.2	0.7
09/28/2024 14:00	3,505.0	10.6	3,505.0	105,505.0	369.8	0.45	0.2	0.7
09/28/2024 15:00	3,594.8	0.0	3,594.8	105,505.0	379.3	0.45	0.2	0.8
09/28/2024 16:00	3,793.7	229.4	3,901.5	105,505.0	411.6	0.51	0.3	0.8
09/28/2024 17:00	4,159.5	663.1	4,822.6	105,505.0	508.8	0.61	0.3	1.0
09/28/2024 18:00	4,192.0	606.1	4,798.1	105,505.0	506.2	0.61	0.3	1.0
09/28/2024 19:00	4,173.8	430.7	4,509.7	105,505.0	475.8	0.58	0.3	1.0
09/28/2024 20:00	3,339.0	0.0	3,339.0	105,505.0	352.3	0.42	0.2	0.7
09/28/2024 21:00	3,311.8	0.0	3,311.8	105,505.0	349.4	0.42	0.2	0.7
09/28/2024 22:00	3,312.2	0.0	3,312.2	105,505.0	349.5	0.42	0.2	0.7
09/28/2024 23:00	3,316.7	0.0	3,316.7	105,505.0	349.9	0.42	0.2	0.7
Average/Sum#:	3,505.4	81.6	3,576.8	105,505.0	377.4	0.45	0.2	0.8
Minimum:	3,306.7	0.0	3,306.7	105,505.0	348.9	0.42	0.2	0.7
Maximum:	4,192.0	663.1	4,822.6	105,505.0	508.8	0.61	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/29/2024 00:00	3,317.8	0.0	3,317.8	105,505.0	350.0	0.42	0.2	0.7
09/29/2024 01:00	3,317.3	0.0	3,317.3	105,505.0	350.0	0.42	0.2	0.7
09/29/2024 02:00	3,320.5	0.0	3,320.5	105,505.0	350.3	0.42	0.2	0.7
09/29/2024 03:00	3,321.9	0.0	3,321.9	105,505.0	350.5	0.42	0.2	0.7
09/29/2024 04:00	3,322.7	0.0	3,322.7	105,505.0	350.6	0.42	0.2	0.7
09/29/2024 05:00	3,321.7	0.0	3,321.7	105,505.0	350.5	0.42	0.2	0.7
09/29/2024 06:00	3,322.8	0.1	3,322.8	105,505.0	350.6	0.42	0.2	0.7
09/29/2024 07:00	3,324.1	0.0	3,324.1	105,505.0	350.7	0.42	0.2	0.7
09/29/2024 08:00	3,321.6	0.1	3,321.6	105,505.0	350.4	0.42	0.2	0.7
09/29/2024 09:00	3,325.6	0.0	3,325.6	105,505.0	350.9	0.42	0.2	0.7
09/29/2024 10:00	3,325.4	0.0	3,325.4	105,505.0	350.8	0.42	0.2	0.7
09/29/2024 11:00	3,321.1	0.0	3,321.1	105,505.0	350.4	0.42	0.2	0.7
09/29/2024 12:00	3,321.2	0.0	3,321.2	105,505.0	350.4	0.42	0.2	0.7
09/29/2024 13:00	3,314.2	12.3	3,314.2	105,505.0	349.7	0.42	0.2	0.7
09/29/2024 14:00	3,320.8	10.9	3,320.8	105,505.0	350.4	0.42	0.2	0.7
09/29/2024 15:00	3,317.3	0.0	3,317.3	105,505.0	350.0	0.42	0.2	0.7
09/29/2024 16:00	3,723.1	0.0	3,723.1	105,505.0	392.8	0.47	0.2	0.8
09/29/2024 17:00	3,363.0	0.0	3,363.0	105,505.0	354.8	0.43	0.2	0.7
09/29/2024 18:00	3,319.5	3.5	3,319.5	105,505.0	350.2	0.42	0.2	0.7
09/29/2024 19:00	3,339.5	3.9	3,339.5	105,505.0	352.3	0.42	0.2	0.7
09/29/2024 20:00	3,313.6	0.4	3,313.6	105,505.0	349.6	0.42	0.2	0.7
09/29/2024 21:00	3,314.5	0.3	3,314.5	105,505.0	349.7	0.42	0.2	0.7
09/29/2024 22:00	3,316.2	0.4	3,316.2	105,505.0	349.9	0.42	0.2	0.7
09/29/2024 23:00	3,322.0	0.6	3,322.0	105,505.0	350.5	0.42	0.2	0.7
Average/Sum#:	3,339.5	1.4	3,339.5	105,505.0	352.3	0.42	0.2	0.7
Minimum:	3,313.6	0.0	3,313.6	105,505.0	349.6	0.42	0.2	0.7
Maximum:	3,723.1	12.3	3,723.1	105,505.0	392.8	0.47	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:47 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2024 00:00	3,324.4	0.0	3,324.4	105,505.0	350.7	0.42	0.2	0.7
09/30/2024 01:00	3,322.5	0.1	3,322.5	105,505.0	350.5	0.42	0.2	0.7
09/30/2024 02:00	3,323.6	0.1	3,323.6	105,505.0	350.7	0.42	0.2	0.7
09/30/2024 03:00	3,331.4	4.1	3,331.4	105,505.0	351.5	0.42	0.2	0.7
09/30/2024 04:00	3,333.0	3.0	3,333.0	105,505.0	351.6	0.42	0.2	0.7
09/30/2024 05:00	3,368.1	0.6	3,368.1	105,505.0	355.4	0.43	0.2	0.7
09/30/2024 06:00	3,637.9	0.2	3,637.9	105,505.0	383.8	0.46	0.2	0.8
09/30/2024 07:00	3,331.0	0.3	3,331.0	105,505.0	351.4	0.42	0.2	0.7
09/30/2024 08:00	3,326.6	0.0	3,326.6	105,505.0	351.0	0.42	0.2	0.7
09/30/2024 09:00	3,332.6	0.0	3,332.6	105,505.0	351.6	0.42	0.2	0.7
09/30/2024 10:00	3,338.9	0.0	3,338.9	105,505.0	352.3	0.42	0.2	0.7
09/30/2024 11:00	3,335.2	0.0	3,335.2	105,505.0	351.9	0.42	0.2	0.7
09/30/2024 12:00	3,341.2	0.0	3,341.2	105,505.0	352.5	0.42	0.2	0.7
09/30/2024 13:00	3,346.3	14.1	3,346.3	105,505.0	353.1	0.42	0.2	0.7
09/30/2024 14:00	3,348.9	17.3	3,348.9	105,505.0	353.3	0.42	0.2	0.7
09/30/2024 15:00	3,860.9	217.0	3,962.9	105,505.0	418.1	0.52	0.3	0.9
09/30/2024 16:00	4,213.4	1,561.1	5,774.5	105,505.0	609.2	0.73	0.4	1.2
09/30/2024 17:00	4,213.9	1,487.7	5,701.6	105,505.0	601.5	0.72	0.4	1.2
09/30/2024 18:00	4,225.1	1,317.6	5,542.7	105,505.0	584.8	0.70	0.4	1.2
09/30/2024 19:00	4,252.9	1,342.8	5,595.7	105,505.0	590.4	0.71	0.4	1.2
09/30/2024 20:00	4,251.2	1,402.8	5,654.0	105,505.0	596.5	0.72	0.4	1.2
09/30/2024 21:00	4,288.1	1,334.8	5,622.9	105,505.0	593.2	0.71	0.4	1.2
09/30/2024 22:00	4,317.1	850.3	5,167.4	105,505.0	545.2	0.65	0.3	1.1
09/30/2024 23:00	4,182.8	0.9	4,182.8	105,505.0	441.3	0.53	0.3	0.9
Average/Sum#:	3,672.8	398.1	4,064.4	105,505.0	428.8	0.51	0.3	0.9
Minimum:	3,322.5	0.0	3,322.5	105,505.0	350.5	0.42	0.2	0.7
Maximum:	4,317.1	1,561.1	5,774.5	105,505.0	609.2	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2024 00:00	3,635.4	0.0	3,635.4	104,400.0	379.5	0.5	0.2	0.8
07/01/2024 01:00	3,637.8	0.0	3,637.8	104,400.0	379.8	0.5	0.2	0.8
07/01/2024 02:00	3,637.8	0.0	3,637.8	104,400.0	379.8	0.5	0.2	0.8
07/01/2024 03:00	3,646.5	0.0	3,646.5	104,400.0	380.7	0.5	0.2	0.8
07/01/2024 04:00	3,651.0	0.0	3,651.0	104,400.0	381.2	0.5	0.2	0.8
07/01/2024 05:00	3,653.6	0.0	3,653.6	104,400.0	381.4	0.5	0.2	0.8
07/01/2024 06:00	3,659.5	0.1	3,659.5	104,400.0	382.1	0.5	0.2	0.8
07/01/2024 07:00	3,659.7	0.3	3,659.7	104,400.0	382.1	0.5	0.2	0.8
07/01/2024 08:00	3,657.1	17.1	3,657.1	104,400.0	381.8	0.5	0.2	0.8
07/01/2024 09:00	3,653.7	45.1	3,653.7	104,400.0	381.4	0.5	0.2	0.8
07/01/2024 10:00	3,646.8	82.3	3,646.8	104,400.0	380.7	0.5	0.2	0.8
07/01/2024 11:00	3,642.3	83.8	3,642.3	104,400.0	380.3	0.5	0.2	0.8
07/01/2024 12:00	3,639.4	84.3	3,639.4	104,400.0	380.0	0.5	0.2	0.8
07/01/2024 13:00	3,632.2	56.3	3,632.2	104,400.0	379.2	0.5	0.2	0.8
07/01/2024 14:00	3,646.0	18.1	3,646.0	104,400.0	380.6	0.5	0.2	0.8
07/01/2024 15:00	3,659.2	0.1	3,659.2	104,400.0	382.0	0.5	0.2	0.8
07/01/2024 16:00	3,653.7	4.2	3,653.7	104,400.0	381.4	0.5	0.2	0.8
07/01/2024 17:00	3,886.2	0.0	3,886.2	104,400.0	405.7	0.5	0.2	0.8
07/01/2024 18:00	4,525.7	1,065.3	5,356.6	104,400.0	559.2	0.7	0.4	1.2
07/01/2024 19:00	4,526.6	1,938.6	6,465.2	104,400.0	675.0	0.8	0.4	1.3
07/01/2024 20:00	4,550.6	1,182.4	5,733.0	104,400.0	598.5	0.7	0.4	1.2
07/01/2024 21:00	3,903.7	7.0	3,903.9	104,400.0	407.6	0.5	0.2	0.8
07/01/2024 22:00	3,646.8	0.0	3,646.8	104,400.0	380.7	0.5	0.2	0.8
07/01/2024 23:00	3,643.5	0.0	3,643.5	104,400.0	380.4	0.5	0.2	0.8
Average/Sum#:	3,779.0	191.0	3,943.6	104,400.0	411.7	0.5	0.2	0.9
Minimum:	3,632.2	0.0	3,632.2	104,400.0	379.2	0.5	0.2	0.8
Maximum:	4,550.6	1,938.6	6,465.2	104,400.0	675.0	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/02/2024 00:00	3,646.7	0.0	3,646.7	104,400.0	380.7	0.5	0.2	0.8
07/02/2024 01:00	3,649.2	0.0	3,649.2	104,400.0	381.0	0.5	0.2	0.8
07/02/2024 02:00	3,646.5	0.0	3,646.5	104,400.0	380.7	0.5	0.2	0.8
07/02/2024 03:00	3,645.2	0.1	3,645.2	104,400.0	380.6	0.5	0.2	0.8
07/02/2024 04:00	3,654.0	0.0	3,654.0	104,400.0	381.5	0.5	0.2	0.8
07/02/2024 05:00	3,971.6	0.0	3,971.6	104,400.0	414.6	0.5	0.2	0.8
07/02/2024 06:00	3,713.0	0.0	3,713.0	104,400.0	387.6	0.5	0.2	0.8
07/02/2024 07:00	3,660.8	0.0	3,660.8	104,400.0	382.2	0.5	0.2	0.8
07/02/2024 08:00	3,643.4	0.0	3,643.4	104,400.0	380.4	0.5	0.2	0.8
07/02/2024 09:00	3,636.4	38.0	3,636.4	104,400.0	379.6	0.5	0.2	0.8
07/02/2024 10:00	3,629.8	69.0	3,629.8	104,400.0	379.0	0.5	0.2	0.8
07/02/2024 11:00	3,624.3	82.3	3,624.3	104,400.0	378.4	0.5	0.2	0.8
07/02/2024 12:00	3,692.7	87.4	3,692.7	104,400.0	385.5	0.5	0.2	0.8
07/02/2024 13:00	4,190.9	216.6	4,271.0	104,400.0	445.9	0.6	0.3	0.9
07/02/2024 14:00	4,470.8	1,294.3	5,765.1	104,400.0	601.9	0.7	0.4	1.2
07/02/2024 15:00	4,465.1	1,604.2	6,069.3	104,400.0	633.6	0.8	0.4	1.3
07/02/2024 16:00	4,460.4	1,725.3	6,185.7	104,400.0	645.8	0.8	0.4	1.3
07/02/2024 17:00	4,460.5	1,867.4	6,327.9	104,400.0	660.6	0.8	0.4	1.3
07/02/2024 18:00	4,494.0	1,857.7	6,351.7	104,400.0	663.1	0.8	0.4	1.3
07/02/2024 19:00	4,496.3	1,814.6	6,310.9	104,400.0	658.9	0.8	0.4	1.3
07/02/2024 20:00	4,532.3	1,743.0	6,275.3	104,400.0	655.1	0.8	0.4	1.3
07/02/2024 21:00	4,532.8	1,463.8	5,996.6	104,400.0	626.0	0.8	0.4	1.3
07/02/2024 22:00	4,149.3	10.4	4,149.8	104,400.0	433.2	0.5	0.3	0.9
07/02/2024 23:00	3,677.8	0.0	3,677.8	104,400.0	384.0	0.5	0.2	0.8
Average/Sum#:	3,989.3	578.1	4,549.8	104,400.0	475.0	0.6	0.3	1.0
Minimum:	3,624.3	0.0	3,624.3	104,400.0	378.4	0.5	0.2	0.8
Maximum:	4,532.8	1,867.4	6,351.7	104,400.0	663.1	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/03/2024 00:00	3,678.5	0.0	3,678.5	104,400.0	384.0	0.5	0.2	0.8
07/03/2024 01:00	3,656.5	0.0	3,656.5	104,400.0	381.7	0.5	0.2	0.8
07/03/2024 02:00	3,656.5	0.0	3,656.5	104,400.0	381.7	0.5	0.2	0.8
07/03/2024 03:00	3,658.1	0.0	3,658.1	104,400.0	381.9	0.5	0.2	0.8
07/03/2024 04:00	3,655.2	0.0	3,655.2	104,400.0	381.6	0.5	0.2	0.8
07/03/2024 05:00	3,658.6	0.0	3,658.6	104,400.0	382.0	0.5	0.2	0.8
07/03/2024 06:00	3,655.2	0.0	3,655.2	104,400.0	381.6	0.5	0.2	0.8
07/03/2024 07:00	3,650.8	0.0	3,650.8	104,400.0	381.1	0.5	0.2	0.8
07/03/2024 08:00	3,648.7	2.0	3,648.7	104,400.0	380.9	0.5	0.2	0.8
07/03/2024 09:00	3,644.1	52.9	3,644.1	104,400.0	380.4	0.5	0.2	0.8
07/03/2024 10:00	3,634.3	73.2	3,634.3	104,400.0	379.4	0.5	0.2	0.8
07/03/2024 11:00	3,631.4	90.5	3,631.4	104,400.0	379.1	0.5	0.2	0.8
07/03/2024 12:00	3,635.8	92.6	3,635.8	104,400.0	379.6	0.5	0.2	0.8
07/03/2024 13:00	3,717.9	70.3	3,717.9	104,400.0	388.1	0.5	0.2	0.8
07/03/2024 14:00	4,487.2	754.3	5,105.7	104,400.0	533.0	0.7	0.3	1.1
07/03/2024 15:00	4,477.1	1,229.0	5,706.1	104,400.0	595.7	0.7	0.4	1.2
07/03/2024 16:00	4,469.8	1,643.1	6,112.9	104,400.0	638.2	0.8	0.4	1.3
07/03/2024 17:00	4,460.8	1,842.1	6,302.9	104,400.0	658.0	0.8	0.4	1.3
07/03/2024 18:00	4,477.8	1,818.1	6,295.9	104,400.0	657.3	0.8	0.4	1.3
07/03/2024 19:00	4,477.1	1,797.0	6,274.1	104,400.0	655.0	0.8	0.4	1.3
07/03/2024 20:00	4,523.4	1,392.7	5,916.1	104,400.0	617.6	0.7	0.4	1.2
07/03/2024 21:00	4,078.9	167.9	4,129.3	104,400.0	431.1	0.5	0.3	0.9
07/03/2024 22:00	3,652.5	0.0	3,652.5	104,400.0	381.3	0.5	0.2	0.8
07/03/2024 23:00	3,656.8	0.0	3,656.8	104,400.0	381.8	0.5	0.2	0.8
Average/Sum#:	3,914.3	459.4	4,347.2	104,400.0	453.8	0.6	0.3	0.9
Minimum:	3,631.4	0.0	3,631.4	104,400.0	379.1	0.5	0.2	0.8
Maximum:	4,523.4	1,842.1	6,302.9	104,400.0	658.0	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/04/2024 00:00	3,661.3	0.0	3,661.3	104,400.0	382.2	0.5	0.2	0.8
07/04/2024 01:00	3,658.6	0.0	3,658.6	104,400.0	382.0	0.5	0.2	0.8
07/04/2024 02:00	3,658.5	0.0	3,658.5	104,400.0	381.9	0.5	0.2	0.8
07/04/2024 03:00	3,661.0	0.0	3,661.0	104,400.0	382.2	0.5	0.2	0.8
07/04/2024 04:00	3,666.3	0.0	3,666.3	104,400.0	382.8	0.5	0.2	0.8
07/04/2024 05:00	3,667.4	0.0	3,667.4	104,400.0	382.9	0.5	0.2	0.8
07/04/2024 06:00	3,663.3	0.0	3,663.3	104,400.0	382.4	0.5	0.2	0.8
07/04/2024 07:00	3,658.7	5.1	3,658.7	104,400.0	382.0	0.5	0.2	0.8
07/04/2024 08:00	3,653.4	49.0	3,653.4	104,400.0	381.4	0.5	0.2	0.8
07/04/2024 09:00	3,650.6	74.4	3,650.6	104,400.0	381.1	0.5	0.2	0.8
07/04/2024 10:00	3,645.0	97.0	3,645.0	104,400.0	380.5	0.5	0.2	0.8
07/04/2024 11:00	3,644.5	103.4	3,644.5	104,400.0	380.5	0.5	0.2	0.8
07/04/2024 12:00	3,638.2	89.4	3,638.2	104,400.0	379.8	0.5	0.2	0.8
07/04/2024 13:00	3,634.4	72.5	3,634.4	104,400.0	379.4	0.5	0.2	0.8
07/04/2024 14:00	3,634.7	34.4	3,634.7	104,400.0	379.5	0.5	0.2	0.8
07/04/2024 15:00	3,628.9	29.0	3,628.9	104,400.0	378.9	0.5	0.2	0.8
07/04/2024 16:00	4,096.3	48.2	4,097.3	104,400.0	427.8	0.5	0.3	0.9
07/04/2024 17:00	3,811.4	25.5	3,811.4	104,400.0	397.9	0.5	0.2	0.8
07/04/2024 18:00	4,197.1	39.4	4,197.1	104,400.0	438.2	0.5	0.3	0.9
07/04/2024 19:00	3,644.3	2.0	3,644.3	104,400.0	380.5	0.5	0.2	0.8
07/04/2024 20:00	3,636.0	0.1	3,636.0	104,400.0	379.6	0.5	0.2	0.8
07/04/2024 21:00	3,637.7	0.0	3,637.7	104,400.0	379.8	0.5	0.2	0.8
07/04/2024 22:00	3,641.2	0.0	3,641.2	104,400.0	380.1	0.5	0.2	0.8
07/04/2024 23:00	3,658.5	0.0	3,658.5	104,400.0	381.9	0.5	0.2	0.8
Average/Sum#:	3,697.8	27.9	3,697.8	104,400.0	386.1	0.5	0.2	0.8
Minimum:	3,628.9	0.0	3,628.9	104,400.0	378.9	0.5	0.2	0.8
Maximum:	4,197.1	103.4	4,197.1	104,400.0	438.2	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/05/2024 00:00	4,292.7	0.0	4,292.7	104,400.0	448.2	0.5	0.3	0.9
07/05/2024 01:00	4,288.1	0.0	4,288.1	104,400.0	447.7	0.5	0.3	0.9
07/05/2024 02:00	4,284.6	0.0	4,284.6	104,400.0	447.3	0.5	0.3	0.9
07/05/2024 03:00	3,658.3	0.0	3,658.3	104,400.0	381.9	0.5	0.2	0.8
07/05/2024 04:00	3,657.9	0.0	3,657.9	104,400.0	381.9	0.5	0.2	0.8
07/05/2024 05:00	3,657.8	0.0	3,657.8	104,400.0	381.9	0.5	0.2	0.8
07/05/2024 06:00	3,654.0	6.3	3,654.0	104,400.0	381.5	0.5	0.2	0.8
07/05/2024 07:00	3,650.5	46.8	3,650.5	104,400.0	381.1	0.5	0.2	0.8
07/05/2024 08:00	3,642.3	67.7	3,642.3	104,400.0	380.3	0.5	0.2	0.8
07/05/2024 09:00	3,637.3	59.9	3,637.3	104,400.0	379.7	0.5	0.2	0.8
07/05/2024 10:00	3,630.3	94.2	3,630.3	104,400.0	379.0	0.5	0.2	0.8
07/05/2024 11:00	3,627.3	103.3	3,627.3	104,400.0	378.7	0.5	0.2	0.8
07/05/2024 12:00	3,623.2	99.6	3,623.2	104,400.0	378.3	0.5	0.2	0.8
07/05/2024 13:00	3,620.7	90.9	3,620.7	104,400.0	378.0	0.5	0.2	0.8
07/05/2024 14:00	3,618.0	42.2	3,618.0	104,400.0	377.7	0.5	0.2	0.8
07/05/2024 15:00	3,617.7	42.1	3,617.7	104,400.0	377.7	0.5	0.2	0.8
07/05/2024 16:00	3,612.4	62.8	3,612.4	104,400.0	377.1	0.5	0.2	0.8
07/05/2024 17:00	4,127.8	296.2	4,255.2	104,400.0	444.2	0.6	0.3	0.9
07/05/2024 18:00	4,453.4	1,617.1	6,070.5	104,400.0	633.8	0.8	0.4	1.3
07/05/2024 19:00	4,456.6	889.5	5,346.1	104,400.0	558.1	0.7	0.3	1.1
07/05/2024 20:00	4,053.4	202.4	4,114.1	104,400.0	429.5	0.5	0.3	0.9
07/05/2024 21:00	3,632.1	3.4	3,632.1	104,400.0	379.2	0.5	0.2	0.8
07/05/2024 22:00	3,632.8	0.5	3,632.8	104,400.0	379.3	0.5	0.2	0.8
07/05/2024 23:00	3,637.4	0.0	3,637.4	104,400.0	379.7	0.5	0.2	0.8
Average/Sum#:	3,823.6	155.2	3,935.9	104,400.0	410.9	0.5	0.2	0.9
Minimum:	3,612.4	0.0	3,612.4	104,400.0	377.1	0.5	0.2	0.8
Maximum:	4,456.6	1,617.1	6,070.5	104,400.0	633.8	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/06/2024 00:00	3,641.4	0.0	3,641.4	104,400.0	380.2	0.5	0.2	0.8
07/06/2024 01:00	3,645.6	0.0	3,645.6	104,400.0	380.6	0.5	0.2	0.8
07/06/2024 02:00	3,646.9	0.0	3,646.9	104,400.0	380.7	0.5	0.2	0.8
07/06/2024 03:00	3,648.1	0.0	3,648.1	104,400.0	380.9	0.5	0.2	0.8
07/06/2024 04:00	3,656.0	0.0	3,656.0	104,400.0	381.7	0.5	0.2	0.8
07/06/2024 05:00	3,660.5	0.0	3,660.5	104,400.0	382.2	0.5	0.2	0.8
07/06/2024 06:00	3,658.2	21.4	3,658.2	104,400.0	381.9	0.5	0.2	0.8
07/06/2024 07:00	3,650.1	64.6	3,650.1	104,400.0	381.1	0.5	0.2	0.8
07/06/2024 08:00	3,645.4	80.0	3,645.4	104,400.0	380.6	0.5	0.2	0.8
07/06/2024 09:00	3,639.2	89.9	3,639.2	104,400.0	379.9	0.5	0.2	0.8
07/06/2024 10:00	3,636.9	100.0	3,636.9	104,400.0	379.7	0.5	0.2	0.8
07/06/2024 11:00	3,631.3	110.3	3,631.3	104,400.0	379.1	0.5	0.2	0.8
07/06/2024 12:00	3,652.0	109.3	3,652.0	104,400.0	381.3	0.5	0.2	0.8
07/06/2024 13:00	3,653.8	92.4	3,653.8	104,400.0	381.5	0.5	0.2	0.8
07/06/2024 14:00	3,998.6	62.5	3,998.6	104,400.0	417.5	0.5	0.3	0.8
07/06/2024 15:00	3,659.4	53.8	3,659.4	104,400.0	382.0	0.5	0.2	0.8
07/06/2024 16:00	3,813.9	71.7	3,813.9	104,400.0	398.2	0.5	0.2	0.8
07/06/2024 17:00	4,283.2	559.1	4,551.6	104,400.0	475.2	0.6	0.3	1.0
07/06/2024 18:00	4,452.8	1,585.1	6,037.9	104,400.0	630.4	0.8	0.4	1.3
07/06/2024 19:00	4,444.1	1,206.0	5,650.1	104,400.0	589.9	0.7	0.4	1.2
07/06/2024 20:00	4,443.8	628.4	4,946.5	104,400.0	516.4	0.6	0.3	1.1
07/06/2024 21:00	4,399.2	45.6	4,399.2	104,400.0	459.3	0.6	0.3	0.9
07/06/2024 22:00	4,321.7	24.5	4,321.7	104,400.0	451.2	0.5	0.3	0.9
07/06/2024 23:00	3,761.5	10.5	3,761.5	104,400.0	392.7	0.5	0.2	0.8
Average/Sum#:	3,860.2	204.8	4,008.6	104,400.0	418.5	0.5	0.2	0.9
Minimum:	3,631.3	0.0	3,631.3	104,400.0	379.1	0.5	0.2	0.8
Maximum:	4,452.8	1,585.1	6,037.9	104,400.0	630.4	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2024 00:00	3,648.6	0.3	3,648.6	104,400.0	380.9	0.5	0.2	0.8
07/07/2024 01:00	3,649.8	0.2	3,649.8	104,400.0	381.0	0.5	0.2	0.8
07/07/2024 02:00	3,652.4	0.0	3,652.4	104,400.0	381.3	0.5	0.2	0.8
07/07/2024 03:00	3,654.7	0.0	3,654.7	104,400.0	381.6	0.5	0.2	0.8
07/07/2024 04:00	3,658.0	0.0	3,658.0	104,400.0	381.9	0.5	0.2	0.8
07/07/2024 05:00	3,660.1	0.0	3,660.1	104,400.0	382.1	0.5	0.2	0.8
07/07/2024 06:00	3,660.1	46.3	3,660.1	104,400.0	382.1	0.5	0.2	0.8
07/07/2024 07:00	3,653.4	65.9	3,653.4	104,400.0	381.4	0.5	0.2	0.8
07/07/2024 08:00	3,646.5	78.1	3,646.5	104,400.0	380.7	0.5	0.2	0.8
07/07/2024 09:00	3,644.1	85.6	3,644.1	104,400.0	380.4	0.5	0.2	0.8
07/07/2024 10:00	3,642.4	101.5	3,642.4	104,400.0	380.3	0.5	0.2	0.8
07/07/2024 11:00	3,638.6	114.3	3,638.6	104,400.0	379.9	0.5	0.2	0.8
07/07/2024 12:00	3,831.6	114.2	3,831.6	104,400.0	400.0	0.5	0.2	0.8
07/07/2024 13:00	3,807.3	99.8	3,807.3	104,400.0	397.5	0.5	0.2	0.8
07/07/2024 14:00	4,110.8	57.5	4,110.8	104,400.0	429.2	0.5	0.3	0.9
07/07/2024 15:00	3,903.6	94.9	3,920.7	104,400.0	409.3	0.5	0.3	0.8
07/07/2024 16:00	4,389.2	1,613.9	6,003.1	104,400.0	626.7	0.8	0.4	1.3
07/07/2024 17:00	4,412.0	1,714.3	6,126.3	104,400.0	639.6	0.8	0.4	1.3
07/07/2024 18:00	4,459.7	1,648.2	6,107.9	104,400.0	637.7	0.8	0.4	1.3
07/07/2024 19:00	4,483.3	1,600.1	6,083.4	104,400.0	635.1	0.8	0.4	1.3
07/07/2024 20:00	4,517.2	1,507.0	6,024.2	104,400.0	628.9	0.8	0.4	1.3
07/07/2024 21:00	4,290.9	395.1	4,500.3	104,400.0	469.8	0.6	0.3	1.0
07/07/2024 22:00	3,657.2	0.0	3,657.2	104,400.0	381.8	0.5	0.2	0.8
07/07/2024 23:00	3,654.2	0.0	3,654.2	104,400.0	381.5	0.5	0.2	0.8
Average/Sum#:	3,888.6	389.1	4,234.8	104,400.0	442.1	0.6	0.3	0.9
Minimum:	3,638.6	0.0	3,638.6	104,400.0	379.9	0.5	0.2	0.8
Maximum:	4,517.2	1,714.3	6,126.3	104,400.0	639.6	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2024 00:00	3,656.3	0.0	3,656.3	104,400.0	381.7	0.5	0.2	0.8
07/08/2024 01:00	3,659.2	0.0	3,659.2	104,400.0	382.0	0.5	0.2	0.8
07/08/2024 02:00	3,661.7	0.1	3,661.7	104,400.0	382.3	0.5	0.2	0.8
07/08/2024 03:00	3,663.6	0.0	3,663.6	104,400.0	382.5	0.5	0.2	0.8
07/08/2024 04:00	3,665.4	0.0	3,665.4	104,400.0	382.7	0.5	0.2	0.8
07/08/2024 05:00	3,664.3	0.0	3,664.3	104,400.0	382.6	0.5	0.2	0.8
07/08/2024 06:00	3,666.8	0.1	3,666.8	104,400.0	382.8	0.5	0.2	0.8
07/08/2024 07:00	3,661.8	24.6	3,661.8	104,400.0	382.3	0.5	0.2	0.8
07/08/2024 08:00	3,659.3	67.9	3,659.3	104,400.0	382.0	0.5	0.2	0.8
07/08/2024 09:00	3,652.8	76.2	3,652.8	104,400.0	381.4	0.5	0.2	0.8
07/08/2024 10:00	3,647.1	104.1	3,647.1	104,400.0	380.8	0.5	0.2	0.8
07/08/2024 11:00	3,644.0	100.7	3,644.0	104,400.0	380.4	0.5	0.2	0.8
07/08/2024 12:00	3,681.8	103.5	3,681.8	104,400.0	384.4	0.5	0.2	0.8
07/08/2024 13:00	3,779.7	94.0	3,779.7	104,400.0	394.6	0.5	0.2	0.8
07/08/2024 14:00	4,429.5	45.4	4,429.5	104,400.0	462.4	0.6	0.3	0.9
07/08/2024 15:00	4,053.7	57.5	4,053.7	104,400.0	423.2	0.5	0.3	0.9
07/08/2024 16:00	4,465.1	612.2	4,789.6	104,400.0	500.0	0.6	0.3	1.1
07/08/2024 17:00	4,484.6	1,718.2	6,202.8	104,400.0	647.6	0.8	0.4	1.3
07/08/2024 18:00	4,499.1	1,763.9	6,263.0	104,400.0	653.9	0.8	0.4	1.3
07/08/2024 19:00	4,525.4	1,565.3	6,090.7	104,400.0	635.9	0.8	0.4	1.3
07/08/2024 20:00	4,538.0	1,515.6	6,053.6	104,400.0	632.0	0.8	0.4	1.3
07/08/2024 21:00	4,576.8	1,330.6	5,907.4	104,400.0	616.7	0.7	0.4	1.2
07/08/2024 22:00	4,614.8	1,276.8	5,891.6	104,400.0	615.1	0.7	0.4	1.2
07/08/2024 23:00	4,655.1	969.4	5,624.5	104,400.0	587.2	0.7	0.4	1.2
Average/Sum#:	4,008.6	476.1	4,444.6	104,400.0	464.0	0.6	0.3	1.0
Minimum:	3,644.0	0.0	3,644.0	104,400.0	380.4	0.5	0.2	0.8
Maximum:	4,655.1	1,763.9	6,263.0	104,400.0	653.9	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/09/2024 00:00	4,371.9	284.5	4,519.8	104,400.0	471.9	0.6	0.3	1.0
07/09/2024 01:00	3,669.8	0.1	3,669.8	104,400.0	383.1	0.5	0.2	0.8
07/09/2024 02:00	3,670.9	0.0	3,670.9	104,400.0	383.2	0.5	0.2	0.8
07/09/2024 03:00	3,674.0	0.0	3,674.0	104,400.0	383.6	0.5	0.2	0.8
07/09/2024 04:00	3,699.0	0.0	3,699.0	104,400.0	386.2	0.5	0.2	0.8
07/09/2024 05:00	3,674.3	0.0	3,674.3	104,400.0	383.6	0.5	0.2	0.8
07/09/2024 06:00	3,674.0	0.0	3,674.0	104,400.0	383.6	0.5	0.2	0.8
07/09/2024 07:00	3,672.3	0.0	3,672.3	104,400.0	383.4	0.5	0.2	0.8
07/09/2024 08:00	3,668.2	1.7	3,668.2	104,400.0	383.0	0.5	0.2	0.8
07/09/2024 09:00	3,658.9	43.8	3,658.9	104,400.0	382.0	0.5	0.2	0.8
07/09/2024 10:00	3,651.9	88.4	3,651.9	104,400.0	381.3	0.5	0.2	0.8
07/09/2024 11:00	3,648.0	97.6	3,648.0	104,400.0	380.9	0.5	0.2	0.8
07/09/2024 12:00	3,689.1	107.0	3,689.1	104,400.0	385.1	0.5	0.2	0.8
07/09/2024 13:00	4,495.2	89.4	4,495.2	104,400.0	469.3	0.6	0.3	1.0
07/09/2024 14:00	4,353.3	40.1	4,353.3	104,400.0	454.5	0.5	0.3	0.9
07/09/2024 15:00	4,234.8	200.8	4,291.0	104,400.0	448.0	0.6	0.3	0.9
07/09/2024 16:00	4,493.8	1,513.5	6,007.3	104,400.0	627.2	0.8	0.4	1.3
07/09/2024 17:00	4,500.5	1,599.5	6,100.0	104,400.0	636.8	0.8	0.4	1.3
07/09/2024 18:00	4,527.0	1,752.8	6,279.8	104,400.0	655.6	0.8	0.4	1.3
07/09/2024 19:00	4,567.5	1,549.4	6,116.9	104,400.0	638.6	0.8	0.4	1.3
07/09/2024 20:00	4,607.3	1,393.5	6,000.8	104,400.0	626.5	0.8	0.4	1.3
07/09/2024 21:00	4,623.7	1,382.8	6,006.5	104,400.0	627.1	0.8	0.4	1.3
07/09/2024 22:00	4,636.9	1,310.8	5,947.7	104,400.0	620.9	0.7	0.4	1.2
07/09/2024 23:00	4,617.1	462.1	4,977.5	104,400.0	519.7	0.6	0.3	1.1
Average/Sum#:	4,086.6	496.6	4,547.8	104,400.0	474.8	0.6	0.3	1.0
Minimum:	3,648.0	0.0	3,648.0	104,400.0	380.9	0.5	0.2	0.8
Maximum:	4,636.9	1,752.8	6,279.8	104,400.0	655.6	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT2

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2024 00:00	4,493.6	0.0	4,493.6	104,400.0	469.1	0.6	0.3	0.9
07/10/2024 01:00	4,441.7	0.0	4,441.7	104,400.0	463.7	0.6	0.3	0.9
07/10/2024 02:00	4,538.8	0.0	4,538.8	104,400.0	473.9	0.6	0.3	0.9
07/10/2024 03:00	4,419.8	0.0	4,419.8	104,400.0	461.4	0.6	0.3	0.9
07/10/2024 04:00	4,547.5	0.0	4,547.5	104,400.0	474.8	0.6	0.3	0.9
07/10/2024 05:00	4,210.2	0.1	4,210.2	104,400.0	439.5	0.5	0.3	0.9
07/10/2024 06:00	3,695.6	1.9	3,695.6	104,400.0	385.8	0.5	0.2	0.8
07/10/2024 07:00	3,695.5	13.0	3,695.5	104,400.0	385.8	0.5	0.2	0.8
07/10/2024 08:00	3,686.8	51.8	3,686.8	104,400.0	384.9	0.5	0.2	0.8
07/10/2024 09:00	3,664.8	55.5	3,664.8	104,400.0	382.6	0.5	0.2	0.8
07/10/2024 10:00	3,659.5	89.3	3,659.5	104,400.0	382.1	0.5	0.2	0.8
07/10/2024 11:00	3,655.7	94.1	3,655.7	104,400.0	381.7	0.5	0.2	0.8
07/10/2024 12:00	3,644.0	103.6	3,644.0	104,400.0	380.4	0.5	0.2	0.8
07/10/2024 13:00	4,024.7	85.1	4,024.7	104,400.0	420.2	0.5	0.3	0.9
07/10/2024 14:00	4,278.0	49.0	4,278.0	104,400.0	446.6	0.5	0.3	0.9
07/10/2024 15:00	3,978.8	34.5	3,978.8	104,400.0	415.4	0.5	0.3	0.8
07/10/2024 16:00	4,034.0	65.9	4,034.0	104,400.0	421.1	0.5	0.3	0.9
07/10/2024 17:00	4,452.3	1,407.9	5,832.0	104,400.0	608.9	0.7	0.4	1.2
07/10/2024 18:00	4,452.4	1,767.4	6,219.8	104,400.0	649.3	0.8	0.4	1.3
07/10/2024 19:00	4,483.9	1,699.4	6,183.3	104,400.0	645.5	0.8	0.4	1.3
07/10/2024 20:00	4,524.7	1,436.3	5,961.0	104,400.0	622.3	0.7	0.4	1.2
07/10/2024 21:00	4,525.1	997.5	5,522.6	104,400.0	576.6	0.7	0.3	1.2
07/10/2024 22:00	4,524.1	522.3	4,926.3	104,400.0	514.3	0.6	0.3	1.1
07/10/2024 23:00	4,093.3	0.0	4,093.3	104,400.0	427.3	0.5	0.3	0.9
Average/Sum#:	4,155.2	353.1	4,475.3	104,400.0	467.2	0.6	0.3	0.9
Minimum:	3,644.0	0.0	3,644.0	104,400.0	380.4	0.5	0.2	0.8
Maximum:	4,547.5	1,767.4	6,219.8	104,400.0	649.3	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2024 00:00	3,679.2	0.0	3,679.2	104,400.0	384.1	0.5	0.2	0.8
07/11/2024 01:00	3,670.7	0.0	3,670.7	104,400.0	383.2	0.5	0.2	0.8
07/11/2024 02:00	3,670.9	0.0	3,670.9	104,400.0	383.2	0.5	0.2	0.8
07/11/2024 03:00	3,671.4	0.0	3,671.4	104,400.0	383.3	0.5	0.2	0.8
07/11/2024 04:00	3,673.2	0.0	3,673.2	104,400.0	383.5	0.5	0.2	0.8
07/11/2024 05:00	3,677.2	0.0	3,677.2	104,400.0	383.9	0.5	0.2	0.8
07/11/2024 06:00	3,681.2	24.6	3,681.2	104,400.0	384.3	0.5	0.2	0.8
07/11/2024 07:00	3,678.9	25.4	3,678.9	104,400.0	384.1	0.5	0.2	0.8
07/11/2024 08:00	3,680.6	46.7	3,680.6	104,400.0	384.3	0.5	0.2	0.8
07/11/2024 09:00	3,674.3	46.5	3,674.3	104,400.0	383.6	0.5	0.2	0.8
07/11/2024 10:00	3,670.7	91.7	3,670.7	104,400.0	383.2	0.5	0.2	0.8
07/11/2024 11:00	3,646.3	98.2	3,646.3	104,400.0	380.7	0.5	0.2	0.8
07/11/2024 12:00	3,901.5	102.5	3,901.5	104,400.0	407.3	0.5	0.3	0.8
07/11/2024 13:00	4,441.5	92.8	4,441.5	104,400.0	463.7	0.6	0.3	0.9
07/11/2024 14:00	4,449.5	1,456.6	5,877.0	104,400.0	613.6	0.7	0.4	1.2
07/11/2024 15:00	4,465.0	1,711.9	6,176.9	104,400.0	644.9	0.8	0.4	1.3
07/11/2024 16:00	4,476.9	1,674.0	6,150.9	104,400.0	642.2	0.8	0.4	1.3
07/11/2024 17:00	4,470.8	1,711.8	6,182.6	104,400.0	645.5	0.8	0.4	1.3
07/11/2024 18:00	4,472.0	1,708.6	6,180.6	104,400.0	645.3	0.8	0.4	1.3
07/11/2024 19:00	4,481.0	1,686.0	6,167.0	104,400.0	643.8	0.8	0.4	1.3
07/11/2024 20:00	4,503.9	1,650.5	6,154.4	104,400.0	642.5	0.8	0.4	1.3
07/11/2024 21:00	4,521.3	1,620.2	6,141.5	104,400.0	641.2	0.8	0.4	1.3
07/11/2024 22:00	4,542.1	919.0	5,295.7	104,400.0	552.9	0.7	0.3	1.1
07/11/2024 23:00	4,428.8	18.6	4,428.8	104,400.0	462.4	0.6	0.3	0.9
Average/Sum#:	4,051.2	611.9	4,632.2	104,400.0	483.6	0.6	0.3	1.0
Minimum:	3,646.3	0.0	3,646.3	104,400.0	380.7	0.5	0.2	0.8
Maximum:	4,542.1	1,711.9	6,182.6	104,400.0	645.5	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2024 00:00	3,835.0	4.7	3,835.0	104,400.0	400.4	0.5	0.2	0.8
07/12/2024 01:00	3,670.7	0.0	3,670.7	104,400.0	383.2	0.5	0.2	0.8
07/12/2024 02:00	3,672.5	0.0	3,672.5	104,400.0	383.4	0.5	0.2	0.8
07/12/2024 03:00	3,677.2	0.0	3,677.2	104,400.0	383.9	0.5	0.2	0.8
07/12/2024 04:00	3,680.2	0.0	3,680.2	104,400.0	384.2	0.5	0.2	0.8
07/12/2024 05:00	3,687.2	2.0	3,687.2	104,400.0	384.9	0.5	0.2	0.8
07/12/2024 06:00	3,863.5	57.3	3,863.5	104,400.0	403.3	0.5	0.2	0.8
07/12/2024 07:00	3,682.1	65.1	3,682.1	104,400.0	384.4	0.5	0.2	0.8
07/12/2024 08:00	3,680.1	67.3	3,680.1	104,400.0	384.2	0.5	0.2	0.8
07/12/2024 09:00	3,664.0	76.0	3,664.0	104,400.0	382.5	0.5	0.2	0.8
07/12/2024 10:00	3,657.9	93.4	3,657.9	104,400.0	381.9	0.5	0.2	0.8
07/12/2024 11:00	4,057.0	105.5	4,057.0	104,400.0	423.6	0.5	0.3	0.9
07/12/2024 12:00	4,397.5	104.7	4,397.5	104,400.0	459.1	0.6	0.3	0.9
07/12/2024 13:00	4,405.7	95.4	4,405.7	104,400.0	460.0	0.6	0.3	0.9
07/12/2024 14:00	4,420.7	495.1	4,683.1	104,400.0	488.9	0.6	0.3	1.0
07/12/2024 15:00	4,423.8	823.6	5,247.4	104,400.0	547.8	0.7	0.3	1.1
07/12/2024 16:00	4,415.5	1,088.6	5,504.1	104,400.0	574.6	0.7	0.3	1.1
07/12/2024 17:00	4,404.3	1,796.5	6,200.8	104,400.0	647.4	0.8	0.4	1.3
07/12/2024 18:00	4,423.5	1,761.9	6,185.4	104,400.0	645.8	0.8	0.4	1.3
07/12/2024 19:00	4,475.2	1,426.0	5,901.2	104,400.0	616.1	0.7	0.4	1.2
07/12/2024 20:00	4,495.8	1,274.0	5,769.8	104,400.0	602.4	0.7	0.4	1.2
07/12/2024 21:00	4,349.6	178.2	4,379.9	104,400.0	457.3	0.6	0.3	0.9
07/12/2024 22:00	4,359.9	22.2	4,359.9	104,400.0	455.2	0.5	0.3	0.9
07/12/2024 23:00	3,758.4	6.3	3,758.4	104,400.0	392.4	0.5	0.2	0.8
Average/Sum#:	4,048.2	397.7	4,400.9	104,400.0	459.5	0.6	0.3	0.9
Minimum:	3,657.9	0.0	3,657.9	104,400.0	381.9	0.5	0.2	0.8
Maximum:	4,495.8	1,796.5	6,200.8	104,400.0	647.4	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2024 00:00	3,649.0	2.6	3,649.0	104,400.0	381.0	0.5	0.2	0.8
07/13/2024 01:00	3,631.8	0.0	3,631.8	104,400.0	379.2	0.5	0.2	0.8
07/13/2024 02:00	3,694.3	0.0	3,694.3	104,400.0	385.7	0.5	0.2	0.8
07/13/2024 03:00	3,717.1	0.0	3,717.1	104,400.0	388.1	0.5	0.2	0.8
07/13/2024 04:00	3,623.9	0.0	3,623.9	104,400.0	378.3	0.5	0.2	0.8
07/13/2024 05:00	3,627.3	0.0	3,627.3	104,400.0	378.7	0.5	0.2	0.8
07/13/2024 06:00	3,624.4	0.0	3,624.4	104,400.0	378.4	0.5	0.2	0.8
07/13/2024 07:00	3,623.4	26.6	3,623.4	104,400.0	378.3	0.5	0.2	0.8
07/13/2024 08:00	3,963.3	445.2	4,119.1	104,400.0	430.0	0.6	0.3	0.9
07/13/2024 09:00	3,865.6	17.9	3,866.9	104,400.0	403.7	0.5	0.2	0.8
07/13/2024 10:00	3,664.0	0.0	3,664.0	104,400.0	382.5	0.5	0.2	0.8
07/13/2024 11:00	3,653.4	29.7	3,653.4	104,400.0	381.4	0.5	0.2	0.8
07/13/2024 12:00	3,647.6	102.2	3,647.6	104,400.0	380.8	0.5	0.2	0.8
07/13/2024 13:00	3,653.0	93.9	3,653.0	104,400.0	381.4	0.5	0.2	0.8
07/13/2024 14:00	3,665.8	51.7	3,665.8	104,400.0	382.7	0.5	0.2	0.8
07/13/2024 15:00	3,684.7	39.7	3,684.7	104,400.0	384.7	0.5	0.2	0.8
07/13/2024 16:00	3,732.6	115.7	3,750.0	104,400.0	391.5	0.5	0.2	0.8
07/13/2024 17:00	3,900.0	70.9	3,915.6	104,400.0	408.8	0.5	0.2	0.8
07/13/2024 18:00	4,348.4	34.7	4,348.4	104,400.0	454.0	0.5	0.3	0.9
07/13/2024 19:00	3,723.1	1.2	3,723.1	104,400.0	388.7	0.5	0.2	0.8
07/13/2024 20:00	3,855.7	0.0	3,855.7	104,400.0	402.5	0.5	0.2	0.8
07/13/2024 21:00	3,741.3	0.0	3,741.3	104,400.0	390.6	0.5	0.2	0.8
07/13/2024 22:00	3,722.2	0.0	3,722.2	104,400.0	388.6	0.5	0.2	0.8
07/13/2024 23:00	3,702.7	0.0	3,702.7	104,400.0	386.6	0.5	0.2	0.8
Average/Sum#:	3,738.1	43.0	3,746.0	104,400.0	391.1	0.5	0.2	0.8
Minimum:	3,623.4	0.0	3,623.4	104,400.0	378.3	0.5	0.2	0.8
Maximum:	4,348.4	445.2	4,348.4	104,400.0	454.0	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2024 00:00	3,694.0	0.0	3,694.0	104,400.0	385.7	0.5	0.2	0.8
07/14/2024 01:00	3,690.0	0.0	3,690.0	104,400.0	385.2	0.5	0.2	0.8
07/14/2024 02:00	3,675.4	0.0	3,675.4	104,400.0	383.7	0.5	0.2	0.8
07/14/2024 03:00	3,657.1	0.0	3,657.1	104,400.0	381.8	0.5	0.2	0.8
07/14/2024 04:00	3,658.1	0.0	3,658.1	104,400.0	381.9	0.5	0.2	0.8
07/14/2024 05:00	3,660.5	0.0	3,660.5	104,400.0	382.2	0.5	0.2	0.8
07/14/2024 06:00	3,661.5	0.0	3,661.5	104,400.0	382.3	0.5	0.2	0.8
07/14/2024 07:00	3,662.7	0.0	3,662.7	104,400.0	382.4	0.5	0.2	0.8
07/14/2024 08:00	3,661.9	0.0	3,661.9	104,400.0	382.3	0.5	0.2	0.8
07/14/2024 09:00	3,662.6	0.0	3,662.6	104,400.0	382.4	0.5	0.2	0.8
07/14/2024 10:00	3,656.4	0.1	3,656.4	104,400.0	381.7	0.5	0.2	0.8
07/14/2024 11:00	3,650.6	33.2	3,650.6	104,400.0	381.1	0.5	0.2	0.8
07/14/2024 12:00	3,645.7	57.8	3,645.7	104,400.0	380.6	0.5	0.2	0.8
07/14/2024 13:00	3,641.6	5.6	3,641.6	104,400.0	380.2	0.5	0.2	0.8
07/14/2024 14:00	3,814.2	42.8	3,814.2	104,400.0	398.2	0.5	0.2	0.8
07/14/2024 15:00	3,710.5	0.3	3,710.5	104,400.0	387.4	0.5	0.2	0.8
07/14/2024 16:00	3,674.6	2.5	3,674.6	104,400.0	383.6	0.5	0.2	0.8
07/14/2024 17:00	3,751.6	16.8	3,751.6	104,400.0	391.7	0.5	0.2	0.8
07/14/2024 18:00	3,947.1	29.1	3,948.0	104,400.0	412.2	0.5	0.2	0.8
07/14/2024 19:00	3,927.5	1.4	3,927.5	104,400.0	410.0	0.5	0.2	0.8
07/14/2024 20:00	3,919.3	0.0	3,919.3	104,400.0	409.2	0.5	0.2	0.8
07/14/2024 21:00	4,105.3	0.0	4,105.3	104,400.0	428.6	0.5	0.3	0.9
07/14/2024 22:00	3,668.8	0.0	3,668.8	104,400.0	383.0	0.5	0.2	0.8
07/14/2024 23:00	3,662.2	0.0	3,662.2	104,400.0	382.3	0.5	0.2	0.8
Average/Sum#:	3,727.5	7.9	3,727.5	104,400.0	389.2	0.5	0.2	0.8
Minimum:	3,641.6	0.0	3,641.6	104,400.0	380.2	0.5	0.2	0.8
Maximum:	4,105.3	57.8	4,105.3	104,400.0	428.6	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2024 00:00	3,663.4	0.0	3,663.4	104,400.0	382.5	0.5	0.2	0.8
07/15/2024 01:00	3,663.9	0.0	3,663.9	104,400.0	382.5	0.5	0.2	0.8
07/15/2024 02:00	3,662.6	0.0	3,662.6	104,400.0	382.4	0.5	0.2	0.8
07/15/2024 03:00	3,891.7	0.0	3,891.7	104,400.0	406.3	0.5	0.2	0.8
07/15/2024 04:00	3,666.0	0.0	3,666.0	104,400.0	382.7	0.5	0.2	0.8
07/15/2024 05:00	3,664.1	0.0	3,664.1	104,400.0	382.5	0.5	0.2	0.8
07/15/2024 06:00	3,666.3	0.1	3,666.3	104,400.0	382.8	0.5	0.2	0.8
07/15/2024 07:00	3,662.3	0.0	3,662.3	104,400.0	382.3	0.5	0.2	0.8
07/15/2024 08:00	3,667.3	5.3	3,667.3	104,400.0	382.9	0.5	0.2	0.8
07/15/2024 09:00	3,664.0	14.9	3,664.0	104,400.0	382.5	0.5	0.2	0.8
07/15/2024 10:00	3,663.1	46.4	3,663.1	104,400.0	382.4	0.5	0.2	0.8
07/15/2024 11:00	3,658.4	92.6	3,658.4	104,400.0	381.9	0.5	0.2	0.8
07/15/2024 12:00	3,656.3	99.6	3,656.3	104,400.0	381.7	0.5	0.2	0.8
07/15/2024 13:00	3,656.5	86.7	3,656.5	104,400.0	381.7	0.5	0.2	0.8
07/15/2024 14:00	3,654.4	44.9	3,654.4	104,400.0	381.5	0.5	0.2	0.8
07/15/2024 15:00	3,732.4	14.0	3,732.4	104,400.0	389.7	0.5	0.2	0.8
07/15/2024 16:00	3,663.2	36.9	3,663.2	104,400.0	382.4	0.5	0.2	0.8
07/15/2024 17:00	3,669.2	13.1	3,669.2	104,400.0	383.1	0.5	0.2	0.8
07/15/2024 18:00	3,665.7	27.2	3,665.7	104,400.0	382.7	0.5	0.2	0.8
07/15/2024 19:00	3,687.8	0.1	3,687.8	104,400.0	385.0	0.5	0.2	0.8
07/15/2024 20:00	3,675.8	0.0	3,675.8	104,400.0	383.8	0.5	0.2	0.8
07/15/2024 21:00	3,672.2	0.1	3,672.2	104,400.0	383.4	0.5	0.2	0.8
07/15/2024 22:00	3,668.5	0.1	3,668.5	104,400.0	383.0	0.5	0.2	0.8
07/15/2024 23:00	3,670.5	0.0	3,670.5	104,400.0	383.2	0.5	0.2	0.8
Average/Sum#:	3,677.7	20.1	3,677.7	104,400.0	384.0	0.5	0.2	0.8
Minimum:	3,654.4	0.0	3,654.4	104,400.0	381.5	0.5	0.2	0.8
Maximum:	3,891.7	99.6	3,891.7	104,400.0	406.3	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2024 00:00	3,668.5	0.0	3,668.5	104,400.0	383.0	0.5	0.2	0.8
07/16/2024 01:00	3,667.3	0.0	3,667.3	104,400.0	382.9	0.5	0.2	0.8
07/16/2024 02:00	3,671.4	0.0	3,671.4	104,400.0	383.3	0.5	0.2	0.8
07/16/2024 03:00	3,672.6	0.0	3,672.6	104,400.0	383.4	0.5	0.2	0.8
07/16/2024 04:00	3,935.3	0.0	3,935.3	104,400.0	410.8	0.5	0.2	0.8
07/16/2024 05:00	4,225.2	0.0	4,225.2	104,400.0	441.1	0.5	0.3	0.9
07/16/2024 06:00	3,676.0	0.0	3,676.0	104,400.0	383.8	0.5	0.2	0.8
07/16/2024 07:00	3,676.0	0.0	3,676.0	104,400.0	383.8	0.5	0.2	0.8
07/16/2024 08:00	3,669.6	1.9	3,669.6	104,400.0	383.1	0.5	0.2	0.8
07/16/2024 09:00	3,665.3	22.2	3,665.3	104,400.0	382.7	0.5	0.2	0.8
07/16/2024 10:00	3,658.2	44.6	3,658.2	104,400.0	381.9	0.5	0.2	0.8
07/16/2024 11:00	3,651.1	81.8	3,651.1	104,400.0	381.2	0.5	0.2	0.8
07/16/2024 12:00	3,647.5	91.6	3,647.5	104,400.0	380.8	0.5	0.2	0.8
07/16/2024 13:00	3,640.0	78.3	3,640.0	104,400.0	380.0	0.5	0.2	0.8
07/16/2024 14:00	3,786.9	36.5	3,786.9	104,400.0	395.4	0.5	0.2	0.8
07/16/2024 15:00	4,340.0	2.1	4,340.0	104,400.0	453.1	0.5	0.3	0.9
07/16/2024 16:00	3,634.8	4.3	3,634.8	104,400.0	379.5	0.5	0.2	0.8
07/16/2024 17:00	4,325.0	256.9	4,435.5	104,400.0	463.1	0.6	0.3	1.0
07/16/2024 18:00	4,639.9	698.1	5,338.0	104,400.0	557.3	0.7	0.3	1.1
07/16/2024 19:00	4,666.4	514.3	5,180.7	104,400.0	540.9	0.6	0.3	1.1
07/16/2024 20:00	4,610.8	547.4	5,021.4	104,400.0	524.2	0.6	0.3	1.1
07/16/2024 21:00	4,329.8	0.0	4,329.8	104,400.0	452.0	0.5	0.3	0.9
07/16/2024 22:00	3,995.6	0.0	3,995.6	104,400.0	417.1	0.5	0.3	0.8
07/16/2024 23:00	3,675.1	0.0	3,675.1	104,400.0	383.7	0.5	0.2	0.8
Average/Sum#:	3,922.0	99.2	3,994.2	104,400.0	417.0	0.5	0.2	0.9
Minimum:	3,634.8	0.0	3,634.8	104,400.0	379.5	0.5	0.2	0.8
Maximum:	4,666.4	698.1	5,338.0	104,400.0	557.3	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2024 00:00	3,682.3	0.0	3,682.3	104,400.0	384.4	0.5	0.2	0.8
07/17/2024 01:00	3,685.1	0.0	3,685.1	104,400.0	384.7	0.5	0.2	0.8
07/17/2024 02:00	3,684.2	0.0	3,684.2	104,400.0	384.6	0.5	0.2	0.8
07/17/2024 03:00	3,684.9	0.0	3,684.9	104,400.0	384.7	0.5	0.2	0.8
07/17/2024 04:00	3,708.0	0.0	3,708.0	104,400.0	387.1	0.5	0.2	0.8
07/17/2024 05:00	4,030.9	0.0	4,030.9	104,400.0	420.8	0.5	0.3	0.8
07/17/2024 06:00	3,682.8	0.0	3,682.8	104,400.0	384.5	0.5	0.2	0.8
07/17/2024 07:00	3,681.2	0.1	3,681.2	104,400.0	384.3	0.5	0.2	0.8
07/17/2024 08:00	3,675.1	16.1	3,675.1	104,400.0	383.7	0.5	0.2	0.8
07/17/2024 09:00	3,671.5	23.3	3,671.5	104,400.0	383.3	0.5	0.2	0.8
07/17/2024 10:00	3,664.3	30.1	3,664.3	104,400.0	382.6	0.5	0.2	0.8
07/17/2024 11:00	3,654.3	79.3	3,654.3	104,400.0	381.5	0.5	0.2	0.8
07/17/2024 12:00	3,651.5	93.3	3,651.5	104,400.0	381.2	0.5	0.2	0.8
07/17/2024 13:00	3,645.5	72.0	3,645.5	104,400.0	380.6	0.5	0.2	0.8
07/17/2024 14:00	3,637.1	38.1	3,637.1	104,400.0	379.7	0.5	0.2	0.8
07/17/2024 15:00	3,634.7	0.1	3,634.7	104,400.0	379.5	0.5	0.2	0.8
07/17/2024 16:00	3,633.3	12.4	3,633.3	104,400.0	379.3	0.5	0.2	0.8
07/17/2024 17:00	3,974.5	2.4	3,974.5	104,400.0	414.9	0.5	0.2	0.8
07/17/2024 18:00	4,041.4	22.7	4,041.4	104,400.0	421.9	0.5	0.3	0.8
07/17/2024 19:00	4,478.2	0.0	4,478.2	104,400.0	467.5	0.6	0.3	0.9
07/17/2024 20:00	4,594.9	0.0	4,594.9	104,400.0	479.7	0.6	0.3	1.0
07/17/2024 21:00	4,592.0	0.0	4,592.0	104,400.0	479.4	0.6	0.3	1.0
07/17/2024 22:00	4,130.6	0.0	4,130.6	104,400.0	431.2	0.5	0.3	0.9
07/17/2024 23:00	3,673.9	0.0	3,673.9	104,400.0	383.6	0.5	0.2	0.8
Average/Sum#:	3,841.3	16.2	3,841.3	104,400.0	401.0	0.5	0.2	0.8
Minimum:	3,633.3	0.0	3,633.3	104,400.0	379.3	0.5	0.2	0.8
Maximum:	4,594.9	93.3	4,594.9	104,400.0	479.7	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2024 00:00	3,665.4	0.0	3,665.4	104,400.0	382.7	0.5	0.2	0.8
07/18/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/18/2024 02:00	3,662.0	0.0	3,662.0	104,400.0	382.3	0.5	0.2	0.8
07/18/2024 03:00	3,681.8	0.0	3,681.8	104,400.0	384.4	0.5	0.2	0.8
07/18/2024 04:00	3,678.2	0.0	3,678.2	104,400.0	384.0	0.5	0.2	0.8
07/18/2024 05:00	3,676.9	0.0	3,676.9	104,400.0	383.9	0.5	0.2	0.8
07/18/2024 06:00	3,675.9	0.2	3,675.9	104,400.0	383.8	0.5	0.2	0.8
07/18/2024 07:00	3,670.1	1.5	3,670.1	104,400.0	383.2	0.5	0.2	0.8
07/18/2024 08:00	3,664.3	39.3	3,664.3	104,400.0	382.6	0.5	0.2	0.8
07/18/2024 09:00	3,656.5	29.3	3,656.5	104,400.0	381.7	0.5	0.2	0.8
07/18/2024 10:00	3,650.1	32.5	3,650.1	104,400.0	381.1	0.5	0.2	0.8
07/18/2024 11:00	3,848.0	83.0	3,848.0	104,400.0	401.7	0.5	0.2	0.8
07/18/2024 12:00	4,039.3	99.1	4,039.3	104,400.0	421.7	0.5	0.3	0.9
07/18/2024 13:00	4,021.3	77.8	4,021.3	104,400.0	419.8	0.5	0.3	0.9
07/18/2024 14:00	4,392.9	39.3	4,392.9	104,400.0	458.6	0.6	0.3	0.9
07/18/2024 15:00	3,493.1	25.8	3,493.1	104,400.0	364.7	0.6	0.3	0.9
07/18/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/18/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/18/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/18/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/18/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/18/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/18/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/18/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,765.1	28.5	3,765.1	104,400.0	393.1	0.5	0.2	0.8
Minimum:	3,493.1	0.0	3,493.1	104,400.0	364.7	0.5	0.2	0.8
Maximum:	4,392.9	99.1	4,392.9	104,400.0	458.6	0.6	0.3	0.9
%SI	37.50	37.50	37.50	0.00	37.50	37.50	37.50	37.50

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 07:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 08:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 09:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 10:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 11:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 12:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 13:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 14:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 15:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 16:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 17:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 18:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 19:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 20:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 21:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 22:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/19/2024 23:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2024 00:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/20/2024 01:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/20/2024 02:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/20/2024 03:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/20/2024 04:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/20/2024 05:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/20/2024 06:00	0.0	0.0	0.0	104,400.0	0.0	0.0	0.0	0.0
07/20/2024 07:00	2,224.5	0.2	2,224.5	104,400.0	232.2	0.0	0.0	0.0
07/20/2024 08:00	3,758.1	6.6	3,758.1	104,400.0	392.3	0.5	0.2	0.8
07/20/2024 09:00	3,646.7	33.5	3,646.7	104,400.0	380.7	0.5	0.2	0.8
07/20/2024 10:00	3,642.4	53.3	3,642.4	104,400.0	380.3	0.5	0.2	0.8
07/20/2024 11:00	3,775.3	116.8	3,790.5	104,400.0	395.7	0.5	0.2	0.8
07/20/2024 12:00	3,941.6	100.4	3,941.6	104,400.0	411.5	0.5	0.3	0.8
07/20/2024 13:00	4,395.9	79.6	4,395.9	104,400.0	458.9	0.6	0.3	0.9
07/20/2024 14:00	4,474.2	265.9	4,548.7	104,400.0	474.9	0.6	0.3	1.0
07/20/2024 15:00	4,458.9	833.7	5,292.6	104,400.0	552.5	0.7	0.3	1.1
07/20/2024 16:00	4,436.7	862.7	5,299.4	104,400.0	553.3	0.7	0.3	1.1
07/20/2024 17:00	4,453.0	1,296.9	5,749.9	104,400.0	600.3	0.7	0.4	1.2
07/20/2024 18:00	4,481.7	1,561.9	6,043.6	104,400.0	631.0	0.8	0.4	1.3
07/20/2024 19:00	4,523.8	1,493.1	6,016.9	104,400.0	628.2	0.8	0.4	1.3
07/20/2024 20:00	4,558.8	1,454.1	6,012.9	104,400.0	627.7	0.8	0.4	1.3
07/20/2024 21:00	4,591.0	1,398.5	5,989.5	104,400.0	625.3	0.8	0.4	1.3
07/20/2024 22:00	4,621.1	1,346.1	5,967.2	104,400.0	623.0	0.7	0.4	1.2
07/20/2024 23:00	4,636.5	1,267.0	5,903.5	104,400.0	616.3	0.7	0.4	1.2
Average/Sum#:	4,154.1	715.9	4,836.7	104,400.0	504.9	0.7	0.3	1.1
Minimum:	2,224.5	0.2	2,224.5	104,400.0	232.2	0.5	0.2	0.8
Maximum:	4,636.5	1,561.9	6,043.6	104,400.0	631.0	0.8	0.4	1.3
%SI	29.17	29.17	29.17	0.00	29.17	33.33	33.33	33.33

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2024 00:00	4,427.8	303.2	4,640.0	104,400.0	484.4	0.6	0.3	1.0
07/21/2024 01:00	3,669.5	0.3	3,669.5	104,400.0	383.1	0.5	0.2	0.8
07/21/2024 02:00	3,669.4	0.0	3,669.4	104,400.0	383.1	0.5	0.2	0.8
07/21/2024 03:00	3,673.9	0.0	3,673.9	104,400.0	383.6	0.5	0.2	0.8
07/21/2024 04:00	3,674.9	0.0	3,674.9	104,400.0	383.7	0.5	0.2	0.8
07/21/2024 05:00	3,682.7	0.0	3,682.7	104,400.0	384.5	0.5	0.2	0.8
07/21/2024 06:00	3,679.2	0.1	3,679.2	104,400.0	384.1	0.5	0.2	0.8
07/21/2024 07:00	3,679.6	0.0	3,679.6	104,400.0	384.2	0.5	0.2	0.8
07/21/2024 08:00	3,675.4	2.1	3,675.4	104,400.0	383.7	0.5	0.2	0.8
07/21/2024 09:00	3,670.5	9.1	3,670.5	104,400.0	383.2	0.5	0.2	0.8
07/21/2024 10:00	3,665.0	21.2	3,665.0	104,400.0	382.6	0.5	0.2	0.8
07/21/2024 11:00	3,657.3	79.5	3,657.3	104,400.0	381.8	0.5	0.2	0.8
07/21/2024 12:00	3,651.7	100.8	3,651.7	104,400.0	381.2	0.5	0.2	0.8
07/21/2024 13:00	3,647.3	79.0	3,647.3	104,400.0	380.8	0.5	0.2	0.8
07/21/2024 14:00	3,643.0	16.5	3,643.0	104,400.0	380.3	0.5	0.2	0.8
07/21/2024 15:00	3,641.3	10.7	3,641.3	104,400.0	380.2	0.5	0.2	0.8
07/21/2024 16:00	3,639.2	9.0	3,639.2	104,400.0	379.9	0.5	0.2	0.8
07/21/2024 17:00	4,026.1	1.5	4,026.1	104,400.0	420.3	0.5	0.3	0.8
07/21/2024 18:00	4,406.9	9.3	4,406.9	104,400.0	460.1	0.6	0.3	0.9
07/21/2024 19:00	4,305.7	0.0	4,305.7	104,400.0	449.5	0.5	0.3	0.9
07/21/2024 20:00	4,355.8	0.0	4,355.8	104,400.0	454.7	0.5	0.3	0.9
07/21/2024 21:00	4,384.9	0.0	4,384.9	104,400.0	457.8	0.5	0.3	0.9
07/21/2024 22:00	3,920.8	0.0	3,920.8	104,400.0	409.3	0.5	0.2	0.8
07/21/2024 23:00	4,188.0	0.0	4,188.0	104,400.0	437.2	0.5	0.3	0.9
Average/Sum#:	3,859.8	26.8	3,868.7	104,400.0	403.9	0.5	0.2	0.8
Minimum:	3,639.2	0.0	3,639.2	104,400.0	379.9	0.5	0.2	0.8
Maximum:	4,427.8	303.2	4,640.0	104,400.0	484.4	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2024 00:00	3,979.7	0.0	3,979.7	104,400.0	415.5	0.5	0.2	0.8
07/22/2024 01:00	3,666.2	0.0	3,666.2	104,400.0	382.8	0.5	0.2	0.8
07/22/2024 02:00	4,401.2	0.0	4,401.2	104,400.0	459.5	0.6	0.3	0.9
07/22/2024 03:00	4,386.8	0.0	4,386.8	104,400.0	458.0	0.5	0.3	0.9
07/22/2024 04:00	4,541.2	0.1	4,541.2	104,400.0	474.1	0.6	0.3	0.9
07/22/2024 05:00	4,274.7	0.0	4,274.7	104,400.0	446.3	0.5	0.3	0.9
07/22/2024 06:00	3,675.1	0.0	3,675.1	104,400.0	383.7	0.5	0.2	0.8
07/22/2024 07:00	3,666.5	25.4	3,666.5	104,400.0	382.8	0.5	0.2	0.8
07/22/2024 08:00	3,659.5	55.8	3,659.5	104,400.0	382.1	0.5	0.2	0.8
07/22/2024 09:00	3,658.1	37.0	3,658.1	104,400.0	381.9	0.5	0.2	0.8
07/22/2024 10:00	3,648.8	22.2	3,648.8	104,400.0	380.9	0.5	0.2	0.8
07/22/2024 11:00	3,876.3	82.5	3,876.3	104,400.0	404.7	0.5	0.2	0.8
07/22/2024 12:00	4,371.4	95.3	4,371.4	104,400.0	456.4	0.6	0.3	0.9
07/22/2024 13:00	4,407.3	76.3	4,407.3	104,400.0	460.1	0.6	0.3	0.9
07/22/2024 14:00	4,410.9	19.6	4,410.9	104,400.0	460.5	0.6	0.3	0.9
07/22/2024 15:00	4,445.2	1,427.0	5,843.7	104,400.0	610.1	0.7	0.4	1.2
07/22/2024 16:00	4,437.1	1,675.1	6,112.2	104,400.0	638.1	0.8	0.4	1.3
07/22/2024 17:00	4,459.6	1,718.4	6,178.0	104,400.0	645.0	0.8	0.4	1.3
07/22/2024 18:00	4,460.2	1,631.0	6,091.2	104,400.0	635.9	0.8	0.4	1.3
07/22/2024 19:00	4,470.5	1,582.6	6,053.1	104,400.0	631.9	0.8	0.4	1.3
07/22/2024 20:00	4,494.9	1,101.7	5,596.6	104,400.0	584.3	0.7	0.4	1.2
07/22/2024 21:00	4,521.7	1,019.9	5,541.6	104,400.0	578.5	0.7	0.3	1.2
07/22/2024 22:00	4,471.0	361.6	4,659.0	104,400.0	486.4	0.6	0.3	1.0
07/22/2024 23:00	4,423.1	0.0	4,423.1	104,400.0	461.8	0.6	0.3	0.9
Average/Sum#:	4,200.3	455.5	4,630.1	104,400.0	483.4	0.6	0.3	1.0
Minimum:	3,648.8	0.0	3,648.8	104,400.0	380.9	0.5	0.2	0.8
Maximum:	4,541.2	1,718.4	6,178.0	104,400.0	645.0	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2024 00:00	4,283.7	0.0	4,283.7	104,400.0	447.2	0.5	0.3	0.9
07/23/2024 01:00	4,381.5	0.0	4,381.5	104,400.0	457.4	0.6	0.3	0.9
07/23/2024 02:00	4,239.7	0.0	4,239.7	104,400.0	442.6	0.5	0.3	0.9
07/23/2024 03:00	4,151.0	134.9	4,182.0	104,400.0	436.6	0.5	0.3	0.9
07/23/2024 04:00	4,643.4	1,265.4	5,908.8	104,400.0	616.9	0.7	0.4	1.2
07/23/2024 05:00	4,652.3	1,364.2	6,016.5	104,400.0	628.1	0.8	0.4	1.3
07/23/2024 06:00	4,630.1	1,323.8	5,953.9	104,400.0	621.6	0.7	0.4	1.2
07/23/2024 07:00	4,603.7	1,369.1	5,972.8	104,400.0	623.6	0.8	0.4	1.2
07/23/2024 08:00	4,564.7	1,428.6	5,993.3	104,400.0	625.7	0.8	0.4	1.3
07/23/2024 09:00	4,542.4	1,460.6	6,003.0	104,400.0	626.7	0.8	0.4	1.3
07/23/2024 10:00	4,521.0	1,472.5	5,993.5	104,400.0	625.7	0.8	0.4	1.3
07/23/2024 11:00	4,482.2	1,525.8	6,008.0	104,400.0	627.2	0.8	0.4	1.3
07/23/2024 12:00	4,448.1	1,693.0	6,141.1	104,400.0	641.1	0.8	0.4	1.3
07/23/2024 13:00	4,426.5	1,831.3	6,257.8	104,400.0	653.3	0.8	0.4	1.3
07/23/2024 14:00	4,418.9	1,832.8	6,251.7	104,400.0	652.7	0.8	0.4	1.3
07/23/2024 15:00	4,436.1	1,800.6	6,236.7	104,400.0	651.1	0.8	0.4	1.3
07/23/2024 16:00	4,439.2	1,784.5	6,223.7	104,400.0	649.8	0.8	0.4	1.3
07/23/2024 17:00	4,432.7	1,803.9	6,236.6	104,400.0	651.1	0.8	0.4	1.3
07/23/2024 18:00	4,454.6	1,764.3	6,218.9	104,400.0	649.3	0.8	0.4	1.3
07/23/2024 19:00	4,498.2	1,674.8	6,173.0	104,400.0	644.5	0.8	0.4	1.3
07/23/2024 20:00	4,531.6	1,619.7	6,151.3	104,400.0	642.2	0.8	0.4	1.3
07/23/2024 21:00	4,555.1	1,589.5	6,144.6	104,400.0	641.5	0.8	0.4	1.3
07/23/2024 22:00	4,572.7	1,586.7	6,159.4	104,400.0	643.0	0.8	0.4	1.3
07/23/2024 23:00	4,584.2	1,414.7	5,998.9	104,400.0	626.3	0.8	0.4	1.3
Average/Sum#:	4,478.9	1,322.5	5,797.1	104,400.0	605.2	0.7	0.4	1.2
Minimum:	4,151.0	0.0	4,182.0	104,400.0	436.6	0.5	0.3	0.9
Maximum:	4,652.3	1,832.8	6,257.8	104,400.0	653.3	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2024 00:00	4,605.5	629.0	5,234.5	104,400.0	546.5	0.7	0.3	1.1
07/24/2024 01:00	4,067.4	188.4	4,137.1	104,400.0	431.9	0.5	0.3	0.9
07/24/2024 02:00	3,684.6	0.0	3,684.6	104,400.0	384.7	0.5	0.2	0.8
07/24/2024 03:00	3,855.8	0.0	3,855.8	104,400.0	402.5	0.5	0.2	0.8
07/24/2024 04:00	4,616.5	720.1	5,135.0	104,400.0	536.1	0.7	0.3	1.1
07/24/2024 05:00	4,698.3	924.5	5,622.8	104,400.0	587.0	0.7	0.4	1.2
07/24/2024 06:00	4,002.8	25.0	4,003.3	104,400.0	417.9	0.5	0.3	0.8
07/24/2024 07:00	4,126.0	45.9	4,126.0	104,400.0	430.8	0.5	0.3	0.9
07/24/2024 08:00	3,746.0	62.8	3,746.0	104,400.0	391.1	0.5	0.2	0.8
07/24/2024 09:00	4,339.2	42.6	4,342.6	104,400.0	453.4	0.5	0.3	0.9
07/24/2024 10:00	4,401.0	173.7	4,439.2	104,400.0	463.5	0.6	0.3	1.0
07/24/2024 11:00	4,548.6	1,116.2	5,664.8	104,400.0	591.4	0.7	0.4	1.2
07/24/2024 12:00	4,525.9	1,616.4	6,142.3	104,400.0	641.3	0.8	0.4	1.3
07/24/2024 13:00	4,500.0	1,640.7	6,140.7	104,400.0	641.1	0.8	0.4	1.3
07/24/2024 14:00	4,473.6	1,738.7	6,212.3	104,400.0	648.6	0.8	0.4	1.3
07/24/2024 15:00	4,464.5	1,759.2	6,223.7	104,400.0	649.8	0.8	0.4	1.3
07/24/2024 16:00	4,465.3	1,745.7	6,211.0	104,400.0	648.4	0.8	0.4	1.3
07/24/2024 17:00	4,485.3	1,831.3	6,316.6	104,400.0	659.5	0.8	0.4	1.3
07/24/2024 18:00	4,529.5	1,766.7	6,296.2	104,400.0	657.3	0.8	0.4	1.3
07/24/2024 19:00	4,577.9	1,669.1	6,247.0	104,400.0	652.2	0.8	0.4	1.3
07/24/2024 20:00	4,619.5	1,614.0	6,233.5	104,400.0	650.8	0.8	0.4	1.3
07/24/2024 21:00	4,639.8	1,555.0	6,194.8	104,400.0	646.7	0.8	0.4	1.3
07/24/2024 22:00	4,660.5	747.6	5,408.1	104,400.0	564.6	0.7	0.3	1.1
07/24/2024 23:00	4,588.3	563.2	5,027.6	104,400.0	524.9	0.6	0.3	1.1
Average/Sum#:	4,384.2	924.0	5,276.9	104,400.0	550.9	0.7	0.3	1.1
Minimum:	3,684.6	0.0	3,684.6	104,400.0	384.7	0.5	0.2	0.8
Maximum:	4,698.3	1,831.3	6,316.6	104,400.0	659.5	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2024 00:00	4,290.0	0.0	4,290.0	104,400.0	447.9	0.5	0.3	0.9
07/25/2024 01:00	3,953.2	0.0	3,953.2	104,400.0	412.7	0.5	0.2	0.8
07/25/2024 02:00	3,662.2	0.0	3,662.2	104,400.0	382.3	0.5	0.2	0.8
07/25/2024 03:00	3,663.8	0.0	3,663.8	104,400.0	382.5	0.5	0.2	0.8
07/25/2024 04:00	3,939.5	0.0	3,939.5	104,400.0	411.3	0.5	0.2	0.8
07/25/2024 05:00	4,307.7	0.1	4,307.7	104,400.0	449.7	0.5	0.3	0.9
07/25/2024 06:00	3,874.1	0.7	3,874.1	104,400.0	404.5	0.5	0.2	0.8
07/25/2024 07:00	3,664.8	6.0	3,664.8	104,400.0	382.6	0.5	0.2	0.8
07/25/2024 08:00	3,663.3	46.8	3,663.3	104,400.0	382.4	0.5	0.2	0.8
07/25/2024 09:00	3,684.2	40.6	3,684.2	104,400.0	384.6	0.5	0.2	0.8
07/25/2024 10:00	3,682.5	34.0	3,682.5	104,400.0	384.5	0.5	0.2	0.8
07/25/2024 11:00	3,680.0	90.9	3,680.0	104,400.0	384.2	0.5	0.2	0.8
07/25/2024 12:00	4,142.2	108.1	4,142.2	104,400.0	432.4	0.5	0.3	0.9
07/25/2024 13:00	4,576.0	821.2	5,315.1	104,400.0	554.9	0.7	0.3	1.1
07/25/2024 14:00	4,588.1	1,256.7	5,844.8	104,400.0	610.2	0.7	0.4	1.2
07/25/2024 15:00	4,571.4	1,309.9	5,881.3	104,400.0	614.0	0.7	0.4	1.2
07/25/2024 16:00	4,554.2	1,335.1	5,889.3	104,400.0	614.8	0.7	0.4	1.2
07/25/2024 17:00	4,550.9	1,512.7	6,063.6	104,400.0	633.0	0.8	0.4	1.3
07/25/2024 18:00	4,563.1	1,607.9	6,171.0	104,400.0	644.3	0.8	0.4	1.3
07/25/2024 19:00	4,587.1	1,543.6	6,130.7	104,400.0	640.0	0.8	0.4	1.3
07/25/2024 20:00	4,620.5	1,495.4	6,115.9	104,400.0	638.5	0.8	0.4	1.3
07/25/2024 21:00	4,611.4	677.2	5,187.0	104,400.0	541.5	0.7	0.3	1.1
07/25/2024 22:00	4,186.4	0.0	4,186.4	104,400.0	437.1	0.5	0.3	0.9
07/25/2024 23:00	3,663.1	0.0	3,663.1	104,400.0	382.4	0.5	0.2	0.8
Average/Sum#:	4,136.7	495.3	4,610.7	104,400.0	481.3	0.6	0.3	1.0
Minimum:	3,662.2	0.0	3,662.2	104,400.0	382.3	0.5	0.2	0.8
Maximum:	4,620.5	1,607.9	6,171.0	104,400.0	644.3	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2024 00:00	3,658.6	0.0	3,658.6	104,400.0	382.0	0.5	0.2	0.8
07/26/2024 01:00	3,657.9	0.1	3,657.9	104,400.0	381.9	0.5	0.2	0.8
07/26/2024 02:00	3,660.0	0.1	3,660.0	104,400.0	382.1	0.5	0.2	0.8
07/26/2024 03:00	3,659.9	0.0	3,659.9	104,400.0	382.1	0.5	0.2	0.8
07/26/2024 04:00	3,661.8	0.0	3,661.8	104,400.0	382.3	0.5	0.2	0.8
07/26/2024 05:00	3,660.2	0.0	3,660.2	104,400.0	382.1	0.5	0.2	0.8
07/26/2024 06:00	3,653.9	0.1	3,653.9	104,400.0	381.5	0.5	0.2	0.8
07/26/2024 07:00	3,647.8	20.8	3,647.8	104,400.0	380.8	0.5	0.2	0.8
07/26/2024 08:00	3,643.5	64.1	3,643.5	104,400.0	380.4	0.5	0.2	0.8
07/26/2024 09:00	3,639.8	43.9	3,639.8	104,400.0	380.0	0.5	0.2	0.8
07/26/2024 10:00	3,638.8	29.7	3,638.8	104,400.0	379.9	0.5	0.2	0.8
07/26/2024 11:00	3,635.8	94.9	3,635.8	104,400.0	379.6	0.5	0.2	0.8
07/26/2024 12:00	3,641.4	105.2	3,641.4	104,400.0	380.2	0.5	0.2	0.8
07/26/2024 13:00	3,639.7	89.1	3,639.7	104,400.0	380.0	0.5	0.2	0.8
07/26/2024 14:00	3,650.6	29.6	3,650.6	104,400.0	381.1	0.5	0.2	0.8
07/26/2024 15:00	3,649.3	37.9	3,649.3	104,400.0	381.0	0.5	0.2	0.8
07/26/2024 16:00	3,648.1	25.0	3,648.1	104,400.0	380.9	0.5	0.2	0.8
07/26/2024 17:00	3,752.1	44.2	3,755.2	104,400.0	392.0	0.5	0.2	0.8
07/26/2024 18:00	4,493.7	168.4	4,544.2	104,400.0	474.4	0.6	0.3	1.0
07/26/2024 19:00	4,408.2	0.0	4,408.2	104,400.0	460.2	0.6	0.3	0.9
07/26/2024 20:00	4,077.4	0.0	4,077.4	104,400.0	425.7	0.5	0.3	0.9
07/26/2024 21:00	3,656.1	0.1	3,656.1	104,400.0	381.7	0.5	0.2	0.8
07/26/2024 22:00	3,664.5	0.0	3,664.5	104,400.0	382.6	0.5	0.2	0.8
07/26/2024 23:00	3,671.8	0.0	3,671.8	104,400.0	383.3	0.5	0.2	0.8
Average/Sum#:	3,740.5	31.4	3,742.7	104,400.0	390.7	0.5	0.2	0.8
Minimum:	3,635.8	0.0	3,635.8	104,400.0	379.6	0.5	0.2	0.8
Maximum:	4,493.7	168.4	4,544.2	104,400.0	474.4	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2024 00:00	3,675.2	0.0	3,675.2	104,400.0	383.7	0.5	0.2	0.8
07/27/2024 01:00	3,682.9	0.0	3,682.9	104,400.0	384.5	0.5	0.2	0.8
07/27/2024 02:00	3,683.6	0.0	3,683.6	104,400.0	384.6	0.5	0.2	0.8
07/27/2024 03:00	3,685.2	0.0	3,685.2	104,400.0	384.7	0.5	0.2	0.8
07/27/2024 04:00	3,688.6	0.0	3,688.6	104,400.0	385.1	0.5	0.2	0.8
07/27/2024 05:00	3,691.5	0.0	3,691.5	104,400.0	385.4	0.5	0.2	0.8
07/27/2024 06:00	3,692.7	0.0	3,692.7	104,400.0	385.5	0.5	0.2	0.8
07/27/2024 07:00	3,687.4	0.0	3,687.4	104,400.0	385.0	0.5	0.2	0.8
07/27/2024 08:00	3,683.1	0.0	3,683.1	104,400.0	384.5	0.5	0.2	0.8
07/27/2024 09:00	3,682.4	0.0	3,682.4	104,400.0	384.4	0.5	0.2	0.8
07/27/2024 10:00	3,678.9	0.0	3,678.9	104,400.0	384.1	0.5	0.2	0.8
07/27/2024 11:00	3,677.8	53.1	3,677.8	104,400.0	384.0	0.5	0.2	0.8
07/27/2024 12:00	3,672.2	78.7	3,672.2	104,400.0	383.4	0.5	0.2	0.8
07/27/2024 13:00	3,664.5	50.4	3,664.5	104,400.0	382.6	0.5	0.2	0.8
07/27/2024 14:00	3,660.0	0.0	3,660.0	104,400.0	382.1	0.5	0.2	0.8
07/27/2024 15:00	3,655.9	0.0	3,655.9	104,400.0	381.7	0.5	0.2	0.8
07/27/2024 16:00	3,658.0	0.0	3,658.0	104,400.0	381.9	0.5	0.2	0.8
07/27/2024 17:00	3,660.3	0.0	3,660.3	104,400.0	382.1	0.5	0.2	0.8
07/27/2024 18:00	3,666.7	0.0	3,666.7	104,400.0	382.8	0.5	0.2	0.8
07/27/2024 19:00	3,670.5	0.0	3,670.5	104,400.0	383.2	0.5	0.2	0.8
07/27/2024 20:00	3,672.5	0.0	3,672.5	104,400.0	383.4	0.5	0.2	0.8
07/27/2024 21:00	3,675.3	0.0	3,675.3	104,400.0	383.7	0.5	0.2	0.8
07/27/2024 22:00	3,679.2	0.0	3,679.2	104,400.0	384.1	0.5	0.2	0.8
07/27/2024 23:00	3,682.1	0.0	3,682.1	104,400.0	384.4	0.5	0.2	0.8
Average/Sum#:	3,676.1	7.6	3,676.1	104,400.0	383.8	0.5	0.2	0.8
Minimum:	3,655.9	0.0	3,655.9	104,400.0	381.7	0.5	0.2	0.8
Maximum:	3,692.7	78.7	3,692.7	104,400.0	385.5	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2024 00:00	3,683.5	0.0	3,683.5	104,400.0	384.6	0.5	0.2	0.8
07/28/2024 01:00	3,687.6	0.0	3,687.6	104,400.0	385.0	0.5	0.2	0.8
07/28/2024 02:00	3,689.8	0.0	3,689.8	104,400.0	385.2	0.5	0.2	0.8
07/28/2024 03:00	3,689.7	0.0	3,689.7	104,400.0	385.2	0.5	0.2	0.8
07/28/2024 04:00	3,690.3	0.0	3,690.3	104,400.0	385.3	0.5	0.2	0.8
07/28/2024 05:00	3,693.6	0.0	3,693.6	104,400.0	385.6	0.5	0.2	0.8
07/28/2024 06:00	3,693.8	0.0	3,693.8	104,400.0	385.6	0.5	0.2	0.8
07/28/2024 07:00	3,691.6	0.0	3,691.6	104,400.0	385.4	0.5	0.2	0.8
07/28/2024 08:00	3,686.8	0.0	3,686.8	104,400.0	384.9	0.5	0.2	0.8
07/28/2024 09:00	3,682.3	0.0	3,682.3	104,400.0	384.4	0.5	0.2	0.8
07/28/2024 10:00	3,676.6	0.0	3,676.6	104,400.0	383.8	0.5	0.2	0.8
07/28/2024 11:00	3,659.4	46.7	3,659.4	104,400.0	382.0	0.5	0.2	0.8
07/28/2024 12:00	3,656.3	79.4	3,656.3	104,400.0	381.7	0.5	0.2	0.8
07/28/2024 13:00	3,661.4	48.3	3,661.4	104,400.0	382.3	0.5	0.2	0.8
07/28/2024 14:00	3,672.9	0.0	3,672.9	104,400.0	383.5	0.5	0.2	0.8
07/28/2024 15:00	3,674.0	0.0	3,674.0	104,400.0	383.6	0.5	0.2	0.8
07/28/2024 16:00	3,670.3	0.0	3,670.3	104,400.0	383.2	0.5	0.2	0.8
07/28/2024 17:00	3,762.9	0.0	3,762.9	104,400.0	392.8	0.5	0.2	0.8
07/28/2024 18:00	3,657.5	0.0	3,657.5	104,400.0	381.8	0.5	0.2	0.8
07/28/2024 19:00	3,655.3	0.0	3,655.3	104,400.0	381.6	0.5	0.2	0.8
07/28/2024 20:00	3,667.8	0.0	3,667.8	104,400.0	382.9	0.5	0.2	0.8
07/28/2024 21:00	3,677.0	0.0	3,677.0	104,400.0	383.9	0.5	0.2	0.8
07/28/2024 22:00	3,681.9	0.0	3,681.9	104,400.0	384.4	0.5	0.2	0.8
07/28/2024 23:00	3,685.3	0.0	3,685.3	104,400.0	384.7	0.5	0.2	0.8
Average/Sum#:	3,681.2	7.3	3,681.2	104,400.0	384.3	0.5	0.2	0.8
Minimum:	3,655.3	0.0	3,655.3	104,400.0	381.6	0.5	0.2	0.8
Maximum:	3,762.9	79.4	3,762.9	104,400.0	392.8	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2024 00:00	3,692.3	0.0	3,692.3	104,400.0	385.5	0.5	0.2	0.8
07/29/2024 01:00	3,694.5	0.0	3,694.5	104,400.0	385.7	0.5	0.2	0.8
07/29/2024 02:00	3,694.7	0.0	3,694.7	104,400.0	385.7	0.5	0.2	0.8
07/29/2024 03:00	3,698.2	0.0	3,698.2	104,400.0	386.1	0.5	0.2	0.8
07/29/2024 04:00	3,700.4	0.0	3,700.4	104,400.0	386.3	0.5	0.2	0.8
07/29/2024 05:00	3,702.8	0.0	3,702.8	104,400.0	386.6	0.5	0.2	0.8
07/29/2024 06:00	3,699.4	0.0	3,699.4	104,400.0	386.2	0.5	0.2	0.8
07/29/2024 07:00	3,697.1	0.0	3,697.1	104,400.0	386.0	0.5	0.2	0.8
07/29/2024 08:00	3,687.6	0.0	3,687.6	104,400.0	385.0	0.5	0.2	0.8
07/29/2024 09:00	3,681.4	0.1	3,681.4	104,400.0	384.3	0.5	0.2	0.8
07/29/2024 10:00	3,678.0	0.0	3,678.0	104,400.0	384.0	0.5	0.2	0.8
07/29/2024 11:00	3,666.2	63.0	3,666.2	104,400.0	382.8	0.5	0.2	0.8
07/29/2024 12:00	3,656.9	86.4	3,656.9	104,400.0	381.8	0.5	0.2	0.8
07/29/2024 13:00	3,653.4	66.1	3,653.4	104,400.0	381.4	0.5	0.2	0.8
07/29/2024 14:00	3,649.6	0.1	3,649.6	104,400.0	381.0	0.5	0.2	0.8
07/29/2024 15:00	3,646.8	0.0	3,646.8	104,400.0	380.7	0.5	0.2	0.8
07/29/2024 16:00	3,784.2	0.0	3,784.2	104,400.0	395.1	0.5	0.2	0.8
07/29/2024 17:00	4,377.5	411.4	4,570.9	104,400.0	477.2	0.6	0.3	1.0
07/29/2024 18:00	4,626.0	1,072.7	5,698.7	104,400.0	594.9	0.7	0.4	1.2
07/29/2024 19:00	4,652.6	510.4	5,163.0	104,400.0	539.0	0.6	0.3	1.1
07/29/2024 20:00	4,673.9	478.2	5,152.1	104,400.0	537.9	0.6	0.3	1.1
07/29/2024 21:00	4,375.8	219.7	4,490.0	104,400.0	468.8	0.6	0.3	1.0
07/29/2024 22:00	3,673.5	0.0	3,673.5	104,400.0	383.5	0.5	0.2	0.8
07/29/2024 23:00	3,672.9	0.0	3,672.9	104,400.0	383.5	0.5	0.2	0.8
Average/Sum#:	3,864.0	121.2	3,962.7	104,400.0	413.7	0.5	0.2	0.9
Minimum:	3,646.8	0.0	3,646.8	104,400.0	380.7	0.5	0.2	0.8
Maximum:	4,673.9	1,072.7	5,698.7	104,400.0	594.9	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2024 00:00	3,676.3	0.0	3,676.3	104,400.0	383.8	0.5	0.2	0.8
07/30/2024 01:00	3,676.4	0.0	3,676.4	104,400.0	383.8	0.5	0.2	0.8
07/30/2024 02:00	3,677.9	0.0	3,677.9	104,400.0	384.0	0.5	0.2	0.8
07/30/2024 03:00	3,677.2	0.0	3,677.2	104,400.0	383.9	0.5	0.2	0.8
07/30/2024 04:00	3,683.9	0.0	3,683.9	104,400.0	384.6	0.5	0.2	0.8
07/30/2024 05:00	4,006.4	0.0	4,006.4	104,400.0	418.3	0.5	0.3	0.8
07/30/2024 06:00	3,677.2	0.0	3,677.2	104,400.0	383.9	0.5	0.2	0.8
07/30/2024 07:00	3,678.5	0.0	3,678.5	104,400.0	384.0	0.5	0.2	0.8
07/30/2024 08:00	3,671.4	0.0	3,671.4	104,400.0	383.3	0.5	0.2	0.8
07/30/2024 09:00	3,666.9	0.3	3,666.9	104,400.0	382.8	0.5	0.2	0.8
07/30/2024 10:00	3,656.3	0.0	3,656.3	104,400.0	381.7	0.5	0.2	0.8
07/30/2024 11:00	3,647.8	70.6	3,647.8	104,400.0	380.8	0.5	0.2	0.8
07/30/2024 12:00	3,664.9	93.9	3,664.9	104,400.0	382.6	0.5	0.2	0.8
07/30/2024 13:00	3,640.7	54.4	3,640.7	104,400.0	380.1	0.5	0.2	0.8
07/30/2024 14:00	3,635.5	4.1	3,635.5	104,400.0	379.5	0.5	0.2	0.8
07/30/2024 15:00	4,118.8	163.4	4,164.6	104,400.0	434.8	0.5	0.3	0.9
07/30/2024 16:00	4,552.2	1,033.0	5,585.2	104,400.0	583.1	0.7	0.3	1.2
07/30/2024 17:00	4,546.9	1,504.4	6,051.3	104,400.0	631.8	0.8	0.4	1.3
07/30/2024 18:00	4,558.1	1,541.2	6,099.3	104,400.0	636.8	0.8	0.4	1.3
07/30/2024 19:00	4,589.0	1,399.4	5,988.4	104,400.0	625.2	0.8	0.4	1.2
07/30/2024 20:00	4,622.1	1,207.1	5,829.2	104,400.0	608.6	0.7	0.4	1.2
07/30/2024 21:00	4,577.1	609.8	5,046.6	104,400.0	526.9	0.6	0.3	1.1
07/30/2024 22:00	3,675.7	0.0	3,675.7	104,400.0	383.7	0.5	0.2	0.8
07/30/2024 23:00	3,773.8	0.0	3,773.8	104,400.0	394.0	0.5	0.2	0.8
Average/Sum#:	3,931.3	320.1	4,231.3	104,400.0	441.8	0.6	0.3	0.9
Minimum:	3,635.5	0.0	3,635.5	104,400.0	379.5	0.5	0.2	0.8
Maximum:	4,622.1	1,541.2	6,099.3	104,400.0	636.8	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2024 00:00	3,660.3	0.0	3,660.3	104,400.0	382.1	0.5	0.2	0.8
07/31/2024 01:00	3,661.6	0.0	3,661.6	104,400.0	382.3	0.5	0.2	0.8
07/31/2024 02:00	3,664.7	0.0	3,664.7	104,400.0	382.6	0.5	0.2	0.8
07/31/2024 03:00	3,706.9	0.0	3,706.9	104,400.0	387.0	0.5	0.2	0.8
07/31/2024 04:00	4,152.5	0.0	4,152.5	104,400.0	433.5	0.5	0.3	0.9
07/31/2024 05:00	4,207.6	0.0	4,207.6	104,400.0	439.3	0.5	0.3	0.9
07/31/2024 06:00	3,668.3	0.1	3,668.3	104,400.0	383.0	0.5	0.2	0.8
07/31/2024 07:00	3,668.0	0.0	3,668.0	104,400.0	382.9	0.5	0.2	0.8
07/31/2024 08:00	3,661.3	1.8	3,661.3	104,400.0	382.2	0.5	0.2	0.8
07/31/2024 09:00	3,652.2	18.3	3,652.2	104,400.0	381.3	0.5	0.2	0.8
07/31/2024 10:00	3,643.3	2.8	3,643.3	104,400.0	380.4	0.5	0.2	0.8
07/31/2024 11:00	3,672.1	73.4	3,672.1	104,400.0	383.4	0.5	0.2	0.8
07/31/2024 12:00	3,772.9	95.6	3,772.9	104,400.0	393.9	0.5	0.2	0.8
07/31/2024 13:00	3,634.8	60.1	3,634.8	104,400.0	379.5	0.5	0.2	0.8
07/31/2024 14:00	3,810.9	10.5	3,810.9	104,400.0	397.9	0.5	0.2	0.8
07/31/2024 15:00	4,162.7	152.0	4,200.7	104,400.0	438.6	0.5	0.3	0.9
07/31/2024 16:00	4,496.3	1,219.2	5,715.5	104,400.0	596.7	0.7	0.4	1.2
07/31/2024 17:00	4,499.5	1,115.7	5,615.2	104,400.0	586.2	0.7	0.4	1.2
07/31/2024 18:00	4,523.2	1,426.7	5,949.9	104,400.0	621.2	0.7	0.4	1.2
07/31/2024 19:00	4,571.9	988.5	5,560.4	104,400.0	580.5	0.7	0.3	1.2
07/31/2024 20:00	4,590.5	1,336.5	5,927.0	104,400.0	618.8	0.7	0.4	1.2
07/31/2024 21:00	4,594.5	1,201.8	5,796.3	104,400.0	605.1	0.7	0.4	1.2
07/31/2024 22:00	4,615.7	1,065.4	5,681.1	104,400.0	593.1	0.7	0.4	1.2
07/31/2024 23:00	4,572.5	659.0	5,086.5	104,400.0	531.0	0.7	0.3	1.1
Average/Sum#:	4,036.0	392.8	4,407.1	104,400.0	460.1	0.6	0.3	0.9
Minimum:	3,634.8	0.0	3,634.8	104,400.0	379.5	0.5	0.2	0.8
Maximum:	4,615.7	1,426.7	5,949.9	104,400.0	621.2	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2024 00:00	4,226.2	0.0	4,226.2	104,900.0	443.3	0.5	0.3	0.9
08/01/2024 01:00	3,771.4	0.0	3,771.4	104,900.0	395.6	0.5	0.2	0.8
08/01/2024 02:00	3,673.1	0.0	3,673.1	104,900.0	385.3	0.5	0.2	0.8
08/01/2024 03:00	3,758.5	0.0	3,758.5	104,900.0	394.3	0.5	0.2	0.8
08/01/2024 04:00	3,919.7	0.0	3,919.7	104,900.0	411.2	0.5	0.2	0.8
08/01/2024 05:00	4,356.3	0.0	4,356.3	104,900.0	457.0	0.5	0.3	0.9
08/01/2024 06:00	3,725.3	0.0	3,725.3	104,900.0	390.8	0.5	0.2	0.8
08/01/2024 07:00	3,171.8	0.0	3,171.8	104,900.0	332.7	0.5	0.2	0.8
08/01/2024 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
08/01/2024 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
08/01/2024 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
08/01/2024 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
08/01/2024 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
08/01/2024 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
08/01/2024 14:00	1,864.4	14.1	1,864.4	104,900.0	195.6	0.0	0.0	0.0
08/01/2024 15:00	4,209.3	122.6	4,236.3	104,900.0	444.4	0.6	0.3	1.1
08/01/2024 16:00	4,556.1	1,441.2	5,997.3	104,900.0	629.1	0.8	0.4	1.3
08/01/2024 17:00	4,552.7	1,329.6	5,882.3	104,900.0	617.1	0.7	0.4	1.2
08/01/2024 18:00	4,558.2	1,491.1	6,049.3	104,900.0	634.6	0.8	0.4	1.3
08/01/2024 19:00	4,571.6	1,181.6	5,753.2	104,900.0	603.5	0.7	0.4	1.2
08/01/2024 20:00	4,598.0	1,424.1	6,022.1	104,900.0	631.7	0.8	0.4	1.3
08/01/2024 21:00	4,614.0	1,381.7	5,995.7	104,900.0	628.9	0.8	0.4	1.3
08/01/2024 22:00	4,616.0	1,129.0	5,745.0	104,900.0	602.7	0.7	0.4	1.2
08/01/2024 23:00	4,631.4	501.1	5,132.5	104,900.0	538.4	0.6	0.3	1.1
Average/Sum#:	4,076.3	556.5	4,626.7	104,900.0	485.3	0.6	0.3	1.0
Minimum:	1,864.4	0.0	1,864.4	104,900.0	195.6	0.5	0.2	0.8
Maximum:	4,631.4	1,491.1	6,049.3	104,900.0	634.6	0.8	0.4	1.3
%SI	25.00	25.00	25.00	0.00	25.00	29.17	29.17	29.17

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2024 00:00	4,273.5	4.7	4,273.6	104,900.0	448.3	0.5	0.3	0.9
08/02/2024 01:00	3,889.9	0.0	3,889.9	104,900.0	408.1	0.5	0.2	0.8
08/02/2024 02:00	3,676.0	0.0	3,676.0	104,900.0	385.6	0.5	0.2	0.8
08/02/2024 03:00	3,845.2	0.0	3,845.2	104,900.0	403.4	0.5	0.2	0.8
08/02/2024 04:00	4,402.8	0.0	4,402.8	104,900.0	461.9	0.6	0.3	0.9
08/02/2024 05:00	4,385.6	0.0	4,385.6	104,900.0	460.0	0.6	0.3	0.9
08/02/2024 06:00	4,355.0	0.0	4,355.0	104,900.0	456.8	0.5	0.3	0.9
08/02/2024 07:00	4,375.8	0.0	4,375.8	104,900.0	459.0	0.6	0.3	0.9
08/02/2024 08:00	4,424.5	1.4	4,424.5	104,900.0	464.1	0.6	0.3	0.9
08/02/2024 09:00	4,534.8	279.6	4,683.0	104,900.0	491.2	0.6	0.3	1.0
08/02/2024 10:00	4,589.1	1,457.5	6,046.6	104,900.0	634.3	0.8	0.4	1.3
08/02/2024 11:00	4,565.2	1,516.9	6,082.1	104,900.0	638.0	0.8	0.4	1.3
08/02/2024 12:00	4,543.3	1,536.2	6,079.5	104,900.0	637.7	0.8	0.4	1.3
08/02/2024 13:00	4,535.9	1,560.7	6,096.6	104,900.0	639.5	0.8	0.4	1.3
08/02/2024 14:00	4,536.8	1,453.9	5,990.7	104,900.0	628.4	0.8	0.4	1.3
08/02/2024 15:00	4,533.3	1,193.3	5,726.6	104,900.0	600.7	0.7	0.4	1.2
08/02/2024 16:00	4,525.0	665.3	5,190.3	104,900.0	544.5	0.7	0.3	1.1
08/02/2024 17:00	4,526.6	822.5	5,349.1	104,900.0	561.1	0.7	0.3	1.1
08/02/2024 18:00	4,577.3	1,059.7	5,637.0	104,900.0	591.3	0.7	0.4	1.2
08/02/2024 19:00	4,600.8	539.9	5,140.7	104,900.0	539.3	0.7	0.3	1.1
08/02/2024 20:00	4,595.8	539.6	5,135.4	104,900.0	538.7	0.6	0.3	1.1
08/02/2024 21:00	4,544.5	427.6	4,878.0	104,900.0	511.7	0.6	0.3	1.0
08/02/2024 22:00	4,365.1	0.0	4,365.1	104,900.0	457.9	0.6	0.3	0.9
08/02/2024 23:00	4,292.8	0.0	4,292.8	104,900.0	450.3	0.5	0.3	0.9
Average/Sum#:	4,395.6	544.1	4,930.1	104,900.0	517.2	0.6	0.3	1.0
Minimum:	3,676.0	0.0	3,676.0	104,900.0	385.6	0.5	0.2	0.8
Maximum:	4,600.8	1,560.7	6,096.6	104,900.0	639.5	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2024 00:00	4,095.1	0.0	4,095.1	104,900.0	429.6	0.5	0.3	0.9
08/03/2024 01:00	3,748.4	0.0	3,748.4	104,900.0	393.2	0.5	0.2	0.8
08/03/2024 02:00	3,653.3	0.0	3,653.3	104,900.0	383.2	0.5	0.2	0.8
08/03/2024 03:00	3,650.2	0.0	3,650.2	104,900.0	382.9	0.5	0.2	0.8
08/03/2024 04:00	3,651.2	0.0	3,651.2	104,900.0	383.0	0.5	0.2	0.8
08/03/2024 05:00	3,655.7	0.0	3,655.7	104,900.0	383.5	0.5	0.2	0.8
08/03/2024 06:00	3,655.3	0.0	3,655.3	104,900.0	383.4	0.5	0.2	0.8
08/03/2024 07:00	3,652.5	0.1	3,652.5	104,900.0	383.1	0.5	0.2	0.8
08/03/2024 08:00	3,648.8	0.0	3,648.8	104,900.0	382.8	0.5	0.2	0.8
08/03/2024 09:00	3,640.9	34.2	3,640.9	104,900.0	381.9	0.5	0.2	0.8
08/03/2024 10:00	3,634.7	7.1	3,634.7	104,900.0	381.3	0.5	0.2	0.8
08/03/2024 11:00	3,629.3	75.6	3,629.3	104,900.0	380.7	0.5	0.2	0.8
08/03/2024 12:00	3,628.4	79.0	3,628.4	104,900.0	380.6	0.5	0.2	0.8
08/03/2024 13:00	3,625.1	52.4	3,625.1	104,900.0	380.3	0.5	0.2	0.8
08/03/2024 14:00	3,623.4	23.1	3,623.4	104,900.0	380.1	0.5	0.2	0.8
08/03/2024 15:00	3,625.5	0.0	3,625.5	104,900.0	380.3	0.5	0.2	0.8
08/03/2024 16:00	3,624.1	0.1	3,624.1	104,900.0	380.2	0.5	0.2	0.8
08/03/2024 17:00	4,064.4	91.4	4,078.1	104,900.0	427.8	0.5	0.3	0.9
08/03/2024 18:00	4,499.7	1,464.6	5,964.3	104,900.0	625.7	0.8	0.4	1.3
08/03/2024 19:00	4,544.9	1,126.9	5,671.8	104,900.0	595.0	0.7	0.4	1.2
08/03/2024 20:00	4,359.2	406.8	4,574.8	104,900.0	479.9	0.6	0.3	1.0
08/03/2024 21:00	4,095.5	0.0	4,095.5	104,900.0	429.6	0.5	0.3	0.9
08/03/2024 22:00	4,243.4	0.0	4,243.4	104,900.0	445.1	0.5	0.3	0.9
08/03/2024 23:00	3,778.0	0.0	3,778.0	104,900.0	396.3	0.5	0.2	0.8
Average/Sum#:	3,834.5	140.1	3,952.0	104,900.0	414.6	0.5	0.2	0.9
Minimum:	3,623.4	0.0	3,623.4	104,900.0	380.1	0.5	0.2	0.8
Maximum:	4,544.9	1,464.6	5,964.3	104,900.0	625.7	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2024 00:00	3,645.3	0.0	3,645.3	104,900.0	382.4	0.5	0.2	0.8
08/04/2024 01:00	3,648.7	0.0	3,648.7	104,900.0	382.7	0.5	0.2	0.8
08/04/2024 02:00	3,651.3	0.0	3,651.3	104,900.0	383.0	0.5	0.2	0.8
08/04/2024 03:00	3,652.4	0.0	3,652.4	104,900.0	383.1	0.5	0.2	0.8
08/04/2024 04:00	3,656.8	0.0	3,656.8	104,900.0	383.6	0.5	0.2	0.8
08/04/2024 05:00	3,660.2	0.0	3,660.2	104,900.0	384.0	0.5	0.2	0.8
08/04/2024 06:00	3,663.8	0.0	3,663.8	104,900.0	384.3	0.5	0.2	0.8
08/04/2024 07:00	3,660.0	6.5	3,660.0	104,900.0	383.9	0.5	0.2	0.8
08/04/2024 08:00	3,656.5	17.7	3,656.5	104,900.0	383.6	0.5	0.2	0.8
08/04/2024 09:00	3,651.1	16.5	3,651.1	104,900.0	383.0	0.5	0.2	0.8
08/04/2024 10:00	3,646.1	8.7	3,646.1	104,900.0	382.5	0.5	0.2	0.8
08/04/2024 11:00	3,640.5	77.5	3,640.5	104,900.0	381.9	0.5	0.2	0.8
08/04/2024 12:00	3,634.8	95.7	3,634.8	104,900.0	381.3	0.5	0.2	0.8
08/04/2024 13:00	3,625.4	64.7	3,625.4	104,900.0	380.3	0.5	0.2	0.8
08/04/2024 14:00	3,626.1	10.2	3,626.1	104,900.0	380.4	0.5	0.2	0.8
08/04/2024 15:00	3,624.2	0.1	3,624.2	104,900.0	380.2	0.5	0.2	0.8
08/04/2024 16:00	3,621.1	0.5	3,621.1	104,900.0	379.9	0.5	0.2	0.8
08/04/2024 17:00	4,314.2	482.0	4,545.6	104,900.0	476.8	0.6	0.3	1.0
08/04/2024 18:00	4,534.6	1,444.7	5,979.3	104,900.0	627.2	0.8	0.4	1.3
08/04/2024 19:00	4,561.8	763.9	5,325.7	104,900.0	558.7	0.7	0.3	1.1
08/04/2024 20:00	4,575.8	599.3	5,175.1	104,900.0	542.9	0.6	0.3	1.1
08/04/2024 21:00	4,386.3	3.0	4,386.4	104,900.0	460.1	0.6	0.3	0.9
08/04/2024 22:00	4,296.9	0.0	4,296.9	104,900.0	450.7	0.5	0.3	0.9
08/04/2024 23:00	4,002.1	0.0	4,002.1	104,900.0	419.8	0.5	0.3	0.8
Average/Sum#:	3,859.8	149.6	3,986.5	104,900.0	418.2	0.5	0.2	0.9
Minimum:	3,621.1	0.0	3,621.1	104,900.0	379.9	0.5	0.2	0.8
Maximum:	4,575.8	1,444.7	5,979.3	104,900.0	627.2	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2024 00:00	3,742.6	0.0	3,742.6	104,900.0	392.6	0.5	0.2	0.8
08/05/2024 01:00	3,655.9	0.0	3,655.9	104,900.0	383.5	0.5	0.2	0.8
08/05/2024 02:00	3,659.8	0.0	3,659.8	104,900.0	383.9	0.5	0.2	0.8
08/05/2024 03:00	3,661.8	0.0	3,661.8	104,900.0	384.1	0.5	0.2	0.8
08/05/2024 04:00	4,157.0	0.0	4,157.0	104,900.0	436.1	0.5	0.3	0.9
08/05/2024 05:00	4,182.6	0.0	4,182.6	104,900.0	438.8	0.5	0.3	0.9
08/05/2024 06:00	3,922.0	0.2	3,922.0	104,900.0	411.4	0.5	0.2	0.8
08/05/2024 07:00	3,673.5	0.0	3,673.5	104,900.0	385.4	0.5	0.2	0.8
08/05/2024 08:00	3,670.0	0.2	3,670.0	104,900.0	385.0	0.5	0.2	0.8
08/05/2024 09:00	3,666.9	3.2	3,666.9	104,900.0	384.7	0.5	0.2	0.8
08/05/2024 10:00	3,662.9	0.0	3,662.9	104,900.0	384.2	0.5	0.2	0.8
08/05/2024 11:00	3,656.2	73.6	3,656.2	104,900.0	383.5	0.5	0.2	0.8
08/05/2024 12:00	4,086.6	95.2	4,086.6	104,900.0	428.7	0.5	0.3	0.9
08/05/2024 13:00	3,677.9	64.5	3,677.9	104,900.0	385.8	0.5	0.2	0.8
08/05/2024 14:00	3,963.8	0.1	3,963.8	104,900.0	415.8	0.5	0.2	0.8
08/05/2024 15:00	3,658.0	0.0	3,658.0	104,900.0	383.7	0.5	0.2	0.8
08/05/2024 16:00	3,657.3	0.0	3,657.3	104,900.0	383.7	0.5	0.2	0.8
08/05/2024 17:00	3,882.8	0.0	3,882.8	104,900.0	407.3	0.5	0.2	0.8
08/05/2024 18:00	4,584.5	700.7	5,131.0	104,900.0	538.2	0.7	0.3	1.1
08/05/2024 19:00	4,077.8	216.6	4,136.3	104,900.0	433.9	0.5	0.3	0.9
08/05/2024 20:00	3,926.5	0.0	3,926.5	104,900.0	411.9	0.5	0.2	0.8
08/05/2024 21:00	4,128.6	0.0	4,128.6	104,900.0	433.1	0.5	0.3	0.9
08/05/2024 22:00	4,131.5	0.0	4,131.5	104,900.0	433.4	0.5	0.3	0.9
08/05/2024 23:00	3,670.6	0.0	3,670.6	104,900.0	385.0	0.5	0.2	0.8
Average/Sum#:	3,864.9	48.1	3,890.1	104,900.0	408.1	0.5	0.2	0.8
Minimum:	3,655.9	0.0	3,655.9	104,900.0	383.5	0.5	0.2	0.8
Maximum:	4,584.5	700.7	5,131.0	104,900.0	538.2	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2024 00:00	3,661.0	0.0	3,661.0	104,900.0	384.0	0.5	0.2	0.8
08/06/2024 01:00	3,663.1	0.0	3,663.1	104,900.0	384.3	0.5	0.2	0.8
08/06/2024 02:00	3,664.1	0.0	3,664.1	104,900.0	384.4	0.5	0.2	0.8
08/06/2024 03:00	3,665.0	0.0	3,665.0	104,900.0	384.5	0.5	0.2	0.8
08/06/2024 04:00	3,670.7	0.0	3,670.7	104,900.0	385.1	0.5	0.2	0.8
08/06/2024 05:00	3,709.8	0.0	3,709.8	104,900.0	389.2	0.5	0.2	0.8
08/06/2024 06:00	3,731.4	0.0	3,731.4	104,900.0	391.4	0.5	0.2	0.8
08/06/2024 07:00	3,668.5	0.0	3,668.5	104,900.0	384.8	0.5	0.2	0.8
08/06/2024 08:00	3,661.6	20.1	3,661.6	104,900.0	384.1	0.5	0.2	0.8
08/06/2024 09:00	3,650.6	13.0	3,650.6	104,900.0	382.9	0.5	0.2	0.8
08/06/2024 10:00	3,641.6	0.0	3,641.6	104,900.0	382.0	0.5	0.2	0.8
08/06/2024 11:00	3,636.8	68.4	3,636.8	104,900.0	381.5	0.5	0.2	0.8
08/06/2024 12:00	3,630.7	81.9	3,630.7	104,900.0	380.9	0.5	0.2	0.8
08/06/2024 13:00	3,626.9	59.5	3,626.9	104,900.0	380.5	0.5	0.2	0.8
08/06/2024 14:00	3,623.2	1.6	3,623.2	104,900.0	380.1	0.5	0.2	0.8
08/06/2024 15:00	3,621.3	0.1	3,621.3	104,900.0	379.9	0.5	0.2	0.8
08/06/2024 16:00	3,806.8	0.0	3,806.8	104,900.0	399.3	0.5	0.2	0.8
08/06/2024 17:00	4,104.5	148.0	4,138.5	104,900.0	434.1	0.5	0.3	0.9
08/06/2024 18:00	4,544.8	1,387.0	5,931.8	104,900.0	622.2	0.7	0.4	1.2
08/06/2024 19:00	4,571.2	596.0	5,167.2	104,900.0	542.0	0.7	0.3	1.1
08/06/2024 20:00	4,328.3	281.4	4,477.4	104,900.0	469.7	0.6	0.3	1.0
08/06/2024 21:00	4,380.4	0.0	4,380.4	104,900.0	459.5	0.5	0.3	0.9
08/06/2024 22:00	4,263.9	0.0	4,263.9	104,900.0	447.3	0.5	0.3	0.9
08/06/2024 23:00	3,909.3	0.0	3,909.3	104,900.0	410.1	0.5	0.2	0.8
Average/Sum#:	3,851.5	110.7	3,941.7	104,900.0	413.5	0.5	0.2	0.9
Minimum:	3,621.3	0.0	3,621.3	104,900.0	379.9	0.5	0.2	0.8
Maximum:	4,571.2	1,387.0	5,931.8	104,900.0	622.2	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2024 00:00	3,651.7	0.0	3,651.7	104,900.0	383.1	0.5	0.2	0.8
08/07/2024 01:00	3,645.5	0.0	3,645.5	104,900.0	382.4	0.5	0.2	0.8
08/07/2024 02:00	3,647.7	0.0	3,647.7	104,900.0	382.6	0.5	0.2	0.8
08/07/2024 03:00	3,653.6	0.0	3,653.6	104,900.0	383.3	0.5	0.2	0.8
08/07/2024 04:00	3,657.2	0.0	3,657.2	104,900.0	383.6	0.5	0.2	0.8
08/07/2024 05:00	3,681.2	0.0	3,681.2	104,900.0	386.2	0.5	0.2	0.8
08/07/2024 06:00	3,852.2	0.0	3,852.2	104,900.0	404.1	0.5	0.2	0.8
08/07/2024 07:00	3,653.9	3.5	3,653.9	104,900.0	383.3	0.5	0.2	0.8
08/07/2024 08:00	3,647.9	31.6	3,647.9	104,900.0	382.7	0.5	0.2	0.8
08/07/2024 09:00	3,640.5	20.4	3,640.5	104,900.0	381.9	0.5	0.2	0.8
08/07/2024 10:00	3,638.1	0.3	3,638.1	104,900.0	381.6	0.5	0.2	0.8
08/07/2024 11:00	3,634.6	70.3	3,634.6	104,900.0	381.3	0.5	0.2	0.8
08/07/2024 12:00	3,630.3	88.6	3,630.3	104,900.0	380.8	0.5	0.2	0.8
08/07/2024 13:00	3,622.3	61.6	3,622.3	104,900.0	380.0	0.5	0.2	0.8
08/07/2024 14:00	3,619.8	0.3	3,619.8	104,900.0	379.7	0.5	0.2	0.8
08/07/2024 15:00	3,618.0	0.0	3,618.0	104,900.0	379.5	0.5	0.2	0.8
08/07/2024 16:00	3,615.1	0.0	3,615.1	104,900.0	379.2	0.5	0.2	0.8
08/07/2024 17:00	3,827.8	1.2	3,827.8	104,900.0	401.5	0.5	0.2	0.8
08/07/2024 18:00	3,901.2	0.0	3,901.2	104,900.0	409.2	0.5	0.2	0.8
08/07/2024 19:00	4,026.4	0.0	4,026.4	104,900.0	422.4	0.5	0.3	0.8
08/07/2024 20:00	3,818.9	0.0	3,818.9	104,900.0	400.6	0.5	0.2	0.8
08/07/2024 21:00	3,708.3	0.0	3,708.3	104,900.0	389.0	0.5	0.2	0.8
08/07/2024 22:00	3,708.6	0.0	3,708.6	104,900.0	389.0	0.5	0.2	0.8
08/07/2024 23:00	3,668.2	0.0	3,668.2	104,900.0	384.8	0.5	0.2	0.8
Average/Sum#:	3,698.7	11.6	3,698.7	104,900.0	388.0	0.5	0.2	0.8
Minimum:	3,615.1	0.0	3,615.1	104,900.0	379.2	0.5	0.2	0.8
Maximum:	4,026.4	88.6	4,026.4	104,900.0	422.4	0.5	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2024 00:00	3,669.1	0.0	3,669.1	104,900.0	384.9	0.5	0.2	0.8
08/08/2024 01:00	3,671.7	0.0	3,671.7	104,900.0	385.2	0.5	0.2	0.8
08/08/2024 02:00	3,672.4	0.0	3,672.4	104,900.0	385.2	0.5	0.2	0.8
08/08/2024 03:00	3,676.3	0.0	3,676.3	104,900.0	385.6	0.5	0.2	0.8
08/08/2024 04:00	3,665.0	0.0	3,665.0	104,900.0	384.5	0.5	0.2	0.8
08/08/2024 05:00	3,688.7	0.0	3,688.7	104,900.0	386.9	0.5	0.2	0.8
08/08/2024 06:00	3,848.7	0.1	3,848.7	104,900.0	403.7	0.5	0.2	0.8
08/08/2024 07:00	3,656.5	0.0	3,656.5	104,900.0	383.6	0.5	0.2	0.8
08/08/2024 08:00	3,654.3	6.6	3,654.3	104,900.0	383.3	0.5	0.2	0.8
08/08/2024 09:00	3,649.0	0.0	3,649.0	104,900.0	382.8	0.5	0.2	0.8
08/08/2024 10:00	3,646.3	0.0	3,646.3	104,900.0	382.5	0.5	0.2	0.8
08/08/2024 11:00	3,646.9	69.8	3,646.9	104,900.0	382.6	0.5	0.2	0.8
08/08/2024 12:00	3,635.8	90.4	3,635.8	104,900.0	381.4	0.5	0.2	0.8
08/08/2024 13:00	3,631.2	59.5	3,631.2	104,900.0	380.9	0.5	0.2	0.8
08/08/2024 14:00	3,627.2	0.1	3,627.2	104,900.0	380.5	0.5	0.2	0.8
08/08/2024 15:00	3,627.4	0.0	3,627.4	104,900.0	380.5	0.5	0.2	0.8
08/08/2024 16:00	3,621.6	0.0	3,621.6	104,900.0	379.9	0.5	0.2	0.8
08/08/2024 17:00	3,645.3	11.3	3,645.3	104,900.0	382.4	0.5	0.2	0.8
08/08/2024 18:00	3,676.4	1.3	3,676.4	104,900.0	385.7	0.5	0.2	0.8
08/08/2024 19:00	3,636.2	0.0	3,636.2	104,900.0	381.4	0.5	0.2	0.8
08/08/2024 20:00	3,820.3	0.0	3,820.3	104,900.0	400.7	0.5	0.2	0.8
08/08/2024 21:00	3,785.1	0.0	3,785.1	104,900.0	397.1	0.5	0.2	0.8
08/08/2024 22:00	3,650.4	0.0	3,650.4	104,900.0	382.9	0.5	0.2	0.8
08/08/2024 23:00	3,654.1	0.0	3,654.1	104,900.0	383.3	0.5	0.2	0.8
Average/Sum#:	3,673.2	10.0	3,673.2	104,900.0	385.3	0.5	0.2	0.8
Minimum:	3,621.6	0.0	3,621.6	104,900.0	379.9	0.5	0.2	0.8
Maximum:	3,848.7	90.4	3,848.7	104,900.0	403.7	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2024 00:00	3,658.2	0.0	3,658.2	104,900.0	383.7	0.5	0.2	0.8
08/09/2024 01:00	3,660.9	0.0	3,660.9	104,900.0	384.0	0.5	0.2	0.8
08/09/2024 02:00	3,659.8	0.0	3,659.8	104,900.0	383.9	0.5	0.2	0.8
08/09/2024 03:00	3,663.3	0.0	3,663.3	104,900.0	384.3	0.5	0.2	0.8
08/09/2024 04:00	3,664.0	0.0	3,664.0	104,900.0	384.4	0.5	0.2	0.8
08/09/2024 05:00	3,686.3	0.0	3,686.3	104,900.0	386.7	0.5	0.2	0.8
08/09/2024 06:00	4,063.3	0.0	4,063.3	104,900.0	426.2	0.5	0.3	0.9
08/09/2024 07:00	3,668.8	0.0	3,668.8	104,900.0	384.9	0.5	0.2	0.8
08/09/2024 08:00	3,661.6	0.0	3,661.6	104,900.0	384.1	0.5	0.2	0.8
08/09/2024 09:00	3,650.5	0.1	3,650.5	104,900.0	382.9	0.5	0.2	0.8
08/09/2024 10:00	3,642.6	0.0	3,642.6	104,900.0	382.1	0.5	0.2	0.8
08/09/2024 11:00	3,642.3	72.6	3,642.3	104,900.0	382.1	0.5	0.2	0.8
08/09/2024 12:00	3,636.2	88.0	3,636.2	104,900.0	381.4	0.5	0.2	0.8
08/09/2024 13:00	3,625.2	54.9	3,625.2	104,900.0	380.3	0.5	0.2	0.8
08/09/2024 14:00	3,622.3	2.5	3,622.3	104,900.0	380.0	0.5	0.2	0.8
08/09/2024 15:00	3,618.9	0.0	3,618.9	104,900.0	379.6	0.5	0.2	0.8
08/09/2024 16:00	3,617.6	0.0	3,617.6	104,900.0	379.5	0.5	0.2	0.8
08/09/2024 17:00	3,801.5	4.7	3,801.5	104,900.0	398.8	0.5	0.2	0.8
08/09/2024 18:00	3,731.8	0.1	3,731.8	104,900.0	391.5	0.5	0.2	0.8
08/09/2024 19:00	3,660.2	0.0	3,660.2	104,900.0	384.0	0.5	0.2	0.8
08/09/2024 20:00	3,658.4	0.0	3,658.4	104,900.0	383.8	0.5	0.2	0.8
08/09/2024 21:00	3,646.0	0.0	3,646.0	104,900.0	382.5	0.5	0.2	0.8
08/09/2024 22:00	3,650.8	0.0	3,650.8	104,900.0	383.0	0.5	0.2	0.8
08/09/2024 23:00	3,653.3	0.0	3,653.3	104,900.0	383.2	0.5	0.2	0.8
Average/Sum#:	3,676.8	9.3	3,676.8	104,900.0	385.7	0.5	0.2	0.8
Minimum:	3,617.6	0.0	3,617.6	104,900.0	379.5	0.5	0.2	0.8
Maximum:	4,063.3	88.0	4,063.3	104,900.0	426.2	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2024 00:00	3,660.4	0.0	3,660.4	104,900.0	384.0	0.5	0.2	0.8
08/10/2024 01:00	3,663.3	0.0	3,663.3	104,900.0	384.3	0.5	0.2	0.8
08/10/2024 02:00	3,665.6	0.0	3,665.6	104,900.0	384.5	0.5	0.2	0.8
08/10/2024 03:00	3,661.5	0.0	3,661.5	104,900.0	384.1	0.5	0.2	0.8
08/10/2024 04:00	3,661.3	0.0	3,661.3	104,900.0	384.1	0.5	0.2	0.8
08/10/2024 05:00	3,663.5	0.0	3,663.5	104,900.0	384.3	0.5	0.2	0.8
08/10/2024 06:00	3,668.3	0.0	3,668.3	104,900.0	384.8	0.5	0.2	0.8
08/10/2024 07:00	3,668.5	0.0	3,668.5	104,900.0	384.8	0.5	0.2	0.8
08/10/2024 08:00	3,661.0	0.0	3,661.0	104,900.0	384.0	0.5	0.2	0.8
08/10/2024 09:00	3,657.2	0.0	3,657.2	104,900.0	383.6	0.5	0.2	0.8
08/10/2024 10:00	3,658.6	0.0	3,658.6	104,900.0	383.8	0.5	0.2	0.8
08/10/2024 11:00	3,658.8	67.1	3,658.8	104,900.0	383.8	0.5	0.2	0.8
08/10/2024 12:00	3,648.9	79.7	3,648.9	104,900.0	382.8	0.5	0.2	0.8
08/10/2024 13:00	3,759.3	50.7	3,759.3	104,900.0	394.4	0.5	0.2	0.8
08/10/2024 14:00	3,632.8	0.3	3,632.8	104,900.0	381.1	0.5	0.2	0.8
08/10/2024 15:00	3,631.0	0.0	3,631.0	104,900.0	380.9	0.5	0.2	0.8
08/10/2024 16:00	3,630.1	0.0	3,630.1	104,900.0	380.8	0.5	0.2	0.8
08/10/2024 17:00	3,847.5	6.2	3,847.5	104,900.0	403.6	0.5	0.2	0.8
08/10/2024 18:00	3,646.5	0.0	3,646.5	104,900.0	382.5	0.5	0.2	0.8
08/10/2024 19:00	3,638.5	0.0	3,638.5	104,900.0	381.7	0.5	0.2	0.8
08/10/2024 20:00	3,645.0	0.0	3,645.0	104,900.0	382.4	0.5	0.2	0.8
08/10/2024 21:00	3,643.5	0.0	3,643.5	104,900.0	382.2	0.5	0.2	0.8
08/10/2024 22:00	3,644.3	0.0	3,644.3	104,900.0	382.3	0.5	0.2	0.8
08/10/2024 23:00	3,650.0	0.0	3,650.0	104,900.0	382.9	0.5	0.2	0.8
Average/Sum#:	3,665.2	8.5	3,665.2	104,900.0	384.5	0.5	0.2	0.8
Minimum:	3,630.1	0.0	3,630.1	104,900.0	380.8	0.5	0.2	0.8
Maximum:	3,847.5	79.7	3,847.5	104,900.0	403.6	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2024 00:00	3,653.7	0.0	3,653.7	104,900.0	383.3	0.5	0.2	0.8
08/11/2024 01:00	3,655.2	0.0	3,655.2	104,900.0	383.4	0.5	0.2	0.8
08/11/2024 02:00	3,660.5	0.0	3,660.5	104,900.0	384.0	0.5	0.2	0.8
08/11/2024 03:00	3,662.1	0.0	3,662.1	104,900.0	384.2	0.5	0.2	0.8
08/11/2024 04:00	3,663.7	0.0	3,663.7	104,900.0	384.3	0.5	0.2	0.8
08/11/2024 05:00	3,665.4	0.0	3,665.4	104,900.0	384.5	0.5	0.2	0.8
08/11/2024 06:00	3,666.3	0.0	3,666.3	104,900.0	384.6	0.5	0.2	0.8
08/11/2024 07:00	3,665.0	0.0	3,665.0	104,900.0	384.5	0.5	0.2	0.8
08/11/2024 08:00	3,659.1	0.1	3,659.1	104,900.0	383.8	0.5	0.2	0.8
08/11/2024 09:00	3,654.6	0.0	3,654.6	104,900.0	383.4	0.5	0.2	0.8
08/11/2024 10:00	3,646.3	0.0	3,646.3	104,900.0	382.5	0.5	0.2	0.8
08/11/2024 11:00	3,639.9	69.9	3,639.9	104,900.0	381.8	0.5	0.2	0.8
08/11/2024 12:00	4,029.8	31.8	4,029.8	104,900.0	422.7	0.5	0.3	0.9
08/11/2024 13:00	4,467.7	24.3	4,467.7	104,900.0	468.7	0.6	0.3	0.9
08/11/2024 14:00	4,476.1	0.0	4,476.1	104,900.0	469.5	0.6	0.3	0.9
08/11/2024 15:00	4,452.6	0.0	4,452.6	104,900.0	467.1	0.6	0.3	0.9
08/11/2024 16:00	4,385.1	0.0	4,385.1	104,900.0	460.0	0.6	0.3	0.9
08/11/2024 17:00	4,181.3	0.1	4,181.3	104,900.0	438.6	0.5	0.3	0.9
08/11/2024 18:00	4,491.2	120.0	4,518.8	104,900.0	474.0	0.6	0.3	1.0
08/11/2024 19:00	4,601.3	582.0	5,183.3	104,900.0	543.7	0.7	0.3	1.1
08/11/2024 20:00	4,631.1	1,008.4	5,639.5	104,900.0	591.6	0.7	0.4	1.2
08/11/2024 21:00	4,585.9	370.1	4,870.9	104,900.0	511.0	0.6	0.3	1.0
08/11/2024 22:00	3,677.0	0.0	3,677.0	104,900.0	385.7	0.5	0.2	0.8
08/11/2024 23:00	3,674.3	0.0	3,674.3	104,900.0	385.4	0.5	0.2	0.8
Average/Sum#:	3,981.1	91.9	4,060.3	104,900.0	425.9	0.5	0.2	0.9
Minimum:	3,639.9	0.0	3,639.9	104,900.0	381.8	0.5	0.2	0.8
Maximum:	4,631.1	1,008.4	5,639.5	104,900.0	591.6	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2024 00:00	3,677.9	0.0	3,677.9	104,900.0	385.8	0.5	0.2	0.8
08/12/2024 01:00	3,680.7	0.0	3,680.7	104,900.0	386.1	0.5	0.2	0.8
08/12/2024 02:00	3,683.5	0.0	3,683.5	104,900.0	386.4	0.5	0.2	0.8
08/12/2024 03:00	3,685.1	0.0	3,685.1	104,900.0	386.6	0.5	0.2	0.8
08/12/2024 04:00	3,853.6	0.0	3,853.6	104,900.0	404.2	0.5	0.2	0.8
08/12/2024 05:00	4,004.4	0.0	4,004.4	104,900.0	420.1	0.5	0.3	0.8
08/12/2024 06:00	3,686.1	0.0	3,686.1	104,900.0	386.7	0.5	0.2	0.8
08/12/2024 07:00	3,685.7	0.0	3,685.7	104,900.0	386.6	0.5	0.2	0.8
08/12/2024 08:00	3,679.3	0.0	3,679.3	104,900.0	386.0	0.5	0.2	0.8
08/12/2024 09:00	3,675.1	0.0	3,675.1	104,900.0	385.5	0.5	0.2	0.8
08/12/2024 10:00	3,662.4	0.0	3,662.4	104,900.0	384.2	0.5	0.2	0.8
08/12/2024 11:00	3,653.2	55.5	3,653.2	104,900.0	383.2	0.5	0.2	0.8
08/12/2024 12:00	3,644.6	48.8	3,644.6	104,900.0	382.3	0.5	0.2	0.8
08/12/2024 13:00	3,639.5	27.2	3,639.5	104,900.0	381.8	0.5	0.2	0.8
08/12/2024 14:00	3,637.8	0.0	3,637.8	104,900.0	381.6	0.5	0.2	0.8
08/12/2024 15:00	3,639.5	0.0	3,639.5	104,900.0	381.8	0.5	0.2	0.8
08/12/2024 16:00	3,637.5	0.0	3,637.5	104,900.0	381.6	0.5	0.2	0.8
08/12/2024 17:00	4,129.8	117.4	4,155.6	104,900.0	435.9	0.5	0.3	0.9
08/12/2024 18:00	4,611.5	561.5	5,173.0	104,900.0	542.6	0.7	0.3	1.1
08/12/2024 19:00	4,552.4	332.6	4,801.9	104,900.0	503.7	0.6	0.3	1.0
08/12/2024 20:00	3,768.9	0.0	3,768.9	104,900.0	395.4	0.5	0.2	0.8
08/12/2024 21:00	3,649.6	0.0	3,649.6	104,900.0	382.8	0.5	0.2	0.8
08/12/2024 22:00	3,653.7	0.0	3,653.7	104,900.0	383.3	0.5	0.2	0.8
08/12/2024 23:00	3,657.0	0.0	3,657.0	104,900.0	383.6	0.5	0.2	0.8
Average/Sum#:	3,785.4	47.6	3,820.2	104,900.0	400.7	0.5	0.2	0.8
Minimum:	3,637.5	0.0	3,637.5	104,900.0	381.6	0.5	0.2	0.8
Maximum:	4,611.5	561.5	5,173.0	104,900.0	542.6	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2024 00:00	3,655.7	0.0	3,655.7	104,900.0	383.5	0.5	0.2	0.8
08/13/2024 01:00	3,655.4	0.0	3,655.4	104,900.0	383.5	0.5	0.2	0.8
08/13/2024 02:00	3,659.4	0.0	3,659.4	104,900.0	383.9	0.5	0.2	0.8
08/13/2024 03:00	3,662.5	0.0	3,662.5	104,900.0	384.2	0.5	0.2	0.8
08/13/2024 04:00	3,661.8	0.0	3,661.8	104,900.0	384.1	0.5	0.2	0.8
08/13/2024 05:00	3,687.6	0.0	3,687.6	104,900.0	386.8	0.5	0.2	0.8
08/13/2024 06:00	3,667.3	0.0	3,667.3	104,900.0	384.7	0.5	0.2	0.8
08/13/2024 07:00	3,662.6	0.0	3,662.6	104,900.0	384.2	0.5	0.2	0.8
08/13/2024 08:00	3,658.8	0.0	3,658.8	104,900.0	383.8	0.5	0.2	0.8
08/13/2024 09:00	3,654.7	0.0	3,654.7	104,900.0	383.4	0.5	0.2	0.8
08/13/2024 10:00	3,650.9	0.0	3,650.9	104,900.0	383.0	0.5	0.2	0.8
08/13/2024 11:00	3,645.5	57.9	3,645.5	104,900.0	382.4	0.5	0.2	0.8
08/13/2024 12:00	3,640.6	44.3	3,640.6	104,900.0	381.9	0.5	0.2	0.8
08/13/2024 13:00	3,640.7	41.7	3,640.7	104,900.0	381.9	0.5	0.2	0.8
08/13/2024 14:00	3,638.2	0.0	3,638.2	104,900.0	381.6	0.5	0.2	0.8
08/13/2024 15:00	3,635.8	0.0	3,635.8	104,900.0	381.4	0.5	0.2	0.8
08/13/2024 16:00	3,634.8	0.0	3,634.8	104,900.0	381.3	0.5	0.2	0.8
08/13/2024 17:00	4,377.3	505.1	4,645.0	104,900.0	487.3	0.6	0.3	1.0
08/13/2024 18:00	4,595.9	837.7	5,433.6	104,900.0	570.0	0.7	0.3	1.1
08/13/2024 19:00	4,323.4	252.5	4,457.2	104,900.0	467.6	0.6	0.3	1.0
08/13/2024 20:00	3,684.8	0.0	3,684.8	104,900.0	386.5	0.5	0.2	0.8
08/13/2024 21:00	3,702.2	0.0	3,702.2	104,900.0	388.4	0.5	0.2	0.8
08/13/2024 22:00	3,648.7	0.0	3,648.7	104,900.0	382.7	0.5	0.2	0.8
08/13/2024 23:00	3,650.1	0.0	3,650.1	104,900.0	382.9	0.5	0.2	0.8
Average/Sum#:	3,753.9	72.5	3,805.6	104,900.0	399.2	0.5	0.2	0.8
Minimum:	3,634.8	0.0	3,634.8	104,900.0	381.3	0.5	0.2	0.8
Maximum:	4,595.9	837.7	5,433.6	104,900.0	570.0	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2024 00:00	3,653.7	0.0	3,653.7	104,900.0	383.3	0.5	0.2	0.8
08/14/2024 01:00	3,659.5	0.0	3,659.5	104,900.0	383.9	0.5	0.2	0.8
08/14/2024 02:00	3,663.4	0.0	3,663.4	104,900.0	384.3	0.5	0.2	0.8
08/14/2024 03:00	3,665.7	0.0	3,665.7	104,900.0	384.5	0.5	0.2	0.8
08/14/2024 04:00	3,668.8	0.0	3,668.8	104,900.0	384.9	0.5	0.2	0.8
08/14/2024 05:00	3,664.0	0.0	3,664.0	104,900.0	384.4	0.5	0.2	0.8
08/14/2024 06:00	3,666.0	0.0	3,666.0	104,900.0	384.6	0.5	0.2	0.8
08/14/2024 07:00	3,664.2	0.0	3,664.2	104,900.0	384.4	0.5	0.2	0.8
08/14/2024 08:00	3,660.8	0.0	3,660.8	104,900.0	384.0	0.5	0.2	0.8
08/14/2024 09:00	3,653.4	0.0	3,653.4	104,900.0	383.2	0.5	0.2	0.8
08/14/2024 10:00	3,649.7	0.0	3,649.7	104,900.0	382.9	0.5	0.2	0.8
08/14/2024 11:00	3,644.3	63.7	3,644.3	104,900.0	382.3	0.5	0.2	0.8
08/14/2024 12:00	3,639.6	51.4	3,639.6	104,900.0	381.8	0.5	0.2	0.8
08/14/2024 13:00	3,632.4	47.0	3,632.4	104,900.0	381.0	0.5	0.2	0.8
08/14/2024 14:00	3,629.0	0.0	3,629.0	104,900.0	380.7	0.5	0.2	0.8
08/14/2024 15:00	3,625.8	0.0	3,625.8	104,900.0	380.3	0.5	0.2	0.8
08/14/2024 16:00	3,665.3	0.0	3,665.3	104,900.0	384.5	0.5	0.2	0.8
08/14/2024 17:00	4,471.7	813.7	5,204.0	104,900.0	545.9	0.7	0.3	1.1
08/14/2024 18:00	4,546.7	1,562.5	6,109.2	104,900.0	640.9	0.8	0.4	1.3
08/14/2024 19:00	4,575.7	1,566.9	6,142.6	104,900.0	644.4	0.8	0.4	1.3
08/14/2024 20:00	4,552.1	689.4	5,089.8	104,900.0	533.9	0.7	0.3	1.1
08/14/2024 21:00	4,236.1	0.0	4,236.1	104,900.0	444.4	0.5	0.3	0.9
08/14/2024 22:00	3,699.2	0.0	3,699.2	104,900.0	388.0	0.5	0.2	0.8
08/14/2024 23:00	4,201.7	0.0	4,201.7	104,900.0	440.8	0.5	0.3	0.9
Average/Sum#:	3,849.5	199.8	4,032.8	104,900.0	423.1	0.5	0.2	0.9
Minimum:	3,625.8	0.0	3,625.8	104,900.0	380.3	0.5	0.2	0.8
Maximum:	4,575.7	1,566.9	6,142.6	104,900.0	644.4	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2024 00:00	3,651.9	0.0	3,651.9	104,900.0	383.1	0.5	0.2	0.8
08/15/2024 01:00	3,655.6	0.0	3,655.6	104,900.0	383.5	0.5	0.2	0.8
08/15/2024 02:00	3,661.5	0.0	3,661.5	104,900.0	384.1	0.5	0.2	0.8
08/15/2024 03:00	3,661.7	0.0	3,661.7	104,900.0	384.1	0.5	0.2	0.8
08/15/2024 04:00	3,822.0	0.0	3,822.0	104,900.0	400.9	0.5	0.2	0.8
08/15/2024 05:00	4,039.9	0.0	4,039.9	104,900.0	423.8	0.5	0.3	0.8
08/15/2024 06:00	3,667.4	0.0	3,667.4	104,900.0	384.7	0.5	0.2	0.8
08/15/2024 07:00	3,667.3	0.0	3,667.3	104,900.0	384.7	0.5	0.2	0.8
08/15/2024 08:00	3,658.1	0.0	3,658.1	104,900.0	383.7	0.5	0.2	0.8
08/15/2024 09:00	3,649.6	0.0	3,649.6	104,900.0	382.8	0.5	0.2	0.8
08/15/2024 10:00	3,645.4	0.0	3,645.4	104,900.0	382.4	0.5	0.2	0.8
08/15/2024 11:00	3,636.7	52.1	3,636.7	104,900.0	381.5	0.5	0.2	0.8
08/15/2024 12:00	3,626.6	27.4	3,626.6	104,900.0	380.4	0.5	0.2	0.8
08/15/2024 13:00	3,617.8	26.6	3,617.8	104,900.0	379.5	0.5	0.2	0.8
08/15/2024 14:00	3,611.8	0.0	3,611.8	104,900.0	378.9	0.5	0.2	0.8
08/15/2024 15:00	4,043.6	163.2	4,089.3	104,900.0	429.0	0.5	0.3	0.9
08/15/2024 16:00	4,536.2	675.1	5,211.3	104,900.0	546.7	0.7	0.3	1.1
08/15/2024 17:00	4,527.7	1,138.1	5,665.8	104,900.0	594.3	0.7	0.4	1.2
08/15/2024 18:00	4,538.3	1,428.1	5,966.4	104,900.0	625.9	0.8	0.4	1.3
08/15/2024 19:00	4,574.9	1,166.8	5,741.7	104,900.0	602.3	0.7	0.4	1.2
08/15/2024 20:00	4,268.0	296.8	4,416.4	104,900.0	463.3	0.6	0.3	1.0
08/15/2024 21:00	3,648.3	0.0	3,648.3	104,900.0	382.7	0.5	0.2	0.8
08/15/2024 22:00	3,642.7	0.0	3,642.7	104,900.0	382.1	0.5	0.2	0.8
08/15/2024 23:00	3,690.4	0.0	3,690.4	104,900.0	387.1	0.5	0.2	0.8
Average/Sum#:	3,864.3	207.3	4,056.1	104,900.0	425.5	0.5	0.2	0.9
Minimum:	3,611.8	0.0	3,611.8	104,900.0	378.9	0.5	0.2	0.8
Maximum:	4,574.9	1,428.1	5,966.4	104,900.0	625.9	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2024 00:00	3,648.9	0.0	3,648.9	104,900.0	382.8	0.5	0.2	0.8
08/16/2024 01:00	3,650.3	0.0	3,650.3	104,900.0	382.9	0.5	0.2	0.8
08/16/2024 02:00	3,655.5	0.0	3,655.5	104,900.0	383.5	0.5	0.2	0.8
08/16/2024 03:00	3,657.6	0.0	3,657.6	104,900.0	383.7	0.5	0.2	0.8
08/16/2024 04:00	3,963.3	0.0	3,963.3	104,900.0	415.8	0.5	0.2	0.8
08/16/2024 05:00	4,090.0	0.0	4,090.0	104,900.0	429.0	0.5	0.3	0.9
08/16/2024 06:00	3,667.1	0.0	3,667.1	104,900.0	384.7	0.5	0.2	0.8
08/16/2024 07:00	3,665.3	0.0	3,665.3	104,900.0	384.5	0.5	0.2	0.8
08/16/2024 08:00	3,654.5	0.0	3,654.5	104,900.0	383.4	0.5	0.2	0.8
08/16/2024 09:00	3,643.2	0.0	3,643.2	104,900.0	382.2	0.5	0.2	0.8
08/16/2024 10:00	3,636.0	0.0	3,636.0	104,900.0	381.4	0.5	0.2	0.8
08/16/2024 11:00	3,629.0	62.1	3,629.0	104,900.0	380.7	0.5	0.2	0.8
08/16/2024 12:00	3,623.1	39.8	3,623.1	104,900.0	380.1	0.5	0.2	0.8
08/16/2024 13:00	3,660.1	42.7	3,660.1	104,900.0	383.9	0.5	0.2	0.8
08/16/2024 14:00	3,617.6	0.0	3,617.6	104,900.0	379.5	0.5	0.2	0.8
08/16/2024 15:00	3,615.7	0.0	3,615.7	104,900.0	379.3	0.5	0.2	0.8
08/16/2024 16:00	3,612.7	0.0	3,612.7	104,900.0	379.0	0.5	0.2	0.8
08/16/2024 17:00	3,637.0	0.0	3,637.0	104,900.0	381.5	0.5	0.2	0.8
08/16/2024 18:00	3,623.6	0.0	3,623.6	104,900.0	380.1	0.5	0.2	0.8
08/16/2024 19:00	3,650.6	0.0	3,650.6	104,900.0	382.9	0.5	0.2	0.8
08/16/2024 20:00	3,639.1	0.0	3,639.1	104,900.0	381.7	0.5	0.2	0.8
08/16/2024 21:00	4,366.4	0.0	4,366.4	104,900.0	458.0	0.5	0.3	0.9
08/16/2024 22:00	4,254.4	0.0	4,254.4	104,900.0	446.3	0.5	0.3	0.9
08/16/2024 23:00	4,167.4	0.0	4,167.4	104,900.0	437.2	0.5	0.3	0.9
Average/Sum#:	3,751.2	6.0	3,751.2	104,900.0	393.5	0.5	0.2	0.8
Minimum:	3,612.7	0.0	3,612.7	104,900.0	379.0	0.5	0.2	0.8
Maximum:	4,366.4	62.1	4,366.4	104,900.0	458.0	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2024 00:00	3,996.3	0.0	3,996.3	104,900.0	419.2	0.5	0.3	0.8
08/17/2024 01:00	3,646.8	0.0	3,646.8	104,900.0	382.5	0.5	0.2	0.8
08/17/2024 02:00	3,648.8	0.0	3,648.8	104,900.0	382.8	0.5	0.2	0.8
08/17/2024 03:00	3,651.6	0.0	3,651.6	104,900.0	383.1	0.5	0.2	0.8
08/17/2024 04:00	3,658.8	0.0	3,658.8	104,900.0	383.8	0.5	0.2	0.8
08/17/2024 05:00	4,002.7	0.0	4,002.7	104,900.0	419.9	0.5	0.3	0.8
08/17/2024 06:00	3,654.4	0.0	3,654.4	104,900.0	383.3	0.5	0.2	0.8
08/17/2024 07:00	3,653.9	0.0	3,653.9	104,900.0	383.3	0.5	0.2	0.8
08/17/2024 08:00	3,651.2	0.0	3,651.2	104,900.0	383.0	0.5	0.2	0.8
08/17/2024 09:00	3,645.0	0.0	3,645.0	104,900.0	382.4	0.5	0.2	0.8
08/17/2024 10:00	3,636.9	0.0	3,636.9	104,900.0	381.5	0.5	0.2	0.8
08/17/2024 11:00	3,630.5	37.2	3,630.5	104,900.0	380.8	0.5	0.2	0.8
08/17/2024 12:00	3,628.3	29.3	3,628.3	104,900.0	380.6	0.5	0.2	0.8
08/17/2024 13:00	3,625.6	28.1	3,625.6	104,900.0	380.3	0.5	0.2	0.8
08/17/2024 14:00	3,630.0	0.0	3,630.0	104,900.0	380.8	0.5	0.2	0.8
08/17/2024 15:00	3,631.0	0.0	3,631.0	104,900.0	380.9	0.5	0.2	0.8
08/17/2024 16:00	3,630.6	0.0	3,630.6	104,900.0	380.8	0.5	0.2	0.8
08/17/2024 17:00	3,677.5	0.0	3,677.5	104,900.0	385.8	0.5	0.2	0.8
08/17/2024 18:00	3,641.0	0.0	3,641.0	104,900.0	381.9	0.5	0.2	0.8
08/17/2024 19:00	3,642.9	0.0	3,642.9	104,900.0	382.1	0.5	0.2	0.8
08/17/2024 20:00	3,643.4	0.0	3,643.4	104,900.0	382.2	0.5	0.2	0.8
08/17/2024 21:00	3,645.6	0.0	3,645.6	104,900.0	382.4	0.5	0.2	0.8
08/17/2024 22:00	3,648.4	0.0	3,648.4	104,900.0	382.7	0.5	0.2	0.8
08/17/2024 23:00	3,649.7	0.0	3,649.7	104,900.0	382.9	0.5	0.2	0.8
Average/Sum#:	3,673.8	3.9	3,673.8	104,900.0	385.4	0.5	0.2	0.8
Minimum:	3,625.6	0.0	3,625.6	104,900.0	380.3	0.5	0.2	0.8
Maximum:	4,002.7	37.2	4,002.7	104,900.0	419.9	0.5	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2024 00:00	3,656.2	0.0	3,656.2	104,900.0	383.5	0.5	0.2	0.8
08/18/2024 01:00	3,657.5	0.0	3,657.5	104,900.0	383.7	0.5	0.2	0.8
08/18/2024 02:00	3,657.4	0.0	3,657.4	104,900.0	383.7	0.5	0.2	0.8
08/18/2024 03:00	3,659.5	0.0	3,659.5	104,900.0	383.9	0.5	0.2	0.8
08/18/2024 04:00	3,663.3	0.0	3,663.3	104,900.0	384.3	0.5	0.2	0.8
08/18/2024 05:00	3,665.0	0.0	3,665.0	104,900.0	384.5	0.5	0.2	0.8
08/18/2024 06:00	3,662.5	0.0	3,662.5	104,900.0	384.2	0.5	0.2	0.8
08/18/2024 07:00	3,661.5	0.0	3,661.5	104,900.0	384.1	0.5	0.2	0.8
08/18/2024 08:00	3,659.3	0.0	3,659.3	104,900.0	383.9	0.5	0.2	0.8
08/18/2024 09:00	3,652.0	0.0	3,652.0	104,900.0	383.1	0.5	0.2	0.8
08/18/2024 10:00	3,645.3	0.0	3,645.3	104,900.0	382.4	0.5	0.2	0.8
08/18/2024 11:00	3,639.1	22.0	3,639.1	104,900.0	381.7	0.5	0.2	0.8
08/18/2024 12:00	3,634.7	30.5	3,634.7	104,900.0	381.3	0.5	0.2	0.8
08/18/2024 13:00	3,634.1	13.5	3,634.1	104,900.0	381.2	0.5	0.2	0.8
08/18/2024 14:00	3,631.2	0.0	3,631.2	104,900.0	380.9	0.5	0.2	0.8
08/18/2024 15:00	3,628.7	0.0	3,628.7	104,900.0	380.7	0.5	0.2	0.8
08/18/2024 16:00	3,705.7	0.0	3,705.7	104,900.0	388.7	0.5	0.2	0.8
08/18/2024 17:00	3,701.1	0.0	3,701.1	104,900.0	388.2	0.5	0.2	0.8
08/18/2024 18:00	3,633.5	0.0	3,633.5	104,900.0	381.2	0.5	0.2	0.8
08/18/2024 19:00	3,641.0	0.0	3,641.0	104,900.0	381.9	0.5	0.2	0.8
08/18/2024 20:00	3,650.6	0.0	3,650.6	104,900.0	382.9	0.5	0.2	0.8
08/18/2024 21:00	3,672.8	0.0	3,672.8	104,900.0	385.3	0.5	0.2	0.8
08/18/2024 22:00	3,649.6	0.0	3,649.6	104,900.0	382.8	0.5	0.2	0.8
08/18/2024 23:00	3,695.7	0.0	3,695.7	104,900.0	387.7	0.5	0.2	0.8
Average/Sum#:	3,656.6	2.8	3,656.6	104,900.0	383.6	0.5	0.2	0.8
Minimum:	3,628.7	0.0	3,628.7	104,900.0	380.7	0.5	0.2	0.8
Maximum:	3,705.7	30.5	3,705.7	104,900.0	388.7	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2024 00:00	3,658.4	0.0	3,658.4	104,900.0	383.8	0.5	0.2	0.8
08/19/2024 01:00	3,658.2	0.0	3,658.2	104,900.0	383.7	0.5	0.2	0.8
08/19/2024 02:00	3,659.3	0.0	3,659.3	104,900.0	383.9	0.5	0.2	0.8
08/19/2024 03:00	3,660.2	0.0	3,660.2	104,900.0	384.0	0.5	0.2	0.8
08/19/2024 04:00	4,096.1	0.0	4,096.1	104,900.0	429.7	0.5	0.3	0.9
08/19/2024 05:00	4,172.9	0.0	4,172.9	104,900.0	437.7	0.5	0.3	0.9
08/19/2024 06:00	3,666.5	0.0	3,666.5	104,900.0	384.6	0.5	0.2	0.8
08/19/2024 07:00	3,665.0	0.0	3,665.0	104,900.0	384.5	0.5	0.2	0.8
08/19/2024 08:00	3,661.7	0.0	3,661.7	104,900.0	384.1	0.5	0.2	0.8
08/19/2024 09:00	3,658.8	0.0	3,658.8	104,900.0	383.8	0.5	0.2	0.8
08/19/2024 10:00	3,647.8	0.0	3,647.8	104,900.0	382.7	0.5	0.2	0.8
08/19/2024 11:00	3,639.1	1.9	3,639.1	104,900.0	381.7	0.5	0.2	0.8
08/19/2024 12:00	3,636.8	33.3	3,636.8	104,900.0	381.5	0.5	0.2	0.8
08/19/2024 13:00	3,629.6	22.7	3,629.6	104,900.0	380.7	0.5	0.2	0.8
08/19/2024 14:00	3,627.3	0.0	3,627.3	104,900.0	380.5	0.5	0.2	0.8
08/19/2024 15:00	3,626.5	0.0	3,626.5	104,900.0	380.4	0.5	0.2	0.8
08/19/2024 16:00	3,625.3	0.0	3,625.3	104,900.0	380.3	0.5	0.2	0.8
08/19/2024 17:00	3,626.4	0.0	3,626.4	104,900.0	380.4	0.5	0.2	0.8
08/19/2024 18:00	3,633.0	0.0	3,633.0	104,900.0	381.1	0.5	0.2	0.8
08/19/2024 19:00	3,636.6	0.0	3,636.6	104,900.0	381.5	0.5	0.2	0.8
08/19/2024 20:00	3,641.6	0.0	3,641.6	104,900.0	382.0	0.5	0.2	0.8
08/19/2024 21:00	4,030.2	0.0	4,030.2	104,900.0	422.8	0.5	0.3	0.8
08/19/2024 22:00	3,647.4	0.0	3,647.4	104,900.0	382.6	0.5	0.2	0.8
08/19/2024 23:00	3,648.0	0.0	3,648.0	104,900.0	382.7	0.5	0.2	0.8
Average/Sum#:	3,702.2	2.4	3,702.2	104,900.0	388.4	0.5	0.2	0.8
Minimum:	3,625.3	0.0	3,625.3	104,900.0	380.3	0.5	0.2	0.8
Maximum:	4,172.9	33.3	4,172.9	104,900.0	437.7	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2024 00:00	3,651.1	0.0	3,651.1	104,900.0	383.0	0.5	0.2	0.8
08/20/2024 01:00	3,653.3	0.0	3,653.3	104,900.0	383.2	0.5	0.2	0.8
08/20/2024 02:00	3,652.0	0.0	3,652.0	104,900.0	383.1	0.5	0.2	0.8
08/20/2024 03:00	3,656.2	0.0	3,656.2	104,900.0	383.5	0.5	0.2	0.8
08/20/2024 04:00	3,658.4	0.0	3,658.4	104,900.0	383.8	0.5	0.2	0.8
08/20/2024 05:00	3,660.7	0.0	3,660.7	104,900.0	384.0	0.5	0.2	0.8
08/20/2024 06:00	3,659.6	0.0	3,659.6	104,900.0	383.9	0.5	0.2	0.8
08/20/2024 07:00	3,657.4	0.0	3,657.4	104,900.0	383.7	0.5	0.2	0.8
08/20/2024 08:00	3,656.2	0.0	3,656.2	104,900.0	383.5	0.5	0.2	0.8
08/20/2024 09:00	3,656.6	0.0	3,656.6	104,900.0	383.6	0.5	0.2	0.8
08/20/2024 10:00	3,651.8	0.0	3,651.8	104,900.0	383.1	0.5	0.2	0.8
08/20/2024 11:00	3,648.1	0.0	3,648.1	104,900.0	382.7	0.5	0.2	0.8
08/20/2024 12:00	3,645.5	22.2	3,645.5	104,900.0	382.4	0.5	0.2	0.8
08/20/2024 13:00	3,641.2	32.2	3,641.2	104,900.0	382.0	0.5	0.2	0.8
08/20/2024 14:00	3,637.3	0.0	3,637.3	104,900.0	381.6	0.5	0.2	0.8
08/20/2024 15:00	3,640.8	0.0	3,640.8	104,900.0	381.9	0.5	0.2	0.8
08/20/2024 16:00	3,636.5	0.0	3,636.5	104,900.0	381.5	0.5	0.2	0.8
08/20/2024 17:00	3,821.9	0.0	3,821.9	104,900.0	400.9	0.5	0.2	0.8
08/20/2024 18:00	3,643.0	0.0	3,643.0	104,900.0	382.2	0.5	0.2	0.8
08/20/2024 19:00	3,648.6	0.0	3,648.6	104,900.0	382.7	0.5	0.2	0.8
08/20/2024 20:00	3,644.1	0.0	3,644.1	104,900.0	382.3	0.5	0.2	0.8
08/20/2024 21:00	3,614.5	0.0	3,614.5	104,900.0	379.2	0.5	0.2	0.8
08/20/2024 22:00	3,625.4	0.0	3,625.4	104,900.0	380.3	0.5	0.2	0.8
08/20/2024 23:00	3,624.8	0.0	3,624.8	104,900.0	380.2	0.5	0.2	0.8
Average/Sum#:	3,653.5	2.3	3,653.5	104,900.0	383.3	0.5	0.2	0.8
Minimum:	3,614.5	0.0	3,614.5	104,900.0	379.2	0.5	0.2	0.8
Maximum:	3,821.9	32.2	3,821.9	104,900.0	400.9	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2024 00:00	3,623.3	0.0	3,623.3	104,900.0	380.1	0.5	0.2	0.8
08/21/2024 01:00	3,627.5	0.0	3,627.5	104,900.0	380.5	0.5	0.2	0.8
08/21/2024 02:00	3,629.8	0.0	3,629.8	104,900.0	380.8	0.5	0.2	0.8
08/21/2024 03:00	3,635.2	0.0	3,635.2	104,900.0	381.3	0.5	0.2	0.8
08/21/2024 04:00	3,638.1	0.0	3,638.1	104,900.0	381.6	0.5	0.2	0.8
08/21/2024 05:00	3,650.1	0.0	3,650.1	104,900.0	382.9	0.5	0.2	0.8
08/21/2024 06:00	3,644.2	0.0	3,644.2	104,900.0	382.3	0.5	0.2	0.8
08/21/2024 07:00	3,650.7	0.0	3,650.7	104,900.0	383.0	0.5	0.2	0.8
08/21/2024 08:00	3,650.5	0.0	3,650.5	104,900.0	382.9	0.5	0.2	0.8
08/21/2024 09:00	3,644.9	0.0	3,644.9	104,900.0	382.4	0.5	0.2	0.8
08/21/2024 10:00	3,635.7	0.0	3,635.7	104,900.0	381.4	0.5	0.2	0.8
08/21/2024 11:00	3,628.8	0.0	3,628.8	104,900.0	380.7	0.5	0.2	0.8
08/21/2024 12:00	3,627.4	19.9	3,627.4	104,900.0	380.5	0.5	0.2	0.8
08/21/2024 13:00	3,624.5	26.6	3,624.5	104,900.0	380.2	0.5	0.2	0.8
08/21/2024 14:00	3,619.1	0.0	3,619.1	104,900.0	379.6	0.5	0.2	0.8
08/21/2024 15:00	3,619.8	0.0	3,619.8	104,900.0	379.7	0.5	0.2	0.8
08/21/2024 16:00	3,711.2	0.0	3,711.2	104,900.0	389.3	0.5	0.2	0.8
08/21/2024 17:00	3,709.9	0.0	3,709.9	104,900.0	389.2	0.5	0.2	0.8
08/21/2024 18:00	3,631.6	0.0	3,631.6	104,900.0	381.0	0.5	0.2	0.8
08/21/2024 19:00	3,626.8	0.0	3,626.8	104,900.0	380.5	0.5	0.2	0.8
08/21/2024 20:00	3,611.6	0.0	3,611.6	104,900.0	378.9	0.5	0.2	0.8
08/21/2024 21:00	3,632.0	0.0	3,632.0	104,900.0	381.0	0.5	0.2	0.8
08/21/2024 22:00	3,607.5	0.0	3,607.5	104,900.0	378.4	0.5	0.2	0.8
08/21/2024 23:00	3,606.7	0.0	3,606.7	104,900.0	378.3	0.5	0.2	0.8
Average/Sum#:	3,637.0	1.9	3,637.0	104,900.0	381.5	0.5	0.2	0.8
Minimum:	3,606.7	0.0	3,606.7	104,900.0	378.3	0.5	0.2	0.8
Maximum:	3,711.2	26.6	3,711.2	104,900.0	389.3	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2024 00:00	3,614.2	0.0	3,614.2	104,900.0	379.1	0.5	0.2	0.8
08/22/2024 01:00	3,623.8	0.0	3,623.8	104,900.0	380.1	0.5	0.2	0.8
08/22/2024 02:00	3,632.3	0.0	3,632.3	104,900.0	381.0	0.5	0.2	0.8
08/22/2024 03:00	3,639.0	0.0	3,639.0	104,900.0	381.7	0.5	0.2	0.8
08/22/2024 04:00	3,642.8	0.0	3,642.8	104,900.0	382.1	0.5	0.2	0.8
08/22/2024 05:00	3,770.9	0.0	3,770.9	104,900.0	395.6	0.5	0.2	0.8
08/22/2024 06:00	3,660.6	0.0	3,660.6	104,900.0	384.0	0.5	0.2	0.8
08/22/2024 07:00	3,661.3	0.0	3,661.3	104,900.0	384.1	0.5	0.2	0.8
08/22/2024 08:00	3,655.6	0.0	3,655.6	104,900.0	383.5	0.5	0.2	0.8
08/22/2024 09:00	3,648.8	0.0	3,648.8	104,900.0	382.8	0.5	0.2	0.8
08/22/2024 10:00	3,645.6	0.0	3,645.6	104,900.0	382.4	0.5	0.2	0.8
08/22/2024 11:00	3,641.5	0.0	3,641.5	104,900.0	382.0	0.5	0.2	0.8
08/22/2024 12:00	3,636.2	1.7	3,636.2	104,900.0	381.4	0.5	0.2	0.8
08/22/2024 13:00	3,634.4	0.0	3,634.4	104,900.0	381.2	0.5	0.2	0.8
08/22/2024 14:00	3,634.1	0.0	3,634.1	104,900.0	381.2	0.5	0.2	0.8
08/22/2024 15:00	3,633.6	0.0	3,633.6	104,900.0	381.2	0.5	0.2	0.8
08/22/2024 16:00	3,635.8	0.0	3,635.8	104,900.0	381.4	0.5	0.2	0.8
08/22/2024 17:00	3,637.3	0.0	3,637.3	104,900.0	381.6	0.5	0.2	0.8
08/22/2024 18:00	3,643.3	0.0	3,643.3	104,900.0	382.2	0.5	0.2	0.8
08/22/2024 19:00	3,648.9	0.0	3,648.9	104,900.0	382.8	0.5	0.2	0.8
08/22/2024 20:00	3,654.2	0.0	3,654.2	104,900.0	383.3	0.5	0.2	0.8
08/22/2024 21:00	3,655.9	0.0	3,655.9	104,900.0	383.5	0.5	0.2	0.8
08/22/2024 22:00	3,658.3	0.0	3,658.3	104,900.0	383.8	0.5	0.2	0.8
08/22/2024 23:00	3,660.3	0.0	3,660.3	104,900.0	384.0	0.5	0.2	0.8
Average/Sum#:	3,648.7	0.1	3,648.7	104,900.0	382.8	0.5	0.2	0.8
Minimum:	3,614.2	0.0	3,614.2	104,900.0	379.1	0.5	0.2	0.8
Maximum:	3,770.9	1.7	3,770.9	104,900.0	395.6	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2024 00:00	3,661.1	0.0	3,661.1	104,900.0	384.0	0.5	0.2	0.8
08/23/2024 01:00	3,662.7	0.0	3,662.7	104,900.0	384.2	0.5	0.2	0.8
08/23/2024 02:00	3,663.6	0.0	3,663.6	104,900.0	384.3	0.5	0.2	0.8
08/23/2024 03:00	3,666.9	0.0	3,666.9	104,900.0	384.7	0.5	0.2	0.8
08/23/2024 04:00	3,671.6	0.0	3,671.6	104,900.0	385.2	0.5	0.2	0.8
08/23/2024 05:00	3,676.1	0.0	3,676.1	104,900.0	385.6	0.5	0.2	0.8
08/23/2024 06:00	3,675.7	0.0	3,675.7	104,900.0	385.6	0.5	0.2	0.8
08/23/2024 07:00	3,670.6	0.0	3,670.6	104,900.0	385.0	0.5	0.2	0.8
08/23/2024 08:00	3,666.5	0.0	3,666.5	104,900.0	384.6	0.5	0.2	0.8
08/23/2024 09:00	3,661.6	0.0	3,661.6	104,900.0	384.1	0.5	0.2	0.8
08/23/2024 10:00	3,657.9	0.0	3,657.9	104,900.0	383.7	0.5	0.2	0.8
08/23/2024 11:00	3,654.2	0.0	3,654.2	104,900.0	383.3	0.5	0.2	0.8
08/23/2024 12:00	3,652.8	0.0	3,652.8	104,900.0	383.2	0.5	0.2	0.8
08/23/2024 13:00	3,652.6	0.0	3,652.6	104,900.0	383.2	0.5	0.2	0.8
08/23/2024 14:00	3,654.3	0.0	3,654.3	104,900.0	383.3	0.5	0.2	0.8
08/23/2024 15:00	3,651.4	0.0	3,651.4	104,900.0	383.0	0.5	0.2	0.8
08/23/2024 16:00	3,651.2	0.0	3,651.2	104,900.0	383.0	0.5	0.2	0.8
08/23/2024 17:00	3,648.0	0.0	3,648.0	104,900.0	382.7	0.5	0.2	0.8
08/23/2024 18:00	3,647.9	0.0	3,647.9	104,900.0	382.7	0.5	0.2	0.8
08/23/2024 19:00	3,651.8	0.0	3,651.8	104,900.0	383.1	0.5	0.2	0.8
08/23/2024 20:00	3,652.3	0.0	3,652.3	104,900.0	383.1	0.5	0.2	0.8
08/23/2024 21:00	3,652.1	0.0	3,652.1	104,900.0	383.1	0.5	0.2	0.8
08/23/2024 22:00	3,655.8	0.0	3,655.8	104,900.0	383.5	0.5	0.2	0.8
08/23/2024 23:00	3,914.3	0.0	3,914.3	104,900.0	410.6	0.5	0.2	0.8
Average/Sum#:	3,669.7	0.0	3,669.7	104,900.0	385.0	0.5	0.2	0.8
Minimum:	3,647.9	0.0	3,647.9	104,900.0	382.7	0.5	0.2	0.8
Maximum:	3,914.3	0.0	3,914.3	104,900.0	410.6	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/24/2024 00:00	3,660.9	0.0	3,660.9	104,900.0	384.0	0.5	0.2	0.8
08/24/2024 01:00	3,665.4	0.0	3,665.4	104,900.0	384.5	0.5	0.2	0.8
08/24/2024 02:00	3,664.9	0.0	3,664.9	104,900.0	384.4	0.5	0.2	0.8
08/24/2024 03:00	3,666.3	0.0	3,666.3	104,900.0	384.6	0.5	0.2	0.8
08/24/2024 04:00	3,705.4	0.0	3,705.4	104,900.0	388.7	0.5	0.2	0.8
08/24/2024 05:00	3,889.8	0.0	3,889.8	104,900.0	408.0	0.5	0.2	0.8
08/24/2024 06:00	3,767.0	0.0	3,767.0	104,900.0	395.2	0.5	0.2	0.8
08/24/2024 07:00	3,677.0	0.0	3,677.0	104,900.0	385.7	0.5	0.2	0.8
08/24/2024 08:00	3,675.2	0.0	3,675.2	104,900.0	385.5	0.5	0.2	0.8
08/24/2024 09:00	3,670.7	0.0	3,670.7	104,900.0	385.1	0.5	0.2	0.8
08/24/2024 10:00	3,667.2	0.0	3,667.2	104,900.0	384.7	0.5	0.2	0.8
08/24/2024 11:00	3,663.6	0.0	3,663.6	104,900.0	384.3	0.5	0.2	0.8
08/24/2024 12:00	3,660.0	0.0	3,660.0	104,900.0	383.9	0.5	0.2	0.8
08/24/2024 13:00	3,659.9	0.0	3,659.9	104,900.0	383.9	0.5	0.2	0.8
08/24/2024 14:00	3,671.3	0.0	3,671.3	104,900.0	385.1	0.5	0.2	0.8
08/24/2024 15:00	3,666.4	0.0	3,666.4	104,900.0	384.6	0.5	0.2	0.8
08/24/2024 16:00	3,657.7	0.0	3,657.7	104,900.0	383.7	0.5	0.2	0.8
08/24/2024 17:00	3,657.8	0.0	3,657.8	104,900.0	383.7	0.5	0.2	0.8
08/24/2024 18:00	3,658.4	0.0	3,658.4	104,900.0	383.8	0.5	0.2	0.8
08/24/2024 19:00	3,660.8	0.0	3,660.8	104,900.0	384.0	0.5	0.2	0.8
08/24/2024 20:00	3,665.6	0.0	3,665.6	104,900.0	384.5	0.5	0.2	0.8
08/24/2024 21:00	3,674.4	0.0	3,674.4	104,900.0	385.4	0.5	0.2	0.8
08/24/2024 22:00	3,682.4	0.0	3,682.4	104,900.0	386.3	0.5	0.2	0.8
08/24/2024 23:00	3,682.9	0.0	3,682.9	104,900.0	386.3	0.5	0.2	0.8
Average/Sum#:	3,682.1	0.0	3,682.1	104,900.0	386.2	0.5	0.2	0.8
Minimum:	3,657.7	0.0	3,657.7	104,900.0	383.7	0.5	0.2	0.8
Maximum:	3,889.8	0.0	3,889.8	104,900.0	408.0	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2024 00:00	3,686.8	0.0	3,686.8	104,900.0	386.7	0.5	0.2	0.8
08/25/2024 01:00	3,689.5	0.0	3,689.5	104,900.0	387.0	0.5	0.2	0.8
08/25/2024 02:00	3,693.6	0.0	3,693.6	104,900.0	387.5	0.5	0.2	0.8
08/25/2024 03:00	3,698.2	0.0	3,698.2	104,900.0	387.9	0.5	0.2	0.8
08/25/2024 04:00	3,703.6	0.0	3,703.6	104,900.0	388.5	0.5	0.2	0.8
08/25/2024 05:00	3,705.8	0.0	3,705.8	104,900.0	388.7	0.5	0.2	0.8
08/25/2024 06:00	3,703.3	0.0	3,703.3	104,900.0	388.5	0.5	0.2	0.8
08/25/2024 07:00	3,702.6	0.0	3,702.6	104,900.0	388.4	0.5	0.2	0.8
08/25/2024 08:00	3,695.1	0.0	3,695.1	104,900.0	387.6	0.5	0.2	0.8
08/25/2024 09:00	3,694.5	0.0	3,694.5	104,900.0	387.6	0.5	0.2	0.8
08/25/2024 10:00	3,692.7	0.0	3,692.7	104,900.0	387.4	0.5	0.2	0.8
08/25/2024 11:00	3,675.2	0.0	3,675.2	104,900.0	385.5	0.5	0.2	0.8
08/25/2024 12:00	3,662.5	0.0	3,662.5	104,900.0	384.2	0.5	0.2	0.8
08/25/2024 13:00	3,663.0	0.0	3,663.0	104,900.0	384.2	0.5	0.2	0.8
08/25/2024 14:00	3,656.2	0.0	3,656.2	104,900.0	383.5	0.5	0.2	0.8
08/25/2024 15:00	3,657.3	0.0	3,657.3	104,900.0	383.7	0.5	0.2	0.8
08/25/2024 16:00	3,696.2	0.0	3,696.2	104,900.0	387.7	0.5	0.2	0.8
08/25/2024 17:00	4,081.8	0.0	4,081.8	104,900.0	428.2	0.5	0.3	0.9
08/25/2024 18:00	4,396.5	0.0	4,396.5	104,900.0	461.2	0.6	0.3	0.9
08/25/2024 19:00	4,390.6	0.0	4,390.6	104,900.0	460.6	0.6	0.3	0.9
08/25/2024 20:00	4,176.9	0.0	4,176.9	104,900.0	438.2	0.5	0.3	0.9
08/25/2024 21:00	3,670.4	0.0	3,670.4	104,900.0	385.0	0.5	0.2	0.8
08/25/2024 22:00	3,676.5	0.0	3,676.5	104,900.0	385.7	0.5	0.2	0.8
08/25/2024 23:00	3,739.6	0.0	3,739.6	104,900.0	392.3	0.5	0.2	0.8
Average/Sum#:	3,783.7	0.0	3,783.7	104,900.0	396.9	0.5	0.2	0.8
Minimum:	3,656.2	0.0	3,656.2	104,900.0	383.5	0.5	0.2	0.8
Maximum:	4,396.5	0.0	4,396.5	104,900.0	461.2	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2024 00:00	3,680.7	0.0	3,680.7	104,900.0	386.1	0.5	0.2	0.8
08/26/2024 01:00	3,682.3	0.0	3,682.3	104,900.0	386.3	0.5	0.2	0.8
08/26/2024 02:00	3,683.0	0.0	3,683.0	104,900.0	386.3	0.5	0.2	0.8
08/26/2024 03:00	3,684.9	0.0	3,684.9	104,900.0	386.5	0.5	0.2	0.8
08/26/2024 04:00	4,022.6	0.0	4,022.6	104,900.0	422.0	0.5	0.3	0.8
08/26/2024 05:00	4,369.9	0.0	4,369.9	104,900.0	458.4	0.6	0.3	0.9
08/26/2024 06:00	3,764.1	0.0	3,764.1	104,900.0	394.9	0.5	0.2	0.8
08/26/2024 07:00	3,706.5	0.0	3,706.5	104,900.0	388.8	0.5	0.2	0.8
08/26/2024 08:00	3,702.8	0.0	3,702.8	104,900.0	388.4	0.5	0.2	0.8
08/26/2024 09:00	3,687.4	0.0	3,687.4	104,900.0	386.8	0.5	0.2	0.8
08/26/2024 10:00	3,661.1	0.0	3,661.1	104,900.0	384.0	0.5	0.2	0.8
08/26/2024 11:00	3,654.4	0.0	3,654.4	104,900.0	383.3	0.5	0.2	0.8
08/26/2024 12:00	3,648.0	0.1	3,648.0	104,900.0	382.7	0.5	0.2	0.8
08/26/2024 13:00	3,645.1	0.0	3,645.1	104,900.0	382.4	0.5	0.2	0.8
08/26/2024 14:00	3,639.8	0.0	3,639.8	104,900.0	381.8	0.5	0.2	0.8
08/26/2024 15:00	3,638.1	0.0	3,638.1	104,900.0	381.6	0.5	0.2	0.8
08/26/2024 16:00	3,823.7	0.0	3,823.7	104,900.0	401.1	0.5	0.2	0.8
08/26/2024 17:00	4,062.3	0.0	4,062.3	104,900.0	426.1	0.5	0.3	0.9
08/26/2024 18:00	4,166.2	0.0	4,166.2	104,900.0	437.0	0.5	0.3	0.9
08/26/2024 19:00	3,818.0	0.0	3,818.0	104,900.0	400.5	0.5	0.2	0.8
08/26/2024 20:00	3,756.2	0.0	3,756.2	104,900.0	394.0	0.5	0.2	0.8
08/26/2024 21:00	3,654.2	0.0	3,654.2	104,900.0	383.3	0.5	0.2	0.8
08/26/2024 22:00	3,653.5	0.0	3,653.5	104,900.0	383.3	0.5	0.2	0.8
08/26/2024 23:00	3,658.9	0.0	3,658.9	104,900.0	383.8	0.5	0.2	0.8
Average/Sum#:	3,769.3	0.0	3,769.3	104,900.0	395.4	0.5	0.2	0.8
Minimum:	3,638.1	0.0	3,638.1	104,900.0	381.6	0.5	0.2	0.8
Maximum:	4,369.9	0.1	4,369.9	104,900.0	458.4	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2024 00:00	3,660.9	0.0	3,660.9	104,900.0	384.0	0.5	0.2	0.8
08/27/2024 01:00	3,663.8	0.0	3,663.8	104,900.0	384.3	0.5	0.2	0.8
08/27/2024 02:00	3,663.5	0.0	3,663.5	104,900.0	384.3	0.5	0.2	0.8
08/27/2024 03:00	3,664.4	0.0	3,664.4	104,900.0	384.4	0.5	0.2	0.8
08/27/2024 04:00	3,665.4	0.0	3,665.4	104,900.0	384.5	0.5	0.2	0.8
08/27/2024 05:00	3,668.1	0.0	3,668.1	104,900.0	384.8	0.5	0.2	0.8
08/27/2024 06:00	3,674.3	0.0	3,674.3	104,900.0	385.4	0.5	0.2	0.8
08/27/2024 07:00	3,669.1	0.0	3,669.1	104,900.0	384.9	0.5	0.2	0.8
08/27/2024 08:00	3,663.4	0.0	3,663.4	104,900.0	384.3	0.5	0.2	0.8
08/27/2024 09:00	3,660.0	0.0	3,660.0	104,900.0	383.9	0.5	0.2	0.8
08/27/2024 10:00	3,654.9	0.0	3,654.9	104,900.0	383.4	0.5	0.2	0.8
08/27/2024 11:00	3,647.7	0.0	3,647.7	104,900.0	382.6	0.5	0.2	0.8
08/27/2024 12:00	3,644.2	2.7	3,644.2	104,900.0	382.3	0.5	0.2	0.8
08/27/2024 13:00	3,639.4	0.7	3,639.4	104,900.0	381.8	0.5	0.2	0.8
08/27/2024 14:00	3,635.4	0.0	3,635.4	104,900.0	381.4	0.5	0.2	0.8
08/27/2024 15:00	3,636.2	0.0	3,636.2	104,900.0	381.4	0.5	0.2	0.8
08/27/2024 16:00	3,661.0	0.0	3,661.0	104,900.0	384.0	0.5	0.2	0.8
08/27/2024 17:00	3,913.7	0.0	3,913.7	104,900.0	410.5	0.5	0.2	0.8
08/27/2024 18:00	4,202.3	0.0	4,202.3	104,900.0	440.8	0.5	0.3	0.9
08/27/2024 19:00	3,645.5	0.0	3,645.5	104,900.0	382.4	0.5	0.2	0.8
08/27/2024 20:00	3,651.7	0.0	3,651.7	104,900.0	383.1	0.5	0.2	0.8
08/27/2024 21:00	3,651.7	0.0	3,651.7	104,900.0	383.1	0.5	0.2	0.8
08/27/2024 22:00	3,657.7	0.0	3,657.7	104,900.0	383.7	0.5	0.2	0.8
08/27/2024 23:00	3,664.4	0.0	3,664.4	104,900.0	384.4	0.5	0.2	0.8
Average/Sum#:	3,689.9	0.1	3,689.9	104,900.0	387.1	0.5	0.2	0.8
Minimum:	3,635.4	0.0	3,635.4	104,900.0	381.4	0.5	0.2	0.8
Maximum:	4,202.3	2.7	4,202.3	104,900.0	440.8	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2024 00:00	3,668.5	0.0	3,668.5	104,900.0	384.8	0.5	0.2	0.8
08/28/2024 01:00	3,669.6	0.0	3,669.6	104,900.0	384.9	0.5	0.2	0.8
08/28/2024 02:00	3,670.5	0.0	3,670.5	104,900.0	385.0	0.5	0.2	0.8
08/28/2024 03:00	3,670.8	0.0	3,670.8	104,900.0	385.1	0.5	0.2	0.8
08/28/2024 04:00	3,720.4	0.0	3,720.4	104,900.0	390.3	0.5	0.2	0.8
08/28/2024 05:00	4,128.5	0.0	4,128.5	104,900.0	433.1	0.5	0.3	0.9
08/28/2024 06:00	3,792.3	0.0	3,792.3	104,900.0	397.8	0.5	0.2	0.8
08/28/2024 07:00	3,677.9	0.0	3,677.9	104,900.0	385.8	0.5	0.2	0.8
08/28/2024 08:00	3,676.4	0.0	3,676.4	104,900.0	385.7	0.5	0.2	0.8
08/28/2024 09:00	3,672.4	0.0	3,672.4	104,900.0	385.2	0.5	0.2	0.8
08/28/2024 10:00	3,673.2	0.0	3,673.2	104,900.0	385.3	0.5	0.2	0.8
08/28/2024 11:00	3,646.8	0.0	3,646.8	104,900.0	382.5	0.5	0.2	0.8
08/28/2024 12:00	3,640.0	13.4	3,640.0	104,900.0	381.8	0.5	0.2	0.8
08/28/2024 13:00	3,637.5	7.3	3,637.5	104,900.0	381.6	0.5	0.2	0.8
08/28/2024 14:00	3,632.5	0.0	3,632.5	104,900.0	381.0	0.5	0.2	0.8
08/28/2024 15:00	3,632.0	0.0	3,632.0	104,900.0	381.0	0.5	0.2	0.8
08/28/2024 16:00	3,655.6	0.0	3,655.6	104,900.0	383.5	0.5	0.2	0.8
08/28/2024 17:00	3,655.2	0.0	3,655.2	104,900.0	383.4	0.5	0.2	0.8
08/28/2024 18:00	3,648.0	0.0	3,648.0	104,900.0	382.7	0.5	0.2	0.8
08/28/2024 19:00	3,637.0	0.0	3,637.0	104,900.0	381.5	0.5	0.2	0.8
08/28/2024 20:00	3,649.4	0.0	3,649.4	104,900.0	382.8	0.5	0.2	0.8
08/28/2024 21:00	3,660.2	0.0	3,660.2	104,900.0	384.0	0.5	0.2	0.8
08/28/2024 22:00	3,670.7	0.0	3,670.7	104,900.0	385.1	0.5	0.2	0.8
08/28/2024 23:00	3,674.0	0.0	3,674.0	104,900.0	385.4	0.5	0.2	0.8
Average/Sum#:	3,685.8	0.9	3,685.8	104,900.0	386.6	0.5	0.2	0.8
Minimum:	3,632.0	0.0	3,632.0	104,900.0	381.0	0.5	0.2	0.8
Maximum:	4,128.5	13.4	4,128.5	104,900.0	433.1	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2024 00:00	3,674.3	0.0	3,674.3	104,900.0	385.4	0.5	0.2	0.8
08/29/2024 01:00	3,671.3	0.0	3,671.3	104,900.0	385.1	0.5	0.2	0.8
08/29/2024 02:00	3,705.7	0.0	3,705.7	104,900.0	388.7	0.5	0.2	0.8
08/29/2024 03:00	3,665.1	0.0	3,665.1	104,900.0	384.5	0.5	0.2	0.8
08/29/2024 04:00	3,665.3	0.0	3,665.3	104,900.0	384.5	0.5	0.2	0.8
08/29/2024 05:00	3,669.8	0.0	3,669.8	104,900.0	385.0	0.5	0.2	0.8
08/29/2024 06:00	4,662.1	0.0	4,662.1	104,900.0	489.1	0.6	0.3	1.0
08/29/2024 07:00	4,739.5	0.0	4,739.5	104,900.0	497.2	0.6	0.3	1.0
08/29/2024 08:00	4,718.8	0.0	4,718.8	104,900.0	495.0	0.6	0.3	1.0
08/29/2024 09:00	4,018.1	0.0	4,018.1	104,900.0	421.5	0.5	0.3	0.8
08/29/2024 10:00	3,695.2	0.0	3,695.2	104,900.0	387.6	0.5	0.2	0.8
08/29/2024 11:00	3,643.8	0.0	3,643.8	104,900.0	382.2	0.5	0.2	0.8
08/29/2024 12:00	3,640.2	12.7	3,640.2	104,900.0	381.9	0.5	0.2	0.8
08/29/2024 13:00	3,638.9	7.6	3,638.9	104,900.0	381.7	0.5	0.2	0.8
08/29/2024 14:00	3,634.6	0.0	3,634.6	104,900.0	381.3	0.5	0.2	0.8
08/29/2024 15:00	3,631.0	0.0	3,631.0	104,900.0	380.9	0.5	0.2	0.8
08/29/2024 16:00	3,627.4	0.0	3,627.4	104,900.0	380.5	0.5	0.2	0.8
08/29/2024 17:00	3,631.5	0.0	3,631.5	104,900.0	380.9	0.5	0.2	0.8
08/29/2024 18:00	3,640.1	0.0	3,640.1	104,900.0	381.8	0.5	0.2	0.8
08/29/2024 19:00	3,647.8	0.0	3,647.8	104,900.0	382.7	0.5	0.2	0.8
08/29/2024 20:00	3,655.2	0.0	3,655.2	104,900.0	383.4	0.5	0.2	0.8
08/29/2024 21:00	3,660.8	0.0	3,660.8	104,900.0	384.0	0.5	0.2	0.8
08/29/2024 22:00	3,665.2	0.0	3,665.2	104,900.0	384.5	0.5	0.2	0.8
08/29/2024 23:00	3,668.4	0.0	3,668.4	104,900.0	384.8	0.5	0.2	0.8
Average/Sum#:	3,802.9	0.8	3,802.9	104,900.0	398.9	0.5	0.2	0.8
Minimum:	3,627.4	0.0	3,627.4	104,900.0	380.5	0.5	0.2	0.8
Maximum:	4,739.5	12.7	4,739.5	104,900.0	497.2	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2024 00:00	3,669.8	0.0	3,669.8	104,900.0	385.0	0.5	0.2	0.8
08/30/2024 01:00	3,673.4	0.0	3,673.4	104,900.0	385.3	0.5	0.2	0.8
08/30/2024 02:00	3,674.9	0.0	3,674.9	104,900.0	385.5	0.5	0.2	0.8
08/30/2024 03:00	3,677.1	0.0	3,677.1	104,900.0	385.7	0.5	0.2	0.8
08/30/2024 04:00	3,685.3	0.0	3,685.3	104,900.0	386.6	0.5	0.2	0.8
08/30/2024 05:00	3,678.1	0.0	3,678.1	104,900.0	385.8	0.5	0.2	0.8
08/30/2024 06:00	3,678.7	0.0	3,678.7	104,900.0	385.9	0.5	0.2	0.8
08/30/2024 07:00	3,677.3	0.0	3,677.3	104,900.0	385.7	0.5	0.2	0.8
08/30/2024 08:00	3,671.3	0.0	3,671.3	104,900.0	385.1	0.5	0.2	0.8
08/30/2024 09:00	3,665.1	0.0	3,665.1	104,900.0	384.5	0.5	0.2	0.8
08/30/2024 10:00	3,661.1	0.0	3,661.1	104,900.0	384.0	0.5	0.2	0.8
08/30/2024 11:00	3,651.7	0.0	3,651.7	104,900.0	383.1	0.5	0.2	0.8
08/30/2024 12:00	3,645.5	12.8	3,645.5	104,900.0	382.4	0.5	0.2	0.8
08/30/2024 13:00	3,643.0	17.2	3,643.0	104,900.0	382.2	0.5	0.2	0.8
08/30/2024 14:00	3,640.0	0.0	3,640.0	104,900.0	381.8	0.5	0.2	0.8
08/30/2024 15:00	3,637.7	0.0	3,637.7	104,900.0	381.6	0.5	0.2	0.8
08/30/2024 16:00	3,697.5	0.0	3,697.5	104,900.0	387.9	0.5	0.2	0.8
08/30/2024 17:00	3,641.4	0.0	3,641.4	104,900.0	382.0	0.5	0.2	0.8
08/30/2024 18:00	3,646.0	0.0	3,646.0	104,900.0	382.5	0.5	0.2	0.8
08/30/2024 19:00	3,655.0	0.0	3,655.0	104,900.0	383.4	0.5	0.2	0.8
08/30/2024 20:00	3,659.8	0.0	3,659.8	104,900.0	383.9	0.5	0.2	0.8
08/30/2024 21:00	3,686.0	0.0	3,686.0	104,900.0	386.7	0.5	0.2	0.8
08/30/2024 22:00	3,666.1	0.0	3,666.1	104,900.0	384.6	0.5	0.2	0.8
08/30/2024 23:00	3,673.2	0.0	3,673.2	104,900.0	385.3	0.5	0.2	0.8
Average/Sum#:	3,664.8	1.3	3,664.8	104,900.0	384.4	0.5	0.2	0.8
Minimum:	3,637.7	0.0	3,637.7	104,900.0	381.6	0.5	0.2	0.8
Maximum:	3,697.5	17.2	3,697.5	104,900.0	387.9	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2024 00:00	3,679.7	0.0	3,679.7	104,900.0	386.0	0.5	0.2	0.8
08/31/2024 01:00	3,672.4	0.0	3,672.4	104,900.0	385.2	0.5	0.2	0.8
08/31/2024 02:00	3,674.8	0.0	3,674.8	104,900.0	385.5	0.5	0.2	0.8
08/31/2024 03:00	3,674.3	0.0	3,674.3	104,900.0	385.4	0.5	0.2	0.8
08/31/2024 04:00	3,677.1	0.0	3,677.1	104,900.0	385.7	0.5	0.2	0.8
08/31/2024 05:00	3,676.2	0.0	3,676.2	104,900.0	385.6	0.5	0.2	0.8
08/31/2024 06:00	3,676.1	0.0	3,676.1	104,900.0	385.6	0.5	0.2	0.8
08/31/2024 07:00	3,675.2	0.0	3,675.2	104,900.0	385.5	0.5	0.2	0.8
08/31/2024 08:00	3,669.1	0.0	3,669.1	104,900.0	384.9	0.5	0.2	0.8
08/31/2024 09:00	3,664.5	0.0	3,664.5	104,900.0	384.4	0.5	0.2	0.8
08/31/2024 10:00	3,658.5	0.0	3,658.5	104,900.0	383.8	0.5	0.2	0.8
08/31/2024 11:00	3,655.6	0.0	3,655.6	104,900.0	383.5	0.5	0.2	0.8
08/31/2024 12:00	3,654.8	11.5	3,654.8	104,900.0	383.4	0.5	0.2	0.8
08/31/2024 13:00	3,659.7	16.2	3,659.7	104,900.0	383.9	0.5	0.2	0.8
08/31/2024 14:00	3,657.7	0.0	3,657.7	104,900.0	383.7	0.5	0.2	0.8
08/31/2024 15:00	3,740.3	0.0	3,740.3	104,900.0	392.4	0.5	0.2	0.8
08/31/2024 16:00	4,196.4	203.9	4,253.5	104,900.0	446.2	0.6	0.3	0.9
08/31/2024 17:00	4,552.0	1,399.0	5,951.0	104,900.0	624.3	0.7	0.4	1.2
08/31/2024 18:00	4,585.6	1,318.5	5,904.1	104,900.0	619.3	0.7	0.4	1.2
08/31/2024 19:00	4,617.6	1,385.1	6,002.7	104,900.0	629.7	0.8	0.4	1.3
08/31/2024 20:00	4,573.6	659.9	5,081.7	104,900.0	533.1	0.7	0.3	1.1
08/31/2024 21:00	4,386.8	0.0	4,386.8	104,900.0	460.2	0.6	0.3	0.9
08/31/2024 22:00	4,403.6	0.0	4,403.6	104,900.0	461.9	0.6	0.3	0.9
08/31/2024 23:00	4,322.5	85.0	4,352.3	104,900.0	456.6	0.6	0.3	0.9
Average/Sum#:	3,933.5	211.6	4,129.2	104,900.0	433.2	0.6	0.2	0.9
Minimum:	3,654.8	0.0	3,654.8	104,900.0	383.4	0.5	0.2	0.8
Maximum:	4,617.6	1,399.0	6,002.7	104,900.0	629.7	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2024 00:00	3,710.7	0.0	3,710.7	104,900.0	389.3	0.5	0.2	0.8
09/01/2024 01:00	3,675.2	0.0	3,675.2	104,900.0	385.5	0.5	0.2	0.8
09/01/2024 02:00	3,676.1	0.0	3,676.1	104,900.0	385.6	0.5	0.2	0.8
09/01/2024 03:00	3,680.6	0.0	3,680.6	104,900.0	386.1	0.5	0.2	0.8
09/01/2024 04:00	3,681.1	0.0	3,681.1	104,900.0	386.1	0.5	0.2	0.8
09/01/2024 05:00	3,684.6	0.0	3,684.6	104,900.0	386.5	0.5	0.2	0.8
09/01/2024 06:00	3,682.7	0.0	3,682.7	104,900.0	386.3	0.5	0.2	0.8
09/01/2024 07:00	3,679.3	0.0	3,679.3	104,900.0	386.0	0.5	0.2	0.8
09/01/2024 08:00	3,675.9	0.0	3,675.9	104,900.0	385.6	0.5	0.2	0.8
09/01/2024 09:00	3,665.5	0.0	3,665.5	104,900.0	384.5	0.5	0.2	0.8
09/01/2024 10:00	3,659.4	0.0	3,659.4	104,900.0	383.9	0.5	0.2	0.8
09/01/2024 11:00	3,650.9	0.0	3,650.9	104,900.0	383.0	0.5	0.2	0.8
09/01/2024 12:00	3,645.5	13.5	3,645.5	104,900.0	382.4	0.5	0.2	0.8
09/01/2024 13:00	3,640.7	17.5	3,640.7	104,900.0	381.9	0.5	0.2	0.8
09/01/2024 14:00	3,638.0	0.0	3,638.0	104,900.0	381.6	0.5	0.2	0.8
09/01/2024 15:00	3,645.8	0.0	3,645.8	104,900.0	382.4	0.5	0.2	0.8
09/01/2024 16:00	3,771.7	0.0	3,771.7	104,900.0	395.7	0.5	0.2	0.8
09/01/2024 17:00	3,905.4	0.0	3,905.4	104,900.0	409.7	0.5	0.2	0.8
09/01/2024 18:00	3,652.1	0.0	3,652.1	104,900.0	383.1	0.5	0.2	0.8
09/01/2024 19:00	3,647.4	0.0	3,647.4	104,900.0	382.6	0.5	0.2	0.8
09/01/2024 20:00	3,656.0	0.0	3,656.0	104,900.0	383.5	0.5	0.2	0.8
09/01/2024 21:00	3,725.5	0.0	3,725.5	104,900.0	390.8	0.5	0.2	0.8
09/01/2024 22:00	3,696.5	0.0	3,696.5	104,900.0	387.8	0.5	0.2	0.8
09/01/2024 23:00	3,727.3	0.0	3,727.3	104,900.0	391.0	0.5	0.2	0.8
Average/Sum#:	3,686.4	1.3	3,686.4	104,900.0	386.7	0.5	0.2	0.8
Minimum:	3,638.0	0.0	3,638.0	104,900.0	381.6	0.5	0.2	0.8
Maximum:	3,905.4	17.5	3,905.4	104,900.0	409.7	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/02/2024 00:00	3,769.8	0.0	3,769.8	104,900.0	395.5	0.5	0.2	0.8
09/02/2024 01:00	3,669.2	0.0	3,669.2	104,900.0	384.9	0.5	0.2	0.8
09/02/2024 02:00	3,674.1	0.0	3,674.1	104,900.0	385.4	0.5	0.2	0.8
09/02/2024 03:00	3,676.0	0.0	3,676.0	104,900.0	385.6	0.5	0.2	0.8
09/02/2024 04:00	3,677.2	0.0	3,677.2	104,900.0	385.7	0.5	0.2	0.8
09/02/2024 05:00	3,681.2	0.0	3,681.2	104,900.0	386.2	0.5	0.2	0.8
09/02/2024 06:00	3,681.5	0.0	3,681.5	104,900.0	386.2	0.5	0.2	0.8
09/02/2024 07:00	3,676.1	0.0	3,676.1	104,900.0	385.6	0.5	0.2	0.8
09/02/2024 08:00	3,678.7	0.0	3,678.7	104,900.0	385.9	0.5	0.2	0.8
09/02/2024 09:00	3,671.7	0.0	3,671.7	104,900.0	385.2	0.5	0.2	0.8
09/02/2024 10:00	3,662.2	0.0	3,662.2	104,900.0	384.2	0.5	0.2	0.8
09/02/2024 11:00	3,651.6	0.0	3,651.6	104,900.0	383.1	0.5	0.2	0.8
09/02/2024 12:00	3,649.9	10.7	3,649.9	104,900.0	382.9	0.5	0.2	0.8
09/02/2024 13:00	3,646.8	24.8	3,646.8	104,900.0	382.5	0.5	0.2	0.8
09/02/2024 14:00	3,796.9	0.0	3,796.9	104,900.0	398.3	0.5	0.2	0.8
09/02/2024 15:00	3,725.5	0.0	3,725.5	104,900.0	390.8	0.5	0.2	0.8
09/02/2024 16:00	3,996.5	0.0	3,996.5	104,900.0	419.2	0.5	0.3	0.8
09/02/2024 17:00	4,073.1	0.0	4,073.1	104,900.0	427.3	0.5	0.3	0.9
09/02/2024 18:00	4,109.3	0.0	4,109.3	104,900.0	431.1	0.5	0.3	0.9
09/02/2024 19:00	3,824.7	0.0	3,824.7	104,900.0	401.2	0.5	0.2	0.8
09/02/2024 20:00	3,785.4	0.0	3,785.4	104,900.0	397.1	0.5	0.2	0.8
09/02/2024 21:00	3,662.3	0.0	3,662.3	104,900.0	384.2	0.5	0.2	0.8
09/02/2024 22:00	3,665.4	0.0	3,665.4	104,900.0	384.5	0.5	0.2	0.8
09/02/2024 23:00	3,668.0	0.0	3,668.0	104,900.0	384.8	0.5	0.2	0.8
Average/Sum#:	3,740.5	1.5	3,740.5	104,900.0	392.4	0.5	0.2	0.8
Minimum:	3,646.8	0.0	3,646.8	104,900.0	382.5	0.5	0.2	0.8
Maximum:	4,109.3	24.8	4,109.3	104,900.0	431.1	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2024 00:00	3,670.8	0.0	3,670.8	104,900.0	385.1	0.5	0.2	0.8
09/03/2024 01:00	3,669.6	0.0	3,669.6	104,900.0	384.9	0.5	0.2	0.8
09/03/2024 02:00	3,676.8	0.0	3,676.8	104,900.0	385.7	0.5	0.2	0.8
09/03/2024 03:00	3,675.5	0.0	3,675.5	104,900.0	385.6	0.5	0.2	0.8
09/03/2024 04:00	3,672.6	0.0	3,672.6	104,900.0	385.3	0.5	0.2	0.8
09/03/2024 05:00	3,943.1	0.0	3,943.1	104,900.0	413.6	0.5	0.2	0.8
09/03/2024 06:00	3,777.7	0.0	3,777.7	104,900.0	396.3	0.5	0.2	0.8
09/03/2024 07:00	3,851.0	0.0	3,851.0	104,900.0	404.0	0.5	0.2	0.8
09/03/2024 08:00	3,663.2	0.0	3,663.2	104,900.0	384.3	0.5	0.2	0.8
09/03/2024 09:00	3,651.0	0.0	3,651.0	104,900.0	383.0	0.5	0.2	0.8
09/03/2024 10:00	3,645.7	0.0	3,645.7	104,900.0	382.4	0.5	0.2	0.8
09/03/2024 11:00	3,640.8	0.0	3,640.8	104,900.0	381.9	0.5	0.2	0.8
09/03/2024 12:00	3,632.4	2.5	3,632.4	104,900.0	381.0	0.5	0.2	0.8
09/03/2024 13:00	4,025.4	0.8	4,025.4	104,900.0	422.3	0.5	0.3	0.8
09/03/2024 14:00	4,183.7	0.0	4,183.7	105,505.0	441.4	0.5	0.3	0.9
09/03/2024 15:00	4,079.1	0.0	4,079.1	105,505.0	430.4	0.5	0.3	0.9
09/03/2024 16:00	4,398.3	421.9	4,600.8	105,505.0	485.4	0.6	0.3	1.0
09/03/2024 17:00	4,546.9	1,426.2	5,973.1	105,505.0	630.2	0.8	0.4	1.3
09/03/2024 18:00	4,542.2	1,480.3	6,022.5	105,505.0	635.4	0.8	0.4	1.3
09/03/2024 19:00	4,521.1	705.4	5,071.3	105,505.0	535.0	0.7	0.3	1.1
09/03/2024 20:00	4,501.5	0.0	4,501.5	105,505.0	474.9	0.6	0.3	0.9
09/03/2024 21:00	4,503.0	0.0	4,503.0	105,505.0	475.1	0.6	0.3	1.0
09/03/2024 22:00	4,035.9	0.0	4,035.9	105,505.0	425.8	0.5	0.3	0.9
09/03/2024 23:00	4,420.7	0.0	4,420.7	105,505.0	466.4	0.6	0.3	0.9
Average/Sum#:	3,997.0	168.2	4,149.5	105,152.1	436.5	0.6	0.3	0.9
Minimum:	3,632.4	0.0	3,632.4	104,900.0	381.0	0.5	0.2	0.8
Maximum:	4,546.9	1,480.3	6,022.5	105,505.0	635.4	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2024 00:00	4,015.0	0.0	4,015.0	105,505.0	423.6	0.5	0.3	0.8
09/04/2024 01:00	4,017.7	0.0	4,017.7	105,505.0	423.9	0.5	0.3	0.8
09/04/2024 02:00	3,679.6	0.0	3,679.6	105,505.0	388.2	0.5	0.2	0.8
09/04/2024 03:00	4,200.4	0.0	4,200.4	105,505.0	443.2	0.5	0.3	0.9
09/04/2024 04:00	4,238.7	0.0	4,238.7	105,505.0	447.2	0.5	0.3	0.9
09/04/2024 05:00	4,466.8	0.0	4,466.8	105,505.0	471.3	0.6	0.3	0.9
09/04/2024 06:00	3,822.9	0.0	3,822.9	105,505.0	403.3	0.5	0.2	0.8
09/04/2024 07:00	3,664.0	0.0	3,664.0	105,505.0	386.6	0.5	0.2	0.8
09/04/2024 08:00	3,655.1	0.0	3,655.1	105,505.0	385.6	0.5	0.2	0.8
09/04/2024 09:00	3,645.3	0.0	3,645.3	105,505.0	384.6	0.5	0.2	0.8
09/04/2024 10:00	3,635.7	0.0	3,635.7	105,505.0	383.6	0.5	0.2	0.8
09/04/2024 11:00	3,631.0	0.0	3,631.0	105,505.0	383.1	0.5	0.2	0.8
09/04/2024 12:00	3,627.2	9.0	3,627.2	105,505.0	382.7	0.5	0.2	0.8
09/04/2024 13:00	3,952.0	21.7	3,952.0	105,505.0	417.0	0.5	0.3	0.8
09/04/2024 14:00	4,123.1	0.0	4,123.1	105,505.0	435.0	0.5	0.3	0.9
09/04/2024 15:00	3,667.6	0.0	3,667.6	105,505.0	387.0	0.5	0.2	0.8
09/04/2024 16:00	4,313.2	507.9	4,557.0	105,505.0	480.8	0.6	0.3	1.0
09/04/2024 17:00	4,507.9	1,685.2	6,193.1	105,505.0	653.4	0.8	0.4	1.3
09/04/2024 18:00	4,532.5	1,547.9	6,080.4	105,505.0	641.5	0.8	0.4	1.3
09/04/2024 19:00	4,568.3	1,410.6	5,978.9	105,505.0	630.8	0.8	0.4	1.3
09/04/2024 20:00	4,607.9	1,368.8	5,976.7	105,505.0	630.6	0.8	0.4	1.3
09/04/2024 21:00	4,616.0	1,327.4	5,943.4	105,505.0	627.1	0.8	0.4	1.3
09/04/2024 22:00	4,634.8	1,199.8	5,834.6	105,505.0	615.6	0.7	0.4	1.2
09/04/2024 23:00	4,596.1	653.6	5,099.4	105,505.0	538.0	0.7	0.3	1.1
Average/Sum#:	4,100.8	405.5	4,487.7	105,505.0	473.5	0.6	0.3	1.0
Minimum:	3,627.2	0.0	3,627.2	105,505.0	382.7	0.5	0.2	0.8
Maximum:	4,634.8	1,685.2	6,193.1	105,505.0	653.4	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2024 00:00	4,024.9	0.0	4,024.9	105,505.0	424.6	0.5	0.3	0.8
09/05/2024 01:00	3,754.7	0.0	3,754.7	105,505.0	396.1	0.5	0.2	0.8
09/05/2024 02:00	3,662.1	0.0	3,662.1	105,505.0	386.4	0.5	0.2	0.8
09/05/2024 03:00	3,662.1	0.0	3,662.1	105,505.0	386.4	0.5	0.2	0.8
09/05/2024 04:00	3,950.7	0.0	3,950.7	105,505.0	416.8	0.5	0.3	0.8
09/05/2024 05:00	4,385.8	0.0	4,385.8	105,505.0	462.7	0.6	0.3	0.9
09/05/2024 06:00	3,925.5	0.0	3,925.5	105,505.0	414.2	0.5	0.2	0.8
09/05/2024 07:00	3,661.6	0.0	3,661.6	105,505.0	386.3	0.5	0.2	0.8
09/05/2024 08:00	3,656.7	0.0	3,656.7	105,505.0	385.8	0.5	0.2	0.8
09/05/2024 09:00	3,757.0	0.0	3,757.0	105,505.0	396.4	0.5	0.2	0.8
09/05/2024 10:00	4,173.3	1.6	4,173.3	105,505.0	440.3	0.5	0.3	0.9
09/05/2024 11:00	3,866.0	0.0	3,866.0	105,505.0	407.9	0.5	0.2	0.8
09/05/2024 12:00	4,397.1	9.6	4,397.1	105,505.0	463.9	0.6	0.3	0.9
09/05/2024 13:00	4,458.8	523.9	4,710.3	105,505.0	497.0	0.6	0.3	1.1
09/05/2024 14:00	4,497.3	1,678.7	6,176.0	105,505.0	651.6	0.8	0.4	1.3
09/05/2024 15:00	4,496.7	1,385.5	5,882.2	105,505.0	620.6	0.7	0.4	1.2
09/05/2024 16:00	4,510.8	1,452.4	5,963.2	105,505.0	629.1	0.8	0.4	1.3
09/05/2024 17:00	4,513.5	1,608.8	6,122.3	105,505.0	645.9	0.8	0.4	1.3
09/05/2024 18:00	4,538.7	1,527.0	6,065.7	105,505.0	640.0	0.8	0.4	1.3
09/05/2024 19:00	4,573.7	1,397.4	5,971.1	105,505.0	630.0	0.8	0.4	1.3
09/05/2024 20:00	4,619.4	1,290.0	5,909.4	105,505.0	623.5	0.7	0.4	1.2
09/05/2024 21:00	4,619.8	1,213.9	5,833.7	105,505.0	615.5	0.7	0.4	1.2
09/05/2024 22:00	4,633.3	1,073.5	5,706.8	105,505.0	602.1	0.7	0.4	1.2
09/05/2024 23:00	4,654.9	847.0	5,501.9	105,505.0	580.5	0.7	0.3	1.2
Average/Sum#:	4,208.1	583.7	4,780.0	105,505.0	504.3	0.6	0.3	1.0
Minimum:	3,656.7	0.0	3,656.7	105,505.0	385.8	0.5	0.2	0.8
Maximum:	4,654.9	1,678.7	6,176.0	105,505.0	651.6	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2024 00:00	4,010.4	1.7	4,010.4	105,505.0	423.1	0.5	0.3	0.8
09/06/2024 01:00	3,653.5	0.0	3,653.5	105,505.0	385.5	0.5	0.2	0.8
09/06/2024 02:00	3,653.0	0.0	3,653.0	105,505.0	385.4	0.5	0.2	0.8
09/06/2024 03:00	3,657.4	0.0	3,657.4	105,505.0	385.9	0.5	0.2	0.8
09/06/2024 04:00	3,914.3	0.0	3,914.3	105,505.0	413.0	0.5	0.2	0.8
09/06/2024 05:00	4,361.6	0.0	4,361.6	105,505.0	460.2	0.6	0.3	0.9
09/06/2024 06:00	4,121.5	0.0	4,121.5	105,505.0	434.8	0.5	0.3	0.9
09/06/2024 07:00	4,025.7	0.0	4,025.7	105,505.0	424.7	0.5	0.3	0.8
09/06/2024 08:00	3,650.6	0.0	3,650.6	105,505.0	385.2	0.5	0.2	0.8
09/06/2024 09:00	3,642.5	0.0	3,642.5	105,505.0	384.3	0.5	0.2	0.8
09/06/2024 10:00	3,637.4	0.0	3,637.4	105,505.0	383.8	0.5	0.2	0.8
09/06/2024 11:00	3,757.6	0.0	3,757.6	105,505.0	396.4	0.5	0.2	0.8
09/06/2024 12:00	4,241.7	9.2	4,241.7	105,505.0	447.5	0.5	0.3	0.9
09/06/2024 13:00	4,444.2	596.8	4,760.5	105,505.0	502.3	0.6	0.3	1.1
09/06/2024 14:00	4,491.9	1,554.7	6,046.6	105,505.0	637.9	0.8	0.4	1.3
09/06/2024 15:00	4,475.9	1,666.3	6,142.2	105,505.0	648.0	0.8	0.4	1.3
09/06/2024 16:00	4,477.7	1,380.0	5,857.7	105,505.0	618.0	0.7	0.4	1.2
09/06/2024 17:00	4,481.4	1,658.4	6,139.8	105,505.0	647.8	0.8	0.4	1.3
09/06/2024 18:00	4,503.9	1,728.3	6,232.2	105,505.0	657.5	0.8	0.4	1.3
09/06/2024 19:00	4,541.4	1,393.6	5,935.0	105,505.0	626.2	0.8	0.4	1.3
09/06/2024 20:00	4,575.0	1,349.0	5,924.0	105,505.0	625.0	0.7	0.4	1.3
09/06/2024 21:00	4,582.5	1,456.0	6,038.5	105,505.0	637.1	0.8	0.4	1.3
09/06/2024 22:00	4,606.2	1,354.5	5,960.7	105,505.0	628.9	0.8	0.4	1.3
09/06/2024 23:00	4,629.5	1,411.7	6,041.2	105,505.0	637.4	0.8	0.4	1.3
Average/Sum#:	4,172.4	648.3	4,808.6	105,505.0	507.3	0.6	0.3	1.0
Minimum:	3,637.4	0.0	3,637.4	105,505.0	383.8	0.5	0.2	0.8
Maximum:	4,629.5	1,728.3	6,232.2	105,505.0	657.5	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2024 00:00	4,643.2	1,281.2	5,924.4	105,505.0	625.1	0.7	0.4	1.2
09/07/2024 01:00	4,574.5	595.8	5,033.3	105,505.0	531.0	0.7	0.3	1.1
09/07/2024 02:00	3,679.4	0.0	3,679.4	105,505.0	388.2	0.5	0.2	0.8
09/07/2024 03:00	3,707.6	0.0	3,707.6	105,505.0	391.2	0.5	0.2	0.8
09/07/2024 04:00	3,665.3	0.0	3,665.3	105,505.0	386.7	0.5	0.2	0.8
09/07/2024 05:00	3,650.5	0.0	3,650.5	105,505.0	385.1	0.5	0.2	0.8
09/07/2024 06:00	3,648.8	0.0	3,648.8	105,505.0	385.0	0.5	0.2	0.8
09/07/2024 07:00	3,650.6	0.0	3,650.6	105,505.0	385.2	0.5	0.2	0.8
09/07/2024 08:00	3,644.0	0.0	3,644.0	105,505.0	384.5	0.5	0.2	0.8
09/07/2024 09:00	3,638.3	0.0	3,638.3	105,505.0	383.9	0.5	0.2	0.8
09/07/2024 10:00	3,632.9	0.0	3,632.9	105,505.0	383.3	0.5	0.2	0.8
09/07/2024 11:00	3,630.0	0.0	3,630.0	105,505.0	383.0	0.5	0.2	0.8
09/07/2024 12:00	4,117.1	11.5	4,117.1	105,505.0	434.4	0.5	0.3	0.9
09/07/2024 13:00	4,491.8	29.0	4,492.7	105,505.0	474.0	0.6	0.3	1.0
09/07/2024 14:00	4,506.9	984.3	5,491.2	105,505.0	579.3	0.7	0.3	1.2
09/07/2024 15:00	4,511.7	954.7	5,466.4	105,505.0	576.7	0.7	0.3	1.2
09/07/2024 16:00	4,526.6	783.8	5,310.4	105,505.0	560.3	0.7	0.3	1.1
09/07/2024 17:00	4,552.7	1,358.2	5,910.9	105,505.0	623.6	0.7	0.4	1.2
09/07/2024 18:00	4,575.8	1,392.6	5,968.4	105,505.0	629.7	0.8	0.4	1.3
09/07/2024 19:00	4,597.0	1,283.2	5,880.2	105,505.0	620.4	0.7	0.4	1.2
09/07/2024 20:00	4,623.4	1,335.9	5,959.3	105,505.0	628.7	0.8	0.4	1.3
09/07/2024 21:00	4,648.5	1,306.7	5,955.2	105,505.0	628.3	0.8	0.4	1.3
09/07/2024 22:00	4,672.3	1,308.8	5,981.1	105,505.0	631.0	0.8	0.4	1.3
09/07/2024 23:00	4,687.3	997.9	5,685.2	105,505.0	599.8	0.7	0.4	1.2
Average/Sum#:	4,178.2	567.7	4,738.5	105,505.0	499.9	0.6	0.3	1.0
Minimum:	3,630.0	0.0	3,630.0	105,505.0	383.0	0.5	0.2	0.8
Maximum:	4,687.3	1,392.6	5,981.1	105,505.0	631.0	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2024 00:00	4,104.5	0.5	4,104.5	105,505.0	433.0	0.5	0.3	0.9
09/08/2024 01:00	3,676.6	0.0	3,676.6	105,505.0	387.9	0.5	0.2	0.8
09/08/2024 02:00	3,681.6	0.0	3,681.6	105,505.0	388.4	0.5	0.2	0.8
09/08/2024 03:00	3,684.4	0.0	3,684.4	105,505.0	388.7	0.5	0.2	0.8
09/08/2024 04:00	3,685.9	0.0	3,685.9	105,505.0	388.9	0.5	0.2	0.8
09/08/2024 05:00	3,687.6	0.0	3,687.6	105,505.0	389.1	0.5	0.2	0.8
09/08/2024 06:00	3,683.3	0.0	3,683.3	105,505.0	388.6	0.5	0.2	0.8
09/08/2024 07:00	3,670.1	0.0	3,670.1	105,505.0	387.2	0.5	0.2	0.8
09/08/2024 08:00	3,662.5	0.0	3,662.5	105,505.0	386.4	0.5	0.2	0.8
09/08/2024 09:00	3,650.9	0.0	3,650.9	105,505.0	385.2	0.5	0.2	0.8
09/08/2024 10:00	3,642.3	0.0	3,642.3	105,505.0	384.3	0.5	0.2	0.8
09/08/2024 11:00	3,638.1	0.0	3,638.1	105,505.0	383.8	0.5	0.2	0.8
09/08/2024 12:00	3,725.4	6.6	3,725.4	105,505.0	393.0	0.5	0.2	0.8
09/08/2024 13:00	4,261.1	204.1	4,318.2	105,505.0	455.6	0.6	0.3	0.9
09/08/2024 14:00	4,521.7	1,120.1	5,641.8	105,505.0	595.2	0.7	0.4	1.2
09/08/2024 15:00	4,515.5	1,319.7	5,835.2	105,505.0	615.6	0.7	0.4	1.2
09/08/2024 16:00	4,504.7	1,618.0	6,122.7	105,505.0	646.0	0.8	0.4	1.3
09/08/2024 17:00	4,513.1	1,702.0	6,215.1	105,505.0	655.7	0.8	0.4	1.3
09/08/2024 18:00	4,534.2	1,573.1	6,107.3	105,505.0	644.4	0.8	0.4	1.3
09/08/2024 19:00	4,567.5	1,472.3	6,039.8	105,505.0	637.2	0.8	0.4	1.3
09/08/2024 20:00	4,596.9	1,408.7	6,005.6	105,505.0	633.6	0.8	0.4	1.3
09/08/2024 21:00	4,526.4	674.9	5,032.6	105,505.0	531.0	0.7	0.3	1.1
09/08/2024 22:00	4,179.4	0.0	4,179.4	105,505.0	440.9	0.5	0.3	0.9
09/08/2024 23:00	3,884.8	0.0	3,884.8	105,505.0	409.9	0.5	0.2	0.8
Average/Sum#:	4,033.3	462.5	4,482.3	105,505.0	472.9	0.6	0.3	1.0
Minimum:	3,638.1	0.0	3,638.1	105,505.0	383.8	0.5	0.2	0.8
Maximum:	4,596.9	1,702.0	6,215.1	105,505.0	655.7	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2024 00:00	3,677.3	0.0	3,677.3	105,505.0	388.0	0.5	0.2	0.8
09/09/2024 01:00	3,670.8	0.0	3,670.8	105,505.0	387.3	0.5	0.2	0.8
09/09/2024 02:00	3,679.1	0.0	3,679.1	105,505.0	388.2	0.5	0.2	0.8
09/09/2024 03:00	3,676.1	0.0	3,676.1	105,505.0	387.8	0.5	0.2	0.8
09/09/2024 04:00	3,903.5	0.0	3,903.5	105,505.0	411.8	0.5	0.2	0.8
09/09/2024 05:00	4,305.3	0.0	4,305.3	105,505.0	454.2	0.5	0.3	0.9
09/09/2024 06:00	3,778.4	0.0	3,778.4	105,505.0	398.6	0.5	0.2	0.8
09/09/2024 07:00	3,694.8	0.0	3,694.8	105,505.0	389.8	0.5	0.2	0.8
09/09/2024 08:00	3,684.8	0.0	3,684.8	105,505.0	388.8	0.5	0.2	0.8
09/09/2024 09:00	3,656.5	0.0	3,656.5	105,505.0	385.8	0.5	0.2	0.8
09/09/2024 10:00	3,658.2	0.0	3,658.2	105,505.0	386.0	0.5	0.2	0.8
09/09/2024 11:00	3,642.4	0.0	3,642.4	105,505.0	384.3	0.5	0.2	0.8
09/09/2024 12:00	3,800.8	6.7	3,800.8	105,505.0	401.0	0.5	0.2	0.8
09/09/2024 13:00	3,801.6	21.5	3,801.6	105,505.0	401.1	0.5	0.2	0.8
09/09/2024 14:00	3,630.3	0.0	3,630.3	105,505.0	383.0	0.5	0.2	0.8
09/09/2024 15:00	3,856.5	0.0	3,856.5	105,505.0	406.9	0.5	0.2	0.8
09/09/2024 16:00	4,143.7	0.0	4,143.7	105,505.0	437.2	0.5	0.3	0.9
09/09/2024 17:00	4,325.8	483.8	4,558.0	105,505.0	480.9	0.6	0.3	1.0
09/09/2024 18:00	4,558.8	1,136.5	5,695.3	105,505.0	600.9	0.7	0.4	1.2
09/09/2024 19:00	4,324.6	362.1	4,516.5	105,505.0	476.5	0.6	0.3	1.0
09/09/2024 20:00	3,820.5	0.0	3,820.5	105,505.0	403.1	0.5	0.2	0.8
09/09/2024 21:00	3,746.9	0.0	3,746.9	105,505.0	395.3	0.5	0.2	0.8
09/09/2024 22:00	3,664.0	0.0	3,664.0	105,505.0	386.6	0.5	0.2	0.8
09/09/2024 23:00	4,114.2	0.0	4,114.2	105,505.0	434.1	0.5	0.3	0.9
Average/Sum#:	3,867.3	83.8	3,932.3	105,505.0	414.9	0.5	0.2	0.8
Minimum:	3,630.3	0.0	3,630.3	105,505.0	383.0	0.5	0.2	0.8
Maximum:	4,558.8	1,136.5	5,695.3	105,505.0	600.9	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2024 00:00	3,808.3	0.0	3,808.3	105,505.0	401.8	0.5	0.2	0.8
09/10/2024 01:00	3,668.6	0.0	3,668.6	105,505.0	387.1	0.5	0.2	0.8
09/10/2024 02:00	3,671.6	0.0	3,671.6	105,505.0	387.4	0.5	0.2	0.8
09/10/2024 03:00	3,673.2	0.0	3,673.2	105,505.0	387.5	0.5	0.2	0.8
09/10/2024 04:00	3,675.4	0.0	3,675.4	105,505.0	387.8	0.5	0.2	0.8
09/10/2024 05:00	4,046.1	0.0	4,046.1	105,505.0	426.9	0.5	0.3	0.9
09/10/2024 06:00	3,751.2	0.0	3,751.2	105,505.0	395.8	0.5	0.2	0.8
09/10/2024 07:00	3,680.6	0.0	3,680.6	105,505.0	388.3	0.5	0.2	0.8
09/10/2024 08:00	3,677.1	0.0	3,677.1	105,505.0	388.0	0.5	0.2	0.8
09/10/2024 09:00	3,673.3	0.0	3,673.3	105,505.0	387.6	0.5	0.2	0.8
09/10/2024 10:00	3,660.5	0.0	3,660.5	105,505.0	386.2	0.5	0.2	0.8
09/10/2024 11:00	3,649.1	0.0	3,649.1	105,505.0	385.0	0.5	0.2	0.8
09/10/2024 12:00	3,644.6	1.0	3,644.6	105,505.0	384.5	0.5	0.2	0.8
09/10/2024 13:00	3,646.0	7.6	3,646.0	105,505.0	384.7	0.5	0.2	0.8
09/10/2024 14:00	3,648.2	0.0	3,648.2	105,505.0	384.9	0.5	0.2	0.8
09/10/2024 15:00	3,645.0	0.0	3,645.0	105,505.0	384.6	0.5	0.2	0.8
09/10/2024 16:00	3,638.2	0.0	3,638.2	105,505.0	383.8	0.5	0.2	0.8
09/10/2024 17:00	3,637.2	0.0	3,637.2	105,505.0	383.7	0.5	0.2	0.8
09/10/2024 18:00	3,646.8	0.0	3,646.8	105,505.0	384.8	0.5	0.2	0.8
09/10/2024 19:00	3,657.3	0.0	3,657.3	105,505.0	385.9	0.5	0.2	0.8
09/10/2024 20:00	3,659.7	0.0	3,659.7	105,505.0	386.1	0.5	0.2	0.8
09/10/2024 21:00	3,660.5	0.0	3,660.5	105,505.0	386.2	0.5	0.2	0.8
09/10/2024 22:00	3,659.8	0.0	3,659.8	105,505.0	386.1	0.5	0.2	0.8
09/10/2024 23:00	3,662.1	0.0	3,662.1	105,505.0	386.4	0.5	0.2	0.8
Average/Sum#:	3,685.0	0.4	3,685.0	105,505.0	388.8	0.5	0.2	0.8
Minimum:	3,637.2	0.0	3,637.2	105,505.0	383.7	0.5	0.2	0.8
Maximum:	4,046.1	7.6	4,046.1	105,505.0	426.9	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2024 00:00	3,662.9	0.0	3,662.9	105,505.0	386.5	0.5	0.2	0.8
09/11/2024 01:00	3,663.9	0.0	3,663.9	105,505.0	386.6	0.5	0.2	0.8
09/11/2024 02:00	3,662.1	0.0	3,662.1	105,505.0	386.4	0.5	0.2	0.8
09/11/2024 03:00	3,661.3	0.0	3,661.3	105,505.0	386.3	0.5	0.2	0.8
09/11/2024 04:00	3,663.0	0.0	3,663.0	105,505.0	386.5	0.5	0.2	0.8
09/11/2024 05:00	3,970.3	0.0	3,970.3	105,505.0	418.9	0.5	0.3	0.8
09/11/2024 06:00	3,799.2	0.0	3,799.2	105,505.0	400.8	0.5	0.2	0.8
09/11/2024 07:00	3,662.2	0.0	3,662.2	105,505.0	386.4	0.5	0.2	0.8
09/11/2024 08:00	3,664.6	0.0	3,664.6	105,505.0	386.6	0.5	0.2	0.8
09/11/2024 09:00	3,661.5	0.0	3,661.5	105,505.0	386.3	0.5	0.2	0.8
09/11/2024 10:00	3,660.5	0.0	3,660.5	105,505.0	386.2	0.5	0.2	0.8
09/11/2024 11:00	3,655.9	0.0	3,655.9	105,505.0	385.7	0.5	0.2	0.8
09/11/2024 12:00	3,649.7	0.0	3,649.7	105,505.0	385.1	0.5	0.2	0.8
09/11/2024 13:00	3,640.7	1.4	3,640.7	105,505.0	384.1	0.5	0.2	0.8
09/11/2024 14:00	3,632.5	0.0	3,632.5	105,505.0	383.2	0.5	0.2	0.8
09/11/2024 15:00	3,630.9	0.0	3,630.9	105,505.0	383.1	0.5	0.2	0.8
09/11/2024 16:00	3,634.0	0.0	3,634.0	105,505.0	383.4	0.5	0.2	0.8
09/11/2024 17:00	3,634.0	0.0	3,634.0	105,505.0	383.4	0.5	0.2	0.8
09/11/2024 18:00	3,641.4	0.0	3,641.4	105,505.0	384.2	0.5	0.2	0.8
09/11/2024 19:00	3,645.4	0.0	3,645.4	105,505.0	384.6	0.5	0.2	0.8
09/11/2024 20:00	3,649.3	0.0	3,649.3	105,505.0	385.0	0.5	0.2	0.8
09/11/2024 21:00	3,651.3	0.0	3,651.3	105,505.0	385.2	0.5	0.2	0.8
09/11/2024 22:00	3,655.0	0.0	3,655.0	105,505.0	385.6	0.5	0.2	0.8
09/11/2024 23:00	3,657.2	0.0	3,657.2	105,505.0	385.9	0.5	0.2	0.8
Average/Sum#:	3,671.2	0.1	3,671.2	105,505.0	387.3	0.5	0.2	0.8
Minimum:	3,630.9	0.0	3,630.9	105,505.0	383.1	0.5	0.2	0.8
Maximum:	3,970.3	1.4	3,970.3	105,505.0	418.9	0.5	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/12/2024 00:00	3,661.4	0.0	3,661.4	105,505.0	386.3	0.5	0.2	0.8
09/12/2024 01:00	3,661.1	0.0	3,661.1	105,505.0	386.3	0.5	0.2	0.8
09/12/2024 02:00	3,664.2	0.0	3,664.2	105,505.0	386.6	0.5	0.2	0.8
09/12/2024 03:00	3,665.7	0.0	3,665.7	105,505.0	386.7	0.5	0.2	0.8
09/12/2024 04:00	3,667.5	0.0	3,667.5	105,505.0	386.9	0.5	0.2	0.8
09/12/2024 05:00	3,669.2	0.0	3,669.2	105,505.0	387.1	0.5	0.2	0.8
09/12/2024 06:00	3,671.4	0.0	3,671.4	105,505.0	387.4	0.5	0.2	0.8
09/12/2024 07:00	3,671.0	0.0	3,671.0	105,505.0	387.3	0.5	0.2	0.8
09/12/2024 08:00	3,671.5	0.0	3,671.5	105,505.0	387.4	0.5	0.2	0.8
09/12/2024 09:00	3,672.0	0.0	3,672.0	105,505.0	387.4	0.5	0.2	0.8
09/12/2024 10:00	3,667.9	0.0	3,667.9	105,505.0	387.0	0.5	0.2	0.8
09/12/2024 11:00	3,642.3	0.0	3,642.3	105,505.0	384.3	0.5	0.2	0.8
09/12/2024 12:00	3,642.7	0.0	3,642.7	105,505.0	384.3	0.5	0.2	0.8
09/12/2024 13:00	3,640.5	0.0	3,640.5	105,505.0	384.1	0.5	0.2	0.8
09/12/2024 14:00	3,638.9	0.0	3,638.9	105,505.0	383.9	0.5	0.2	0.8
09/12/2024 15:00	3,638.0	0.0	3,638.0	105,505.0	383.8	0.5	0.2	0.8
09/12/2024 16:00	3,636.4	0.0	3,636.4	105,505.0	383.7	0.5	0.2	0.8
09/12/2024 17:00	3,636.2	0.0	3,636.2	105,505.0	383.6	0.5	0.2	0.8
09/12/2024 18:00	3,638.2	0.0	3,638.2	105,505.0	383.8	0.5	0.2	0.8
09/12/2024 19:00	3,641.6	0.0	3,641.6	105,505.0	384.2	0.5	0.2	0.8
09/12/2024 20:00	3,647.2	0.0	3,647.2	105,505.0	384.8	0.5	0.2	0.8
09/12/2024 21:00	3,655.3	0.0	3,655.3	105,505.0	385.7	0.5	0.2	0.8
09/12/2024 22:00	3,662.9	0.0	3,662.9	105,505.0	386.5	0.5	0.2	0.8
09/12/2024 23:00	3,678.1	0.0	3,678.1	105,505.0	388.1	0.5	0.2	0.8
Average/Sum#:	3,655.9	0.0	3,655.9	105,505.0	385.7	0.5	0.2	0.8
Minimum:	3,636.2	0.0	3,636.2	105,505.0	383.6	0.5	0.2	0.8
Maximum:	3,678.1	0.0	3,678.1	105,505.0	388.1	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2024 00:00	3,661.2	0.0	3,661.2	105,505.0	386.3	0.5	0.2	0.8
09/13/2024 01:00	3,658.9	0.0	3,658.9	105,505.0	386.0	0.5	0.2	0.8
09/13/2024 02:00	3,659.5	0.0	3,659.5	105,505.0	386.1	0.5	0.2	0.8
09/13/2024 03:00	3,658.2	0.0	3,658.2	105,505.0	386.0	0.5	0.2	0.8
09/13/2024 04:00	3,722.0	0.0	3,722.0	105,505.0	392.7	0.5	0.2	0.8
09/13/2024 05:00	4,240.5	0.0	4,240.5	105,505.0	447.4	0.5	0.3	0.9
09/13/2024 06:00	3,992.9	0.0	3,992.9	105,505.0	421.3	0.5	0.3	0.8
09/13/2024 07:00	3,666.8	0.0	3,666.8	105,505.0	386.9	0.5	0.2	0.8
09/13/2024 08:00	3,665.0	0.0	3,665.0	105,505.0	386.7	0.5	0.2	0.8
09/13/2024 09:00	3,651.9	0.0	3,651.9	105,505.0	385.3	0.5	0.2	0.8
09/13/2024 10:00	3,643.1	0.0	3,643.1	105,505.0	384.4	0.5	0.2	0.8
09/13/2024 11:00	3,661.7	0.0	3,661.7	105,505.0	386.3	0.5	0.2	0.8
09/13/2024 12:00	3,782.8	0.0	3,782.8	105,505.0	399.1	0.5	0.2	0.8
09/13/2024 13:00	4,129.5	0.0	4,129.5	105,505.0	435.7	0.5	0.3	0.9
09/13/2024 14:00	4,190.0	0.0	4,190.0	105,505.0	442.1	0.5	0.3	0.9
09/13/2024 15:00	4,152.7	0.0	4,152.7	105,505.0	438.1	0.5	0.3	0.9
09/13/2024 16:00	4,483.3	129.6	4,513.1	105,505.0	476.2	0.6	0.3	1.0
09/13/2024 17:00	4,563.0	1,738.9	6,301.9	105,505.0	664.9	0.8	0.4	1.3
09/13/2024 18:00	4,589.7	1,543.6	6,133.3	105,505.0	647.1	0.8	0.4	1.3
09/13/2024 19:00	4,143.4	137.1	4,181.8	105,505.0	441.2	0.5	0.3	0.9
09/13/2024 20:00	3,697.1	0.0	3,697.1	105,505.0	390.1	0.5	0.2	0.8
09/13/2024 21:00	3,657.5	0.0	3,657.5	105,505.0	385.9	0.5	0.2	0.8
09/13/2024 22:00	3,728.3	0.0	3,728.3	105,505.0	393.4	0.5	0.2	0.8
09/13/2024 23:00	3,986.1	0.0	3,986.1	105,505.0	420.6	0.5	0.3	0.8
Average/Sum#:	3,916.0	147.9	4,055.7	105,505.0	427.9	0.5	0.3	0.9
Minimum:	3,643.1	0.0	3,643.1	105,505.0	384.4	0.5	0.2	0.8
Maximum:	4,589.7	1,738.9	6,301.9	105,505.0	664.9	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2024 00:00	4,018.7	0.0	4,018.7	105,505.0	424.0	0.5	0.3	0.8
09/14/2024 01:00	3,699.0	0.0	3,699.0	105,505.0	390.3	0.5	0.2	0.8
09/14/2024 02:00	3,654.8	0.0	3,654.8	105,505.0	385.6	0.5	0.2	0.8
09/14/2024 03:00	4,338.2	0.0	4,338.2	105,505.0	457.7	0.5	0.3	0.9
09/14/2024 04:00	4,296.1	0.0	4,296.1	105,505.0	453.3	0.5	0.3	0.9
09/14/2024 05:00	4,618.0	0.0	4,618.0	105,505.0	487.2	0.6	0.3	1.0
09/14/2024 06:00	3,861.2	0.0	3,861.2	105,505.0	407.4	0.5	0.2	0.8
09/14/2024 07:00	3,660.7	0.0	3,660.7	105,505.0	386.2	0.5	0.2	0.8
09/14/2024 08:00	3,653.9	0.0	3,653.9	105,505.0	385.5	0.5	0.2	0.8
09/14/2024 09:00	3,649.5	0.0	3,649.5	105,505.0	385.0	0.5	0.2	0.8
09/14/2024 10:00	3,644.6	0.0	3,644.6	105,505.0	384.5	0.5	0.2	0.8
09/14/2024 11:00	3,639.3	0.0	3,639.3	105,505.0	384.0	0.5	0.2	0.8
09/14/2024 12:00	3,649.6	0.0	3,649.6	105,505.0	385.1	0.5	0.2	0.8
09/14/2024 13:00	3,652.4	0.6	3,652.4	105,505.0	385.3	0.5	0.2	0.8
09/14/2024 14:00	3,652.7	0.0	3,652.7	105,505.0	385.4	0.5	0.2	0.8
09/14/2024 15:00	3,637.8	0.0	3,637.8	105,505.0	383.8	0.5	0.2	0.8
09/14/2024 16:00	3,846.6	0.0	3,846.6	105,505.0	405.8	0.5	0.2	0.8
09/14/2024 17:00	4,273.3	0.0	4,273.3	105,505.0	450.9	0.5	0.3	0.9
09/14/2024 18:00	4,111.5	0.0	4,111.5	105,505.0	433.8	0.5	0.3	0.9
09/14/2024 19:00	3,648.4	0.0	3,648.4	105,505.0	384.9	0.5	0.2	0.8
09/14/2024 20:00	3,642.3	0.0	3,642.3	105,505.0	384.3	0.5	0.2	0.8
09/14/2024 21:00	3,654.0	0.0	3,654.0	105,505.0	385.5	0.5	0.2	0.8
09/14/2024 22:00	3,664.8	0.0	3,664.8	105,505.0	386.7	0.5	0.2	0.8
09/14/2024 23:00	3,667.5	0.0	3,667.5	105,505.0	386.9	0.5	0.2	0.8
Average/Sum#:	3,826.5	0.0	3,826.5	105,505.0	403.7	0.5	0.2	0.8
Minimum:	3,637.8	0.0	3,637.8	105,505.0	383.8	0.5	0.2	0.8
Maximum:	4,618.0	0.6	4,618.0	105,505.0	487.2	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2024 00:00	3,669.0	0.0	3,669.0	105,505.0	387.1	0.5	0.2	0.8
09/15/2024 01:00	3,670.4	0.0	3,670.4	105,505.0	387.2	0.5	0.2	0.8
09/15/2024 02:00	3,672.4	0.0	3,672.4	105,505.0	387.5	0.5	0.2	0.8
09/15/2024 03:00	3,674.9	0.0	3,674.9	105,505.0	387.7	0.5	0.2	0.8
09/15/2024 04:00	3,676.3	0.0	3,676.3	105,505.0	387.9	0.5	0.2	0.8
09/15/2024 05:00	3,679.9	0.0	3,679.9	105,505.0	388.2	0.5	0.2	0.8
09/15/2024 06:00	3,677.4	0.0	3,677.4	105,505.0	388.0	0.5	0.2	0.8
09/15/2024 07:00	3,676.8	0.0	3,676.8	105,505.0	387.9	0.5	0.2	0.8
09/15/2024 08:00	3,674.0	0.0	3,674.0	105,505.0	387.6	0.5	0.2	0.8
09/15/2024 09:00	3,668.4	0.0	3,668.4	105,505.0	387.0	0.5	0.2	0.8
09/15/2024 10:00	3,657.0	0.0	3,657.0	105,505.0	385.8	0.5	0.2	0.8
09/15/2024 11:00	3,646.0	0.0	3,646.0	105,505.0	384.7	0.5	0.2	0.8
09/15/2024 12:00	3,644.7	0.0	3,644.7	105,505.0	384.5	0.5	0.2	0.8
09/15/2024 13:00	3,643.0	0.0	3,643.0	105,505.0	384.4	0.5	0.2	0.8
09/15/2024 14:00	3,640.0	0.0	3,640.0	105,505.0	384.0	0.5	0.2	0.8
09/15/2024 15:00	3,643.0	0.0	3,643.0	105,505.0	384.4	0.5	0.2	0.8
09/15/2024 16:00	3,901.4	0.0	3,901.4	105,505.0	411.6	0.5	0.2	0.8
09/15/2024 17:00	3,655.4	0.0	3,655.4	105,505.0	385.7	0.5	0.2	0.8
09/15/2024 18:00	3,649.5	0.0	3,649.5	105,505.0	385.0	0.5	0.2	0.8
09/15/2024 19:00	3,653.5	0.0	3,653.5	105,505.0	385.5	0.5	0.2	0.8
09/15/2024 20:00	3,663.9	0.0	3,663.9	105,505.0	386.6	0.5	0.2	0.8
09/15/2024 21:00	3,659.5	0.0	3,659.5	105,505.0	386.1	0.5	0.2	0.8
09/15/2024 22:00	3,660.4	0.0	3,660.4	105,505.0	386.2	0.5	0.2	0.8
09/15/2024 23:00	3,662.3	0.0	3,662.3	105,505.0	386.4	0.5	0.2	0.8
Average/Sum#:	3,671.6	0.0	3,671.6	105,505.0	387.4	0.5	0.2	0.8
Minimum:	3,640.0	0.0	3,640.0	105,505.0	384.0	0.5	0.2	0.8
Maximum:	3,901.4	0.0	3,901.4	105,505.0	411.6	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2024 00:00	3,665.2	0.0	3,665.2	105,505.0	386.7	0.5	0.2	0.8
09/16/2024 01:00	3,668.4	0.0	3,668.4	105,505.0	387.0	0.5	0.2	0.8
09/16/2024 02:00	3,672.5	0.0	3,672.5	105,505.0	387.5	0.5	0.2	0.8
09/16/2024 03:00	3,676.7	0.0	3,676.7	105,505.0	387.9	0.5	0.2	0.8
09/16/2024 04:00	3,688.4	0.0	3,688.4	105,505.0	389.1	0.5	0.2	0.8
09/16/2024 05:00	4,042.8	0.0	4,042.8	105,505.0	426.5	0.5	0.3	0.9
09/16/2024 06:00	4,013.7	0.0	4,013.7	105,505.0	423.5	0.5	0.3	0.8
09/16/2024 07:00	4,436.9	0.0	4,436.9	105,505.0	468.1	0.6	0.3	0.9
09/16/2024 08:00	4,663.6	131.4	4,753.0	105,505.0	501.5	0.6	0.3	1.0
09/16/2024 09:00	4,592.1	1.5	4,592.1	105,505.0	484.5	0.6	0.3	1.0
09/16/2024 10:00	4,603.3	0.0	4,603.3	105,505.0	485.7	0.6	0.3	1.0
09/16/2024 11:00	4,599.2	0.0	4,599.2	105,505.0	485.2	0.6	0.3	1.0
09/16/2024 12:00	4,096.3	0.0	4,096.3	105,505.0	432.2	0.5	0.3	0.9
09/16/2024 13:00	3,654.6	0.0	3,654.6	105,505.0	385.6	0.5	0.2	0.8
09/16/2024 14:00	3,648.7	0.0	3,648.7	105,505.0	385.0	0.5	0.2	0.8
09/16/2024 15:00	3,653.7	0.0	3,653.7	105,505.0	385.5	0.5	0.2	0.8
09/16/2024 16:00	3,914.8	0.0	3,914.8	105,505.0	413.0	0.5	0.2	0.8
09/16/2024 17:00	3,705.3	0.0	3,705.3	105,505.0	390.9	0.5	0.2	0.8
09/16/2024 18:00	3,681.7	0.0	3,681.7	105,505.0	388.4	0.5	0.2	0.8
09/16/2024 19:00	3,685.6	0.0	3,685.6	105,505.0	388.8	0.5	0.2	0.8
09/16/2024 20:00	4,321.1	0.0	4,321.1	105,505.0	455.9	0.5	0.3	0.9
09/16/2024 21:00	4,093.0	0.0	4,093.0	105,505.0	431.8	0.5	0.3	0.9
09/16/2024 22:00	4,283.4	0.0	4,283.4	105,505.0	451.9	0.5	0.3	0.9
09/16/2024 23:00	3,772.8	0.0	3,772.8	105,505.0	398.0	0.5	0.2	0.8
Average/Sum#:	3,993.1	5.5	3,996.8	105,505.0	421.7	0.5	0.2	0.9
Minimum:	3,648.7	0.0	3,648.7	105,505.0	385.0	0.5	0.2	0.8
Maximum:	4,663.6	131.4	4,753.0	105,505.0	501.5	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2024 00:00	3,667.3	0.0	3,667.3	105,505.0	386.9	0.5	0.2	0.8
09/17/2024 01:00	3,670.5	0.0	3,670.5	105,505.0	387.3	0.5	0.2	0.8
09/17/2024 02:00	3,672.1	0.0	3,672.1	105,505.0	387.4	0.5	0.2	0.8
09/17/2024 03:00	3,674.5	0.0	3,674.5	105,505.0	387.7	0.5	0.2	0.8
09/17/2024 04:00	3,876.8	0.0	3,876.8	105,505.0	409.0	0.5	0.2	0.8
09/17/2024 05:00	4,317.7	0.0	4,317.7	105,505.0	455.5	0.5	0.3	0.9
09/17/2024 06:00	3,874.1	0.0	3,874.1	105,505.0	408.7	0.5	0.2	0.8
09/17/2024 07:00	3,694.2	0.0	3,694.2	105,505.0	389.8	0.5	0.2	0.8
09/17/2024 08:00	3,699.3	0.0	3,699.3	105,505.0	390.3	0.5	0.2	0.8
09/17/2024 09:00	3,698.6	0.0	3,698.6	105,505.0	390.2	0.5	0.2	0.8
09/17/2024 10:00	3,689.2	0.0	3,689.2	105,505.0	389.2	0.5	0.2	0.8
09/17/2024 11:00	3,684.1	0.0	3,684.1	105,505.0	388.7	0.5	0.2	0.8
09/17/2024 12:00	3,697.8	0.0	3,697.8	105,505.0	390.1	0.5	0.2	0.8
09/17/2024 13:00	3,685.3	0.0	3,685.3	105,505.0	388.8	0.5	0.2	0.8
09/17/2024 14:00	3,676.2	0.0	3,676.2	105,505.0	387.9	0.5	0.2	0.8
09/17/2024 15:00	3,677.6	0.0	3,677.6	105,505.0	388.0	0.5	0.2	0.8
09/17/2024 16:00	3,675.0	0.0	3,675.0	105,505.0	387.7	0.5	0.2	0.8
09/17/2024 17:00	3,674.3	0.0	3,674.3	105,505.0	387.7	0.5	0.2	0.8
09/17/2024 18:00	3,675.7	0.0	3,675.7	105,505.0	387.8	0.5	0.2	0.8
09/17/2024 19:00	3,681.0	0.0	3,681.0	105,505.0	388.4	0.5	0.2	0.8
09/17/2024 20:00	3,679.8	0.0	3,679.8	105,505.0	388.2	0.5	0.2	0.8
09/17/2024 21:00	3,681.0	0.0	3,681.0	105,505.0	388.4	0.5	0.2	0.8
09/17/2024 22:00	3,682.1	0.0	3,682.1	105,505.0	388.5	0.5	0.2	0.8
09/17/2024 23:00	3,683.4	0.0	3,683.4	105,505.0	388.6	0.5	0.2	0.8
Average/Sum#:	3,724.5	0.0	3,724.5	105,505.0	393.0	0.5	0.2	0.8
Minimum:	3,667.3	0.0	3,667.3	105,505.0	386.9	0.5	0.2	0.8
Maximum:	4,317.7	0.0	4,317.7	105,505.0	455.5	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/18/2024 00:00	3,684.8	0.0	3,684.8	105,505.0	388.8	0.5	0.2	0.8
09/18/2024 01:00	3,682.6	0.0	3,682.6	105,505.0	388.5	0.5	0.2	0.8
09/18/2024 02:00	3,662.3	0.0	3,662.3	105,505.0	386.4	0.5	0.2	0.8
09/18/2024 03:00	3,663.2	0.0	3,663.2	105,505.0	386.5	0.5	0.2	0.8
09/18/2024 04:00	3,676.5	0.0	3,676.5	105,505.0	387.9	0.5	0.2	0.8
09/18/2024 05:00	3,723.0	0.0	3,723.0	105,505.0	392.8	0.5	0.2	0.8
09/18/2024 06:00	3,918.9	0.0	3,918.9	105,505.0	413.5	0.5	0.2	0.8
09/18/2024 07:00	3,674.7	0.0	3,674.7	105,505.0	387.7	0.5	0.2	0.8
09/18/2024 08:00	3,666.6	0.0	3,666.6	105,505.0	386.8	0.5	0.2	0.8
09/18/2024 09:00	3,668.6	0.0	3,668.6	105,505.0	387.1	0.5	0.2	0.8
09/18/2024 10:00	3,665.9	0.0	3,665.9	105,505.0	386.8	0.5	0.2	0.8
09/18/2024 11:00	3,663.9	0.0	3,663.9	105,505.0	386.6	0.5	0.2	0.8
09/18/2024 12:00	3,667.4	0.0	3,667.4	105,505.0	386.9	0.5	0.2	0.8
09/18/2024 13:00	3,670.5	0.0	3,670.5	105,505.0	387.3	0.5	0.2	0.8
09/18/2024 14:00	3,666.0	0.0	3,666.0	105,505.0	386.8	0.5	0.2	0.8
09/18/2024 15:00	3,667.8	0.0	3,667.8	105,505.0	387.0	0.5	0.2	0.8
09/18/2024 16:00	4,057.1	0.0	4,057.1	105,505.0	428.0	0.5	0.3	0.9
09/18/2024 17:00	4,086.6	0.0	4,086.6	105,505.0	431.2	0.5	0.3	0.9
09/18/2024 18:00	3,658.6	0.0	3,658.6	105,505.0	386.0	0.5	0.2	0.8
09/18/2024 19:00	3,660.0	0.0	3,660.0	105,505.0	386.1	0.5	0.2	0.8
09/18/2024 20:00	4,556.0	0.0	4,556.0	105,505.0	480.7	0.6	0.3	1.0
09/18/2024 21:00	4,607.8	0.0	4,607.8	105,505.0	486.1	0.6	0.3	1.0
09/18/2024 22:00	4,607.8	0.0	4,607.8	105,505.0	486.1	0.6	0.3	1.0
09/18/2024 23:00	4,591.7	0.0	4,591.7	105,505.0	484.4	0.6	0.3	1.0
Average/Sum#:	3,868.7	0.0	3,868.7	105,505.0	408.2	0.5	0.2	0.8
Minimum:	3,658.6	0.0	3,658.6	105,505.0	386.0	0.5	0.2	0.8
Maximum:	4,607.8	0.0	4,607.8	105,505.0	486.1	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/19/2024 00:00	4,612.3	0.0	4,612.3	105,505.0	486.6	0.6	0.3	1.0
09/19/2024 01:00	4,520.0	0.0	4,520.0	105,505.0	476.9	0.6	0.3	1.0
09/19/2024 02:00	4,411.2	0.0	4,411.2	105,505.0	465.4	0.6	0.3	0.9
09/19/2024 03:00	4,595.3	0.0	4,595.3	105,505.0	484.8	0.6	0.3	1.0
09/19/2024 04:00	4,587.9	0.0	4,587.9	105,505.0	484.0	0.6	0.3	1.0
09/19/2024 05:00	4,582.2	0.0	4,582.2	105,505.0	483.4	0.6	0.3	1.0
09/19/2024 06:00	4,001.2	0.0	4,001.2	105,505.0	422.1	0.5	0.3	0.8
09/19/2024 07:00	4,486.8	0.0	4,486.8	105,505.0	473.4	0.6	0.3	0.9
09/19/2024 08:00	3,832.2	0.0	3,832.2	105,505.0	404.3	0.5	0.2	0.8
09/19/2024 09:00	3,643.6	0.0	3,643.6	105,505.0	384.4	0.5	0.2	0.8
09/19/2024 10:00	3,649.9	0.0	3,649.9	105,505.0	385.1	0.5	0.2	0.8
09/19/2024 11:00	3,639.2	0.0	3,639.2	105,505.0	384.0	0.5	0.2	0.8
09/19/2024 12:00	3,641.9	0.0	3,641.9	105,505.0	384.2	0.5	0.2	0.8
09/19/2024 13:00	3,632.6	0.0	3,632.6	105,505.0	383.3	0.5	0.2	0.8
09/19/2024 14:00	3,631.0	0.0	3,631.0	105,505.0	383.1	0.5	0.2	0.8
09/19/2024 15:00	3,630.6	0.0	3,630.6	105,505.0	383.0	0.5	0.2	0.8
09/19/2024 16:00	4,009.3	0.0	4,009.3	105,505.0	423.0	0.5	0.3	0.8
09/19/2024 17:00	4,530.1	130.2	4,560.0	105,505.0	481.1	0.6	0.3	1.0
09/19/2024 18:00	4,581.4	1,173.4	5,754.8	105,505.0	607.2	0.7	0.4	1.2
09/19/2024 19:00	4,595.0	700.2	5,260.2	105,505.0	555.0	0.7	0.3	1.1
09/19/2024 20:00	4,585.4	0.0	4,585.4	105,505.0	483.8	0.6	0.3	1.0
09/19/2024 21:00	4,486.7	0.0	4,486.7	105,505.0	473.4	0.6	0.3	0.9
09/19/2024 22:00	3,697.3	0.0	3,697.3	105,505.0	390.1	0.5	0.2	0.8
09/19/2024 23:00	3,677.0	0.0	3,677.0	105,505.0	387.9	0.5	0.2	0.8
Average/Sum#:	4,135.8	83.5	4,213.7	105,505.0	444.6	0.6	0.3	0.9
Minimum:	3,630.6	0.0	3,630.6	105,505.0	383.0	0.5	0.2	0.8
Maximum:	4,612.3	1,173.4	5,754.8	105,505.0	607.2	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2024 00:00	3,634.6	0.0	3,634.6	105,505.0	383.5	0.5	0.2	0.8
09/20/2024 01:00	3,629.8	0.0	3,629.8	105,505.0	383.0	0.5	0.2	0.8
09/20/2024 02:00	3,621.8	0.0	3,621.8	105,505.0	382.1	0.5	0.2	0.8
09/20/2024 03:00	3,622.0	0.0	3,622.0	105,505.0	382.1	0.5	0.2	0.8
09/20/2024 04:00	3,702.5	0.0	3,702.5	105,505.0	390.6	0.5	0.2	0.8
09/20/2024 05:00	3,915.3	0.0	3,915.3	105,505.0	413.1	0.5	0.2	0.8
09/20/2024 06:00	3,757.9	0.0	3,757.9	105,505.0	396.5	0.5	0.2	0.8
09/20/2024 07:00	3,641.6	0.0	3,641.6	105,505.0	384.2	0.5	0.2	0.8
09/20/2024 08:00	3,626.2	0.0	3,626.2	105,505.0	382.6	0.5	0.2	0.8
09/20/2024 09:00	3,645.9	0.0	3,645.9	105,505.0	384.7	0.5	0.2	0.8
09/20/2024 10:00	3,877.8	0.0	3,877.8	105,505.0	409.1	0.5	0.2	0.8
09/20/2024 11:00	4,466.6	0.0	4,466.6	105,505.0	471.2	0.6	0.3	0.9
09/20/2024 12:00	4,464.2	0.0	4,464.2	105,505.0	471.0	0.6	0.3	0.9
09/20/2024 13:00	4,065.1	0.0	4,065.1	105,505.0	428.9	0.5	0.3	0.9
09/20/2024 14:00	3,999.0	0.0	3,999.0	105,505.0	421.9	0.5	0.3	0.8
09/20/2024 15:00	3,605.0	0.0	3,605.0	105,505.0	380.3	0.5	0.2	0.8
09/20/2024 16:00	3,795.7	0.0	3,795.7	105,505.0	400.5	0.5	0.2	0.8
09/20/2024 17:00	3,866.0	0.0	3,866.0	105,505.0	407.9	0.5	0.2	0.8
09/20/2024 18:00	3,602.7	0.0	3,602.7	105,505.0	380.1	0.5	0.2	0.8
09/20/2024 19:00	3,606.5	0.0	3,606.5	105,505.0	380.5	0.5	0.2	0.8
09/20/2024 20:00	3,611.9	0.0	3,611.9	105,505.0	381.1	0.5	0.2	0.8
09/20/2024 21:00	3,615.3	0.0	3,615.3	105,505.0	381.4	0.5	0.2	0.8
09/20/2024 22:00	3,611.8	0.0	3,611.8	105,505.0	381.1	0.5	0.2	0.8
09/20/2024 23:00	3,612.6	0.0	3,612.6	105,505.0	381.1	0.5	0.2	0.8
Average/Sum#:	3,774.9	0.0	3,774.9	105,505.0	398.3	0.5	0.2	0.8
Minimum:	3,602.7	0.0	3,602.7	105,505.0	380.1	0.5	0.2	0.8
Maximum:	4,466.6	0.0	4,466.6	105,505.0	471.2	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/21/2024 00:00	3,616.5	0.0	3,616.5	105,505.0	381.6	0.5	0.2	0.8
09/21/2024 01:00	3,618.4	0.0	3,618.4	105,505.0	381.8	0.5	0.2	0.8
09/21/2024 02:00	3,639.3	0.0	3,639.3	105,505.0	384.0	0.5	0.2	0.8
09/21/2024 03:00	3,848.2	0.0	3,848.2	105,505.0	406.0	0.5	0.2	0.8
09/21/2024 04:00	4,078.4	0.0	4,078.4	105,505.0	430.3	0.5	0.3	0.9
09/21/2024 05:00	3,695.9	0.0	3,695.9	105,505.0	389.9	0.5	0.2	0.8
09/21/2024 06:00	3,896.0	0.0	3,896.0	105,505.0	411.0	0.5	0.2	0.8
09/21/2024 07:00	3,645.3	0.0	3,645.3	105,505.0	384.6	0.5	0.2	0.8
09/21/2024 08:00	3,639.3	0.0	3,639.3	105,505.0	384.0	0.5	0.2	0.8
09/21/2024 09:00	3,625.3	0.0	3,625.3	105,505.0	382.5	0.5	0.2	0.8
09/21/2024 10:00	3,624.9	0.0	3,624.9	105,505.0	382.4	0.5	0.2	0.8
09/21/2024 11:00	3,941.2	0.0	3,941.2	105,505.0	415.8	0.5	0.2	0.8
09/21/2024 12:00	4,191.8	0.0	4,191.8	105,505.0	442.3	0.5	0.3	0.9
09/21/2024 13:00	4,492.9	0.0	4,492.9	105,505.0	474.0	0.6	0.3	0.9
09/21/2024 14:00	4,446.7	0.0	4,446.7	105,505.0	469.1	0.6	0.3	0.9
09/21/2024 15:00	3,917.6	0.0	3,917.6	105,505.0	413.3	0.5	0.2	0.8
09/21/2024 16:00	4,482.8	909.5	5,374.1	105,505.0	567.0	0.7	0.3	1.1
09/21/2024 17:00	4,488.4	1,389.4	5,877.8	105,505.0	620.1	0.7	0.4	1.2
09/21/2024 18:00	4,501.2	822.3	5,323.5	105,505.0	561.7	0.7	0.3	1.1
09/21/2024 19:00	4,506.8	456.3	4,862.7	105,505.0	513.0	0.6	0.3	1.0
09/21/2024 20:00	3,803.6	0.0	3,803.6	105,505.0	401.3	0.5	0.2	0.8
09/21/2024 21:00	3,723.8	0.0	3,723.8	105,505.0	392.9	0.5	0.2	0.8
09/21/2024 22:00	3,683.9	0.0	3,683.9	105,505.0	388.7	0.5	0.2	0.8
09/21/2024 23:00	3,615.4	0.0	3,615.4	105,505.0	381.4	0.5	0.2	0.8
Average/Sum#:	3,946.8	149.1	4,090.9	105,505.0	431.6	0.5	0.2	0.9
Minimum:	3,615.4	0.0	3,615.4	105,505.0	381.4	0.5	0.2	0.8
Maximum:	4,506.8	1,389.4	5,877.8	105,505.0	620.1	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/22/2024 00:00	3,634.9	0.0	3,634.9	105,505.0	383.5	0.5	0.2	0.8
09/22/2024 01:00	3,620.3	0.0	3,620.3	105,505.0	382.0	0.5	0.2	0.8
09/22/2024 02:00	3,618.4	0.0	3,618.4	105,505.0	381.8	0.5	0.2	0.8
09/22/2024 03:00	3,616.5	0.0	3,616.5	105,505.0	381.6	0.5	0.2	0.8
09/22/2024 04:00	3,618.0	0.0	3,618.0	105,505.0	381.7	0.5	0.2	0.8
09/22/2024 05:00	3,619.4	0.0	3,619.4	105,505.0	381.9	0.5	0.2	0.8
09/22/2024 06:00	3,624.6	0.0	3,624.6	105,505.0	382.4	0.5	0.2	0.8
09/22/2024 07:00	3,640.3	0.0	3,640.3	105,505.0	384.1	0.5	0.2	0.8
09/22/2024 08:00	3,639.4	0.0	3,639.4	105,505.0	384.0	0.5	0.2	0.8
09/22/2024 09:00	3,628.7	0.0	3,628.7	105,505.0	382.8	0.5	0.2	0.8
09/22/2024 10:00	3,624.8	0.0	3,624.8	105,505.0	382.4	0.5	0.2	0.8
09/22/2024 11:00	3,619.1	0.0	3,619.1	105,505.0	381.8	0.5	0.2	0.8
09/22/2024 12:00	3,613.6	0.0	3,613.6	105,505.0	381.3	0.5	0.2	0.8
09/22/2024 13:00	4,375.4	0.0	4,375.4	105,505.0	461.6	0.6	0.3	0.9
09/22/2024 14:00	3,964.9	0.0	3,964.9	105,505.0	418.3	0.5	0.3	0.8
09/22/2024 15:00	3,613.2	0.0	3,613.2	105,505.0	381.2	0.5	0.2	0.8
09/22/2024 16:00	3,923.9	0.0	3,923.9	105,505.0	414.0	0.5	0.2	0.8
09/22/2024 17:00	3,614.9	0.0	3,614.9	105,505.0	381.4	0.5	0.2	0.8
09/22/2024 18:00	3,593.9	0.0	3,593.9	105,505.0	379.2	0.5	0.2	0.8
09/22/2024 19:00	3,598.2	0.0	3,598.2	105,505.0	379.6	0.5	0.2	0.8
09/22/2024 20:00	3,581.8	0.0	3,581.8	105,505.0	377.9	0.5	0.2	0.8
09/22/2024 21:00	3,584.0	0.0	3,584.0	105,505.0	378.1	0.5	0.2	0.8
09/22/2024 22:00	3,597.5	0.0	3,597.5	105,505.0	379.6	0.5	0.2	0.8
09/22/2024 23:00	3,614.8	0.0	3,614.8	105,505.0	381.4	0.5	0.2	0.8
Average/Sum#:	3,674.2	0.0	3,674.2	105,505.0	387.7	0.5	0.2	0.8
Minimum:	3,581.8	0.0	3,581.8	105,505.0	377.9	0.5	0.2	0.8
Maximum:	4,375.4	0.0	4,375.4	105,505.0	461.6	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2024 00:00	3,616.5	0.0	3,616.5	105,505.0	381.6	0.5	0.2	0.8
09/23/2024 01:00	3,619.8	0.0	3,619.8	105,505.0	381.9	0.5	0.2	0.8
09/23/2024 02:00	3,615.7	0.0	3,615.7	105,505.0	381.5	0.5	0.2	0.8
09/23/2024 03:00	3,615.4	0.0	3,615.4	105,505.0	381.4	0.5	0.2	0.8
09/23/2024 04:00	3,614.5	0.0	3,614.5	105,505.0	381.3	0.5	0.2	0.8
09/23/2024 05:00	3,616.2	0.0	3,616.2	105,505.0	381.5	0.5	0.2	0.8
09/23/2024 06:00	3,645.4	0.0	3,645.4	105,505.0	384.6	0.5	0.2	0.8
09/23/2024 07:00	3,620.2	0.0	3,620.2	105,505.0	381.9	0.5	0.2	0.8
09/23/2024 08:00	3,613.4	0.0	3,613.4	105,505.0	381.2	0.5	0.2	0.8
09/23/2024 09:00	3,616.0	0.0	3,616.0	105,505.0	381.5	0.5	0.2	0.8
09/23/2024 10:00	3,627.3	0.0	3,627.3	105,505.0	382.7	0.5	0.2	0.8
09/23/2024 11:00	3,623.7	0.0	3,623.7	105,505.0	382.3	0.5	0.2	0.8
09/23/2024 12:00	3,667.7	0.0	3,667.7	105,505.0	387.0	0.5	0.2	0.8
09/23/2024 13:00	3,888.0	0.0	3,888.0	105,505.0	410.2	0.5	0.2	0.8
09/23/2024 14:00	3,954.4	0.0	3,954.4	105,505.0	417.2	0.5	0.3	0.8
09/23/2024 15:00	4,007.2	27.6	4,011.3	105,505.0	423.2	0.5	0.3	0.9
09/23/2024 16:00	4,392.8	607.1	4,890.6	105,505.0	516.0	0.6	0.3	1.1
09/23/2024 17:00	4,414.0	1,386.4	5,800.4	105,505.0	612.0	0.7	0.4	1.2
09/23/2024 18:00	4,442.6	1,106.7	5,549.3	105,505.0	585.5	0.7	0.4	1.2
09/23/2024 19:00	4,454.3	754.8	5,043.0	105,505.0	532.1	0.7	0.3	1.1
09/23/2024 20:00	4,436.1	0.0	4,436.1	105,505.0	468.0	0.6	0.3	0.9
09/23/2024 21:00	4,425.8	0.0	4,425.8	105,505.0	466.9	0.6	0.3	0.9
09/23/2024 22:00	4,366.8	0.0	4,366.8	105,505.0	460.7	0.6	0.3	0.9
09/23/2024 23:00	4,165.2	0.0	4,165.2	105,505.0	439.4	0.5	0.3	0.9
Average/Sum#:	3,919.1	161.8	4,068.4	105,505.0	429.2	0.5	0.3	0.9
Minimum:	3,613.4	0.0	3,613.4	105,505.0	381.2	0.5	0.2	0.8
Maximum:	4,454.3	1,386.4	5,800.4	105,505.0	612.0	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2024 00:00	4,138.0	0.0	4,138.0	105,505.0	436.6	0.5	0.3	0.9
09/24/2024 01:00	3,661.6	0.0	3,661.6	105,505.0	386.3	0.5	0.2	0.8
09/24/2024 02:00	3,617.7	0.0	3,617.7	105,505.0	381.7	0.5	0.2	0.8
09/24/2024 03:00	3,778.8	0.0	3,778.8	105,505.0	398.7	0.5	0.2	0.8
09/24/2024 04:00	4,278.7	0.0	4,278.7	105,505.0	451.4	0.5	0.3	0.9
09/24/2024 05:00	4,441.6	0.0	4,441.6	105,505.0	468.6	0.6	0.3	0.9
09/24/2024 06:00	3,844.8	0.0	3,844.8	105,505.0	405.6	0.5	0.2	0.8
09/24/2024 07:00	3,611.9	0.0	3,611.9	105,505.0	381.1	0.5	0.2	0.8
09/24/2024 08:00	3,580.9	0.0	3,580.9	105,505.0	377.8	0.5	0.2	0.8
09/24/2024 09:00	3,598.5	0.0	3,598.5	105,505.0	379.7	0.5	0.2	0.8
09/24/2024 10:00	3,612.7	0.0	3,612.7	105,505.0	381.2	0.5	0.2	0.8
09/24/2024 11:00	3,602.0	0.0	3,602.0	105,505.0	380.0	0.5	0.2	0.8
09/24/2024 12:00	3,920.2	0.0	3,920.2	105,505.0	413.6	0.5	0.2	0.8
09/24/2024 13:00	4,198.6	0.0	4,198.6	105,505.0	443.0	0.5	0.3	0.9
09/24/2024 14:00	4,235.7	0.0	4,235.7	105,505.0	446.9	0.5	0.3	0.9
09/24/2024 15:00	3,821.3	0.0	3,821.3	105,505.0	403.2	0.5	0.2	0.8
09/24/2024 16:00	4,051.5	233.1	4,116.8	105,505.0	434.3	0.5	0.3	0.9
09/24/2024 17:00	4,400.1	900.5	5,300.6	105,505.0	559.2	0.7	0.3	1.1
09/24/2024 18:00	4,209.7	386.2	4,422.1	105,505.0	466.6	0.6	0.3	1.0
09/24/2024 19:00	3,605.2	0.0	3,605.2	105,505.0	380.4	0.5	0.2	0.8
09/24/2024 20:00	3,612.1	0.0	3,612.1	105,505.0	381.1	0.5	0.2	0.8
09/24/2024 21:00	3,612.7	0.0	3,612.7	105,505.0	381.2	0.5	0.2	0.8
09/24/2024 22:00	3,606.8	0.0	3,606.8	105,505.0	380.5	0.5	0.2	0.8
09/24/2024 23:00	3,618.9	0.0	3,618.9	105,505.0	381.8	0.5	0.2	0.8
Average/Sum#:	3,860.8	63.3	3,909.9	105,505.0	412.5	0.5	0.2	0.8
Minimum:	3,580.9	0.0	3,580.9	105,505.0	377.8	0.5	0.2	0.8
Maximum:	4,441.6	900.5	5,300.6	105,505.0	559.2	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/25/2024 00:00	3,619.5	0.0	3,619.5	105,505.0	381.9	0.5	0.2	0.8
09/25/2024 01:00	3,618.2	0.0	3,618.2	105,505.0	381.7	0.5	0.2	0.8
09/25/2024 02:00	3,627.9	0.0	3,627.9	105,505.0	382.8	0.5	0.2	0.8
09/25/2024 03:00	3,635.7	0.0	3,635.7	105,505.0	383.6	0.5	0.2	0.8
09/25/2024 04:00	3,784.1	0.0	3,784.1	105,505.0	399.2	0.5	0.2	0.8
09/25/2024 05:00	4,057.0	0.0	4,057.0	105,505.0	428.0	0.5	0.3	0.9
09/25/2024 06:00	3,753.1	0.0	3,753.1	105,505.0	396.0	0.5	0.2	0.8
09/25/2024 07:00	3,599.9	0.0	3,599.9	105,505.0	379.8	0.5	0.2	0.8
09/25/2024 08:00	4,154.5	0.0	4,154.5	105,505.0	438.3	0.5	0.3	0.9
09/25/2024 09:00	3,751.2	0.0	3,751.2	105,505.0	395.8	0.5	0.2	0.8
09/25/2024 10:00	3,633.3	0.0	3,633.3	105,505.0	383.3	0.5	0.2	0.8
09/25/2024 11:00	3,593.7	0.0	3,593.7	105,505.0	379.2	0.5	0.2	0.8
09/25/2024 12:00	3,588.0	0.0	3,588.0	105,505.0	378.6	0.5	0.2	0.8
09/25/2024 13:00	3,594.6	0.0	3,594.6	105,505.0	379.2	0.5	0.2	0.8
09/25/2024 14:00	3,576.5	0.0	3,576.5	105,505.0	377.3	0.5	0.2	0.8
09/25/2024 15:00	3,577.5	0.0	3,577.5	105,505.0	377.4	0.5	0.2	0.8
09/25/2024 16:00	3,769.4	0.0	3,769.4	105,505.0	397.7	0.5	0.2	0.8
09/25/2024 17:00	3,629.4	0.0	3,629.4	105,505.0	382.9	0.5	0.2	0.8
09/25/2024 18:00	3,615.9	0.0	3,615.9	105,505.0	381.5	0.5	0.2	0.8
09/25/2024 19:00	3,601.9	0.0	3,601.9	105,505.0	380.0	0.5	0.2	0.8
09/25/2024 20:00	3,605.1	0.0	3,605.1	105,505.0	380.4	0.5	0.2	0.8
09/25/2024 21:00	3,609.6	0.0	3,609.6	105,505.0	380.8	0.5	0.2	0.8
09/25/2024 22:00	3,608.8	0.0	3,608.8	105,505.0	380.7	0.5	0.2	0.8
09/25/2024 23:00	3,611.5	0.0	3,611.5	105,505.0	381.0	0.5	0.2	0.8
Average/Sum#:	3,675.7	0.0	3,675.7	105,505.0	387.8	0.5	0.2	0.8
Minimum:	3,576.5	0.0	3,576.5	105,505.0	377.3	0.5	0.2	0.8
Maximum:	4,154.5	0.0	4,154.5	105,505.0	438.3	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/26/2024 00:00	3,611.8	0.0	3,611.8	105,505.0	381.1	0.5	0.2	0.8
09/26/2024 01:00	3,612.2	0.0	3,612.2	105,505.0	381.1	0.5	0.2	0.8
09/26/2024 02:00	3,615.0	0.0	3,615.0	105,505.0	381.4	0.5	0.2	0.8
09/26/2024 03:00	3,613.1	0.0	3,613.1	105,505.0	381.2	0.5	0.2	0.8
09/26/2024 04:00	3,615.0	0.0	3,615.0	105,505.0	381.4	0.5	0.2	0.8
09/26/2024 05:00	3,615.8	0.0	3,615.8	105,505.0	381.5	0.5	0.2	0.8
09/26/2024 06:00	3,618.6	0.0	3,618.6	105,505.0	381.8	0.5	0.2	0.8
09/26/2024 07:00	3,622.9	0.0	3,622.9	105,505.0	382.2	0.5	0.2	0.8
09/26/2024 08:00	3,623.6	0.0	3,623.6	105,505.0	382.3	0.5	0.2	0.8
09/26/2024 09:00	3,614.2	0.0	3,614.2	105,505.0	381.3	0.5	0.2	0.8
09/26/2024 10:00	3,602.5	0.0	3,602.5	105,505.0	380.1	0.5	0.2	0.8
09/26/2024 11:00	3,601.2	0.0	3,601.2	105,505.0	379.9	0.5	0.2	0.8
09/26/2024 12:00	3,616.5	0.0	3,616.5	105,505.0	381.6	0.5	0.2	0.8
09/26/2024 13:00	3,609.3	0.0	3,609.3	105,505.0	380.8	0.5	0.2	0.8
09/26/2024 14:00	3,601.5	0.0	3,601.5	105,505.0	380.0	0.5	0.2	0.8
09/26/2024 15:00	3,593.4	0.0	3,593.4	105,505.0	379.1	0.5	0.2	0.8
09/26/2024 16:00	4,145.9	165.8	4,192.3	105,505.0	442.3	0.5	0.3	0.9
09/26/2024 17:00	4,517.9	876.4	5,394.3	105,505.0	569.1	0.7	0.3	1.1
09/26/2024 18:00	4,545.7	860.2	5,405.9	105,505.0	570.3	0.7	0.3	1.1
09/26/2024 19:00	4,575.7	768.4	5,344.1	105,505.0	563.8	0.7	0.3	1.1
09/26/2024 20:00	4,580.6	840.1	5,420.7	105,505.0	571.9	0.7	0.3	1.1
09/26/2024 21:00	4,394.0	281.4	4,543.1	105,505.0	479.3	0.6	0.3	1.0
09/26/2024 22:00	3,955.5	0.0	3,955.5	105,505.0	417.3	0.5	0.3	0.8
09/26/2024 23:00	3,658.1	0.0	3,658.1	105,505.0	385.9	0.5	0.2	0.8
Average/Sum#:	3,840.0	158.0	3,987.5	105,505.0	420.7	0.5	0.2	0.9
Minimum:	3,593.4	0.0	3,593.4	105,505.0	379.1	0.5	0.2	0.8
Maximum:	4,580.6	876.4	5,420.7	105,505.0	571.9	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/27/2024 00:00	3,594.5	0.0	3,594.5	105,505.0	379.2	0.5	0.2	0.8
09/27/2024 01:00	3,597.0	0.0	3,597.0	105,505.0	379.5	0.5	0.2	0.8
09/27/2024 02:00	3,597.4	0.0	3,597.4	105,505.0	379.5	0.5	0.2	0.8
09/27/2024 03:00	3,602.8	0.0	3,602.8	105,505.0	380.1	0.5	0.2	0.8
09/27/2024 04:00	4,096.3	0.0	4,096.3	105,505.0	432.2	0.5	0.3	0.9
09/27/2024 05:00	4,309.0	0.0	4,309.0	105,505.0	454.6	0.5	0.3	0.9
09/27/2024 06:00	3,910.1	0.0	3,910.1	105,505.0	412.5	0.5	0.2	0.8
09/27/2024 07:00	3,609.8	0.0	3,609.8	105,505.0	380.9	0.5	0.2	0.8
09/27/2024 08:00	3,602.4	0.0	3,602.4	105,505.0	380.1	0.5	0.2	0.8
09/27/2024 09:00	3,594.9	0.0	3,594.9	105,505.0	379.3	0.5	0.2	0.8
09/27/2024 10:00	3,591.4	0.0	3,591.4	105,505.0	378.9	0.5	0.2	0.8
09/27/2024 11:00	3,586.0	0.0	3,586.0	105,505.0	378.3	0.5	0.2	0.8
09/27/2024 12:00	3,568.6	0.0	3,568.6	105,505.0	376.5	0.5	0.2	0.8
09/27/2024 13:00	3,565.8	0.0	3,565.8	105,505.0	376.2	0.5	0.2	0.8
09/27/2024 14:00	3,560.5	0.0	3,560.5	105,505.0	375.7	0.5	0.2	0.8
09/27/2024 15:00	3,592.0	0.0	3,592.0	105,505.0	379.0	0.5	0.2	0.8
09/27/2024 16:00	4,115.5	197.2	4,204.2	105,505.0	443.6	0.5	0.3	0.9
09/27/2024 17:00	4,476.2	669.8	5,146.0	105,505.0	542.9	0.7	0.3	1.1
09/27/2024 18:00	4,493.0	641.3	5,134.3	105,505.0	541.7	0.7	0.3	1.1
09/27/2024 19:00	4,506.8	447.6	4,855.9	105,505.0	512.3	0.6	0.3	1.0
09/27/2024 20:00	4,423.8	0.0	4,423.8	105,505.0	466.7	0.6	0.3	0.9
09/27/2024 21:00	4,266.1	0.0	4,266.1	105,505.0	450.1	0.5	0.3	0.9
09/27/2024 22:00	4,233.8	0.0	4,233.8	105,505.0	446.7	0.5	0.3	0.9
09/27/2024 23:00	4,512.5	0.0	4,512.5	105,505.0	476.1	0.6	0.3	1.0
Average/Sum#:	3,916.9	81.5	3,989.8	105,505.0	420.9	0.5	0.2	0.9
Minimum:	3,560.5	0.0	3,560.5	105,505.0	375.7	0.5	0.2	0.8
Maximum:	4,512.5	669.8	5,146.0	105,505.0	542.9	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/28/2024 00:00	4,352.9	0.0	4,352.9	105,505.0	459.3	0.6	0.3	0.9
09/28/2024 01:00	3,855.9	0.0	3,855.9	105,505.0	406.8	0.5	0.2	0.8
09/28/2024 02:00	3,589.5	0.0	3,589.5	105,505.0	378.7	0.5	0.2	0.8
09/28/2024 03:00	3,592.5	0.0	3,592.5	105,505.0	379.0	0.5	0.2	0.8
09/28/2024 04:00	3,600.7	0.0	3,600.7	105,505.0	379.9	0.5	0.2	0.8
09/28/2024 05:00	3,621.8	0.0	3,621.8	105,505.0	382.1	0.5	0.2	0.8
09/28/2024 06:00	3,609.1	0.0	3,609.1	105,505.0	380.8	0.5	0.2	0.8
09/28/2024 07:00	3,595.5	0.0	3,595.5	105,505.0	379.3	0.5	0.2	0.8
09/28/2024 08:00	3,585.2	0.0	3,585.2	105,505.0	378.3	0.5	0.2	0.8
09/28/2024 09:00	3,575.7	0.0	3,575.7	105,505.0	377.3	0.5	0.2	0.8
09/28/2024 10:00	3,570.7	0.0	3,570.7	105,505.0	376.7	0.5	0.2	0.8
09/28/2024 11:00	3,563.6	0.0	3,563.6	105,505.0	376.0	0.5	0.2	0.8
09/28/2024 12:00	3,561.7	0.0	3,561.7	105,505.0	375.8	0.5	0.2	0.8
09/28/2024 13:00	3,587.6	0.0	3,587.6	105,505.0	378.5	0.5	0.2	0.8
09/28/2024 14:00	3,763.5	0.0	3,763.5	105,505.0	397.1	0.5	0.2	0.8
09/28/2024 15:00	3,863.9	0.0	3,863.9	105,505.0	407.7	0.5	0.2	0.8
09/28/2024 16:00	4,078.4	211.8	4,173.7	105,505.0	440.3	0.5	0.3	0.9
09/28/2024 17:00	4,470.8	657.3	5,128.1	105,505.0	541.0	0.7	0.3	1.1
09/28/2024 18:00	4,509.7	600.8	5,110.5	105,505.0	539.2	0.6	0.3	1.1
09/28/2024 19:00	4,492.8	425.9	4,825.0	105,505.0	509.1	0.6	0.3	1.0
09/28/2024 20:00	3,607.9	0.0	3,607.9	105,505.0	380.7	0.5	0.2	0.8
09/28/2024 21:00	3,582.6	0.0	3,582.6	105,505.0	378.0	0.5	0.2	0.8
09/28/2024 22:00	3,587.5	0.0	3,587.5	105,505.0	378.5	0.5	0.2	0.8
09/28/2024 23:00	3,592.6	0.0	3,592.6	105,505.0	379.0	0.5	0.2	0.8
Average/Sum#:	3,783.8	79.0	3,854.1	105,505.0	406.6	0.5	0.2	0.8
Minimum:	3,561.7	0.0	3,561.7	105,505.0	375.8	0.5	0.2	0.8
Maximum:	4,509.7	657.3	5,128.1	105,505.0	541.0	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/29/2024 00:00	3,594.3	0.0	3,594.3	105,505.0	379.2	0.5	0.2	0.8
09/29/2024 01:00	3,599.9	0.0	3,599.9	105,505.0	379.8	0.5	0.2	0.8
09/29/2024 02:00	3,601.3	0.0	3,601.3	105,505.0	380.0	0.5	0.2	0.8
09/29/2024 03:00	3,610.3	0.0	3,610.3	105,505.0	380.9	0.5	0.2	0.8
09/29/2024 04:00	3,613.4	0.0	3,613.4	105,505.0	381.2	0.5	0.2	0.8
09/29/2024 05:00	3,611.8	0.0	3,611.8	105,505.0	381.1	0.5	0.2	0.8
09/29/2024 06:00	3,613.1	0.0	3,613.1	105,505.0	381.2	0.5	0.2	0.8
09/29/2024 07:00	3,614.4	0.0	3,614.4	105,505.0	381.3	0.5	0.2	0.8
09/29/2024 08:00	3,608.7	0.0	3,608.7	105,505.0	380.7	0.5	0.2	0.8
09/29/2024 09:00	3,606.6	0.0	3,606.6	105,505.0	380.5	0.5	0.2	0.8
09/29/2024 10:00	3,603.1	0.0	3,603.1	105,505.0	380.1	0.5	0.2	0.8
09/29/2024 11:00	3,591.6	0.0	3,591.6	105,505.0	378.9	0.5	0.2	0.8
09/29/2024 12:00	3,582.3	0.0	3,582.3	105,505.0	378.0	0.5	0.2	0.8
09/29/2024 13:00	3,579.6	0.0	3,579.6	105,505.0	377.7	0.5	0.2	0.8
09/29/2024 14:00	3,579.5	0.0	3,579.5	105,505.0	377.7	0.5	0.2	0.8
09/29/2024 15:00	3,578.7	0.0	3,578.7	105,505.0	377.6	0.5	0.2	0.8
09/29/2024 16:00	4,013.5	0.0	4,013.5	105,505.0	423.4	0.5	0.3	0.8
09/29/2024 17:00	3,618.8	0.0	3,618.8	105,505.0	381.8	0.5	0.2	0.8
09/29/2024 18:00	3,582.2	0.0	3,582.2	105,505.0	377.9	0.5	0.2	0.8
09/29/2024 19:00	3,610.0	0.0	3,610.0	105,505.0	380.9	0.5	0.2	0.8
09/29/2024 20:00	3,588.4	0.0	3,588.4	105,505.0	378.6	0.5	0.2	0.8
09/29/2024 21:00	3,588.0	0.0	3,588.0	105,505.0	378.6	0.5	0.2	0.8
09/29/2024 22:00	3,592.6	0.0	3,592.6	105,505.0	379.0	0.5	0.2	0.8
09/29/2024 23:00	3,596.1	0.0	3,596.1	105,505.0	379.4	0.5	0.2	0.8
Average/Sum#:	3,615.8	0.0	3,615.8	105,505.0	381.5	0.5	0.2	0.8
Minimum:	3,578.7	0.0	3,578.7	105,505.0	377.6	0.5	0.2	0.8
Maximum:	4,013.5	0.0	4,013.5	105,505.0	423.4	0.5	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 08:48 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2024 00:00	3,598.9	0.0	3,598.9	105,505.0	379.7	0.5	0.2	0.8
09/30/2024 01:00	3,602.5	0.0	3,602.5	105,505.0	380.1	0.5	0.2	0.8
09/30/2024 02:00	3,606.8	0.0	3,606.8	105,505.0	380.5	0.5	0.2	0.8
09/30/2024 03:00	3,610.8	0.0	3,610.8	105,505.0	381.0	0.5	0.2	0.8
09/30/2024 04:00	3,617.5	0.0	3,617.5	105,505.0	381.7	0.5	0.2	0.8
09/30/2024 05:00	3,660.2	0.0	3,660.2	105,505.0	386.2	0.5	0.2	0.8
09/30/2024 06:00	3,944.8	0.0	3,944.8	105,505.0	416.2	0.5	0.2	0.8
09/30/2024 07:00	3,611.7	0.0	3,611.7	105,505.0	381.1	0.5	0.2	0.8
09/30/2024 08:00	3,604.4	0.0	3,604.4	105,505.0	380.3	0.5	0.2	0.8
09/30/2024 09:00	3,606.4	0.0	3,606.4	105,505.0	380.5	0.5	0.2	0.8
09/30/2024 10:00	3,605.3	0.0	3,605.3	105,505.0	380.4	0.5	0.2	0.8
09/30/2024 11:00	3,601.4	0.0	3,601.4	105,505.0	380.0	0.5	0.2	0.8
09/30/2024 12:00	3,597.9	0.0	3,597.9	105,505.0	379.6	0.5	0.2	0.8
09/30/2024 13:00	3,611.4	0.0	3,611.4	105,505.0	381.0	0.5	0.2	0.8
09/30/2024 14:00	3,601.1	0.0	3,601.1	105,505.0	379.9	0.5	0.2	0.8
09/30/2024 15:00	4,156.4	198.2	4,249.6	105,505.0	448.4	0.6	0.3	0.9
09/30/2024 16:00	4,531.8	1,548.7	6,080.5	105,505.0	641.5	0.8	0.4	1.3
09/30/2024 17:00	4,542.6	1,473.6	6,016.2	105,505.0	634.7	0.8	0.4	1.3
09/30/2024 18:00	4,546.3	1,305.3	5,851.6	105,505.0	617.4	0.7	0.4	1.2
09/30/2024 19:00	4,558.7	1,330.6	5,889.3	105,505.0	621.4	0.7	0.4	1.2
09/30/2024 20:00	4,566.5	1,390.4	5,956.9	105,505.0	628.5	0.8	0.4	1.3
09/30/2024 21:00	4,611.6	1,322.6	5,934.2	105,505.0	626.1	0.8	0.4	1.3
09/30/2024 22:00	4,643.4	842.1	5,485.5	105,505.0	578.7	0.7	0.3	1.2
09/30/2024 23:00	4,524.6	1.1	4,524.6	105,505.0	477.4	0.6	0.3	1.0
Average/Sum#:	3,965.1	392.2	4,352.9	105,505.0	459.3	0.6	0.3	0.9
Minimum:	3,597.9	0.0	3,597.9	105,505.0	379.6	0.5	0.2	0.8
Maximum:	4,643.4	1,548.7	6,080.5	105,505.0	641.5	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Linearity Report

10/11/2024

Page 1

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY
EDR Site ID:	CT001	Component ID:	A15
		Component Type:	NOXA
Instrument Name:	CT1_NOXDualRg_P_Instrum	Test End Date/Time:	07/16/2024
Performance Spec:	5 %	Test No.:	131
		Status (Pass/Fail):	Passed
		ReasonForTest:	QA
		Grace Period:	0
		Scale:	High
		Highest Error:	1.0

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/16/2024	1144	L	200.0	51.3	50.4		25.7 %
07/16/2024	1149	M	200.0	111.6	112.2		55.8 %
07/16/2024	1154	H	200.0	182.9	184.2		91.5 %
07/16/2024	1201	L	200.0	51.3	51.1		25.7 %
07/16/2024	1206	M	200.0	111.6	113.0		55.8 %
07/16/2024	1211	H	200.0	182.9	184.8		91.5 %
07/16/2024	1218	L	200.0	51.3	51.2		25.7 %
07/16/2024	1223	M	200.0	111.6	113.1		55.8 %
07/16/2024	1228	H	200.0	182.9	184.9		91.5 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Alt Perf Spec	Results
L	51.300		50.900	No	0.8
M	111.600		112.767	No	1.0
H	182.900		184.633	No	0.9

Linearity Report

10/11/2024

Page 2

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY
EDR Site ID:	CT001	Component ID:	A16
		Component Type:	O2D
		ReasonForTest:	QA
		Grace Period:	0
Instrument Name:	CT1_O2D_P_Instrument	Test End Date/Time:	07/16/2024
Performance Spec:	5 %	Test No.:	132
		Status (Pass/Fail):	Passed
		Scale:	High
		Highest Error:	3.6

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/16/2024	1248	L	18.0	5.5	5.3		30.6 %
07/16/2024	1253	M	18.0	11.2	11.1		62.2 %
07/16/2024	1258	H	18.0	18.1	18.1		100.6 %
07/16/2024	1305	L	18.0	5.5	5.3		30.6 %
07/16/2024	1310	M	18.0	11.2	11.1		62.2 %
07/16/2024	1315	H	18.0	18.1	18.1		100.6 %
07/16/2024	1322	L	18.0	5.5	5.3		30.6 %
07/16/2024	1327	M	18.0	11.2	11.1		62.2 %
07/16/2024	1332	H	18.0	18.1	18.1		100.6 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500		5.300	No	3.6
M	11.200		11.100	No	0.9
H	18.100		18.100	No	0.0

Linearity Report

10/11/2024

Page 3

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY
EDR Site ID:	CT002	Component ID:	A21
		Component Type:	NOXA
Instrument Name:	CT2_NOXDualRg_P_Instrum	Test End Date/Time:	08/20/2024
Performance Spec:	5 %	Test No.:	135
		Status (Pass/Fail):	Passed
		ReasonForTest:	QA
		Grace Period:	0
		Scale:	High
		Highest Error:	1.2

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/20/2024	1151	L	200.0	51.1	50.8		25.6 %
08/20/2024	1156	M	200.0	111.3	112.3		55.7 %
08/20/2024	1201	H	200.0	181.7	183.6		90.9 %
08/20/2024	1208	L	200.0	51.1	51.3		25.6 %
08/20/2024	1213	M	200.0	111.3	112.5		55.7 %
08/20/2024	1218	H	200.0	181.7	184.0		90.9 %
08/20/2024	1225	L	200.0	51.1	51.3		25.6 %
08/20/2024	1230	M	200.0	111.3	112.4		55.7 %
08/20/2024	1235	H	200.0	181.7	183.8		90.9 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Alt Perf Spec	Results
L	51.100		51.133	No	0.1
M	111.300		112.400	No	1.0
H	181.700		183.800	No	1.2

Linearity Report

10/11/2024

Page 4

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY
EDR Site ID:	CT002	Component ID:	A22
		Component Type:	O2D
		ReasonForTest:	QA
		Grace Period:	0
Instrument Name:	CT2_O2D_P_Instrument	Test End Date/Time:	08/20/2024
Performance Spec:	5 %	Test No.:	136
		Status (Pass/Fail):	Passed
		Scale:	High
		Highest Error:	0.9

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/20/2024	1249	L	21.0	5.0	5.0		23.8 %
08/20/2024	1254	M	21.0	11.1	11.0		52.9 %
08/20/2024	1259	H	21.0	18.0	17.9		85.7 %
08/20/2024	1306	L	21.0	5.0	5.0		23.8 %
08/20/2024	1311	M	21.0	11.1	11.0		52.9 %
08/20/2024	1316	H	21.0	18.0	17.9		85.7 %
08/20/2024	1323	L	21.0	5.0	5.0		23.8 %
08/20/2024	1328	M	21.0	11.1	11.0		52.9 %
08/20/2024	1333	H	21.0	18.0	17.9		85.7 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000		5.000	No	0.0
M	11.100		11.000	No	0.9
H	18.000		17.900	No	0.6