

DOCKETED

Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	259821-6
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2024 - Part 1 - searchable
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/30/2024 4:56:32 PM
Docketed Date:	10/30/2024



REP
Roseville Energy Park
(03-AFC-01C)

Quarterly Air Quality Report

2024-Q3

Reporting Period: July 1, 2024 – September 30, 2024
Prepared on: October 1, 2024

Submitted to:

California Energy Commission

QUARTERLY AIR QUALITY REPORT

Part I. Identification

- a. Quarterly emission report period: **JULY 1, 2024 – SEPTEMBER 30, 2024**
- b. Reporting date: **OCTOBER 1, 2024**
- c. Person completing report: **JULIE MANFREDI**
- d. Plant name: **ROSEVILLE ENERGY PARK**
- e. Plant location:
5120 PHILLIP ROAD
ROSEVILLE, CA 95747
- f. Person responsible for review and integrity of report: **NATHAN RIBORDY**
- g. Mailing address of report reviewer:
5120 PHILLIP ROAD
ROSEVILLE, CA 95747
- h. Telephone number of report reviewer: **916-746-1673**

Part II. Measuring Instrumentation Information:

Monitor	Type	Manufacturer	Serial No.	Model No.	Installed
Combustion Turbine Generator #1 (CT1)	Natl Gas Fired, Combined Cycle with Dry Low Nox Combustors	Siemens	B005712	SGT800	
CT1 SCR Catalyst	Ammonia Injection System within the Heat Recovery Steam Generator	Peerless	70373		
CT1 Oxidation Catalyst			017421-CV		
Combustion Turbine Generator #2 (CT2)	Natl Gas Fired, Combined Cycle with Dry Low Nox Combustors	Siemens	B005713	SGT800	
CT2 SCR Catalyst	Ammonia Injection System within the Heat Recovery Steam Generator	Peerless	70373		
CT2 Oxidation Catalyst			017421-CV		
EMERGENCY GENERATOR ENGINE	Diesel Engine	Caterpillar	AFN01451	3412CDITA	
FIRE PUMP ENGINE	Diesel Engine	Clarke	CD6068B003958	JU6H-UF60	

Part III. Excess Emissions by Pollutant

SEE ATTACHED

Part IV. CEMS Span and Range

Combined-Cycle Turbine CEMS Span and Range

GAS	SPAN VALUE	RANGE
SCR Inlet NOx	30 ppm	0-30 ppm
	200 ppm	0-200 ppm
Stack NOx	10 ppm	0-10 ppm
	200 ppm	0-200 ppm
Oxygen	20.9%	0-25%
CO	10 ppm	0-10 ppm
	200 ppm	0-200 ppm

Part V. Types of Fuels Combusted

NATURAL GAS

Part VI. Continuous Emissions Monitoring System Operation Changes and Failures

SEE ATTACHED

Part VII. Certification of Report Integrity by Reviewer

**THIS IS TO CERTIFY THAT TO THE BEST OF MY
KNOWLEDGE THE INFORMATION PROVIDED IN THE
ABOVE REPORT IS BOTH COMPLETE AND ACCURATE.**

NAME: NATHAN RIBORDY



Nathan Ribordy (Oct 23, 2024 15:17 PDT)

TITLE: POWER GENERATION SUPERINTENDENT

DATE: OCTOBER 18, 2024

LIST OF ATTACHMENTS

I. PERMIT CONDITIONS (OTHER)

REP CONDITION #	DESCRIPTION
AQ-20	Sulfur content of fuel
AQ-21	Startup and shutdown emission limits
AQ-47, AQ-69, AQ-90 & AQ-103	No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.
AQ-48, AQ-91 & AQ-104	Stack emissions opacity, nuisance complaints for more than 3 minutes
AQ-86	Diesel Fire pump maintenance and testing log, limited to 50 hours per year
AQ-87	Diesel Fire pump operation limited to 24 hours.
AQ-88	Sulfur content of diesel fuel
AQ-89	Diesel engine operation and maintenance records
AQ-99 & AQ-102	Emergency Generator maintenance and testing log, limited to 50 hours per year. Logs kept for 5 years.
AQ-100	Emergency Generator operation limited to 24 hours.
AQ-101	Sulfur content of diesel fuel, shall not exceed 15ppm by weight

II. EMISSIONS OVERVIEW

REP CONDITION #	DESCRIPTION
AQ-15	Selective catalytic reduction (SCR) system and an oxidation catalyst on the gas turbine
AQ-32	NOX & CO Hourly/Daily/Quarterly Emissions
AQ-33	SOX - Hourly/Daily/Quarterly Emissions
AQ-51	Ammonia slip exceedances
AQ-54 thru AQ-63 & AQ-71 (AQ-SC6)	Fuel use emission and operational data - Hourly/Daily/Quarterly
AQ-70	PM10 emissions rate from cooling tower shall not exceed lbs per day or quarter limits

III. EMISSIONS DEVIATIONS

REP CONDITION #	DESCRIPTION
AQ-34	Records: occurrence, duration, and type of any startup, shutdown, or malfunction; performance testing, evaluations, calibrations, checks, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any continuous emission monitor; emission measurements, total daily and rolling twelve-month average hours of operation, hourly quantity of fuel used, and gross three-hour average operating load.
AQ-36 thru AQ-38, AQ-41, & AQ-117	PCAPCD notifications/corrective action: breakdowns, excess emissions, CEMS inoperable, or a negative declaration when no excess emissions occurred.
AQ-40	CEMS quality assurance test failures

I. Permit Conditions (Other)

AQ-20

AQ-20 The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas.

Verification: The Project owner shall submit to the CPM the most recent fuel testing analysis performed as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6



Search

Q

INSIDetrack

2021 - 2024

Jump to:

2021 - 2024

2016 - 2020

2011 - 2015

2006 - 2010

2024

Date	Total Sulfur Maximum		Total Sulfur Average all sites	
	PPMv	gr/100 scf	PPMv	gr/100 scf
2024				
Third Quarter	4.3	0.25	2.8	0.17
Third Quarter - July	4.2	0.25	2.8	0.17
Third Quarter - August	4.3	0.25	2.9	0.17
Third Quarter - September	4.1	0.24	3.0	0.18

AQ20 ROSEVILLE ENERGY PARK

3Q24

Fuel Quality Analysis BTU values

<http://www.pge.com/pij>

	JUL	AUG	SEP
1	1056.73	1053.00	1049.09
2	1049.49	1054.24	1050.68
3	1046.40	1052.69	1051.85
4	1043.88	1053.27	1052.29
5	1051.00	1051.88	1051.25
6	1048.86	1051.74	1053.39
7	1045.61	1053.30	1052.73
8	1046.65	1053.37	1050.63
9	1046.13	1052.40	1047.17
10	1044.55	1052.70	1047.96
11	1045.15	1050.24	1053.05
12	1046.33	1054.98	1051.65
13	1060.01	1,054.28	1050.92
14	1051.82	1053.81	1056.51
15	1050.20	1054.17	1056.51
16	1049.86	1058.54	1057.47
17	1052.33	1060.16	1062.07
18	1050.27	1060.87	1061.37
19	1050.72	1061.47	1061.72
20	1049.08	1058.84	1076.78
21	1046.58	1057.74	1090.20
22	1048.16	1062.73	1089.98
23	1048.25	1067.56	1088.82
24	1046.97	1060.00	1089.06
25	1045.37	1059.27	1088.90
26	1048.06	1053.72	1088.49
27	1049.83	1049.24	1087.60
28	1047.53	1052.12	1089.20
29	1047.06	1050.25	1088.45
30	1053.54	1049.12	1083.00
31	1052.73	1048.99	N/A

AQ-21

AQ-21 Startup is defined as the period beginning with the turbine light-off until the unit meets the lb/hr and ppmv emission limits in Conditions of Certification AQ-52, -54 and -55. Shutdown is defined as the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Startup and shutdown durations shall not exceed 3.0 hours and one hour, respectively, per occurrence.

Verification: The Project owner shall identify and submit to the CPM as part of the Quarterly Air Quality Report all startups and shutdowns for all units including the maximum hourly emission rate, total emissions and duration.

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
09/16/24 8:52	434087			1			1.48			1.05			2.68			0		
09/16/24 8:53	433827.2			1			1.48			1.05			2.68			0		
09/16/24 8:54	433607.7			1			1.48			1.05			2.68			0		
09/16/24 8:55	432943.4			1			1.48			1.05			2.68			0		
09/16/24 8:56	433399.7			1			1.48			1.05			2.68			0		
09/16/24 8:57	438731.1			0.9			1.45			1.05			2.66			1		
09/16/24 8:58	432706.5			0.9			1.62			1.01			2.88			0		
09/16/24 8:59	432273.3			1			1.32			1.04			2.33			0		
09/16/24 9:00	433434.3			1.1			1.32			1.14			2.34			0		
09/16/24 9:01	435057.4			1.1			1.23			1.14			2.19			0		
09/16/24 9:02	434283.5			1.1			1.23			1.23			2.19			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
07/18/24 15:06	439129.6			0.6			1.48			0.67			2.51			0		
07/18/24 15:07	437876.2			0.6			1.48			0.66			2.5			0		
07/18/24 15:08	439251			0.6			1.48			0.67			2.51			0		
07/18/24 15:09	439539.8			0.6			1.48			0.67			2.51			0		
07/18/24 15:10	440648.8			0.7			1.5			0.78			2.56			0		
07/18/24 15:11	439349.2			0.6			1.48			0.67			2.5			1		
07/18/24 15:12	427300			0.6			1.48			0.55			2.43			1		
07/18/24 15:13	404732.4			0.6			1.57			0.61			2.45			1		
07/18/24 15:14	382020.4			0.6			2			0.57			2.95			1		
07/18/24 15:15	359094.7			0.6			2.32			0.53			3.22			1		
07/18/24 15:16	335308.3			0.7			2.41			0.56			3.13			1		
07/18/24 15:17	310851.8			0.8			2.68			0.59			3.23			1		
07/18/24 15:18	286216.4			0.8			3.5			0.56			3.87			1		
07/18/24 15:19	262406.9			0.7			4.38			0.41			4.43			1		
07/18/24 15:20	236720.1			0.5			8.26			0.27			7.55			1		
07/18/24 15:21	213430.5			0.4			24.13			0.21			19.87			1		
07/18/24 15:22	187096.8			3.9			34.15			1.7			24.74			1		
07/18/24 15:23	164211.5			118.4			40.78			45.74			25.93			1		
07/18/24 15:24	143642.5			627			44.99			212.92			25.14			1		
07/18/24 15:25	98039.4			1370.4			47.72			320.25			18.35			1		
07/18/24 15:26	0			0			54.75			4.93			0.26			0		
07/18/24 15:27	0			0			41.3			8.85			0.12			0		
07/18/24 15:28	0			0			0.3			0			0			0		
07/18/24 15:29	0			0			0.3			0			0			0		
07/18/24 15:30	0			0			0.2			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
07/20/24 7:32	0			0			0			0			0			0		
07/20/24 7:33	0			0			0			0			0			0		
07/20/24 7:34	0			0			0			0			0			0		
07/20/24 7:35	0			0			0			0			0			0		
07/20/24 7:36	0			0			0			0			0			0		
07/20/24 7:37	0			-0.1			0			0			0			1		
07/20/24 7:38	16063.6			-0.1			0			0			0			1		
07/20/24 7:39	31566.9			1233.1			41.3			91.09			5.02			1		
07/20/24 7:40	44719.3			1195.2			18.19			124.95			3.13			1		
07/20/24 7:41	56110			807.6			19.99			105.94			4.32			1		
07/20/24 7:42	68245.8			499.7			25.96			79.76			6.82			1		
07/20/24 7:43	100344.1			329.9			30.57			77.38			11.8			1		
07/20/24 7:44	144872.8			197.8			39.88			66.94			22.22			1		
07/20/24 7:45	174198.6			132.8			56.64			54.05			37.96			1		
07/20/24 7:46	200335.9			518			62.2			242.58			47.94			1		
07/20/24 7:47	216278.2			104.6			60.1			52.85			49.99			1		
07/20/24 7:48	239071.1			21			58			11.71			53.33			1		
07/20/24 7:49	263123.2			1.5			57.87			0.91			58.56			1		
07/20/24 7:50	292766.6			1			51.75			0.71			58.29			1		
07/20/24 7:51	317939.3			1			24.82			0.77			30.34			1		
07/20/24 7:52	339530.7			1.2			16.38			0.98			21.39			1		
07/20/24 7:53	360400.1			1.5			13.97			1.24			19.37			1		
07/20/24 7:54	374753.9			1.6			12.67			1.37			18.27			1		
07/20/24 7:55	375672.4			1.5			9.69			1.31			14			1		
07/20/24 7:56	376278.8			1.3			9.69			1.16			14.02			1		
07/20/24 7:57	375077.5			1.2			9.25			1.08			13.34			1		
07/20/24 7:58	374933			1.2			8.85			1.02			12.76			1		
07/20/24 7:59	373956.8			1.2			8.22			1.02			11.83			1		
07/20/24 8:00	373708.5			1.1			8.05			0.94			11.57			1		
07/20/24 8:01	380894			0.9			7.87			0.8			11.52			1		
07/20/24 8:02	401336			0.9			6.81			0.85			10.51			1		
07/20/24 8:03	417977.3			0.8			6.36			0.81			10.24			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
07/20/24 8:04	415170			0.8			6.27			0.82			10.02			1		
07/20/24 8:05	412998.1			0.8			6.27			0.81			9.98			1		
07/20/24 8:06	411409.7			0.8			6.37			0.81			10.08			1		
07/20/24 8:07	409434.3			0.7			6.46			0.72			10.17			1		
07/20/24 8:08	407978.6			0.7			6.56			0.72			10.3			1		
07/20/24 8:09	390910			0.7			6.56			0.68			9.86			1		
07/20/24 8:10	381142.4			0.8			7.19			0.74			10.54			1		
07/20/24 8:11	383718.6			0.8			7.17			0.73			10.58			1		
07/20/24 8:12	380264.5			0.8			6.64			0.74			9.71			1		
07/20/24 8:13	375701.3			0.8			6.73			0.73			9.72			1		
07/20/24 8:14	374586.5			0.8			6.99			0.72			10.07			1		
07/20/24 8:15	373829.8			0.8			5.17			0.71			7.44			1		
07/20/24 8:16	374771.3			0.8			2.86			0.73			4.12			1		
07/20/24 8:17	374413.1			0.8			2.67			0.73			3.85			1		
07/20/24 8:18	373593			0.8			3.32			0.72			4.77			1		
07/20/24 8:19	372564.8			0.8			3.5			0.72			5.02			1		
07/20/24 8:20	373604.5			0.8			3.96			0.72			5.7			1		
07/20/24 8:21	372495.5			0.8			4.15			0.72			5.94			1		
07/20/24 8:22	370889.7			0.8			3.96			0.72			5.65			1		
07/20/24 8:23	370912.8			0.8			3.04			0.72			4.34			1		
07/20/24 8:24	369982.8			0.8			2.77			0.72			3.94			1		
07/20/24 8:25	370733.7			0.7			2.77			0.64			3.94			1		
07/20/24 8:26	369168.3			0.7			2.77			0.64			3.93			1		
07/20/24 8:27	369018.2			0.7			2.77			0.64			3.93			1		
07/20/24 8:28	369584.3			0.8			2.77			0.72			3.93			1		
07/20/24 8:29	370063.7			0.8			2.67			0.72			3.8			1		
07/20/24 8:30	368856.5			0.9			2.49			0.79			3.53			1		
07/20/24 8:31	367961.2			0.7			2.21			0.63			3.13			1		
07/20/24 8:32	367949.6			0.6			1.94			0.56			2.75			1		
07/20/24 8:33	369451.4			0.6			1.84			0.56			2.63			1		
07/20/24 8:34	369341.6			0.7			1.84			0.64			2.62			1		
07/20/24 8:35	369191.5			0.7			1.75			0.64			2.5			1		
07/20/24 8:36	369532.3			0.7			1.84			0.64			2.63			1		
07/20/24 8:37	368429			0.8			1.84			0.72			2.62			1		
07/20/24 8:38	368821.8			0.8			1.84			0.72			2.62			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
07/20/24 8:39	369093.3			0.8			1.84			0.72			2.62			1		
07/20/24 8:40	368873.8			0.7			1.82			0.63			2.58			1		
07/20/24 8:41	369884.6			0.7			1.72			0.63			2.46			1		
07/20/24 8:42	367759			0.7			1.75			0.63			2.48			1		
07/20/24 8:43	369260.8			0.8			1.66			0.72			2.36			0		
07/20/24 8:44	369630.5			0.8			1.57			0.72			2.23			0		
07/20/24 8:45	368608.1			0.8			1.57			0.72			2.22			0		
07/20/24 8:46	368244.2			0.7			1.57			0.64			2.23			0		
07/20/24 8:47	368902.7			0.7			1.59			0.65			2.26			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/01/24 7:16	366829			0.7			1.54			0.63			2.19			0		
08/01/24 7:17	365408.1			0.8			1.54			0.7			2.18			0		
08/01/24 7:18	365263.7			0.7			1.45			0.62			2.05			0		
08/01/24 7:19	365968.3			0.7			1.45			0.62			2.05			0		
08/01/24 7:20	365858.6			0.7			1.45			0.62			2.05			0		
08/01/24 7:21	362652.8			0.7			1.45			0.62			2.04			1		
08/01/24 7:22	346554.5			0.8			1.45			0.66			1.94			1		
08/01/24 7:23	323241.8			0.8			1.52			0.61			1.9			1		
08/01/24 7:24	299657.6			0.7			2.45			0.51			2.84			1		
08/01/24 7:25	275368.7			0.7			2.72			0.48			2.89			1		
08/01/24 7:26	250831.4			0.6			4.47			0.34			4.34			1		
08/01/24 7:27	228044.3			0.4			12.9			0.21			11.37			1		
08/01/24 7:28	200746			1.1			27.94			0.52			21.68			1		
08/01/24 7:29	175729.3			61.7			31.84			25.46			21.61			1		
08/01/24 7:30	156887.3			490.1			37.23			180.59			22.57			1		
08/01/24 7:31	138744.3			1227			40.66			399.64			21.8			1		
08/01/24 7:32	22452.1			1611.3			42.59			85.12			3.7			1		
08/01/24 7:33	0			0			55.07			0			0			0		
08/01/24 7:34	0			0			11.8			0			0			0		
08/01/24 7:35	0			0			11.8			0			0			0		
08/01/24 7:36	0			0			0.2			0			0			0		
08/01/24 7:37	0			0			5.9			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/01/24 14:16	0			0			0			0			0			0		
08/01/24 14:17	0			0			0			0			0			0		
08/01/24 14:18	0			0			0			0			0			0		
08/01/24 14:19	0			0			0			0			0			0		
08/01/24 14:20	0			0			0			0			0			0		
08/01/24 14:21	0			-0.2			0			0			0			1		
08/01/24 14:22	0			-0.2			0			0			0			1		
08/01/24 14:23	0			0			0			0			0			0		
08/01/24 14:24	0			0			0			0			0			0		
08/01/24 14:25	0			0			5.9			0			0			0		
08/01/24 14:26	0			0			5.9			0			0			0		
08/01/24 14:27	0			0			0			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/01/24 14:16	0			0			0			0			0			0		
08/01/24 14:17	0			0			0			0			0			0		
08/01/24 14:18	0			0			0			0			0			0		
08/01/24 14:19	0			0			0			0			0			0		
08/01/24 14:20	0			0			0			0			0			0		
08/01/24 14:21	0			-0.2			0			0			0			1		
08/01/24 14:22	0			-0.2			0			0			0			1		
08/01/24 14:23	0			0			0			0			0			0		
08/01/24 14:24	0			0			0			0			0			0		
08/01/24 14:25	0			0			5.9			0			0			0		
08/01/24 14:26	0			0			5.9			0			0			0		
08/01/24 14:27	0			0			0			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/01/24 14:33	0			0			0			0			0			0		
08/01/24 14:34	0			0			0			0			0			0		
08/01/24 14:35	0			0			0			0			0			0		
08/01/24 14:36	0			0			0			0			0			0		
08/01/24 14:37	0			0			0			0			0			0		
08/01/24 14:38	0			-0.1			0			0			0			1		
08/01/24 14:39	7867.2			-0.1			0			0			0			1		
08/01/24 14:40	27471.6			1038.4			47.2			76.47			5.72			1		
08/01/24 14:41	41455.8			1019.3			16.79			110.89			3.01			1		
08/01/24 14:42	53695.5			674.9			20.98			92.61			4.74			1		
08/01/24 14:43	65958.4			323.4			25			53.71			6.84			1		
08/01/24 14:44	95642.3			170.8			28.22			39.28			10.68			1		
08/01/24 14:45	141025.9			97.7			40.59			32.63			22.31			1		
08/01/24 14:46	146397.8			66.8			56.53			23.1			32.17			1		
08/01/24 14:47	165990.6			947.6			53.1			371.22			34.23			1		
08/01/24 14:48	189234			898.6			56.54			399.28			41.35			1		
08/01/24 14:49	216468.8			193.1			59.14			98.17			49.48			1		
08/01/24 14:50	241693.5			11.7			59.25			6.62			55.33			1		
08/01/24 14:51	266918.1			1.3			59.67			0.84			61.55			1		
08/01/24 14:52	294672.7			0.9			41.1			0.62			46.8			1		
08/01/24 14:53	318488			1			18.62			0.76			22.92			1		
08/01/24 14:54	340079.4			1.2			11.44			0.93			15.04			1		
08/01/24 14:55	360943			1.2			8.72			1.04			12.16			1		
08/01/24 14:56	374043.5			1.1			8.72			1.01			12.6			1		
08/01/24 14:57	375464.4			1.1			8.1			1.01			11.76			1		
08/01/24 14:58	375250.7			1			8.37			0.85			12.13			1		
08/01/24 14:59	375712.8			1			7.66			0.85			11.12			1		
08/01/24 15:00	374551.8			1			7.38			0.84			10.67			1		
08/01/24 15:01	373893.3			0.8			7.38			0.69			10.66			1		
08/01/24 15:02	373153.9			0.7			7.31			0.62			10.54			1		
08/01/24 15:03	372813.1			0.7			7.22			0.62			10.4			1		
08/01/24 15:04	372564.8			0.8			7.04			0.69			10.14			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/01/24 15:05	372766.9			0.9			6.96			0.77			10.02			1		
08/01/24 15:06	371652.1			0.8			6.88			0.7			9.89			1		
08/01/24 15:07	371068.7			0.8			6.6			0.69			9.47			1		
08/01/24 15:08	369474.5			0.7			4.65			0.62			6.64			1		
08/01/24 15:09	370676			0.8			3.22			0.7			4.61			1		
08/01/24 15:10	369670.9			0.8			3.22			0.7			4.6			1		
08/01/24 15:11	369682.5			0.8			3.49			0.7			4.98			1		
08/01/24 15:12	370392.9			0.7			3.93			0.62			5.63			1		
08/01/24 15:13	368400.1			0.6			3.93			0.54			5.6			1		
08/01/24 15:14	369341.7			0.6			4.02			0.54			5.74			1		
08/01/24 15:15	368677.4			0.6			3.75			0.54			5.35			1		
08/01/24 15:16	368943.1			0.6			2.95			0.54			4.21			1		
08/01/24 15:17	367764.8			0.7			2.68			0.62			3.81			1		
08/01/24 15:18	377220.4			0.7			2.59			0.63			3.78			1		
08/01/24 15:19	397188.7			0.7			2.54			0.68			3.9			1		
08/01/24 15:20	418000.3			0.6			2.58			0.63			4.17			1		
08/01/24 15:21	424123			0.6			2.49			0.55			4.08			1		
08/01/24 15:22	424157.8			0.6			2.53			0.56			4.14			1		
08/01/24 15:23	430442.3			0.6			2.03			0.65			3.37			1		
08/01/24 15:24	440787.4			0.7			1.4			0.68			2.39			1		
08/01/24 15:25	444022.1			0.6			1.29			0.67			2.21			1		
08/01/24 15:26	444362.9			0.7			1.4			0.68			2.41			1		
08/01/24 15:27	444455.3			0.6			1.5			0.59			2.57			1		
08/01/24 15:28	444611.3			0.6			1.78			0.59			3.06			1		
08/01/24 15:29	442820.7			0.6			1.97			0.58			3.37			1		
08/01/24 15:30	440735.5			0.6			2.15			0.58			3.67			1		
08/01/24 15:31	441359.3			0.6			2.25			0.58			3.83			1		
08/01/24 15:32	440336.9			0.6			2.15			0.58			3.67			1		
08/01/24 15:33	440152			0.6			1.97			0.58			3.35			1		
08/01/24 15:34	438500			0.6			1.66			0.66			2.81			1		
08/01/24 15:35	438217			0.6			1.48			0.66			2.5			1		
08/01/24 15:36	438563.6			0.6			1.4			0.58			2.38			1		
08/01/24 15:37	437674.1			0.6			1.38			0.57			2.34			1		
08/01/24 15:38	439043.1			0.6			1.5			0.58			2.54			1		
08/01/24 15:39	438858.2			0.6			1.59			0.58			2.7			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/01/24 15:40	438453.8			0.6			1.66			0.66			2.81			1		
08/01/24 15:41	437633.6			0.6			1.66			0.66			2.81			1		
08/01/24 15:42	438829.3			0.6			1.69			0.58			2.86			1		
08/01/24 15:43	447256.8			0.6			1.38			0.58			2.39			1		
08/01/24 15:44	458329.8			0.6			1.22			0.6			2.16			0		
08/01/24 15:45	455066.2			0.6			1.01			0.59			1.78			0		
08/01/24 15:46	456013.5			0.6			1.01			0.69			1.79			0		
08/01/24 15:47	454794.7			0.7			1.03			0.72			1.85			0		
08/01/24 15:48	453772.3			1.7			0.92			1.84			1.69			0		

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 06:50 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:						
	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	
	CO, Lb	NOx, Lb	SO2, Lb	PM10, Lb	VOC, Lb	
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	
07/01/2024	31.97	102.21	11.44	23.00	38.19	
07/02/2024	28.63	118.95	13.23	26.48	44.14	
07/03/2024	30.29	112.20	12.65	25.36	42.26	
07/04/2024	31.16	93.36	10.71	21.56	35.80	
07/05/2024	33.27	108.77	12.09	24.13	40.31	
07/06/2024	30.38	101.94	11.63	23.32	38.87	
07/07/2024	27.00	108.93	12.31	24.70	41.09	
07/08/2024	26.16	116.41	12.93	25.88	43.17	
07/09/2024	27.05	118.84	13.23	26.54	44.16	
07/10/2024	30.29	114.06	13.03	26.07	43.39	
07/11/2024	25.76	120.56	13.45	27.00	44.98	
07/12/2024	28.46	113.63	12.78	25.66	42.69	
07/13/2024	30.44	95.32	10.87	21.75	36.27	
07/14/2024	29.63	94.99	10.78	21.64	36.02	
07/15/2024	28.51	94.19	10.61	21.37	35.57	
07/16/2024	31.20	95.67	11.30	22.67	37.76	
07/17/2024	30.91	96.29	10.94	22.04	36.62	
07/18/2024	39.37	80.66	8.81	17.59	29.40	
07/19/2024	16.83	68.30	7.72	15.42	25.71	
07/20/2024	40.23	120.49	12.24	24.52	40.87	
07/21/2024	30.39	96.81	11.18	22.50	37.43	
07/22/2024	27.59	121.06	13.45	26.99	44.96	
07/23/2024	16.39	155.62	16.96	33.90	56.54	
07/24/2024	38.44	200.25	18.75	37.14	62.54	
07/25/2024	25.76	121.20	13.44	26.90	44.76	
07/26/2024	30.21	95.59	10.83	21.72	36.18	
07/27/2024	30.40	94.65	10.56	21.33	35.48	
07/28/2024	30.30	96.73	10.58	21.37	35.52	
07/29/2024	33.48	104.92	11.48	23.01	38.30	
07/30/2024	28.60	113.08	12.26	24.63	41.04	
07/31/2024	28.88	114.61	12.81	25.67	42.76	
Monthly Avg/Sum:	917.98 sum	3,390.29 sum	375.05 sum	751.86 sum	1,252.78 sum	
Daily Min:	16.39	68.30	7.72	15.42	25.71	
Daily Max:	40.23	200.25	18.75	37.14	62.54	
Jul 2024 - Jul 2024	917.98 sum	3,390.29 sum	375.05 sum	751.86 sum	1,252.78 sum	
QTD:	917.98 sum	3,390.29 sum	375.05 sum	751.86 sum	1,252.78 sum	
YTD 2024:	5,390.17 sum	12,804.09 sum	1,380.34 sum	2,760.44 sum	4,600.82 sum	

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 06:50 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Lb		NOx, Lb		SO2, Lb		PM10, Lb		VOC, Lb	
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
08/01/2024	70.69		113.14		11.57		23.14		38.64	
08/02/2024	32.47		122.24		14.45		28.87		48.13	
08/03/2024	30.41		85.20		11.50		23.15		38.47	
08/04/2024	30.62		89.43		11.55		23.24		38.67	
08/05/2024	31.50		81.20		11.32		22.66		37.78	
08/06/2024	32.57		81.39		11.45		23.06		38.29	
08/07/2024	31.71		81.29		10.75		21.60		35.92	
08/08/2024	28.86		73.06		10.65		21.45		35.65	
08/09/2024	28.92		73.96		10.65		21.45		35.70	
08/10/2024	28.88		71.83		10.61		21.34		35.58	
08/11/2024	32.43		94.69		11.87		23.87		39.78	
08/12/2024	31.40		82.78		11.12		22.23		37.03	
08/13/2024	32.36		82.91		11.04		22.18		36.98	
08/14/2024	31.37		88.95		11.71		23.57		39.21	
08/15/2024	33.28		85.71		11.80		23.71		39.49	
08/16/2024	32.59		78.02		10.90		21.84		36.45	
08/17/2024	30.52		68.59		10.65		21.39		35.69	
08/18/2024	31.44		80.02		10.49		21.06		35.12	
08/19/2024	32.77		85.43		10.73		21.57		35.95	
08/20/2024	31.32		88.43		10.58		21.30		35.46	
08/21/2024	31.68		92.96		10.58		21.16		35.27	
08/22/2024	31.53		93.29		10.58		21.19		35.37	
08/23/2024	33.18		94.75		10.59		21.38		35.62	
08/24/2024	34.45		94.57		10.64		21.42		35.67	
08/25/2024	36.47		96.81		11.03		22.03		36.68	
08/26/2024	34.30		95.06		10.98		21.94		36.54	
08/27/2024	34.96		93.47		10.68		21.52		35.81	
08/28/2024	34.96		92.35		10.69		21.51		35.74	
08/29/2024	34.75		95.67		11.01		22.21		36.88	
08/30/2024	34.32		92.99		10.61		21.37		35.49	
08/31/2024	34.28		105.42		11.97		24.08		40.09	
Monthly Avg/Sum:	1,040.99	sum	2,755.61	sum	344.75	sum	692.49	sum	1,153.15	sum
Daily Min:	28.86		68.59		10.49		21.06		35.12	
Daily Max:	70.69		122.24		14.45		28.87		48.13	
Jul 2024 - Aug 2024	1,958.97	sum	6,145.90	sum	719.80	sum	1,444.35	sum	2,405.93	sum
QTD:	1,958.97	sum	6,145.90	sum	719.80	sum	1,444.35	sum	2,405.93	sum
YTD 2024:	6,431.16	sum	15,559.70	sum	1,725.09	sum	3,452.93	sum	5,753.97	sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 06:50 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:						
	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	
	CO, Lb	NOx, Lb	SO2, Lb	PM10, Lb	VOC, Lb	
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	
09/01/2024	34.30	93.57	10.69	21.51	35.75	
09/02/2024	34.73	93.42	10.88	21.80	36.26	
09/03/2024	45.72	127.84	13.47	27.00	44.91	
09/04/2024	32.38	111.44	13.19	26.40	43.92	
09/05/2024	26.88	125.11	14.10	28.17	46.83	
09/06/2024	25.61	125.84	14.13	28.31	47.15	
09/07/2024	27.63	124.52	13.91	27.86	46.43	
09/08/2024	28.84	116.78	13.19	26.39	43.95	
09/09/2024	35.54	99.47	11.55	23.04	38.41	
09/10/2024	32.13	94.47	10.80	21.56	35.85	
09/11/2024	32.59	94.20	10.73	21.46	35.72	
09/12/2024	29.93	93.35	10.69	21.37	35.54	
09/13/2024	27.66	103.40	11.90	23.77	39.56	
09/14/2024	27.71	96.66	11.18	22.37	37.28	
09/15/2024	26.29	94.74	10.75	21.49	35.70	
09/16/2024	29.28	99.57	11.70	23.37	38.88	
09/17/2024	27.16	95.77	10.91	21.80	36.30	
09/18/2024	28.09	97.85	11.36	22.59	37.66	
09/19/2024	30.23	107.11	12.34	24.71	41.14	
09/20/2024	26.99	93.73	11.03	22.08	36.75	
09/21/2024	26.44	103.94	11.95	23.93	39.92	
09/22/2024	27.15	93.90	10.73	21.45	35.80	
09/23/2024	28.48	103.19	11.92	23.82	39.68	
09/24/2024	29.12	98.83	11.45	22.88	38.10	
09/25/2024	26.06	92.96	10.76	21.47	35.81	
09/26/2024	28.80	100.70	11.69	23.35	38.84	
09/27/2024	31.64	100.80	11.70	23.38	38.93	
09/28/2024	29.96	97.76	11.33	22.56	37.62	
09/29/2024	27.50	91.75	10.61	21.14	35.23	
09/30/2024	26.21	112.55	12.79	25.58	42.59	
Monthly Avg/Sum:	891.05 sum	3,085.22 sum	353.43 sum	706.61 sum	1,176.51 sum	
Daily Min:	25.61	91.75	10.61	21.14	35.23	
Daily Max:	45.72	127.84	14.13	28.31	47.15	
Jul 2024 - Sep 2024	2,850.02 sum	9,231.12 sum	1,073.23 sum	2,150.96 sum	3,582.44 sum	
QTD:	2,850.02 sum	9,231.12 sum	1,073.23 sum	2,150.96 sum	3,582.44 sum	
YTD 2024:	7,322.21 sum	18,644.92 sum	2,078.52 sum	4,159.54 sum	6,930.48 sum	

Monthly Summary By Day Report



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 06:51 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1		Unit CT2	
	CO_SUSD, LbPerHr		NOX_SUSD, LbPerHr	
	1 Hour(s)		1 Hour(s)	
07/01/2024	0.0	0.0	0.0	0.0
07/02/2024	0.0	0.0	0.2	0.4
07/03/2024	0.0	0.0	0.0	0.0
07/04/2024	0.0	0.0	0.0	0.0
07/05/2024	0.0	0.0	0.0	0.0
07/06/2024	0.0	0.0	0.0	0.0
07/07/2024	0.0	0.0	0.0	0.0
07/08/2024	0.0	0.0	0.0	0.0
07/09/2024	0.0	0.0	0.0	0.0
07/10/2024	0.0	0.0	0.0	0.0
07/11/2024	0.0	0.0	0.0	0.1
07/12/2024	0.0	0.0	0.0	0.0
07/13/2024	0.0	0.0	0.0	0.0
07/14/2024	0.0	0.0	0.0	0.0
07/15/2024	0.0	0.0	0.0	0.0
07/16/2024	0.0	0.0	0.7	2.7
07/17/2024	0.0	0.0	0.4	1.4
07/18/2024	0.0	0.0	13.4	13.1
07/19/2024	0.0	0.0	0.0	0.0
07/20/2024	0.0	0.0	15.8	12.9
07/21/2024	0.0	0.0	0.0	0.0
07/22/2024	0.0	0.0	0.0	0.0
07/23/2024	0.0	0.0	0.0	0.0
07/24/2024	0.0	0.0	0.0	0.0
07/25/2024	0.0	0.0	0.0	0.0
07/26/2024	0.0	0.0	0.0	0.0
07/27/2024	0.0	0.0	0.0	0.0
07/28/2024	0.0	0.0	0.0	0.0
07/29/2024	0.0	0.0	0.0	0.0
07/30/2024	0.0	0.0	0.0	0.0
07/31/2024	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	0.0 sum	0.0 sum	30.5 sum	30.6 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	15.8	13.1
Jul 2024 - Jul 2024	0.0 sum	0.0 sum	30.5 sum	30.6 sum
QTD:	0.0 sum	0.0 sum	30.5 sum	30.6 sum
YTD 2024:	1,016.2 sum	136.5 sum	626.7 sum	209.6 sum

Monthly Summary By Day Report



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 06:51 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1		Unit CT2	
	CO_SUSD, LbPerHr		NOX_SUSD, LbPerHr	
	1 Hour(s)		1 Hour(s)	
08/01/2024	0.0	0.0	34.0	13.3
08/02/2024	0.0	0.0	0.0	0.0
08/03/2024	0.0	0.0	0.0	0.0
08/04/2024	0.0	0.0	0.0	0.2
08/05/2024	0.0	0.0	0.0	0.0
08/06/2024	0.0	0.0	0.0	0.0
08/07/2024	0.0	0.0	0.0	0.0
08/08/2024	0.0	0.0	0.0	0.0
08/09/2024	0.0	0.0	0.0	0.0
08/10/2024	0.0	0.0	0.0	0.0
08/11/2024	0.0	0.0	0.0	0.0
08/12/2024	0.0	0.0	0.0	0.0
08/13/2024	0.0	0.0	0.0	0.0
08/14/2024	0.0	0.0	0.0	0.0
08/15/2024	0.0	0.0	0.0	0.0
08/16/2024	0.0	0.0	0.0	0.0
08/17/2024	0.0	0.0	0.0	0.0
08/18/2024	0.0	0.0	0.3	0.6
08/19/2024	0.0	0.0	0.0	0.0
08/20/2024	0.0	0.0	0.0	0.0
08/21/2024	0.0	0.0	0.0	0.0
08/22/2024	0.0	0.0	0.0	0.0
08/23/2024	0.0	0.0	0.0	0.0
08/24/2024	0.0	0.0	0.0	0.0
08/25/2024	0.0	0.0	0.0	0.0
08/26/2024	0.0	0.0	0.0	0.0
08/27/2024	0.0	0.0	0.0	0.0
08/28/2024	0.0	0.0	0.0	0.0
08/29/2024	0.0	0.0	0.0	0.0
08/30/2024	0.0	0.0	0.0	0.0
08/31/2024	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	0.0 sum	0.0 sum	34.3 sum	14.1 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	34.0	13.3
Jul 2024 - Aug 2024	0.0 sum	0.0 sum	64.8 sum	44.7 sum
QTD:	0.0 sum	0.0 sum	64.8 sum	44.7 sum
YTD 2024:	1,016.2 sum	136.5 sum	661.0 sum	223.7 sum

Monthly Summary By Day Report



From: 07/01/2024 00:00

To: 09/30/2024 23:59

Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 06:51

Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2024	0.0	0.0	0.0	0.0
09/02/2024	0.0	0.0	0.0	0.0
09/03/2024	0.0	0.0	0.0	0.0
09/04/2024	0.0	0.0	0.0	0.0
09/05/2024	0.0	0.0	0.0	0.0
09/06/2024	0.0	0.0	0.0	0.0
09/07/2024	0.0	0.0	0.0	0.0
09/08/2024	0.0	0.0	0.0	0.0
09/09/2024	0.0	0.0	0.0	0.0
09/10/2024	0.0	0.0	0.0	0.0
09/11/2024	0.0	0.0	0.0	0.0
09/12/2024	0.0	0.0	0.0	0.0
09/13/2024	0.0	0.0	0.0	0.0
09/14/2024	0.0	0.0	0.0	0.0
09/15/2024	0.0	0.0	0.0	0.0
09/16/2024	0.0	0.0	0.0	0.0
09/17/2024	0.0	0.0	0.0	0.0
09/18/2024	0.0	0.0	0.0	0.0
09/19/2024	0.0	0.0	0.0	0.0
09/20/2024	0.0	0.0	0.0	0.0
09/21/2024	0.0	0.0	0.0	0.0
09/22/2024	0.0	0.0	0.0	0.0
09/23/2024	0.0	0.0	0.0	0.0
09/24/2024	0.0	0.0	0.0	0.0
09/25/2024	0.0	0.0	0.0	0.0
09/26/2024	0.0	0.0	0.0	0.0
09/27/2024	0.0	0.0	0.0	0.0
09/28/2024	0.0	0.0	0.0	0.0
09/29/2024	0.0	0.0	0.0	0.0
09/30/2024	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	0.0 sum	0.0 sum	0.0 sum	0.0 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	0.0	0.0
Jul 2024 - Sep 2024	0.0 sum	0.0 sum	64.8 sum	44.7 sum
QTD:	0.0 sum	0.0 sum	64.8 sum	44.7 sum
YTD 2024:	1,016.2 sum	136.5 sum	661.0 sum	223.7 sum

Startup / Shutdown Events

CT1



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 06:46 **Location:** Roseville, CA

No source downtime records found.

Startup / Shutdown Events

CT1



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 06:46 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	09/16/2024 08:57	09/16/2024 08:57	Shutdown	1

Startup / Shutdown Events

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 06:46 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	0		0.00
Warm Startup	0		0.00
Shutdown	1	1	0.00
Total Process Events:	1	1	0

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	2,208.00 Hour(s)
Total Startup Time:	0 Minute(s)
Total Shutdown Time:	1 Minute(s)
Total Startup/Shutdown Time:	1 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.00 %

Startup / Shutdown Events

CT2



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 06:48 **Location:** Roseville, CA

Unit offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
07/18/2024 01:00	07/18/2024 01:00	1
07/18/2024 16:00	07/20/2024 06:00	39
08/01/2024 08:00	08/01/2024 13:00	6

Startup / Shutdown Events

CT2



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 06:48 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	46.00 Hour(s)
Offline Percentage:	2.08 %
Total Online:	2,162.00 Hour(s)
Online Percentage:	97.92 %

Startup / Shutdown Events

CT2



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 06:48 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	07/18/2024 15:11	07/18/2024 15:25	Shutdown	15
2	07/20/2024 07:37	07/20/2024 08:42	cold Startup	66
3	08/01/2024 07:21	08/01/2024 07:32	Shutdown	12
4	08/01/2024 14:21	08/01/2024 14:22	warm Startup	2
5	08/01/2024 14:21	08/01/2024 14:22	Shutdown	2
6	08/01/2024 14:38	08/01/2024 15:43	cold Startup	66

Startup / Shutdown Events

CT2



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 06:48 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	2	132	0.10
Warm Startup	1	2	0.00
Shutdown	3	29	0.02
Total Process Events:	6	163	0.13

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	2,152.83 Hour(s)
Total Startup Time:	134 Minute(s)
Total Shutdown Time:	29 Minute(s)
Total Startup/Shutdown Time:	163 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.13 %

AQ-47/69/90/103

AQ-47/69/90/103: No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-47/69/90/103 of Roseville Energy Park's 3Q24 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-48/91/104

AQ-48/91/104: Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-48/91/104 of Roseville Energy Park's 3Q24 QAQR, there were no violations of PCAPCD's Rule 202 for opacity.

AQ-86

AQ-86 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

6	8	DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD	DATE	Initial	START	END	Reason	Hours Total	mins YTD
		7/10/22	DE	1120	1150	BI-WEEKLY TEST RUN	125	395	7-22-23	LH	1139	1149	CD Power Pm's Test Run	140	557
12/24		7/20/22	DWN	1455	1525	Bi-Weekly Test Run	125	425	-1-2023	LAB	1444	1514	BI-WEEKLY TEST RUN	140	587
1/6/		8/7/22	DE	1212	1242	BI-WEEKLY TEST RUN	126	455	-12-23	DWN	1410	1440	Bi-Weekly Test Run	141	617
1-20		8-21-22	CYC	1655	1755	Bi-weekly Test Run	126	485	0-29-23	LAB	1235	1305	BI-WEEKLY TEST RUN	141	647
1-29		8/31/22	DE	0952	1012	CD POWER POST MAINTENANCE RUN	127	505	1-12-23	JAC	1150	1220	BI-WEEKLY TEST RUN	142	677
2-17-1		9-17-22	JN	1410	1440	Bi-weekly test Run	127	535	1-25-2023	LAB	1538	1608	BI-WEEKLY TEST RUN	142	707
3-11-1		9-24-22	CYC	1520	1534	Aborted. Redundant Test Run	127	550	2-7-23	DWN	1055	1125	Bi-Weekly Test Run	143	737
4-29		10/2/22	DE	1230	1300	BI-WEEKLY TEST RUN	128	580	2-21-23	KAB	0900	0905	Diesel Delivery 40 gallons		
4/20		10-15-22	JN	1314	1344	Bi weekly test Run	128	010	2-23-23	KAB	1216	1246	Bi-Weekly Test Run.	143	767
7-18		10/30/2022	LAB	1449	1519	BI-WEEKLY TEST RUN	129	640					2024	143	8
8-20		11-12-22	JN	1238	1308	Bi weekly test Run	129	670	1-6-24	JR	1123	1153	BI-WEEKLY TEST RUN	144	5
9-20		11-27-22	CYC	1011	1041	Bi-weekly Test Run	130	700	-20-2024	LAB	1507	1537	BI-WEEKLY TEST RUN	144	60
9-20		12-10-22	JN	1200	1230	Bi-weekly test Run	130	730	2-1-24	DWN	1205	1235	Bi-Weekly Test Run	145	90
9-20									2-18-24	LAB	0922	0952	BI-WEEKLY TEST RUN	145	120
10-10									2-21/24	DE	0806	0808	EDG BLACK PLANT FUNCTION TEST	146	122
10-10		1-8-23	LH	13:13	13:43	Biweekly Test Run	131	30	2-21/24	DE	0823	0844	EDG BLACK PLANT FUNCTION TEST	146	143
10-10		1-22-23	LAB	1453	1523	BIWEEKLY TEST RUN	131	60	2-21/24	DE	0959	1301	RUNNING TO POWER ESS	149	285
10-10		2-3-23	JN	1110	1144	BIWEEKLY TEST RUN	132	94	3-17-24	LAB	1214	1244	BI-WEEKLY TEST RUN	149	235
10-10		2-19-23	LAB	1459	1529	BIWEEKLY TEST RUN	132	124	3-31-24	DWN	1120	1150	Bi-Weekly Test Run	150	265
10-10		3-5-23	LIA	13:00	13:30	Bi Weekly Test Run	133	154	4-14-24	LAB	1021	1051	BI-WEEKLY TEST RUN	150	295
11-10		3-18-23	LAB	1114	1144	BI WEEKLY TEST RUN	133	184	5-5-24	JAC	1638	1708	BI-WEEKLY TEST RUN	151	325
11-10		5-2-23	CYC	1344	1405	Transfer from Alt to Norm feed	134	205	5-11-24	LAB	1532	1602	BI-WEEKLY TEST RUN	151	355
11-10		5-7-23	CYC	1040	1110	Bi-Weekly Test Run	134	235	5-25-24	JR	1624	1634	BI-WEEKLY TEST RUN	152	385
12-10		5-13-23	LH	21:22	21:52	Bi-weekly Test Run	135	265	6-14/24	LAB			DIESEL FUEL DELIVERY - 130 GALLONS		
12-10		5-28-23	DWN	0810	0840	Bi-Weekly Test Run	135	295	6-9-24	LAB	1104	1134	BI-WEEKLY TEST RUN	152	415
12-10		6-8-23	LAB	0831	0901	BI-WEEKLY TEST RUN	136	325	6-19-24	JR	1202	1217	ANNUAL TEST (CD POWER)	153	430
1/16		6-15-23	EO	14:25	14:57	REPLACE COOLANT HOSE TEST RUN	136	337	6-21-24	JR	1547	1617	BI-WEEKLY TEST RUN	153	460
1/16		6-25-23	DWN	1230	1300	Bi-Weekly Test Run	137	367	7-7-24	LAB	1150	1220	BI-WEEKLY TEST RUN	153	490
1/16		7-6-23	KAB			Diesel Delivery 21 Gallons	137	397	7-18-24	DWN	1255	1325	Bi-Weekly Test Run	154	520
1/16		7-9-23	LAB	1336	1406	BI-WEEKLY TEST RUN	137	427	7-24-24	DWN	1052	1102	PCAPCD TEST RUN	154	530
1/16		7-23-23	JR	1113	1143	BI-WEEKLY TEST RUN	138	457	8-3-24	LAB	1228	1258	BI-WEEKLY TEST RUN	155	560
1/16		8-6-2023	LAB	1635	1705	BI-WEEKLY TEST RUN	138	487	8-17-24	JR	1500	1530	BI-WEEKLY TEST RUN	155	590
1/16		8-20-2023	JR	1251	1321	BI-WEEKLY TEST RUN	139	517	8-31-24	LAB	1343	1413	BI-WEEKLY TEST RUN	156	620
2-10		9-3-2023	LAB	1625	1655	BI-WEEKLY TEST RUN	139	547	9-14-24	JR	1348	1418	BI-WEEKLY TEST RUN	156	650
2-10		9-16-2023	LH	0830	0900	Bi-weekly Test Run	140	577	9-28-24	LAB	1336	1406	BI-WEEKLY TEST RUN	157	680

AQ-87

AQ-87 Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	Start Time	Reason	Stop Time	Total Hrs.	YTD Hrs.	Initials
4-14-24	1414	WEEKLY TEST RUN	1444	281.9	8.3	AAB
4-22-24	0207	Weekly Test Run	0237	282.4	8.8	2AB
4-28-24	1450	Weekly Test Run	1520	282.9	9.3	2AB
5-5-24	1445	Weekly Test Run	1515	283.4	9.8	2AB
5-12-24	1428	WEEKLY TEST RUN	1458	283.9	10.3	AAB
5-16-24	0802	Annual test	0807	284.0	10.4	jm
5-25-24	1521	WEEKLY TEST RUN	1551	284.5	10.9	2AB
6-2-24	11:44	Weekly Test Run	1214	285.0	11.4	2AB
6/4/24	1200	DIESEL FUEL DELIVERY - 70 GALLONS				
6-9-24	1323	WEEKLY TEST RUN	1353	285.5	11.9	AAB
6-16-24		Weekly test Run		286.0	12.4	jm
6-19-24	1000	ANNUAL TEST (CD POWER)		286.3	12.7	2AB
6-22-24	1510	WEEKLY PM		286.8	13.2	2AB
6-30-24	1446	Weekly Test Run	1516	287.3	13.7	2AB
7-7-24	1349	WEEKLY TEST RUN	1419	287.8	14.2	AAB
7-14-24	1632	Weekly Test Run	1643	288.0	14.4	CYC
7-18-24		Changed coolant, Hoses + Battery CUD Power				
7-17-24	1100	Test Run After Service	1106	288.1	14.5	DWN
7-20-24	1347	WEEKLY PM	1617	288.6	15	2AB
7-24-24	1100	PCAPCD Test Run	1106	288.7	15.1	DWN
7/27/24	1135	Weekly Test Run	1205	289.2	15.6	DE
8-4-24	1312	WEEKLY TEST RUN	1342	289.7	16.1	AAB
8-7-24	1020	Weekly test Run	1050	290.2	16.6	jm
8-18-24	1105	Weekly Test Run	1135	290.7	17.1	DWN
8-24-24	1340	Weekly Test Run	1420	291.2	17.6	2AB
9-1-24	1510	WEEKLY TEST RUN	1540	291.7	18.1	AAB
9-8-24	1134	Weekly test Run	1204	292.2	18.6	2AB
9-14-24	1428	WEEKLY TEST RUN	1755	292.7	19.1	2AB
9-22-24	0917	WEEKLY TEST RUN	0947	293.2	19.6	2AB
9-29-24	1443	WEEKLY TEST RUN	1513	293.7	20.1	AAB

AQ-88

AQ-88 The Sulfur content of the Diesel fuel used shall not exceed 15 ppm by weight.

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report as required in Condition of Certification AQ-SC6.

AQ-89

AQ-89 Records of operation and maintenance shall be kept by the owner or Operator for a period of five years and shall be made available to the PCAPCD upon request. Information required for reporting to the PCAPCD includes, but is not limited to:

1. The hours of operation the engine was run for maintenance and testing;
2. The hours of operation the engine was run during interruption of electrical power; and
3. Records of the sulfur content of the diesel used.

VERIFICATION: The Project owner shall include these records as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

6	8	DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD	DATE	Initial	START	END	Reason	Hours Total	Minutes YTD
		7/10/22	DE	1120	1150	BI-WEEKLY TEST RUN	125	395	7-22-23	LH	1139	1149	CD Power Pm's Test Run	140	557
12/24		7/20/22	DWN	1455	1525	Bi-Weekly Test Run	125	425	-1-2023	LAB	1444	1514	BI-WEEKLY TEST RUN	140	587
1/6/		8/7/22	DE	1212	1242	BI-WEEKLY TEST RUN	126	455	-12-23	DWN	1410	1440	Bi-Weekly Test Run	141	617
1-20		8-21-22	CYC	1655	1755	Bi-weekly Test Run	126	485	0-29-23	LAB	1235	1305	BI-WEEKLY TEST RUN	141	647
1-29		8/31/22	DE	0952	1012	CD POWER POST MAINTENANCE RUN	127	505	1-12-23	JAC	1150	1220	BI-WEEKLY TEST RUN	142	677
2-17-1		9-17-22	JN	1410	1440	Bi-weekly test Run	127	535	1-25-2023	LAB	1538	1608	BI-WEEKLY TEST RUN	142	707
3-11-1		9-24-22	CYC	1520	1534	Aborted. Redundant Test Run	127	550	2-7-23	DWN	1055	1125	Bi-Weekly Test Run	143	737
4-29		10/2/22	DE	1230	1300	BI-WEEKLY TEST RUN	128	580	2-21-23	KD	0900	0905	Diesel Delivery 40 gallons		
4/20		10-15-22	JN	1314	1344	Bi weekly test Run	128	010	2-23-23	KD	1216	1246	Bi-Weekly Test Run.	143	767
7-18		10/30/2022	LAB	1449	1519	BI-WEEKLY TEST RUN	129	640					2024	143	8
8-20		11-12-22	JN	1238	1308	Bi weekly test Run	129	670	1-6-24	JR	1123	1153	BI-WEEKLY TEST RUN	144	5
9-20		11-27-22	CYC	1011	1041	Bi-weekly Test Run	130	700	-20-2024	LAB	1507	1537	BI-WEEKLY TEST RUN	144	60
9-20		12-10-22	JN	1200	1230	Bi-weekly test Run	130	730	2-1-24	DWN	1205	1235	Bi-Weekly Test Run	145	90
9-20									2-18-24	LAB	0922	0952	BI-WEEKLY TEST RUN	145	120
10-10									2-21/24	DE	0806	0808	EDG BLACK PLANT FUNCTION TEST	146	122
10-10		1-8-23	LH	13:13	13:43	Biweekly Test Run	131	30	2-21/24	DE	0823	0844	EDG BLACK PLANT FUNCTION TEST	146	143
10-10		1-22-23	LAB	1453	1523	BIWEEKLY TEST RUN	131	60	2-21/24	DE	0959	1301	RUNNING TO POWER ESS	149	285
10-10		2-3-23	DE	1110	1144	BIWEEKLY TEST RUN	132	94	3/17/24	LAB	1214	1244	BI-WEEKLY TEST RUN	149	235
10-10		2-19-23	LAB	1459	1529	BIWEEKLY TEST RUN	132	124	3-31-24	DWN	1120	1150	Bi-Weekly Test Run	150	265
10-10		3-5-23	LIA	13:00	13:30	Bi Weekly Test Run	133	154	4-14-24	LAB	1021	1051	BI-WEEKLY TEST RUN	150	295
11-10		3-18-23	LAB	1114	1144	BI WEEKLY TEST RUN	133	184	5-5-24	JAC	1638	1708	BI-WEEKLY TEST RUN	151	325
11-10		5-2-23	CYC	1344	1405	Transfer from Alt to Norm feed	134	205	5-11-24	LAB	1532	1602	BI-WEEKLY TEST RUN	151	355
11-10		5-7-23	CYC	1040	1110	Bi-Weekly Test Run	134	235	5-25-24	JR	1624	1634	BI-WEEKLY TEST RUN	152	385
12-10		5-13-23	LH	21:22	21:52	Bi-weekly Test Run	135	265	6/4/24	LAB	1104	1134	BI-WEEKLY TEST RUN	152	415
12-10		5-28-23	DWN	0810	0840	Bi-Weekly Test Run	135	295	6-9-24	JR	1202	1217	ANNUAL TEST (CD POWER)	153	430
12-10		6-8-23	LAB	0831	0901	BI-WEEKLY TEST RUN	136	325	6-19-24	JR	1547	1617	BI-WEEKLY TEST RUN	153	460
1/16		6-15-23	EO	14:25	14:57	REPLACE COOLANT HOSE TEST RUN	136	337	6-21-24	LAB	1150	1220	BI-WEEKLY TEST RUN	153	490
1/16		6-25-23	DWN	1230	1300	Bi-Weekly Test Run	137	367	7-7-24	DWN	1255	1325	Bi-Weekly Test Run	154	520
1/16		7-6-23	KD			Diesel Delivery 21 Gallons	137	397	7-18-24	DWN	1052	1102	PCAPCD Test Run	154	530
1/16		7-9-23	LAB	1336	1406	BI-WEEKLY TEST RUN	138	427	7-24-24	LAB	1228	1258	BI-WEEKLY TEST RUN	155	560
1/16		7-23-23	JR	1113	1143	BI-WEEKLY TEST RUN	138	457	8-3-24	JR	1500	1530	BI-WEEKLY TEST RUN	155	590
1/16		8-6-2023	LAB	1635	1705	BI-WEEKLY TEST RUN	139	487	8-17-24	LAB	1343	1413	BI-WEEKLY TEST RUN	156	620
1/16		8-20-2023	JR	1251	1321	BI-WEEKLY TEST RUN	139	517	8-31-24	LAB	1348	1418	BI-WEEKLY TEST RUN	156	650
1/16		9-3-2023	LAB	1625	1655	BI-WEEKLY TEST RUN	140	547	9-14-24	JR	1336	1406	BI-WEEKLY TEST RUN	157	680
1/16		9-16-2023	LH	0830	0900	Bi-weekly Test Run			9-28-24	LAB					

AQ-99/102

AQ-99/102: Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year. Records of operation and maintenance shall be kept by the owner or operator for a period of five years and shall be made available to the PCAPCD by request. Information required for reporting to the PCAPCD includes, but is not limited to:

- A. Hours of operation the engine was run for maintenance and testing
- B. Hours of operation the engine was run during interruption of electrical power
- C. Records of sulfur content of the diesel fuel used

Verification: The Project shall include all necessary operational data to demonstrate compliance with the limits provided as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

6	8	DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD	DATE	Initial	START	END	Reason	Hours Total	Minutes YTD
		7/10/22	DE	1120	1150	BI-WEEKLY TEST RUN	125	395	7-22-23	LH	1139	1149	CD Power Pm's Test Run	140	557
12/24		7/20/22	DWN	1455	1525	Bi-Weekly Test Run	125	425	-1-2023	LAB	1444	1514	BI-WEEKLY TEST RUN	140	587
1/6/		8/7/22	DE	1212	1242	BI-WEEKLY TEST RUN	126	455	-12-23	DWN	1410	1440	Bi-Weekly Test Run	141	617
1-20		8-21-22	CYC	1655	1755	Bi-weekly Test Run	126	485	0-29-23	LAB	1235	1305	BI-WEEKLY TEST RUN	141	647
1-29		8/31/22	DE	0952	1012	CD POWER POST MAINTENANCE RUN	127	505	1-12-23	JXC	1150	1220	BI-WEEKLY TEST RUN	142	677
2-17-1		9-17-22	JN	1410	1440	Bi-weekly test Run	127	535	1-25-2023	LAB	1538	1608	BI-WEEKLY TEST RUN	142	707
3-11-1		9-24-22	CYC	1520	1534	Aborted. Redundant Test Run	127	550	2-7-23	DWN	1055	1125	Bi-Weekly Test Run	143	737
4-29		10/2/22	DE	1230	1300	BI-WEEKLY TEST RUN	128	580	2-21-23	KD	0900	0905	Diesel Delivery 40 gallons		
4/20		10-15-22	JN	1314	1344	Bi weekly test Run	128	010	2-23-23	KD	1216	1246	Bi-Weekly Test Run.	143	767
7-18		10/30/2022	LAB	1449	1519	BI-WEEKLY TEST RUN	129	640					2024	143	8
8-20		11-12-22	JN	1238	1308	Bi weekly test Run	129	670	1-6-24	JR	1123	1153	BI-WEEKLY TEST RUN	144	5
9-20		11-27-22	CYC	1011	1041	Bi-weekly Test Run	130	700	-20-2024	LAB	1507	1537	BI-WEEKLY TEST RUN	144	60
9-20		12-10-22	JN	1200	1230	Bi-weekly test Run	130	730	2-1-24	DWN	1205	1235	Bi-Weekly Test Run	145	90
9-20									2-18-24	LAB	0922	0952	BI-WEEKLY TEST RUN	145	120
10-10									2-21/24	DE	0806	0808	EDG BLACK PLANT FUNCTION TEST	146	122
10-10		1-8-23	LH	13:13	13:43	Biweekly Test Run	131	30	2-21/24	DE	0823	0844	EDG BLACK PLANT FUNCTION TEST	146	143
10-10		1-22-23	LAB	1453	1523	BIWEEKLY TEST RUN	131	60	2-21/24	DE	0959	1301	RUNNING TO POWER ESS	149	285
10-10		2-3-23	DE	1110	1144	BIWEEKLY TEST RUN	132	94	3-17-24	LAB	1214	1244	BI-WEEKLY TEST RUN	149	235
10-10		2-19-23	LAB	1459	1529	BIWEEKLY TEST RUN	132	124	3-31-24	DWN	1120	1150	Bi-Weekly Test Run	150	265
10-10		3-5-23	LIA	13:00	13:30	Bi Weekly Test Run	133	154	4-14-24	LAB	1021	1051	BI-WEEKLY TEST RUN	150	295
11-10		3-18-23	LAB	1114	1144	BI WEEKLY TEST RUN	133	184	5-5-24	JXC	1638	1708	BI-WEEKLY TEST RUN	151	325
11-10		5-2-23	CYC	1344	1405	Transfer from Alt to Norm feed	134	205	5-11-24	LAB	1532	1602	BI-WEEKLY TEST RUN	151	355
11-10		5-7-23	CYC	1040	1110	Bi-Weekly Test Run	134	235	5-25-24	JR	1624	1634	BI-WEEKLY TEST RUN	152	385
12-10		5-13-23	LH	21:22	21:52	Bi-weekly Test Run	135	265	6-14/24	LAB			DIESEL FUEL DELIVERY - 130 GALLONS		
12-10		5-28-23	DWN	0810	0840	Bi-Weekly Test Run	135	295	6-9-24	LAB	1104	1134	BI-WEEKLY TEST RUN	152	415
12-10		6-8-23	LAB	0831	0901	BI-WEEKLY TEST RUN	136	325	6-19-24	JR	1202	1217	ANNUAL TEST (CD POWER)	153	430
1/16		6-15-23	EO	14:25	14:57	REPLACE COOLANT HOSE TEST RUN	136	337	6-21-24	JR	1547	1617	BI-WEEKLY TEST RUN	153	460
1/16		6-25-23	DWN	1230	1300	Bi-Weekly Test Run	137	367	7-7-24	LAB	1150	1220	BI-WEEKLY TEST RUN	153	490
1/16		7-6-23	KD			Diesel Delivery 21 Gallons	137	397	7-18-24	DWN	1255	1325	Bi-Weekly Test Run	154	520
1/16		7-9-23	LAB	1336	1406	BI-WEEKLY TEST RUN	138	427	7-24-24	DWN	1052	1102	PCAPCD TEST RUN	154	530
1/16		7-23-23	JR	1113	1143	BI-WEEKLY TEST RUN	138	457	8-3-24	LAB	1228	1258	BI-WEEKLY TEST RUN	155	560
1/16		8-6-2023	LAB	1635	1705	BI-WEEKLY TEST RUN	139	487	8-17-24	JR	1500	1530	BI-WEEKLY TEST RUN	155	590
1/16		8-20-2023	JR	1251	1321	BI-WEEKLY TEST RUN	139	517	8-31-24	LAB	1343	1413	BI-WEEKLY TEST RUN	156	620
2-10		9-3-2023	LAB	1625	1655	BI-WEEKLY TEST RUN	140	547	9-14-24	JR	1348	1418	BI-WEEKLY TEST RUN	156	650
2-10		9-16-2023	LH	0830	0900	Bi-weekly Test Run	140		9-28-24	LAB	1336	1406	BI-WEEKLY TEST RUN	157	680

AQ-100

AQ-100 In regards to the Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

6		8																					
DATE		INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD	DATE		Initial	START	END	Reason	Hours Total	mins YTD								
7/10/22		DE	1120	1150	BI-WEEKLY TEST RUN	125	395	7-22-23		LH	1139	1149	CD Power Pms Test Run	140	557								
7/20/22		DWN	1455	1525	Bi-Weekly Test Run	125	425	-1-2023		LHAB	1444	1514	BI-WEEKLY TEST RUN	140	587								
8/7/22		DE	1212	1242	BI-WEEKLY TEST RUN	126	455	-12-23		DWN	1410	1440	Bi-Weekly Test Run	141	617								
8-21-22		CYC	1655	1755	Bi-Weekly Test Run	126	485	0-29-23		DAB	1235	1305	BI-WEEKLY TEST RUN	141	647								
8/31/22		DE	0952	1012	CD POWER POST MAINTENANCE RUN	127	505	1-12-23		JAC	1150	1220	BI-WEEKLY TEST RUN	142	677								
9-17-22		JN	1410	1440	Bi-weekly test Run	127	535	1-25-2023		LHAB	1538	1608	BI-WEEKLY TEST RUN	142	707								
9-24-22		CYC	1520	1534	Aborted. Redundant Test Run	127	550	2-7-23		DWN	1055	1125	Bi-Weekly Test Run	143	737								
10/2/22		DE	1230	1300	BI-WEEKLY TEST RUN	128	580	2-21-23		KAB	0900	0905	Diesel Delivery 4 Gallons										
10-15-22		JN	1314	1344	Bi weekly test Run	128	010	2-23-23		KAB	1216	1246	Bi-Weekly Test Run.	143	767								
10/30/2022		LHAB	1449	1519	BI-WEEKLY TEST RUN	129	640						2024	143	787								
11-12-22		JN	1238	1308	Bi weekly test Run	129	670	1-6-24		JAC	1123	1153	BI-WEEKLY TEST RUN	144	797								
11-27-22		CYC	1011	1041	Bi-Weekly Test Run	130	700	-20-2024		LHAB	1507	1537	BI-WEEKLY TEST RUN	144	807								
12-10-22		JN	1200	1230	Bi-weekly test Run	130	730	2-1-24		DWN	1205	1235	Bi-Weekly Test Run	145	827								
								2-18-24		LHAB	0922	0952	BI-WEEKLY TEST RUN	145	847								
								2-21/24		DE	0806	0808	EDG BLACK PLANT FUNCTION TEST	146	857								
1-8-23		LH	13:13	13:43	Biweekly Test Run	130	0	2-21/24		DE	0823	0844	EDG BLACK PLANT FUNCTION TEST	146	867								
1-22-23		LHAB	1453	1523	BIWEEKLY TEST RUN	131	30	2-21/24		DE	0959	1301	RUNNING TO POWER ESS	149	887								
2-3-23		JN	1110	1144	BIWEEKLY TEST RUN	131	60	3-17/24		LHAB	1214	1244	BI-WEEKLY TEST RUN	149	907								
2-19-23		LHAB	1459	1529	BIWEEKLY TEST RUN	132	94	3-31-24		DWN	1120	1150	Bi-Weekly Test Run	150	927								
3-5-23		LH	13:00	13:30	Bi Weekly Test Run	132	124	4-14-24		LHAB	1021	1051	BI-WEEKLY TEST RUN	150	947								
3-18-23		LHAB	1114	1144	BI WEEKLY TEST RUN	133	154	5-5-24		JAC	1638	1708	BI-WEEKLY TEST RUN	151	967								
5-2-23		CYC	1344	1405	Transfer from Alt to Norm feed	133	184	5-11-24		LHAB	1532	1602	BI-WEEKLY TEST RUN	151	987								
5-7-23		CYC	1040	1110	Bi-Weekly Test Run	134	205	5-25-24		JN	1604	1634	BI-WEEKLY TEST RUN	152	1007								
5-13-23		LH	21:22	21:52	Bi-weekly Test Run	134	235	6-4-24					DIESEL FUEL DELIVERY - 130 GALS										
5-28-23		DWN	0810	0840	Bi-weekly Test Run	135	265	6-9-24		LHAB	1104	1134	BI-WEEKLY TEST RUN	152	1017								
6-8-23		LHAB	0831	0901	BI-WEEKLY TEST RUN	135	295	6-19-24		JN	1202	1217	ANNUAL TEST (CD POWER)	153	1037								
6-15-23		EO	14:25	14:57	REPLACE COOLANT HOSE TEST RUN	136	325	6-21-24		JAC	1547	1617	BI-WEEKLY TEST RUN	153	1057								
6-25-23		DWN	1230	1300	Bi-Weekly Test Run	136	337	7-7-24		LHAB	1150	1220	BI-WEEKLY TEST RUN	153	1077								
7-6-23		KAB			Diesel Delivery 21 Gallons	137	367	7-18-24		DWN	1255	1325	Bi-Weekly Test Run	154	1097								
7-9-23		LHAB	1336	1406	BI-WEEKLY TEST RUN	137	397	7-24-24		DWN	1052	1102	PCAPCD Test Run	154	1117								
7-23-23		JAC	1113	1143	BI-WEEKLY TEST RUN	138	427	8-3-24		LHAB	1228	1258	BI-WEEKLY TEST RUN	155	1137								
8-6-2023		LHAB	1635	1705	BI-WEEKLY TEST RUN	138	457	8-17-24		JN	1500	1530	BI-WEEKLY TEST RUN	155	1157								
8-20-2023		JAC	1251	1321	BI-WEEKLY TEST RUN	139	487	8-31-24		LHAB	1343	1413	BI-WEEKLY TEST RUN	156	1177								
9-3-2023		LHAB	1625	1655	BI-WEEKLY TEST RUN	139	517	9-14-24		JN	1348	1418	BI-WEEKLY TEST RUN	156	1197								
9-16-2023		LH	0830	0900	Bi-weekly Test Run	140	547	9-28-24		LHAB	1336	1406	BI-WEEKLY TEST RUN	157	1217								

AQ-101

AQ-101 The sulfur content of the diesel used shall not exceed 15ppm by weight

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report in Condition of Certification AQ-SC6

II. Emissions Overview

AQ-15

AQ-15 The Project owner shall install a selective catalytic reduction (SCR) system and an oxidation catalyst on the gas turbine. The SCR and oxidation catalyst equipment shall be operated whenever the gas turbine is operated.

Verification: The Project owner shall submit to the CPM a written statement by a California registered Professional Engineer stating that said engineer has reviewed the as built designs or inspected the identified equipment and certifies that it is operational and air tight. The Project owner shall include the operational status of the SCR and oxidation catalyst during all hours of operation as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

This document is on file from the 2007 4Q QAQR.

AQ-32

AQ-32 The Project owner shall maintain hourly records of NO_x and CO emission concentrations (ppmv @ 15% O₂), and hourly, daily, and quarterly records of NO_x and CO emissions. Ongoing compliance with the CO emission limits during normal operation shall be deemed compliance with the VOC emission limits during normal operation.

Verification: The project owner shall submit to the CPM all concentration, hourly, daily, and quarter NO_x and CO emissions as part of the Quarterly Air Quality Report required by Condition of Certification AQ-SC6

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:24 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Jul 2024	0.4589	3.9373	1.6951	9.8201	0.3762	2.1164	0.1875	1.0584	0.6265	3.5273
Aug 2024	0.5206	3.9875	1.3777	9.5370	0.3463	2.1015	0.1724	1.0502	0.5763	3.5015
Sep 2024	0.4457	3.9688	1.5432	9.8108	0.3534	2.1779	0.1774	1.0890	0.5887	3.6283
Sum/Avg	3.9688		9.8108		2.1779		1.0890		3.6283	
Limit Value										

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
07/01/2024 00:00	15.23	47.55	16.74	54.66
Average/Sum#:	15.23 #	47.55 #	16.74 #	54.66 #
Minimum:	15.23	47.55	16.74	54.66
Maximum:	15.23	47.55	16.74	54.66
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
07/02/2024 00:00	13.95	56.14	14.68	62.81
Average/Sum#:	13.95 #	56.14 #	14.68 #	62.81 #
Minimum:	13.95	56.14	14.68	62.81
Maximum:	13.95	56.14	14.68	62.81
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
07/03/2024 00:00	14.79	52.28	15.50	59.92
Average/Sum#:	14.79 #	52.28 #	15.50 #	59.92 #
Minimum:	14.79	52.28	15.50	59.92
Maximum:	14.79	52.28	15.50	59.92
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
07/04/2024 00:00	15.25	42.14	15.91	51.22

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	15.25 #	42.14 #	15.91 #	51.22 #
Minimum:	15.25	42.14	15.91	51.22
Maximum:	15.25	42.14	15.91	51.22
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
07/05/2024 00:00	15.33	44.98	15.94	54.12
Average/Sum#:	15.33 #	44.98 #	15.94 #	54.12 #
Minimum:	15.33	44.98	15.94	54.12
Maximum:	15.33	44.98	15.94	54.12
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
07/06/2024 00:00	14.82	46.75	15.56	55.19
Average/Sum#:	14.82 #	46.75 #	15.56 #	55.19 #
Minimum:	14.82	46.75	15.56	55.19
Maximum:	14.82	46.75	15.56	55.19
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
07/07/2024 00:00	13.40	50.72	13.60	58.21
Average/Sum#:	13.40 #	50.72 #	13.60 #	58.21 #
Minimum:	13.40	50.72	13.60	58.21
Maximum:	13.40	50.72	13.60	58.21
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
07/08/2024 00:00	12.82	54.83	13.34	61.58
Average/Sum#:	12.82 #	54.83 #	13.34 #	61.58 #
Minimum:	12.82	54.83	13.34	61.58
Maximum:	12.82	54.83	13.34	61.58
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
07/09/2024 00:00	13.37	55.77	13.68	63.07
Average/Sum#:	13.37 #	55.77 #	13.68 #	63.07 #
Minimum:	13.37	55.77	13.68	63.07
Maximum:	13.37	55.77	13.68	63.07
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
07/10/2024 00:00	15.05	52.79	15.24	61.27
Average/Sum#:	15.05 #	52.79 #	15.24 #	61.27 #
Minimum:	15.05	52.79	15.24	61.27
Maximum:	15.05	52.79	15.24	61.27
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
07/11/2024 00:00	12.69	56.54	13.07	64.02

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	12.69 #	56.54 #	13.07 #	64.02 #
Minimum:	12.69	56.54	13.07	64.02
Maximum:	12.69	56.54	13.07	64.02
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
07/12/2024 00:00	14.17	52.62	14.29	61.01
Average/Sum#:	14.17 #	52.62 #	14.29 #	61.01 #
Minimum:	14.17	52.62	14.29	61.01
Maximum:	14.17	52.62	14.29	61.01
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
07/13/2024 00:00	14.93	43.46	15.51	51.86
Average/Sum#:	14.93 #	43.46 #	15.51 #	51.86 #
Minimum:	14.93	43.46	15.51	51.86
Maximum:	14.93	43.46	15.51	51.86
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
07/14/2024 00:00	14.30	43.29	15.33	51.70
Average/Sum#:	14.30 #	43.29 #	15.33 #	51.70 #
Minimum:	14.30	43.29	15.33	51.70
Maximum:	14.30	43.29	15.33	51.70
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
07/15/2024 00:00	13.52	42.95	14.99	51.24
Average/Sum#:	13.52 #	42.95 #	14.99 #	51.24 #
Minimum:	13.52	42.95	14.99	51.24
Maximum:	13.52	42.95	14.99	51.24
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
07/16/2024 00:00	15.26	43.13	15.94	52.54
Average/Sum#:	15.26 #	43.13 #	15.94 #	52.54 #
Minimum:	15.26	43.13	15.94	52.54
Maximum:	15.26	43.13	15.94	52.54
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
07/17/2024 00:00	15.21	44.30	15.70	51.99
Average/Sum#:	15.21 #	44.30 #	15.70 #	51.99 #
Minimum:	15.21	44.30	15.70	51.99
Maximum:	15.21	44.30	15.70	51.99
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
07/18/2024 00:00	14.95	54.48	24.42	26.18

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	14.95 #	54.48 #	24.42 #	26.18 #
Minimum:	14.95	54.48	24.42	26.18
Maximum:	14.95	54.48	24.42	26.18
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)

07/19/2024 00:00	16.83	68.30	0.00	0.00
------------------	-------	-------	------	------

Average/Sum#:	16.83 #	68.30 #	0.00 #	0.00 #
Minimum:	16.83	68.30	0.00	0.00
Maximum:	16.83	68.30	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)

07/20/2024 00:00	15.83	62.75	24.40	57.74
------------------	-------	-------	-------	-------

Average/Sum#:	15.83 #	62.75 #	24.40 #	57.74 #
Minimum:	15.83	62.75	24.40	57.74
Maximum:	15.83	62.75	24.40	57.74
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)

07/21/2024 00:00	14.58	43.12	15.81	53.69
------------------	-------	-------	-------	-------

Average/Sum#:	14.58 #	43.12 #	15.81 #	53.69 #
Minimum:	14.58	43.12	15.81	53.69
Maximum:	14.58	43.12	15.81	53.69
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
07/22/2024 00:00	13.91	56.35	13.68	64.71
Average/Sum#:	13.91 #	56.35 #	13.68 #	64.71 #
Minimum:	13.91	56.35	13.68	64.71
Maximum:	13.91	56.35	13.68	64.71
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
07/23/2024 00:00	8.61	74.83	7.78	80.79
Average/Sum#:	8.61 #	74.83 #	7.78 #	80.79 #
Minimum:	8.61	74.83	7.78	80.79
Maximum:	8.61	74.83	7.78	80.79
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
07/24/2024 00:00	13.18	69.79	11.91	72.44
Average/Sum#:	13.18 #	69.79 #	11.91 #	72.44 #
Minimum:	13.18	69.79	11.91	72.44
Maximum:	13.18	69.79	11.91	72.44
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
07/25/2024 00:00	12.93	56.99	12.83	64.21

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	12.93 #	56.99 #	12.83 #	64.21 #
Minimum:	12.93	56.99	12.83	64.21
Maximum:	12.93	56.99	12.83	64.21
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
07/26/2024 00:00	15.11	43.62	15.10	51.97
Average/Sum#:	15.11 #	43.62 #	15.10 #	51.97 #
Minimum:	15.11	43.62	15.10	51.97
Maximum:	15.11	43.62	15.10	51.97
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
07/27/2024 00:00	14.98	42.88	15.42	51.77
Average/Sum#:	14.98 #	42.88 #	15.42 #	51.77 #
Minimum:	14.98	42.88	15.42	51.77
Maximum:	14.98	42.88	15.42	51.77
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
07/28/2024 00:00	14.93	45.09	15.37	51.64
Average/Sum#:	14.93 #	45.09 #	15.37 #	51.64 #
Minimum:	14.93	45.09	15.37	51.64
Maximum:	14.93	45.09	15.37	51.64
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
07/29/2024 00:00	16.64	49.67	16.84	55.25
Average/Sum#:	16.64 #	49.67 #	16.84 #	55.25 #
Minimum:	16.64	49.67	16.84	55.25
Maximum:	16.64	49.67	16.84	55.25
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
07/30/2024 00:00	14.40	53.93	14.20	59.15
Average/Sum#:	14.40 #	53.93 #	14.20 #	59.15 #
Minimum:	14.40	53.93	14.20	59.15
Maximum:	14.40	53.93	14.20	59.15
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
07/31/2024 00:00	14.43	53.12	14.45	61.49
Average/Sum#:	14.43 #	53.12 #	14.45 #	61.49 #
Minimum:	14.43	53.12	14.45	61.49
Maximum:	14.43	53.12	14.45	61.49
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
08/01/2024 00:00	13.67	54.49	57.02	58.65

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	13.67 #	54.49 #	57.02 #	58.65 #
Minimum:	13.67	54.49	57.02	58.65
Maximum:	13.67	54.49	57.02	58.65
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/02/2024 00:00	16.03	57.26	16.44	64.98

Average/Sum#:	16.03 #	57.26 #	16.44 #	64.98 #
Minimum:	16.03	57.26	16.44	64.98
Maximum:	16.03	57.26	16.44	64.98
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/03/2024 00:00	14.95	45.04	15.46	40.16

Average/Sum#:	14.95 #	45.04 #	15.46 #	40.16 #
Minimum:	14.95	45.04	15.46	40.16
Maximum:	14.95	45.04	15.46	40.16
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/04/2024 00:00	14.99	46.57	15.63	42.86

Average/Sum#:	14.99 #	46.57 #	15.63 #	42.86 #
Minimum:	14.99	46.57	15.63	42.86
Maximum:	14.99	46.57	15.63	42.86
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
08/05/2024 00:00	15.26	44.53	16.24	36.67
Average/Sum#:	15.26 #	44.53 #	16.24 #	36.67 #
Minimum:	15.26	44.53	16.24	36.67
Maximum:	15.26	44.53	16.24	36.67
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
08/06/2024 00:00	15.82	45.58	16.75	35.81
Average/Sum#:	15.82 #	45.58 #	16.75 #	35.81 #
Minimum:	15.82	45.58	16.75	35.81
Maximum:	15.82	45.58	16.75	35.81
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
08/07/2024 00:00	15.38	41.79	16.33	39.50
Average/Sum#:	15.38 #	41.79 #	16.33 #	39.50 #
Minimum:	15.38	41.79	16.33	39.50
Maximum:	15.38	41.79	16.33	39.50
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
08/08/2024 00:00	13.49	40.54	15.37	32.52

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	13.49 #	40.54 #	15.37 #	32.52 #
Minimum:	13.49	40.54	15.37	32.52
Maximum:	13.49	40.54	15.37	32.52
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/09/2024 00:00	13.45	42.09	15.47	31.87
Average/Sum#:	13.45 #	42.09 #	15.47 #	31.87 #
Minimum:	13.45	42.09	15.47	31.87
Maximum:	13.45	42.09	15.47	31.87
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/10/2024 00:00	13.44	42.11	15.44	29.72
Average/Sum#:	13.44 #	42.11 #	15.44 #	29.72 #
Minimum:	13.44	42.11	15.44	29.72
Maximum:	13.44	42.11	15.44	29.72
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/11/2024 00:00	15.56	47.88	16.87	46.81
Average/Sum#:	15.56 #	47.88 #	16.87 #	46.81 #
Minimum:	15.56	47.88	16.87	46.81
Maximum:	15.56	47.88	16.87	46.81
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOX, Lb	CO, Lb	NOX, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/12/2024 00:00	14.37	44.30	17.03	38.48
Average/Sum#:	14.37 #	44.30 #	17.03 #	38.48 #
Minimum:	14.37	44.30	17.03	38.48
Maximum:	14.37	44.30	17.03	38.48
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOX, Lb	CO, Lb	NOX, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/13/2024 00:00	13.88	44.35	18.48	38.56
Average/Sum#:	13.88 #	44.35 #	18.48 #	38.56 #
Minimum:	13.88	44.35	18.48	38.56
Maximum:	13.88	44.35	18.48	38.56
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOX, Lb	CO, Lb	NOX, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/14/2024 00:00	12.90	47.54	18.47	41.41
Average/Sum#:	12.90 #	47.54 #	18.47 #	41.41 #
Minimum:	12.90	47.54	18.47	41.41
Maximum:	12.90	47.54	18.47	41.41
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOX, Lb	CO, Lb	NOX, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/15/2024 00:00	13.78	47.88	19.50	37.83

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	13.78 #	47.88 #	19.50 #	37.83 #
Minimum:	13.78	47.88	19.50	37.83
Maximum:	13.78	47.88	19.50	37.83
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/16/2024 00:00	13.25	43.38	19.34	34.64

Average/Sum#:	13.25 #	43.38 #	19.34 #	34.64 #
Minimum:	13.25	43.38	19.34	34.64
Maximum:	13.25	43.38	19.34	34.64
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/17/2024 00:00	12.32	42.55	18.20	26.04

Average/Sum#:	12.32 #	42.55 #	18.20 #	26.04 #
Minimum:	12.32	42.55	18.20	26.04
Maximum:	12.32	42.55	18.20	26.04
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/18/2024 00:00	13.07	41.61	18.37	38.41

Average/Sum#:	13.07 #	41.61 #	18.37 #	38.41 #
Minimum:	13.07	41.61	18.37	38.41
Maximum:	13.07	41.61	18.37	38.41
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOX, Lb	CO, Lb	NOX, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/19/2024 00:00	13.49	42.11	19.28	43.32
Average/Sum#:	13.49 #	42.11 #	19.28 #	43.32 #
Minimum:	13.49	42.11	19.28	43.32
Maximum:	13.49	42.11	19.28	43.32
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOX, Lb	CO, Lb	NOX, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/20/2024 00:00	13.64	41.38	17.68	47.05
Average/Sum#:	13.64 #	41.38 #	17.68 #	47.05 #
Minimum:	13.64	41.38	17.68	47.05
Maximum:	13.64	41.38	17.68	47.05
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOX, Lb	CO, Lb	NOX, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/21/2024 00:00	13.27	41.78	18.41	51.18
Average/Sum#:	13.27 #	41.78 #	18.41 #	51.18 #
Minimum:	13.27	41.78	18.41	51.18
Maximum:	13.27	41.78	18.41	51.18
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOX, Lb	CO, Lb	NOX, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/22/2024 00:00	13.36	41.77	18.17	51.52

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	13.36 #	41.77 #	18.17 #	51.52 #
Minimum:	13.36	41.77	18.17	51.52
Maximum:	13.36	41.77	18.17	51.52
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/23/2024 00:00	14.26	42.77	18.92	51.98

Average/Sum#:	14.26 #	42.77 #	18.92 #	51.98 #
Minimum:	14.26	42.77	18.92	51.98
Maximum:	14.26	42.77	18.92	51.98
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/24/2024 00:00	15.24	42.40	19.21	52.17

Average/Sum#:	15.24 #	42.40 #	19.21 #	52.17 #
Minimum:	15.24	42.40	19.21	52.17
Maximum:	15.24	42.40	19.21	52.17
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/25/2024 00:00	15.63	44.12	20.84	52.69

Average/Sum#:	15.63 #	44.12 #	20.84 #	52.69 #
Minimum:	15.63	44.12	20.84	52.69
Maximum:	15.63	44.12	20.84	52.69
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
08/26/2024 00:00	14.35	42.79	19.95	52.27
Average/Sum#:	14.35 #	42.79 #	19.95 #	52.27 #
Minimum:	14.35	42.79	19.95	52.27
Maximum:	14.35	42.79	19.95	52.27
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
08/27/2024 00:00	14.96	41.99	20.00	51.48
Average/Sum#:	14.96 #	41.99 #	20.00 #	51.48 #
Minimum:	14.96	41.99	20.00	51.48
Maximum:	14.96	41.99	20.00	51.48
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
08/28/2024 00:00	14.96	40.81	20.00	51.54
Average/Sum#:	14.96 #	40.81 #	20.00 #	51.54 #
Minimum:	14.96	40.81	20.00	51.54
Maximum:	14.96	40.81	20.00	51.54
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
08/29/2024 00:00	14.64	42.57	20.11	53.10

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	14.64 #	42.57 #	20.11 #	53.10 #
Minimum:	14.64	42.57	20.11	53.10
Maximum:	14.64	42.57	20.11	53.10
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/30/2024 00:00	14.82	41.82	19.50	51.17

Average/Sum#:	14.82 #	41.82 #	19.50 #	51.17 #
Minimum:	14.82	41.82	19.50	51.17
Maximum:	14.82	41.82	19.50	51.17
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
08/31/2024 00:00	14.33	47.91	19.95	57.51

Average/Sum#:	14.33 #	47.91 #	19.95 #	57.51 #
Minimum:	14.33	47.91	19.95	57.51
Maximum:	14.33	47.91	19.95	57.51
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
09/01/2024 00:00	14.87	42.30	19.51	51.50

Average/Sum#:	14.87 #	42.30 #	19.51 #	51.50 #
Minimum:	14.87	42.30	19.51	51.50
Maximum:	14.87	42.30	19.51	51.50
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
09/02/2024 00:00	15.00	43.04	19.90	50.62
Average/Sum#:	15.00 #	43.04 #	19.90 #	50.62 #
Minimum:	15.00	43.04	19.90	50.62
Maximum:	15.00	43.04	19.90	50.62
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
09/03/2024 00:00	15.86	48.29	21.32	57.02
Average/Sum#:	15.86 #	48.29 #	21.32 #	57.02 #
Minimum:	15.86	48.29	21.32	57.02
Maximum:	15.86	48.29	21.32	57.02
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
09/04/2024 00:00	11.67	48.69	20.71	62.75
Average/Sum#:	11.67 #	48.69 #	20.71 #	62.75 #
Minimum:	11.67	48.69	20.71	62.75
Maximum:	11.67	48.69	20.71	62.75
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
09/05/2024 00:00	8.65	57.97	18.23	67.14

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	8.65 #	57.97 #	18.23 #	67.14 #
Minimum:	8.65	57.97	18.23	67.14
Maximum:	8.65	57.97	18.23	67.14
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
09/06/2024 00:00	8.04	58.62	17.57	67.22
Average/Sum#:	8.04 #	58.62 #	17.57 #	67.22 #
Minimum:	8.04	58.62	17.57	67.22
Maximum:	8.04	58.62	17.57	67.22
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
09/07/2024 00:00	8.87	57.32	18.76	67.20
Average/Sum#:	8.87 #	57.32 #	18.76 #	67.20 #
Minimum:	8.87	57.32	18.76	67.20
Maximum:	8.87	57.32	18.76	67.20
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
09/08/2024 00:00	9.55	53.93	19.29	62.85
Average/Sum#:	9.55 #	53.93 #	19.29 #	62.85 #
Minimum:	9.55	53.93	19.29	62.85
Maximum:	9.55	53.93	19.29	62.85
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
09/09/2024 00:00	13.02	44.56	22.52	54.91
Average/Sum#:	13.02 #	44.56 #	22.52 #	54.91 #
Minimum:	13.02	44.56	22.52	54.91
Maximum:	13.02	44.56	22.52	54.91
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
09/10/2024 00:00	11.77	42.27	20.36	52.20
Average/Sum#:	11.77 #	42.27 #	20.36 #	52.20 #
Minimum:	11.77	42.27	20.36	52.20
Maximum:	11.77	42.27	20.36	52.20
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
09/11/2024 00:00	11.97	42.94	20.62	51.26
Average/Sum#:	11.97 #	42.94 #	20.62 #	51.26 #
Minimum:	11.97	42.94	20.62	51.26
Maximum:	11.97	42.94	20.62	51.26
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
09/12/2024 00:00	11.83	42.26	18.10	51.09

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	11.83 #	42.26 #	18.10 #	51.09 #
Minimum:	11.83	42.26	18.10	51.09
Maximum:	11.83	42.26	18.10	51.09
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
09/13/2024 00:00	10.89	46.88	16.77	56.52

Average/Sum#:	10.89 #	46.88 #	16.77 #	56.52 #
Minimum:	10.89	46.88	16.77	56.52
Maximum:	10.89	46.88	16.77	56.52
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
09/14/2024 00:00	10.65	43.20	17.06	53.46

Average/Sum#:	10.65 #	43.20 #	17.06 #	53.46 #
Minimum:	10.65	43.20	17.06	53.46
Maximum:	10.65	43.20	17.06	53.46
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
09/15/2024 00:00	10.51	42.44	15.78	52.30

Average/Sum#:	10.51 #	42.44 #	15.78 #	52.30 #
Minimum:	10.51	42.44	15.78	52.30
Maximum:	10.51	42.44	15.78	52.30
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
09/16/2024 00:00	11.16	45.64	18.12	53.93
Average/Sum#:	11.16 #	45.64 #	18.12 #	53.93 #
Minimum:	11.16	45.64	18.12	53.93
Maximum:	11.16	45.64	18.12	53.93
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
09/17/2024 00:00	10.62	42.95	16.54	52.82
Average/Sum#:	10.62 #	42.95 #	16.54 #	52.82 #
Minimum:	10.62	42.95	16.54	52.82
Maximum:	10.62	42.95	16.54	52.82
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
09/18/2024 00:00	11.03	43.58	17.06	54.27
Average/Sum#:	11.03 #	43.58 #	17.06 #	54.27 #
Minimum:	11.03	43.58	17.06	54.27
Maximum:	11.03	43.58	17.06	54.27
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
09/19/2024 00:00	12.02	49.06	18.21	58.05

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	12.02 #	49.06 #	18.21 #	58.05 #
Minimum:	12.02	49.06	18.21	58.05
Maximum:	12.02	49.06	18.21	58.05
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
09/20/2024 00:00	10.19	41.09	16.80	52.64

Average/Sum#:	10.19 #	41.09 #	16.80 #	52.64 #
Minimum:	10.19	41.09	16.80	52.64
Maximum:	10.19	41.09	16.80	52.64
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
09/21/2024 00:00	10.01	46.59	16.43	57.35

Average/Sum#:	10.01 #	46.59 #	16.43 #	57.35 #
Minimum:	10.01	46.59	16.43	57.35
Maximum:	10.01	46.59	16.43	57.35
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
09/22/2024 00:00	10.47	42.11	16.68	51.79

Average/Sum#:	10.47 #	42.11 #	16.68 #	51.79 #
Minimum:	10.47	42.11	16.68	51.79
Maximum:	10.47	42.11	16.68	51.79
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
09/23/2024 00:00	11.26	46.17	17.22	57.02
Average/Sum#:	11.26 #	46.17 #	17.22 #	57.02 #
Minimum:	11.26	46.17	17.22	57.02
Maximum:	11.26	46.17	17.22	57.02
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
09/24/2024 00:00	11.34	44.45	17.78	54.38
Average/Sum#:	11.34 #	44.45 #	17.78 #	54.38 #
Minimum:	11.34	44.45	17.78	54.38
Maximum:	11.34	44.45	17.78	54.38
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
09/25/2024 00:00	9.99	41.70	16.07	51.26
Average/Sum#:	9.99 #	41.70 #	16.07 #	51.26 #
Minimum:	9.99	41.70	16.07	51.26
Maximum:	9.99	41.70	16.07	51.26
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
09/26/2024 00:00	11.39	46.17	17.41	54.53

AQ32 DAILY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	11.39 #	46.17 #	17.41 #	54.53 #
Minimum:	11.39	46.17	17.41	54.53
Maximum:	11.39	46.17	17.41	54.53
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
09/27/2024 00:00	12.61	45.14	19.03	55.66
Average/Sum#:	12.61 #	45.14 #	19.03 #	55.66 #
Minimum:	12.61	45.14	19.03	55.66
Maximum:	12.61	45.14	19.03	55.66
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
09/28/2024 00:00	11.68	43.68	18.28	54.08
Average/Sum#:	11.68 #	43.68 #	18.28 #	54.08 #
Minimum:	11.68	43.68	18.28	54.08
Maximum:	11.68	43.68	18.28	54.08
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
09/29/2024 00:00	10.82	41.55	16.68	50.20
Average/Sum#:	10.82 #	41.55 #	16.68 #	50.20 #
Minimum:	10.82	41.55	16.68	50.20
Maximum:	10.82	41.55	16.68	50.20
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From:

07/01/2024 00:00

To:

09/30/2024 23:59

Facility Name:

ROSEVILLE ENERGY

Generated:

10/11/2024 08:05

Location:

Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
09/30/2024 00:00	10.02	51.41	16.19	61.14
Average/Sum#:	10.02 #	51.41 #	16.19 #	61.14 #
Minimum:	10.02	51.41	16.19	61.14
Maximum:	10.02	51.41	16.19	61.14
%SI	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT1	Unit CT2	Unit CT2	Unit CT2
	CO, Ppmvdc	O2, Dry, Pct	CO, Ppmvdc	NOx, Ppmvdc	O2, Dry, Pct
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2024 00:00	0.7	14.4	0.8	1.5	14.4
07/01/2024 01:00	0.8	14.4	0.8	1.5	14.4
07/01/2024 02:00	0.8	14.4	0.8	1.5	14.4
07/01/2024 03:00	0.9	14.3	0.9	1.5	14.3
07/01/2024 04:00	0.9	14.3	1.0	1.5	14.3
07/01/2024 05:00	1.0	14.3	1.0	1.5	14.3
07/01/2024 06:00	0.9	14.4	1.0	1.5	14.3
07/01/2024 07:00	0.8	14.4	0.9	1.5	14.4
07/01/2024 08:00	0.7	14.4	0.8	1.5	14.4
07/01/2024 09:00	0.7	14.5	0.8	1.5	14.4
07/01/2024 10:00	0.7	14.5	0.7	1.5	14.5
07/01/2024 11:00	0.7	14.5	0.8	1.5	14.5
07/01/2024 12:00	0.7	14.6	0.7	1.5	14.5
07/01/2024 13:00	0.7	14.6	0.7	1.5	14.5
07/01/2024 14:00	0.7	14.5	0.7	1.5	14.4
07/01/2024 15:00	0.7	14.4	0.7	1.5	14.3
07/01/2024 16:00	0.7	14.4	0.7	1.5	14.4
07/01/2024 17:00	0.7	14.5	0.7	1.5	14.4
07/01/2024 18:00	0.5	13.1	0.6	1.5	13.1
07/01/2024 19:00	0.3	11.7	0.3	1.5	11.9
07/01/2024 20:00	0.5	12.8	0.5	1.5	12.8
07/01/2024 21:00	0.9	14.4	0.9	1.4	14.4
07/01/2024 22:00	0.8	14.5	0.9	1.5	14.4
07/01/2024 23:00	0.9	14.5	1.0	1.5	14.4
Average/Sum#:	0.7	14.2	0.8	1.5	14.2
Minimum:	0.3	11.7	0.3	1.4	11.9
Maximum:	1.0	14.6	1.0	1.5	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/02/2024 00:00	0.9	14.4	1.0	1.5	14.4
07/02/2024 01:00	1.0	14.4	1.1	1.5	14.4
07/02/2024 02:00	0.9	14.4	0.9	1.5	14.4
07/02/2024 03:00	0.9	14.4	0.9	1.5	14.4
07/02/2024 04:00	0.8	14.4	0.9	1.5	14.4
07/02/2024 05:00	0.8	14.4	0.8	1.5	14.4
07/02/2024 06:00	0.8	14.3	0.8	1.5	14.3
07/02/2024 07:00	0.8	14.4	0.8	1.5	14.4
07/02/2024 08:00	0.7	14.5	0.8	1.5	14.5
07/02/2024 09:00	0.7	14.5	0.7	1.5	14.5
07/02/2024 10:00	0.7	14.5	0.7	1.5	14.5
07/02/2024 11:00	0.7	14.6	0.8	1.5	14.6
07/02/2024 12:00	0.7	14.5	0.7	1.5	14.4
07/02/2024 13:00	1.0	14.2	1.1	1.5	14.3
07/02/2024 14:00	0.3	12.7	0.3	1.5	12.7
07/02/2024 15:00	0.3	12.2	0.2	1.5	12.3
07/02/2024 16:00	0.2	12.0	0.1	1.5	12.1
07/02/2024 17:00	0.3	11.8	0.2	1.5	11.9
07/02/2024 18:00	0.3	11.8	0.2	1.5	12.0
07/02/2024 19:00	0.3	11.9	0.2	1.5	12.0
07/02/2024 20:00	0.3	12.0	0.2	1.5	12.1
07/02/2024 21:00	0.4	12.3	0.3	1.5	12.5
07/02/2024 22:00	0.9	14.4	0.9	1.4	14.4
07/02/2024 23:00	0.9	14.5	1.0	1.5	14.5
Average/Sum#:	0.7	13.6	0.7	1.5	13.7
Minimum:	0.2	11.8	0.1	1.4	11.9
Maximum:	1.0	14.6	1.1	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/03/2024 00:00	0.9	14.5	0.9	1.5	14.4
07/03/2024 01:00	1.1	14.4	1.1	1.5	14.4
07/03/2024 02:00	1.1	14.4	1.1	1.5	14.4
07/03/2024 03:00	1.1	14.4	1.1	1.5	14.4
07/03/2024 04:00	1.0	14.4	1.0	1.5	14.4
07/03/2024 05:00	0.9	14.4	1.0	1.5	14.4
07/03/2024 06:00	0.8	14.4	0.9	1.5	14.4
07/03/2024 07:00	0.8	14.5	0.8	1.5	14.4
07/03/2024 08:00	0.8	14.5	0.8	1.5	14.5
07/03/2024 09:00	0.7	14.5	0.8	1.5	14.5
07/03/2024 10:00	0.7	14.5	0.7	1.5	14.5
07/03/2024 11:00	0.7	14.6	0.7	1.5	14.6
07/03/2024 12:00	0.7	14.6	0.7	1.5	14.6
07/03/2024 13:00	0.7	14.6	0.7	1.5	14.6
07/03/2024 14:00	0.6	13.5	0.6	1.5	13.5
07/03/2024 15:00	0.4	12.8	0.3	1.5	12.8
07/03/2024 16:00	0.3	12.2	0.2	1.5	12.3
07/03/2024 17:00	0.2	11.9	0.2	1.5	12.0
07/03/2024 18:00	0.2	11.9	0.1	1.5	12.0
07/03/2024 19:00	0.2	11.9	0.2	1.5	12.0
07/03/2024 20:00	0.3	12.5	0.2	1.5	12.6
07/03/2024 21:00	0.9	14.2	0.8	1.4	14.2
07/03/2024 22:00	0.9	14.5	0.9	1.5	14.5
07/03/2024 23:00	0.9	14.5	0.8	1.5	14.5
Average/Sum#:	0.7	13.9	0.7	1.5	13.9
Minimum:	0.2	11.9	0.1	1.4	12.0
Maximum:	1.1	14.6	1.1	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/04/2024 00:00	0.9	14.5	0.8	1.5	14.4
07/04/2024 01:00	0.8	14.4	0.8	1.5	14.4
07/04/2024 02:00	0.8	14.4	0.8	1.5	14.4
07/04/2024 03:00	0.9	14.4	0.8	1.5	14.4
07/04/2024 04:00	0.8	14.4	0.8	1.5	14.4
07/04/2024 05:00	0.8	14.4	0.8	1.5	14.4
07/04/2024 06:00	0.8	14.4	0.8	1.5	14.4
07/04/2024 07:00	0.8	14.5	0.8	1.5	14.4
07/04/2024 08:00	0.7	14.5	0.7	1.5	14.5
07/04/2024 09:00	0.7	14.5	0.7	1.5	14.5
07/04/2024 10:00	0.7	14.6	0.7	1.5	14.5
07/04/2024 11:00	0.7	14.6	0.7	1.5	14.6
07/04/2024 12:00	0.7	14.6	0.7	1.5	14.6
07/04/2024 13:00	0.7	14.6	0.7	1.5	14.6
07/04/2024 14:00	0.7	14.6	0.7	1.5	14.6
07/04/2024 15:00	0.7	14.6	0.7	1.5	14.6
07/04/2024 16:00	0.7	14.6	0.7	1.5	14.5
07/04/2024 17:00	0.7	14.4	0.7	1.4	14.4
07/04/2024 18:00	0.7	14.5	0.7	1.5	14.5
07/04/2024 19:00	0.7	14.5	0.7	1.5	14.5
07/04/2024 20:00	0.7	14.5	0.7	1.5	14.5
07/04/2024 21:00	0.8	14.5	0.7	1.5	14.5
07/04/2024 22:00	0.8	14.5	0.8	1.5	14.5
07/04/2024 23:00	0.8	14.5	0.7	1.5	14.5
Average/Sum#:	0.8	14.5	0.7	1.5	14.5
Minimum:	0.7	14.4	0.7	1.4	14.4
Maximum:	0.9	14.6	0.8	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/05/2024 00:00	0.7	14.6	0.7	1.5	14.6
07/05/2024 01:00	0.7	14.6	0.7	1.5	14.6
07/05/2024 02:00	0.7	14.6	0.7	1.5	14.6
07/05/2024 03:00	0.8	14.4	0.8	1.5	14.4
07/05/2024 04:00	0.8	14.4	0.8	1.5	14.4
07/05/2024 05:00	0.8	14.4	0.8	1.5	14.4
07/05/2024 06:00	0.8	14.4	0.8	1.5	14.4
07/05/2024 07:00	0.8	14.5	0.8	1.5	14.4
07/05/2024 08:00	0.7	14.5	0.7	1.5	14.5
07/05/2024 09:00	0.7	14.5	0.7	1.5	14.5
07/05/2024 10:00	0.7	14.5	0.8	1.5	14.5
07/05/2024 11:00	0.7	14.6	0.7	1.5	14.5
07/05/2024 12:00	0.7	14.6	0.7	1.5	14.5
07/05/2024 13:00	0.7	14.6	0.7	1.5	14.6
07/05/2024 14:00	0.7	14.6	0.7	1.4	14.6
07/05/2024 15:00	0.7	14.6	0.7	1.5	14.6
07/05/2024 16:00	0.8	14.6	0.7	1.5	14.5
07/05/2024 17:00	1.0	14.2	0.9	1.5	14.2
07/05/2024 18:00	0.3	12.2	0.2	1.5	12.3
07/05/2024 19:00	0.5	13.2	0.5	1.5	13.3
07/05/2024 20:00	0.8	14.1	0.7	1.4	14.1
07/05/2024 21:00	0.8	14.5	0.7	1.5	14.5
07/05/2024 22:00	0.8	14.5	0.7	1.5	14.5
07/05/2024 23:00	0.8	14.5	0.8	1.5	14.5
Average/Sum#:	0.7	14.3	0.7	1.5	14.3
Minimum:	0.3	12.2	0.2	1.4	12.3
Maximum:	1.0	14.6	0.9	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/06/2024 00:00	0.8	14.5	0.8	1.5	14.4
07/06/2024 01:00	0.8	14.5	0.8	1.5	14.4
07/06/2024 02:00	0.8	14.5	0.8	1.5	14.4
07/06/2024 03:00	0.9	14.4	0.8	1.5	14.4
07/06/2024 04:00	0.8	14.4	0.8	1.5	14.4
07/06/2024 05:00	0.8	14.4	0.8	1.5	14.4
07/06/2024 06:00	0.8	14.4	0.8	1.5	14.4
07/06/2024 07:00	0.8	14.5	0.8	1.5	14.4
07/06/2024 08:00	0.7	14.5	0.7	1.5	14.5
07/06/2024 09:00	0.7	14.5	0.7	1.5	14.5
07/06/2024 10:00	0.7	14.6	0.7	1.5	14.5
07/06/2024 11:00	0.7	14.6	0.7	1.4	14.6
07/06/2024 12:00	0.7	14.4	0.7	1.4	14.3
07/06/2024 13:00	0.7	14.4	0.7	1.5	14.3
07/06/2024 14:00	0.7	14.5	0.7	1.5	14.4
07/06/2024 15:00	0.7	14.4	0.7	1.5	14.4
07/06/2024 16:00	0.7	14.5	0.7	1.5	14.4
07/06/2024 17:00	0.6	13.8	0.6	1.5	13.8
07/06/2024 18:00	0.2	12.2	0.2	1.5	12.3
07/06/2024 19:00	0.3	12.7	0.3	1.5	12.8
07/06/2024 20:00	0.7	13.6	0.7	1.5	13.6
07/06/2024 21:00	0.7	14.5	0.7	1.5	14.5
07/06/2024 22:00	0.8	14.5	0.7	1.5	14.5
07/06/2024 23:00	0.8	14.4	0.8	1.5	14.4
Average/Sum#:	0.7	14.2	0.7	1.5	14.2
Minimum:	0.2	12.2	0.2	1.4	12.3
Maximum:	0.9	14.6	0.8	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/07/2024 00:00	0.8	14.5	0.7	1.5	14.5
07/07/2024 01:00	0.8	14.5	0.8	1.5	14.5
07/07/2024 02:00	0.8	14.5	0.7	1.5	14.4
07/07/2024 03:00	0.8	14.5	0.8	1.5	14.4
07/07/2024 04:00	0.8	14.4	0.7	1.5	14.4
07/07/2024 05:00	0.7	14.4	0.7	1.5	14.4
07/07/2024 06:00	0.7	14.4	0.7	1.5	14.4
07/07/2024 07:00	0.7	14.5	0.7	1.5	14.4
07/07/2024 08:00	0.7	14.5	0.7	1.5	14.5
07/07/2024 09:00	0.7	14.5	0.7	1.5	14.5
07/07/2024 10:00	0.7	14.6	0.7	1.5	14.5
07/07/2024 11:00	0.7	14.6	0.7	1.4	14.5
07/07/2024 12:00	0.7	14.5	0.7	1.5	14.4
07/07/2024 13:00	0.7	14.5	0.7	1.5	14.4
07/07/2024 14:00	0.7	14.5	0.7	1.5	14.5
07/07/2024 15:00	1.0	14.4	0.9	1.5	14.4
07/07/2024 16:00	0.3	12.2	0.2	1.5	12.3
07/07/2024 17:00	0.2	12.0	0.1	1.5	12.1
07/07/2024 18:00	0.2	12.1	0.1	1.5	12.2
07/07/2024 19:00	0.2	12.2	0.1	1.5	12.3
07/07/2024 20:00	0.2	12.3	0.2	1.5	12.4
07/07/2024 21:00	0.7	13.8	0.7	1.4	13.9
07/07/2024 22:00	0.7	14.4	0.7	1.5	14.4
07/07/2024 23:00	0.7	14.4	0.7	1.5	14.4
Average/Sum#:	0.6	14.0	0.6	1.5	14.0
Minimum:	0.2	12.0	0.1	1.4	12.1
Maximum:	1.0	14.6	0.9	1.5	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/08/2024 00:00	0.7	14.4	0.7	1.5	14.4
07/08/2024 01:00	0.7	14.4	0.7	1.5	14.4
07/08/2024 02:00	0.7	14.4	0.7	1.5	14.4
07/08/2024 03:00	0.8	14.4	0.7	1.5	14.4
07/08/2024 04:00	0.8	14.4	0.8	1.5	14.4
07/08/2024 05:00	0.8	14.4	0.8	1.5	14.4
07/08/2024 06:00	0.8	14.4	0.8	1.5	14.4
07/08/2024 07:00	0.7	14.4	0.8	1.5	14.4
07/08/2024 08:00	0.7	14.4	0.7	1.5	14.4
07/08/2024 09:00	0.7	14.5	0.7	1.5	14.4
07/08/2024 10:00	0.7	14.5	0.7	1.5	14.5
07/08/2024 11:00	0.7	14.5	0.7	1.5	14.5
07/08/2024 12:00	0.7	14.4	0.7	1.4	14.3
07/08/2024 13:00	0.7	14.4	0.7	1.4	14.4
07/08/2024 14:00	0.7	14.6	0.7	1.5	14.6
07/08/2024 15:00	0.7	14.5	0.7	1.5	14.4
07/08/2024 16:00	0.6	13.8	0.6	1.5	13.8
07/08/2024 17:00	0.2	12.0	0.1	1.5	12.1
07/08/2024 18:00	0.2	11.9	0.1	1.5	12.1
07/08/2024 19:00	0.2	12.2	0.1	1.5	12.4
07/08/2024 20:00	0.2	12.3	0.2	1.5	12.4
07/08/2024 21:00	0.3	12.6	0.3	1.5	12.7
07/08/2024 22:00	0.3	12.7	0.3	1.5	12.7
07/08/2024 23:00	0.5	13.1	0.5	1.5	13.1
Average/Sum#:	0.6	13.8	0.6	1.5	13.8
Minimum:	0.2	11.9	0.1	1.4	12.1
Maximum:	0.8	14.6	0.8	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/09/2024 00:00	0.9	14.0	0.8	1.5	14.0
07/09/2024 01:00	0.8	14.4	0.8	1.5	14.3
07/09/2024 02:00	0.8	14.4	0.8	1.5	14.3
07/09/2024 03:00	0.9	14.4	0.8	1.5	14.3
07/09/2024 04:00	0.8	14.4	0.8	1.5	14.3
07/09/2024 05:00	0.7	14.3	0.8	1.5	14.3
07/09/2024 06:00	0.8	14.3	0.7	1.5	14.3
07/09/2024 07:00	0.7	14.4	0.8	1.5	14.3
07/09/2024 08:00	0.7	14.4	0.7	1.5	14.4
07/09/2024 09:00	0.7	14.4	0.7	1.5	14.4
07/09/2024 10:00	0.7	14.4	0.7	1.5	14.4
07/09/2024 11:00	0.7	14.5	0.7	1.5	14.4
07/09/2024 12:00	0.7	14.5	0.7	1.5	14.5
07/09/2024 13:00	0.6	14.5	0.6	1.5	14.5
07/09/2024 14:00	0.7	14.5	0.6	1.5	14.5
07/09/2024 15:00	0.8	14.3	0.7	1.5	14.2
07/09/2024 16:00	0.3	12.4	0.2	1.6	12.5
07/09/2024 17:00	0.2	12.2	0.1	1.5	12.3
07/09/2024 18:00	0.2	12.0	0.1	1.5	12.1
07/09/2024 19:00	0.2	12.3	0.1	1.5	12.4
07/09/2024 20:00	0.2	12.5	0.2	1.5	12.6
07/09/2024 21:00	0.2	12.5	0.2	1.5	12.6
07/09/2024 22:00	0.3	12.6	0.2	1.5	12.7
07/09/2024 23:00	0.9	13.8	0.8	1.5	13.8
Average/Sum#:	0.6	13.8	0.6	1.5	13.8
Minimum:	0.2	12.0	0.1	1.5	12.1
Maximum:	0.9	14.5	0.8	1.6	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/10/2024 00:00	0.7	14.5	0.6	1.5	14.5
07/10/2024 01:00	0.7	14.5	0.7	1.5	14.5
07/10/2024 02:00	0.7	14.5	0.7	1.4	14.5
07/10/2024 03:00	0.8	14.5	0.7	1.5	14.4
07/10/2024 04:00	0.7	14.5	0.7	1.5	14.4
07/10/2024 05:00	0.7	14.4	0.7	1.5	14.4
07/10/2024 06:00	0.8	14.3	0.8	1.5	14.3
07/10/2024 07:00	0.8	14.3	0.8	1.5	14.3
07/10/2024 08:00	0.8	14.3	0.8	1.5	14.3
07/10/2024 09:00	0.8	14.5	0.7	1.5	14.4
07/10/2024 10:00	0.7	14.5	0.7	1.5	14.5
07/10/2024 11:00	0.7	14.5	0.7	1.5	14.5
07/10/2024 12:00	0.7	14.6	0.7	1.4	14.5
07/10/2024 13:00	0.7	14.6	0.7	1.5	14.5
07/10/2024 14:00	0.7	14.6	0.7	1.5	14.5
07/10/2024 15:00	0.7	14.5	0.7	1.5	14.5
07/10/2024 16:00	0.7	14.5	0.7	1.5	14.5
07/10/2024 17:00	0.4	12.6	0.4	1.5	12.6
07/10/2024 18:00	0.2	11.9	0.1	1.5	12.1
07/10/2024 19:00	0.2	12.0	0.1	1.5	12.2
07/10/2024 20:00	0.3	12.4	0.2	1.5	12.5
07/10/2024 21:00	0.5	13.1	0.5	1.5	13.1
07/10/2024 22:00	0.8	13.7	0.7	1.5	13.7
07/10/2024 23:00	0.9	14.4	0.8	1.4	14.4
Average/Sum#:	0.7	14.0	0.6	1.5	14.0
Minimum:	0.2	11.9	0.1	1.4	12.1
Maximum:	0.9	14.6	0.8	1.5	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/11/2024 00:00	0.9	14.3	0.8	1.5	14.3
07/11/2024 01:00	0.8	14.3	0.8	1.5	14.3
07/11/2024 02:00	0.8	14.3	0.7	1.5	14.3
07/11/2024 03:00	0.9	14.3	0.8	1.5	14.3
07/11/2024 04:00	0.8	14.3	0.8	1.5	14.3
07/11/2024 05:00	0.9	14.3	0.8	1.5	14.3
07/11/2024 06:00	1.0	14.3	0.9	1.5	14.3
07/11/2024 07:00	0.8	14.3	0.8	1.5	14.3
07/11/2024 08:00	0.8	14.3	0.8	1.5	14.3
07/11/2024 09:00	0.8	14.4	0.8	1.5	14.3
07/11/2024 10:00	0.8	14.4	0.8	1.5	14.3
07/11/2024 11:00	0.7	14.6	0.7	1.5	14.6
07/11/2024 12:00	0.7	14.5	0.7	1.5	14.5
07/11/2024 13:00	0.7	14.6	0.7	1.5	14.5
07/11/2024 14:00	0.4	12.5	0.4	1.5	12.6
07/11/2024 15:00	0.1	12.1	0.2	1.5	12.2
07/11/2024 16:00	0.1	12.2	0.1	1.5	12.3
07/11/2024 17:00	0.1	12.1	0.1	1.5	12.2
07/11/2024 18:00	0.1	12.1	0.1	1.5	12.2
07/11/2024 19:00	0.1	12.1	0.1	1.5	12.2
07/11/2024 20:00	0.2	12.1	0.2	1.5	12.3
07/11/2024 21:00	0.2	12.1	0.1	1.5	12.3
07/11/2024 22:00	0.5	13.2	0.5	1.4	13.2
07/11/2024 23:00	0.8	14.5	0.7	1.5	14.5
Average/Sum#:	0.6	13.6	0.6	1.5	13.6
Minimum:	0.1	12.1	0.1	1.4	12.2
Maximum:	1.0	14.6	0.9	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/12/2024 00:00	0.8	14.4	0.7	1.4	14.3
07/12/2024 01:00	0.8	14.3	0.8	1.4	14.3
07/12/2024 02:00	0.8	14.3	0.7	1.5	14.3
07/12/2024 03:00	0.9	14.3	0.8	1.5	14.3
07/12/2024 04:00	0.8	14.3	0.8	1.5	14.3
07/12/2024 05:00	0.8	14.3	0.8	1.5	14.3
07/12/2024 06:00	0.8	14.4	0.8	1.5	14.4
07/12/2024 07:00	0.8	14.3	0.8	1.5	14.3
07/12/2024 08:00	0.8	14.4	0.7	1.5	14.3
07/12/2024 09:00	0.7	14.4	0.7	1.5	14.3
07/12/2024 10:00	0.7	14.4	0.7	1.5	14.3
07/12/2024 11:00	0.7	14.5	0.7	1.5	14.5
07/12/2024 12:00	0.7	14.6	0.7	1.5	14.5
07/12/2024 13:00	0.7	14.6	0.6	1.5	14.6
07/12/2024 14:00	0.7	13.9	0.6	1.6	13.9
07/12/2024 15:00	0.6	13.4	0.6	1.5	13.4
07/12/2024 16:00	0.4	13.0	0.4	1.5	13.1
07/12/2024 17:00	0.2	11.9	0.1	1.5	12.0
07/12/2024 18:00	0.2	11.9	0.1	1.5	12.1
07/12/2024 19:00	0.2	12.4	0.2	1.5	12.5
07/12/2024 20:00	0.3	12.7	0.3	1.5	12.8
07/12/2024 21:00	0.7	14.2	0.6	1.4	14.2
07/12/2024 22:00	0.7	14.5	0.6	1.5	14.5
07/12/2024 23:00	0.8	14.4	0.8	1.5	14.3
Average/Sum#:	0.7	13.9	0.6	1.5	13.9
Minimum:	0.2	11.9	0.1	1.4	12.0
Maximum:	0.9	14.6	0.8	1.6	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/13/2024 00:00	0.8	14.3	0.7	1.5	14.3
07/13/2024 01:00	0.8	14.4	0.7	1.5	14.3
07/13/2024 02:00	0.7	14.5	0.7	1.5	14.4
07/13/2024 03:00	0.8	14.5	0.8	1.5	14.4
07/13/2024 04:00	0.7	14.5	0.7	1.5	14.4
07/13/2024 05:00	0.8	14.5	0.7	1.5	14.4
07/13/2024 06:00	0.8	14.5	0.7	1.5	14.4
07/13/2024 07:00	0.7	14.5	0.7	1.5	14.4
07/13/2024 08:00	0.6	13.8	0.7	1.5	13.9
07/13/2024 09:00	0.8	14.4	0.7	1.4	14.4
07/13/2024 10:00	0.7	14.5	0.7	1.5	14.4
07/13/2024 11:00	0.8	14.5	0.7	1.5	14.5
07/13/2024 12:00	0.7	14.6	0.7	1.5	14.5
07/13/2024 13:00	0.7	14.6	0.7	1.5	14.5
07/13/2024 14:00	0.7	14.6	0.7	1.5	14.5
07/13/2024 15:00	0.7	14.6	0.7	1.5	14.6
07/13/2024 16:00	0.7	14.5	0.7	1.6	14.5
07/13/2024 17:00	0.9	14.5	0.9	1.4	14.5
07/13/2024 18:00	0.7	14.5	0.7	1.5	14.4
07/13/2024 19:00	0.7	14.4	0.7	1.5	14.3
07/13/2024 20:00	0.7	14.4	0.7	1.5	14.3
07/13/2024 21:00	0.7	14.4	0.7	1.5	14.3
07/13/2024 22:00	0.7	14.4	0.7	1.5	14.4
07/13/2024 23:00	0.7	14.5	0.7	1.5	14.5
Average/Sum#:	0.7	14.5	0.7	1.5	14.4
Minimum:	0.6	13.8	0.7	1.4	13.9
Maximum:	0.9	14.6	0.9	1.6	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/14/2024 00:00	0.7	14.5	0.7	1.5	14.5
07/14/2024 01:00	0.7	14.5	0.7	1.5	14.4
07/14/2024 02:00	0.7	14.4	0.7	1.5	14.4
07/14/2024 03:00	0.8	14.4	0.7	1.5	14.4
07/14/2024 04:00	0.7	14.4	0.7	1.5	14.4
07/14/2024 05:00	0.7	14.4	0.7	1.5	14.4
07/14/2024 06:00	0.7	14.4	0.7	1.5	14.4
07/14/2024 07:00	0.7	14.4	0.7	1.5	14.4
07/14/2024 08:00	0.7	14.4	0.7	1.5	14.4
07/14/2024 09:00	0.7	14.4	0.7	1.5	14.4
07/14/2024 10:00	0.7	14.4	0.7	1.5	14.4
07/14/2024 11:00	0.7	14.5	0.7	1.5	14.5
07/14/2024 12:00	0.7	14.5	0.7	1.5	14.5
07/14/2024 13:00	0.7	14.5	0.7	1.5	14.5
07/14/2024 14:00	0.7	14.6	0.7	1.5	14.5
07/14/2024 15:00	0.7	14.5	0.7	1.5	14.5
07/14/2024 16:00	0.7	14.5	0.7	1.5	14.4
07/14/2024 17:00	0.7	14.5	0.7	1.5	14.4
07/14/2024 18:00	0.7	14.5	0.7	1.6	14.5
07/14/2024 19:00	0.8	14.4	0.9	1.5	14.4
07/14/2024 20:00	0.7	14.4	0.7	1.5	14.4
07/14/2024 21:00	0.7	14.4	0.7	1.5	14.4
07/14/2024 22:00	0.7	14.3	0.7	1.5	14.3
07/14/2024 23:00	0.7	14.4	0.7	1.5	14.4
Average/Sum#:	0.7	14.4	0.7	1.5	14.4
Minimum:	0.7	14.3	0.7	1.5	14.3
Maximum:	0.8	14.6	0.9	1.6	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/15/2024 00:00	0.7	14.4	0.7	1.5	14.4
07/15/2024 01:00	0.7	14.4	0.7	1.5	14.4
07/15/2024 02:00	0.7	14.4	0.8	1.5	14.4
07/15/2024 03:00	0.8	14.5	0.7	1.5	14.4
07/15/2024 04:00	0.7	14.4	0.7	1.5	14.3
07/15/2024 05:00	0.7	14.4	0.7	1.5	14.3
07/15/2024 06:00	0.7	14.4	0.7	1.5	14.3
07/15/2024 07:00	0.7	14.4	0.7	1.5	14.4
07/15/2024 08:00	0.7	14.4	0.7	1.5	14.4
07/15/2024 09:00	0.7	14.4	0.7	1.5	14.4
07/15/2024 10:00	0.7	14.5	0.7	1.5	14.4
07/15/2024 11:00	0.7	14.5	0.7	1.5	14.5
07/15/2024 12:00	0.6	14.5	0.7	1.5	14.5
07/15/2024 13:00	0.6	14.5	0.7	1.5	14.5
07/15/2024 14:00	0.6	14.5	0.7	1.5	14.5
07/15/2024 15:00	0.7	14.6	0.7	1.5	14.6
07/15/2024 16:00	0.7	14.5	0.7	1.5	14.5
07/15/2024 17:00	0.7	14.5	0.7	1.5	14.5
07/15/2024 18:00	0.6	14.5	0.7	1.5	14.5
07/15/2024 19:00	0.7	14.3	0.7	1.4	14.3
07/15/2024 20:00	0.7	14.4	0.7	1.5	14.4
07/15/2024 21:00	0.7	14.4	0.7	1.5	14.4
07/15/2024 22:00	0.7	14.4	0.7	1.5	14.4
07/15/2024 23:00	0.7	14.4	0.7	1.5	14.4
Average/Sum#:	0.7	14.4	0.7	1.5	14.4
Minimum:	0.6	14.3	0.7	1.4	14.3
Maximum:	0.8	14.6	0.8	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/16/2024 00:00	0.7	14.4	0.7	1.5	14.4
07/16/2024 01:00	0.7	14.4	0.7	1.5	14.4
07/16/2024 02:00	0.7	14.4	0.7	1.5	14.4
07/16/2024 03:00	0.8	14.3	0.8	1.5	14.4
07/16/2024 04:00	0.7	14.4	0.7	1.5	14.4
07/16/2024 05:00	0.7	14.5	0.7	1.5	14.4
07/16/2024 06:00	0.8	14.4	0.8	1.5	14.3
07/16/2024 07:00	0.8	14.4	0.8	1.5	14.3
07/16/2024 08:00	0.8	14.4	0.8	1.5	14.4
07/16/2024 09:00	0.7	14.4	0.7	1.5	14.4
07/16/2024 10:00	0.7	14.4	0.7	1.5	14.4
07/16/2024 11:00	0.7	14.5	0.7	1.5	14.5
07/16/2024 12:00	0.0	0.0	0.7	1.5	14.5
07/16/2024 13:00	0.0	0.0	0.7	1.5	14.5
07/16/2024 14:00	0.7	14.6	0.7	1.5	14.5
07/16/2024 15:00	0.7	14.5	0.7	1.4	14.4
07/16/2024 16:00	0.7	14.5	0.7	1.5	14.5
07/16/2024 17:00	0.8	14.3	0.8	1.5	14.2
07/16/2024 18:00	0.7	13.6	0.8	1.5	13.7
07/16/2024 19:00	1.0	13.8	0.9	1.5	13.8
07/16/2024 20:00	0.9	13.6	0.7	1.5	13.7
07/16/2024 21:00	1.0	14.3	0.6	1.5	14.4
07/16/2024 22:00	0.7	14.4	0.7	1.5	14.3
07/16/2024 23:00	0.8	14.4	0.8	1.5	14.3
Average/Sum#:	0.8	14.3	0.7	1.5	14.3
Minimum:	0.7	13.6	0.6	1.4	13.7
Maximum:	1.0	14.6	0.9	1.5	14.5
%SI	8.33	8.33	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/17/2024 00:00	0.8	14.3	0.8	1.5	14.3
07/17/2024 01:00	0.8	14.3	0.8	1.5	14.3
07/17/2024 02:00	0.8	14.3	0.8	1.5	14.3
07/17/2024 03:00	0.9	14.3	0.8	1.5	14.3
07/17/2024 04:00	0.8	14.3	0.8	1.5	14.3
07/17/2024 05:00	0.7	14.4	0.7	1.5	14.4
07/17/2024 06:00	0.8	14.3	0.8	1.5	14.3
07/17/2024 07:00	0.8	14.3	0.8	1.5	14.3
07/17/2024 08:00	0.8	14.3	0.7	1.5	14.3
07/17/2024 09:00	0.8	14.4	0.8	1.5	14.4
07/17/2024 10:00	0.7	14.4	0.7	1.5	14.4
07/17/2024 11:00	0.7	14.4	0.7	1.5	14.4
07/17/2024 12:00	0.7	14.5	0.7	1.5	14.5
07/17/2024 13:00	0.7	14.5	0.7	1.5	14.5
07/17/2024 14:00	0.7	14.6	0.7	1.5	14.5
07/17/2024 15:00	0.7	14.6	0.7	1.5	14.5
07/17/2024 16:00	0.7	14.6	0.7	1.5	14.5
07/17/2024 17:00	0.7	14.6	0.7	1.5	14.5
07/17/2024 18:00	0.7	14.5	0.7	1.5	14.5
07/17/2024 19:00	0.7	14.6	0.6	1.5	14.5
07/17/2024 20:00	0.7	14.5	0.7	1.5	14.5
07/17/2024 21:00	0.7	14.6	0.6	1.5	14.5
07/17/2024 22:00	0.7	14.4	0.7	1.5	14.4
07/17/2024 23:00	0.8	14.4	0.8	1.5	14.3
Average/Sum#:	0.7	14.4	0.7	1.5	14.4
Minimum:	0.7	14.3	0.6	1.5	14.3
Maximum:	0.9	14.6	0.8	1.5	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/18/2024 00:00	0.8	14.4	0.7	1.5	14.4
07/18/2024 01:00	0.8	14.4	0.0	0.0	0.0
07/18/2024 02:00	0.8	14.4	0.7	1.5	14.4
07/18/2024 03:00	0.9	14.4	0.0	1.5	0.0
07/18/2024 04:00	0.8	14.4	0.9	1.7	14.3
07/18/2024 05:00	0.8	14.3	0.8	1.6	14.4
07/18/2024 06:00	0.9	14.4	0.9	1.5	14.3
07/18/2024 07:00	0.8	14.4	0.8	1.5	14.4
07/18/2024 08:00	0.9	14.4	0.9	1.5	14.4
07/18/2024 09:00	0.8	14.5	0.8	1.5	14.5
07/18/2024 10:00	0.8	14.5	0.7	1.5	14.5
07/18/2024 11:00	0.7	14.6	0.7	1.5	14.5
07/18/2024 12:00	0.7	14.5	0.7	1.5	14.4
07/18/2024 13:00	0.7	14.5	0.7	1.5	14.4
07/18/2024 14:00	0.7	14.6	0.6	1.5	14.5
07/18/2024 15:00	0.7	14.6	0.6	1.5	14.9
07/18/2024 16:00	0.7	14.3	0.0	0.0	0.0
07/18/2024 17:00	0.3	11.8	0.0	0.0	0.0
07/18/2024 18:00	0.3	11.7	0.0	0.0	0.0
07/18/2024 19:00	0.3	11.7	0.0	0.0	0.0
07/18/2024 20:00	0.3	11.8	0.0	0.0	0.0
07/18/2024 21:00	0.5	13.0	0.0	0.0	0.0
07/18/2024 22:00	0.6	13.3	0.0	0.0	0.0
07/18/2024 23:00	0.7	13.4	0.0	0.0	0.0
Average/Sum#:	0.7	13.8	0.8	1.5	14.5
Minimum:	0.3	11.7	0.6	1.5	14.3
Maximum:	0.9	14.6	0.9	1.7	14.9
%SI	0.00	0.00	41.67	41.67	41.67

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/19/2024 00:00	0.8	13.5	0.0	0.0	0.0
07/19/2024 01:00	0.9	13.6	0.0	0.0	0.0
07/19/2024 02:00	0.9	13.6	0.0	0.0	0.0
07/19/2024 03:00	1.0	13.7	0.0	0.0	0.0
07/19/2024 04:00	1.0	13.6	0.0	0.0	0.0
07/19/2024 05:00	0.8	13.5	0.0	0.0	0.0
07/19/2024 06:00	1.1	13.7	0.0	0.0	0.0
07/19/2024 07:00	1.2	13.8	0.0	0.0	0.0
07/19/2024 08:00	0.9	14.4	0.0	0.0	0.0
07/19/2024 09:00	0.8	14.5	0.0	0.0	0.0
07/19/2024 10:00	0.8	14.6	0.0	0.0	0.0
07/19/2024 11:00	0.8	14.6	0.0	0.0	0.0
07/19/2024 12:00	0.6	13.2	0.0	0.0	0.0
07/19/2024 13:00	0.5	13.1	0.0	0.0	0.0
07/19/2024 14:00	0.3	12.3	0.0	0.0	0.0
07/19/2024 15:00	0.3	11.8	0.0	0.0	0.0
07/19/2024 16:00	0.3	11.7	0.0	0.0	0.0
07/19/2024 17:00	0.3	11.8	0.0	0.0	0.0
07/19/2024 18:00	0.3	11.7	0.0	0.0	0.0
07/19/2024 19:00	0.3	11.8	0.0	0.0	0.0
07/19/2024 20:00	0.3	12.6	0.0	0.0	0.0
07/19/2024 21:00	0.3	12.4	0.0	0.0	0.0
07/19/2024 22:00	0.3	12.2	0.0	0.0	0.0
07/19/2024 23:00	0.3	12.6	0.0	0.0	0.0
Average/Sum#:	0.6	13.1	0.0	0.0	0.0
Minimum:	0.3	11.7	0.0	0.0	0.0
Maximum:	1.2	14.6	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/20/2024 00:00	0.5	13.1	0.0	0.0	0.0
07/20/2024 01:00	0.8	13.5	0.0	0.0	0.0
07/20/2024 02:00	0.8	13.5	0.0	0.0	0.0
07/20/2024 03:00	0.8	13.4	0.0	0.0	0.0
07/20/2024 04:00	0.9	13.6	0.0	0.0	0.0
07/20/2024 05:00	1.0	13.6	0.0	0.0	0.0
07/20/2024 06:00	1.0	13.7	0.0	0.0	0.0
07/20/2024 07:00	0.8	14.5	0.0	0.0	16.7
07/20/2024 08:00	0.8	14.4	0.8	1.6	14.5
07/20/2024 09:00	0.7	14.4	0.7	1.5	14.5
07/20/2024 10:00	0.7	14.4	0.7	1.5	14.5
07/20/2024 11:00	0.9	14.4	0.8	1.5	14.5
07/20/2024 12:00	0.7	14.5	0.7	1.5	14.6
07/20/2024 13:00	0.7	14.6	0.7	1.5	14.6
07/20/2024 14:00	0.7	14.4	0.6	1.5	14.2
07/20/2024 15:00	0.6	13.4	0.5	1.5	13.4
07/20/2024 16:00	0.5	13.3	0.5	1.5	13.4
07/20/2024 17:00	0.3	12.7	0.3	1.5	12.8
07/20/2024 18:00	0.2	12.3	0.1	1.5	12.4
07/20/2024 19:00	0.2	12.4	0.1	1.5	12.5
07/20/2024 20:00	0.2	12.4	0.2	1.5	12.5
07/20/2024 21:00	0.2	12.5	0.2	1.5	12.6
07/20/2024 22:00	0.3	12.6	0.2	1.5	12.7
07/20/2024 23:00	0.4	12.7	0.3	1.5	12.8
Average/Sum#:	0.6	13.5	0.4	1.4	13.7
Minimum:	0.2	12.3	0.0	0.0	12.4
Maximum:	1.0	14.6	0.8	1.6	16.7
%SI	0.00	0.00	29.17	29.17	29.17

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/21/2024 00:00	1.0	14.0	0.9	1.5	14.0
07/21/2024 01:00	0.7	14.4	0.7	1.5	14.4
07/21/2024 02:00	0.7	14.4	0.7	1.5	14.4
07/21/2024 03:00	0.8	14.4	0.7	1.5	14.4
07/21/2024 04:00	0.7	14.4	0.7	1.5	14.4
07/21/2024 05:00	0.7	14.4	0.7	1.5	14.4
07/21/2024 06:00	0.0	0.0	0.7	1.5	14.4
07/21/2024 07:00	0.7	14.4	0.7	1.5	14.4
07/21/2024 08:00	0.7	14.4	0.7	1.5	14.4
07/21/2024 09:00	0.7	14.5	0.7	1.5	14.4
07/21/2024 10:00	0.7	14.5	0.7	1.5	14.4
07/21/2024 11:00	0.7	14.5	0.7	1.5	14.4
07/21/2024 12:00	0.7	14.5	0.7	1.5	14.5
07/21/2024 13:00	0.7	14.5	0.7	1.5	14.5
07/21/2024 14:00	0.7	14.6	0.7	1.5	14.5
07/21/2024 15:00	0.7	14.6	0.7	1.5	14.5
07/21/2024 16:00	0.7	14.6	0.7	1.5	14.5
07/21/2024 17:00	0.7	14.6	0.7	1.5	14.5
07/21/2024 18:00	0.7	14.6	0.6	1.5	14.5
07/21/2024 19:00	0.7	14.5	0.7	1.5	14.5
07/21/2024 20:00	0.7	14.6	0.7	1.5	14.5
07/21/2024 21:00	0.7	14.5	0.7	1.5	14.5
07/21/2024 22:00	0.8	14.4	0.7	1.5	14.4
07/21/2024 23:00	0.7	14.5	0.7	1.5	14.5
Average/Sum#:	0.7	14.5	0.7	1.5	14.4
Minimum:	0.7	14.0	0.6	1.5	14.0
Maximum:	1.0	14.6	0.9	1.5	14.5
%SI	4.17	4.17	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/22/2024 00:00	0.8	14.4	0.7	1.5	14.4
07/22/2024 01:00	0.8	14.4	0.8	1.5	14.4
07/22/2024 02:00	0.7	14.6	0.7	1.6	14.5
07/22/2024 03:00	0.8	14.5	0.7	1.5	14.5
07/22/2024 04:00	0.7	14.5	0.7	1.5	14.5
07/22/2024 05:00	0.7	14.4	0.7	1.5	14.4
07/22/2024 06:00	0.8	14.4	0.8	1.5	14.3
07/22/2024 07:00	0.7	14.4	0.7	1.5	14.4
07/22/2024 08:00	0.7	14.4	0.7	1.5	14.4
07/22/2024 09:00	0.7	14.5	0.7	1.5	14.4
07/22/2024 10:00	0.7	14.5	0.7	1.5	14.5
07/22/2024 11:00	0.7	14.6	0.7	1.5	14.6
07/22/2024 12:00	0.7	14.6	0.7	1.5	14.6
07/22/2024 13:00	0.7	14.6	0.7	1.5	14.6
07/22/2024 14:00	0.7	14.6	0.7	1.5	14.6
07/22/2024 15:00	0.4	12.5	0.1	1.6	12.2
07/22/2024 16:00	0.2	12.1	0.1	1.5	12.3
07/22/2024 17:00	0.2	12.1	0.1	1.5	12.2
07/22/2024 18:00	0.2	12.2	0.1	1.5	12.3
07/22/2024 19:00	0.2	12.2	0.1	1.5	12.4
07/22/2024 20:00	0.4	12.9	0.4	1.5	13.0
07/22/2024 21:00	0.5	13.0	0.4	1.5	13.1
07/22/2024 22:00	0.7	14.0	0.7	1.5	14.0
07/22/2024 23:00	0.7	14.5	0.7	1.5	14.5
Average/Sum#:	0.6	13.9	0.6	1.5	13.9
Minimum:	0.2	12.1	0.1	1.5	12.2
Maximum:	0.8	14.6	0.8	1.6	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/23/2024 00:00	0.7	14.5	0.7	1.5	14.5
07/23/2024 01:00	0.7	14.5	0.7	1.5	14.5
07/23/2024 02:00	0.7	14.5	0.7	1.5	14.5
07/23/2024 03:00	1.0	14.3	0.8	1.5	14.3
07/23/2024 04:00	0.4	12.7	0.3	1.5	12.8
07/23/2024 05:00	0.3	12.6	0.2	1.5	12.7
07/23/2024 06:00	0.3	12.6	0.2	1.5	12.7
07/23/2024 07:00	0.3	12.6	0.2	1.5	12.7
07/23/2024 08:00	0.2	12.5	0.2	1.5	12.6
07/23/2024 09:00	0.2	12.4	0.2	1.5	12.5
07/23/2024 10:00	0.2	12.4	0.2	1.5	12.5
07/23/2024 11:00	0.2	12.4	0.1	1.5	12.5
07/23/2024 12:00	0.2	12.1	0.2	1.5	12.2
07/23/2024 13:00	0.2	11.8	0.1	1.5	12.0
07/23/2024 14:00	0.2	11.8	0.2	1.5	12.0
07/23/2024 15:00	0.2	11.9	0.1	1.5	12.1
07/23/2024 16:00	0.1	11.9	0.1	1.5	12.1
07/23/2024 17:00	0.1	11.9	0.1	1.5	12.1
07/23/2024 18:00	0.1	12.0	0.1	1.5	12.1
07/23/2024 19:00	0.1	12.1	0.1	1.5	12.3
07/23/2024 20:00	0.1	12.2	0.1	1.5	12.3
07/23/2024 21:00	0.2	12.2	0.1	1.5	12.4
07/23/2024 22:00	0.2	12.2	0.1	1.5	12.4
07/23/2024 23:00	0.3	12.5	0.2	1.5	12.6
Average/Sum#:	0.3	12.6	0.3	1.5	12.7
Minimum:	0.1	11.8	0.1	1.5	12.0
Maximum:	1.0	14.5	0.8	1.5	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/24/2024 00:00	0.8	13.6	0.7	1.5	13.7
07/24/2024 01:00	0.9	14.1	0.8	1.4	14.1
07/24/2024 02:00	0.8	14.4	0.7	1.5	14.3
07/24/2024 03:00	0.8	14.4	0.7	1.6	14.4
07/24/2024 04:00	0.7	13.6	0.7	1.5	13.6
07/24/2024 05:00	0.6	13.2	0.5	1.5	13.3
07/24/2024 06:00	1.1	14.3	0.8	1.5	14.4
07/24/2024 07:00	0.7	14.6	0.7	1.5	14.6
07/24/2024 08:00	0.7	14.6	0.7	1.5	14.5
07/24/2024 09:00	0.8	14.6	0.7	1.4	14.5
07/24/2024 10:00	0.8	14.4	0.7	1.5	14.4
07/24/2024 11:00	0.4	13.0	0.3	1.4	12.8
07/24/2024 12:00	0.1	12.3	0.1	1.4	12.4
07/24/2024 13:00	0.1	12.2	0.1	1.4	12.3
07/24/2024 14:00	0.1	12.0	0.1	1.5	12.2
07/24/2024 15:00	0.1	12.0	0.1	1.5	12.1
07/24/2024 16:00	0.2	12.0	0.1	1.5	12.2
07/24/2024 17:00	0.2	11.9	0.1	1.5	12.0
07/24/2024 18:00	0.2	12.0	0.1	1.5	12.2
07/24/2024 19:00	0.1	12.2	0.1	1.5	12.3
07/24/2024 20:00	0.2	12.2	0.1	1.5	12.4
07/24/2024 21:00	0.2	12.3	0.2	1.5	12.4
07/24/2024 22:00	0.7	13.5	0.6	1.5	13.5
07/24/2024 23:00	0.8	13.7	0.7	1.5	13.7
Average/Sum#:	0.5	13.2	0.4	1.5	13.3
Minimum:	0.1	11.9	0.1	1.4	12.0
Maximum:	1.1	14.6	0.8	1.6	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/25/2024 00:00	0.7	14.7	0.7	1.5	14.6
07/25/2024 01:00	0.7	14.6	0.7	1.5	14.5
07/25/2024 02:00	0.7	14.5	0.7	1.5	14.4
07/25/2024 03:00	0.8	14.5	0.7	1.5	14.4
07/25/2024 04:00	0.7	14.6	0.7	1.5	14.5
07/25/2024 05:00	0.7	14.6	0.7	1.5	14.6
07/25/2024 06:00	0.8	14.5	0.7	1.5	14.5
07/25/2024 07:00	0.7	14.5	0.7	1.5	14.4
07/25/2024 08:00	0.7	14.5	0.7	1.5	14.4
07/25/2024 09:00	0.7	14.4	0.7	1.5	14.3
07/25/2024 10:00	0.7	14.4	0.7	1.5	14.3
07/25/2024 11:00	0.7	14.4	0.7	1.5	14.3
07/25/2024 12:00	0.7	14.5	0.6	1.5	14.4
07/25/2024 13:00	0.6	13.4	0.6	1.5	13.5
07/25/2024 14:00	0.3	12.8	0.3	1.5	12.8
07/25/2024 15:00	0.2	12.7	0.2	1.5	12.8
07/25/2024 16:00	0.3	12.7	0.2	1.5	12.7
07/25/2024 17:00	0.2	12.4	0.2	1.5	12.5
07/25/2024 18:00	0.2	12.2	0.1	1.5	12.3
07/25/2024 19:00	0.2	12.3	0.1	1.5	12.4
07/25/2024 20:00	0.2	12.4	0.2	1.5	12.5
07/25/2024 21:00	0.7	13.5	0.6	1.5	13.6
07/25/2024 22:00	0.7	14.5	0.6	1.5	14.4
07/25/2024 23:00	0.7	14.5	0.7	1.5	14.5
Average/Sum#:	0.6	13.8	0.5	1.5	13.8
Minimum:	0.2	12.2	0.1	1.5	12.3
Maximum:	0.8	14.7	0.7	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT1	Unit CT2	Unit CT2	Unit CT2
	CO, Ppmvdc	O2, Dry, Pct	CO, Ppmvdc	NOx, Ppmvdc	O2, Dry, Pct
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2024 00:00	0.7	14.5	0.7	1.5	14.5
07/26/2024 01:00	0.7	14.5	0.7	1.5	14.4
07/26/2024 02:00	0.8	14.5	0.7	1.5	14.4
07/26/2024 03:00	0.9	14.5	0.8	1.5	14.4
07/26/2024 04:00	0.8	14.4	0.7	1.5	14.4
07/26/2024 05:00	0.8	14.5	0.7	1.5	14.4
07/26/2024 06:00	0.8	14.5	0.7	1.5	14.4
07/26/2024 07:00	0.8	14.5	0.7	1.5	14.5
07/26/2024 08:00	0.8	14.5	0.7	1.5	14.5
07/26/2024 09:00	0.7	14.6	0.7	1.5	14.5
07/26/2024 10:00	0.7	14.6	0.7	1.5	14.5
07/26/2024 11:00	0.7	14.6	0.7	1.5	14.6
07/26/2024 12:00	0.7	14.6	0.7	1.5	14.6
07/26/2024 13:00	0.8	14.7	0.7	1.5	14.6
07/26/2024 14:00	0.7	14.6	0.7	1.5	14.6
07/26/2024 15:00	0.7	14.6	0.7	1.5	14.6
07/26/2024 16:00	0.7	14.6	0.7	1.5	14.6
07/26/2024 17:00	0.7	14.6	0.7	1.5	14.6
07/26/2024 18:00	0.8	14.3	0.7	1.5	14.4
07/26/2024 19:00	0.7	14.6	0.6	1.5	14.5
07/26/2024 20:00	0.7	14.4	0.7	1.5	14.4
07/26/2024 21:00	0.7	14.4	0.7	1.6	14.4
07/26/2024 22:00	0.8	14.4	0.7	1.5	14.4
07/26/2024 23:00	0.8	14.4	0.7	1.5	14.3
Average/Sum#:	0.8	14.5	0.7	1.5	14.5
Minimum:	0.7	14.3	0.6	1.5	14.3
Maximum:	0.9	14.7	0.8	1.6	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/27/2024 00:00	0.8	14.3	0.7	1.5	14.3
07/27/2024 01:00	0.8	14.3	0.7	1.5	14.3
07/27/2024 02:00	0.8	14.3	0.8	1.5	14.3
07/27/2024 03:00	0.9	14.3	0.8	1.5	14.3
07/27/2024 04:00	0.8	14.3	0.8	1.5	14.3
07/27/2024 05:00	0.8	14.3	0.8	1.5	14.3
07/27/2024 06:00	0.8	14.3	0.8	1.5	14.3
07/27/2024 07:00	0.8	14.3	0.7	1.5	14.3
07/27/2024 08:00	0.8	14.3	0.8	1.5	14.3
07/27/2024 09:00	0.8	14.3	0.7	1.5	14.3
07/27/2024 10:00	0.8	14.4	0.8	1.5	14.4
07/27/2024 11:00	0.8	14.4	0.8	1.5	14.4
07/27/2024 12:00	0.8	14.4	0.7	1.5	14.4
07/27/2024 13:00	0.7	14.4	0.7	1.5	14.4
07/27/2024 14:00	0.7	14.4	0.7	1.5	14.4
07/27/2024 15:00	0.7	14.4	0.7	1.5	14.4
07/27/2024 16:00	0.7	14.4	0.7	1.5	14.4
07/27/2024 17:00	0.7	14.4	0.7	1.5	14.4
07/27/2024 18:00	0.7	14.4	0.7	1.5	14.4
07/27/2024 19:00	0.7	14.4	0.7	1.5	14.4
07/27/2024 20:00	0.7	14.4	0.7	1.5	14.3
07/27/2024 21:00	0.8	14.3	0.7	1.5	14.3
07/27/2024 22:00	0.8	14.3	0.7	1.5	14.3
07/27/2024 23:00	0.8	14.3	0.7	1.5	14.3
Average/Sum#:	0.8	14.3	0.7	1.5	14.3
Minimum:	0.7	14.3	0.7	1.5	14.3
Maximum:	0.9	14.4	0.8	1.5	14.4
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/28/2024 00:00	0.8	14.3	0.7	1.5	14.3
07/28/2024 01:00	0.8	14.3	0.7	1.5	14.3
07/28/2024 02:00	0.8	14.3	0.8	1.5	14.3
07/28/2024 03:00	0.9	14.3	0.8	1.5	14.3
07/28/2024 04:00	0.8	14.3	0.8	1.5	14.3
07/28/2024 05:00	0.8	14.3	0.8	1.5	14.3
07/28/2024 06:00	0.8	14.3	0.8	1.5	14.3
07/28/2024 07:00	0.8	14.3	0.8	1.5	14.3
07/28/2024 08:00	0.8	14.3	0.8	1.5	14.3
07/28/2024 09:00	0.8	14.3	0.7	1.5	14.3
07/28/2024 10:00	0.8	14.4	0.7	1.5	14.4
07/28/2024 11:00	0.8	14.4	0.7	1.5	14.4
07/28/2024 12:00	0.7	14.4	0.7	1.5	14.4
07/28/2024 13:00	0.7	14.4	0.7	1.4	14.4
07/28/2024 14:00	0.7	14.3	0.7	1.5	14.3
07/28/2024 15:00	0.7	14.3	0.7	1.5	14.3
07/28/2024 16:00	0.7	14.3	0.7	1.5	14.3
07/28/2024 17:00	0.7	14.3	0.7	1.5	14.3
07/28/2024 18:00	0.7	14.5	0.7	1.5	14.5
07/28/2024 19:00	0.7	14.5	0.7	1.5	14.4
07/28/2024 20:00	0.7	14.4	0.7	1.5	14.4
07/28/2024 21:00	0.8	14.4	0.7	1.5	14.4
07/28/2024 22:00	0.8	14.4	0.7	1.5	14.4
07/28/2024 23:00	0.8	14.4	0.7	1.5	14.4
Average/Sum#:	0.8	14.4	0.7	1.5	14.3
Minimum:	0.7	14.3	0.7	1.4	14.3
Maximum:	0.9	14.5	0.8	1.5	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/29/2024 00:00	0.8	14.3	0.7	1.5	14.3
07/29/2024 01:00	0.8	14.3	0.7	1.5	14.3
07/29/2024 02:00	0.8	14.3	0.8	1.5	14.3
07/29/2024 03:00	0.9	14.3	0.7	1.5	14.3
07/29/2024 04:00	0.8	14.3	0.7	1.5	14.3
07/29/2024 05:00	0.8	14.3	0.8	1.5	14.3
07/29/2024 06:00	0.8	14.3	0.8	1.5	14.3
07/29/2024 07:00	0.8	14.3	0.7	1.5	14.3
07/29/2024 08:00	0.8	14.3	0.8	1.5	14.3
07/29/2024 09:00	0.8	14.3	0.8	1.5	14.4
07/29/2024 10:00	0.8	14.4	0.7	1.5	14.4
07/29/2024 11:00	0.8	14.4	0.7	1.5	14.4
07/29/2024 12:00	0.7	14.4	0.7	1.5	14.4
07/29/2024 13:00	0.7	14.5	0.7	1.5	14.5
07/29/2024 14:00	0.7	14.5	0.7	1.5	14.5
07/29/2024 15:00	0.7	14.5	0.7	1.5	14.5
07/29/2024 16:00	0.7	14.6	0.7	1.5	14.5
07/29/2024 17:00	0.7	13.9	0.7	1.5	14.0
07/29/2024 18:00	0.5	13.0	0.6	1.5	13.3
07/29/2024 19:00	1.0	13.8	0.9	1.5	13.8
07/29/2024 20:00	1.1	13.8	0.9	1.5	13.8
07/29/2024 21:00	1.0	14.1	0.9	1.5	14.1
07/29/2024 22:00	0.8	14.4	0.7	1.5	14.3
07/29/2024 23:00	0.8	14.4	0.8	1.5	14.3
Average/Sum#:	0.8	14.2	0.7	1.5	14.2
Minimum:	0.5	13.0	0.6	1.5	13.3
Maximum:	1.1	14.6	0.9	1.5	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/30/2024 00:00	0.8	14.3	0.8	1.5	14.3
07/30/2024 01:00	0.8	14.3	0.8	1.5	14.3
07/30/2024 02:00	0.8	14.3	0.8	1.5	14.3
07/30/2024 03:00	0.9	14.3	0.8	1.5	14.3
07/30/2024 04:00	0.8	14.3	0.8	1.5	14.3
07/30/2024 05:00	0.8	14.4	0.7	1.5	14.4
07/30/2024 06:00	0.8	14.3	0.7	1.5	14.3
07/30/2024 07:00	0.8	14.3	0.7	1.5	14.3
07/30/2024 08:00	0.8	14.4	0.7	1.5	14.4
07/30/2024 09:00	0.8	14.4	0.7	1.5	14.4
07/30/2024 10:00	0.7	14.4	0.7	1.5	14.4
07/30/2024 11:00	0.7	14.5	0.7	1.5	14.4
07/30/2024 12:00	0.7	14.5	0.7	1.5	14.5
07/30/2024 13:00	0.7	14.5	0.7	1.5	14.5
07/30/2024 14:00	0.7	14.5	0.7	1.5	14.5
07/30/2024 15:00	0.9	14.3	0.8	1.5	14.3
07/30/2024 16:00	0.5	13.1	0.5	1.5	13.1
07/30/2024 17:00	0.2	12.4	0.2	1.5	12.5
07/30/2024 18:00	0.2	12.3	0.2	1.5	12.4
07/30/2024 19:00	0.2	12.5	0.2	1.5	12.6
07/30/2024 20:00	0.4	12.8	0.3	1.5	12.8
07/30/2024 21:00	0.7	13.6	0.6	1.5	13.6
07/30/2024 22:00	0.8	14.4	0.7	1.5	14.3
07/30/2024 23:00	0.8	14.4	0.7	1.5	14.4
Average/Sum#:	0.7	14.0	0.6	1.5	14.0
Minimum:	0.2	12.3	0.2	1.5	12.4
Maximum:	0.9	14.5	0.8	1.5	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
07/31/2024 00:00	0.8	14.4	0.7	1.5	14.3
07/31/2024 01:00	0.8	14.4	0.7	1.5	14.3
07/31/2024 02:00	0.8	14.3	0.7	1.5	14.3
07/31/2024 03:00	0.8	14.3	0.7	1.5	14.3
07/31/2024 04:00	0.7	14.5	0.7	1.5	14.4
07/31/2024 05:00	0.7	14.4	0.7	1.5	14.4
07/31/2024 06:00	0.8	14.3	0.8	1.5	14.3
07/31/2024 07:00	0.8	14.4	0.8	1.5	14.3
07/31/2024 08:00	0.8	14.4	0.8	1.5	14.4
07/31/2024 09:00	0.8	14.4	0.7	1.5	14.4
07/31/2024 10:00	0.7	14.5	0.7	1.5	14.4
07/31/2024 11:00	0.7	14.5	0.7	1.5	14.5
07/31/2024 12:00	0.7	14.6	0.7	1.5	14.5
07/31/2024 13:00	0.7	14.5	0.7	1.5	14.5
07/31/2024 14:00	0.7	14.5	0.7	1.5	14.4
07/31/2024 15:00	0.8	14.3	0.7	1.5	14.3
07/31/2024 16:00	0.4	12.8	0.3	1.6	12.8
07/31/2024 17:00	0.4	12.9	0.4	1.5	13.0
07/31/2024 18:00	0.2	12.5	0.2	1.5	12.4
07/31/2024 19:00	0.5	13.1	0.5	1.5	13.1
07/31/2024 20:00	0.3	12.6	0.3	1.5	12.7
07/31/2024 21:00	0.4	12.7	0.3	1.5	12.8
07/31/2024 22:00	0.5	13.0	0.5	1.5	13.1
07/31/2024 23:00	0.7	13.5	0.6	1.5	13.5
Average/Sum#:	0.6	13.9	0.6	1.5	13.9
Minimum:	0.2	12.5	0.2	1.5	12.4
Maximum:	0.8	14.6	0.8	1.6	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/01/2024 00:00	0.7	14.5	0.7	1.5	14.4
08/01/2024 01:00	0.8	14.3	0.7	1.5	14.3
08/01/2024 02:00	0.8	14.3	0.7	1.5	14.3
08/01/2024 03:00	0.8	14.3	0.7	1.5	14.3
08/01/2024 04:00	0.7	14.4	0.7	1.5	14.4
08/01/2024 05:00	0.7	14.5	0.7	1.5	14.5
08/01/2024 06:00	0.8	14.4	0.7	1.5	14.4
08/01/2024 07:00	0.7	14.4	0.7	1.5	14.8
08/01/2024 08:00	0.8	14.5	0.0	0.0	0.0
08/01/2024 09:00	0.7	14.5	0.0	0.0	0.0
08/01/2024 10:00	0.7	14.5	0.0	0.0	0.0
08/01/2024 11:00	0.7	14.6	0.0	0.0	0.0
08/01/2024 12:00	0.7	14.5	0.0	0.0	0.0
08/01/2024 13:00	0.7	14.6	0.0	0.0	0.0
08/01/2024 14:00	0.7	14.5	0.0	0.0	17.3
08/01/2024 15:00	0.7	14.4	1.1	1.1	14.3
08/01/2024 16:00	0.2	12.5	0.2	1.5	12.6
08/01/2024 17:00	0.2	12.6	0.2	1.5	12.7
08/01/2024 18:00	0.1	12.4	0.2	1.5	12.5
08/01/2024 19:00	0.3	12.8	0.3	1.5	12.9
08/01/2024 20:00	0.2	12.5	0.2	1.5	12.6
08/01/2024 21:00	0.2	12.5	0.2	1.5	12.6
08/01/2024 22:00	0.4	12.9	0.3	1.5	13.0
08/01/2024 23:00	1.1	13.8	0.9	1.5	13.8
Average/Sum#:	0.6	13.9	0.5	1.4	13.9
Minimum:	0.1	12.4	0.0	0.0	12.5
Maximum:	1.1	14.6	1.1	1.5	17.3
%SI	0.00	0.00	25.00	25.00	25.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/02/2024 00:00	0.8	14.4	0.7	1.4	14.4
08/02/2024 01:00	0.8	14.4	0.8	1.4	14.3
08/02/2024 02:00	0.8	14.3	0.8	1.3	14.3
08/02/2024 03:00	0.9	14.5	0.8	0.9	14.4
08/02/2024 04:00	0.8	14.6	0.7	1.2	14.6
08/02/2024 05:00	0.7	14.5	0.7	1.4	14.5
08/02/2024 06:00	0.7	14.5	0.7	1.3	14.5
08/02/2024 07:00	0.7	14.6	0.7	1.2	14.6
08/02/2024 08:00	0.7	14.5	0.7	1.3	14.5
08/02/2024 09:00	1.0	14.2	1.2	1.4	14.2
08/02/2024 10:00	0.2	12.4	0.2	1.5	12.5
08/02/2024 11:00	0.2	12.3	0.2	1.5	12.5
08/02/2024 12:00	0.2	12.3	0.1	1.5	12.4
08/02/2024 13:00	0.2	12.3	0.2	1.5	12.4
08/02/2024 14:00	0.2	12.4	0.2	1.5	12.5
08/02/2024 15:00	0.3	12.8	0.3	1.5	12.9
08/02/2024 16:00	0.7	13.6	0.6	1.5	13.6
08/02/2024 17:00	0.6	13.4	0.6	1.5	13.4
08/02/2024 18:00	0.4	13.0	0.6	1.5	13.3
08/02/2024 19:00	0.9	13.8	0.8	1.5	13.8
08/02/2024 20:00	0.9	13.8	0.8	1.5	13.8
08/02/2024 21:00	0.9	13.9	0.8	1.5	13.9
08/02/2024 22:00	0.7	14.5	0.7	1.5	14.5
08/02/2024 23:00	0.7	14.5	0.7	1.4	14.5
Average/Sum#:	0.6	13.7	0.6	1.4	13.8
Minimum:	0.2	12.3	0.1	0.9	12.4
Maximum:	1.0	14.6	1.2	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/03/2024 00:00	0.7	14.4	0.7	1.2	14.4
08/03/2024 01:00	0.8	14.4	0.7	1.1	14.4
08/03/2024 02:00	0.8	14.4	0.7	1.0	14.4
08/03/2024 03:00	0.9	14.4	0.8	1.0	14.4
08/03/2024 04:00	0.8	14.4	0.8	1.0	14.4
08/03/2024 05:00	0.8	14.4	0.8	0.9	14.4
08/03/2024 06:00	0.8	14.4	0.8	0.8	14.4
08/03/2024 07:00	0.8	14.4	0.8	0.9	14.4
08/03/2024 08:00	0.8	14.4	0.7	0.9	14.4
08/03/2024 09:00	0.8	14.5	0.7	0.9	14.5
08/03/2024 10:00	0.7	14.5	0.8	0.8	14.5
08/03/2024 11:00	0.7	14.5	0.7	0.7	14.5
08/03/2024 12:00	0.7	14.6	0.7	0.8	14.5
08/03/2024 13:00	0.7	14.6	0.7	0.8	14.6
08/03/2024 14:00	0.7	14.6	0.7	0.7	14.6
08/03/2024 15:00	0.7	14.6	0.7	1.0	14.6
08/03/2024 16:00	0.7	14.6	0.7	1.0	14.6
08/03/2024 17:00	0.8	14.5	0.8	1.2	14.5
08/03/2024 18:00	0.2	12.4	0.2	1.6	12.4
08/03/2024 19:00	0.4	12.9	0.3	1.5	13.0
08/03/2024 20:00	0.7	13.9	0.7	1.4	13.9
08/03/2024 21:00	0.7	14.4	0.7	1.3	14.4
08/03/2024 22:00	0.7	14.6	0.7	1.4	14.6
08/03/2024 23:00	0.8	14.5	0.7	1.4	14.5
Average/Sum#:	0.7	14.3	0.7	1.1	14.3
Minimum:	0.2	12.4	0.2	0.7	12.4
Maximum:	0.9	14.6	0.8	1.6	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/04/2024 00:00	0.8	14.5	0.7	1.4	14.5
08/04/2024 01:00	0.8	14.5	0.8	1.5	14.4
08/04/2024 02:00	0.8	14.4	0.8	1.3	14.4
08/04/2024 03:00	0.8	14.4	0.7	1.0	14.4
08/04/2024 04:00	0.8	14.4	0.7	1.0	14.4
08/04/2024 05:00	0.8	14.4	0.7	1.0	14.4
08/04/2024 06:00	0.7	14.4	0.7	0.9	14.4
08/04/2024 07:00	0.7	14.4	0.7	0.8	14.4
08/04/2024 08:00	0.7	14.4	0.7	0.9	14.4
08/04/2024 09:00	0.7	14.5	0.7	1.0	14.4
08/04/2024 10:00	0.7	14.5	0.7	1.0	14.5
08/04/2024 11:00	0.7	14.5	0.7	1.0	14.5
08/04/2024 12:00	0.7	14.6	0.7	0.9	14.5
08/04/2024 13:00	0.7	14.6	0.7	0.8	14.6
08/04/2024 14:00	0.7	14.6	0.7	0.7	14.6
08/04/2024 15:00	0.7	14.6	0.7	0.9	14.6
08/04/2024 16:00	0.7	14.6	0.7	1.0	14.6
08/04/2024 17:00	0.7	13.9	0.6	1.4	13.9
08/04/2024 18:00	0.2	12.4	0.2	1.5	12.6
08/04/2024 19:00	0.6	13.4	0.6	1.5	13.5
08/04/2024 20:00	0.8	13.6	0.8	1.5	13.7
08/04/2024 21:00	0.7	14.5	0.7	1.4	14.5
08/04/2024 22:00	0.7	14.5	0.7	1.4	14.4
08/04/2024 23:00	0.7	14.4	0.7	1.2	14.4
Average/Sum#:	0.7	14.3	0.7	1.1	14.3
Minimum:	0.2	12.4	0.2	0.7	12.6
Maximum:	0.8	14.6	0.8	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/05/2024 00:00	0.8	14.4	0.8	0.9	14.3
08/05/2024 01:00	0.8	14.4	0.7	1.0	14.4
08/05/2024 02:00	0.8	14.4	0.8	1.0	14.3
08/05/2024 03:00	0.9	14.4	0.8	0.9	14.3
08/05/2024 04:00	0.7	14.5	0.7	1.0	14.5
08/05/2024 05:00	0.7	14.4	0.7	1.3	14.4
08/05/2024 06:00	0.8	14.4	0.8	0.9	14.4
08/05/2024 07:00	0.8	14.4	0.8	0.6	14.3
08/05/2024 08:00	0.7	14.4	0.7	0.6	14.4
08/05/2024 09:00	0.7	14.4	0.7	0.7	14.4
08/05/2024 10:00	0.7	14.4	0.8	0.7	14.4
08/05/2024 11:00	0.7	14.5	0.7	0.7	14.5
08/05/2024 12:00	0.7	14.6	0.7	0.9	14.5
08/05/2024 13:00	0.7	14.4	0.7	0.9	14.3
08/05/2024 14:00	0.7	14.5	0.7	0.9	14.4
08/05/2024 15:00	0.7	14.4	0.7	1.0	14.4
08/05/2024 16:00	0.7	14.4	0.7	1.1	14.4
08/05/2024 17:00	0.7	14.4	0.7	1.3	14.4
08/05/2024 18:00	0.7	13.6	0.6	1.6	13.3
08/05/2024 19:00	0.7	14.1	0.7	1.2	14.1
08/05/2024 20:00	0.8	14.5	0.7	1.2	14.5
08/05/2024 21:00	0.8	14.6	0.7	1.3	14.5
08/05/2024 22:00	0.7	14.5	0.7	1.3	14.5
08/05/2024 23:00	0.8	14.4	0.7	0.9	14.4
Average/Sum#:	0.7	14.4	0.7	1.0	14.3
Minimum:	0.7	13.6	0.6	0.6	13.3
Maximum:	0.9	14.6	0.8	1.6	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT1	Unit CT2	Unit CT2	Unit CT2
	CO, Ppmvdc	O2, Dry, Pct	CO, Ppmvdc	NOx, Ppmvdc	O2, Dry, Pct
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2024 00:00	0.8	14.4	0.8	0.8	14.4
08/06/2024 01:00	0.8	14.4	0.8	0.8	14.4
08/06/2024 02:00	0.8	14.4	0.8	0.8	14.4
08/06/2024 03:00	0.9	14.4	0.8	0.6	14.3
08/06/2024 04:00	0.8	14.4	0.8	0.5	14.3
08/06/2024 05:00	0.8	14.4	0.8	0.5	14.3
08/06/2024 06:00	0.8	14.4	0.8	0.6	14.3
08/06/2024 07:00	0.8	14.4	0.8	0.6	14.4
08/06/2024 08:00	0.8	14.4	0.8	0.7	14.4
08/06/2024 09:00	0.8	14.4	0.7	0.8	14.4
08/06/2024 10:00	0.8	14.5	0.8	0.8	14.5
08/06/2024 11:00	0.8	14.5	0.8	0.8	14.5
08/06/2024 12:00	0.7	14.5	0.8	0.8	14.5
08/06/2024 13:00	0.7	14.6	0.7	0.8	14.6
08/06/2024 14:00	0.7	14.6	0.7	0.8	14.6
08/06/2024 15:00	0.7	14.6	0.7	1.0	14.6
08/06/2024 16:00	0.7	14.6	0.7	1.1	14.6
08/06/2024 17:00	0.8	14.3	0.8	1.4	14.3
08/06/2024 18:00	0.2	12.5	0.2	1.6	12.6
08/06/2024 19:00	0.8	13.7	0.7	1.5	13.7
08/06/2024 20:00	0.9	14.1	0.8	1.4	14.1
08/06/2024 21:00	0.7	14.5	0.7	1.4	14.5
08/06/2024 22:00	0.8	14.5	0.7	1.4	14.5
08/06/2024 23:00	0.8	14.5	0.8	1.3	14.4
Average/Sum#:	0.8	14.3	0.7	1.0	14.3
Minimum:	0.2	12.5	0.2	0.5	12.6
Maximum:	0.9	14.6	0.8	1.6	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/07/2024 00:00	0.8	14.5	0.7	1.4	14.5
08/07/2024 01:00	0.8	14.5	0.8	1.1	14.5
08/07/2024 02:00	0.8	14.5	0.8	1.0	14.5
08/07/2024 03:00	0.9	14.5	0.8	1.1	14.4
08/07/2024 04:00	0.8	14.4	0.8	1.1	14.4
08/07/2024 05:00	0.8	14.4	0.8	1.1	14.4
08/07/2024 06:00	0.9	14.5	0.8	1.1	14.4
08/07/2024 07:00	0.9	14.5	0.9	1.0	14.4
08/07/2024 08:00	0.8	14.5	0.9	1.1	14.5
08/07/2024 09:00	0.7	14.5	0.7	1.3	14.5
08/07/2024 10:00	0.8	14.5	0.8	1.3	14.5
08/07/2024 11:00	0.7	14.5	0.8	1.1	14.5
08/07/2024 12:00	0.7	14.6	0.8	1.0	14.5
08/07/2024 13:00	0.7	14.6	0.7	1.0	14.6
08/07/2024 14:00	0.7	14.7	0.7	1.1	14.6
08/07/2024 15:00	0.7	14.7	0.7	1.5	14.7
08/07/2024 16:00	0.7	14.7	0.7	1.4	14.6
08/07/2024 17:00	0.7	14.6	0.7	1.3	14.6
08/07/2024 18:00	0.7	14.4	0.7	1.4	14.4
08/07/2024 19:00	0.7	14.4	0.7	1.3	14.4
08/07/2024 20:00	0.8	14.4	0.7	1.1	14.3
08/07/2024 21:00	0.8	14.3	0.7	1.0	14.3
08/07/2024 22:00	0.8	14.3	0.7	0.9	14.3
08/07/2024 23:00	0.8	14.3	0.7	1.0	14.3
Average/Sum#:	0.8	14.5	0.8	1.2	14.5
Minimum:	0.7	14.3	0.7	0.9	14.3
Maximum:	0.9	14.7	0.9	1.5	14.7
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/08/2024 00:00	0.8	14.3	0.7	1.1	14.3
08/08/2024 01:00	0.8	14.3	0.7	1.2	14.3
08/08/2024 02:00	0.8	14.3	0.7	1.3	14.3
08/08/2024 03:00	0.9	14.3	0.8	1.3	14.3
08/08/2024 04:00	0.8	14.4	0.8	1.0	14.4
08/08/2024 05:00	0.8	14.4	0.8	1.0	14.4
08/08/2024 06:00	0.8	14.4	0.7	1.0	14.4
08/08/2024 07:00	0.8	14.4	0.7	0.8	14.4
08/08/2024 08:00	0.8	14.4	0.7	0.7	14.4
08/08/2024 09:00	0.7	14.4	0.7	0.8	14.4
08/08/2024 10:00	0.0	0.0	0.7	0.8	14.4
08/08/2024 11:00	0.6	14.5	0.7	0.8	14.5
08/08/2024 12:00	0.6	14.5	0.7	0.8	14.5
08/08/2024 13:00	0.6	14.5	0.7	0.8	14.5
08/08/2024 14:00	0.6	14.5	0.7	0.7	14.5
08/08/2024 15:00	0.6	14.5	0.7	0.9	14.6
08/08/2024 16:00	0.7	14.6	0.7	1.1	14.6
08/08/2024 17:00	0.7	14.6	0.7	1.2	14.6
08/08/2024 18:00	0.6	14.5	0.7	1.1	14.5
08/08/2024 19:00	0.6	14.5	0.7	0.9	14.5
08/08/2024 20:00	0.7	14.5	0.7	1.0	14.5
08/08/2024 21:00	0.7	14.5	0.7	0.9	14.5
08/08/2024 22:00	0.7	14.4	0.7	0.9	14.4
08/08/2024 23:00	0.7	14.4	0.7	0.9	14.4
Average/Sum#:	0.7	14.4	0.7	1.0	14.4
Minimum:	0.6	14.3	0.7	0.7	14.3
Maximum:	0.9	14.6	0.8	1.3	14.6
%SI	4.17	4.17	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/09/2024 00:00	0.7	14.4	0.8	0.9	14.4
08/09/2024 01:00	0.7	14.3	0.7	0.8	14.4
08/09/2024 02:00	0.7	14.3	0.7	0.8	14.4
08/09/2024 03:00	0.8	14.3	0.7	0.8	14.4
08/09/2024 04:00	0.7	14.3	0.8	0.7	14.3
08/09/2024 05:00	0.7	14.3	0.8	0.8	14.3
08/09/2024 06:00	0.7	14.3	0.7	0.9	14.4
08/09/2024 07:00	0.7	14.3	0.8	0.8	14.3
08/09/2024 08:00	0.7	14.4	0.8	1.0	14.4
08/09/2024 09:00	0.7	14.4	0.7	1.0	14.4
08/09/2024 10:00	0.7	14.4	0.7	1.0	14.4
08/09/2024 11:00	0.6	14.5	0.7	0.9	14.5
08/09/2024 12:00	0.6	14.5	0.7	0.8	14.5
08/09/2024 13:00	0.6	14.5	0.7	0.8	14.5
08/09/2024 14:00	0.7	14.6	0.7	0.8	14.6
08/09/2024 15:00	0.7	14.6	0.7	0.8	14.6
08/09/2024 16:00	0.7	14.6	0.7	0.9	14.6
08/09/2024 17:00	0.6	14.4	0.7	0.9	14.4
08/09/2024 18:00	0.6	14.3	0.7	1.0	14.4
08/09/2024 19:00	0.7	14.3	0.7	1.0	14.3
08/09/2024 20:00	0.7	14.4	0.7	1.1	14.4
08/09/2024 21:00	0.7	14.4	0.7	1.4	14.5
08/09/2024 22:00	0.7	14.4	0.7	1.3	14.4
08/09/2024 23:00	0.7	14.4	0.7	1.1	14.4
Average/Sum#:	0.7	14.4	0.7	0.9	14.4
Minimum:	0.6	14.3	0.7	0.7	14.3
Maximum:	0.8	14.6	0.8	1.4	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/10/2024 00:00	0.7	14.3	0.8	1.0	14.4
08/10/2024 01:00	0.7	14.3	0.7	1.0	14.4
08/10/2024 02:00	0.7	14.3	0.7	0.9	14.4
08/10/2024 03:00	0.8	14.3	0.7	0.7	14.3
08/10/2024 04:00	0.7	14.3	0.7	0.6	14.3
08/10/2024 05:00	0.7	14.3	0.7	0.6	14.3
08/10/2024 06:00	0.7	14.3	0.8	0.7	14.4
08/10/2024 07:00	0.7	14.3	0.8	0.7	14.4
08/10/2024 08:00	0.7	14.3	0.7	0.7	14.4
08/10/2024 09:00	0.7	14.3	0.8	0.7	14.4
08/10/2024 10:00	0.7	14.4	0.7	0.8	14.4
08/10/2024 11:00	0.6	14.4	0.7	0.7	14.5
08/10/2024 12:00	0.6	14.5	0.7	0.7	14.5
08/10/2024 13:00	0.6	14.5	0.7	0.9	14.5
08/10/2024 14:00	0.6	14.5	0.7	0.9	14.5
08/10/2024 15:00	0.6	14.5	0.7	1.1	14.6
08/10/2024 16:00	0.6	14.5	0.7	1.3	14.6
08/10/2024 17:00	0.6	14.5	0.7	1.3	14.5
08/10/2024 18:00	0.7	14.4	0.7	0.9	14.4
08/10/2024 19:00	0.7	14.5	0.7	0.9	14.5
08/10/2024 20:00	0.7	14.5	0.7	0.9	14.5
08/10/2024 21:00	0.7	14.4	0.7	0.9	14.5
08/10/2024 22:00	0.7	14.4	0.7	1.0	14.4
08/10/2024 23:00	0.7	14.4	0.8	1.0	14.4
Average/Sum#:	0.7	14.4	0.7	0.9	14.4
Minimum:	0.6	14.3	0.7	0.6	14.3
Maximum:	0.8	14.5	0.8	1.3	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/11/2024 00:00	0.7	14.4	0.8	1.1	14.4
08/11/2024 01:00	0.7	14.4	0.7	1.1	14.4
08/11/2024 02:00	0.7	14.3	0.8	1.1	14.4
08/11/2024 03:00	0.8	14.3	0.7	1.2	14.4
08/11/2024 04:00	0.8	14.3	0.8	1.2	14.4
08/11/2024 05:00	0.7	14.3	0.8	1.1	14.4
08/11/2024 06:00	0.7	14.3	0.8	1.0	14.4
08/11/2024 07:00	0.7	14.3	0.7	0.9	14.4
08/11/2024 08:00	0.7	14.3	0.7	0.9	14.4
08/11/2024 09:00	0.7	14.4	0.7	1.1	14.4
08/11/2024 10:00	0.7	14.4	0.7	1.2	14.4
08/11/2024 11:00	0.6	14.4	0.7	1.2	14.5
08/11/2024 12:00	0.6	14.5	0.7	1.2	14.5
08/11/2024 13:00	0.6	14.5	0.7	1.4	14.5
08/11/2024 14:00	0.6	14.5	0.6	1.4	14.5
08/11/2024 15:00	0.6	14.5	0.7	1.4	14.5
08/11/2024 16:00	0.6	14.5	0.6	1.4	14.5
08/11/2024 17:00	0.6	14.5	0.7	1.3	14.5
08/11/2024 18:00	0.7	14.3	0.8	1.5	14.3
08/11/2024 19:00	0.8	13.7	0.9	1.6	13.7
08/11/2024 20:00	0.5	13.0	0.5	1.5	13.1
08/11/2024 21:00	1.0	13.9	0.9	1.5	13.9
08/11/2024 22:00	1.1	14.2	0.8	1.1	14.3
08/11/2024 23:00	0.8	14.3	0.8	1.1	14.4
Average/Sum#:	0.7	14.3	0.7	1.2	14.3
Minimum:	0.5	13.0	0.5	0.9	13.1
Maximum:	1.1	14.5	0.9	1.6	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/12/2024 00:00	0.7	14.3	0.8	1.2	14.3
08/12/2024 01:00	0.7	14.3	0.8	1.3	14.3
08/12/2024 02:00	0.7	14.3	0.8	1.3	14.3
08/12/2024 03:00	0.8	14.3	0.8	0.9	14.3
08/12/2024 04:00	0.7	14.3	0.8	1.0	14.3
08/12/2024 05:00	0.7	14.3	0.8	0.9	14.4
08/12/2024 06:00	0.7	14.3	0.8	0.8	14.3
08/12/2024 07:00	0.7	14.3	0.8	0.8	14.3
08/12/2024 08:00	0.7	14.3	0.8	0.9	14.4
08/12/2024 09:00	0.7	14.3	0.8	1.1	14.4
08/12/2024 10:00	0.7	14.4	0.7	1.1	14.4
08/12/2024 11:00	0.6	14.4	0.7	1.1	14.4
08/12/2024 12:00	0.6	14.5	0.7	1.1	14.5
08/12/2024 13:00	0.6	14.5	0.7	1.1	14.5
08/12/2024 14:00	0.6	14.5	0.7	0.9	14.5
08/12/2024 15:00	0.6	14.5	0.7	1.0	14.5
08/12/2024 16:00	0.6	14.5	0.7	1.0	14.5
08/12/2024 17:00	0.7	14.3	0.8	1.1	14.3
08/12/2024 18:00	0.8	13.7	0.8	1.6	13.7
08/12/2024 19:00	0.9	14.0	1.0	1.5	14.0
08/12/2024 20:00	0.7	14.4	0.7	1.2	14.5
08/12/2024 21:00	0.7	14.4	0.7	1.0	14.4
08/12/2024 22:00	0.7	14.4	0.8	1.0	14.4
08/12/2024 23:00	0.7	14.3	0.7	0.9	14.4
Average/Sum#:	0.7	14.3	0.8	1.1	14.3
Minimum:	0.6	13.7	0.7	0.8	13.7
Maximum:	0.9	14.5	1.0	1.6	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/13/2024 00:00	0.7	14.3	0.8	0.8	14.4
08/13/2024 01:00	0.7	14.3	0.7	0.8	14.4
08/13/2024 02:00	0.7	14.3	0.8	0.8	14.4
08/13/2024 03:00	0.8	14.3	0.8	0.8	14.4
08/13/2024 04:00	0.7	14.3	0.8	0.8	14.4
08/13/2024 05:00	0.7	14.3	0.8	0.8	14.4
08/13/2024 06:00	0.7	14.3	0.8	0.8	14.3
08/13/2024 07:00	0.7	14.3	0.7	1.0	14.4
08/13/2024 08:00	0.7	14.3	0.7	1.1	14.4
08/13/2024 09:00	0.7	14.4	0.9	1.3	14.4
08/13/2024 10:00	0.7	14.4	0.9	1.3	14.4
08/13/2024 11:00	0.6	14.4	0.9	1.2	14.4
08/13/2024 12:00	0.6	14.4	0.8	1.0	14.5
08/13/2024 13:00	0.6	14.5	0.9	1.0	14.5
08/13/2024 14:00	0.6	14.5	0.9	1.1	14.5
08/13/2024 15:00	0.6	14.5	0.8	1.3	14.5
08/13/2024 16:00	0.6	14.5	0.9	1.4	14.5
08/13/2024 17:00	0.7	13.8	0.8	1.4	13.8
08/13/2024 18:00	0.6	13.3	0.9	1.5	13.7
08/13/2024 19:00	0.8	14.0	1.0	1.3	14.1
08/13/2024 20:00	0.7	14.3	0.9	0.9	14.4
08/13/2024 21:00	0.7	14.4	0.9	1.0	14.4
08/13/2024 22:00	0.7	14.4	0.9	1.1	14.4
08/13/2024 23:00	0.7	14.4	0.9	1.2	14.4
Average/Sum#:	0.7	14.3	0.8	1.1	14.4
Minimum:	0.6	13.3	0.7	0.8	13.7
Maximum:	0.8	14.5	1.0	1.5	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/14/2024 00:00	0.7	14.3	0.9	1.3	14.4
08/14/2024 01:00	0.7	14.3	0.9	1.4	14.4
08/14/2024 02:00	0.7	14.3	0.9	1.0	14.4
08/14/2024 03:00	0.8	14.3	0.9	0.8	14.4
08/14/2024 04:00	0.7	14.3	0.9	0.8	14.3
08/14/2024 05:00	0.7	14.3	0.9	0.8	14.3
08/14/2024 06:00	0.7	14.3	0.9	0.8	14.3
08/14/2024 07:00	0.7	14.3	0.9	0.8	14.4
08/14/2024 08:00	0.7	14.3	0.9	0.9	14.4
08/14/2024 09:00	0.7	14.4	0.9	1.0	14.4
08/14/2024 10:00	0.7	14.4	0.9	1.0	14.4
08/14/2024 11:00	0.6	14.4	0.9	1.0	14.5
08/14/2024 12:00	0.6	14.5	0.9	0.9	14.5
08/14/2024 13:00	0.6	14.5	0.9	1.0	14.5
08/14/2024 14:00	0.6	14.5	0.9	1.0	14.5
08/14/2024 15:00	0.6	14.5	0.8	1.2	14.5
08/14/2024 16:00	0.6	14.5	0.8	1.2	14.5
08/14/2024 17:00	0.6	13.4	0.8	1.5	13.5
08/14/2024 18:00	0.1	12.3	0.3	1.4	12.4
08/14/2024 19:00	0.1	12.2	0.3	1.3	12.4
08/14/2024 20:00	0.6	13.4	0.8	1.3	13.5
08/14/2024 21:00	0.7	14.6	0.9	1.3	14.6
08/14/2024 22:00	0.7	14.4	1.0	1.0	14.4
08/14/2024 23:00	0.7	14.5	0.9	1.2	14.5
Average/Sum#:	0.6	14.1	0.8	1.1	14.2
Minimum:	0.1	12.2	0.3	0.8	12.4
Maximum:	0.8	14.6	1.0	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/15/2024 00:00	0.8	14.3	1.0	0.9	14.4
08/15/2024 01:00	0.8	14.3	1.0	0.7	14.4
08/15/2024 02:00	0.7	14.3	1.0	0.7	14.4
08/15/2024 03:00	0.8	14.3	1.0	0.6	14.3
08/15/2024 04:00	0.7	14.3	0.9	0.6	14.4
08/15/2024 05:00	0.7	14.4	0.9	0.9	14.4
08/15/2024 06:00	0.8	14.3	1.0	0.8	14.3
08/15/2024 07:00	0.8	14.3	1.0	1.0	14.4
08/15/2024 08:00	0.8	14.4	1.0	0.9	14.4
08/15/2024 09:00	0.7	14.4	0.9	1.0	14.4
08/15/2024 10:00	0.7	14.4	0.9	1.1	14.4
08/15/2024 11:00	0.7	14.4	0.9	1.0	14.4
08/15/2024 12:00	0.6	14.5	0.9	0.9	14.5
08/15/2024 13:00	0.6	14.5	0.9	0.9	14.5
08/15/2024 14:00	0.6	14.5	0.9	0.9	14.5
08/15/2024 15:00	0.7	14.3	1.0	1.2	14.3
08/15/2024 16:00	0.6	13.5	0.9	1.4	13.6
08/15/2024 17:00	0.3	12.9	0.5	1.3	13.0
08/15/2024 18:00	0.1	12.4	0.4	1.3	12.6
08/15/2024 19:00	0.3	12.8	0.5	1.3	12.9
08/15/2024 20:00	0.7	14.0	0.9	1.2	14.0
08/15/2024 21:00	0.7	14.3	0.9	0.8	14.3
08/15/2024 22:00	0.7	14.4	0.9	1.0	14.4
08/15/2024 23:00	0.7	14.4	0.9	1.0	14.4
Average/Sum#:	0.7	14.1	0.9	1.0	14.2
Minimum:	0.1	12.4	0.4	0.6	12.6
Maximum:	0.8	14.5	1.0	1.4	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/16/2024 00:00	0.7	14.4	1.0	0.9	14.4
08/16/2024 01:00	0.7	14.4	0.9	0.9	14.4
08/16/2024 02:00	0.7	14.3	0.9	0.8	14.4
08/16/2024 03:00	0.8	14.3	0.9	0.7	14.3
08/16/2024 04:00	0.7	14.4	0.9	0.7	14.4
08/16/2024 05:00	0.6	14.4	0.9	0.9	14.4
08/16/2024 06:00	0.7	14.3	1.0	0.9	14.3
08/16/2024 07:00	0.8	14.4	1.0	1.0	14.4
08/16/2024 08:00	0.8	14.4	0.9	1.0	14.4
08/16/2024 09:00	0.7	14.4	0.9	1.0	14.4
08/16/2024 10:00	0.6	14.4	0.9	1.1	14.4
08/16/2024 11:00	0.6	14.4	0.9	1.1	14.5
08/16/2024 12:00	0.6	14.5	0.9	1.0	14.5
08/16/2024 13:00	0.6	14.5	0.9	1.0	14.5
08/16/2024 14:00	0.6	14.5	0.9	0.9	14.5
08/16/2024 15:00	0.6	14.5	0.9	1.0	14.5
08/16/2024 16:00	0.6	14.5	0.9	1.1	14.5
08/16/2024 17:00	0.6	14.5	0.9	1.2	14.5
08/16/2024 18:00	0.6	14.4	0.9	1.0	14.5
08/16/2024 19:00	0.6	14.4	0.9	0.9	14.4
08/16/2024 20:00	0.6	14.4	0.9	1.1	14.4
08/16/2024 21:00	0.6	14.5	0.8	1.3	14.5
08/16/2024 22:00	0.6	14.4	0.9	1.2	14.4
08/16/2024 23:00	0.6	14.5	0.8	1.1	14.5
Average/Sum#:	0.7	14.4	0.9	1.0	14.4
Minimum:	0.6	14.3	0.8	0.7	14.3
Maximum:	0.8	14.5	1.0	1.3	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/17/2024 00:00	0.6	14.4	0.9	1.1	14.4
08/17/2024 01:00	0.6	14.3	0.9	0.8	14.4
08/17/2024 02:00	0.6	14.3	0.9	0.7	14.4
08/17/2024 03:00	0.7	14.3	0.9	0.6	14.3
08/17/2024 04:00	0.7	14.3	0.9	0.6	14.3
08/17/2024 05:00	0.6	14.4	0.9	0.7	14.4
08/17/2024 06:00	0.6	14.3	0.9	0.6	14.3
08/17/2024 07:00	0.6	14.3	0.9	0.6	14.3
08/17/2024 08:00	0.6	14.3	0.9	0.7	14.4
08/17/2024 09:00	0.6	14.3	0.9	0.8	14.4
08/17/2024 10:00	0.6	14.4	0.9	0.9	14.4
08/17/2024 11:00	0.6	14.4	0.9	0.9	14.4
08/17/2024 12:00	0.6	14.4	0.8	0.8	14.4
08/17/2024 13:00	0.6	14.4	0.9	0.8	14.4
08/17/2024 14:00	0.6	14.4	0.8	0.7	14.4
08/17/2024 15:00	0.6	14.4	0.8	0.7	14.4
08/17/2024 16:00	0.6	14.4	0.8	0.7	14.4
08/17/2024 17:00	0.6	14.4	0.8	0.8	14.4
08/17/2024 18:00	0.6	14.3	0.8	0.8	14.4
08/17/2024 19:00	0.6	14.3	0.8	0.7	14.4
08/17/2024 20:00	0.6	14.3	0.9	0.8	14.3
08/17/2024 21:00	0.6	14.3	0.9	0.8	14.3
08/17/2024 22:00	0.7	14.3	0.9	1.0	14.3
08/17/2024 23:00	0.7	14.3	0.9	1.0	14.3
Average/Sum#:	0.6	14.3	0.9	0.8	14.4
Minimum:	0.6	14.3	0.8	0.6	14.3
Maximum:	0.7	14.4	0.9	1.1	14.4
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT1	Unit CT2	Unit CT2	Unit CT2
	CO, Ppmvdc	O2, Dry, Pct	CO, Ppmvdc	NOx, Ppmvdc	O2, Dry, Pct
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2024 00:00	0.7	14.3	0.9	1.1	14.3
08/18/2024 01:00	0.7	14.3	0.9	1.2	14.3
08/18/2024 02:00	0.7	14.3	0.9	1.3	14.3
08/18/2024 03:00	0.8	14.2	0.9	1.4	14.3
08/18/2024 04:00	0.7	14.2	0.9	1.4	14.3
08/18/2024 05:00	0.7	14.2	0.9	1.4	14.3
08/18/2024 06:00	0.7	14.2	0.9	1.4	14.3
08/18/2024 07:00	0.7	14.3	0.9	1.3	14.3
08/18/2024 08:00	0.7	14.3	0.9	1.1	14.3
08/18/2024 09:00	0.7	14.3	0.9	1.0	14.4
08/18/2024 10:00	0.7	14.3	0.9	0.9	14.4
08/18/2024 11:00	0.6	14.4	0.9	0.9	14.4
08/18/2024 12:00	0.6	14.4	0.9	1.0	14.5
08/18/2024 13:00	0.6	14.4	0.9	0.9	14.5
08/18/2024 14:00	0.6	14.4	0.9	0.8	14.5
08/18/2024 15:00	0.6	14.5	0.9	1.1	14.5
08/18/2024 16:00	0.6	14.5	0.9	1.3	14.5
08/18/2024 17:00	0.6	14.5	0.9	1.4	14.5
08/18/2024 18:00	0.6	14.5	0.9	1.3	14.5
08/18/2024 19:00	0.6	14.4	0.9	1.4	14.5
08/18/2024 20:00	0.6	14.4	0.9	1.1	14.4
08/18/2024 21:00	0.7	14.4	0.9	1.0	14.4
08/18/2024 22:00	0.7	14.3	0.9	1.0	14.4
08/18/2024 23:00	0.7	14.3	0.9	0.9	14.4
Average/Sum#:	0.7	14.3	0.9	1.2	14.4
Minimum:	0.6	14.2	0.9	0.8	14.3
Maximum:	0.8	14.5	0.9	1.4	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/19/2024 00:00	0.7	14.3	0.9	0.8	14.4
08/19/2024 01:00	0.7	14.3	0.9	0.8	14.4
08/19/2024 02:00	0.7	14.3	0.9	0.8	14.4
08/19/2024 03:00	0.8	14.3	1.0	0.8	14.3
08/19/2024 04:00	0.6	14.4	0.9	0.9	14.4
08/19/2024 05:00	0.7	14.4	0.9	1.3	14.4
08/19/2024 06:00	0.8	14.3	1.0	1.2	14.3
08/19/2024 07:00	0.8	14.3	1.0	1.3	14.3
08/19/2024 08:00	0.7	14.3	1.0	0.9	14.4
08/19/2024 09:00	0.7	14.3	0.9	0.8	14.4
08/19/2024 10:00	0.7	14.4	0.9	1.3	14.4
08/19/2024 11:00	0.6	14.4	0.9	1.5	14.5
08/19/2024 12:00	0.6	14.4	0.9	1.5	14.5
08/19/2024 13:00	0.6	14.5	0.9	1.5	14.5
08/19/2024 14:00	0.6	14.5	0.8	1.5	14.5
08/19/2024 15:00	0.6	14.5	0.9	1.5	14.5
08/19/2024 16:00	0.6	14.5	0.9	1.5	14.5
08/19/2024 17:00	0.6	14.5	0.9	1.5	14.5
08/19/2024 18:00	0.6	14.5	0.9	1.5	14.5
08/19/2024 19:00	0.6	14.4	0.9	1.5	14.5
08/19/2024 20:00	0.7	14.4	0.9	1.5	14.4
08/19/2024 21:00	0.7	14.5	0.9	1.5	14.5
08/19/2024 22:00	0.7	14.4	0.9	1.5	14.4
08/19/2024 23:00	0.7	14.4	0.9	1.5	14.4
Average/Sum#:	0.7	14.4	0.9	1.3	14.4
Minimum:	0.6	14.3	0.8	0.8	14.3
Maximum:	0.8	14.5	1.0	1.5	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/20/2024 00:00	0.7	14.3	0.9	1.5	14.4
08/20/2024 01:00	0.7	14.3	1.0	1.5	14.4
08/20/2024 02:00	0.7	14.3	1.0	1.5	14.4
08/20/2024 03:00	0.8	14.3	0.9	1.5	14.4
08/20/2024 04:00	0.8	14.3	1.0	1.5	14.3
08/20/2024 05:00	0.8	14.3	1.0	1.5	14.3
08/20/2024 06:00	0.8	14.3	1.0	1.5	14.3
08/20/2024 07:00	0.8	14.3	0.9	1.5	14.4
08/20/2024 08:00	0.8	14.3	1.0	1.5	14.4
08/20/2024 09:00	0.8	14.4	0.9	1.5	14.4
08/20/2024 10:00	0.7	14.4	0.9	1.5	14.4
08/20/2024 11:00	0.6	14.4	0.9	1.5	14.5
08/20/2024 12:00	0.6	14.5	0.0	0.0	0.0
08/20/2024 13:00	0.6	14.5	0.0	0.0	0.0
08/20/2024 14:00	0.6	14.5	0.9	1.6	14.5
08/20/2024 15:00	0.6	14.5	0.9	1.5	14.5
08/20/2024 16:00	0.6	14.5	0.9	1.5	14.5
08/20/2024 17:00	0.6	14.5	0.9	1.5	14.5
08/20/2024 18:00	0.6	14.5	0.9	1.5	14.5
08/20/2024 19:00	0.6	14.4	0.9	1.5	14.5
08/20/2024 20:00	0.7	14.4	0.9	1.5	14.4
08/20/2024 21:00	0.7	14.4	0.9	1.5	14.4
08/20/2024 22:00	0.7	14.3	0.9	1.5	14.4
08/20/2024 23:00	0.7	14.3	0.9	1.5	14.4
Average/Sum#:	0.7	14.4	0.9	1.5	14.4
Minimum:	0.6	14.3	0.9	1.5	14.3
Maximum:	0.8	14.5	1.0	1.6	14.5
%SI	0.00	0.00	8.33	8.33	8.33

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/21/2024 00:00	0.7	14.3	0.9	1.5	14.4
08/21/2024 01:00	0.7	14.3	0.9	1.5	14.4
08/21/2024 02:00	0.7	14.3	0.9	1.5	14.4
08/21/2024 03:00	0.8	14.3	0.9	1.5	14.4
08/21/2024 04:00	0.7	14.3	1.0	1.5	14.4
08/21/2024 05:00	0.7	14.3	0.9	1.5	14.4
08/21/2024 06:00	0.8	14.3	0.9	1.5	14.4
08/21/2024 07:00	0.7	14.3	0.9	1.5	14.4
08/21/2024 08:00	0.7	14.3	0.9	1.5	14.4
08/21/2024 09:00	0.7	14.4	0.9	1.5	14.4
08/21/2024 10:00	0.7	14.4	0.9	1.5	14.5
08/21/2024 11:00	0.7	14.4	0.9	1.5	14.5
08/21/2024 12:00	0.6	14.5	0.9	1.5	14.5
08/21/2024 13:00	0.6	14.5	0.9	1.5	14.5
08/21/2024 14:00	0.6	14.5	0.8	1.5	14.5
08/21/2024 15:00	0.6	14.5	0.8	1.5	14.5
08/21/2024 16:00	0.6	14.5	0.8	1.5	14.5
08/21/2024 17:00	0.6	14.5	0.9	1.5	14.5
08/21/2024 18:00	0.6	14.4	0.8	1.5	14.5
08/21/2024 19:00	0.6	14.4	0.8	1.5	14.4
08/21/2024 20:00	0.7	14.4	0.9	1.5	14.4
08/21/2024 21:00	0.7	14.4	0.9	1.5	14.4
08/21/2024 22:00	0.7	14.3	0.9	1.5	14.4
08/21/2024 23:00	0.7	14.3	0.9	1.5	14.4
Average/Sum#:	0.7	14.4	0.9	1.5	14.4
Minimum:	0.6	14.3	0.8	1.5	14.4
Maximum:	0.8	14.5	1.0	1.5	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/22/2024 00:00	0.7	14.3	0.9	1.5	14.4
08/22/2024 01:00	0.7	14.3	0.9	1.5	14.3
08/22/2024 02:00	0.7	14.3	0.9	1.5	14.3
08/22/2024 03:00	0.8	14.3	0.9	1.5	14.3
08/22/2024 04:00	0.7	14.3	0.9	1.5	14.3
08/22/2024 05:00	0.8	14.3	0.9	1.5	14.3
08/22/2024 06:00	0.8	14.3	0.9	1.5	14.3
08/22/2024 07:00	0.7	14.3	0.9	1.5	14.3
08/22/2024 08:00	0.7	14.3	0.9	1.5	14.3
08/22/2024 09:00	0.7	14.3	0.9	1.5	14.4
08/22/2024 10:00	0.7	14.3	0.9	1.5	14.4
08/22/2024 11:00	0.7	14.3	0.9	1.5	14.4
08/22/2024 12:00	0.6	14.4	0.9	1.5	14.4
08/22/2024 13:00	0.6	14.4	0.9	1.5	14.4
08/22/2024 14:00	0.6	14.4	0.8	1.5	14.4
08/22/2024 15:00	0.6	14.4	0.8	1.5	14.4
08/22/2024 16:00	0.6	14.4	0.8	1.5	14.4
08/22/2024 17:00	0.6	14.4	0.8	1.5	14.4
08/22/2024 18:00	0.6	14.4	0.8	1.5	14.4
08/22/2024 19:00	0.7	14.3	0.9	1.5	14.4
08/22/2024 20:00	0.7	14.3	0.9	1.5	14.4
08/22/2024 21:00	0.7	14.3	0.9	1.5	14.4
08/22/2024 22:00	0.7	14.3	0.9	1.5	14.3
08/22/2024 23:00	0.7	14.3	0.9	1.5	14.3
Average/Sum#:	0.7	14.3	0.9	1.5	14.4
Minimum:	0.6	14.3	0.8	1.5	14.3
Maximum:	0.8	14.4	0.9	1.5	14.4
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/23/2024 00:00	0.7	14.3	0.9	1.5	14.3
08/23/2024 01:00	0.7	14.3	0.9	1.5	14.3
08/23/2024 02:00	0.7	14.3	0.9	1.5	14.3
08/23/2024 03:00	0.8	14.3	0.9	1.5	14.3
08/23/2024 04:00	0.8	14.3	1.0	1.5	14.3
08/23/2024 05:00	0.8	14.2	1.0	1.5	14.3
08/23/2024 06:00	0.8	14.3	1.0	1.5	14.3
08/23/2024 07:00	0.8	14.3	0.9	1.5	14.3
08/23/2024 08:00	0.8	14.3	0.9	1.5	14.3
08/23/2024 09:00	0.7	14.3	0.9	1.5	14.4
08/23/2024 10:00	0.7	14.3	0.9	1.5	14.4
08/23/2024 11:00	0.7	14.4	0.9	1.5	14.4
08/23/2024 12:00	0.7	14.4	0.9	1.5	14.4
08/23/2024 13:00	0.7	14.4	0.9	1.5	14.4
08/23/2024 14:00	0.7	14.4	0.9	1.5	14.4
08/23/2024 15:00	0.7	14.4	0.9	1.5	14.4
08/23/2024 16:00	0.7	14.3	0.9	1.5	14.4
08/23/2024 17:00	0.7	14.3	0.9	1.5	14.4
08/23/2024 18:00	0.7	14.3	0.9	1.5	14.4
08/23/2024 19:00	0.7	14.3	0.9	1.5	14.4
08/23/2024 20:00	0.7	14.3	0.9	1.5	14.4
08/23/2024 21:00	0.7	14.3	0.9	1.5	14.4
08/23/2024 22:00	0.8	14.3	0.9	1.5	14.4
08/23/2024 23:00	0.7	14.4	0.9	1.5	14.4
Average/Sum#:	0.7	14.3	0.9	1.5	14.4
Minimum:	0.7	14.2	0.9	1.5	14.3
Maximum:	0.8	14.4	1.0	1.5	14.4
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/24/2024 00:00	0.7	14.3	0.9	1.5	14.4
08/24/2024 01:00	0.7	14.3	0.9	1.5	14.3
08/24/2024 02:00	0.8	14.3	0.9	1.5	14.3
08/24/2024 03:00	0.8	14.3	0.9	1.5	14.3
08/24/2024 04:00	0.8	14.3	0.9	1.5	14.3
08/24/2024 05:00	0.7	14.3	0.9	1.5	14.3
08/24/2024 06:00	0.8	14.3	0.9	1.5	14.3
08/24/2024 07:00	0.8	14.2	0.9	1.5	14.3
08/24/2024 08:00	0.8	14.2	1.0	1.5	14.3
08/24/2024 09:00	0.8	14.3	0.9	1.5	14.3
08/24/2024 10:00	0.7	14.3	0.9	1.5	14.3
08/24/2024 11:00	0.7	14.3	0.9	1.5	14.4
08/24/2024 12:00	0.7	14.3	0.9	1.5	14.4
08/24/2024 13:00	0.8	14.3	0.9	1.5	14.4
08/24/2024 14:00	0.8	14.3	0.9	1.5	14.3
08/24/2024 15:00	0.8	14.3	0.9	1.5	14.3
08/24/2024 16:00	0.7	14.3	0.9	1.5	14.4
08/24/2024 17:00	0.8	14.3	0.9	1.5	14.4
08/24/2024 18:00	0.8	14.3	0.9	1.5	14.4
08/24/2024 19:00	0.8	14.3	0.9	1.5	14.4
08/24/2024 20:00	0.9	14.3	1.0	1.5	14.4
08/24/2024 21:00	0.8	14.3	1.0	1.5	14.3
08/24/2024 22:00	1.0	14.3	1.1	1.5	14.3
08/24/2024 23:00	1.0	14.2	1.1	1.5	14.3
Average/Sum#:	0.8	14.3	0.9	1.5	14.3
Minimum:	0.7	14.2	0.9	1.5	14.3
Maximum:	1.0	14.3	1.1	1.5	14.4
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/25/2024 00:00	1.0	14.2	1.1	1.5	14.3
08/25/2024 01:00	1.0	14.2	1.2	1.5	14.3
08/25/2024 02:00	1.0	14.2	1.2	1.4	14.3
08/25/2024 03:00	1.0	14.2	1.2	1.5	14.3
08/25/2024 04:00	0.9	14.2	1.1	1.5	14.3
08/25/2024 05:00	0.9	14.2	1.1	1.5	14.3
08/25/2024 06:00	0.9	14.2	1.1	1.5	14.3
08/25/2024 07:00	1.0	14.2	1.1	1.5	14.3
08/25/2024 08:00	0.9	14.3	1.0	1.5	14.3
08/25/2024 09:00	0.8	14.3	1.0	1.5	14.4
08/25/2024 10:00	0.8	14.4	0.9	1.5	14.4
08/25/2024 11:00	0.7	14.4	0.9	1.5	14.4
08/25/2024 12:00	0.7	14.4	0.9	1.5	14.5
08/25/2024 13:00	0.7	14.4	0.9	1.5	14.5
08/25/2024 14:00	0.7	14.5	0.9	1.5	14.5
08/25/2024 15:00	0.6	14.5	0.9	1.5	14.5
08/25/2024 16:00	0.6	14.4	0.8	1.5	14.4
08/25/2024 17:00	0.6	14.5	0.9	1.5	14.5
08/25/2024 18:00	0.6	14.6	0.9	1.5	14.7
08/25/2024 19:00	0.7	14.6	0.9	1.5	14.7
08/25/2024 20:00	0.7	14.5	0.9	1.5	14.6
08/25/2024 21:00	0.7	14.4	0.9	1.5	14.4
08/25/2024 22:00	0.8	14.4	1.0	1.5	14.4
08/25/2024 23:00	0.8	14.4	1.0	1.5	14.4
Average/Sum#:	0.8	14.4	1.0	1.5	14.4
Minimum:	0.6	14.2	0.8	1.4	14.3
Maximum:	1.0	14.6	1.2	1.5	14.7
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/26/2024 00:00	0.8	14.3	1.0	1.5	14.4
08/26/2024 01:00	0.8	14.3	1.0	1.5	14.4
08/26/2024 02:00	0.8	14.3	0.9	1.5	14.3
08/26/2024 03:00	0.8	14.3	1.0	1.5	14.3
08/26/2024 04:00	0.7	14.4	0.9	1.5	14.4
08/26/2024 05:00	0.7	14.4	0.9	1.5	14.5
08/26/2024 06:00	0.8	14.2	1.0	1.5	14.3
08/26/2024 07:00	0.8	14.2	1.0	1.5	14.3
08/26/2024 08:00	0.8	14.2	1.0	1.5	14.3
08/26/2024 09:00	0.7	14.4	0.9	1.5	14.4
08/26/2024 10:00	0.7	14.4	0.9	1.5	14.4
08/26/2024 11:00	0.6	14.5	0.9	1.5	14.5
08/26/2024 12:00	0.6	14.5	0.9	1.5	14.5
08/26/2024 13:00	0.6	14.5	0.9	1.5	14.5
08/26/2024 14:00	0.6	14.5	0.9	1.5	14.5
08/26/2024 15:00	0.6	14.5	0.9	1.5	14.5
08/26/2024 16:00	0.7	14.5	0.9	1.5	14.5
08/26/2024 17:00	0.6	14.4	0.8	1.5	14.4
08/26/2024 18:00	0.7	14.4	0.9	1.5	14.4
08/26/2024 19:00	0.7	14.4	0.9	1.5	14.4
08/26/2024 20:00	0.7	14.5	0.9	1.5	14.5
08/26/2024 21:00	0.8	14.4	1.0	1.5	14.4
08/26/2024 22:00	0.8	14.4	1.0	1.5	14.4
08/26/2024 23:00	0.8	14.4	1.0	1.5	14.4
Average/Sum#:	0.7	14.4	0.9	1.5	14.4
Minimum:	0.6	14.2	0.8	1.5	14.3
Maximum:	0.8	14.5	1.0	1.5	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/27/2024 00:00	0.8	14.4	1.0	1.5	14.4
08/27/2024 01:00	0.8	14.4	0.9	1.5	14.4
08/27/2024 02:00	0.8	14.3	0.9	1.5	14.4
08/27/2024 03:00	0.9	14.3	1.0	1.5	14.4
08/27/2024 04:00	0.8	14.3	1.0	1.5	14.4
08/27/2024 05:00	0.8	14.3	1.0	1.5	14.4
08/27/2024 06:00	0.9	14.3	1.0	1.5	14.4
08/27/2024 07:00	0.9	14.3	1.1	1.5	14.4
08/27/2024 08:00	0.8	14.3	1.0	1.5	14.4
08/27/2024 09:00	0.8	14.4	1.0	1.5	14.4
08/27/2024 10:00	0.7	14.4	0.9	1.5	14.5
08/27/2024 11:00	0.7	14.5	0.9	1.5	14.5
08/27/2024 12:00	0.7	14.5	0.9	1.5	14.5
08/27/2024 13:00	0.7	14.5	0.9	1.5	14.5
08/27/2024 14:00	0.7	14.5	0.9	1.5	14.5
08/27/2024 15:00	0.6	14.5	0.9	1.5	14.6
08/27/2024 16:00	0.7	14.6	0.9	1.5	14.6
08/27/2024 17:00	0.6	14.6	0.9	1.5	14.6
08/27/2024 18:00	0.6	14.5	0.9	1.5	14.5
08/27/2024 19:00	0.7	14.5	0.9	1.5	14.5
08/27/2024 20:00	0.8	14.5	1.0	1.5	14.5
08/27/2024 21:00	0.8	14.5	1.0	1.5	14.5
08/27/2024 22:00	0.8	14.4	1.0	1.5	14.4
08/27/2024 23:00	0.8	14.4	1.0	1.5	14.4
Average/Sum#:	0.8	14.4	1.0	1.5	14.5
Minimum:	0.6	14.3	0.9	1.5	14.4
Maximum:	0.9	14.6	1.1	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/28/2024 00:00	0.8	14.4	1.0	1.5	14.4
08/28/2024 01:00	0.8	14.4	0.9	1.5	14.4
08/28/2024 02:00	0.8	14.4	0.9	1.6	14.4
08/28/2024 03:00	0.9	14.3	1.0	1.5	14.4
08/28/2024 04:00	0.8	14.4	0.9	1.5	14.4
08/28/2024 05:00	0.8	14.4	1.0	1.5	14.4
08/28/2024 06:00	1.0	14.2	1.1	1.5	14.3
08/28/2024 07:00	0.9	14.2	1.1	1.5	14.3
08/28/2024 08:00	0.9	14.3	1.0	1.5	14.3
08/28/2024 09:00	0.8	14.3	1.0	1.5	14.3
08/28/2024 10:00	0.8	14.3	1.0	1.5	14.3
08/28/2024 11:00	0.7	14.5	1.0	1.5	14.5
08/28/2024 12:00	0.7	14.5	0.9	1.5	14.5
08/28/2024 13:00	0.7	14.5	0.9	1.5	14.5
08/28/2024 14:00	0.7	14.5	0.9	1.5	14.5
08/28/2024 15:00	0.7	14.5	0.9	1.5	14.6
08/28/2024 16:00	0.7	14.5	0.9	1.5	14.6
08/28/2024 17:00	0.7	14.6	0.9	1.5	14.6
08/28/2024 18:00	0.7	14.5	0.9	1.5	14.6
08/28/2024 19:00	0.7	14.5	0.9	1.5	14.5
08/28/2024 20:00	0.7	14.5	0.9	1.5	14.5
08/28/2024 21:00	0.7	14.5	1.0	1.5	14.5
08/28/2024 22:00	0.7	14.4	0.9	1.5	14.4
08/28/2024 23:00	0.7	14.4	0.9	1.5	14.4
Average/Sum#:	0.8	14.4	1.0	1.5	14.4
Minimum:	0.7	14.2	0.9	1.5	14.3
Maximum:	1.0	14.6	1.1	1.6	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/29/2024 00:00	0.8	14.4	1.0	1.5	14.4
08/29/2024 01:00	0.8	14.3	1.0	1.5	14.4
08/29/2024 02:00	0.8	14.3	1.0	1.5	14.4
08/29/2024 03:00	0.9	14.3	1.0	1.5	14.4
08/29/2024 04:00	0.8	14.3	1.0	1.5	14.4
08/29/2024 05:00	0.8	14.3	0.9	1.5	14.3
08/29/2024 06:00	0.6	14.4	0.9	1.5	14.5
08/29/2024 07:00	0.7	14.4	0.9	1.5	14.5
08/29/2024 08:00	0.6	14.4	0.9	1.5	14.5
08/29/2024 09:00	0.7	14.4	0.9	1.5	14.4
08/29/2024 10:00	0.7	14.4	0.9	1.5	14.4
08/29/2024 11:00	0.7	14.5	0.9	1.5	14.5
08/29/2024 12:00	0.7	14.5	0.9	1.5	14.5
08/29/2024 13:00	0.7	14.5	0.9	1.5	14.5
08/29/2024 14:00	0.7	14.5	0.9	1.5	14.5
08/29/2024 15:00	0.7	14.5	0.9	1.5	14.6
08/29/2024 16:00	0.6	14.5	0.9	1.5	14.6
08/29/2024 17:00	0.7	14.5	0.9	1.5	14.5
08/29/2024 18:00	0.7	14.5	0.9	1.5	14.5
08/29/2024 19:00	0.7	14.4	0.9	1.5	14.4
08/29/2024 20:00	0.7	14.4	0.9	1.5	14.4
08/29/2024 21:00	0.7	14.4	1.0	1.5	14.4
08/29/2024 22:00	0.7	14.4	0.9	1.5	14.4
08/29/2024 23:00	0.7	14.4	0.9	1.5	14.4
Average/Sum#:	0.7	14.4	0.9	1.5	14.5
Minimum:	0.6	14.3	0.9	1.5	14.3
Maximum:	0.9	14.5	1.0	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/30/2024 00:00	0.7	14.3	0.9	1.5	14.4
08/30/2024 01:00	0.7	14.3	1.0	1.5	14.3
08/30/2024 02:00	0.8	14.3	1.0	1.6	14.3
08/30/2024 03:00	0.9	14.3	1.0	1.5	14.3
08/30/2024 04:00	0.8	14.3	1.0	1.5	14.3
08/30/2024 05:00	0.8	14.3	1.0	1.5	14.3
08/30/2024 06:00	0.8	14.3	1.0	1.5	14.3
08/30/2024 07:00	0.8	14.3	1.0	1.5	14.3
08/30/2024 08:00	0.8	14.3	0.9	1.5	14.4
08/30/2024 09:00	0.8	14.4	0.9	1.5	14.4
08/30/2024 10:00	0.8	14.4	0.9	1.5	14.4
08/30/2024 11:00	0.7	14.4	0.9	1.5	14.5
08/30/2024 12:00	0.7	14.5	0.9	1.5	14.5
08/30/2024 13:00	0.7	14.5	0.9	1.5	14.5
08/30/2024 14:00	0.7	14.5	0.9	1.5	14.5
08/30/2024 15:00	0.7	14.5	0.9	1.5	14.6
08/30/2024 16:00	0.7	14.6	0.9	1.5	14.6
08/30/2024 17:00	0.7	14.5	0.9	1.5	14.5
08/30/2024 18:00	0.7	14.5	0.9	1.5	14.5
08/30/2024 19:00	0.7	14.4	0.9	1.5	14.5
08/30/2024 20:00	0.8	14.4	0.9	1.5	14.4
08/30/2024 21:00	0.8	14.4	0.9	1.5	14.4
08/30/2024 22:00	0.8	14.4	1.0	1.5	14.4
08/30/2024 23:00	0.8	14.4	1.0	1.5	14.4
Average/Sum#:	0.8	14.4	0.9	1.5	14.4
Minimum:	0.7	14.3	0.9	1.5	14.3
Maximum:	0.9	14.6	1.0	1.6	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
08/31/2024 00:00	0.8	14.3	1.0	1.5	14.4
08/31/2024 01:00	0.8	14.3	1.0	1.5	14.4
08/31/2024 02:00	0.8	14.3	1.0	1.5	14.4
08/31/2024 03:00	0.9	14.3	1.0	1.5	14.4
08/31/2024 04:00	0.8	14.3	1.0	1.5	14.3
08/31/2024 05:00	0.8	14.3	1.0	1.5	14.3
08/31/2024 06:00	0.8	14.3	1.0	1.5	14.3
08/31/2024 07:00	0.8	14.3	1.0	1.5	14.3
08/31/2024 08:00	0.8	14.3	0.9	1.5	14.4
08/31/2024 09:00	0.8	14.4	1.0	1.5	14.4
08/31/2024 10:00	0.7	14.4	0.9	1.5	14.4
08/31/2024 11:00	0.7	14.4	0.9	1.5	14.5
08/31/2024 12:00	0.7	14.5	0.9	1.5	14.5
08/31/2024 13:00	0.7	14.5	0.9	1.5	14.5
08/31/2024 14:00	0.7	14.5	0.9	1.5	14.5
08/31/2024 15:00	0.7	14.5	0.9	1.5	14.6
08/31/2024 16:00	0.7	14.2	0.9	1.5	14.2
08/31/2024 17:00	0.2	12.5	0.4	1.5	12.6
08/31/2024 18:00	0.2	12.6	0.4	1.5	12.7
08/31/2024 19:00	0.2	12.5	0.4	1.5	12.6
08/31/2024 20:00	0.7	13.5	0.8	1.5	13.5
08/31/2024 21:00	0.7	14.5	0.9	1.5	14.4
08/31/2024 22:00	0.7	14.6	0.9	1.5	14.5
08/31/2024 23:00	0.7	14.5	1.2	1.5	14.3
Average/Sum#:	0.7	14.1	0.9	1.5	14.1
Minimum:	0.2	12.5	0.4	1.5	12.6
Maximum:	0.9	14.6	1.2	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/01/2024 00:00	0.8	14.3	0.9	1.5	14.4
09/01/2024 01:00	0.8	14.3	1.0	1.5	14.4
09/01/2024 02:00	0.8	14.3	1.0	1.5	14.4
09/01/2024 03:00	0.9	14.3	1.0	1.5	14.3
09/01/2024 04:00	0.8	14.3	1.0	1.5	14.3
09/01/2024 05:00	0.8	14.3	1.0	1.5	14.3
09/01/2024 06:00	0.8	14.3	0.9	1.5	14.3
09/01/2024 07:00	0.8	14.3	0.9	1.5	14.3
09/01/2024 08:00	0.8	14.3	1.0	1.5	14.4
09/01/2024 09:00	0.8	14.4	0.9	1.5	14.4
09/01/2024 10:00	0.7	14.4	0.9	1.5	14.4
09/01/2024 11:00	0.7	14.4	0.9	1.5	14.4
09/01/2024 12:00	0.7	14.5	0.9	1.5	14.5
09/01/2024 13:00	0.7	14.5	0.9	1.5	14.5
09/01/2024 14:00	0.7	14.5	0.9	1.5	14.5
09/01/2024 15:00	0.7	14.4	0.9	1.5	14.4
09/01/2024 16:00	0.7	14.3	0.9	1.5	14.5
09/01/2024 17:00	0.7	14.4	0.9	1.5	14.6
09/01/2024 18:00	0.7	14.3	0.9	1.5	14.5
09/01/2024 19:00	0.7	14.3	0.9	1.5	14.4
09/01/2024 20:00	0.7	14.3	0.9	1.5	14.4
09/01/2024 21:00	0.8	14.3	1.0	1.5	14.4
09/01/2024 22:00	0.8	14.3	0.9	1.5	14.4
09/01/2024 23:00	0.8	14.2	1.0	1.5	14.4
Average/Sum#:	0.8	14.3	0.9	1.5	14.4
Minimum:	0.7	14.2	0.9	1.5	14.3
Maximum:	0.9	14.5	1.0	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/02/2024 00:00	0.7	14.3	1.0	1.5	14.4
09/02/2024 01:00	0.8	14.2	1.0	1.5	14.3
09/02/2024 02:00	0.8	14.2	0.9	1.4	14.3
09/02/2024 03:00	0.9	14.2	1.0	1.4	14.3
09/02/2024 04:00	0.8	14.2	1.0	1.4	14.3
09/02/2024 05:00	0.8	14.2	1.0	1.2	14.3
09/02/2024 06:00	0.8	14.2	1.0	1.2	14.3
09/02/2024 07:00	0.8	14.2	1.0	1.5	14.3
09/02/2024 08:00	0.8	14.2	1.0	1.5	14.3
09/02/2024 09:00	0.8	14.2	1.0	1.5	14.4
09/02/2024 10:00	0.8	14.2	0.9	1.5	14.4
09/02/2024 11:00	0.8	14.3	0.9	1.5	14.4
09/02/2024 12:00	0.7	14.3	0.9	1.5	14.5
09/02/2024 13:00	0.7	14.3	0.9	1.5	14.5
09/02/2024 14:00	0.7	14.4	0.9	1.5	14.6
09/02/2024 15:00	0.7	14.5	0.9	1.5	14.5
09/02/2024 16:00	0.7	14.5	0.9	1.4	14.5
09/02/2024 17:00	0.6	14.4	0.9	1.5	14.4
09/02/2024 18:00	0.6	14.4	0.9	1.5	14.4
09/02/2024 19:00	0.7	14.4	0.9	1.5	14.4
09/02/2024 20:00	0.8	14.4	0.9	1.5	14.4
09/02/2024 21:00	0.8	14.3	1.0	1.5	14.4
09/02/2024 22:00	0.8	14.3	0.9	1.5	14.4
09/02/2024 23:00	0.8	14.3	1.0	1.5	14.4
Average/Sum#:	0.8	14.3	0.9	1.5	14.4
Minimum:	0.6	14.2	0.9	1.2	14.3
Maximum:	0.9	14.5	1.0	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/03/2024 00:00	0.8	14.3	1.0	1.5	14.4
09/03/2024 01:00	0.8	14.3	1.0	1.5	14.3
09/03/2024 02:00	1.0	14.3	1.1	1.6	14.3
09/03/2024 03:00	1.2	14.3	1.2	1.5	14.3
09/03/2024 04:00	1.1	14.3	1.1	1.5	14.3
09/03/2024 05:00	1.0	14.4	1.1	1.4	14.4
09/03/2024 06:00	1.0	14.3	1.1	1.3	14.3
09/03/2024 07:00	0.9	14.4	1.0	1.5	14.4
09/03/2024 08:00	0.9	14.4	1.0	1.5	14.4
09/03/2024 09:00	0.8	14.4	1.0	1.5	14.4
09/03/2024 10:00	0.7	14.4	1.0	1.5	14.5
09/03/2024 11:00	0.7	14.4	1.0	1.5	14.5
09/03/2024 12:00	0.7	14.5	0.9	1.5	14.5
09/03/2024 13:00	0.6	14.5	0.9	1.5	14.5
09/03/2024 14:00	0.6	14.4	0.9	1.5	14.5
09/03/2024 15:00	0.6	14.4	0.9	1.5	14.4
09/03/2024 16:00	0.6	13.9	0.9	1.5	14.0
09/03/2024 17:00	0.2	12.5	0.4	1.6	12.6
09/03/2024 18:00	0.1	12.4	0.4	1.5	12.5
09/03/2024 19:00	0.7	13.4	0.8	1.5	13.5
09/03/2024 20:00	0.6	14.5	0.9	1.5	14.5
09/03/2024 21:00	0.7	14.5	0.9	1.5	14.5
09/03/2024 22:00	0.7	14.4	1.0	1.5	14.5
09/03/2024 23:00	0.8	14.6	1.0	1.5	14.6
Average/Sum#:	0.7	14.2	0.9	1.5	14.2
Minimum:	0.1	12.4	0.4	1.3	12.5
Maximum:	1.2	14.6	1.2	1.6	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/04/2024 00:00	0.8	14.5	1.1	1.5	14.5
09/04/2024 01:00	0.9	14.4	1.1	1.5	14.5
09/04/2024 02:00	0.9	14.4	1.2	1.6	14.4
09/04/2024 03:00	0.9	14.5	1.1	1.5	14.5
09/04/2024 04:00	0.9	14.4	1.2	1.5	14.5
09/04/2024 05:00	0.9	14.5	1.2	1.5	14.5
09/04/2024 06:00	1.1	14.3	1.3	1.5	14.4
09/04/2024 07:00	1.0	14.3	1.3	1.5	14.4
09/04/2024 08:00	0.9	14.4	1.1	1.5	14.4
09/04/2024 09:00	0.8	14.4	1.0	1.5	14.5
09/04/2024 10:00	0.7	14.5	0.9	1.5	14.5
09/04/2024 11:00	0.7	14.5	0.9	1.5	14.5
09/04/2024 12:00	0.0	0.0	0.9	1.5	14.6
09/04/2024 13:00	0.0	0.0	0.9	1.4	14.6
09/04/2024 14:00	0.6	14.6	0.9	1.5	14.5
09/04/2024 15:00	0.6	14.5	0.9	1.5	14.4
09/04/2024 16:00	0.5	14.0	0.8	1.5	13.9
09/04/2024 17:00	0.0	12.2	0.3	1.5	12.2
09/04/2024 18:00	0.0	12.4	0.3	1.5	12.4
09/04/2024 19:00	0.0	12.6	0.4	1.5	12.6
09/04/2024 20:00	0.1	12.7	0.4	1.5	12.7
09/04/2024 21:00	0.1	12.7	0.4	1.5	12.7
09/04/2024 22:00	0.2	12.9	0.5	1.5	12.9
09/04/2024 23:00	0.6	13.6	0.8	1.5	13.6
Average/Sum#:	0.6	13.9	0.9	1.5	13.9
Minimum:	0.0	12.2	0.3	1.4	12.2
Maximum:	1.1	14.6	1.3	1.6	14.6
%SI	8.33	8.33	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/05/2024 00:00	0.6	14.6	1.0	1.5	14.5
09/05/2024 01:00	0.7	14.5	1.0	1.5	14.4
09/05/2024 02:00	0.6	14.5	1.0	1.5	14.4
09/05/2024 03:00	0.7	14.5	1.0	1.5	14.4
09/05/2024 04:00	0.6	14.6	1.0	1.5	14.5
09/05/2024 05:00	0.6	14.7	0.9	1.5	14.5
09/05/2024 06:00	0.6	14.6	1.0	1.5	14.4
09/05/2024 07:00	0.6	14.5	1.0	1.5	14.4
09/05/2024 08:00	0.6	14.5	0.9	1.5	14.4
09/05/2024 09:00	0.6	14.6	0.9	1.5	14.5
09/05/2024 10:00	0.5	14.6	0.9	1.5	14.5
09/05/2024 11:00	0.6	14.6	0.9	1.5	14.5
09/05/2024 12:00	0.5	14.7	0.8	1.5	14.5
09/05/2024 13:00	0.5	14.0	0.8	1.5	13.9
09/05/2024 14:00	0.0	12.2	0.3	1.5	12.2
09/05/2024 15:00	0.1	12.6	0.4	1.5	12.6
09/05/2024 16:00	0.0	12.5	0.4	1.5	12.6
09/05/2024 17:00	0.0	12.3	0.3	1.5	12.4
09/05/2024 18:00	0.0	12.4	0.4	1.5	12.5
09/05/2024 19:00	0.0	12.6	0.4	1.5	12.6
09/05/2024 20:00	0.1	12.8	0.4	1.5	12.8
09/05/2024 21:00	0.1	12.9	0.4	1.5	12.9
09/05/2024 22:00	0.3	13.1	0.5	1.5	13.1
09/05/2024 23:00	0.5	13.4	0.7	1.5	13.3
Average/Sum#:	0.4	13.8	0.7	1.5	13.7
Minimum:	0.0	12.2	0.3	1.5	12.2
Maximum:	0.7	14.7	1.0	1.5	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/06/2024 00:00	0.7	14.6	1.0	1.5	14.5
09/06/2024 01:00	0.6	14.6	1.0	1.5	14.5
09/06/2024 02:00	0.6	14.5	0.9	1.5	14.4
09/06/2024 03:00	0.7	14.5	1.0	1.5	14.4
09/06/2024 04:00	0.6	14.6	0.9	1.5	14.5
09/06/2024 05:00	0.6	14.7	0.9	1.5	14.6
09/06/2024 06:00	0.6	14.6	0.9	1.5	14.5
09/06/2024 07:00	0.7	14.6	1.0	1.5	14.5
09/06/2024 08:00	0.7	14.5	1.0	1.5	14.4
09/06/2024 09:00	0.7	14.6	1.0	1.5	14.5
09/06/2024 10:00	0.6	14.6	1.0	1.5	14.5
09/06/2024 11:00	0.6	14.7	0.9	1.5	14.6
09/06/2024 12:00	0.5	14.7	0.8	1.5	14.6
09/06/2024 13:00	0.5	13.9	0.8	1.5	13.8
09/06/2024 14:00	0.0	12.4	0.3	1.5	12.4
09/06/2024 15:00	0.0	12.2	0.3	1.5	12.2
09/06/2024 16:00	0.1	12.6	0.4	1.5	12.7
09/06/2024 17:00	0.0	12.3	0.3	1.5	12.3
09/06/2024 18:00	0.0	12.1	0.3	1.5	12.2
09/06/2024 19:00	0.1	12.6	0.4	1.5	12.6
09/06/2024 20:00	0.1	12.7	0.4	1.5	12.7
09/06/2024 21:00	0.1	12.5	0.4	1.5	12.5
09/06/2024 22:00	0.1	12.6	0.4	1.5	12.7
09/06/2024 23:00	0.1	12.6	0.4	1.5	12.6
Average/Sum#:	0.4	13.7	0.7	1.5	13.6
Minimum:	0.0	12.1	0.3	1.5	12.2
Maximum:	0.7	14.7	1.0	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/07/2024 00:00	0.1	12.8	0.5	1.5	12.8
09/07/2024 01:00	0.6	13.7	0.9	1.5	13.6
09/07/2024 02:00	0.6	14.4	1.0	1.8	14.3
09/07/2024 03:00	0.7	14.4	1.0	1.5	14.3
09/07/2024 04:00	0.6	14.4	1.0	1.5	14.3
09/07/2024 05:00	0.6	14.5	0.9	1.5	14.4
09/07/2024 06:00	0.6	14.5	1.0	1.5	14.4
09/07/2024 07:00	0.6	14.6	1.0	1.5	14.5
09/07/2024 08:00	0.6	14.6	0.9	1.5	14.5
09/07/2024 09:00	0.6	14.6	0.9	1.5	14.5
09/07/2024 10:00	0.6	14.7	0.9	1.5	14.6
09/07/2024 11:00	0.5	14.7	0.9	1.5	14.6
09/07/2024 12:00	0.5	14.7	0.9	1.4	14.6
09/07/2024 13:00	0.5	14.7	0.8	1.5	14.5
09/07/2024 14:00	0.3	13.2	0.7	1.5	13.2
09/07/2024 15:00	0.3	13.3	0.6	1.5	13.2
09/07/2024 16:00	0.4	13.5	0.7	1.5	13.5
09/07/2024 17:00	0.1	12.7	0.4	1.5	12.7
09/07/2024 18:00	0.0	12.6	0.4	1.5	12.7
09/07/2024 19:00	0.1	12.8	0.4	1.5	12.8
09/07/2024 20:00	0.1	12.7	0.4	1.5	12.7
09/07/2024 21:00	0.1	12.8	0.4	1.5	12.8
09/07/2024 22:00	0.1	12.8	0.4	1.5	12.8
09/07/2024 23:00	0.4	13.2	0.7	1.5	13.1
Average/Sum#:	0.4	13.8	0.7	1.5	13.7
Minimum:	0.0	12.6	0.4	1.4	12.7
Maximum:	0.7	14.7	1.0	1.8	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/08/2024 00:00	0.7	14.5	1.0	1.5	14.4
09/08/2024 01:00	0.6	14.4	1.1	1.5	14.3
09/08/2024 02:00	0.6	14.4	1.1	1.5	14.3
09/08/2024 03:00	0.7	14.4	1.1	1.5	14.3
09/08/2024 04:00	0.6	14.4	1.0	1.5	14.3
09/08/2024 05:00	0.6	14.4	1.0	1.5	14.3
09/08/2024 06:00	0.6	14.4	1.0	1.5	14.3
09/08/2024 07:00	0.6	14.5	1.1	1.5	14.4
09/08/2024 08:00	0.6	14.5	1.0	1.5	14.4
09/08/2024 09:00	0.6	14.6	1.0	1.5	14.5
09/08/2024 10:00	0.6	14.6	0.9	1.5	14.5
09/08/2024 11:00	0.6	14.6	0.9	1.5	14.5
09/08/2024 12:00	0.5	14.7	0.9	1.5	14.6
09/08/2024 13:00	0.6	14.5	0.9	1.5	14.4
09/08/2024 14:00	0.2	13.1	0.6	1.6	13.0
09/08/2024 15:00	0.1	12.8	0.4	1.5	12.8
09/08/2024 16:00	0.0	12.3	0.3	1.5	12.3
09/08/2024 17:00	0.0	12.2	0.3	1.5	12.2
09/08/2024 18:00	0.0	12.4	0.3	1.5	12.4
09/08/2024 19:00	0.1	12.5	0.4	1.5	12.5
09/08/2024 20:00	0.1	12.6	0.4	1.5	12.6
09/08/2024 21:00	0.5	13.6	0.9	1.5	13.5
09/08/2024 22:00	0.6	14.5	1.0	1.5	14.4
09/08/2024 23:00	0.6	14.5	1.0	1.5	14.4
Average/Sum#:	0.4	13.9	0.8	1.5	13.8
Minimum:	0.0	12.2	0.3	1.5	12.2
Maximum:	0.7	14.7	1.1	1.6	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/09/2024 00:00	0.6	14.4	1.1	1.5	14.3
09/09/2024 01:00	0.7	14.5	1.1	1.5	14.4
09/09/2024 02:00	0.8	14.5	1.2	1.5	14.4
09/09/2024 03:00	0.9	14.5	1.3	1.5	14.4
09/09/2024 04:00	1.0	14.5	1.4	1.5	14.4
09/09/2024 05:00	0.8	14.5	1.2	1.5	14.4
09/09/2024 06:00	0.9	14.4	1.3	1.5	14.3
09/09/2024 07:00	0.9	14.4	1.3	1.5	14.3
09/09/2024 08:00	0.8	14.4	1.1	1.5	14.3
09/09/2024 09:00	0.7	14.6	1.0	1.5	14.5
09/09/2024 10:00	0.6	14.6	1.0	1.5	14.5
09/09/2024 11:00	0.6	14.6	0.9	1.5	14.5
09/09/2024 12:00	0.5	14.7	0.9	1.5	14.6
09/09/2024 13:00	0.5	14.6	0.9	1.4	14.5
09/09/2024 14:00	0.6	14.7	0.9	1.5	14.6
09/09/2024 15:00	0.5	14.7	0.9	1.5	14.6
09/09/2024 16:00	0.5	14.6	0.9	1.5	14.5
09/09/2024 17:00	0.5	14.0	0.8	1.5	13.9
09/09/2024 18:00	0.2	13.0	0.5	1.5	12.9
09/09/2024 19:00	0.6	14.0	0.9	1.5	13.9
09/09/2024 20:00	0.6	14.6	1.0	1.5	14.4
09/09/2024 21:00	0.6	14.6	1.0	1.5	14.5
09/09/2024 22:00	0.6	14.5	1.0	1.5	14.4
09/09/2024 23:00	0.6	14.6	0.9	1.5	14.5
Average/Sum#:	0.7	14.4	1.0	1.5	14.3
Minimum:	0.2	13.0	0.5	1.4	12.9
Maximum:	1.0	14.7	1.4	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/10/2024 00:00	0.6	14.5	1.0	1.5	14.4
09/10/2024 01:00	0.6	14.5	1.0	1.5	14.4
09/10/2024 02:00	0.6	14.4	1.0	1.5	14.3
09/10/2024 03:00	0.7	14.4	1.0	1.5	14.3
09/10/2024 04:00	0.6	14.4	1.0	1.5	14.3
09/10/2024 05:00	0.6	14.5	1.0	1.4	14.4
09/10/2024 06:00	0.6	14.4	1.0	1.5	14.3
09/10/2024 07:00	0.6	14.4	1.0	1.5	14.3
09/10/2024 08:00	0.6	14.4	1.0	1.5	14.3
09/10/2024 09:00	0.6	14.5	1.0	1.5	14.4
09/10/2024 10:00	0.6	14.5	1.0	1.5	14.4
09/10/2024 11:00	0.6	14.5	0.9	1.5	14.4
09/10/2024 12:00	0.6	14.5	1.0	1.5	14.4
09/10/2024 13:00	0.6	14.6	1.0	1.5	14.5
09/10/2024 14:00	0.6	14.6	0.9	1.5	14.5
09/10/2024 15:00	0.6	14.6	0.9	1.5	14.5
09/10/2024 16:00	0.6	14.6	1.0	1.5	14.5
09/10/2024 17:00	0.6	14.6	0.9	1.5	14.4
09/10/2024 18:00	0.6	14.5	0.9	1.5	14.4
09/10/2024 19:00	0.6	14.5	1.0	1.5	14.4
09/10/2024 20:00	0.6	14.4	1.0	1.5	14.4
09/10/2024 21:00	0.6	14.4	1.0	1.5	14.3
09/10/2024 22:00	0.6	14.4	1.0	1.5	14.3
09/10/2024 23:00	0.6	14.4	1.0	1.5	14.3
Average/Sum#:	0.6	14.5	1.0	1.5	14.4
Minimum:	0.6	14.4	0.9	1.4	14.3
Maximum:	0.7	14.6	1.0	1.5	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/11/2024 00:00	0.6	14.4	1.0	1.5	14.3
09/11/2024 01:00	0.6	14.4	1.0	1.5	14.3
09/11/2024 02:00	0.6	14.4	1.0	1.5	14.3
09/11/2024 03:00	0.7	14.4	1.0	1.5	14.3
09/11/2024 04:00	0.7	14.4	1.0	1.5	14.3
09/11/2024 05:00	0.6	14.5	0.9	1.5	14.4
09/11/2024 06:00	0.7	14.4	1.0	1.4	14.3
09/11/2024 07:00	0.7	14.4	1.0	1.5	14.3
09/11/2024 08:00	0.6	14.4	1.0	1.5	14.3
09/11/2024 09:00	0.6	14.4	1.1	1.5	14.4
09/11/2024 10:00	0.6	14.5	1.0	1.5	14.4
09/11/2024 11:00	0.6	14.5	1.0	1.5	14.4
09/11/2024 12:00	0.6	14.5	1.0	1.4	14.4
09/11/2024 13:00	0.6	14.6	1.0	1.5	14.5
09/11/2024 14:00	0.6	14.6	0.9	1.5	14.5
09/11/2024 15:00	0.6	14.6	1.0	1.5	14.5
09/11/2024 16:00	0.6	14.6	1.0	1.5	14.5
09/11/2024 17:00	0.6	14.6	1.0	1.5	14.5
09/11/2024 18:00	0.6	14.5	1.0	1.5	14.4
09/11/2024 19:00	0.6	14.5	1.0	1.5	14.4
09/11/2024 20:00	0.6	14.5	1.0	1.5	14.4
09/11/2024 21:00	0.6	14.5	1.0	1.5	14.4
09/11/2024 22:00	0.6	14.4	1.0	1.5	14.4
09/11/2024 23:00	0.6	14.4	1.0	1.5	14.3
Average/Sum#:	0.6	14.5	1.0	1.5	14.4
Minimum:	0.6	14.4	0.9	1.4	14.3
Maximum:	0.7	14.6	1.1	1.5	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/12/2024 00:00	0.6	14.4	1.0	1.5	14.3
09/12/2024 01:00	0.6	14.4	1.0	1.5	14.3
09/12/2024 02:00	0.6	14.4	1.0	1.5	14.3
09/12/2024 03:00	0.8	14.4	1.0	1.5	14.3
09/12/2024 04:00	0.7	14.4	1.0	1.5	14.3
09/12/2024 05:00	0.9	14.4	1.1	1.4	14.3
09/12/2024 06:00	1.1	14.4	1.5	1.4	14.3
09/12/2024 07:00	0.8	14.4	0.8	1.6	14.4
09/12/2024 08:00	0.7	14.4	0.8	1.5	14.4
09/12/2024 09:00	0.6	14.3	0.8	1.5	14.4
09/12/2024 10:00	0.5	14.4	0.8	1.5	14.4
09/12/2024 11:00	0.5	14.4	0.7	1.5	14.5
09/12/2024 12:00	0.5	14.4	0.7	1.5	14.5
09/12/2024 13:00	0.5	14.5	0.7	1.5	14.5
09/12/2024 14:00	0.5	14.5	0.7	1.5	14.5
09/12/2024 15:00	0.5	14.5	0.7	1.5	14.5
09/12/2024 16:00	0.5	14.5	0.7	1.5	14.5
09/12/2024 17:00	0.5	14.5	0.7	1.5	14.5
09/12/2024 18:00	0.5	14.5	0.7	1.5	14.5
09/12/2024 19:00	0.5	14.4	0.7	1.5	14.5
09/12/2024 20:00	0.5	14.4	0.8	1.5	14.5
09/12/2024 21:00	0.5	14.4	0.8	1.5	14.5
09/12/2024 22:00	0.6	14.4	0.9	1.5	14.4
09/12/2024 23:00	0.6	14.3	0.9	1.5	14.4
Average/Sum#:	0.6	14.4	0.9	1.5	14.4
Minimum:	0.5	14.3	0.7	1.4	14.3
Maximum:	1.1	14.5	1.5	1.6	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/13/2024 00:00	0.6	14.3	0.9	1.5	14.4
09/13/2024 01:00	0.6	14.3	0.8	1.5	14.4
09/13/2024 02:00	0.6	14.3	0.8	1.5	14.4
09/13/2024 03:00	0.6	14.3	0.8	1.5	14.4
09/13/2024 04:00	0.6	14.3	0.7	1.5	14.4
09/13/2024 05:00	0.6	14.5	0.8	1.5	14.5
09/13/2024 06:00	0.6	14.4	0.8	1.5	14.4
09/13/2024 07:00	0.6	14.3	0.8	1.5	14.4
09/13/2024 08:00	0.6	14.4	0.8	1.5	14.4
09/13/2024 09:00	0.5	14.4	0.8	1.5	14.5
09/13/2024 10:00	0.5	14.4	0.7	1.5	14.5
09/13/2024 11:00	0.6	14.5	0.7	1.5	14.5
09/13/2024 12:00	0.5	14.5	0.7	1.4	14.6
09/13/2024 13:00	0.5	14.5	0.7	1.5	14.5
09/13/2024 14:00	0.5	14.5	0.7	1.5	14.5
09/13/2024 15:00	0.5	14.5	0.7	1.5	14.5
09/13/2024 16:00	0.6	14.4	0.8	1.5	14.4
09/13/2024 17:00	0.1	12.1	0.2	1.5	12.2
09/13/2024 18:00	0.1	12.3	0.3	1.5	12.4
09/13/2024 19:00	0.6	14.2	0.8	1.4	14.2
09/13/2024 20:00	0.6	14.3	0.8	1.5	14.4
09/13/2024 21:00	0.6	14.3	0.8	1.5	14.4
09/13/2024 22:00	0.6	14.4	0.8	1.5	14.4
09/13/2024 23:00	0.6	14.5	0.8	1.5	14.5
Average/Sum#:	0.5	14.2	0.7	1.5	14.3
Minimum:	0.1	12.1	0.2	1.4	12.2
Maximum:	0.6	14.5	0.9	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/14/2024 00:00	0.6	14.5	0.8	1.5	14.5
09/14/2024 01:00	0.6	14.4	0.8	1.5	14.4
09/14/2024 02:00	0.6	14.4	0.8	1.5	14.4
09/14/2024 03:00	0.6	14.6	0.7	1.5	14.6
09/14/2024 04:00	0.6	14.5	0.8	1.5	14.5
09/14/2024 05:00	0.6	14.6	0.8	1.5	14.6
09/14/2024 06:00	0.6	14.4	0.8	1.4	14.4
09/14/2024 07:00	0.5	14.4	0.8	1.5	14.4
09/14/2024 08:00	0.5	14.4	0.8	1.5	14.5
09/14/2024 09:00	0.6	14.5	0.8	1.5	14.5
09/14/2024 10:00	0.6	14.5	0.8	1.5	14.5
09/14/2024 11:00	0.5	14.5	0.7	1.5	14.5
09/14/2024 12:00	0.5	14.5	0.7	1.5	14.5
09/14/2024 13:00	0.5	14.5	0.7	1.5	14.6
09/14/2024 14:00	0.5	14.5	0.7	1.5	14.6
09/14/2024 15:00	0.5	14.5	0.8	1.5	14.6
09/14/2024 16:00	0.5	14.6	0.7	1.5	14.6
09/14/2024 17:00	0.4	14.5	0.7	1.4	14.5
09/14/2024 18:00	0.5	14.4	0.7	1.4	14.4
09/14/2024 19:00	0.5	14.3	0.7	1.5	14.4
09/14/2024 20:00	0.5	14.4	0.8	1.5	14.4
09/14/2024 21:00	0.5	14.4	0.7	1.5	14.4
09/14/2024 22:00	0.5	14.4	0.8	1.5	14.4
09/14/2024 23:00	0.5	14.4	0.7	1.5	14.4
Average/Sum#:	0.5	14.5	0.8	1.5	14.5
Minimum:	0.4	14.3	0.7	1.4	14.4
Maximum:	0.6	14.6	0.8	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/15/2024 00:00	0.5	14.4	0.8	1.5	14.4
09/15/2024 01:00	0.5	14.4	0.8	1.5	14.4
09/15/2024 02:00	0.5	14.3	0.7	1.5	14.4
09/15/2024 03:00	0.6	14.3	0.8	1.5	14.4
09/15/2024 04:00	0.5	14.3	0.8	1.5	14.4
09/15/2024 05:00	0.5	14.3	0.8	1.5	14.4
09/15/2024 06:00	0.5	14.3	0.8	1.5	14.4
09/15/2024 07:00	0.5	14.3	0.7	1.5	14.4
09/15/2024 08:00	0.5	14.3	0.8	1.5	14.4
09/15/2024 09:00	0.5	14.3	0.7	1.5	14.4
09/15/2024 10:00	0.5	14.3	0.7	1.5	14.4
09/15/2024 11:00	0.5	14.3	0.7	1.5	14.4
09/15/2024 12:00	0.5	14.4	0.7	1.5	14.4
09/15/2024 13:00	0.5	14.4	0.7	1.5	14.4
09/15/2024 14:00	0.5	14.4	0.7	1.5	14.5
09/15/2024 15:00	0.5	14.4	0.7	1.5	14.4
09/15/2024 16:00	0.5	14.4	0.7	1.5	14.5
09/15/2024 17:00	0.5	14.3	0.7	1.5	14.4
09/15/2024 18:00	0.5	14.3	0.7	1.5	14.4
09/15/2024 19:00	0.5	14.3	0.7	1.5	14.4
09/15/2024 20:00	0.5	14.3	0.7	1.5	14.4
09/15/2024 21:00	0.5	14.3	0.7	1.5	14.4
09/15/2024 22:00	0.6	14.3	0.8	1.5	14.4
09/15/2024 23:00	0.6	14.3	0.7	1.5	14.4
Average/Sum#:	0.5	14.3	0.7	1.5	14.4
Minimum:	0.5	14.3	0.7	1.5	14.4
Maximum:	0.6	14.4	0.8	1.5	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/16/2024 00:00	0.6	14.3	0.8	1.5	14.4
09/16/2024 01:00	0.6	14.3	0.8	1.5	14.4
09/16/2024 02:00	0.6	14.3	0.8	1.4	14.4
09/16/2024 03:00	0.7	14.3	0.8	1.3	14.3
09/16/2024 04:00	0.6	14.3	0.9	1.2	14.3
09/16/2024 05:00	0.6	14.4	0.8	1.4	14.4
09/16/2024 06:00	0.6	14.4	0.8	1.3	14.4
09/16/2024 07:00	0.5	14.5	0.7	1.4	14.5
09/16/2024 08:00	0.8	14.3	1.4	1.5	14.3
09/16/2024 09:00	0.6	14.5	0.8	1.5	14.6
09/16/2024 10:00	0.4	14.6	0.7	1.5	14.6
09/16/2024 11:00	0.4	14.6	0.7	1.5	14.6
09/16/2024 12:00	0.5	14.5	0.8	1.4	14.5
09/16/2024 13:00	0.5	14.4	0.8	1.5	14.4
09/16/2024 14:00	0.5	14.4	0.8	1.5	14.4
09/16/2024 15:00	0.5	14.4	0.7	1.5	14.4
09/16/2024 16:00	0.5	14.5	0.7	1.5	14.5
09/16/2024 17:00	0.5	14.3	0.7	1.4	14.4
09/16/2024 18:00	0.5	14.4	0.7	1.5	14.4
09/16/2024 19:00	0.5	14.4	0.7	1.5	14.4
09/16/2024 20:00	0.5	14.5	0.7	1.5	14.5
09/16/2024 21:00	0.5	14.4	0.8	1.4	14.5
09/16/2024 22:00	0.5	14.5	0.7	1.5	14.5
09/16/2024 23:00	0.5	14.4	0.8	1.5	14.4
Average/Sum#:	0.5	14.4	0.8	1.4	14.4
Minimum:	0.4	14.3	0.7	1.2	14.3
Maximum:	0.8	14.6	1.4	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/17/2024 00:00	0.5	14.4	0.8	1.5	14.4
09/17/2024 01:00	0.5	14.3	0.8	1.5	14.4
09/17/2024 02:00	0.5	14.3	0.8	1.6	14.4
09/17/2024 03:00	0.6	14.3	0.8	1.5	14.4
09/17/2024 04:00	0.6	14.4	0.7	1.5	14.4
09/17/2024 05:00	0.5	14.4	0.7	1.4	14.5
09/17/2024 06:00	0.6	14.3	0.8	1.3	14.3
09/17/2024 07:00	0.6	14.3	0.8	1.5	14.3
09/17/2024 08:00	0.6	14.3	0.8	1.5	14.4
09/17/2024 09:00	0.5	14.3	0.8	1.5	14.4
09/17/2024 10:00	0.5	14.4	0.8	1.5	14.4
09/17/2024 11:00	0.5	14.4	0.8	1.5	14.4
09/17/2024 12:00	0.5	14.4	0.7	1.5	14.4
09/17/2024 13:00	0.5	14.4	0.7	1.5	14.5
09/17/2024 14:00	0.5	14.4	0.7	1.5	14.5
09/17/2024 15:00	0.5	14.4	0.7	1.5	14.5
09/17/2024 16:00	0.5	14.4	0.7	1.5	14.5
09/17/2024 17:00	0.5	14.4	0.7	1.5	14.5
09/17/2024 18:00	0.5	14.4	0.7	1.5	14.4
09/17/2024 19:00	0.5	14.4	0.8	1.5	14.4
09/17/2024 20:00	0.5	14.4	0.8	1.5	14.4
09/17/2024 21:00	0.5	14.3	0.8	1.5	14.4
09/17/2024 22:00	0.5	14.3	0.8	1.5	14.4
09/17/2024 23:00	0.5	14.3	0.8	1.5	14.4
Average/Sum#:	0.5	14.4	0.8	1.5	14.4
Minimum:	0.5	14.3	0.7	1.3	14.3
Maximum:	0.6	14.4	0.8	1.6	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/18/2024 00:00	0.5	14.3	0.8	1.5	14.4
09/18/2024 01:00	0.5	14.3	0.7	1.5	14.4
09/18/2024 02:00	0.5	14.3	0.8	1.4	14.4
09/18/2024 03:00	0.6	14.3	0.8	1.5	14.3
09/18/2024 04:00	0.5	14.3	0.8	1.5	14.3
09/18/2024 05:00	0.6	14.3	0.8	1.5	14.4
09/18/2024 06:00	0.6	14.4	0.8	1.4	14.4
09/18/2024 07:00	0.6	14.3	0.8	1.5	14.3
09/18/2024 08:00	0.6	14.3	0.8	1.5	14.4
09/18/2024 09:00	0.6	14.3	0.8	1.5	14.4
09/18/2024 10:00	0.6	14.3	0.8	1.5	14.4
09/18/2024 11:00	0.5	14.4	0.7	1.5	14.4
09/18/2024 12:00	0.5	14.4	0.7	1.5	14.5
09/18/2024 13:00	0.5	14.4	0.7	1.5	14.5
09/18/2024 14:00	0.5	14.4	0.7	1.5	14.5
09/18/2024 15:00	0.5	14.4	0.8	1.5	14.5
09/18/2024 16:00	0.5	14.5	0.7	1.5	14.6
09/18/2024 17:00	0.5	14.5	0.7	1.5	14.5
09/18/2024 18:00	0.5	14.4	0.8	1.4	14.4
09/18/2024 19:00	0.5	14.4	0.7	1.5	14.4
09/18/2024 20:00	0.5	14.5	0.7	1.5	14.6
09/18/2024 21:00	0.5	14.5	0.7	1.5	14.6
09/18/2024 22:00	0.6	14.5	0.7	1.5	14.6
09/18/2024 23:00	0.6	14.5	0.7	1.5	14.6
Average/Sum#:	0.5	14.4	0.8	1.5	14.5
Minimum:	0.5	14.3	0.7	1.4	14.3
Maximum:	0.6	14.5	0.8	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/19/2024 00:00	0.6	14.5	0.7	1.5	14.6
09/19/2024 01:00	0.6	14.5	0.8	1.5	14.6
09/19/2024 02:00	0.6	14.5	0.8	1.4	14.5
09/19/2024 03:00	0.6	14.5	0.8	1.5	14.5
09/19/2024 04:00	0.6	14.5	0.8	1.5	14.5
09/19/2024 05:00	0.6	14.5	0.8	1.5	14.5
09/19/2024 06:00	0.7	14.4	1.0	1.4	14.4
09/19/2024 07:00	0.6	14.5	0.7	1.5	14.6
09/19/2024 08:00	0.6	14.3	0.8	1.4	14.4
09/19/2024 09:00	0.6	14.4	0.8	1.5	14.4
09/19/2024 10:00	0.5	14.4	0.8	1.5	14.5
09/19/2024 11:00	0.5	14.4	0.7	1.5	14.5
09/19/2024 12:00	0.5	14.4	0.7	1.5	14.5
09/19/2024 13:00	0.6	14.5	0.7	1.5	14.5
09/19/2024 14:00	0.6	14.5	0.7	1.5	14.5
09/19/2024 15:00	0.5	14.5	0.7	1.5	14.5
09/19/2024 16:00	0.5	14.6	0.7	1.5	14.6
09/19/2024 17:00	0.6	14.3	0.8	1.5	14.4
09/19/2024 18:00	0.2	12.8	0.4	1.5	12.9
09/19/2024 19:00	0.5	13.5	0.7	1.5	13.5
09/19/2024 20:00	0.5	14.5	0.7	1.5	14.6
09/19/2024 21:00	0.5	14.5	0.7	1.5	14.5
09/19/2024 22:00	0.5	14.4	0.8	1.5	14.4
09/19/2024 23:00	0.6	14.4	0.8	1.5	14.4
Average/Sum#:	0.6	14.3	0.7	1.5	14.4
Minimum:	0.2	12.8	0.4	1.4	12.9
Maximum:	0.7	14.6	1.0	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/20/2024 00:00	0.5	14.3	0.7	1.5	14.4
09/20/2024 01:00	0.5	14.3	0.8	1.5	14.4
09/20/2024 02:00	0.6	14.3	0.8	1.5	14.4
09/20/2024 03:00	0.7	14.3	0.8	1.5	14.4
09/20/2024 04:00	0.6	14.3	0.8	1.5	14.4
09/20/2024 05:00	0.6	14.4	0.8	1.4	14.4
09/20/2024 06:00	0.6	14.3	0.8	1.4	14.3
09/20/2024 07:00	0.0	0.0	0.9	1.5	14.4
09/20/2024 08:00	0.6	14.3	0.8	1.5	14.4
09/20/2024 09:00	0.5	14.4	0.8	1.5	14.4
09/20/2024 10:00	0.5	14.5	0.7	1.5	14.5
09/20/2024 11:00	0.5	14.5	0.7	1.5	14.6
09/20/2024 12:00	0.5	14.5	0.7	1.5	14.5
09/20/2024 13:00	0.5	14.5	0.7	1.4	14.5
09/20/2024 14:00	0.5	14.4	0.7	1.5	14.5
09/20/2024 15:00	0.5	14.5	0.7	1.5	14.6
09/20/2024 16:00	0.5	14.6	0.7	1.5	14.6
09/20/2024 17:00	0.5	14.5	0.7	1.4	14.5
09/20/2024 18:00	0.6	14.5	0.7	1.5	14.5
09/20/2024 19:00	0.6	14.5	0.8	1.5	14.5
09/20/2024 20:00	0.5	14.4	0.8	1.5	14.5
09/20/2024 21:00	0.5	14.4	0.7	1.5	14.5
09/20/2024 22:00	0.5	14.4	0.8	1.5	14.4
09/20/2024 23:00	0.5	14.4	0.8	1.5	14.4
Average/Sum#:	0.5	14.4	0.8	1.5	14.5
Minimum:	0.5	14.3	0.7	1.4	14.3
Maximum:	0.7	14.6	0.9	1.5	14.6
%SI	4.17	4.17	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/21/2024 00:00	0.5	14.4	0.7	1.5	14.4
09/21/2024 01:00	0.5	14.4	0.8	1.5	14.4
09/21/2024 02:00	0.5	14.4	0.7	1.5	14.4
09/21/2024 03:00	0.6	14.5	0.8	1.5	14.5
09/21/2024 04:00	0.5	14.4	0.7	1.4	14.5
09/21/2024 05:00	0.5	14.4	0.8	1.4	14.4
09/21/2024 06:00	0.5	14.4	0.8	1.5	14.4
09/21/2024 07:00	0.5	14.3	0.8	1.5	14.4
09/21/2024 08:00	0.5	14.4	0.8	1.5	14.4
09/21/2024 09:00	0.5	14.4	0.7	1.5	14.4
09/21/2024 10:00	0.5	14.4	0.7	1.5	14.5
09/21/2024 11:00	0.5	14.5	0.7	1.5	14.5
09/21/2024 12:00	0.4	14.5	0.7	1.5	14.5
09/21/2024 13:00	0.4	14.5	0.7	1.5	14.5
09/21/2024 14:00	0.4	14.5	0.7	1.5	14.5
09/21/2024 15:00	0.5	14.5	0.7	1.5	14.5
09/21/2024 16:00	0.4	13.3	0.6	1.5	13.3
09/21/2024 17:00	0.0	12.5	0.2	1.5	12.6
09/21/2024 18:00	0.4	13.3	0.6	1.5	13.4
09/21/2024 19:00	0.6	13.8	0.8	1.5	13.9
09/21/2024 20:00	0.5	14.5	0.8	1.5	14.5
09/21/2024 21:00	0.6	14.5	0.8	1.5	14.5
09/21/2024 22:00	0.6	14.4	0.8	1.5	14.5
09/21/2024 23:00	0.6	14.4	0.8	1.5	14.4
Average/Sum#:	0.5	14.2	0.7	1.5	14.3
Minimum:	0.0	12.5	0.2	1.4	12.6
Maximum:	0.6	14.5	0.8	1.5	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/22/2024 00:00	0.6	14.4	0.8	1.5	14.4
09/22/2024 01:00	0.6	14.4	0.9	1.5	14.4
09/22/2024 02:00	0.6	14.4	0.9	1.5	14.4
09/22/2024 03:00	0.6	14.4	0.8	1.5	14.4
09/22/2024 04:00	0.5	14.3	0.8	1.5	14.4
09/22/2024 05:00	0.5	14.3	0.8	1.5	14.4
09/22/2024 06:00	0.6	14.3	0.8	1.5	14.4
09/22/2024 07:00	0.5	14.3	0.8	1.5	14.4
09/22/2024 08:00	0.6	14.4	0.8	1.5	14.4
09/22/2024 09:00	0.5	14.4	0.8	1.5	14.5
09/22/2024 10:00	0.6	14.5	0.7	1.5	14.5
09/22/2024 11:00	0.5	14.5	0.7	1.5	14.5
09/22/2024 12:00	0.5	14.5	0.7	1.5	14.5
09/22/2024 13:00	0.4	14.6	0.7	1.6	14.6
09/22/2024 14:00	0.5	14.5	0.7	1.5	14.5
09/22/2024 15:00	0.5	14.4	0.7	1.5	14.4
09/22/2024 16:00	0.5	14.5	0.7	1.5	14.5
09/22/2024 17:00	0.5	14.5	0.7	1.4	14.5
09/22/2024 18:00	0.5	14.5	0.7	1.5	14.5
09/22/2024 19:00	0.6	14.5	0.8	1.5	14.5
09/22/2024 20:00	0.6	14.5	0.8	1.5	14.5
09/22/2024 21:00	0.6	14.4	0.9	1.5	14.5
09/22/2024 22:00	0.6	14.4	0.8	1.5	14.5
09/22/2024 23:00	0.6	14.4	0.8	1.5	14.4
Average/Sum#:	0.5	14.4	0.8	1.5	14.5
Minimum:	0.4	14.3	0.7	1.4	14.4
Maximum:	0.6	14.6	0.9	1.6	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/23/2024 00:00	0.6	14.4	0.8	1.5	14.4
09/23/2024 01:00	0.5	14.4	0.8	1.5	14.4
09/23/2024 02:00	0.6	14.4	0.8	1.5	14.4
09/23/2024 03:00	0.6	14.4	0.8	1.5	14.4
09/23/2024 04:00	0.6	14.3	0.9	1.5	14.4
09/23/2024 05:00	0.7	14.3	1.0	1.5	14.4
09/23/2024 06:00	0.8	14.3	0.9	1.5	14.4
09/23/2024 07:00	0.7	14.4	0.9	1.5	14.4
09/23/2024 08:00	0.6	14.4	0.8	1.5	14.5
09/23/2024 09:00	0.6	14.5	0.8	1.5	14.5
09/23/2024 10:00	0.6	14.5	0.7	1.5	14.6
09/23/2024 11:00	0.5	14.5	0.7	1.5	14.6
09/23/2024 12:00	0.5	14.5	0.7	1.5	14.6
09/23/2024 13:00	0.5	14.6	0.7	1.5	14.6
09/23/2024 14:00	0.4	14.5	0.7	1.5	14.5
09/23/2024 15:00	0.8	14.4	0.9	1.5	14.5
09/23/2024 16:00	0.9	13.7	0.9	1.5	13.7
09/23/2024 17:00	0.0	12.5	0.2	1.5	12.6
09/23/2024 18:00	0.1	12.9	0.3	1.5	13.0
09/23/2024 19:00	0.4	13.4	0.5	1.5	13.5
09/23/2024 20:00	0.6	14.5	0.8	1.5	14.6
09/23/2024 21:00	0.6	14.5	0.8	1.5	14.6
09/23/2024 22:00	0.6	14.5	0.8	1.5	14.5
09/23/2024 23:00	0.6	14.4	0.8	1.5	14.5
Average/Sum#:	0.6	14.2	0.8	1.5	14.3
Minimum:	0.0	12.5	0.2	1.5	12.6
Maximum:	0.9	14.6	1.0	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/24/2024 00:00	0.6	14.5	0.9	1.5	14.5
09/24/2024 01:00	0.6	14.4	0.9	1.5	14.4
09/24/2024 02:00	0.6	14.4	0.9	1.5	14.4
09/24/2024 03:00	0.7	14.5	0.8	1.5	14.5
09/24/2024 04:00	0.6	14.5	0.8	1.5	14.6
09/24/2024 05:00	0.7	14.5	1.0	1.5	14.6
09/24/2024 06:00	0.7	14.4	0.9	1.4	14.4
09/24/2024 07:00	0.6	14.4	0.9	1.5	14.4
09/24/2024 08:00	0.6	14.4	0.8	1.5	14.5
09/24/2024 09:00	0.6	14.5	0.8	1.5	14.5
09/24/2024 10:00	0.6	14.5	0.8	1.5	14.6
09/24/2024 11:00	0.5	14.6	0.7	1.5	14.6
09/24/2024 12:00	0.5	14.6	0.7	1.5	14.6
09/24/2024 13:00	0.5	14.5	0.7	1.5	14.6
09/24/2024 14:00	0.4	14.6	0.7	1.5	14.6
09/24/2024 15:00	0.5	14.5	0.7	1.5	14.5
09/24/2024 16:00	0.5	14.2	0.8	1.5	14.2
09/24/2024 17:00	0.3	13.2	0.5	1.5	13.3
09/24/2024 18:00	0.5	13.9	0.7	1.5	14.0
09/24/2024 19:00	0.6	14.5	0.8	1.5	14.6
09/24/2024 20:00	0.6	14.5	0.8	1.5	14.5
09/24/2024 21:00	0.6	14.4	0.8	1.5	14.5
09/24/2024 22:00	0.5	14.4	0.8	1.5	14.5
09/24/2024 23:00	0.5	14.4	0.8	1.5	14.5
Average/Sum#:	0.6	14.4	0.8	1.5	14.4
Minimum:	0.3	13.2	0.5	1.4	13.3
Maximum:	0.7	14.6	1.0	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/25/2024 00:00	0.5	14.4	0.8	1.5	14.5
09/25/2024 01:00	0.5	14.4	0.8	1.5	14.4
09/25/2024 02:00	0.5	14.4	0.8	1.5	14.4
09/25/2024 03:00	0.6	14.4	0.8	1.5	14.4
09/25/2024 04:00	0.5	14.4	0.8	1.5	14.4
09/25/2024 05:00	0.5	14.4	0.7	1.5	14.5
09/25/2024 06:00	0.5	14.3	0.8	1.4	14.4
09/25/2024 07:00	0.5	14.3	0.8	1.5	14.4
09/25/2024 08:00	0.5	14.5	0.7	1.5	14.5
09/25/2024 09:00	0.5	14.4	0.7	1.4	14.4
09/25/2024 10:00	0.5	14.4	0.7	1.5	14.4
09/25/2024 11:00	0.5	14.4	0.8	1.4	14.4
09/25/2024 12:00	0.5	14.4	0.7	1.5	14.5
09/25/2024 13:00	0.5	14.5	0.7	1.5	14.5
09/25/2024 14:00	0.5	14.5	0.7	1.5	14.5
09/25/2024 15:00	0.5	14.5	0.7	1.5	14.5
09/25/2024 16:00	0.5	14.5	0.7	1.5	14.5
09/25/2024 17:00	0.5	14.3	0.7	1.5	14.3
09/25/2024 18:00	0.5	14.3	0.8	1.5	14.3
09/25/2024 19:00	0.5	14.3	0.8	1.5	14.3
09/25/2024 20:00	0.5	14.3	0.8	1.5	14.3
09/25/2024 21:00	0.5	14.3	0.7	1.5	14.3
09/25/2024 22:00	0.5	14.3	0.7	1.5	14.3
09/25/2024 23:00	0.5	14.3	0.8	1.5	14.3
Average/Sum#:	0.5	14.4	0.8	1.5	14.4
Minimum:	0.5	14.3	0.7	1.4	14.3
Maximum:	0.6	14.5	0.8	1.5	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/26/2024 00:00	0.5	14.2	0.8	1.5	14.3
09/26/2024 01:00	0.5	14.3	0.8	1.5	14.3
09/26/2024 02:00	0.5	14.2	0.8	1.4	14.3
09/26/2024 03:00	0.6	14.2	0.8	1.3	14.3
09/26/2024 04:00	0.5	14.2	0.8	1.4	14.3
09/26/2024 05:00	0.5	14.2	0.8	1.4	14.3
09/26/2024 06:00	0.6	14.2	0.8	1.4	14.3
09/26/2024 07:00	0.7	14.2	1.0	1.4	14.3
09/26/2024 08:00	0.6	14.3	0.8	1.4	14.3
09/26/2024 09:00	0.6	14.3	0.8	1.5	14.4
09/26/2024 10:00	0.5	14.4	0.8	1.5	14.4
09/26/2024 11:00	0.5	14.4	0.8	1.5	14.4
09/26/2024 12:00	0.5	14.4	0.7	1.5	14.5
09/26/2024 13:00	0.5	14.5	0.7	1.5	14.5
09/26/2024 14:00	0.5	14.5	0.7	1.5	14.5
09/26/2024 15:00	0.5	14.5	0.7	1.5	14.5
09/26/2024 16:00	0.7	14.3	0.9	1.5	14.3
09/26/2024 17:00	0.4	13.3	0.5	1.5	13.3
09/26/2024 18:00	0.4	13.3	0.5	1.5	13.3
09/26/2024 19:00	0.5	13.4	0.6	1.5	13.5
09/26/2024 20:00	0.5	13.3	0.6	1.5	13.4
09/26/2024 21:00	0.7	14.0	0.9	1.4	14.1
09/26/2024 22:00	0.6	14.4	0.8	1.5	14.4
09/26/2024 23:00	0.7	14.4	0.9	1.5	14.4
Average/Sum#:	0.5	14.1	0.8	1.5	14.2
Minimum:	0.4	13.3	0.5	1.3	13.3
Maximum:	0.7	14.5	1.0	1.5	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/27/2024 00:00	0.7	14.3	0.8	1.5	14.4
09/27/2024 01:00	0.7	14.3	0.8	1.5	14.4
09/27/2024 02:00	0.6	14.4	0.8	1.5	14.4
09/27/2024 03:00	0.9	14.3	1.0	1.5	14.4
09/27/2024 04:00	0.7	14.4	0.8	1.5	14.5
09/27/2024 05:00	0.6	14.5	0.9	1.4	14.5
09/27/2024 06:00	0.7	14.4	1.0	1.3	14.4
09/27/2024 07:00	0.7	14.3	1.0	1.5	14.4
09/27/2024 08:00	0.6	14.4	0.9	1.5	14.4
09/27/2024 09:00	0.5	14.4	0.8	1.5	14.4
09/27/2024 10:00	0.5	14.5	0.8	1.5	14.5
09/27/2024 11:00	0.5	14.5	0.7	1.5	14.5
09/27/2024 12:00	0.5	14.5	0.7	1.5	14.5
09/27/2024 13:00	0.5	14.5	0.8	1.5	14.6
09/27/2024 14:00	0.5	14.6	0.7	1.5	14.6
09/27/2024 15:00	0.5	14.6	0.8	1.5	14.6
09/27/2024 16:00	0.7	14.2	1.0	1.5	14.2
09/27/2024 17:00	0.5	13.6	0.7	1.6	13.6
09/27/2024 18:00	0.5	13.6	0.8	1.5	13.6
09/27/2024 19:00	0.7	13.8	0.9	1.5	13.9
09/27/2024 20:00	0.6	14.5	0.8	1.5	14.5
09/27/2024 21:00	0.6	14.5	0.8	1.5	14.5
09/27/2024 22:00	0.7	14.6	0.8	1.5	14.6
09/27/2024 23:00	0.6	14.5	0.7	1.5	14.5
Average/Sum#:	0.6	14.3	0.8	1.5	14.4
Minimum:	0.5	13.6	0.7	1.3	13.6
Maximum:	0.9	14.6	1.0	1.6	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/28/2024 00:00	0.5	14.5	0.7	1.4	14.5
09/28/2024 01:00	0.6	14.4	0.9	1.5	14.4
09/28/2024 02:00	0.6	14.4	0.9	1.5	14.4
09/28/2024 03:00	0.7	14.4	0.9	1.5	14.4
09/28/2024 04:00	0.6	14.3	0.9	1.5	14.4
09/28/2024 05:00	0.7	14.3	0.9	1.5	14.4
09/28/2024 06:00	0.7	14.3	0.9	1.5	14.4
09/28/2024 07:00	0.6	14.4	0.9	1.5	14.4
09/28/2024 08:00	0.6	14.4	0.9	1.5	14.5
09/28/2024 09:00	0.6	14.5	0.8	1.5	14.5
09/28/2024 10:00	0.5	14.5	0.8	1.5	14.5
09/28/2024 11:00	0.5	14.5	0.7	1.5	14.6
09/28/2024 12:00	0.5	14.5	0.7	1.5	14.6
09/28/2024 13:00	0.5	14.6	0.7	1.5	14.6
09/28/2024 14:00	0.5	14.6	0.7	1.5	14.6
09/28/2024 15:00	0.5	14.5	0.7	1.5	14.5
09/28/2024 16:00	0.7	14.2	1.0	1.5	14.2
09/28/2024 17:00	0.5	13.6	0.7	1.5	13.6
09/28/2024 18:00	0.6	13.6	0.8	1.5	13.7
09/28/2024 19:00	0.7	13.9	0.9	1.5	13.9
09/28/2024 20:00	0.5	14.4	0.8	1.5	14.4
09/28/2024 21:00	0.5	14.4	0.8	1.5	14.4
09/28/2024 22:00	0.5	14.4	0.8	1.5	14.4
09/28/2024 23:00	0.5	14.3	0.8	1.5	14.4
Average/Sum#:	0.6	14.3	0.8	1.5	14.4
Minimum:	0.5	13.6	0.7	1.4	13.6
Maximum:	0.7	14.6	1.0	1.5	14.6
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/29/2024 00:00	0.5	14.3	0.8	1.5	14.4
09/29/2024 01:00	0.5	14.3	0.8	1.5	14.4
09/29/2024 02:00	0.6	14.3	0.8	1.5	14.3
09/29/2024 03:00	0.6	14.3	0.8	1.4	14.3
09/29/2024 04:00	0.6	14.3	0.8	1.4	14.3
09/29/2024 05:00	0.6	14.3	0.8	1.4	14.3
09/29/2024 06:00	0.6	14.3	0.8	1.4	14.3
09/29/2024 07:00	0.6	14.3	0.8	1.5	14.3
09/29/2024 08:00	0.6	14.3	0.8	1.5	14.4
09/29/2024 09:00	0.5	14.3	0.8	1.5	14.4
09/29/2024 10:00	0.5	14.4	0.8	1.5	14.4
09/29/2024 11:00	0.5	14.4	0.8	1.5	14.5
09/29/2024 12:00	0.5	14.5	0.8	1.5	14.5
09/29/2024 13:00	0.5	14.5	0.7	1.5	14.5
09/29/2024 14:00	0.5	14.5	0.7	1.5	14.5
09/29/2024 15:00	0.5	14.5	0.7	1.5	14.5
09/29/2024 16:00	0.5	14.4	0.7	1.6	14.5
09/29/2024 17:00	0.5	14.4	0.8	1.4	14.4
09/29/2024 18:00	0.6	14.5	0.8	1.5	14.5
09/29/2024 19:00	0.6	14.5	0.8	1.5	14.5
09/29/2024 20:00	0.6	14.4	0.9	1.5	14.4
09/29/2024 21:00	0.6	14.4	0.8	1.5	14.4
09/29/2024 22:00	0.7	14.4	0.9	1.5	14.4
09/29/2024 23:00	0.7	14.3	0.9	1.5	14.4
Average/Sum#:	0.6	14.4	0.8	1.5	14.4
Minimum:	0.5	14.3	0.7	1.4	14.3
Maximum:	0.7	14.5	0.9	1.6	14.5
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
09/30/2024 00:00	0.6	14.3	0.8	1.5	14.4
09/30/2024 01:00	0.6	14.3	0.8	1.5	14.4
09/30/2024 02:00	0.6	14.3	0.8	1.5	14.4
09/30/2024 03:00	0.7	14.3	0.9	1.5	14.4
09/30/2024 04:00	0.8	14.3	1.0	1.5	14.4
09/30/2024 05:00	0.7	14.3	0.9	1.5	14.4
09/30/2024 06:00	0.7	14.4	0.9	1.4	14.4
09/30/2024 07:00	0.7	14.3	1.0	1.5	14.4
09/30/2024 08:00	0.6	14.4	0.9	1.5	14.4
09/30/2024 09:00	0.6	14.4	0.8	1.5	14.4
09/30/2024 10:00	0.5	14.4	0.8	1.5	14.5
09/30/2024 11:00	0.6	14.5	0.8	1.5	14.5
09/30/2024 12:00	0.6	14.5	0.8	1.5	14.5
09/30/2024 13:00	0.5	14.5	0.7	1.5	14.5
09/30/2024 14:00	0.5	14.5	0.8	1.5	14.6
09/30/2024 15:00	1.0	14.2	1.1	1.5	14.2
09/30/2024 16:00	0.1	12.3	0.3	1.6	12.4
09/30/2024 17:00	0.0	12.4	0.2	1.5	12.5
09/30/2024 18:00	0.1	12.6	0.3	1.5	12.8
09/30/2024 19:00	0.1	12.6	0.3	1.5	12.7
09/30/2024 20:00	0.1	12.5	0.3	1.5	12.6
09/30/2024 21:00	0.1	12.6	0.3	1.5	12.7
09/30/2024 22:00	0.5	13.3	0.7	1.5	13.3
09/30/2024 23:00	0.6	14.5	0.8	1.5	14.5
Average/Sum#:	0.5	13.9	0.7	1.5	13.9
Minimum:	0.0	12.3	0.2	1.4	12.4
Maximum:	1.0	14.5	1.1	1.6	14.6
%SI	0.00	0.00	0.00	0.00	0.00