

DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	259821-7
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2024 - Part 2 - searchable
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/30/2024 4:56:32 PM
Docketed Date:	10/30/2024

AQ-33

AQ-33 The Project owner shall maintain records of Sox lb/hr, lb/day, and lb, quarter emissions. Sox emissions shall be based on fuel use records, natural gas sulfur content, and mass balance calculations.

Verification: The Project owner shall submit to the CPM all hourly, daily, and quarterly Sox emissions as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:24 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Jul 2024	0.4589	3.9373	1.6951	9.8201	0.3762	2.1164	0.1875	1.0584	0.6265	3.5273
Aug 2024	0.5206	3.9875	1.3777	9.5370	0.3463	2.1015	0.1724	1.0502	0.5763	3.5015
Sep 2024	0.4457	3.9688	1.5432	9.8108	0.3534	2.1779	0.1774	1.0890	0.5887	3.6283
Sum/Avg	3.9688		9.8108		2.1779		1.0890		3.6283	
Limit Value										

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/01/2024 00:00	5.2	5.3
Average/Sum#:	5.2 #	5.3 #
Minimum:	5.2	5.3
Maximum:	5.2	5.3
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/02/2024 00:00	6.4	6.6
Average/Sum#:	6.4 #	6.6 #
Minimum:	6.4	6.6
Maximum:	6.4	6.6
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/03/2024 00:00	6.0	6.2
Average/Sum#:	6.0 #	6.2 #
Minimum:	6.0	6.2
Maximum:	6.0	6.2
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/04/2024 00:00	4.8	5.0

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	4.8 #	5.0 #
Minimum:	4.8	5.0
Maximum:	4.8	5.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/05/2024 00:00	5.1	5.6

Average/Sum#:	5.1 #	5.6 #
Minimum:	5.1	5.6
Maximum:	5.1	5.6
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/06/2024 00:00	5.5	5.7

Average/Sum#:	5.5 #	5.7 #
Minimum:	5.5	5.7
Maximum:	5.5	5.7
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/07/2024 00:00	5.9	6.0

Average/Sum#:	5.9 #	6.0 #
Minimum:	5.9	6.0
Maximum:	5.9	6.0
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/08/2024 00:00	6.1	6.5
Average/Sum#:	6.1 #	6.5 #
Minimum:	6.1	6.5
Maximum:	6.1	6.5
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/09/2024 00:00	6.7	6.7
Average/Sum#:	6.7 #	6.7 #
Minimum:	6.7	6.7
Maximum:	6.7	6.7
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/10/2024 00:00	6.3	6.8
Average/Sum#:	6.3 #	6.8 #
Minimum:	6.3	6.8
Maximum:	6.3	6.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/11/2024 00:00	6.6	6.7

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	6.6 #	6.7 #
Minimum:	6.6	6.7
Maximum:	6.6	6.7
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)

07/12/2024 00:00	6.2	6.4
------------------	-----	-----

Average/Sum#:	6.2 #	6.4 #
Minimum:	6.2	6.4
Maximum:	6.2	6.4
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)

07/13/2024 00:00	4.9	5.0
------------------	-----	-----

Average/Sum#:	4.9 #	5.0 #
Minimum:	4.9	5.0
Maximum:	4.9	5.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)

07/14/2024 00:00	4.8	4.9
------------------	-----	-----

Average/Sum#:	4.8 #	4.9 #
Minimum:	4.8	4.9
Maximum:	4.8	4.9
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/15/2024 00:00	4.8	4.8
Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/16/2024 00:00	5.4	5.4
Average/Sum#:	5.4 #	5.4 #
Minimum:	5.4	5.4
Maximum:	5.4	5.4
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/17/2024 00:00	5.1	5.3
Average/Sum#:	5.1 #	5.3 #
Minimum:	5.1	5.3
Maximum:	5.1	5.3
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/18/2024 00:00	6.2	2.3

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	6.2 #	2.3 #
Minimum:	6.2	2.3
Maximum:	6.2	2.3
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/19/2024 00:00	7.7	0.0

Average/Sum#:	7.7 #	0.0 #
Minimum:	7.7	0.0
Maximum:	7.7	0.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/20/2024 00:00	7.1	5.1

Average/Sum#:	7.1 #	5.1 #
Minimum:	7.1	5.1
Maximum:	7.1	5.1
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/21/2024 00:00	5.3	5.5

Average/Sum#:	5.3 #	5.5 #
Minimum:	5.3	5.5
Maximum:	5.3	5.5
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/22/2024 00:00	6.7	7.0
Average/Sum#:	6.7 #	7.0 #
Minimum:	6.7	7.0
Maximum:	6.7	7.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/23/2024 00:00	8.8	9.2
Average/Sum#:	8.8 #	9.2 #
Minimum:	8.8	9.2
Maximum:	8.8	9.2
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/24/2024 00:00	8.0	8.1
Average/Sum#:	8.0 #	8.1 #
Minimum:	8.0	8.1
Maximum:	8.0	8.1
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/25/2024 00:00	6.2	6.8

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	6.2 #	6.8 #
Minimum:	6.2	6.8
Maximum:	6.2	6.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/26/2024 00:00	5.0	5.1

Average/Sum#:	5.0 #	5.1 #
Minimum:	5.0	5.1
Maximum:	5.0	5.1
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/27/2024 00:00	4.8	4.8

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/28/2024 00:00	4.8	4.8

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/29/2024 00:00	5.3	5.4
Average/Sum#:	5.3 #	5.4 #
Minimum:	5.3	5.4
Maximum:	5.3	5.4
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/30/2024 00:00	5.7	6.0
Average/Sum#:	5.7 #	6.0 #
Minimum:	5.7	6.0
Maximum:	5.7	6.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/31/2024 00:00	5.8	6.5
Average/Sum#:	5.8 #	6.5 #
Minimum:	5.8	6.5
Maximum:	5.8	6.5
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/01/2024 00:00	6.4	5.1

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	6.4 #	5.1 #
Minimum:	6.4	5.1
Maximum:	6.4	5.1
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/02/2024 00:00	7.4	7.6

Average/Sum#:	7.4 #	7.6 #
Minimum:	7.4	7.6
Maximum:	7.4	7.6
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/03/2024 00:00	5.2	5.7

Average/Sum#:	5.2 #	5.7 #
Minimum:	5.2	5.7
Maximum:	5.2	5.7
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/04/2024 00:00	5.5	5.6

Average/Sum#:	5.5 #	5.6 #
Minimum:	5.5	5.6
Maximum:	5.5	5.6
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/05/2024 00:00	4.9	5.5
Average/Sum#:	4.9 #	5.5 #
Minimum:	4.9	5.5
Maximum:	4.9	5.5
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/06/2024 00:00	5.3	5.5
Average/Sum#:	5.3 #	5.5 #
Minimum:	5.3	5.5
Maximum:	5.3	5.5
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/07/2024 00:00	4.8	4.9
Average/Sum#:	4.8 #	4.9 #
Minimum:	4.8	4.9
Maximum:	4.8	4.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/08/2024 00:00	4.8	4.8

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/09/2024 00:00	4.8	4.9

Average/Sum#:	4.8 #	4.9 #
Minimum:	4.8	4.9
Maximum:	4.8	4.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/10/2024 00:00	4.8	4.8

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/11/2024 00:00	5.7	5.9

Average/Sum#:	5.7 #	5.9 #
Minimum:	5.7	5.9
Maximum:	5.7	5.9
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/12/2024 00:00	5.0	5.2
Average/Sum#:	5.0 #	5.2 #
Minimum:	5.0	5.2
Maximum:	5.0	5.2
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/13/2024 00:00	5.1	5.1
Average/Sum#:	5.1 #	5.1 #
Minimum:	5.1	5.1
Maximum:	5.1	5.1
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/14/2024 00:00	5.4	5.6
Average/Sum#:	5.4 #	5.6 #
Minimum:	5.4	5.6
Maximum:	5.4	5.6
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/15/2024 00:00	5.4	5.8

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	5.4 #	5.8 #
Minimum:	5.4	5.8
Maximum:	5.4	5.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/16/2024 00:00	4.9	5.2

Average/Sum#:	4.9 #	5.2 #
Minimum:	4.9	5.2
Maximum:	4.9	5.2
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/17/2024 00:00	4.8	5.0

Average/Sum#:	4.8 #	5.0 #
Minimum:	4.8	5.0
Maximum:	4.8	5.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/18/2024 00:00	4.8	4.8

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/19/2024 00:00	4.8	5.1
Average/Sum#:	4.8 #	5.1 #
Minimum:	4.8	5.1
Maximum:	4.8	5.1
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/20/2024 00:00	4.8	4.8
Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/21/2024 00:00	4.8	4.8
Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/22/2024 00:00	4.8	4.8

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/23/2024 00:00	4.8	4.8

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/24/2024 00:00	4.8	4.8

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/25/2024 00:00	5.0	5.2

Average/Sum#:	5.0 #	5.2 #
Minimum:	5.0	5.2
Maximum:	5.0	5.2
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/26/2024 00:00	4.9	5.2
Average/Sum#:	4.9 #	5.2 #
Minimum:	4.9	5.2
Maximum:	4.9	5.2
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/27/2024 00:00	4.8	4.9
Average/Sum#:	4.8 #	4.9 #
Minimum:	4.8	4.9
Maximum:	4.8	4.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/28/2024 00:00	4.8	4.9
Average/Sum#:	4.8 #	4.9 #
Minimum:	4.8	4.9
Maximum:	4.8	4.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/29/2024 00:00	5.1	5.2

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	5.1 #	5.2 #
Minimum:	5.1	5.2
Maximum:	5.1	5.2
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/30/2024 00:00	4.8	4.8

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/31/2024 00:00	5.8	5.9

Average/Sum#:	5.8 #	5.9 #
Minimum:	5.8	5.9
Maximum:	5.8	5.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/01/2024 00:00	4.8	4.8

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/02/2024 00:00	4.8	5.1
Average/Sum#:	4.8 #	5.1 #
Minimum:	4.8	5.1
Maximum:	4.8	5.1
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/03/2024 00:00	5.7	6.1
Average/Sum#:	5.7 #	6.1 #
Minimum:	5.7	6.1
Maximum:	5.7	6.1
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/04/2024 00:00	6.2	6.9
Average/Sum#:	6.2 #	6.9 #
Minimum:	6.2	6.9
Maximum:	6.2	6.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/05/2024 00:00	6.8	7.3

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	6.8 #	7.3 #
Minimum:	6.8	7.3
Maximum:	6.8	7.3
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/06/2024 00:00	7.1	7.4

Average/Sum#:	7.1 #	7.4 #
Minimum:	7.1	7.4
Maximum:	7.1	7.4
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/07/2024 00:00	6.7	7.0

Average/Sum#:	6.7 #	7.0 #
Minimum:	6.7	7.0
Maximum:	6.7	7.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/08/2024 00:00	6.2	6.6

Average/Sum#:	6.2 #	6.6 #
Minimum:	6.2	6.6
Maximum:	6.2	6.6
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/09/2024 00:00	5.2	5.5
Average/Sum#:	5.2 #	5.5 #
Minimum:	5.2	5.5
Maximum:	5.2	5.5
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/10/2024 00:00	4.8	4.9
Average/Sum#:	4.8 #	4.9 #
Minimum:	4.8	4.9
Maximum:	4.8	4.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/11/2024 00:00	4.8	4.9
Average/Sum#:	4.8 #	4.9 #
Minimum:	4.8	4.9
Maximum:	4.8	4.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/12/2024 00:00	4.8	4.8

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/13/2024 00:00	5.3	6.0

Average/Sum#:	5.3 #	6.0 #
Minimum:	5.3	6.0
Maximum:	5.3	6.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/14/2024 00:00	5.2	5.4

Average/Sum#:	5.2 #	5.4 #
Minimum:	5.2	5.4
Maximum:	5.2	5.4
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/15/2024 00:00	4.8	4.8

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/16/2024 00:00	5.4	5.9
Average/Sum#:	5.4 #	5.9 #
Minimum:	5.4	5.9
Maximum:	5.4	5.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/17/2024 00:00	4.9	4.9
Average/Sum#:	4.9 #	4.9 #
Minimum:	4.9	4.9
Maximum:	4.9	4.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/18/2024 00:00	5.2	5.4
Average/Sum#:	5.2 #	5.4 #
Minimum:	5.2	5.4
Maximum:	5.2	5.4
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/19/2024 00:00	6.0	6.3

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	6.0 #	6.3 #
Minimum:	6.0	6.3
Maximum:	6.0	6.3
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/20/2024 00:00	5.0	5.2

Average/Sum#:	5.0 #	5.2 #
Minimum:	5.0	5.2
Maximum:	5.0	5.2
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/21/2024 00:00	5.5	5.7

Average/Sum#:	5.5 #	5.7 #
Minimum:	5.5	5.7
Maximum:	5.5	5.7
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/22/2024 00:00	4.9	5.0

Average/Sum#:	4.9 #	5.0 #
Minimum:	4.9	5.0
Maximum:	4.9	5.0
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/23/2024 00:00	5.5	6.0
Average/Sum#:	5.5 #	6.0 #
Minimum:	5.5	6.0
Maximum:	5.5	6.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/24/2024 00:00	5.2	5.6
Average/Sum#:	5.2 #	5.6 #
Minimum:	5.2	5.6
Maximum:	5.2	5.6
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/25/2024 00:00	4.8	5.0
Average/Sum#:	4.8 #	5.0 #
Minimum:	4.8	5.0
Maximum:	4.8	5.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/26/2024 00:00	5.3	5.5

AQ33 DAILY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	5.3 #	5.5 #
Minimum:	5.3	5.5
Maximum:	5.3	5.5
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)

09/27/2024 00:00	5.5	5.8
------------------	-----	-----

Average/Sum#:	5.5 #	5.8 #
Minimum:	5.5	5.8
Maximum:	5.5	5.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)

09/28/2024 00:00	5.2	5.3
------------------	-----	-----

Average/Sum#:	5.2 #	5.3 #
Minimum:	5.2	5.3
Maximum:	5.2	5.3
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)

09/29/2024 00:00	4.8	4.9
------------------	-----	-----

Average/Sum#:	4.8 #	4.9 #
Minimum:	4.8	4.9
Maximum:	4.8	4.9
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2024 00:00 **To:** 09/30/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/11/2024 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/30/2024 00:00	6.3	6.3
Average/Sum#:	6.3 #	6.3 #
Minimum:	6.3	6.3
Maximum:	6.3	6.3
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/01/2024 00:00	0.21090	0.22770
07/01/2024 01:00	0.21072	0.22788
07/01/2024 02:00	0.21090	0.22788
07/01/2024 03:00	0.21138	0.22842
07/01/2024 04:00	0.21108	0.22872
07/01/2024 05:00	0.21132	0.22884
07/01/2024 06:00	0.21204	0.22926
07/01/2024 07:00	0.21306	0.22926
07/01/2024 08:00	0.21282	0.22908
07/01/2024 09:00	0.21276	0.22884
07/01/2024 10:00	0.21276	0.22842
07/01/2024 11:00	0.21360	0.22818
07/01/2024 12:00	0.21378	0.22800
07/01/2024 13:00	0.21372	0.22752
07/01/2024 14:00	0.21444	0.22836
07/01/2024 15:00	0.21480	0.22920
07/01/2024 16:00	0.21462	0.22884
07/01/2024 17:00	0.22776	0.24342
07/01/2024 18:00	0.31698	0.33552
07/01/2024 19:00	0.38688	0.40500
07/01/2024 20:00	0.34008	0.35910
07/01/2024 21:00	0.22848	0.24456
07/01/2024 22:00	0.21204	0.22842
07/01/2024 23:00	0.21162	0.22824
Average/Sum#:	0.23077	0.24703
Minimum:	0.21072	0.22752
Maximum:	0.38688	0.40500
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/02/2024 00:00	0.21198	0.22842
07/02/2024 01:00	0.21150	0.22860
07/02/2024 02:00	0.21138	0.22842
07/02/2024 03:00	0.21126	0.22836
07/02/2024 04:00	0.21162	0.22890
07/02/2024 05:00	0.23040	0.24876
07/02/2024 06:00	0.21552	0.23256
07/02/2024 07:00	0.21300	0.22932
07/02/2024 08:00	0.21192	0.22824
07/02/2024 09:00	0.21156	0.22776
07/02/2024 10:00	0.21168	0.22740
07/02/2024 11:00	0.21294	0.22704
07/02/2024 12:00	0.21714	0.23130
07/02/2024 13:00	0.25452	0.26754
07/02/2024 14:00	0.34368	0.36114
07/02/2024 15:00	0.36306	0.38016
07/02/2024 16:00	0.37062	0.38748
07/02/2024 17:00	0.38082	0.39636
07/02/2024 18:00	0.37938	0.39786
07/02/2024 19:00	0.37632	0.39534
07/02/2024 20:00	0.37416	0.39306
07/02/2024 21:00	0.35718	0.37560
07/02/2024 22:00	0.24252	0.25992
07/02/2024 23:00	0.21348	0.23040
Average/Sum#:	0.26824	0.28500
Minimum:	0.21126	0.22704
Maximum:	0.38082	0.39786
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/03/2024 00:00	0.21444	0.23040
07/03/2024 01:00	0.21246	0.22902
07/03/2024 02:00	0.21216	0.22902
07/03/2024 03:00	0.21216	0.22914
07/03/2024 04:00	0.21198	0.22896
07/03/2024 05:00	0.21222	0.22920
07/03/2024 06:00	0.21210	0.22896
07/03/2024 07:00	0.21276	0.22866
07/03/2024 08:00	0.21246	0.22854
07/03/2024 09:00	0.21234	0.22824
07/03/2024 10:00	0.21228	0.22764
07/03/2024 11:00	0.21348	0.22746
07/03/2024 12:00	0.21396	0.22776
07/03/2024 13:00	0.21882	0.23286
07/03/2024 14:00	0.30432	0.31980
07/03/2024 15:00	0.33996	0.35742
07/03/2024 16:00	0.36546	0.38292
07/03/2024 17:00	0.37800	0.39480
07/03/2024 18:00	0.37674	0.39438
07/03/2024 19:00	0.37506	0.39300
07/03/2024 20:00	0.35160	0.37056
07/03/2024 21:00	0.24234	0.25866
07/03/2024 22:00	0.21234	0.22878
07/03/2024 23:00	0.21258	0.22908
Average/Sum#:	0.25592	0.27230
Minimum:	0.21198	0.22746
Maximum:	0.37800	0.39480
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/04/2024 00:00	0.21306	0.22932
07/04/2024 01:00	0.21258	0.22920
07/04/2024 02:00	0.21234	0.22914
07/04/2024 03:00	0.21228	0.22932
07/04/2024 04:00	0.21240	0.22968
07/04/2024 05:00	0.21258	0.22974
07/04/2024 06:00	0.21282	0.22944
07/04/2024 07:00	0.21324	0.22920
07/04/2024 08:00	0.21306	0.22884
07/04/2024 09:00	0.21300	0.22866
07/04/2024 10:00	0.21324	0.22830
07/04/2024 11:00	0.21402	0.22830
07/04/2024 12:00	0.21408	0.22788
07/04/2024 13:00	0.21402	0.22764
07/04/2024 14:00	0.21402	0.22770
07/04/2024 15:00	0.21342	0.22734
07/04/2024 16:00	0.24024	0.25668
07/04/2024 17:00	0.22362	0.23874
07/04/2024 18:00	0.24552	0.26292
07/04/2024 19:00	0.21294	0.22830
07/04/2024 20:00	0.21204	0.22776
07/04/2024 21:00	0.21192	0.22788
07/04/2024 22:00	0.21198	0.22806
07/04/2024 23:00	0.21276	0.22914
Average/Sum#:	0.21588	0.23163
Minimum:	0.21192	0.22734
Maximum:	0.24552	0.26292
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/05/2024 00:00	0.24948	0.26892
07/05/2024 01:00	0.24912	0.26862
07/05/2024 02:00	0.24888	0.26838
07/05/2024 03:00	0.21216	0.22914
07/05/2024 04:00	0.21174	0.22914
07/05/2024 05:00	0.21198	0.22914
07/05/2024 06:00	0.21210	0.22890
07/05/2024 07:00	0.21264	0.22866
07/05/2024 08:00	0.21228	0.22818
07/05/2024 09:00	0.21198	0.22782
07/05/2024 10:00	0.21204	0.22740
07/05/2024 11:00	0.21294	0.22722
07/05/2024 12:00	0.21312	0.22698
07/05/2024 13:00	0.21312	0.22680
07/05/2024 14:00	0.21312	0.22662
07/05/2024 15:00	0.21318	0.22662
07/05/2024 16:00	0.21300	0.22626
07/05/2024 17:00	0.24936	0.26652
07/05/2024 18:00	0.36168	0.38028
07/05/2024 19:00	0.31572	0.33486
07/05/2024 20:00	0.24102	0.25770
07/05/2024 21:00	0.21150	0.22752
07/05/2024 22:00	0.21144	0.22758
07/05/2024 23:00	0.21138	0.22782
Average/Sum#:	0.23021	0.24655
Minimum:	0.21138	0.22626
Maximum:	0.36168	0.38028
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
07/06/2024 00:00	0.21144	0.22812
07/06/2024 01:00	0.21168	0.22836
07/06/2024 02:00	0.21168	0.22842
07/06/2024 03:00	0.21162	0.22854
07/06/2024 04:00	0.21210	0.22902
07/06/2024 05:00	0.21222	0.22932
07/06/2024 06:00	0.21210	0.22914
07/06/2024 07:00	0.21264	0.22866
07/06/2024 08:00	0.21252	0.22836
07/06/2024 09:00	0.21234	0.22794
07/06/2024 10:00	0.21246	0.22782
07/06/2024 11:00	0.21336	0.22746
07/06/2024 12:00	0.21492	0.22878
07/06/2024 13:00	0.21522	0.22890
07/06/2024 14:00	0.23460	0.25050
07/06/2024 15:00	0.21546	0.22920
07/06/2024 16:00	0.22416	0.23892
07/06/2024 17:00	0.26652	0.28512
07/06/2024 18:00	0.35868	0.37824
07/06/2024 19:00	0.33420	0.35394
07/06/2024 20:00	0.29118	0.30984
07/06/2024 21:00	0.25662	0.27558
07/06/2024 22:00	0.25200	0.27072
07/06/2024 23:00	0.21906	0.23562
Average/Sum#:	0.23453	0.25111
Minimum:	0.21144	0.22746
Maximum:	0.35868	0.37824
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/07/2024 00:00	0.21246	0.22854
07/07/2024 01:00	0.21216	0.22860
07/07/2024 02:00	0.21204	0.22878
07/07/2024 03:00	0.21198	0.22896
07/07/2024 04:00	0.21204	0.22914
07/07/2024 05:00	0.21246	0.22926
07/07/2024 06:00	0.21270	0.22926
07/07/2024 07:00	0.21306	0.22884
07/07/2024 08:00	0.21258	0.22842
07/07/2024 09:00	0.21252	0.22824
07/07/2024 10:00	0.21276	0.22818
07/07/2024 11:00	0.21360	0.22794
07/07/2024 12:00	0.22494	0.24000
07/07/2024 13:00	0.22332	0.23850
07/07/2024 14:00	0.24054	0.25752
07/07/2024 15:00	0.22938	0.24558
07/07/2024 16:00	0.35568	0.37602
07/07/2024 17:00	0.36360	0.38376
07/07/2024 18:00	0.36390	0.38262
07/07/2024 19:00	0.36174	0.38106
07/07/2024 20:00	0.35796	0.37734
07/07/2024 21:00	0.26724	0.28188
07/07/2024 22:00	0.21252	0.22908
07/07/2024 23:00	0.21246	0.22890
Average/Sum#:	0.24849	0.26527
Minimum:	0.21198	0.22794
Maximum:	0.36390	0.38376
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/08/2024 00:00	0.21234	0.22902
07/08/2024 01:00	0.21228	0.22920
07/08/2024 02:00	0.21222	0.22938
07/08/2024 03:00	0.21216	0.22950
07/08/2024 04:00	0.21216	0.22962
07/08/2024 05:00	0.21228	0.22956
07/08/2024 06:00	0.21252	0.22968
07/08/2024 07:00	0.21312	0.22938
07/08/2024 08:00	0.21276	0.22920
07/08/2024 09:00	0.21270	0.22884
07/08/2024 10:00	0.21270	0.22848
07/08/2024 11:00	0.21342	0.22824
07/08/2024 12:00	0.21642	0.23064
07/08/2024 13:00	0.22194	0.23676
07/08/2024 14:00	0.25956	0.27744
07/08/2024 15:00	0.23736	0.25392
07/08/2024 16:00	0.28134	0.30000
07/08/2024 17:00	0.37056	0.38856
07/08/2024 18:00	0.37398	0.39234
07/08/2024 19:00	0.36162	0.38154
07/08/2024 20:00	0.35898	0.37920
07/08/2024 21:00	0.34968	0.37002
07/08/2024 22:00	0.34848	0.36906
07/08/2024 23:00	0.33114	0.35232
Average/Sum#:	0.26091	0.27841
Minimum:	0.21216	0.22824
Maximum:	0.37398	0.39234
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/09/2024 00:00	0.26490	0.28314
07/09/2024 01:00	0.21270	0.22986
07/09/2024 02:00	0.21264	0.22992
07/09/2024 03:00	0.21276	0.23016
07/09/2024 04:00	0.21408	0.23172
07/09/2024 05:00	0.21270	0.23016
07/09/2024 06:00	0.21300	0.23016
07/09/2024 07:00	0.21342	0.23004
07/09/2024 08:00	0.21294	0.22980
07/09/2024 09:00	0.21258	0.22920
07/09/2024 10:00	0.21258	0.22878
07/09/2024 11:00	0.21336	0.22854
07/09/2024 12:00	0.21624	0.23106
07/09/2024 13:00	0.26364	0.28158
07/09/2024 14:00	0.25488	0.27270
07/09/2024 15:00	0.25230	0.26880
07/09/2024 16:00	0.35850	0.37632
07/09/2024 17:00	0.36456	0.38208
07/09/2024 18:00	0.37524	0.39336
07/09/2024 19:00	0.36390	0.38316
07/09/2024 20:00	0.35616	0.37590
07/09/2024 21:00	0.35544	0.37626
07/09/2024 22:00	0.35112	0.37254
07/09/2024 23:00	0.29244	0.31182
Average/Sum#:	0.26717	0.28488
Minimum:	0.21258	0.22854
Maximum:	0.37524	0.39336
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/10/2024 00:00	0.26076	0.28146
07/10/2024 01:00	0.25776	0.27822
07/10/2024 02:00	0.26262	0.28434
07/10/2024 03:00	0.25626	0.27684
07/10/2024 04:00	0.26358	0.28488
07/10/2024 05:00	0.24426	0.26370
07/10/2024 06:00	0.21426	0.23148
07/10/2024 07:00	0.21480	0.23148
07/10/2024 08:00	0.21426	0.23094
07/10/2024 09:00	0.21330	0.22956
07/10/2024 10:00	0.21330	0.22926
07/10/2024 11:00	0.21402	0.22902
07/10/2024 12:00	0.21402	0.22824
07/10/2024 13:00	0.23574	0.25212
07/10/2024 14:00	0.25056	0.26796
07/10/2024 15:00	0.23358	0.24924
07/10/2024 16:00	0.23574	0.25266
07/10/2024 17:00	0.34608	0.36534
07/10/2024 18:00	0.37050	0.38958
07/10/2024 19:00	0.36828	0.38730
07/10/2024 20:00	0.35358	0.37338
07/10/2024 21:00	0.32604	0.34596
07/10/2024 22:00	0.28974	0.30858
07/10/2024 23:00	0.23772	0.25638
Average/Sum#:	0.26212	0.28033
Minimum:	0.21330	0.22824
Maximum:	0.37050	0.38958
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/11/2024 00:00	0.21366	0.23046
07/11/2024 01:00	0.21306	0.22992
07/11/2024 02:00	0.21300	0.22992
07/11/2024 03:00	0.21312	0.22998
07/11/2024 04:00	0.21312	0.23010
07/11/2024 05:00	0.21318	0.23034
07/11/2024 06:00	0.21354	0.23058
07/11/2024 07:00	0.21462	0.23046
07/11/2024 08:00	0.21426	0.23058
07/11/2024 09:00	0.21414	0.23016
07/11/2024 10:00	0.21432	0.22992
07/11/2024 11:00	0.21402	0.22842
07/11/2024 12:00	0.22896	0.24438
07/11/2024 13:00	0.25860	0.27822
07/11/2024 14:00	0.34836	0.36816
07/11/2024 15:00	0.36792	0.38694
07/11/2024 16:00	0.36630	0.38532
07/11/2024 17:00	0.36828	0.38730
07/11/2024 18:00	0.36786	0.38718
07/11/2024 19:00	0.36666	0.38628
07/11/2024 20:00	0.36570	0.38550
07/11/2024 21:00	0.36480	0.38472
07/11/2024 22:00	0.31122	0.33174
07/11/2024 23:00	0.25686	0.27744
Average/Sum#:	0.27232	0.29017
Minimum:	0.21300	0.22842
Maximum:	0.36828	0.38730
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/12/2024 00:00	0.22272	0.24024
07/12/2024 01:00	0.21318	0.22992
07/12/2024 02:00	0.21300	0.23004
07/12/2024 03:00	0.21306	0.23034
07/12/2024 04:00	0.21324	0.23052
07/12/2024 05:00	0.21366	0.23094
07/12/2024 06:00	0.22452	0.24198
07/12/2024 07:00	0.21444	0.23064
07/12/2024 08:00	0.21384	0.23052
07/12/2024 09:00	0.21372	0.22950
07/12/2024 10:00	0.21402	0.22914
07/12/2024 11:00	0.23766	0.25416
07/12/2024 12:00	0.25854	0.27546
07/12/2024 13:00	0.25830	0.27600
07/12/2024 14:00	0.27528	0.29334
07/12/2024 15:00	0.30990	0.32868
07/12/2024 16:00	0.32550	0.34476
07/12/2024 17:00	0.36846	0.38844
07/12/2024 18:00	0.36780	0.38748
07/12/2024 19:00	0.35034	0.36966
07/12/2024 20:00	0.34212	0.36144
07/12/2024 21:00	0.25560	0.27438
07/12/2024 22:00	0.25422	0.27312
07/12/2024 23:00	0.21846	0.23544
Average/Sum#:	0.25798	0.27567
Minimum:	0.21300	0.22914
Maximum:	0.36846	0.38844
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/13/2024 00:00	0.21210	0.22860
07/13/2024 01:00	0.21084	0.22752
07/13/2024 02:00	0.21438	0.23142
07/13/2024 03:00	0.21864	0.23286
07/13/2024 04:00	0.21024	0.22698
07/13/2024 05:00	0.21024	0.22722
07/13/2024 06:00	0.21036	0.22704
07/13/2024 07:00	0.21078	0.22698
07/13/2024 08:00	0.24336	0.25800
07/13/2024 09:00	0.22608	0.24222
07/13/2024 10:00	0.21324	0.22950
07/13/2024 11:00	0.21282	0.22884
07/13/2024 12:00	0.21396	0.22848
07/13/2024 13:00	0.21432	0.22884
07/13/2024 14:00	0.21498	0.22962
07/13/2024 15:00	0.21588	0.23082
07/13/2024 16:00	0.21936	0.23490
07/13/2024 17:00	0.22962	0.24528
07/13/2024 18:00	0.25236	0.27240
07/13/2024 19:00	0.21678	0.23322
07/13/2024 20:00	0.22416	0.24150
07/13/2024 21:00	0.21750	0.23436
07/13/2024 22:00	0.21612	0.23316
07/13/2024 23:00	0.21492	0.23196
Average/Sum#:	0.21846	0.23466
Minimum:	0.21024	0.22698
Maximum:	0.25236	0.27240
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/14/2024 00:00	0.21456	0.23142
07/14/2024 01:00	0.21372	0.23112
07/14/2024 02:00	0.21306	0.23022
07/14/2024 03:00	0.21210	0.22908
07/14/2024 04:00	0.21204	0.22914
07/14/2024 05:00	0.21216	0.22932
07/14/2024 06:00	0.21234	0.22938
07/14/2024 07:00	0.21234	0.22944
07/14/2024 08:00	0.21252	0.22938
07/14/2024 09:00	0.21276	0.22944
07/14/2024 10:00	0.21276	0.22902
07/14/2024 11:00	0.21276	0.22866
07/14/2024 12:00	0.21336	0.22836
07/14/2024 13:00	0.21264	0.22812
07/14/2024 14:00	0.22362	0.23892
07/14/2024 15:00	0.21738	0.23244
07/14/2024 16:00	0.21546	0.23016
07/14/2024 17:00	0.21984	0.23502
07/14/2024 18:00	0.23070	0.24732
07/14/2024 19:00	0.22890	0.24600
07/14/2024 20:00	0.22806	0.24552
07/14/2024 21:00	0.23856	0.25716
07/14/2024 22:00	0.21258	0.22980
07/14/2024 23:00	0.21210	0.22938
Average/Sum#:	0.21693	0.23349
Minimum:	0.21204	0.22812
Maximum:	0.23856	0.25716
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/15/2024 00:00	0.21222	0.22950
07/15/2024 01:00	0.21216	0.22950
07/15/2024 02:00	0.21210	0.22944
07/15/2024 03:00	0.22536	0.24378
07/15/2024 04:00	0.21216	0.22962
07/15/2024 05:00	0.21216	0.22950
07/15/2024 06:00	0.21234	0.22968
07/15/2024 07:00	0.21282	0.22938
07/15/2024 08:00	0.21270	0.22974
07/15/2024 09:00	0.21282	0.22950
07/15/2024 10:00	0.21312	0.22944
07/15/2024 11:00	0.21384	0.22914
07/15/2024 12:00	0.21408	0.22902
07/15/2024 13:00	0.21438	0.22902
07/15/2024 14:00	0.21426	0.22890
07/15/2024 15:00	0.21876	0.23382
07/15/2024 16:00	0.21462	0.22944
07/15/2024 17:00	0.21492	0.22986
07/15/2024 18:00	0.21396	0.22962
07/15/2024 19:00	0.21444	0.23100
07/15/2024 20:00	0.21348	0.23028
07/15/2024 21:00	0.21300	0.23004
07/15/2024 22:00	0.21276	0.22980
07/15/2024 23:00	0.21264	0.22992
Average/Sum#:	0.21396	0.23037
Minimum:	0.21210	0.22890
Maximum:	0.22536	0.24378
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/16/2024 00:00	0.21252	0.22980
07/16/2024 01:00	0.21240	0.22974
07/16/2024 02:00	0.21240	0.22998
07/16/2024 03:00	0.21240	0.23004
07/16/2024 04:00	0.22764	0.24648
07/16/2024 05:00	0.24486	0.26466
07/16/2024 06:00	0.21288	0.23028
07/16/2024 07:00	0.21342	0.23028
07/16/2024 08:00	0.21294	0.22986
07/16/2024 09:00	0.21276	0.22962
07/16/2024 10:00	0.21264	0.22914
07/16/2024 11:00	0.21336	0.22872
07/16/2024 12:00	0.21354	0.22848
07/16/2024 13:00	0.21342	0.22800
07/16/2024 14:00	0.22194	0.23724
07/16/2024 15:00	0.25380	0.27186
07/16/2024 16:00	0.21282	0.22770
07/16/2024 17:00	0.26130	0.27786
07/16/2024 18:00	0.31386	0.33438
07/16/2024 19:00	0.30318	0.32454
07/16/2024 20:00	0.31134	0.31452
07/16/2024 21:00	0.27210	0.27120
07/16/2024 22:00	0.23130	0.25026
07/16/2024 23:00	0.21270	0.23022
Average/Sum#:	0.23423	0.25020
Minimum:	0.21240	0.22770
Maximum:	0.31386	0.33438
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
07/17/2024 00:00	0.21276	0.23064
07/17/2024 01:00	0.21288	0.23082
07/17/2024 02:00	0.21282	0.23076
07/17/2024 03:00	0.21270	0.23082
07/17/2024 04:00	0.21378	0.23226
07/17/2024 05:00	0.23310	0.25248
07/17/2024 06:00	0.21300	0.23070
07/17/2024 07:00	0.21354	0.23058
07/17/2024 08:00	0.21306	0.23022
07/17/2024 09:00	0.21288	0.22998
07/17/2024 10:00	0.21294	0.22956
07/17/2024 11:00	0.21330	0.22890
07/17/2024 12:00	0.21342	0.22872
07/17/2024 13:00	0.21342	0.22836
07/17/2024 14:00	0.21318	0.22782
07/17/2024 15:00	0.21270	0.22770
07/17/2024 16:00	0.21264	0.22758
07/17/2024 17:00	0.23238	0.24894
07/17/2024 18:00	0.23574	0.25314
07/17/2024 19:00	0.25998	0.28050
07/17/2024 20:00	0.26706	0.28782
07/17/2024 21:00	0.26622	0.28764
07/17/2024 22:00	0.23964	0.25872
07/17/2024 23:00	0.21264	0.23016
Average/Sum#:	0.22316	0.24062
Minimum:	0.21264	0.22758
Maximum:	0.26706	0.28782
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
07/18/2024 00:00	0.21228	0.22962
07/18/2024 01:00	0.21228	0.00000
07/18/2024 02:00	0.21228	0.22938
07/18/2024 03:00	0.21240	0.23064
07/18/2024 04:00	0.22290	0.23040
07/18/2024 05:00	0.21396	0.23034
07/18/2024 06:00	0.21300	0.23028
07/18/2024 07:00	0.21330	0.22992
07/18/2024 08:00	0.21276	0.22956
07/18/2024 09:00	0.21234	0.22902
07/18/2024 10:00	0.21246	0.22866
07/18/2024 11:00	0.22542	0.24102
07/18/2024 12:00	0.23700	0.25302
07/18/2024 13:00	0.23592	0.25188
07/18/2024 14:00	0.25746	0.27516
07/18/2024 15:00	0.26202	0.21882
07/18/2024 16:00	0.26826	0.00000
07/18/2024 17:00	0.38418	0.00000
07/18/2024 18:00	0.38610	0.00000
07/18/2024 19:00	0.38694	0.00000
07/18/2024 20:00	0.38610	0.00000
07/18/2024 21:00	0.33222	0.00000
07/18/2024 22:00	0.32154	0.00000
07/18/2024 23:00	0.31728	0.00000
Average/Sum#:	0.26460	0.23585
Minimum:	0.21228	0.21882
Maximum:	0.38694	0.27516
%SI	0.00	37.50

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
07/19/2024 00:00	0.31554	0.00000
07/19/2024 01:00	0.31332	0.00000
07/19/2024 02:00	0.31146	0.00000
07/19/2024 03:00	0.31104	0.00000
07/19/2024 04:00	0.31194	0.00000
07/19/2024 05:00	0.31578	0.00000
07/19/2024 06:00	0.30882	0.00000
07/19/2024 07:00	0.29622	0.00000
07/19/2024 08:00	0.21930	0.00000
07/19/2024 09:00	0.21702	0.00000
07/19/2024 10:00	0.21564	0.00000
07/19/2024 11:00	0.22746	0.00000
07/19/2024 12:00	0.32382	0.00000
07/19/2024 13:00	0.32778	0.00000
07/19/2024 14:00	0.35892	0.00000
07/19/2024 15:00	0.38232	0.00000
07/19/2024 16:00	0.38322	0.00000
07/19/2024 17:00	0.38322	0.00000
07/19/2024 18:00	0.38364	0.00000
07/19/2024 19:00	0.37974	0.00000
07/19/2024 20:00	0.35058	0.00000
07/19/2024 21:00	0.35970	0.00000
07/19/2024 22:00	0.36546	0.00000
07/19/2024 23:00	0.34908	0.00000
Average/Sum#:	0.32129	0.00000
Minimum:	0.21564	0.00000
Maximum:	0.38364	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/20/2024 00:00	0.33240	0.00000
07/20/2024 01:00	0.31368	0.00000
07/20/2024 02:00	0.31572	0.00000
07/20/2024 03:00	0.31992	0.00000
07/20/2024 04:00	0.31392	0.00000
07/20/2024 05:00	0.31302	0.00000
07/20/2024 06:00	0.30624	0.00000
07/20/2024 07:00	0.24768	0.13932
07/20/2024 08:00	0.21852	0.23538
07/20/2024 09:00	0.21378	0.22842
07/20/2024 10:00	0.21396	0.22818
07/20/2024 11:00	0.23040	0.23742
07/20/2024 12:00	0.24168	0.24690
07/20/2024 13:00	0.25752	0.27534
07/20/2024 14:00	0.26166	0.28494
07/20/2024 15:00	0.31314	0.33150
07/20/2024 16:00	0.31260	0.33198
07/20/2024 17:00	0.34170	0.36018
07/20/2024 18:00	0.36012	0.37860
07/20/2024 19:00	0.35736	0.37692
07/20/2024 20:00	0.35568	0.37662
07/20/2024 21:00	0.35406	0.37518
07/20/2024 22:00	0.35244	0.37380
07/20/2024 23:00	0.34854	0.36978
Average/Sum#:	0.29982	0.30297
Minimum:	0.21378	0.13932
Maximum:	0.36012	0.37860
%SI	0.00	29.17

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/21/2024 00:00	0.27096	0.29064
07/21/2024 01:00	0.21264	0.22986
07/21/2024 02:00	0.21258	0.22986
07/21/2024 03:00	0.21258	0.23016
07/21/2024 04:00	0.21252	0.23022
07/21/2024 05:00	0.21318	0.23070
07/21/2024 06:00	0.21318	0.23046
07/21/2024 07:00	0.21372	0.23052
07/21/2024 08:00	0.21324	0.23022
07/21/2024 09:00	0.21312	0.22992
07/21/2024 10:00	0.21312	0.22956
07/21/2024 11:00	0.21384	0.22908
07/21/2024 12:00	0.21384	0.22872
07/21/2024 13:00	0.21378	0.22848
07/21/2024 14:00	0.21366	0.22818
07/21/2024 15:00	0.21318	0.22812
07/21/2024 16:00	0.21318	0.22794
07/21/2024 17:00	0.23556	0.25218
07/21/2024 18:00	0.25722	0.27606
07/21/2024 19:00	0.25092	0.26970
07/21/2024 20:00	0.25410	0.27282
07/21/2024 21:00	0.25518	0.27468
07/21/2024 22:00	0.22746	0.24558
07/21/2024 23:00	0.24300	0.26232
Average/Sum#:	0.22524	0.24233
Minimum:	0.21252	0.22794
Maximum:	0.27096	0.29064
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/22/2024 00:00	0.23088	0.24930
07/22/2024 01:00	0.21246	0.22968
07/22/2024 02:00	0.25464	0.27570
07/22/2024 03:00	0.25434	0.27480
07/22/2024 04:00	0.26352	0.28446
07/22/2024 05:00	0.24792	0.26778
07/22/2024 06:00	0.21318	0.23022
07/22/2024 07:00	0.21336	0.22968
07/22/2024 08:00	0.21288	0.22926
07/22/2024 09:00	0.21288	0.22914
07/22/2024 10:00	0.21276	0.22854
07/22/2024 11:00	0.22710	0.24282
07/22/2024 12:00	0.25596	0.27384
07/22/2024 13:00	0.25866	0.27606
07/22/2024 14:00	0.25848	0.27630
07/22/2024 15:00	0.34728	0.36606
07/22/2024 16:00	0.36528	0.38286
07/22/2024 17:00	0.36906	0.38700
07/22/2024 18:00	0.36330	0.38154
07/22/2024 19:00	0.36054	0.37914
07/22/2024 20:00	0.33162	0.35058
07/22/2024 21:00	0.32754	0.34710
07/22/2024 22:00	0.27306	0.29184
07/22/2024 23:00	0.25716	0.27708
Average/Sum#:	0.27183	0.29003
Minimum:	0.21246	0.22854
Maximum:	0.36906	0.38700
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/23/2024 00:00	0.24924	0.26832
07/23/2024 01:00	0.25482	0.27444
07/23/2024 02:00	0.24672	0.26556
07/23/2024 03:00	0.24390	0.26196
07/23/2024 04:00	0.34806	0.37014
07/23/2024 05:00	0.35502	0.37686
07/23/2024 06:00	0.35250	0.37296
07/23/2024 07:00	0.35466	0.37416
07/23/2024 08:00	0.35586	0.37542
07/23/2024 09:00	0.35664	0.37602
07/23/2024 10:00	0.35724	0.37542
07/23/2024 11:00	0.35886	0.37632
07/23/2024 12:00	0.36726	0.38466
07/23/2024 13:00	0.37350	0.39198
07/23/2024 14:00	0.37248	0.39162
07/23/2024 15:00	0.37122	0.39066
07/23/2024 16:00	0.37050	0.38988
07/23/2024 17:00	0.37122	0.39066
07/23/2024 18:00	0.37020	0.38958
07/23/2024 19:00	0.36762	0.38670
07/23/2024 20:00	0.36648	0.38532
07/23/2024 21:00	0.36540	0.38490
07/23/2024 22:00	0.36474	0.38580
07/23/2024 23:00	0.35412	0.37578
Average/Sum#:	0.34368	0.36313
Minimum:	0.24390	0.26196
Maximum:	0.37350	0.39198
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/24/2024 00:00	0.30486	0.32790
07/24/2024 01:00	0.24366	0.25914
07/24/2024 02:00	0.21390	0.23082
07/24/2024 03:00	0.22368	0.24150
07/24/2024 04:00	0.29982	0.32166
07/24/2024 05:00	0.32994	0.35220
07/24/2024 06:00	0.25998	0.25074
07/24/2024 07:00	0.24090	0.25848
07/24/2024 08:00	0.21840	0.23466
07/24/2024 09:00	0.25356	0.27204
07/24/2024 10:00	0.25920	0.27810
07/24/2024 11:00	0.33594	0.35484
07/24/2024 12:00	0.36648	0.38478
07/24/2024 13:00	0.36666	0.38466
07/24/2024 14:00	0.37146	0.38916
07/24/2024 15:00	0.37146	0.38988
07/24/2024 16:00	0.36984	0.38904
07/24/2024 17:00	0.46212	0.39570
07/24/2024 18:00	0.46956	0.39438
07/24/2024 19:00	0.46338	0.39132
07/24/2024 20:00	0.41118	0.39048
07/24/2024 21:00	0.36522	0.38802
07/24/2024 22:00	0.31566	0.33876
07/24/2024 23:00	0.30162	0.31494
Average/Sum#:	0.32577	0.33055
Minimum:	0.21390	0.23082
Maximum:	0.46956	0.39570
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/25/2024 00:00	0.24954	0.26874
07/25/2024 01:00	0.22968	0.24762
07/25/2024 02:00	0.21264	0.22938
07/25/2024 03:00	0.21270	0.22950
07/25/2024 04:00	0.22860	0.24678
07/25/2024 05:00	0.24996	0.26982
07/25/2024 06:00	0.22542	0.24270
07/25/2024 07:00	0.21342	0.22956
07/25/2024 08:00	0.21300	0.22944
07/25/2024 09:00	0.21426	0.23076
07/25/2024 10:00	0.21474	0.23070
07/25/2024 11:00	0.21558	0.23052
07/25/2024 12:00	0.24270	0.25944
07/25/2024 13:00	0.31680	0.33294
07/25/2024 14:00	0.34722	0.36612
07/25/2024 15:00	0.34854	0.36840
07/25/2024 16:00	0.34944	0.36888
07/25/2024 17:00	0.36060	0.37980
07/25/2024 18:00	0.36726	0.38658
07/25/2024 19:00	0.36390	0.38400
07/25/2024 20:00	0.36168	0.38310
07/25/2024 21:00	0.30438	0.32490
07/25/2024 22:00	0.24324	0.26226
07/25/2024 23:00	0.21276	0.22944
Average/Sum#:	0.27075	0.28881
Minimum:	0.21264	0.22938
Maximum:	0.36726	0.38658
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/26/2024 00:00	0.21240	0.22920
07/26/2024 01:00	0.21210	0.22914
07/26/2024 02:00	0.21186	0.22926
07/26/2024 03:00	0.21192	0.22926
07/26/2024 04:00	0.21192	0.22938
07/26/2024 05:00	0.21186	0.22926
07/26/2024 06:00	0.21222	0.22890
07/26/2024 07:00	0.21258	0.22848
07/26/2024 08:00	0.21192	0.22824
07/26/2024 09:00	0.21192	0.22800
07/26/2024 10:00	0.21216	0.22794
07/26/2024 11:00	0.21294	0.22776
07/26/2024 12:00	0.21378	0.22812
07/26/2024 13:00	0.21408	0.22800
07/26/2024 14:00	0.21426	0.22866
07/26/2024 15:00	0.21372	0.22860
07/26/2024 16:00	0.21360	0.22854
07/26/2024 17:00	0.22044	0.23520
07/26/2024 18:00	0.26700	0.28464
07/26/2024 19:00	0.25632	0.27612
07/26/2024 20:00	0.23688	0.25542
07/26/2024 21:00	0.21198	0.22902
07/26/2024 22:00	0.21228	0.22956
07/26/2024 23:00	0.21210	0.22998
Average/Sum#:	0.21801	0.23445
Minimum:	0.21186	0.22776
Maximum:	0.26700	0.28464
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/27/2024 00:00	0.21222	0.23022
07/27/2024 01:00	0.21246	0.23070
07/27/2024 02:00	0.21246	0.23076
07/27/2024 03:00	0.21258	0.23082
07/27/2024 04:00	0.21270	0.23106
07/27/2024 05:00	0.21306	0.23124
07/27/2024 06:00	0.21318	0.23130
07/27/2024 07:00	0.21330	0.23100
07/27/2024 08:00	0.21336	0.23070
07/27/2024 09:00	0.21336	0.23064
07/27/2024 10:00	0.21324	0.23046
07/27/2024 11:00	0.21408	0.23040
07/27/2024 12:00	0.21414	0.23004
07/27/2024 13:00	0.21396	0.22956
07/27/2024 14:00	0.21372	0.22926
07/27/2024 15:00	0.21300	0.22902
07/27/2024 16:00	0.21318	0.22914
07/27/2024 17:00	0.21306	0.22926
07/27/2024 18:00	0.21288	0.22968
07/27/2024 19:00	0.21276	0.22992
07/27/2024 20:00	0.21264	0.23004
07/27/2024 21:00	0.21252	0.23022
07/27/2024 22:00	0.21264	0.23046
07/27/2024 23:00	0.21270	0.23064
Average/Sum#:	0.21305	0.23027
Minimum:	0.21222	0.22902
Maximum:	0.21414	0.23130
%SI	0.00	0.00

AQ33 HOURLY SOX



From:

07/01/2024 00:00

To:

09/30/2024 23:59

Facility Name:

ROSEVILLE ENERGY

Generated:

10/11/2024 08:21

Location:

Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/28/2024 00:00	0.21282	0.23076
07/28/2024 01:00	0.21294	0.23100
07/28/2024 02:00	0.21282	0.23112
07/28/2024 03:00	0.21264	0.23112
07/28/2024 04:00	0.21282	0.23118
07/28/2024 05:00	0.21288	0.23136
07/28/2024 06:00	0.21324	0.23136
07/28/2024 07:00	0.21354	0.23124
07/28/2024 08:00	0.21336	0.23094
07/28/2024 09:00	0.21348	0.23064
07/28/2024 10:00	0.21336	0.23028
07/28/2024 11:00	0.21342	0.22920
07/28/2024 12:00	0.21348	0.22902
07/28/2024 13:00	0.21414	0.22938
07/28/2024 14:00	0.21462	0.23010
07/28/2024 15:00	0.21444	0.23016
07/28/2024 16:00	0.21426	0.22992
07/28/2024 17:00	0.21954	0.23568
07/28/2024 18:00	0.21330	0.22908
07/28/2024 19:00	0.21222	0.22896
07/28/2024 20:00	0.21258	0.22974
07/28/2024 21:00	0.21282	0.23034
07/28/2024 22:00	0.21300	0.23064
07/28/2024 23:00	0.21312	0.23082
Average/Sum#:	0.21354	0.23059
Minimum:	0.21222	0.22896
Maximum:	0.21954	0.23568
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/29/2024 00:00	0.21324	0.23130
07/29/2024 01:00	0.21348	0.23142
07/29/2024 02:00	0.21360	0.23142
07/29/2024 03:00	0.21354	0.23166
07/29/2024 04:00	0.21360	0.23178
07/29/2024 05:00	0.21366	0.23196
07/29/2024 06:00	0.21396	0.23172
07/29/2024 07:00	0.21426	0.23160
07/29/2024 08:00	0.21360	0.23100
07/29/2024 09:00	0.21336	0.23058
07/29/2024 10:00	0.21342	0.23040
07/29/2024 11:00	0.21408	0.22968
07/29/2024 12:00	0.21372	0.22908
07/29/2024 13:00	0.21378	0.22884
07/29/2024 14:00	0.21354	0.22860
07/29/2024 15:00	0.21312	0.22842
07/29/2024 16:00	0.22152	0.23706
07/29/2024 17:00	0.27486	0.28632
07/29/2024 18:00	0.33672	0.35694
07/29/2024 19:00	0.30198	0.32340
07/29/2024 20:00	0.30060	0.32274
07/29/2024 21:00	0.26274	0.28128
07/29/2024 22:00	0.21252	0.23010
07/29/2024 23:00	0.21246	0.23010
Average/Sum#:	0.23089	0.24823
Minimum:	0.21246	0.22842
Maximum:	0.33672	0.35694
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/30/2024 00:00	0.21252	0.23028
07/30/2024 01:00	0.21246	0.23028
07/30/2024 02:00	0.21246	0.23040
07/30/2024 03:00	0.21240	0.23034
07/30/2024 04:00	0.21258	0.23076
07/30/2024 05:00	0.23160	0.25098
07/30/2024 06:00	0.21288	0.23034
07/30/2024 07:00	0.21336	0.23040
07/30/2024 08:00	0.21270	0.22998
07/30/2024 09:00	0.21276	0.22968
07/30/2024 10:00	0.21252	0.22902
07/30/2024 11:00	0.21312	0.22848
07/30/2024 12:00	0.21438	0.22956
07/30/2024 13:00	0.21324	0.22806
07/30/2024 14:00	0.21294	0.22770
07/30/2024 15:00	0.24546	0.26088
07/30/2024 16:00	0.33114	0.34986
07/30/2024 17:00	0.36042	0.37908
07/30/2024 18:00	0.36324	0.38208
07/30/2024 19:00	0.35550	0.37512
07/30/2024 20:00	0.34452	0.36516
07/30/2024 21:00	0.29610	0.31614
07/30/2024 22:00	0.21306	0.23022
07/30/2024 23:00	0.21852	0.23640
Average/Sum#:	0.24750	0.26505
Minimum:	0.21240	0.22770
Maximum:	0.36324	0.38208
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/31/2024 00:00	0.21162	0.22926
07/31/2024 01:00	0.21156	0.22938
07/31/2024 02:00	0.21180	0.22956
07/31/2024 03:00	0.21408	0.23220
07/31/2024 04:00	0.24078	0.26010
07/31/2024 05:00	0.24324	0.26358
07/31/2024 06:00	0.21270	0.22980
07/31/2024 07:00	0.21288	0.22974
07/31/2024 08:00	0.21234	0.22932
07/31/2024 09:00	0.21210	0.22878
07/31/2024 10:00	0.21180	0.22824
07/31/2024 11:00	0.21444	0.23004
07/31/2024 12:00	0.22092	0.23634
07/31/2024 13:00	0.21306	0.22770
07/31/2024 14:00	0.22350	0.23874
07/31/2024 15:00	0.24624	0.26316
07/31/2024 16:00	0.33966	0.35802
07/31/2024 17:00	0.33318	0.35172
07/31/2024 18:00	0.35400	0.37272
07/31/2024 19:00	0.32862	0.34830
07/31/2024 20:00	0.35106	0.37128
07/31/2024 21:00	0.34188	0.36306
07/31/2024 22:00	0.33324	0.35586
07/31/2024 23:00	0.30120	0.31860
Average/Sum#:	0.25816	0.27606
Minimum:	0.21156	0.22770
Maximum:	0.35400	0.37272
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/01/2024 00:00	0.24606	0.26598
08/01/2024 01:00	0.21960	0.23736
08/01/2024 02:00	0.21366	0.23118
08/01/2024 03:00	0.21858	0.23658
08/01/2024 04:00	0.22770	0.24672
08/01/2024 05:00	0.25404	0.27420
08/01/2024 06:00	0.21726	0.23448
08/01/2024 07:00	0.22452	0.19962
08/01/2024 08:00	0.21756	0.00000
08/01/2024 09:00	0.21750	0.00000
08/01/2024 10:00	0.21780	0.00000
08/01/2024 11:00	0.24756	0.00000
08/01/2024 12:00	0.23736	0.00000
08/01/2024 13:00	0.26580	0.00000
08/01/2024 14:00	0.25710	0.11736
08/01/2024 15:00	0.24798	0.26664
08/01/2024 16:00	0.35760	0.37746
08/01/2024 17:00	0.35052	0.37026
08/01/2024 18:00	0.36072	0.38076
08/01/2024 19:00	0.34110	0.36210
08/01/2024 20:00	0.35856	0.37902
08/01/2024 21:00	0.35688	0.37734
08/01/2024 22:00	0.34044	0.36162
08/01/2024 23:00	0.30156	0.32304
Average/Sum#:	0.27073	0.29121
Minimum:	0.21366	0.11736
Maximum:	0.36072	0.38076
%SI	0.00	25.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/02/2024 00:00	0.25002	0.26898
08/02/2024 01:00	0.22668	0.24486
08/02/2024 02:00	0.21396	0.23136
08/02/2024 03:00	0.22344	0.24204
08/02/2024 04:00	0.25596	0.27714
08/02/2024 05:00	0.25560	0.27600
08/02/2024 06:00	0.25392	0.27408
08/02/2024 07:00	0.25446	0.27540
08/02/2024 08:00	0.25854	0.27846
08/02/2024 09:00	0.28134	0.29472
08/02/2024 10:00	0.36120	0.38058
08/02/2024 11:00	0.36444	0.38280
08/02/2024 12:00	0.36396	0.38262
08/02/2024 13:00	0.36480	0.38370
08/02/2024 14:00	0.35850	0.37704
08/02/2024 15:00	0.34176	0.36042
08/02/2024 16:00	0.30744	0.32670
08/02/2024 17:00	0.31686	0.33666
08/02/2024 18:00	0.33462	0.35478
08/02/2024 19:00	0.30312	0.32358
08/02/2024 20:00	0.30300	0.32322
08/02/2024 21:00	0.28776	0.30702
08/02/2024 22:00	0.25476	0.27474
08/02/2024 23:00	0.25086	0.27018
Average/Sum#:	0.29113	0.31030
Minimum:	0.21396	0.23136
Maximum:	0.36480	0.38370
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/03/2024 00:00	0.23928	0.25776
08/03/2024 01:00	0.21840	0.23592
08/03/2024 02:00	0.21270	0.22992
08/03/2024 03:00	0.21276	0.22974
08/03/2024 04:00	0.21258	0.22980
08/03/2024 05:00	0.21294	0.23010
08/03/2024 06:00	0.21300	0.23004
08/03/2024 07:00	0.21300	0.22986
08/03/2024 08:00	0.21276	0.22968
08/03/2024 09:00	0.21276	0.22914
08/03/2024 10:00	0.21258	0.22878
08/03/2024 11:00	0.21330	0.22842
08/03/2024 12:00	0.21366	0.22836
08/03/2024 13:00	0.21384	0.22818
08/03/2024 14:00	0.21378	0.22806
08/03/2024 15:00	0.21324	0.22818
08/03/2024 16:00	0.21306	0.22812
08/03/2024 17:00	0.24024	0.25668
08/03/2024 18:00	0.35670	0.37542
08/03/2024 19:00	0.33738	0.35700
08/03/2024 20:00	0.27102	0.28794
08/03/2024 21:00	0.23928	0.25776
08/03/2024 22:00	0.24720	0.26706
08/03/2024 23:00	0.22056	0.23778
Average/Sum#:	0.23192	0.24874
Minimum:	0.21258	0.22806
Maximum:	0.35670	0.37542
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/04/2024 00:00	0.21234	0.22944
08/04/2024 01:00	0.21234	0.22962
08/04/2024 02:00	0.21258	0.22980
08/04/2024 03:00	0.21252	0.22986
08/04/2024 04:00	0.21252	0.23016
08/04/2024 05:00	0.21270	0.23040
08/04/2024 06:00	0.21336	0.23058
08/04/2024 07:00	0.21378	0.23034
08/04/2024 08:00	0.21306	0.23016
08/04/2024 09:00	0.21294	0.22980
08/04/2024 10:00	0.21306	0.22950
08/04/2024 11:00	0.21372	0.22914
08/04/2024 12:00	0.21366	0.22878
08/04/2024 13:00	0.21372	0.22818
08/04/2024 14:00	0.21360	0.22824
08/04/2024 15:00	0.21306	0.22812
08/04/2024 16:00	0.21288	0.22794
08/04/2024 17:00	0.26886	0.28608
08/04/2024 18:00	0.35718	0.37632
08/04/2024 19:00	0.31488	0.33522
08/04/2024 20:00	0.30456	0.32574
08/04/2024 21:00	0.25602	0.27606
08/04/2024 22:00	0.25062	0.27042
08/04/2024 23:00	0.23316	0.25188
Average/Sum#:	0.23363	0.25091
Minimum:	0.21234	0.22794
Maximum:	0.35718	0.37632
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/05/2024 00:00	0.21756	0.23556
08/05/2024 01:00	0.21234	0.23010
08/05/2024 02:00	0.21234	0.23034
08/05/2024 03:00	0.21240	0.23046
08/05/2024 04:00	0.24126	0.26166
08/05/2024 05:00	0.24294	0.26328
08/05/2024 06:00	0.22824	0.24684
08/05/2024 07:00	0.21414	0.23124
08/05/2024 08:00	0.21354	0.23100
08/05/2024 09:00	0.21360	0.23082
08/05/2024 10:00	0.21366	0.23052
08/05/2024 11:00	0.21426	0.23010
08/05/2024 12:00	0.24030	0.25722
08/05/2024 13:00	0.21642	0.23148
08/05/2024 14:00	0.23322	0.24948
08/05/2024 15:00	0.21492	0.23022
08/05/2024 16:00	0.21492	0.23022
08/05/2024 17:00	0.22794	0.24438
08/05/2024 18:00	0.30342	0.32292
08/05/2024 19:00	0.24330	0.26034
08/05/2024 20:00	0.22872	0.24714
08/05/2024 21:00	0.24060	0.25986
08/05/2024 22:00	0.24060	0.26004
08/05/2024 23:00	0.21318	0.23100
Average/Sum#:	0.22724	0.24484
Minimum:	0.21234	0.23010
Maximum:	0.30342	0.32292
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/06/2024 00:00	0.21252	0.23040
08/06/2024 01:00	0.21258	0.23058
08/06/2024 02:00	0.21264	0.23064
08/06/2024 03:00	0.21270	0.23070
08/06/2024 04:00	0.21282	0.23106
08/06/2024 05:00	0.21498	0.23352
08/06/2024 06:00	0.21708	0.23484
08/06/2024 07:00	0.21378	0.23088
08/06/2024 08:00	0.21300	0.23046
08/06/2024 09:00	0.21276	0.22974
08/06/2024 10:00	0.21276	0.22920
08/06/2024 11:00	0.21348	0.22890
08/06/2024 12:00	0.21360	0.22854
08/06/2024 13:00	0.21372	0.22830
08/06/2024 14:00	0.21354	0.22806
08/06/2024 15:00	0.21300	0.22794
08/06/2024 16:00	0.22368	0.23958
08/06/2024 17:00	0.24378	0.26046
08/06/2024 18:00	0.35406	0.37332
08/06/2024 19:00	0.30414	0.32520
08/06/2024 20:00	0.26364	0.28182
08/06/2024 21:00	0.25560	0.27570
08/06/2024 22:00	0.24888	0.26838
08/06/2024 23:00	0.22782	0.24606
Average/Sum#:	0.23069	0.24810
Minimum:	0.21252	0.22794
Maximum:	0.35406	0.37332
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/07/2024 00:00	0.21234	0.22986
08/07/2024 01:00	0.21216	0.22944
08/07/2024 02:00	0.21234	0.22956
08/07/2024 03:00	0.21246	0.22998
08/07/2024 04:00	0.21240	0.23016
08/07/2024 05:00	0.21372	0.23172
08/07/2024 06:00	0.22440	0.24246
08/07/2024 07:00	0.21342	0.22998
08/07/2024 08:00	0.21276	0.22962
08/07/2024 09:00	0.21282	0.22914
08/07/2024 10:00	0.21294	0.22896
08/07/2024 11:00	0.21354	0.22878
08/07/2024 12:00	0.21354	0.22848
08/07/2024 13:00	0.21354	0.22800
08/07/2024 14:00	0.21348	0.22782
08/07/2024 15:00	0.21300	0.22770
08/07/2024 16:00	0.21270	0.22752
08/07/2024 17:00	0.22512	0.24090
08/07/2024 18:00	0.22902	0.24552
08/07/2024 19:00	0.23520	0.25344
08/07/2024 20:00	0.22278	0.24036
08/07/2024 21:00	0.21618	0.23340
08/07/2024 22:00	0.21600	0.23340
08/07/2024 23:00	0.21348	0.23088
Average/Sum#:	0.21622	0.23280
Minimum:	0.21216	0.22752
Maximum:	0.23520	0.25344
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/08/2024 00:00	0.21330	0.23094
08/08/2024 01:00	0.21366	0.23112
08/08/2024 02:00	0.21366	0.23112
08/08/2024 03:00	0.21354	0.23136
08/08/2024 04:00	0.21276	0.23070
08/08/2024 05:00	0.21408	0.23214
08/08/2024 06:00	0.22416	0.24222
08/08/2024 07:00	0.21294	0.23016
08/08/2024 08:00	0.21282	0.22998
08/08/2024 09:00	0.21264	0.22968
08/08/2024 10:00	0.21300	0.22950
08/08/2024 11:00	0.21384	0.22956
08/08/2024 12:00	0.21360	0.22884
08/08/2024 13:00	0.21372	0.22854
08/08/2024 14:00	0.21366	0.22830
08/08/2024 15:00	0.21330	0.22830
08/08/2024 16:00	0.21306	0.22794
08/08/2024 17:00	0.21426	0.22944
08/08/2024 18:00	0.21570	0.23142
08/08/2024 19:00	0.21228	0.22884
08/08/2024 20:00	0.22260	0.24042
08/08/2024 21:00	0.22050	0.23826
08/08/2024 22:00	0.21228	0.22974
08/08/2024 23:00	0.21252	0.22998
Average/Sum#:	0.21450	0.23119
Minimum:	0.21228	0.22794
Maximum:	0.22416	0.24222
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/09/2024 00:00	0.21246	0.23022
08/09/2024 01:00	0.21252	0.23040
08/09/2024 02:00	0.21246	0.23034
08/09/2024 03:00	0.21252	0.23058
08/09/2024 04:00	0.21240	0.23064
08/09/2024 05:00	0.21378	0.23202
08/09/2024 06:00	0.23694	0.25572
08/09/2024 07:00	0.21384	0.23094
08/09/2024 08:00	0.21312	0.23046
08/09/2024 09:00	0.21264	0.22974
08/09/2024 10:00	0.21264	0.22926
08/09/2024 11:00	0.21330	0.22926
08/09/2024 12:00	0.21336	0.22884
08/09/2024 13:00	0.21354	0.22818
08/09/2024 14:00	0.21348	0.22800
08/09/2024 15:00	0.21288	0.22776
08/09/2024 16:00	0.21276	0.22770
08/09/2024 17:00	0.22344	0.23928
08/09/2024 18:00	0.21894	0.23490
08/09/2024 19:00	0.21342	0.23040
08/09/2024 20:00	0.21306	0.23028
08/09/2024 21:00	0.21234	0.22950
08/09/2024 22:00	0.21234	0.22980
08/09/2024 23:00	0.21222	0.22992
Average/Sum#:	0.21460	0.23142
Minimum:	0.21222	0.22770
Maximum:	0.23694	0.25572
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/10/2024 00:00	0.21264	0.23040
08/10/2024 01:00	0.21282	0.23058
08/10/2024 02:00	0.21276	0.23070
08/10/2024 03:00	0.21246	0.23046
08/10/2024 04:00	0.21216	0.23046
08/10/2024 05:00	0.21234	0.23058
08/10/2024 06:00	0.21318	0.23088
08/10/2024 07:00	0.21360	0.23088
08/10/2024 08:00	0.21288	0.23040
08/10/2024 09:00	0.21288	0.23016
08/10/2024 10:00	0.21324	0.23028
08/10/2024 11:00	0.21420	0.23028
08/10/2024 12:00	0.21414	0.22968
08/10/2024 13:00	0.22134	0.23664
08/10/2024 14:00	0.21396	0.22866
08/10/2024 15:00	0.21330	0.22854
08/10/2024 16:00	0.21300	0.22848
08/10/2024 17:00	0.22584	0.24216
08/10/2024 18:00	0.21396	0.22950
08/10/2024 19:00	0.21246	0.22902
08/10/2024 20:00	0.21234	0.22944
08/10/2024 21:00	0.21198	0.22932
08/10/2024 22:00	0.21210	0.22938
08/10/2024 23:00	0.21216	0.22974
Average/Sum#:	0.21382	0.23069
Minimum:	0.21198	0.22848
Maximum:	0.22584	0.24216
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/11/2024 00:00	0.21234	0.22998
08/11/2024 01:00	0.21240	0.23004
08/11/2024 02:00	0.21252	0.23040
08/11/2024 03:00	0.21252	0.23052
08/11/2024 04:00	0.21258	0.23058
08/11/2024 05:00	0.21264	0.23070
08/11/2024 06:00	0.21348	0.23076
08/11/2024 07:00	0.21372	0.23070
08/11/2024 08:00	0.21300	0.23028
08/11/2024 09:00	0.21276	0.23004
08/11/2024 10:00	0.21276	0.22950
08/11/2024 11:00	0.21348	0.22908
08/11/2024 12:00	0.23634	0.25362
08/11/2024 13:00	0.26238	0.28122
08/11/2024 14:00	0.26274	0.28170
08/11/2024 15:00	0.26088	0.28026
08/11/2024 16:00	0.25704	0.27600
08/11/2024 17:00	0.24528	0.26316
08/11/2024 18:00	0.26580	0.28440
08/11/2024 19:00	0.30438	0.32622
08/11/2024 20:00	0.33306	0.35496
08/11/2024 21:00	0.29790	0.30660
08/11/2024 22:00	0.28260	0.23142
08/11/2024 23:00	0.22752	0.23124
Average/Sum#:	0.24126	0.25556
Minimum:	0.21234	0.22908
Maximum:	0.33306	0.35496
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/12/2024 00:00	0.21342	0.23148
08/12/2024 01:00	0.21342	0.23166
08/12/2024 02:00	0.21342	0.23184
08/12/2024 03:00	0.21348	0.23196
08/12/2024 04:00	0.22314	0.24252
08/12/2024 05:00	0.23232	0.25206
08/12/2024 06:00	0.21414	0.23202
08/12/2024 07:00	0.21456	0.23196
08/12/2024 08:00	0.21396	0.23160
08/12/2024 09:00	0.21372	0.23130
08/12/2024 10:00	0.21348	0.23052
08/12/2024 11:00	0.21384	0.22992
08/12/2024 12:00	0.21384	0.22938
08/12/2024 13:00	0.21378	0.22908
08/12/2024 14:00	0.21312	0.22896
08/12/2024 15:00	0.21282	0.22908
08/12/2024 16:00	0.21270	0.22896
08/12/2024 17:00	0.24480	0.26154
08/12/2024 18:00	0.30492	0.32556
08/12/2024 19:00	0.28200	0.30222
08/12/2024 20:00	0.21930	0.23724
08/12/2024 21:00	0.21204	0.22968
08/12/2024 22:00	0.21228	0.22998
08/12/2024 23:00	0.21222	0.23016
Average/Sum#:	0.22278	0.24045
Minimum:	0.21204	0.22896
Maximum:	0.30492	0.32556
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/13/2024 00:00	0.21216	0.23010
08/13/2024 01:00	0.21210	0.23010
08/13/2024 02:00	0.21222	0.23034
08/13/2024 03:00	0.21216	0.23052
08/13/2024 04:00	0.21228	0.23046
08/13/2024 05:00	0.21372	0.23208
08/13/2024 06:00	0.21336	0.23082
08/13/2024 07:00	0.21360	0.23052
08/13/2024 08:00	0.21300	0.23028
08/13/2024 09:00	0.21294	0.23004
08/13/2024 10:00	0.21300	0.22980
08/13/2024 11:00	0.21336	0.22944
08/13/2024 12:00	0.21348	0.22914
08/13/2024 13:00	0.21372	0.22914
08/13/2024 14:00	0.21378	0.22896
08/13/2024 15:00	0.21330	0.22884
08/13/2024 16:00	0.21294	0.22878
08/13/2024 17:00	0.27504	0.29238
08/13/2024 18:00	0.32256	0.34200
08/13/2024 19:00	0.26322	0.28056
08/13/2024 20:00	0.21468	0.23190
08/13/2024 21:00	0.21546	0.23304
08/13/2024 22:00	0.21216	0.22962
08/13/2024 23:00	0.21222	0.22974
Average/Sum#:	0.22235	0.23953
Minimum:	0.21210	0.22878
Maximum:	0.32256	0.34200
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/14/2024 00:00	0.21222	0.22998
08/14/2024 01:00	0.21252	0.23034
08/14/2024 02:00	0.21264	0.23058
08/14/2024 03:00	0.21270	0.23070
08/14/2024 04:00	0.21288	0.23094
08/14/2024 05:00	0.21264	0.23064
08/14/2024 06:00	0.21330	0.23076
08/14/2024 07:00	0.21360	0.23064
08/14/2024 08:00	0.21288	0.23040
08/14/2024 09:00	0.21258	0.22992
08/14/2024 10:00	0.21282	0.22974
08/14/2024 11:00	0.21354	0.22938
08/14/2024 12:00	0.21360	0.22908
08/14/2024 13:00	0.21378	0.22860
08/14/2024 14:00	0.21342	0.22842
08/14/2024 15:00	0.21306	0.22818
08/14/2024 16:00	0.21486	0.23070
08/14/2024 17:00	0.30282	0.32754
08/14/2024 18:00	0.36480	0.38454
08/14/2024 19:00	0.36612	0.38664
08/14/2024 20:00	0.30204	0.32034
08/14/2024 21:00	0.24672	0.26664
08/14/2024 22:00	0.21498	0.23280
08/14/2024 23:00	0.24444	0.26448
Average/Sum#:	0.23604	0.25383
Minimum:	0.21222	0.22818
Maximum:	0.36612	0.38664
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/15/2024 00:00	0.21216	0.22986
08/15/2024 01:00	0.21234	0.23010
08/15/2024 02:00	0.21258	0.23046
08/15/2024 03:00	0.21264	0.23046
08/15/2024 04:00	0.22182	0.24054
08/15/2024 05:00	0.23496	0.25428
08/15/2024 06:00	0.21354	0.23082
08/15/2024 07:00	0.21366	0.23082
08/15/2024 08:00	0.21306	0.23022
08/15/2024 09:00	0.21270	0.22968
08/15/2024 10:00	0.21264	0.22944
08/15/2024 11:00	0.21360	0.22890
08/15/2024 12:00	0.21270	0.22824
08/15/2024 13:00	0.21252	0.22770
08/15/2024 14:00	0.21252	0.22734
08/15/2024 15:00	0.24264	0.25740
08/15/2024 16:00	0.30816	0.32802
08/15/2024 17:00	0.33762	0.35658
08/15/2024 18:00	0.35640	0.37554
08/15/2024 19:00	0.34140	0.36138
08/15/2024 20:00	0.26046	0.27798
08/15/2024 21:00	0.21252	0.22962
08/15/2024 22:00	0.21174	0.22926
08/15/2024 23:00	0.21456	0.23226
Average/Sum#:	0.23787	0.25529
Minimum:	0.21174	0.22734
Maximum:	0.35640	0.37554
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/16/2024 00:00	0.21186	0.22968
08/16/2024 01:00	0.21198	0.22974
08/16/2024 02:00	0.21204	0.23010
08/16/2024 03:00	0.21198	0.23022
08/16/2024 04:00	0.22986	0.24948
08/16/2024 05:00	0.23760	0.25740
08/16/2024 06:00	0.21324	0.23082
08/16/2024 07:00	0.21312	0.23070
08/16/2024 08:00	0.21228	0.23004
08/16/2024 09:00	0.21222	0.22932
08/16/2024 10:00	0.21216	0.22884
08/16/2024 11:00	0.21270	0.22842
08/16/2024 12:00	0.21264	0.22806
08/16/2024 13:00	0.21534	0.23034
08/16/2024 14:00	0.21288	0.22770
08/16/2024 15:00	0.21228	0.22758
08/16/2024 16:00	0.21156	0.22740
08/16/2024 17:00	0.21336	0.22890
08/16/2024 18:00	0.21216	0.22806
08/16/2024 19:00	0.21306	0.22974
08/16/2024 20:00	0.21174	0.22902
08/16/2024 21:00	0.25410	0.27480
08/16/2024 22:00	0.24798	0.26778
08/16/2024 23:00	0.24228	0.26232
Average/Sum#:	0.21877	0.23610
Minimum:	0.21156	0.22740
Maximum:	0.25410	0.27480
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/17/2024 00:00	0.23250	0.25152
08/17/2024 01:00	0.21162	0.22950
08/17/2024 02:00	0.21174	0.22968
08/17/2024 03:00	0.21192	0.22986
08/17/2024 04:00	0.21216	0.23028
08/17/2024 05:00	0.23256	0.25194
08/17/2024 06:00	0.21294	0.22998
08/17/2024 07:00	0.21288	0.22998
08/17/2024 08:00	0.21210	0.22980
08/17/2024 09:00	0.21192	0.22944
08/17/2024 10:00	0.21180	0.22890
08/17/2024 11:00	0.21258	0.22848
08/17/2024 12:00	0.21276	0.22836
08/17/2024 13:00	0.21294	0.22818
08/17/2024 14:00	0.21300	0.22848
08/17/2024 15:00	0.21282	0.22854
08/17/2024 16:00	0.21228	0.22848
08/17/2024 17:00	0.21510	0.23148
08/17/2024 18:00	0.21276	0.22914
08/17/2024 19:00	0.21198	0.22926
08/17/2024 20:00	0.21192	0.22932
08/17/2024 21:00	0.21186	0.22944
08/17/2024 22:00	0.21156	0.22962
08/17/2024 23:00	0.21180	0.22974
Average/Sum#:	0.21406	0.23123
Minimum:	0.21156	0.22818
Maximum:	0.23256	0.25194
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/18/2024 00:00	0.21192	0.23010
08/18/2024 01:00	0.21174	0.23022
08/18/2024 02:00	0.21174	0.23022
08/18/2024 03:00	0.21198	0.23034
08/18/2024 04:00	0.21222	0.23058
08/18/2024 05:00	0.21240	0.23070
08/18/2024 06:00	0.21312	0.23052
08/18/2024 07:00	0.21306	0.23046
08/18/2024 08:00	0.21258	0.23034
08/18/2024 09:00	0.21246	0.22986
08/18/2024 10:00	0.21246	0.22944
08/18/2024 11:00	0.21258	0.22902
08/18/2024 12:00	0.21276	0.22878
08/18/2024 13:00	0.21306	0.22872
08/18/2024 14:00	0.21294	0.22854
08/18/2024 15:00	0.21258	0.22842
08/18/2024 16:00	0.21642	0.23322
08/18/2024 17:00	0.21660	0.23292
08/18/2024 18:00	0.21252	0.22872
08/18/2024 19:00	0.21210	0.22914
08/18/2024 20:00	0.21204	0.22974
08/18/2024 21:00	0.21312	0.23118
08/18/2024 22:00	0.21192	0.22968
08/18/2024 23:00	0.21444	0.23262
Average/Sum#:	0.21287	0.23015
Minimum:	0.21174	0.22842
Maximum:	0.21660	0.23322
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/19/2024 00:00	0.21198	0.23028
08/19/2024 01:00	0.21198	0.23022
08/19/2024 02:00	0.21192	0.23034
08/19/2024 03:00	0.21210	0.23040
08/19/2024 04:00	0.23778	0.25782
08/19/2024 05:00	0.24234	0.26262
08/19/2024 06:00	0.21306	0.23076
08/19/2024 07:00	0.21330	0.23070
08/19/2024 08:00	0.21288	0.23046
08/19/2024 09:00	0.21282	0.23028
08/19/2024 10:00	0.21258	0.22962
08/19/2024 11:00	0.21294	0.22902
08/19/2024 12:00	0.21306	0.22890
08/19/2024 13:00	0.21318	0.22842
08/19/2024 14:00	0.21312	0.22830
08/19/2024 15:00	0.21258	0.22824
08/19/2024 16:00	0.21198	0.22818
08/19/2024 17:00	0.21234	0.22824
08/19/2024 18:00	0.21246	0.22866
08/19/2024 19:00	0.21204	0.22890
08/19/2024 20:00	0.21186	0.22920
08/19/2024 21:00	0.23424	0.25368
08/19/2024 22:00	0.21180	0.22956
08/19/2024 23:00	0.21180	0.22962
Average/Sum#:	0.21567	0.23302
Minimum:	0.21180	0.22818
Maximum:	0.24234	0.26262
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/20/2024 00:00	0.21174	0.22980
08/20/2024 01:00	0.21186	0.22992
08/20/2024 02:00	0.21180	0.22986
08/20/2024 03:00	0.21186	0.23010
08/20/2024 04:00	0.21198	0.23028
08/20/2024 05:00	0.21234	0.23040
08/20/2024 06:00	0.21306	0.23034
08/20/2024 07:00	0.21318	0.23022
08/20/2024 08:00	0.21294	0.23010
08/20/2024 09:00	0.21324	0.23016
08/20/2024 10:00	0.21288	0.22986
08/20/2024 11:00	0.21342	0.22962
08/20/2024 12:00	0.21366	0.22944
08/20/2024 13:00	0.21360	0.22920
08/20/2024 14:00	0.21366	0.22896
08/20/2024 15:00	0.21318	0.22914
08/20/2024 16:00	0.21276	0.22890
08/20/2024 17:00	0.22428	0.24054
08/20/2024 18:00	0.21324	0.22932
08/20/2024 19:00	0.21270	0.22962
08/20/2024 20:00	0.21210	0.22938
08/20/2024 21:00	0.21006	0.22752
08/20/2024 22:00	0.21066	0.22818
08/20/2024 23:00	0.21060	0.22812
Average/Sum#:	0.21295	0.22996
Minimum:	0.21006	0.22752
Maximum:	0.22428	0.24054
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/21/2024 00:00	0.21042	0.22806
08/21/2024 01:00	0.21054	0.22830
08/21/2024 02:00	0.21060	0.22848
08/21/2024 03:00	0.21084	0.22878
08/21/2024 04:00	0.21096	0.22896
08/21/2024 05:00	0.21162	0.22974
08/21/2024 06:00	0.21204	0.22938
08/21/2024 07:00	0.21258	0.22980
08/21/2024 08:00	0.21222	0.22974
08/21/2024 09:00	0.21198	0.22944
08/21/2024 10:00	0.21192	0.22884
08/21/2024 11:00	0.21246	0.22842
08/21/2024 12:00	0.21258	0.22830
08/21/2024 13:00	0.21264	0.22812
08/21/2024 14:00	0.21234	0.22776
08/21/2024 15:00	0.21198	0.22782
08/21/2024 16:00	0.21684	0.23358
08/21/2024 17:00	0.21732	0.23352
08/21/2024 18:00	0.21240	0.22860
08/21/2024 19:00	0.21102	0.22830
08/21/2024 20:00	0.20988	0.22734
08/21/2024 21:00	0.21090	0.22860
08/21/2024 22:00	0.20934	0.22704
08/21/2024 23:00	0.20922	0.22698
Average/Sum#:	0.21186	0.22891
Minimum:	0.20922	0.22698
Maximum:	0.21732	0.23358
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/22/2024 00:00	0.20958	0.22746
08/22/2024 01:00	0.21012	0.22806
08/22/2024 02:00	0.21048	0.22860
08/22/2024 03:00	0.21072	0.22902
08/22/2024 04:00	0.21108	0.22926
08/22/2024 05:00	0.21846	0.23736
08/22/2024 06:00	0.21246	0.23040
08/22/2024 07:00	0.21270	0.23046
08/22/2024 08:00	0.21210	0.23010
08/22/2024 09:00	0.21186	0.22968
08/22/2024 10:00	0.21198	0.22944
08/22/2024 11:00	0.21270	0.22920
08/22/2024 12:00	0.21282	0.22884
08/22/2024 13:00	0.21294	0.22872
08/22/2024 14:00	0.21264	0.22872
08/22/2024 15:00	0.21240	0.22872
08/22/2024 16:00	0.21204	0.22884
08/22/2024 17:00	0.21222	0.22896
08/22/2024 18:00	0.21210	0.22932
08/22/2024 19:00	0.21174	0.22968
08/22/2024 20:00	0.21204	0.22998
08/22/2024 21:00	0.21204	0.23010
08/22/2024 22:00	0.21228	0.23028
08/22/2024 23:00	0.21234	0.23040
Average/Sum#:	0.21216	0.22965
Minimum:	0.20958	0.22746
Maximum:	0.21846	0.23736
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/23/2024 00:00	0.21234	0.23040
08/23/2024 01:00	0.21252	0.23052
08/23/2024 02:00	0.21246	0.23058
08/23/2024 03:00	0.21246	0.23082
08/23/2024 04:00	0.21258	0.23112
08/23/2024 05:00	0.21276	0.23136
08/23/2024 06:00	0.21318	0.23136
08/23/2024 07:00	0.21324	0.23100
08/23/2024 08:00	0.21276	0.23076
08/23/2024 09:00	0.21264	0.23046
08/23/2024 10:00	0.21282	0.23022
08/23/2024 11:00	0.21330	0.22998
08/23/2024 12:00	0.21318	0.22992
08/23/2024 13:00	0.21294	0.22992
08/23/2024 14:00	0.21282	0.22998
08/23/2024 15:00	0.21294	0.22980
08/23/2024 16:00	0.21282	0.22980
08/23/2024 17:00	0.21264	0.22962
08/23/2024 18:00	0.21264	0.22962
08/23/2024 19:00	0.21270	0.22986
08/23/2024 20:00	0.21264	0.22986
08/23/2024 21:00	0.21258	0.22986
08/23/2024 22:00	0.21252	0.23010
08/23/2024 23:00	0.22722	0.24636
Average/Sum#:	0.21336	0.23097
Minimum:	0.21234	0.22962
Maximum:	0.22722	0.24636
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/24/2024 00:00	0.21234	0.23040
08/24/2024 01:00	0.21282	0.23070
08/24/2024 02:00	0.21282	0.23064
08/24/2024 03:00	0.21282	0.23076
08/24/2024 04:00	0.21462	0.23322
08/24/2024 05:00	0.22518	0.24480
08/24/2024 06:00	0.21828	0.23712
08/24/2024 07:00	0.21270	0.23142
08/24/2024 08:00	0.21282	0.23130
08/24/2024 09:00	0.21348	0.23106
08/24/2024 10:00	0.21342	0.23082
08/24/2024 11:00	0.21354	0.23058
08/24/2024 12:00	0.21348	0.23034
08/24/2024 13:00	0.21306	0.23034
08/24/2024 14:00	0.21252	0.23106
08/24/2024 15:00	0.21348	0.23076
08/24/2024 16:00	0.21306	0.23022
08/24/2024 17:00	0.21288	0.23022
08/24/2024 18:00	0.21276	0.23028
08/24/2024 19:00	0.21246	0.23040
08/24/2024 20:00	0.21258	0.23070
08/24/2024 21:00	0.21330	0.23124
08/24/2024 22:00	0.21330	0.23178
08/24/2024 23:00	0.21336	0.23178
Average/Sum#:	0.21380	0.23175
Minimum:	0.21234	0.23022
Maximum:	0.22518	0.24480
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/25/2024 00:00	0.21342	0.23202
08/25/2024 01:00	0.21342	0.23220
08/25/2024 02:00	0.21360	0.23250
08/25/2024 03:00	0.21402	0.23274
08/25/2024 04:00	0.21468	0.23310
08/25/2024 05:00	0.21456	0.23322
08/25/2024 06:00	0.21492	0.23310
08/25/2024 07:00	0.21468	0.23304
08/25/2024 08:00	0.21438	0.23256
08/25/2024 09:00	0.21456	0.23256
08/25/2024 10:00	0.21474	0.23244
08/25/2024 11:00	0.21498	0.23130
08/25/2024 12:00	0.21462	0.23052
08/25/2024 13:00	0.21378	0.23052
08/25/2024 14:00	0.21360	0.23010
08/25/2024 15:00	0.21378	0.23022
08/25/2024 16:00	0.21594	0.23262
08/25/2024 17:00	0.23820	0.25692
08/25/2024 18:00	0.25602	0.27672
08/25/2024 19:00	0.25560	0.27636
08/25/2024 20:00	0.24336	0.26292
08/25/2024 21:00	0.21342	0.23100
08/25/2024 22:00	0.21360	0.23142
08/25/2024 23:00	0.21714	0.23538
Average/Sum#:	0.22004	0.23815
Minimum:	0.21342	0.23010
Maximum:	0.25602	0.27672
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/26/2024 00:00	0.21378	0.23166
08/26/2024 01:00	0.21378	0.23178
08/26/2024 02:00	0.21378	0.23178
08/26/2024 03:00	0.21390	0.23190
08/26/2024 04:00	0.23340	0.25320
08/26/2024 05:00	0.25380	0.27504
08/26/2024 06:00	0.21906	0.23694
08/26/2024 07:00	0.21546	0.23328
08/26/2024 08:00	0.21564	0.23304
08/26/2024 09:00	0.21492	0.23208
08/26/2024 10:00	0.21354	0.23040
08/26/2024 11:00	0.21384	0.22998
08/26/2024 12:00	0.21390	0.22962
08/26/2024 13:00	0.21300	0.22944
08/26/2024 14:00	0.21300	0.22908
08/26/2024 15:00	0.21282	0.22896
08/26/2024 16:00	0.22476	0.24066
08/26/2024 17:00	0.23772	0.25566
08/26/2024 18:00	0.24378	0.26220
08/26/2024 19:00	0.22224	0.24030
08/26/2024 20:00	0.21882	0.23640
08/26/2024 21:00	0.21246	0.22998
08/26/2024 22:00	0.21240	0.22998
08/26/2024 23:00	0.21228	0.23028
Average/Sum#:	0.21967	0.23724
Minimum:	0.21228	0.22896
Maximum:	0.25380	0.27504
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/27/2024 00:00	0.21276	0.23040
08/27/2024 01:00	0.21288	0.23058
08/27/2024 02:00	0.21258	0.23058
08/27/2024 03:00	0.21240	0.23064
08/27/2024 04:00	0.21252	0.23070
08/27/2024 05:00	0.21282	0.23088
08/27/2024 06:00	0.21360	0.23124
08/27/2024 07:00	0.21360	0.23094
08/27/2024 08:00	0.21312	0.23058
08/27/2024 09:00	0.21306	0.23034
08/27/2024 10:00	0.21312	0.23004
08/27/2024 11:00	0.21396	0.22956
08/27/2024 12:00	0.21396	0.22938
08/27/2024 13:00	0.21306	0.22908
08/27/2024 14:00	0.21288	0.22884
08/27/2024 15:00	0.21288	0.22884
08/27/2024 16:00	0.21462	0.23040
08/27/2024 17:00	0.23022	0.24630
08/27/2024 18:00	0.24612	0.26448
08/27/2024 19:00	0.21246	0.22944
08/27/2024 20:00	0.21252	0.22986
08/27/2024 21:00	0.21264	0.22986
08/27/2024 22:00	0.21246	0.23022
08/27/2024 23:00	0.21300	0.23064
Average/Sum#:	0.21514	0.23224
Minimum:	0.21240	0.22884
Maximum:	0.24612	0.26448
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/28/2024 00:00	0.21300	0.23088
08/28/2024 01:00	0.21294	0.23094
08/28/2024 02:00	0.21312	0.23100
08/28/2024 03:00	0.21318	0.23106
08/28/2024 04:00	0.21624	0.23418
08/28/2024 05:00	0.23982	0.25986
08/28/2024 06:00	0.22044	0.23868
08/28/2024 07:00	0.21408	0.23148
08/28/2024 08:00	0.21396	0.23142
08/28/2024 09:00	0.21408	0.23112
08/28/2024 10:00	0.21426	0.23118
08/28/2024 11:00	0.21372	0.22950
08/28/2024 12:00	0.21360	0.22908
08/28/2024 13:00	0.21282	0.22896
08/28/2024 14:00	0.21264	0.22860
08/28/2024 15:00	0.21270	0.22860
08/28/2024 16:00	0.21432	0.23010
08/28/2024 17:00	0.21462	0.23004
08/28/2024 18:00	0.21366	0.22962
08/28/2024 19:00	0.21258	0.22890
08/28/2024 20:00	0.21294	0.22968
08/28/2024 21:00	0.21276	0.23040
08/28/2024 22:00	0.21330	0.23106
08/28/2024 23:00	0.21348	0.23124
Average/Sum#:	0.21493	0.23198
Minimum:	0.21258	0.22860
Maximum:	0.23982	0.25986
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/29/2024 00:00	0.21318	0.23124
08/29/2024 01:00	0.21306	0.23106
08/29/2024 02:00	0.21540	0.23322
08/29/2024 03:00	0.21252	0.23070
08/29/2024 04:00	0.21264	0.23070
08/29/2024 05:00	0.21270	0.23100
08/29/2024 06:00	0.27114	0.29346
08/29/2024 07:00	0.27600	0.29832
08/29/2024 08:00	0.27504	0.29700
08/29/2024 09:00	0.23424	0.25290
08/29/2024 10:00	0.21534	0.23256
08/29/2024 11:00	0.21330	0.22932
08/29/2024 12:00	0.21330	0.22914
08/29/2024 13:00	0.21270	0.22902
08/29/2024 14:00	0.21270	0.22878
08/29/2024 15:00	0.21252	0.22854
08/29/2024 16:00	0.21240	0.22830
08/29/2024 17:00	0.21282	0.22854
08/29/2024 18:00	0.21294	0.22908
08/29/2024 19:00	0.21288	0.22962
08/29/2024 20:00	0.21264	0.23004
08/29/2024 21:00	0.21264	0.23040
08/29/2024 22:00	0.21282	0.23070
08/29/2024 23:00	0.21294	0.23088
Average/Sum#:	0.22158	0.23936
Minimum:	0.21240	0.22830
Maximum:	0.27600	0.29832
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/30/2024 00:00	0.21300	0.23100
08/30/2024 01:00	0.21288	0.23118
08/30/2024 02:00	0.21294	0.23130
08/30/2024 03:00	0.21288	0.23142
08/30/2024 04:00	0.21342	0.23196
08/30/2024 05:00	0.21324	0.23148
08/30/2024 06:00	0.21372	0.23154
08/30/2024 07:00	0.21390	0.23142
08/30/2024 08:00	0.21354	0.23106
08/30/2024 09:00	0.21348	0.23070
08/30/2024 10:00	0.21348	0.23040
08/30/2024 11:00	0.21354	0.22986
08/30/2024 12:00	0.21354	0.22944
08/30/2024 13:00	0.21288	0.22932
08/30/2024 14:00	0.21294	0.22908
08/30/2024 15:00	0.21288	0.22896
08/30/2024 16:00	0.21690	0.23274
08/30/2024 17:00	0.21342	0.22920
08/30/2024 18:00	0.21336	0.22950
08/30/2024 19:00	0.21330	0.23004
08/30/2024 20:00	0.21294	0.23034
08/30/2024 21:00	0.21420	0.23202
08/30/2024 22:00	0.21282	0.23076
08/30/2024 23:00	0.21318	0.23118
Average/Sum#:	0.21343	0.23066
Minimum:	0.21282	0.22896
Maximum:	0.21690	0.23274
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/31/2024 00:00	0.21354	0.23160
08/31/2024 01:00	0.21312	0.23112
08/31/2024 02:00	0.21318	0.23130
08/31/2024 03:00	0.21318	0.23124
08/31/2024 04:00	0.21300	0.23142
08/31/2024 05:00	0.21300	0.23136
08/31/2024 06:00	0.21348	0.23136
08/31/2024 07:00	0.21360	0.23130
08/31/2024 08:00	0.21330	0.23094
08/31/2024 09:00	0.21312	0.23064
08/31/2024 10:00	0.21318	0.23028
08/31/2024 11:00	0.21378	0.23010
08/31/2024 12:00	0.21384	0.23004
08/31/2024 13:00	0.21384	0.23034
08/31/2024 14:00	0.21408	0.23022
08/31/2024 15:00	0.21912	0.23544
08/31/2024 16:00	0.25122	0.26772
08/31/2024 17:00	0.35478	0.37458
08/31/2024 18:00	0.35190	0.37158
08/31/2024 19:00	0.35718	0.37782
08/31/2024 20:00	0.30426	0.31986
08/31/2024 21:00	0.25536	0.27612
08/31/2024 22:00	0.25650	0.27714
08/31/2024 23:00	0.24642	0.27396
Average/Sum#:	0.24158	0.25990
Minimum:	0.21300	0.23004
Maximum:	0.35718	0.37782
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/01/2024 00:00	0.21660	0.23358
09/01/2024 01:00	0.21450	0.23130
09/01/2024 02:00	0.21450	0.23136
09/01/2024 03:00	0.21456	0.23166
09/01/2024 04:00	0.21450	0.23166
09/01/2024 05:00	0.21474	0.23190
09/01/2024 06:00	0.21540	0.23178
09/01/2024 07:00	0.21534	0.23160
09/01/2024 08:00	0.21486	0.23136
09/01/2024 09:00	0.21462	0.23070
09/01/2024 10:00	0.21432	0.23034
09/01/2024 11:00	0.21474	0.22980
09/01/2024 12:00	0.21468	0.22944
09/01/2024 13:00	0.21396	0.22914
09/01/2024 14:00	0.21390	0.22896
09/01/2024 15:00	0.21450	0.22944
09/01/2024 16:00	0.22398	0.23742
09/01/2024 17:00	0.23430	0.24582
09/01/2024 18:00	0.21588	0.22986
09/01/2024 19:00	0.21474	0.22956
09/01/2024 20:00	0.21480	0.23010
09/01/2024 21:00	0.21888	0.23448
09/01/2024 22:00	0.21696	0.23268
09/01/2024 23:00	0.21846	0.23460
Average/Sum#:	0.21641	0.23202
Minimum:	0.21390	0.22896
Maximum:	0.23430	0.24582
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/02/2024 00:00	0.22086	0.23730
09/02/2024 01:00	0.21498	0.23094
09/02/2024 02:00	0.21498	0.23124
09/02/2024 03:00	0.21498	0.23136
09/02/2024 04:00	0.21498	0.23142
09/02/2024 05:00	0.21504	0.23172
09/02/2024 06:00	0.21540	0.23172
09/02/2024 07:00	0.21528	0.23136
09/02/2024 08:00	0.21516	0.23154
09/02/2024 09:00	0.21522	0.23112
09/02/2024 10:00	0.21540	0.23052
09/02/2024 11:00	0.21618	0.22986
09/02/2024 12:00	0.21636	0.22974
09/02/2024 13:00	0.21582	0.22950
09/02/2024 14:00	0.22446	0.23898
09/02/2024 15:00	0.21876	0.23448
09/02/2024 16:00	0.23532	0.25152
09/02/2024 17:00	0.23952	0.25638
09/02/2024 18:00	0.24156	0.25866
09/02/2024 19:00	0.22404	0.24072
09/02/2024 20:00	0.22152	0.23826
09/02/2024 21:00	0.21378	0.23052
09/02/2024 22:00	0.21396	0.23070
09/02/2024 23:00	0.21402	0.23088
Average/Sum#:	0.21948	0.23544
Minimum:	0.21378	0.22950
Maximum:	0.24156	0.25866
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/03/2024 00:00	0.21402	0.23106
09/03/2024 01:00	0.21408	0.23094
09/03/2024 02:00	0.21450	0.23142
09/03/2024 03:00	0.21432	0.23136
09/03/2024 04:00	0.21384	0.23118
09/03/2024 05:00	0.22944	0.24816
09/03/2024 06:00	0.22050	0.23778
09/03/2024 07:00	0.22530	0.24240
09/03/2024 08:00	0.21414	0.23058
09/03/2024 09:00	0.21354	0.22980
09/03/2024 10:00	0.21348	0.22944
09/03/2024 11:00	0.21444	0.22914
09/03/2024 12:00	0.21426	0.22860
09/03/2024 13:00	0.23664	0.25338
09/03/2024 14:00	0.24612	0.26484
09/03/2024 15:00	0.23994	0.25824
09/03/2024 16:00	0.27294	0.29124
09/03/2024 17:00	0.35808	0.37812
09/03/2024 18:00	0.36234	0.38124
09/03/2024 19:00	0.31326	0.32100
09/03/2024 20:00	0.26382	0.28494
09/03/2024 21:00	0.26436	0.28506
09/03/2024 22:00	0.23664	0.25548
09/03/2024 23:00	0.25980	0.27984
Average/Sum#:	0.24458	0.26189
Minimum:	0.21348	0.22860
Maximum:	0.36234	0.38124
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/04/2024 00:00	0.23514	0.25416
09/04/2024 01:00	0.23466	0.25434
09/04/2024 02:00	0.21474	0.23292
09/04/2024 03:00	0.24564	0.26592
09/04/2024 04:00	0.24762	0.26832
09/04/2024 05:00	0.26106	0.28278
09/04/2024 06:00	0.22344	0.24198
09/04/2024 07:00	0.21432	0.23196
09/04/2024 08:00	0.21390	0.23136
09/04/2024 09:00	0.21372	0.23076
09/04/2024 10:00	0.21360	0.23016
09/04/2024 11:00	0.21408	0.22986
09/04/2024 12:00	0.21402	0.22962
09/04/2024 13:00	0.23292	0.25020
09/04/2024 14:00	0.24288	0.26100
09/04/2024 15:00	0.21618	0.23220
09/04/2024 16:00	0.27078	0.28848
09/04/2024 17:00	0.37266	0.39204
09/04/2024 18:00	0.36546	0.38490
09/04/2024 19:00	0.35826	0.37848
09/04/2024 20:00	0.35766	0.37836
09/04/2024 21:00	0.35478	0.37626
09/04/2024 22:00	0.34638	0.36936
09/04/2024 23:00	0.30228	0.32280
Average/Sum#:	0.26526	0.28409
Minimum:	0.21360	0.22962
Maximum:	0.37266	0.39204
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/05/2024 00:00	0.23568	0.25476
09/05/2024 01:00	0.21948	0.23766
09/05/2024 02:00	0.21396	0.23184
09/05/2024 03:00	0.21390	0.23184
09/05/2024 04:00	0.23064	0.25008
09/05/2024 05:00	0.25620	0.27762
09/05/2024 06:00	0.22980	0.24852
09/05/2024 07:00	0.21432	0.23178
09/05/2024 08:00	0.21402	0.23148
09/05/2024 09:00	0.22038	0.23784
09/05/2024 10:00	0.24534	0.26418
09/05/2024 11:00	0.22770	0.24474
09/05/2024 12:00	0.25938	0.27834
09/05/2024 13:00	0.27924	0.29820
09/05/2024 14:00	0.37152	0.39096
09/05/2024 15:00	0.35286	0.37236
09/05/2024 16:00	0.35784	0.37746
09/05/2024 17:00	0.36822	0.38754
09/05/2024 18:00	0.36354	0.38400
09/05/2024 19:00	0.35754	0.37800
09/05/2024 20:00	0.35298	0.37410
09/05/2024 21:00	0.34782	0.36930
09/05/2024 22:00	0.33852	0.36126
09/05/2024 23:00	0.32478	0.34830
Average/Sum#:	0.28315	0.30259
Minimum:	0.21390	0.23148
Maximum:	0.37152	0.39096
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/06/2024 00:00	0.23496	0.25386
09/06/2024 01:00	0.21348	0.23130
09/06/2024 02:00	0.21354	0.23124
09/06/2024 03:00	0.21354	0.23154
09/06/2024 04:00	0.22866	0.24780
09/06/2024 05:00	0.25506	0.27612
09/06/2024 06:00	0.24138	0.26088
09/06/2024 07:00	0.23556	0.25482
09/06/2024 08:00	0.21336	0.23112
09/06/2024 09:00	0.21348	0.23058
09/06/2024 10:00	0.21372	0.23028
09/06/2024 11:00	0.22224	0.23784
09/06/2024 12:00	0.25044	0.26850
09/06/2024 13:00	0.28326	0.30138
09/06/2024 14:00	0.36342	0.38274
09/06/2024 15:00	0.37002	0.38880
09/06/2024 16:00	0.35154	0.37080
09/06/2024 17:00	0.36954	0.38868
09/06/2024 18:00	0.37470	0.39450
09/06/2024 19:00	0.35532	0.37572
09/06/2024 20:00	0.35418	0.37500
09/06/2024 21:00	0.36030	0.38226
09/06/2024 22:00	0.35424	0.37734
09/06/2024 23:00	0.35862	0.38244
Average/Sum#:	0.28519	0.30440
Minimum:	0.21336	0.23028
Maximum:	0.37470	0.39450
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
09/07/2024 00:00	0.35130	0.37506
09/07/2024 01:00	0.29934	0.31860
09/07/2024 02:00	0.21534	0.23292
09/07/2024 03:00	0.21678	0.23472
09/07/2024 04:00	0.21408	0.23202
09/07/2024 05:00	0.21324	0.23106
09/07/2024 06:00	0.21354	0.23100
09/07/2024 07:00	0.21372	0.23112
09/07/2024 08:00	0.21360	0.23070
09/07/2024 09:00	0.21360	0.23034
09/07/2024 10:00	0.21366	0.22998
09/07/2024 11:00	0.21408	0.22980
09/07/2024 12:00	0.24534	0.26064
09/07/2024 13:00	0.26364	0.28440
09/07/2024 14:00	0.32742	0.34758
09/07/2024 15:00	0.32616	0.34602
09/07/2024 16:00	0.31596	0.33618
09/07/2024 17:00	0.35388	0.37416
09/07/2024 18:00	0.35664	0.37782
09/07/2024 19:00	0.34920	0.37224
09/07/2024 20:00	0.35412	0.37722
09/07/2024 21:00	0.35316	0.37698
09/07/2024 22:00	0.35598	0.37860
09/07/2024 23:00	0.33624	0.35988
Average/Sum#:	0.28042	0.29996
Minimum:	0.21324	0.22980
Maximum:	0.35664	0.37860
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/08/2024 00:00	0.24306	0.25980
09/08/2024 01:00	0.21456	0.23274
09/08/2024 02:00	0.21486	0.23304
09/08/2024 03:00	0.21504	0.23322
09/08/2024 04:00	0.21510	0.23334
09/08/2024 05:00	0.21504	0.23346
09/08/2024 06:00	0.21510	0.23316
09/08/2024 07:00	0.21462	0.23232
09/08/2024 08:00	0.21438	0.23184
09/08/2024 09:00	0.21384	0.23112
09/08/2024 10:00	0.21384	0.23058
09/08/2024 11:00	0.21432	0.23028
09/08/2024 12:00	0.21954	0.23580
09/08/2024 13:00	0.25542	0.27336
09/08/2024 14:00	0.33648	0.35712
09/08/2024 15:00	0.34920	0.36936
09/08/2024 16:00	0.36804	0.38760
09/08/2024 17:00	0.37404	0.39342
09/08/2024 18:00	0.36690	0.38664
09/08/2024 19:00	0.36276	0.38232
09/08/2024 20:00	0.36018	0.38016
09/08/2024 21:00	0.29910	0.31860
09/08/2024 22:00	0.24528	0.26454
09/08/2024 23:00	0.22806	0.24594
Average/Sum#:	0.26537	0.28374
Minimum:	0.21384	0.23028
Maximum:	0.37404	0.39342
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/09/2024 00:00	0.21504	0.23280
09/09/2024 01:00	0.21462	0.23238
09/09/2024 02:00	0.21462	0.23292
09/09/2024 03:00	0.21444	0.23268
09/09/2024 04:00	0.22818	0.24708
09/09/2024 05:00	0.25170	0.27252
09/09/2024 06:00	0.22140	0.23916
09/09/2024 07:00	0.21606	0.23388
09/09/2024 08:00	0.21552	0.23328
09/09/2024 09:00	0.21426	0.23148
09/09/2024 10:00	0.21468	0.23160
09/09/2024 11:00	0.21468	0.23058
09/09/2024 12:00	0.22470	0.24060
09/09/2024 13:00	0.22362	0.24066
09/09/2024 14:00	0.21372	0.22980
09/09/2024 15:00	0.22680	0.24414
09/09/2024 16:00	0.24444	0.26232
09/09/2024 17:00	0.26982	0.28854
09/09/2024 18:00	0.33978	0.36054
09/09/2024 19:00	0.26868	0.28590
09/09/2024 20:00	0.22386	0.24186
09/09/2024 21:00	0.21954	0.23718
09/09/2024 22:00	0.21414	0.23196
09/09/2024 23:00	0.24078	0.26046
Average/Sum#:	0.23105	0.24893
Minimum:	0.21372	0.22980
Maximum:	0.33978	0.36054
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/10/2024 00:00	0.22266	0.24108
09/10/2024 01:00	0.21414	0.23226
09/10/2024 02:00	0.21420	0.23244
09/10/2024 03:00	0.21420	0.23250
09/10/2024 04:00	0.21426	0.23268
09/10/2024 05:00	0.23586	0.25614
09/10/2024 06:00	0.21918	0.23748
09/10/2024 07:00	0.21480	0.23298
09/10/2024 08:00	0.21450	0.23280
09/10/2024 09:00	0.21432	0.23256
09/10/2024 10:00	0.21426	0.23172
09/10/2024 11:00	0.21432	0.23100
09/10/2024 12:00	0.21420	0.23070
09/10/2024 13:00	0.21384	0.23082
09/10/2024 14:00	0.21426	0.23094
09/10/2024 15:00	0.21408	0.23076
09/10/2024 16:00	0.21372	0.23028
09/10/2024 17:00	0.21342	0.23022
09/10/2024 18:00	0.21342	0.23088
09/10/2024 19:00	0.21348	0.23154
09/10/2024 20:00	0.21348	0.23166
09/10/2024 21:00	0.21348	0.23172
09/10/2024 22:00	0.21336	0.23166
09/10/2024 23:00	0.21366	0.23184
Average/Sum#:	0.21546	0.23328
Minimum:	0.21336	0.23022
Maximum:	0.23586	0.25614
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
09/11/2024 00:00	0.21372	0.23190
09/11/2024 01:00	0.21360	0.23196
09/11/2024 02:00	0.21348	0.23184
09/11/2024 03:00	0.21348	0.23178
09/11/2024 04:00	0.21348	0.23190
09/11/2024 05:00	0.23142	0.25134
09/11/2024 06:00	0.22170	0.24048
09/11/2024 07:00	0.21360	0.23184
09/11/2024 08:00	0.21372	0.23196
09/11/2024 09:00	0.21372	0.23178
09/11/2024 10:00	0.21414	0.23172
09/11/2024 11:00	0.21468	0.23142
09/11/2024 12:00	0.21438	0.23106
09/11/2024 13:00	0.21342	0.23046
09/11/2024 14:00	0.21312	0.22992
09/11/2024 15:00	0.21312	0.22986
09/11/2024 16:00	0.21318	0.23004
09/11/2024 17:00	0.21288	0.23004
09/11/2024 18:00	0.21294	0.23052
09/11/2024 19:00	0.21318	0.23076
09/11/2024 20:00	0.21330	0.23100
09/11/2024 21:00	0.21342	0.23112
09/11/2024 22:00	0.21324	0.23136
09/11/2024 23:00	0.21330	0.23154
Average/Sum#:	0.21459	0.23240
Minimum:	0.21288	0.22986
Maximum:	0.23142	0.25134
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/12/2024 00:00	0.21342	0.23178
09/12/2024 01:00	0.21330	0.23178
09/12/2024 02:00	0.21354	0.23196
09/12/2024 03:00	0.21378	0.23202
09/12/2024 04:00	0.21366	0.23214
09/12/2024 05:00	0.21366	0.23226
09/12/2024 06:00	0.21426	0.23244
09/12/2024 07:00	0.21420	0.23238
09/12/2024 08:00	0.21438	0.23244
09/12/2024 09:00	0.21426	0.23244
09/12/2024 10:00	0.21450	0.23220
09/12/2024 11:00	0.21396	0.23058
09/12/2024 12:00	0.21408	0.23058
09/12/2024 13:00	0.21330	0.23046
09/12/2024 14:00	0.21336	0.23034
09/12/2024 15:00	0.21336	0.23028
09/12/2024 16:00	0.21330	0.23022
09/12/2024 17:00	0.21306	0.23016
09/12/2024 18:00	0.21312	0.23028
09/12/2024 19:00	0.21330	0.23052
09/12/2024 20:00	0.21312	0.23088
09/12/2024 21:00	0.21336	0.23142
09/12/2024 22:00	0.21330	0.23190
09/12/2024 23:00	0.21432	0.23286
Average/Sum#:	0.21366	0.23143
Minimum:	0.21306	0.23016
Maximum:	0.21450	0.23286
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/13/2024 00:00	0.21348	0.23178
09/13/2024 01:00	0.21354	0.23160
09/13/2024 02:00	0.21336	0.23166
09/13/2024 03:00	0.21324	0.23160
09/13/2024 04:00	0.21684	0.23562
09/13/2024 05:00	0.24726	0.26844
09/13/2024 06:00	0.23298	0.25278
09/13/2024 07:00	0.21426	0.23214
09/13/2024 08:00	0.21396	0.23202
09/13/2024 09:00	0.21336	0.23118
09/13/2024 10:00	0.21348	0.23064
09/13/2024 11:00	0.21546	0.23178
09/13/2024 12:00	0.22248	0.23946
09/13/2024 13:00	0.24264	0.26142
09/13/2024 14:00	0.24594	0.26526
09/13/2024 15:00	0.24348	0.26286
09/13/2024 16:00	0.26598	0.28572
09/13/2024 17:00	0.37860	0.39894
09/13/2024 18:00	0.36762	0.38826
09/13/2024 19:00	0.24750	0.26472
09/13/2024 20:00	0.21612	0.23406
09/13/2024 21:00	0.21354	0.23154
09/13/2024 22:00	0.21780	0.23604
09/13/2024 23:00	0.23298	0.25236
Average/Sum#:	0.23816	0.25675
Minimum:	0.21324	0.23064
Maximum:	0.37860	0.39894
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/14/2024 00:00	0.23478	0.25440
09/14/2024 01:00	0.21612	0.23418
09/14/2024 02:00	0.21330	0.23136
09/14/2024 03:00	0.25296	0.27462
09/14/2024 04:00	0.25056	0.27198
09/14/2024 05:00	0.26916	0.29232
09/14/2024 06:00	0.22554	0.24444
09/14/2024 07:00	0.21372	0.23172
09/14/2024 08:00	0.21330	0.23130
09/14/2024 09:00	0.21324	0.23100
09/14/2024 10:00	0.21348	0.23070
09/14/2024 11:00	0.21468	0.23040
09/14/2024 12:00	0.21510	0.23106
09/14/2024 13:00	0.21474	0.23118
09/14/2024 14:00	0.21492	0.23124
09/14/2024 15:00	0.21414	0.23028
09/14/2024 16:00	0.22626	0.24348
09/14/2024 17:00	0.25068	0.27054
09/14/2024 18:00	0.24114	0.26028
09/14/2024 19:00	0.21330	0.23094
09/14/2024 20:00	0.21276	0.23058
09/14/2024 21:00	0.21288	0.23130
09/14/2024 22:00	0.21300	0.23202
09/14/2024 23:00	0.21426	0.23214
Average/Sum#:	0.22392	0.24223
Minimum:	0.21276	0.23028
Maximum:	0.26916	0.29232
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/15/2024 00:00	0.21426	0.23226
09/15/2024 01:00	0.21432	0.23232
09/15/2024 02:00	0.21432	0.23250
09/15/2024 03:00	0.21426	0.23262
09/15/2024 04:00	0.21432	0.23274
09/15/2024 05:00	0.21444	0.23292
09/15/2024 06:00	0.21444	0.23280
09/15/2024 07:00	0.21456	0.23274
09/15/2024 08:00	0.21426	0.23256
09/15/2024 09:00	0.21426	0.23220
09/15/2024 10:00	0.21372	0.23148
09/15/2024 11:00	0.21408	0.23082
09/15/2024 12:00	0.21360	0.23070
09/15/2024 13:00	0.21300	0.23064
09/15/2024 14:00	0.21306	0.23040
09/15/2024 15:00	0.21312	0.23064
09/15/2024 16:00	0.22806	0.24696
09/15/2024 17:00	0.21360	0.23142
09/15/2024 18:00	0.21300	0.23100
09/15/2024 19:00	0.21306	0.23130
09/15/2024 20:00	0.21312	0.23196
09/15/2024 21:00	0.21318	0.23166
09/15/2024 22:00	0.21342	0.23172
09/15/2024 23:00	0.21348	0.23184
Average/Sum#:	0.21437	0.23243
Minimum:	0.21300	0.23040
Maximum:	0.22806	0.24696
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/16/2024 00:00	0.21360	0.23202
09/16/2024 01:00	0.21366	0.23220
09/16/2024 02:00	0.21372	0.23250
09/16/2024 03:00	0.21360	0.23274
09/16/2024 04:00	0.21348	0.23346
09/16/2024 05:00	0.23454	0.25590
09/16/2024 06:00	0.23382	0.25410
09/16/2024 07:00	0.25872	0.28086
09/16/2024 08:00	0.27606	0.30090
09/16/2024 09:00	0.26994	0.29070
09/16/2024 10:00	0.26916	0.29142
09/16/2024 11:00	0.26916	0.29112
09/16/2024 12:00	0.24012	0.25932
09/16/2024 13:00	0.21372	0.23136
09/16/2024 14:00	0.21336	0.23100
09/16/2024 15:00	0.21354	0.23130
09/16/2024 16:00	0.22890	0.24780
09/16/2024 17:00	0.21636	0.23454
09/16/2024 18:00	0.21504	0.23304
09/16/2024 19:00	0.21516	0.23328
09/16/2024 20:00	0.25176	0.27354
09/16/2024 21:00	0.23898	0.25908
09/16/2024 22:00	0.24960	0.27114
09/16/2024 23:00	0.22002	0.23880
Average/Sum#:	0.23317	0.25301
Minimum:	0.21336	0.23100
Maximum:	0.27606	0.30090
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/17/2024 00:00	0.21348	0.23214
09/17/2024 01:00	0.21384	0.23238
09/17/2024 02:00	0.21372	0.23244
09/17/2024 03:00	0.21402	0.23262
09/17/2024 04:00	0.22554	0.24540
09/17/2024 05:00	0.25140	0.27330
09/17/2024 06:00	0.22560	0.24522
09/17/2024 07:00	0.21504	0.23388
09/17/2024 08:00	0.21534	0.23418
09/17/2024 09:00	0.21594	0.23412
09/17/2024 10:00	0.21492	0.23352
09/17/2024 11:00	0.21576	0.23322
09/17/2024 12:00	0.21594	0.23406
09/17/2024 13:00	0.21570	0.23328
09/17/2024 14:00	0.21582	0.23274
09/17/2024 15:00	0.21582	0.23280
09/17/2024 16:00	0.21564	0.23262
09/17/2024 17:00	0.21450	0.23262
09/17/2024 18:00	0.21408	0.23268
09/17/2024 19:00	0.21432	0.23304
09/17/2024 20:00	0.21534	0.23292
09/17/2024 21:00	0.21570	0.23304
09/17/2024 22:00	0.21558	0.23310
09/17/2024 23:00	0.21462	0.23316
Average/Sum#:	0.21740	0.23577
Minimum:	0.21348	0.23214
Maximum:	0.25140	0.27330
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/18/2024 00:00	0.21450	0.23328
09/18/2024 01:00	0.21468	0.23310
09/18/2024 02:00	0.21396	0.23184
09/18/2024 03:00	0.21378	0.23190
09/18/2024 04:00	0.21390	0.23274
09/18/2024 05:00	0.21648	0.23568
09/18/2024 06:00	0.22842	0.24810
09/18/2024 07:00	0.21420	0.23262
09/18/2024 08:00	0.21420	0.23208
09/18/2024 09:00	0.21480	0.23226
09/18/2024 10:00	0.21486	0.23208
09/18/2024 11:00	0.21522	0.23196
09/18/2024 12:00	0.21498	0.23214
09/18/2024 13:00	0.21492	0.23238
09/18/2024 14:00	0.21480	0.23208
09/18/2024 15:00	0.21432	0.23220
09/18/2024 16:00	0.23760	0.25680
09/18/2024 17:00	0.23964	0.25872
09/18/2024 18:00	0.21396	0.23160
09/18/2024 19:00	0.21420	0.23166
09/18/2024 20:00	0.26694	0.28842
09/18/2024 21:00	0.26904	0.29166
09/18/2024 22:00	0.26898	0.29166
09/18/2024 23:00	0.26742	0.29064
Average/Sum#:	0.22608	0.24490
Minimum:	0.21378	0.23160
Maximum:	0.26904	0.29166
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/19/2024 00:00	0.26880	0.29196
09/19/2024 01:00	0.26370	0.28614
09/19/2024 02:00	0.25716	0.27924
09/19/2024 03:00	0.26790	0.29088
09/19/2024 04:00	0.26868	0.29040
09/19/2024 05:00	0.26730	0.29004
09/19/2024 06:00	0.23346	0.25326
09/19/2024 07:00	0.26202	0.28404
09/19/2024 08:00	0.22344	0.24258
09/19/2024 09:00	0.21318	0.23064
09/19/2024 10:00	0.21336	0.23106
09/19/2024 11:00	0.21300	0.23040
09/19/2024 12:00	0.21360	0.23052
09/19/2024 13:00	0.21252	0.22998
09/19/2024 14:00	0.21246	0.22986
09/19/2024 15:00	0.21282	0.22980
09/19/2024 16:00	0.23586	0.25380
09/19/2024 17:00	0.26916	0.28866
09/19/2024 18:00	0.34410	0.36432
09/19/2024 19:00	0.31350	0.33300
09/19/2024 20:00	0.26832	0.29028
09/19/2024 21:00	0.26268	0.28404
09/19/2024 22:00	0.21546	0.23406
09/19/2024 23:00	0.21462	0.23274
Average/Sum#:	0.24696	0.26674
Minimum:	0.21246	0.22980
Maximum:	0.34410	0.36432
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/20/2024 00:00	0.21156	0.23010
09/20/2024 01:00	0.21120	0.22980
09/20/2024 02:00	0.21168	0.22926
09/20/2024 03:00	0.21096	0.22926
09/20/2024 04:00	0.21546	0.23436
09/20/2024 05:00	0.22764	0.24786
09/20/2024 06:00	0.21906	0.23790
09/20/2024 07:00	0.21174	0.23052
09/20/2024 08:00	0.21102	0.22956
09/20/2024 09:00	0.21270	0.23082
09/20/2024 10:00	0.22680	0.24546
09/20/2024 11:00	0.26172	0.28272
09/20/2024 12:00	0.26280	0.28260
09/20/2024 13:00	0.23850	0.25734
09/20/2024 14:00	0.23460	0.25314
09/20/2024 15:00	0.21138	0.22818
09/20/2024 16:00	0.22278	0.24030
09/20/2024 17:00	0.22716	0.24474
09/20/2024 18:00	0.21114	0.22806
09/20/2024 19:00	0.21072	0.22830
09/20/2024 20:00	0.21084	0.22866
09/20/2024 21:00	0.21102	0.22884
09/20/2024 22:00	0.21054	0.22866
09/20/2024 23:00	0.21072	0.22866
Average/Sum#:	0.22057	0.23896
Minimum:	0.21054	0.22806
Maximum:	0.26280	0.28272
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/21/2024 00:00	0.21078	0.22896
09/21/2024 01:00	0.21060	0.22908
09/21/2024 02:00	0.21120	0.23040
09/21/2024 03:00	0.22440	0.24360
09/21/2024 04:00	0.23772	0.25818
09/21/2024 05:00	0.21522	0.23394
09/21/2024 06:00	0.22686	0.24660
09/21/2024 07:00	0.21198	0.23076
09/21/2024 08:00	0.21198	0.23040
09/21/2024 09:00	0.21168	0.22950
09/21/2024 10:00	0.21198	0.22944
09/21/2024 11:00	0.23148	0.24948
09/21/2024 12:00	0.24600	0.26538
09/21/2024 13:00	0.26382	0.28440
09/21/2024 14:00	0.26124	0.28146
09/21/2024 15:00	0.23004	0.24798
09/21/2024 16:00	0.31884	0.34020
09/21/2024 17:00	0.35238	0.37206
09/21/2024 18:00	0.31680	0.33702
09/21/2024 19:00	0.28710	0.30780
09/21/2024 20:00	0.22260	0.24078
09/21/2024 21:00	0.21762	0.23574
09/21/2024 22:00	0.21546	0.23322
09/21/2024 23:00	0.21132	0.22884
Average/Sum#:	0.23996	0.25897
Minimum:	0.21060	0.22884
Maximum:	0.35238	0.37206
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/22/2024 00:00	0.21120	0.23010
09/22/2024 01:00	0.21096	0.22920
09/22/2024 02:00	0.21114	0.22908
09/22/2024 03:00	0.21168	0.22896
09/22/2024 04:00	0.21108	0.22902
09/22/2024 05:00	0.21078	0.22914
09/22/2024 06:00	0.21156	0.22944
09/22/2024 07:00	0.21180	0.23046
09/22/2024 08:00	0.21138	0.23040
09/22/2024 09:00	0.21210	0.22968
09/22/2024 10:00	0.21240	0.22944
09/22/2024 11:00	0.21240	0.22908
09/22/2024 12:00	0.21210	0.22878
09/22/2024 13:00	0.25674	0.27696
09/22/2024 14:00	0.23298	0.25098
09/22/2024 15:00	0.21228	0.22872
09/22/2024 16:00	0.23016	0.24840
09/22/2024 17:00	0.21246	0.22884
09/22/2024 18:00	0.21132	0.22752
09/22/2024 19:00	0.21096	0.22776
09/22/2024 20:00	0.20964	0.22674
09/22/2024 21:00	0.21012	0.22686
09/22/2024 22:00	0.21060	0.22776
09/22/2024 23:00	0.21156	0.22884
Average/Sum#:	0.21498	0.23259
Minimum:	0.20964	0.22674
Maximum:	0.25674	0.27696
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/23/2024 00:00	0.21108	0.22896
09/23/2024 01:00	0.21144	0.22914
09/23/2024 02:00	0.21114	0.22890
09/23/2024 03:00	0.21168	0.22884
09/23/2024 04:00	0.21138	0.22878
09/23/2024 05:00	0.21078	0.22890
09/23/2024 06:00	0.21234	0.23076
09/23/2024 07:00	0.21102	0.22914
09/23/2024 08:00	0.21066	0.22872
09/23/2024 09:00	0.21108	0.22890
09/23/2024 10:00	0.21180	0.22962
09/23/2024 11:00	0.21186	0.22938
09/23/2024 12:00	0.21534	0.23220
09/23/2024 13:00	0.22974	0.24612
09/23/2024 14:00	0.23268	0.25032
09/23/2024 15:00	0.23598	0.25392
09/23/2024 16:00	0.29028	0.30960
09/23/2024 17:00	0.34794	0.36720
09/23/2024 18:00	0.33084	0.35130
09/23/2024 19:00	0.29880	0.31926
09/23/2024 20:00	0.25992	0.28080
09/23/2024 21:00	0.25920	0.28014
09/23/2024 22:00	0.25542	0.27642
09/23/2024 23:00	0.24390	0.26364
Average/Sum#:	0.23901	0.25754
Minimum:	0.21066	0.22872
Maximum:	0.34794	0.36720
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/24/2024 00:00	0.24198	0.26196
09/24/2024 01:00	0.21384	0.23178
09/24/2024 02:00	0.21126	0.22902
09/24/2024 03:00	0.22080	0.23922
09/24/2024 04:00	0.25014	0.27084
09/24/2024 05:00	0.25944	0.28116
09/24/2024 06:00	0.22434	0.24336
09/24/2024 07:00	0.21036	0.22866
09/24/2024 08:00	0.20928	0.22668
09/24/2024 09:00	0.21048	0.22782
09/24/2024 10:00	0.21144	0.22872
09/24/2024 11:00	0.21132	0.22800
09/24/2024 12:00	0.23064	0.24816
09/24/2024 13:00	0.24732	0.26580
09/24/2024 14:00	0.24894	0.26814
09/24/2024 15:00	0.22512	0.24192
09/24/2024 16:00	0.24318	0.26058
09/24/2024 17:00	0.31596	0.33552
09/24/2024 18:00	0.26058	0.27996
09/24/2024 19:00	0.21096	0.22824
09/24/2024 20:00	0.21120	0.22866
09/24/2024 21:00	0.21150	0.22872
09/24/2024 22:00	0.21060	0.22830
09/24/2024 23:00	0.21072	0.22908
Average/Sum#:	0.22923	0.24751
Minimum:	0.20928	0.22668
Maximum:	0.31596	0.33552
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/25/2024 00:00	0.21174	0.22914
09/25/2024 01:00	0.21144	0.22902
09/25/2024 02:00	0.21192	0.22968
09/25/2024 03:00	0.21234	0.23016
09/25/2024 04:00	0.22098	0.23952
09/25/2024 05:00	0.23664	0.25680
09/25/2024 06:00	0.21924	0.23760
09/25/2024 07:00	0.21078	0.22788
09/25/2024 08:00	0.24246	0.26298
09/25/2024 09:00	0.21936	0.23748
09/25/2024 10:00	0.21222	0.22998
09/25/2024 11:00	0.21024	0.22752
09/25/2024 12:00	0.20940	0.22716
09/25/2024 13:00	0.21018	0.22752
09/25/2024 14:00	0.20970	0.22638
09/25/2024 15:00	0.21000	0.22644
09/25/2024 16:00	0.22092	0.23862
09/25/2024 17:00	0.21246	0.22974
09/25/2024 18:00	0.21132	0.22890
09/25/2024 19:00	0.21102	0.22800
09/25/2024 20:00	0.21114	0.22824
09/25/2024 21:00	0.21072	0.22848
09/25/2024 22:00	0.21060	0.22842
09/25/2024 23:00	0.21054	0.22860
Average/Sum#:	0.21489	0.23268
Minimum:	0.20940	0.22638
Maximum:	0.24246	0.26298
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/26/2024 00:00	0.21048	0.22866
09/26/2024 01:00	0.21048	0.22866
09/26/2024 02:00	0.21048	0.22884
09/26/2024 03:00	0.21048	0.22872
09/26/2024 04:00	0.21030	0.22884
09/26/2024 05:00	0.21042	0.22890
09/26/2024 06:00	0.21054	0.22908
09/26/2024 07:00	0.21090	0.22932
09/26/2024 08:00	0.21084	0.22938
09/26/2024 09:00	0.21066	0.22878
09/26/2024 10:00	0.21048	0.22806
09/26/2024 11:00	0.21072	0.22794
09/26/2024 12:00	0.21138	0.22896
09/26/2024 13:00	0.21204	0.22848
09/26/2024 14:00	0.21156	0.22800
09/26/2024 15:00	0.21114	0.22746
09/26/2024 16:00	0.24678	0.26538
09/26/2024 17:00	0.32136	0.34146
09/26/2024 18:00	0.32226	0.34218
09/26/2024 19:00	0.31746	0.33828
09/26/2024 20:00	0.32292	0.34314
09/26/2024 21:00	0.26760	0.28758
09/26/2024 22:00	0.23136	0.25038
09/26/2024 23:00	0.21390	0.23154
Average/Sum#:	0.23402	0.25242
Minimum:	0.21030	0.22746
Maximum:	0.32292	0.34314
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/27/2024 00:00	0.21018	0.22752
09/27/2024 01:00	0.21048	0.22770
09/27/2024 02:00	0.21048	0.22770
09/27/2024 03:00	0.21078	0.22806
09/27/2024 04:00	0.23886	0.25932
09/27/2024 05:00	0.25110	0.27276
09/27/2024 06:00	0.22824	0.24750
09/27/2024 07:00	0.21048	0.22854
09/27/2024 08:00	0.21054	0.22806
09/27/2024 09:00	0.21048	0.22758
09/27/2024 10:00	0.21060	0.22734
09/27/2024 11:00	0.21084	0.22698
09/27/2024 12:00	0.20994	0.22590
09/27/2024 13:00	0.20964	0.22572
09/27/2024 14:00	0.20952	0.22542
09/27/2024 15:00	0.21144	0.22740
09/27/2024 16:00	0.24810	0.26616
09/27/2024 17:00	0.30612	0.32574
09/27/2024 18:00	0.30486	0.32502
09/27/2024 19:00	0.28704	0.30738
09/27/2024 20:00	0.25926	0.28002
09/27/2024 21:00	0.24996	0.27006
09/27/2024 22:00	0.24864	0.26802
09/27/2024 23:00	0.26454	0.28566
Average/Sum#:	0.23426	0.25257
Minimum:	0.20952	0.22542
Maximum:	0.30612	0.32574
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/28/2024 00:00	0.25530	0.27558
09/28/2024 01:00	0.22572	0.24408
09/28/2024 02:00	0.20964	0.22722
09/28/2024 03:00	0.21012	0.22740
09/28/2024 04:00	0.21060	0.22794
09/28/2024 05:00	0.21138	0.22926
09/28/2024 06:00	0.21072	0.22848
09/28/2024 07:00	0.20976	0.22758
09/28/2024 08:00	0.20964	0.22698
09/28/2024 09:00	0.20934	0.22638
09/28/2024 10:00	0.20934	0.22602
09/28/2024 11:00	0.20952	0.22560
09/28/2024 12:00	0.20994	0.22548
09/28/2024 13:00	0.21144	0.22710
09/28/2024 14:00	0.22188	0.23826
09/28/2024 15:00	0.22758	0.24462
09/28/2024 16:00	0.24696	0.26418
09/28/2024 17:00	0.30528	0.32460
09/28/2024 18:00	0.30372	0.32352
09/28/2024 19:00	0.28548	0.30546
09/28/2024 20:00	0.21138	0.22842
09/28/2024 21:00	0.20964	0.22680
09/28/2024 22:00	0.20970	0.22710
09/28/2024 23:00	0.20994	0.22740
Average/Sum#:	0.22642	0.24398
Minimum:	0.20934	0.22548
Maximum:	0.30528	0.32460
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/29/2024 00:00	0.21000	0.22752
09/29/2024 01:00	0.21000	0.22788
09/29/2024 02:00	0.21018	0.22800
09/29/2024 03:00	0.21030	0.22854
09/29/2024 04:00	0.21036	0.22872
09/29/2024 05:00	0.21030	0.22866
09/29/2024 06:00	0.21036	0.22872
09/29/2024 07:00	0.21042	0.22878
09/29/2024 08:00	0.21024	0.22842
09/29/2024 09:00	0.21054	0.22830
09/29/2024 10:00	0.21048	0.22806
09/29/2024 11:00	0.21024	0.22734
09/29/2024 12:00	0.21024	0.22680
09/29/2024 13:00	0.20982	0.22662
09/29/2024 14:00	0.21024	0.22662
09/29/2024 15:00	0.21000	0.22656
09/29/2024 16:00	0.23568	0.25404
09/29/2024 17:00	0.21288	0.22908
09/29/2024 18:00	0.21012	0.22674
09/29/2024 19:00	0.21138	0.22854
09/29/2024 20:00	0.20976	0.22716
09/29/2024 21:00	0.20982	0.22716
09/29/2024 22:00	0.20994	0.22740
09/29/2024 23:00	0.21030	0.22764
Average/Sum#:	0.21140	0.22889
Minimum:	0.20976	0.22656
Maximum:	0.23568	0.25404
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 08:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/30/2024 00:00	0.21042	0.22782
09/30/2024 01:00	0.21030	0.22806
09/30/2024 02:00	0.21042	0.22830
09/30/2024 03:00	0.21090	0.22860
09/30/2024 04:00	0.21096	0.22902
09/30/2024 05:00	0.21324	0.23172
09/30/2024 06:00	0.23028	0.24972
09/30/2024 07:00	0.21084	0.22866
09/30/2024 08:00	0.21060	0.22818
09/30/2024 09:00	0.21096	0.22830
09/30/2024 10:00	0.21138	0.22824
09/30/2024 11:00	0.21114	0.22800
09/30/2024 12:00	0.21150	0.22776
09/30/2024 13:00	0.21186	0.22860
09/30/2024 14:00	0.21198	0.22794
09/30/2024 15:00	0.25086	0.26904
09/30/2024 16:00	0.36552	0.38490
09/30/2024 17:00	0.36090	0.38082
09/30/2024 18:00	0.35088	0.37044
09/30/2024 19:00	0.35424	0.37284
09/30/2024 20:00	0.35790	0.37710
09/30/2024 21:00	0.35592	0.37566
09/30/2024 22:00	0.32712	0.34722
09/30/2024 23:00	0.26478	0.28644
Average/Sum#:	0.25729	0.27556
Minimum:	0.21030	0.22776
Maximum:	0.36552	0.38490
%SI	0.00	0.00

AQ-51

AQ-51 The ammonia slip shall not exceed 10 ppmv @ 15% O₂ averaged over one hour. The SCR catalyst shall be replaced, repaired or otherwise reconditioned within 24 months of the ammonia slip reaching 7 ppm @ 15% O₂ averaged over 24 hours. The SCR ammonia injection grid replacement, repair or reconditioning scheduled event may be cancelled if the Project owner can demonstrate to the CPM that, subsequent to the initial exceedance, the ammonia slip consistently remains below 7 ppm @ 15% O₂ averaged over 24 hours and that the initial exceedance does not accurately indicate expected future operating conditions.

Compliance with ammonia slip limits shall be demonstrated by using the following calculation procedure:

$$\text{Ammonia slip ppmv @ 15\% O}_2 = ((a - (b \times c / 1,000,000)) \times 1,000,000 / b) \times d,$$

Where

a = ammonia injection rate (lb/hr)/17(lb/lb mol)

b = dry exhaust gas flow rate (lb/hr)/ (29(lb/lb mol)

c = change in measured NOX conc. Ppmv @ 15% O₂ across catalyst, and

d = correction factor

The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip.

Verification: The Project owner shall include the ammonia slip concentrations averaged on an hourly and 24 hour basis calculated via the protocol provided as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6. The Project owner shall notify the CPM within 10 days of an exceedance of the 7 ppm ammonia slip limit herein. The Project owner shall notify the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event. If the Project owner finds that the exceedance of the 7 ppm slip limit does not accurately reflect the expected future operations provided for in this condition, the Project owner shall submit all relevant information to the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event in order to cancel the event.

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2024 00:00	1	1.5	9.6	14.4	18.0	740,542.6	0.00	1.00
07/01/2024 01:00	1	1.5	9.5	14.4	17.9	739,910.5	0.00	1.00
07/01/2024 02:00	1	1.6	10.0	14.4	17.3	740,542.6	0.00	1.00
07/01/2024 03:00	1	1.6	9.9	14.3	17.8	730,982.1	0.00	1.00
07/01/2024 04:00	1	1.5	9.7	14.3	18.1	729,944.7	0.00	1.00
07/01/2024 05:00	1	1.6	9.8	14.3	18.2	730,774.6	0.00	1.00
07/01/2024 06:00	1	1.6	9.5	14.4	17.3	744,545.5	0.00	1.00
07/01/2024 07:00	1	1.5	9.4	14.4	17.1	748,127.1	0.00	1.00
07/01/2024 08:00	1	1.6	9.4	14.4	17.0	747,284.4	0.00	1.00
07/01/2024 09:00	1	1.5	9.4	14.5	17.2	758,746.7	0.00	1.00
07/01/2024 10:00	1	1.5	9.5	14.5	18.4	758,746.7	0.00	1.00
07/01/2024 11:00	0	1.3	7.4	14.5	11.0	761,742.3	0.00	1.00
07/01/2024 12:00	0	1.4	6.7	14.6	10.4	774,485.6	0.00	1.00
07/01/2024 13:00	0	1.3	6.6	14.6	9.8	774,268.2	0.00	1.00
07/01/2024 14:00	0	1.5	7.9	14.5	14.2	764,737.9	0.00	1.00
07/01/2024 15:00	0	1.5	9.1	14.4	16.0	754,236.8	0.00	1.00
07/01/2024 16:00	1	1.5	9.2	14.4	17.6	753,604.8	0.00	1.00
07/01/2024 17:00	0	1.4	8.5	14.5	14.8	812,239.8	0.00	1.00
07/01/2024 18:00	1	2.0	10.8	13.1	24.6	927,521.7	0.00	1.00
07/01/2024 19:00	2	2.4	13.5	11.7	37.2	959,787.9	0.00	1.00
07/01/2024 20:00	1	2.0	11.3	12.8	27.1	958,258.9	0.00	1.00
07/01/2024 21:00	1	1.6	8.9	14.4	16.7	802,272.0	0.00	1.00
07/01/2024 22:00	1	1.5	9.6	14.5	17.5	756,179.0	0.00	1.00
07/01/2024 23:00	1	1.6	9.5	14.5	17.5	754,681.2	0.00	1.00
Average/Sum#:	1	1.6	9.4	14.2	17.9	780,173.5	0.00 #	24.00 #
Minimum:	0	1.3	6.6	11.7	9.8	729,944.7	0.00	1.00
Maximum:	2	2.4	13.5	14.6	37.2	959,787.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/02/2024 00:00	1	1.5	9.5	14.4	17.8	744,334.8	0.00	1.00
07/02/2024 01:00	1	1.6	9.8	14.4	18.5	742,649.4	0.00	1.00
07/02/2024 02:00	1	1.5	10.3	14.4	19.0	742,228.0	0.00	1.00
07/02/2024 03:00	1	1.5	10.3	14.4	19.5	741,806.7	0.00	1.00
07/02/2024 04:00	1	1.6	10.2	14.4	18.9	743,070.7	0.00	1.00
07/02/2024 05:00	1	1.4	8.8	14.4	17.8	809,013.8	0.00	1.00
07/02/2024 06:00	1	1.5	9.6	14.3	18.0	745,298.8	0.00	1.00
07/02/2024 07:00	1	1.5	9.8	14.4	18.8	747,916.4	0.00	1.00
07/02/2024 08:00	1	1.5	9.7	14.5	17.8	755,751.1	0.00	1.00
07/02/2024 09:00	0	1.4	8.2	14.5	14.0	754,467.2	0.00	1.00
07/02/2024 10:00	0	1.4	7.0	14.5	10.6	754,895.2	0.00	1.00
07/02/2024 11:00	0	1.4	6.7	14.6	10.1	771,442.4	0.00	1.00
07/02/2024 12:00	0	1.5	8.3	14.5	14.5	774,366.7	0.00	1.00
07/02/2024 13:00	0	1.5	7.7	14.2	14.6	867,029.6	0.00	1.00
07/02/2024 14:00	1	2.1	11.7	12.7	26.7	956,593.0	0.00	1.00
07/02/2024 15:00	1	2.2	12.4	12.2	31.5	952,458.3	0.00	1.00
07/02/2024 16:00	2	2.3	12.8	12.0	33.8	950,442.1	0.00	1.00
07/02/2024 17:00	2	2.3	13.0	11.8	35.7	955,135.9	0.00	1.00
07/02/2024 18:00	2	2.3	13.0	11.8	36.0	951,524.2	0.00	1.00
07/02/2024 19:00	2	2.3	12.8	11.9	34.4	954,336.6	0.00	1.00
07/02/2024 20:00	2	2.3	12.8	12.0	34.2	959,520.3	0.00	1.00
07/02/2024 21:00	1	2.1	12.1	12.3	29.7	947,928.3	0.00	1.00
07/02/2024 22:00	1	1.5	8.3	14.4	16.6	851,571.3	0.00	1.00
07/02/2024 23:00	1	1.5	9.5	14.5	17.7	761,314.4	0.00	1.00
Average/Sum#:	1	1.7	10.2	13.6	21.9	830,629.0	0.00 #	24.00 #
Minimum:	0	1.4	6.7	11.8	10.1	741,806.7	0.00	1.00
Maximum:	2	2.3	13.0	14.6	36.0	959,520.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/03/2024 00:00	1	1.5	9.4	14.5	17.4	764,737.9	0.00	1.00
07/03/2024 01:00	1	1.5	9.2	14.4	16.8	746,020.3	0.00	1.00
07/03/2024 02:00	1	1.6	9.9	14.4	17.3	744,966.9	0.00	1.00
07/03/2024 03:00	1	1.6	9.8	14.4	18.3	744,966.9	0.00	1.00
07/03/2024 04:00	1	1.6	9.9	14.4	18.8	744,334.8	0.00	1.00
07/03/2024 05:00	1	1.5	10.0	14.4	19.2	745,177.5	0.00	1.00
07/03/2024 06:00	1	1.5	10.0	14.4	18.4	744,756.2	0.00	1.00
07/03/2024 07:00	1	1.5	9.9	14.5	19.4	758,746.7	0.00	1.00
07/03/2024 08:00	1	1.5	9.8	14.5	17.5	757,676.8	0.00	1.00
07/03/2024 09:00	0	1.4	8.9	14.5	15.7	757,248.9	0.00	1.00
07/03/2024 10:00	0	1.3	7.1	14.5	12.2	757,034.9	0.00	1.00
07/03/2024 11:00	0	1.2	6.9	14.6	12.0	773,398.7	0.00	1.00
07/03/2024 12:00	0	1.2	6.5	14.6	10.9	775,137.7	0.00	1.00
07/03/2024 13:00	0	1.2	6.3	14.6	9.9	792,744.6	0.00	1.00
07/03/2024 14:00	1	1.8	10.0	13.5	22.0	938,610.9	0.00	1.00
07/03/2024 15:00	1	2.0	11.6	12.8	27.4	957,920.8	0.00	1.00
07/03/2024 16:00	1	2.2	12.5	12.2	31.9	958,754.5	0.00	1.00
07/03/2024 17:00	2	2.3	12.7	11.9	34.5	958,597.1	0.00	1.00
07/03/2024 18:00	2	2.3	12.6	11.9	34.0	955,401.7	0.00	1.00
07/03/2024 19:00	2	2.3	12.5	11.9	33.6	951,141.3	0.00	1.00
07/03/2024 20:00	1	2.1	12.0	12.5	28.1	955,336.5	0.00	1.00
07/03/2024 21:00	1	1.5	8.4	14.2	16.9	825,538.1	0.00	1.00
07/03/2024 22:00	0	1.4	7.8	14.5	12.3	757,248.9	0.00	1.00
07/03/2024 23:00	1	1.5	8.9	14.5	16.3	758,104.8	0.00	1.00
Average/Sum#:	1	1.6	9.7	13.9	20.0	817,650.1	0.00 #	24.00 #
Minimum:	0	1.2	6.3	11.9	9.9	744,334.8	0.00	1.00
Maximum:	2	2.3	12.7	14.6	34.5	958,754.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/04/2024 00:00	1	1.5	9.2	14.5	16.8	759,816.6	0.00	1.00
07/04/2024 01:00	1	1.5	9.2	14.4	17.2	746,441.6	0.00	1.00
07/04/2024 02:00	1	1.6	9.8	14.4	16.6	745,598.9	0.00	1.00
07/04/2024 03:00	1	1.6	9.7	14.4	18.2	745,388.2	0.00	1.00
07/04/2024 04:00	1	1.5	9.6	14.4	18.0	745,809.6	0.00	1.00
07/04/2024 05:00	1	1.5	9.5	14.4	17.7	746,441.6	0.00	1.00
07/04/2024 06:00	1	1.5	9.6	14.4	18.1	747,284.4	0.00	1.00
07/04/2024 07:00	1	1.5	9.4	14.5	18.5	760,458.5	0.00	1.00
07/04/2024 08:00	0	1.3	8.4	14.5	14.6	759,816.6	0.00	1.00
07/04/2024 09:00	0	1.4	6.9	14.5	9.9	759,602.6	0.00	1.00
07/04/2024 10:00	0	1.4	6.7	14.6	10.8	772,529.2	0.00	1.00
07/04/2024 11:00	0	1.3	6.4	14.6	9.5	775,355.0	0.00	1.00
07/04/2024 12:00	0	1.4	5.9	14.6	8.2	775,572.4	0.00	1.00
07/04/2024 13:00	0	1.4	5.9	14.6	8.5	775,355.0	0.00	1.00
07/04/2024 14:00	0	1.4	6.0	14.6	8.0	775,355.0	0.00	1.00
07/04/2024 15:00	0	1.3	6.2	14.6	9.9	773,181.4	0.00	1.00
07/04/2024 16:00	0	1.4	7.4	14.6	15.2	870,345.3	0.00	1.00
07/04/2024 17:00	1	1.4	8.4	14.4	16.1	785,206.9	0.00	1.00
07/04/2024 18:00	0	1.4	7.4	14.5	14.1	875,575.7	0.00	1.00
07/04/2024 19:00	0	1.4	7.8	14.5	12.0	759,388.6	0.00	1.00
07/04/2024 20:00	0	1.4	7.1	14.5	11.5	756,179.0	0.00	1.00
07/04/2024 21:00	0	1.4	6.9	14.5	11.3	755,751.1	0.00	1.00
07/04/2024 22:00	1	1.5	8.8	14.5	16.9	755,965.1	0.00	1.00
07/04/2024 23:00	1	1.5	9.5	14.5	17.9	758,746.7	0.00	1.00
Average/Sum#:	0	1.4	8.0	14.5	14.0	770,048.5	0.00 #	24.00 #
Minimum:	0	1.3	5.9	14.4	8.0	745,388.2	0.00	1.00
Maximum:	1	1.6	9.8	14.6	18.5	875,575.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/05/2024 00:00	0	1.4	6.9	14.6	13.8	903,820.1	0.00	1.00
07/05/2024 01:00	0	1.4	7.1	14.6	14.5	902,515.9	0.00	1.00
07/05/2024 02:00	0	1.5	7.5	14.6	14.6	901,646.4	0.00	1.00
07/05/2024 03:00	1	1.5	10.0	14.4	19.7	744,966.9	0.00	1.00
07/05/2024 04:00	1	1.5	9.8	14.4	18.7	743,492.1	0.00	1.00
07/05/2024 05:00	1	1.5	9.8	14.4	19.0	744,334.8	0.00	1.00
07/05/2024 06:00	1	1.5	9.6	14.4	18.7	744,756.2	0.00	1.00
07/05/2024 07:00	1	1.5	9.5	14.5	18.7	758,318.8	0.00	1.00
07/05/2024 08:00	1	1.5	9.4	14.5	17.8	757,034.9	0.00	1.00
07/05/2024 09:00	0	1.4	8.2	14.5	13.2	755,965.1	0.00	1.00
07/05/2024 10:00	0	1.4	6.8	14.5	11.0	756,179.0	0.00	1.00
07/05/2024 11:00	0	1.3	6.7	14.6	10.5	771,442.4	0.00	1.00
07/05/2024 12:00	0	1.4	6.3	14.6	9.4	772,094.5	0.00	1.00
07/05/2024 13:00	0	1.4	6.1	14.6	8.7	772,094.5	0.00	1.00
07/05/2024 14:00	0	1.3	6.1	14.6	9.9	772,094.5	0.00	1.00
07/05/2024 15:00	0	1.3	6.2	14.6	9.3	772,311.9	0.00	1.00
07/05/2024 16:00	0	1.4	6.8	14.6	12.0	771,659.8	0.00	1.00
07/05/2024 17:00	0	1.4	8.3	14.2	16.5	849,451.9	0.00	1.00
07/05/2024 18:00	1	2.2	12.4	12.2	30.3	948,838.0	0.00	1.00
07/05/2024 19:00	1	1.8	9.6	13.2	20.7	935,832.6	0.00	1.00
07/05/2024 20:00	1	1.5	8.1	14.1	16.6	808,967.3	0.00	1.00
07/05/2024 21:00	0	1.4	6.6	14.5	9.4	754,253.3	0.00	1.00
07/05/2024 22:00	0	1.4	6.7	14.5	10.4	754,039.3	0.00	1.00
07/05/2024 23:00	0	1.4	6.8	14.5	10.9	753,825.3	0.00	1.00
Average/Sum#:	0	1.5	8.0	14.3	14.8	797,914.0	0.00 #	24.00 #
Minimum:	0	1.3	6.1	12.2	8.7	743,492.1	0.00	1.00
Maximum:	1	2.2	12.4	14.6	30.3	948,838.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/06/2024 00:00	0	1.4	7.4	14.5	13.3	754,039.3	0.00	1.00
07/06/2024 01:00	1	1.5	9.4	14.5	18.2	754,895.2	0.00	1.00
07/06/2024 02:00	1	1.6	9.9	14.5	17.1	754,895.2	0.00	1.00
07/06/2024 03:00	1	1.5	9.7	14.4	18.5	743,070.7	0.00	1.00
07/06/2024 04:00	1	1.5	9.5	14.4	17.5	744,756.2	0.00	1.00
07/06/2024 05:00	1	1.5	9.6	14.4	18.2	745,177.5	0.00	1.00
07/06/2024 06:00	1	1.5	9.4	14.4	17.5	744,756.2	0.00	1.00
07/06/2024 07:00	1	1.5	9.3	14.5	16.6	758,318.8	0.00	1.00
07/06/2024 08:00	0	1.4	8.0	14.5	13.3	757,890.8	0.00	1.00
07/06/2024 09:00	0	1.4	6.8	14.5	10.2	757,248.9	0.00	1.00
07/06/2024 10:00	0	1.3	6.5	14.6	10.2	769,703.5	0.00	1.00
07/06/2024 11:00	0	1.3	6.1	14.6	9.1	772,964.0	0.00	1.00
07/06/2024 12:00	1	1.5	8.6	14.4	16.2	754,658.2	0.00	1.00
07/06/2024 13:00	1	1.5	8.5	14.4	15.4	755,711.6	0.00	1.00
07/06/2024 14:00	0	1.4	7.6	14.5	13.3	836,632.7	0.00	1.00
07/06/2024 15:00	1	1.5	8.8	14.4	15.7	756,554.3	0.00	1.00
07/06/2024 16:00	0	1.5	8.1	14.5	14.4	799,401.5	0.00	1.00
07/06/2024 17:00	1	1.6	9.0	13.8	18.3	856,758.2	0.00	1.00
07/06/2024 18:00	1	2.2	12.5	12.2	30.5	940,967.7	0.00	1.00
07/06/2024 19:00	1	2.0	11.0	12.7	24.7	930,206.6	0.00	1.00
07/06/2024 20:00	1	1.7	8.7	13.6	18.2	910,385.8	0.00	1.00
07/06/2024 21:00	0	1.4	6.4	14.5	12.7	915,160.6	0.00	1.00
07/06/2024 22:00	0	1.5	6.5	14.5	12.1	898,684.8	0.00	1.00
07/06/2024 23:00	0	1.4	7.5	14.4	12.9	769,195.1	0.00	1.00
Average/Sum#:	1	1.5	8.5	14.2	16.0	799,251.4	0.00 #	24.00 #
Minimum:	0	1.3	6.1	12.2	9.1	743,070.7	0.00	1.00
Maximum:	1	2.2	12.5	14.6	30.5	940,967.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2024 00:00	0	1.4	7.0	14.5	12.1	757,676.8	0.00	1.00
07/07/2024 01:00	1	1.5	8.5	14.5	15.9	756,607.0	0.00	1.00
07/07/2024 02:00	1	1.7	10.0	14.5	16.3	756,179.0	0.00	1.00
07/07/2024 03:00	1	1.5	9.8	14.5	20.0	755,965.1	0.00	1.00
07/07/2024 04:00	1	1.5	9.6	14.4	17.5	744,545.5	0.00	1.00
07/07/2024 05:00	1	1.5	9.6	14.4	18.0	746,020.3	0.00	1.00
07/07/2024 06:00	1	1.5	9.5	14.4	17.2	746,863.0	0.00	1.00
07/07/2024 07:00	1	1.5	9.5	14.5	17.9	759,816.6	0.00	1.00
07/07/2024 08:00	0	1.5	8.3	14.5	13.6	758,104.8	0.00	1.00
07/07/2024 09:00	0	1.3	6.9	14.5	10.6	757,890.8	0.00	1.00
07/07/2024 10:00	0	1.3	6.7	14.6	10.8	770,790.3	0.00	1.00
07/07/2024 11:00	0	1.3	6.2	14.6	10.1	773,833.5	0.00	1.00
07/07/2024 12:00	0	1.4	7.7	14.5	13.4	802,183.1	0.00	1.00
07/07/2024 13:00	0	1.4	7.4	14.5	12.5	796,405.9	0.00	1.00
07/07/2024 14:00	0	1.4	7.0	14.5	12.9	857,816.0	0.00	1.00
07/07/2024 15:00	0	1.5	7.7	14.4	14.5	805,432.2	0.00	1.00
07/07/2024 16:00	1	2.2	11.8	12.2	28.4	933,097.4	0.00	1.00
07/07/2024 17:00	1	2.3	12.3	12.0	30.7	932,439.5	0.00	1.00
07/07/2024 18:00	1	2.2	12.4	12.1	31.4	943,813.5	0.00	1.00
07/07/2024 19:00	1	2.2	12.5	12.2	30.7	948,995.4	0.00	1.00
07/07/2024 20:00	1	2.2	12.7	12.3	29.8	949,998.4	0.00	1.00
07/07/2024 21:00	1	1.6	8.8	13.8	18.8	859,072.7	0.00	1.00
07/07/2024 22:00	1	1.5	9.4	14.4	18.2	746,230.9	0.00	1.00
07/07/2024 23:00	1	1.5	9.4	14.4	17.5	746,020.3	0.00	1.00
Average/Sum#:	1	1.6	9.2	14.0	18.3	808,574.9	0.00 #	24.00 #
Minimum:	0	1.3	6.2	12.0	10.1	744,545.5	0.00	1.00
Maximum:	1	2.3	12.7	14.6	31.4	949,998.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2024 00:00	1	1.5	9.5	14.4	18.1	745,598.9	0.00	1.00
07/08/2024 01:00	1	1.5	9.5	14.4	18.0	745,388.2	0.00	1.00
07/08/2024 02:00	1	1.6	10.0	14.4	17.0	745,177.5	0.00	1.00
07/08/2024 03:00	1	1.6	9.8	14.4	17.4	744,966.9	0.00	1.00
07/08/2024 04:00	1	1.5	9.7	14.4	18.4	744,966.9	0.00	1.00
07/08/2024 05:00	1	1.5	9.7	14.4	18.5	745,388.2	0.00	1.00
07/08/2024 06:00	1	1.5	9.6	14.4	18.3	746,230.9	0.00	1.00
07/08/2024 07:00	1	1.5	9.5	14.4	18.1	748,337.8	0.00	1.00
07/08/2024 08:00	1	1.5	9.5	14.4	17.6	747,073.7	0.00	1.00
07/08/2024 09:00	1	1.5	9.5	14.5	17.6	758,532.7	0.00	1.00
07/08/2024 10:00	0	1.4	7.6	14.5	11.6	758,532.7	0.00	1.00
07/08/2024 11:00	0	1.5	6.7	14.5	9.6	761,100.4	0.00	1.00
07/08/2024 12:00	1	1.5	8.3	14.4	15.3	759,925.2	0.00	1.00
07/08/2024 13:00	0	1.5	8.3	14.4	14.7	779,307.8	0.00	1.00
07/08/2024 14:00	0	1.4	6.5	14.6	12.1	940,338.1	0.00	1.00
07/08/2024 15:00	0	1.5	7.8	14.5	15.1	846,475.4	0.00	1.00
07/08/2024 16:00	1	1.7	9.1	13.8	19.6	904,398.7	0.00	1.00
07/08/2024 17:00	1	2.3	12.7	12.0	32.1	950,288.2	0.00	1.00
07/08/2024 18:00	2	2.3	12.6	11.9	33.5	948,402.5	0.00	1.00
07/08/2024 19:00	1	2.2	12.8	12.2	30.9	948,680.5	0.00	1.00
07/08/2024 20:00	1	2.2	12.7	12.3	30.1	952,705.4	0.00	1.00
07/08/2024 21:00	1	2.1	12.2	12.6	28.5	961,566.9	0.00	1.00
07/08/2024 22:00	1	2.1	12.1	12.7	28.2	969,953.3	0.00	1.00
07/08/2024 23:00	1	2.0	10.8	13.1	24.9	968,955.5	0.00	1.00
Average/Sum#:	1	1.7	9.9	13.8	20.2	830,095.5	0.00 #	24.00 #
Minimum:	0	1.4	6.5	11.9	9.6	744,966.9	0.00	1.00
Maximum:	2	2.3	12.8	14.6	33.5	969,953.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/09/2024 00:00	1	1.6	8.7	14.0	20.5	876,233.1	0.00	1.00
07/09/2024 01:00	1	1.5	9.9	14.4	20.3	746,863.0	0.00	1.00
07/09/2024 02:00	1	1.5	10.5	14.4	18.8	746,652.3	0.00	1.00
07/09/2024 03:00	1	1.5	10.3	14.4	21.1	747,073.7	0.00	1.00
07/09/2024 04:00	1	1.5	9.8	14.4	18.1	751,708.6	0.00	1.00
07/09/2024 05:00	1	1.5	9.9	14.3	19.8	735,546.9	0.00	1.00
07/09/2024 06:00	1	1.5	9.7	14.3	18.2	736,584.3	0.00	1.00
07/09/2024 07:00	1	1.5	9.6	14.4	17.7	749,391.2	0.00	1.00
07/09/2024 08:00	1	1.5	9.4	14.4	16.9	747,705.7	0.00	1.00
07/09/2024 09:00	1	1.5	9.4	14.4	17.5	746,441.6	0.00	1.00
07/09/2024 10:00	1	1.5	9.3	14.4	18.0	746,441.6	0.00	1.00
07/09/2024 11:00	1	1.5	9.2	14.5	16.7	760,886.4	0.00	1.00
07/09/2024 12:00	0	1.4	7.6	14.5	12.4	771,157.1	0.00	1.00
07/09/2024 13:00	0	1.5	7.1	14.5	14.0	940,195.4	0.00	1.00
07/09/2024 14:00	0	1.5	7.2	14.5	14.4	908,955.4	0.00	1.00
07/09/2024 15:00	0	1.5	8.0	14.3	15.8	872,489.3	0.00	1.00
07/09/2024 16:00	1	2.2	12.5	12.4	29.9	962,624.8	0.00	1.00
07/09/2024 17:00	1	2.2	12.8	12.2	31.2	956,393.4	0.00	1.00
07/09/2024 18:00	2	2.3	12.8	12.0	34.0	962,289.9	0.00	1.00
07/09/2024 19:00	1	2.2	13.1	12.3	31.9	965,762.7	0.00	1.00
07/09/2024 20:00	1	2.1	12.8	12.5	30.2	967,726.6	0.00	1.00
07/09/2024 21:00	1	2.1	12.8	12.5	30.0	965,770.2	0.00	1.00
07/09/2024 22:00	1	2.1	12.5	12.6	28.7	965,526.7	0.00	1.00
07/09/2024 23:00	1	1.7	8.7	13.8	20.4	940,080.9	0.00	1.00
Average/Sum#:	1	1.7	10.2	13.8	21.5	844,604.2	0.00 #	24.00 #
Minimum:	0	1.4	7.1	12.0	12.4	735,546.9	0.00	1.00
Maximum:	2	2.3	13.1	14.5	34.0	967,726.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2024 00:00	0	1.5	6.9	14.5	14.4	929,924.7	0.00	1.00
07/10/2024 01:00	0	1.5	7.0	14.5	15.2	919,226.1	0.00	1.00
07/10/2024 02:00	0	1.4	7.3	14.5	16.2	936,557.9	0.00	1.00
07/10/2024 03:00	0	1.5	7.3	14.5	15.1	913,876.8	0.00	1.00
07/10/2024 04:00	0	1.4	7.1	14.5	15.3	939,981.5	0.00	1.00
07/10/2024 05:00	1	1.5	8.3	14.4	18.3	857,681.0	0.00	1.00
07/10/2024 06:00	1	1.5	9.9	14.3	19.8	740,941.6	0.00	1.00
07/10/2024 07:00	1	1.5	9.7	14.3	17.9	742,809.0	0.00	1.00
07/10/2024 08:00	1	1.5	9.6	14.3	17.7	740,941.6	0.00	1.00
07/10/2024 09:00	1	1.5	9.4	14.5	17.3	760,672.5	0.00	1.00
07/10/2024 10:00	0	1.4	8.1	14.5	14.0	760,672.5	0.00	1.00
07/10/2024 11:00	0	1.3	6.8	14.5	11.0	763,240.1	0.00	1.00
07/10/2024 12:00	0	1.4	6.5	14.6	9.5	775,355.0	0.00	1.00
07/10/2024 13:00	0	1.3	6.5	14.6	11.3	854,042.6	0.00	1.00
07/10/2024 14:00	0	1.4	7.0	14.6	13.7	907,732.7	0.00	1.00
07/10/2024 15:00	0	1.4	6.9	14.5	12.2	832,995.2	0.00	1.00
07/10/2024 16:00	0	1.3	7.3	14.5	14.1	840,698.2	0.00	1.00
07/10/2024 17:00	1	2.1	11.8	12.6	27.4	951,667.5	0.00	1.00
07/10/2024 18:00	2	2.3	12.8	11.9	32.8	939,577.3	0.00	1.00
07/10/2024 19:00	1	2.3	12.8	12.0	32.4	944,441.2	0.00	1.00
07/10/2024 20:00	1	2.1	12.5	12.4	29.2	949,413.9	0.00	1.00
07/10/2024 21:00	1	1.9	10.8	13.1	24.2	954,032.3	0.00	1.00
07/10/2024 22:00	1	1.7	8.5	13.7	19.4	918,465.3	0.00	1.00
07/10/2024 23:00	0	1.5	7.8	14.4	14.5	834,716.8	0.00	1.00
Average/Sum#:	1	1.6	8.7	14.0	18.0	862,902.6	0.00 #	24.00 #
Minimum:	0	1.3	6.5	11.9	9.5	740,941.6	0.00	1.00
Maximum:	2	2.3	12.8	14.6	32.8	954,032.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2024 00:00	1	1.5	8.8	14.3	15.6	738,866.7	0.00	1.00
07/11/2024 01:00	1	1.5	9.0	14.3	16.3	736,791.8	0.00	1.00
07/11/2024 02:00	1	1.6	9.4	14.3	15.5	736,584.3	0.00	1.00
07/11/2024 03:00	0	1.5	9.4	14.3	17.6	736,999.3	0.00	1.00
07/11/2024 04:00	1	1.6	9.3	14.3	16.0	736,999.3	0.00	1.00
07/11/2024 05:00	1	1.5	9.3	14.3	17.2	737,206.8	0.00	1.00
07/11/2024 06:00	1	1.5	9.4	14.3	17.3	738,451.7	0.00	1.00
07/11/2024 07:00	1	1.5	9.1	14.3	16.1	742,186.5	0.00	1.00
07/11/2024 08:00	1	1.5	9.1	14.3	16.5	740,941.6	0.00	1.00
07/11/2024 09:00	1	1.4	9.1	14.4	16.5	751,919.3	0.00	1.00
07/11/2024 10:00	1	1.5	8.9	14.4	16.0	752,551.4	0.00	1.00
07/11/2024 11:00	0	1.4	6.3	14.6	7.8	775,355.0	0.00	1.00
07/11/2024 12:00	0	1.4	7.2	14.5	13.0	816,519.3	0.00	1.00
07/11/2024 13:00	0	1.4	6.8	14.6	13.9	936,860.2	0.00	1.00
07/11/2024 14:00	1	2.1	11.9	12.5	28.2	946,533.1	0.00	1.00
07/11/2024 15:00	2	2.3	13.3	12.1	34.5	954,239.8	0.00	1.00
07/11/2024 16:00	2	2.2	13.5	12.2	34.9	960,958.1	0.00	1.00
07/11/2024 17:00	2	2.2	13.3	12.1	34.8	955,173.5	0.00	1.00
07/11/2024 18:00	2	2.3	13.2	12.1	34.5	954,084.2	0.00	1.00
07/11/2024 19:00	2	2.2	13.1	12.1	34.2	950,971.9	0.00	1.00
07/11/2024 20:00	1	2.2	13.1	12.1	33.4	948,482.0	0.00	1.00
07/11/2024 21:00	1	2.2	13.0	12.1	32.7	946,147.8	0.00	1.00
07/11/2024 22:00	1	1.8	10.4	13.2	23.0	922,494.1	0.00	1.00
07/11/2024 23:00	0	1.4	7.4	14.5	15.6	916,016.5	0.00	1.00
Average/Sum#:	1	1.7	10.1	13.6	21.7	838,888.9	0.00 #	24.00 #
Minimum:	0	1.4	6.3	12.1	7.8	736,584.3	0.00	1.00
Maximum:	2	2.3	13.5	14.6	34.9	960,958.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2024 00:00	1	1.5	8.5	14.4	15.5	782,046.7	0.00	1.00
07/12/2024 01:00	1	1.5	9.0	14.3	16.6	737,206.8	0.00	1.00
07/12/2024 02:00	1	1.7	9.6	14.3	15.7	736,584.3	0.00	1.00
07/12/2024 03:00	1	1.5	9.4	14.3	16.4	736,791.8	0.00	1.00
07/12/2024 04:00	1	1.5	9.5	14.3	17.6	737,414.3	0.00	1.00
07/12/2024 05:00	1	1.6	9.4	14.3	16.6	738,866.7	0.00	1.00
07/12/2024 06:00	0	1.5	8.7	14.4	15.2	788,367.1	0.00	1.00
07/12/2024 07:00	1	1.5	9.2	14.3	17.4	741,564.1	0.00	1.00
07/12/2024 08:00	0	1.5	9.1	14.4	15.9	750,865.9	0.00	1.00
07/12/2024 09:00	1	1.5	9.1	14.4	17.0	750,444.6	0.00	1.00
07/12/2024 10:00	1	1.5	9.1	14.4	17.2	751,498.0	0.00	1.00
07/12/2024 11:00	0	1.4	7.3	14.5	11.8	847,545.3	0.00	1.00
07/12/2024 12:00	0	1.4	6.4	14.6	12.4	936,642.8	0.00	1.00
07/12/2024 13:00	0	1.4	6.6	14.6	13.5	935,773.3	0.00	1.00
07/12/2024 14:00	1	1.5	8.6	13.9	18.5	897,559.9	0.00	1.00
07/12/2024 15:00	1	1.7	9.9	13.4	22.5	943,076.9	0.00	1.00
07/12/2024 16:00	1	1.9	11.0	13.0	25.3	940,395.9	0.00	1.00
07/12/2024 17:00	2	2.3	13.1	11.9	34.1	934,403.9	0.00	1.00
07/12/2024 18:00	2	2.3	13.0	11.9	34.3	932,730.2	0.00	1.00
07/12/2024 19:00	1	2.1	12.6	12.4	30.4	940,714.0	0.00	1.00
07/12/2024 20:00	1	2.1	11.9	12.7	27.7	952,251.0	0.00	1.00
07/12/2024 21:00	0	1.4	7.8	14.2	16.1	870,708.6	0.00	1.00
07/12/2024 22:00	0	1.5	6.7	14.5	12.7	906,601.7	0.00	1.00
07/12/2024 23:00	1	1.5	8.4	14.4	15.9	767,088.3	0.00	1.00
Average/Sum#:	1	1.6	9.3	13.9	19.0	835,714.3	0.00 #	24.00 #
Minimum:	0	1.4	6.4	11.9	11.8	736,584.3	0.00	1.00
Maximum:	2	2.3	13.1	14.6	34.3	952,251.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2024 00:00	1	1.5	9.3	14.3	16.8	733,472.0	0.00	1.00
07/13/2024 01:00	1	1.5	9.5	14.4	18.3	740,331.9	0.00	1.00
07/13/2024 02:00	1	1.5	9.7	14.5	18.1	764,524.0	0.00	1.00
07/13/2024 03:00	1	1.5	9.6	14.5	18.5	779,716.0	0.00	1.00
07/13/2024 04:00	1	1.5	9.8	14.5	18.8	749,759.9	0.00	1.00
07/13/2024 05:00	1	1.5	9.7	14.5	18.2	749,759.9	0.00	1.00
07/13/2024 06:00	1	1.5	9.7	14.5	18.9	750,187.8	0.00	1.00
07/13/2024 07:00	1	1.5	9.7	14.5	18.5	751,685.6	0.00	1.00
07/13/2024 08:00	1	1.6	10.4	13.8	22.7	782,307.8	0.00	1.00
07/13/2024 09:00	1	1.4	8.7	14.4	17.7	793,844.8	0.00	1.00
07/13/2024 10:00	1	1.5	9.6	14.5	19.1	760,458.5	0.00	1.00
07/13/2024 11:00	1	1.5	9.3	14.5	17.4	758,960.7	0.00	1.00
07/13/2024 12:00	0	1.4	7.0	14.6	11.3	775,137.7	0.00	1.00
07/13/2024 13:00	0	1.4	7.0	14.6	11.2	776,441.9	0.00	1.00
07/13/2024 14:00	0	1.3	6.8	14.6	10.3	778,832.9	0.00	1.00
07/13/2024 15:00	0	1.4	6.6	14.6	10.5	782,093.5	0.00	1.00
07/13/2024 16:00	0	1.4	6.6	14.5	10.7	782,283.7	0.00	1.00
07/13/2024 17:00	0	1.5	6.7	14.5	11.1	818,873.0	0.00	1.00
07/13/2024 18:00	0	1.4	7.6	14.5	16.2	899,968.6	0.00	1.00
07/13/2024 19:00	1	1.5	9.5	14.4	18.2	761,189.3	0.00	1.00
07/13/2024 20:00	0	1.5	8.7	14.4	15.8	787,103.0	0.00	1.00
07/13/2024 21:00	1	1.5	9.3	14.4	17.3	763,717.4	0.00	1.00
07/13/2024 22:00	1	1.6	9.8	14.4	18.5	758,871.8	0.00	1.00
07/13/2024 23:00	1	1.5	10.1	14.5	19.8	766,449.7	0.00	1.00
Average/Sum#:	1	1.5	8.8	14.5	16.4	773,582.1	0.00 #	24.00 #
Minimum:	0	1.3	6.6	13.8	10.3	733,472.0	0.00	1.00
Maximum:	1	1.6	10.4	14.6	22.7	899,968.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2024 00:00	1	1.5	10.3	14.5	20.4	765,165.9	0.00	1.00
07/14/2024 01:00	1	1.5	10.2	14.5	19.4	762,170.3	0.00	1.00
07/14/2024 02:00	1	1.6	10.5	14.4	18.9	748,127.1	0.00	1.00
07/14/2024 03:00	1	1.5	10.3	14.4	20.7	744,756.2	0.00	1.00
07/14/2024 04:00	1	1.5	10.2	14.4	19.9	744,545.5	0.00	1.00
07/14/2024 05:00	1	1.5	10.2	14.4	19.3	744,966.9	0.00	1.00
07/14/2024 06:00	1	1.5	10.2	14.4	19.3	745,598.9	0.00	1.00
07/14/2024 07:00	1	1.6	10.2	14.4	19.5	745,598.9	0.00	1.00
07/14/2024 08:00	1	1.6	10.2	14.4	20.1	746,230.9	0.00	1.00
07/14/2024 09:00	1	1.5	10.1	14.4	19.5	747,073.7	0.00	1.00
07/14/2024 10:00	1	1.5	9.9	14.4	19.4	747,073.7	0.00	1.00
07/14/2024 11:00	1	1.5	9.8	14.5	18.5	758,746.7	0.00	1.00
07/14/2024 12:00	0	1.4	8.1	14.5	13.8	760,886.4	0.00	1.00
07/14/2024 13:00	0	1.4	7.3	14.5	10.9	758,318.8	0.00	1.00
07/14/2024 14:00	0	1.4	7.0	14.6	11.9	810,134.1	0.00	1.00
07/14/2024 15:00	0	1.4	7.8	14.5	14.3	775,222.6	0.00	1.00
07/14/2024 16:00	0	1.5	8.4	14.5	14.9	768,375.5	0.00	1.00
07/14/2024 17:00	0	1.4	8.1	14.5	15.0	783,995.5	0.00	1.00
07/14/2024 18:00	0	1.4	7.9	14.5	15.1	822,724.5	0.00	1.00
07/14/2024 19:00	0	1.4	8.5	14.4	15.9	803,746.8	0.00	1.00
07/14/2024 20:00	0	1.5	8.5	14.4	15.6	800,797.2	0.00	1.00
07/14/2024 21:00	1	1.5	8.4	14.4	16.3	837,666.4	0.00	1.00
07/14/2024 22:00	1	1.5	9.8	14.3	19.0	735,131.9	0.00	1.00
07/14/2024 23:00	1	1.5	9.8	14.4	17.3	744,756.2	0.00	1.00
Average/Sum#:	1	1.5	9.2	14.4	17.3	766,742.1	0.00 #	24.00 #
Minimum:	0	1.4	7.0	14.3	10.9	735,131.9	0.00	1.00
Maximum:	1	1.6	10.5	14.6	20.7	837,666.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2024 00:00	1	1.5	9.9	14.4	19.1	745,177.5	0.00	1.00
07/15/2024 01:00	1	1.5	10.0	14.4	18.8	744,966.9	0.00	1.00
07/15/2024 02:00	1	1.5	10.8	14.4	19.8	744,756.2	0.00	1.00
07/15/2024 03:00	1	1.5	10.0	14.5	19.0	803,680.9	0.00	1.00
07/15/2024 04:00	1	1.6	10.6	14.4	19.6	744,966.9	0.00	1.00
07/15/2024 05:00	1	1.5	10.5	14.4	19.9	744,966.9	0.00	1.00
07/15/2024 06:00	1	1.5	10.5	14.4	19.2	745,598.9	0.00	1.00
07/15/2024 07:00	1	1.6	10.5	14.4	19.1	747,284.4	0.00	1.00
07/15/2024 08:00	1	1.6	10.4	14.4	18.9	746,863.0	0.00	1.00
07/15/2024 09:00	1	1.6	10.2	14.4	18.3	747,284.4	0.00	1.00
07/15/2024 10:00	1	1.5	10.0	14.5	19.2	760,030.5	0.00	1.00
07/15/2024 11:00	1	1.5	10.0	14.5	18.3	762,598.2	0.00	1.00
07/15/2024 12:00	0	1.4	9.5	14.5	16.4	763,454.1	0.00	1.00
07/15/2024 13:00	0	1.4	7.5	14.5	10.0	764,524.0	0.00	1.00
07/15/2024 14:00	0	1.4	7.6	14.5	12.1	764,096.0	0.00	1.00
07/15/2024 15:00	0	1.4	7.5	14.6	12.0	792,527.2	0.00	1.00
07/15/2024 16:00	0	1.4	8.2	14.5	13.0	765,379.8	0.00	1.00
07/15/2024 17:00	0	1.4	7.7	14.5	12.4	766,449.7	0.00	1.00
07/15/2024 18:00	0	1.4	8.8	14.5	14.8	763,026.1	0.00	1.00
07/15/2024 19:00	1	1.6	10.2	14.3	17.7	741,564.1	0.00	1.00
07/15/2024 20:00	1	1.5	10.4	14.4	19.0	749,601.8	0.00	1.00
07/15/2024 21:00	1	1.5	10.5	14.4	19.7	747,916.4	0.00	1.00
07/15/2024 22:00	1	1.5	10.7	14.4	19.5	747,073.7	0.00	1.00
07/15/2024 23:00	1	1.5	10.8	14.4	20.0	746,652.3	0.00	1.00
Average/Sum#:	1	1.5	9.7	14.4	17.3	756,268.3	0.00 #	24.00 #
Minimum:	0	1.4	7.5	14.3	10.0	741,564.1	0.00	1.00
Maximum:	1	1.6	10.8	14.6	20.0	803,680.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2024 00:00	1	1.5	10.9	14.4	19.4	746,230.9	0.00	1.00
07/16/2024 01:00	1	1.6	11.1	14.4	19.9	745,809.6	0.00	1.00
07/16/2024 02:00	1	1.6	11.5	14.4	19.5	745,809.6	0.00	1.00
07/16/2024 03:00	1	1.6	11.4	14.3	21.5	734,509.4	0.00	1.00
07/16/2024 04:00	0	1.5	10.1	14.4	17.5	799,322.5	0.00	1.00
07/16/2024 05:00	1	1.5	9.6	14.5	20.3	873,222.0	0.00	1.00
07/16/2024 06:00	1	1.6	11.2	14.4	21.3	747,495.0	0.00	1.00
07/16/2024 07:00	1	1.6	11.1	14.4	20.6	749,391.2	0.00	1.00
07/16/2024 08:00	1	1.5	11.0	14.4	20.6	747,705.7	0.00	1.00
07/16/2024 09:00	1	1.5	10.9	14.4	20.4	747,073.7	0.00	1.00
07/16/2024 10:00	1	1.6	10.6	14.4	19.2	746,652.3	0.00	1.00
07/16/2024 11:00	1	1.5	10.5	14.5	17.0	760,886.4	0.00	1.00
07/16/2024 12:00	0	0.0	10.5	0.0	20.5	233,195.3	0.00	1.00
07/16/2024 13:00	0	0.0	10.6	0.0	24.1	233,064.2	0.00	1.00
07/16/2024 14:00	0	0.3	8.4	14.6	28.3	804,047.7	0.00	1.00
07/16/2024 15:00	0	1.4	8.4	14.5	10.2	905,103.9	0.00	1.00
07/16/2024 16:00	0	1.4	9.7	14.5	17.0	758,960.7	0.00	1.00
07/16/2024 17:00	0	1.6	8.9	14.3	17.3	903,612.6	0.00	1.00
07/16/2024 18:00	1	1.8	11.0	13.6	23.6	981,295.7	0.00	1.00
07/16/2024 19:00	1	1.7	9.8	13.8	23.4	974,605.8	0.00	1.00
07/16/2024 20:00	1	1.7	10.6	13.6	24.2	973,416.9	0.00	1.00
07/16/2024 21:00	0	1.6	8.8	14.3	18.7	940,960.5	0.00	1.00
07/16/2024 22:00	1	1.5	9.8	14.4	20.5	812,174.0	0.00	1.00
07/16/2024 23:00	1	1.6	11.2	14.4	20.9	746,863.0	0.00	1.00
Average/Sum#:	1	1.5	10.3	14.3	20.2	815,688.6	0.00 #	24.00 #
Minimum:	0	0.3	8.4	13.6	10.2	734,509.4	0.00	1.00
Maximum:	1	1.8	11.5	14.6	28.3	981,295.7	0.00	1.00
%SI	8.33	8.33	0.00	8.33	0.00	8.33	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2024 00:00	1	1.5	11.3	14.3	21.0	735,754.4	0.00	1.00
07/17/2024 01:00	1	1.5	11.4	14.3	21.3	736,169.4	0.00	1.00
07/17/2024 02:00	1	1.5	11.9	14.3	21.6	735,961.9	0.00	1.00
07/17/2024 03:00	1	1.6	11.7	14.3	22.0	735,546.9	0.00	1.00
07/17/2024 04:00	1	1.6	11.4	14.3	19.9	739,281.7	0.00	1.00
07/17/2024 05:00	1	1.4	9.5	14.4	18.8	818,494.4	0.00	1.00
07/17/2024 06:00	1	1.5	11.2	14.3	21.5	736,584.3	0.00	1.00
07/17/2024 07:00	1	1.6	11.2	14.3	20.3	738,451.7	0.00	1.00
07/17/2024 08:00	1	1.6	11.3	14.3	20.1	736,791.8	0.00	1.00
07/17/2024 09:00	1	1.5	11.2	14.4	21.0	747,495.0	0.00	1.00
07/17/2024 10:00	1	1.5	11.2	14.4	20.1	747,705.7	0.00	1.00
07/17/2024 11:00	1	1.5	10.6	14.4	18.5	748,969.8	0.00	1.00
07/17/2024 12:00	0	1.6	10.4	14.5	18.1	761,100.4	0.00	1.00
07/17/2024 13:00	1	1.5	10.5	14.5	18.7	761,100.4	0.00	1.00
07/17/2024 14:00	0	1.4	9.7	14.6	16.2	772,311.9	0.00	1.00
07/17/2024 15:00	0	1.4	8.1	14.6	12.3	770,572.9	0.00	1.00
07/17/2024 16:00	0	1.3	8.1	14.6	12.9	770,355.6	0.00	1.00
07/17/2024 17:00	0	1.4	8.2	14.6	13.4	841,869.9	0.00	1.00
07/17/2024 18:00	0	1.3	9.1	14.5	17.6	840,698.2	0.00	1.00
07/17/2024 19:00	0	1.4	8.3	14.6	15.2	941,859.7	0.00	1.00
07/17/2024 20:00	0	1.5	8.2	14.5	16.6	952,391.9	0.00	1.00
07/17/2024 21:00	0	1.4	7.8	14.6	16.1	964,466.0	0.00	1.00
07/17/2024 22:00	0	1.5	9.1	14.4	16.5	841,458.6	0.00	1.00
07/17/2024 23:00	1	1.5	10.3	14.4	18.8	746,652.3	0.00	1.00
Average/Sum#:	1	1.5	10.1	14.4	18.3	788,418.5	0.00 #	24.00 #
Minimum:	0	1.3	7.8	14.3	12.3	735,546.9	0.00	1.00
Maximum:	1	1.6	11.9	14.6	22.0	964,466.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2024 00:00	1	1.5	10.4	14.4	18.2	745,388.2	0.00	1.00
07/18/2024 01:00	1	1.5	10.5	14.4	18.3	745,388.2	0.00	1.00
07/18/2024 02:00	1	1.6	11.1	14.4	18.5	745,388.2	0.00	1.00
07/18/2024 03:00	1	1.5	10.9	14.4	19.5	745,809.6	0.00	1.00
07/18/2024 04:00	0	1.5	9.5	14.4	15.8	782,678.7	0.00	1.00
07/18/2024 05:00	1	1.5	10.8	14.3	20.0	739,904.1	0.00	1.00
07/18/2024 06:00	1	1.6	10.7	14.4	18.5	747,916.4	0.00	1.00
07/18/2024 07:00	1	1.5	10.5	14.4	18.9	748,969.8	0.00	1.00
07/18/2024 08:00	1	1.5	10.4	14.4	17.9	747,073.7	0.00	1.00
07/18/2024 09:00	0	1.5	10.7	14.5	18.3	757,248.9	0.00	1.00
07/18/2024 10:00	0	1.5	10.2	14.5	16.7	757,676.8	0.00	1.00
07/18/2024 11:00	0	1.4	7.5	14.6	10.7	816,655.1	0.00	1.00
07/18/2024 12:00	0	1.3	7.6	14.5	13.6	845,191.6	0.00	1.00
07/18/2024 13:00	0	1.4	8.6	14.5	14.8	841,340.1	0.00	1.00
07/18/2024 14:00	0	1.3	7.7	14.6	15.5	932,730.2	0.00	1.00
07/18/2024 15:00	0	1.5	8.4	14.6	16.2	949,250.2	0.00	1.00
07/18/2024 16:00	1	1.5	8.8	14.3	20.5	927,681.3	0.00	1.00
07/18/2024 17:00	2	2.4	14.3	11.8	39.2	963,563.1	0.00	1.00
07/18/2024 18:00	2	2.3	14.2	11.7	39.1	957,852.8	0.00	1.00
07/18/2024 19:00	2	2.4	14.1	11.7	39.1	959,936.7	0.00	1.00
07/18/2024 20:00	2	2.3	14.1	11.8	39.3	968,378.7	0.00	1.00
07/18/2024 21:00	1	1.9	11.5	13.0	24.6	959,810.5	0.00	1.00
07/18/2024 22:00	1	1.8	10.5	13.3	23.6	965,624.4	0.00	1.00
07/18/2024 23:00	1	1.8	10.2	13.4	22.8	965,535.5	0.00	1.00
Average/Sum#:	1	1.7	10.6	13.8	21.7	846,541.4	0.00 #	24.00 #
Minimum:	0	1.3	7.5	11.7	10.7	739,904.1	0.00	1.00
Maximum:	2	2.4	14.3	14.6	39.3	968,378.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2024 00:00	1	1.8	10.0	13.5	23.5	973,216.6	0.00	1.00
07/19/2024 01:00	1	1.8	9.8	13.6	23.3	979,607.4	0.00	1.00
07/19/2024 02:00	1	1.7	10.3	13.6	24.0	973,792.1	0.00	1.00
07/19/2024 03:00	1	1.8	9.9	13.7	23.7	985,985.6	0.00	1.00
07/19/2024 04:00	1	1.8	9.9	13.6	24.6	975,292.8	0.00	1.00
07/19/2024 05:00	1	1.8	10.3	13.5	24.5	973,956.8	0.00	1.00
07/19/2024 06:00	1	1.7	9.4	13.7	23.6	978,948.2	0.00	1.00
07/19/2024 07:00	1	1.6	8.8	13.8	20.6	952,232.1	0.00	1.00
07/19/2024 08:00	1	1.5	9.6	14.4	18.9	770,037.9	0.00	1.00
07/19/2024 09:00	0	1.4	8.2	14.5	13.9	773,938.7	0.00	1.00
07/19/2024 10:00	0	1.4	7.6	14.6	11.4	781,224.0	0.00	1.00
07/19/2024 11:00	0	1.4	7.2	14.6	11.7	824,045.7	0.00	1.00
07/19/2024 12:00	1	1.9	11.2	13.2	25.0	959,842.0	0.00	1.00
07/19/2024 13:00	1	1.8	11.7	13.1	25.6	959,123.8	0.00	1.00
07/19/2024 14:00	1	2.2	13.5	12.3	33.4	952,546.1	0.00	1.00
07/19/2024 15:00	2	2.3	14.8	11.8	40.0	958,898.0	0.00	1.00
07/19/2024 16:00	2	2.3	14.8	11.7	40.2	950,708.0	0.00	1.00
07/19/2024 17:00	2	2.3	14.8	11.8	40.1	961,155.3	0.00	1.00
07/19/2024 18:00	2	2.3	14.8	11.7	39.9	951,749.9	0.00	1.00
07/19/2024 19:00	2	2.3	14.7	11.8	38.9	952,427.1	0.00	1.00
07/19/2024 20:00	1	2.1	13.8	12.6	29.6	964,041.8	0.00	1.00
07/19/2024 21:00	1	2.2	14.3	12.4	32.5	965,847.0	0.00	1.00
07/19/2024 22:00	1	2.2	14.5	12.2	33.3	958,754.5	0.00	1.00
07/19/2024 23:00	1	2.1	13.8	12.6	29.5	959,917.0	0.00	1.00
Average/Sum#:	1	1.9	11.6	13.1	27.2	934,887.0	0.00 #	24.00 #
Minimum:	0	1.4	7.2	11.7	11.4	770,037.9	0.00	1.00
Maximum:	2	2.3	14.8	14.6	40.2	985,985.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2024 00:00	1	1.9	12.3	13.1	26.0	972,642.4	0.00	1.00
07/20/2024 01:00	1	1.8	10.5	13.5	22.5	967,479.8	0.00	1.00
07/20/2024 02:00	0	1.8	0.0	13.5	24.3	973,771.8	0.00	1.00
07/20/2024 03:00	0	1.8	0.0	13.4	26.4	973,569.4	0.00	1.00
07/20/2024 04:00	0	1.8	0.0	13.6	23.3	981,483.3	0.00	1.00
07/20/2024 05:00	0	1.7	0.0	13.6	24.9	978,669.5	0.00	1.00
07/20/2024 06:00	0	1.7	0.0	13.7	23.2	970,769.7	0.00	1.00
07/20/2024 07:00	0	1.4	0.0	14.5	14.7	883,278.7	0.00	1.00
07/20/2024 08:00	0	1.5	0.0	14.4	16.6	767,299.0	0.00	1.00
07/20/2024 09:00	0	1.5	0.0	14.4	17.4	750,655.2	0.00	1.00
07/20/2024 10:00	0	1.5	0.0	14.4	17.0	751,287.3	0.00	1.00
07/20/2024 11:00	0	1.5	0.0	14.4	14.7	809,013.8	0.00	1.00
07/20/2024 12:00	0	1.4	0.0	14.5	15.7	861,881.5	0.00	1.00
07/20/2024 13:00	0	1.4	0.0	14.6	13.1	932,947.5	0.00	1.00
07/20/2024 14:00	0	1.5	0.0	14.4	15.9	918,778.4	0.00	1.00
07/20/2024 15:00	0	1.8	0.0	13.4	23.2	952,936.8	0.00	1.00
07/20/2024 16:00	0	1.8	0.0	13.3	21.9	938,776.5	0.00	1.00
07/20/2024 17:00	0	2.1	0.0	12.7	27.6	951,081.9	0.00	1.00
07/20/2024 18:00	0	2.2	0.0	12.3	31.2	955,730.8	0.00	1.00
07/20/2024 19:00	0	2.2	0.0	12.4	30.4	959,563.7	0.00	1.00
07/20/2024 20:00	0	2.1	0.0	12.4	29.9	955,052.7	0.00	1.00
07/20/2024 21:00	0	2.1	0.0	12.5	29.8	962,020.6	0.00	1.00
07/20/2024 22:00	0	2.1	0.0	12.6	29.5	969,156.5	0.00	1.00
07/20/2024 23:00	0	2.0	0.0	12.7	29.0	970,120.3	0.00	1.00
Average/Sum#:	1	1.8	11.4	13.5	22.8	921,165.3	0.00 #	24.00 #
Minimum:	1	1.4	10.5	12.3	13.1	750,655.2	0.00	1.00
Maximum:	1	2.2	12.3	14.6	31.2	981,483.3	0.00	1.00
%SI	91.67	0.00	91.67	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2024 00:00	0	1.6	0.0	14.0	20.5	896,278.3	0.00	1.00
07/21/2024 01:00	0	1.5	0.0	14.4	17.8	746,652.3	0.00	1.00
07/21/2024 02:00	0	1.4	0.0	14.4	19.3	746,441.6	0.00	1.00
07/21/2024 03:00	0	1.6	0.0	14.4	17.6	746,441.6	0.00	1.00
07/21/2024 04:00	0	1.6	0.0	14.4	18.2	746,230.9	0.00	1.00
07/21/2024 05:00	0	1.5	0.0	14.4	19.3	748,548.4	0.00	1.00
07/21/2024 06:00	0	0.0	0.0	0.0	15.6	232,802.1	0.00	1.00
07/21/2024 07:00	1	1.6	10.3	14.4	19.0	750,444.6	0.00	1.00
07/21/2024 08:00	1	1.5	9.8	14.4	18.8	748,759.1	0.00	1.00
07/21/2024 09:00	1	1.5	9.5	14.5	18.5	760,030.5	0.00	1.00
07/21/2024 10:00	1	1.5	9.3	14.5	18.7	760,030.5	0.00	1.00
07/21/2024 11:00	1	1.5	9.3	14.5	17.8	762,598.2	0.00	1.00
07/21/2024 12:00	0	1.4	8.0	14.5	14.4	762,598.2	0.00	1.00
07/21/2024 13:00	0	1.5	6.7	14.5	9.6	762,384.2	0.00	1.00
07/21/2024 14:00	0	1.4	6.6	14.6	11.3	774,050.8	0.00	1.00
07/21/2024 15:00	0	1.4	6.7	14.6	9.7	772,311.9	0.00	1.00
07/21/2024 16:00	0	1.3	6.8	14.6	12.9	772,311.9	0.00	1.00
07/21/2024 17:00	0	1.3	6.8	14.6	12.5	853,390.5	0.00	1.00
07/21/2024 18:00	0	1.4	6.6	14.6	14.2	931,860.7	0.00	1.00
07/21/2024 19:00	0	1.5	6.8	14.5	13.9	894,833.2	0.00	1.00
07/21/2024 20:00	0	1.5	7.0	14.6	14.2	920,557.5	0.00	1.00
07/21/2024 21:00	0	1.5	6.8	14.5	14.6	910,025.3	0.00	1.00
07/21/2024 22:00	1	1.5	8.2	14.4	15.8	798,690.4	0.00	1.00
07/21/2024 23:00	1	1.4	7.1	14.5	15.2	866,588.9	0.00	1.00
Average/Sum#:	0	1.5	7.8	14.5	15.8	801,393.9	0.00 #	24.00 #
Minimum:	0	1.3	6.6	14.0	9.6	746,230.9	0.00	1.00
Maximum:	1	1.6	10.3	14.6	20.5	931,860.7	0.00	1.00
%SI	29.17	4.17	29.17	4.17	0.00	4.17	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2024 00:00	1	1.5	8.3	14.4	16.1	810,699.2	0.00	1.00
07/22/2024 01:00	1	1.5	9.1	14.4	17.9	746,020.3	0.00	1.00
07/22/2024 02:00	0	1.8	7.7	14.6	12.4	922,513.8	0.00	1.00
07/22/2024 03:00	1	1.4	7.7	14.5	17.8	907,029.7	0.00	1.00
07/22/2024 04:00	0	1.5	7.1	14.5	15.4	939,767.5	0.00	1.00
07/22/2024 05:00	1	1.5	7.9	14.4	16.8	870,532.5	0.00	1.00
07/22/2024 06:00	1	1.5	9.4	14.4	18.3	748,548.4	0.00	1.00
07/22/2024 07:00	1	1.5	9.2	14.4	17.4	749,180.5	0.00	1.00
07/22/2024 08:00	1	1.5	9.0	14.4	17.2	747,495.0	0.00	1.00
07/22/2024 09:00	1	1.5	9.0	14.5	17.9	759,174.6	0.00	1.00
07/22/2024 10:00	0	1.4	7.0	14.5	10.4	758,746.7	0.00	1.00
07/22/2024 11:00	0	1.3	6.2	14.6	11.3	822,741.5	0.00	1.00
07/22/2024 12:00	0	1.5	6.3	14.6	12.1	927,295.9	0.00	1.00
07/22/2024 13:00	0	1.4	6.5	14.6	12.8	937,077.5	0.00	1.00
07/22/2024 14:00	0	1.4	6.7	14.6	14.8	936,425.4	0.00	1.00
07/22/2024 15:00	1	2.1	11.8	12.5	29.7	943,598.6	0.00	1.00
07/22/2024 16:00	2	2.2	12.8	12.1	33.9	947,392.7	0.00	1.00
07/22/2024 17:00	2	2.3	13.0	12.1	35.7	957,196.5	0.00	1.00
07/22/2024 18:00	2	2.2	12.9	12.2	33.8	953,087.9	0.00	1.00
07/22/2024 19:00	1	2.2	12.5	12.2	31.5	945,847.3	0.00	1.00
07/22/2024 20:00	1	2.0	10.7	12.9	24.3	946,101.1	0.00	1.00
07/22/2024 21:00	1	1.9	10.4	13.0	24.7	946,289.6	0.00	1.00
07/22/2024 22:00	1	1.6	7.6	14.0	16.6	903,224.7	0.00	1.00
07/22/2024 23:00	0	1.4	6.6	14.5	13.8	917,086.4	0.00	1.00
Average/Sum#:	1	1.7	9.0	13.9	19.7	876,794.7	0.00 #	24.00 #
Minimum:	0	1.3	6.2	12.1	10.4	746,020.3	0.00	1.00
Maximum:	2	2.3	13.0	14.6	35.7	957,196.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2024 00:00	0	1.4	7.0	14.5	14.5	888,842.0	0.00	1.00
07/23/2024 01:00	0	1.4	6.4	14.5	12.8	908,741.5	0.00	1.00
07/23/2024 02:00	0	1.6	7.1	14.5	12.1	879,855.2	0.00	1.00
07/23/2024 03:00	1	1.6	8.5	14.3	17.7	843,440.9	0.00	1.00
07/23/2024 04:00	1	2.0	12.4	12.7	29.5	968,784.3	0.00	1.00
07/23/2024 05:00	1	2.1	12.8	12.6	31.0	976,251.1	0.00	1.00
07/23/2024 06:00	1	2.1	12.5	12.6	30.1	969,321.5	0.00	1.00
07/23/2024 07:00	1	2.1	12.6	12.6	30.4	975,261.1	0.00	1.00
07/23/2024 08:00	1	2.1	12.7	12.5	30.6	966,911.4	0.00	1.00
07/23/2024 09:00	1	2.1	12.8	12.4	31.0	957,630.4	0.00	1.00
07/23/2024 10:00	1	2.1	13.0	12.4	32.1	959,241.5	0.00	1.00
07/23/2024 11:00	1	2.2	12.9	12.4	31.8	963,591.4	0.00	1.00
07/23/2024 12:00	2	2.3	12.6	12.1	32.8	952,528.0	0.00	1.00
07/23/2024 13:00	2	2.3	12.4	11.8	34.0	936,776.6	0.00	1.00
07/23/2024 14:00	2	2.3	12.5	11.8	34.9	934,218.3	0.00	1.00
07/23/2024 15:00	2	2.3	12.8	11.9	36.1	941,403.2	0.00	1.00
07/23/2024 16:00	2	2.3	12.9	11.9	36.1	939,577.3	0.00	1.00
07/23/2024 17:00	2	2.3	12.9	11.9	36.1	941,403.2	0.00	1.00
07/23/2024 18:00	2	2.3	12.9	12.0	35.9	949,365.0	0.00	1.00
07/23/2024 19:00	2	2.2	13.1	12.1	35.2	953,461.7	0.00	1.00
07/23/2024 20:00	1	2.2	13.2	12.2	33.9	961,430.4	0.00	1.00
07/23/2024 21:00	1	2.2	13.3	12.2	33.5	958,597.1	0.00	1.00
07/23/2024 22:00	1	2.2	13.3	12.2	33.0	956,865.6	0.00	1.00
07/23/2024 23:00	1	2.1	12.3	12.5	30.2	962,183.7	0.00	1.00
Average/Sum#:	1	2.1	11.9	12.6	29.8	943,570.1	0.00 #	24.00 #
Minimum:	0	1.4	6.4	11.8	12.1	843,440.9	0.00	1.00
Maximum:	2	2.3	13.3	14.5	36.1	976,251.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2024 00:00	1	1.7	8.7	13.6	20.8	953,156.9	0.00	1.00
07/24/2024 01:00	1	1.6	8.9	14.1	19.1	817,828.3	0.00	1.00
07/24/2024 02:00	1	1.5	9.6	14.4	18.3	751,076.6	0.00	1.00
07/24/2024 03:00	1	1.6	8.8	14.4	15.0	785,417.6	0.00	1.00
07/24/2024 04:00	1	1.8	10.1	13.6	23.2	937,399.1	0.00	1.00
07/24/2024 05:00	1	1.9	11.1	13.2	27.5	977,982.4	0.00	1.00
07/24/2024 06:00	1	1.5	8.6	14.3	19.5	899,047.9	0.00	1.00
07/24/2024 07:00	0	1.5	8.0	14.6	16.5	872,736.3	0.00	1.00
07/24/2024 08:00	0	1.4	7.5	14.6	13.0	791,223.0	0.00	1.00
07/24/2024 09:00	0	1.4	7.0	14.6	15.9	918,601.2	0.00	1.00
07/24/2024 10:00	0	1.5	7.5	14.4	15.9	910,140.5	0.00	1.00
07/24/2024 11:00	1	1.9	11.2	13.0	27.8	970,557.9	0.00	1.00
07/24/2024 12:00	1	2.2	13.2	12.3	33.8	972,609.8	0.00	1.00
07/24/2024 13:00	2	2.2	12.9	12.2	34.1	961,902.6	0.00	1.00
07/24/2024 14:00	2	2.3	12.6	12.0	35.1	952,596.2	0.00	1.00
07/24/2024 15:00	2	2.3	12.5	12.0	34.8	952,596.2	0.00	1.00
07/24/2024 16:00	2	2.3	12.5	12.0	34.2	948,441.8	0.00	1.00
07/24/2024 17:00	1	2.3	12.5	11.9	35.4	1,171,923.0	0.00	1.00
07/24/2024 18:00	1	2.3	12.6	12.0	35.3	1,204,170.3	0.00	1.00
07/24/2024 19:00	1	2.2	13.1	12.2	35.7	1,215,639.6	0.00	1.00
07/24/2024 20:00	1	2.2	13.7	12.2	35.9	1,078,697.2	0.00	1.00
07/24/2024 21:00	1	2.2	13.6	12.3	34.1	969,265.8	0.00	1.00
07/24/2024 22:00	1	1.8	10.3	13.5	24.8	973,586.7	0.00	1.00
07/24/2024 23:00	1	1.7	9.8	13.7	24.1	956,124.5	0.00	1.00
Average/Sum#:	1	1.9	10.7	13.2	26.2	955,946.7	0.00 #	24.00 #
Minimum:	0	1.4	7.0	11.9	13.0	751,076.6	0.00	1.00
Maximum:	2	2.3	13.7	14.6	35.9	1,215,639.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2024 00:00	0	1.5	7.4	14.7	15.9	918,618.7	0.00	1.00
07/25/2024 01:00	1	1.5	8.7	14.6	18.7	832,088.3	0.00	1.00
07/25/2024 02:00	1	1.6	10.0	14.5	18.2	758,318.8	0.00	1.00
07/25/2024 03:00	1	1.5	9.8	14.5	20.3	758,532.7	0.00	1.00
07/25/2024 04:00	1	1.4	8.2	14.6	16.3	828,175.7	0.00	1.00
07/25/2024 05:00	0	1.4	7.2	14.6	16.3	905,559.0	0.00	1.00
07/25/2024 06:00	1	1.4	8.8	14.5	18.8	803,894.9	0.00	1.00
07/25/2024 07:00	1	1.5	9.6	14.5	19.1	761,100.4	0.00	1.00
07/25/2024 08:00	1	1.5	9.5	14.5	18.4	759,602.6	0.00	1.00
07/25/2024 09:00	1	1.5	9.4	14.4	18.3	752,340.7	0.00	1.00
07/25/2024 10:00	1	1.6	9.4	14.4	17.5	754,026.1	0.00	1.00
07/25/2024 11:00	1	1.5	9.3	14.4	18.5	756,975.7	0.00	1.00
07/25/2024 12:00	0	1.4	7.6	14.5	15.6	865,519.0	0.00	1.00
07/25/2024 13:00	1	1.9	10.1	13.4	22.6	964,074.8	0.00	1.00
07/25/2024 14:00	1	2.0	12.2	12.8	30.0	978,377.6	0.00	1.00
07/25/2024 15:00	1	2.0	12.5	12.7	30.9	970,120.3	0.00	1.00
07/25/2024 16:00	1	2.1	12.3	12.7	30.2	972,625.3	0.00	1.00
07/25/2024 17:00	1	2.2	12.9	12.4	32.5	968,263.6	0.00	1.00
07/25/2024 18:00	1	2.2	13.1	12.2	33.4	963,476.6	0.00	1.00
07/25/2024 19:00	1	2.2	13.1	12.3	33.0	965,762.7	0.00	1.00
07/25/2024 20:00	1	2.2	13.2	12.4	32.7	971,163.6	0.00	1.00
07/25/2024 21:00	1	1.8	9.8	13.5	23.2	938,795.9	0.00	1.00
07/25/2024 22:00	1	1.5	7.8	14.5	16.8	867,444.8	0.00	1.00
07/25/2024 23:00	1	1.5	9.8	14.5	20.5	758,746.7	0.00	1.00
Average/Sum#:	1	1.7	10.1	13.8	22.4	865,566.9	0.00 #	24.00 #
Minimum:	0	1.4	7.2	12.2	15.6	752,340.7	0.00	1.00
Maximum:	1	2.2	13.2	14.7	33.4	978,377.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2024 00:00	1	1.5	9.8	14.5	19.8	757,462.9	0.00	1.00
07/26/2024 01:00	1	1.5	9.9	14.5	20.2	756,393.0	0.00	1.00
07/26/2024 02:00	1	1.6	10.4	14.5	19.7	755,537.1	0.00	1.00
07/26/2024 03:00	1	1.6	10.3	14.5	20.6	755,751.1	0.00	1.00
07/26/2024 04:00	1	1.5	10.2	14.4	20.3	744,124.1	0.00	1.00
07/26/2024 05:00	1	1.5	10.1	14.5	20.8	755,537.1	0.00	1.00
07/26/2024 06:00	1	1.5	10.0	14.5	19.8	756,820.9	0.00	1.00
07/26/2024 07:00	1	1.5	9.9	14.5	20.3	758,104.8	0.00	1.00
07/26/2024 08:00	1	1.5	9.8	14.5	20.1	755,751.1	0.00	1.00
07/26/2024 09:00	1	1.5	9.3	14.6	17.8	767,747.1	0.00	1.00
07/26/2024 10:00	0	1.4	7.9	14.6	13.9	768,616.6	0.00	1.00
07/26/2024 11:00	0	1.5	7.1	14.6	11.3	771,442.4	0.00	1.00
07/26/2024 12:00	0	1.4	6.7	14.6	10.8	774,485.6	0.00	1.00
07/26/2024 13:00	0	1.4	6.4	14.7	9.8	788,081.6	0.00	1.00
07/26/2024 14:00	0	1.4	6.6	14.6	11.0	776,224.5	0.00	1.00
07/26/2024 15:00	0	1.3	6.7	14.6	11.8	774,268.2	0.00	1.00
07/26/2024 16:00	0	1.4	7.0	14.6	11.8	773,833.5	0.00	1.00
07/26/2024 17:00	0	1.4	7.1	14.6	13.2	798,613.5	0.00	1.00
07/26/2024 18:00	1	1.5	7.8	14.3	17.6	923,324.0	0.00	1.00
07/26/2024 19:00	0	1.4	7.2	14.6	16.5	928,600.2	0.00	1.00
07/26/2024 20:00	1	1.5	8.4	14.4	17.9	831,767.3	0.00	1.00
07/26/2024 21:00	1	1.5	9.5	14.4	19.6	744,334.8	0.00	1.00
07/26/2024 22:00	1	1.5	9.6	14.4	19.2	745,388.2	0.00	1.00
07/26/2024 23:00	1	1.5	9.9	14.4	19.9	744,756.2	0.00	1.00
Average/Sum#:	1	1.5	8.7	14.5	16.8	779,456.9	0.00 #	24.00 #
Minimum:	0	1.3	6.4	14.3	9.8	744,124.1	0.00	1.00
Maximum:	1	1.6	10.4	14.7	20.8	928,600.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2024 00:00	1	1.5	10.0	14.3	19.5	733,887.0	0.00	1.00
07/27/2024 01:00	1	1.6	10.2	14.3	20.4	734,716.9	0.00	1.00
07/27/2024 02:00	1	1.6	10.7	14.3	20.7	734,716.9	0.00	1.00
07/27/2024 03:00	1	1.6	10.5	14.3	21.4	735,131.9	0.00	1.00
07/27/2024 04:00	1	1.5	10.4	14.3	20.9	735,546.9	0.00	1.00
07/27/2024 05:00	1	1.5	10.5	14.3	21.1	736,791.8	0.00	1.00
07/27/2024 06:00	1	1.6	10.5	14.3	20.8	737,206.8	0.00	1.00
07/27/2024 07:00	1	1.5	10.3	14.3	20.8	737,621.8	0.00	1.00
07/27/2024 08:00	1	1.5	10.4	14.3	21.1	737,829.3	0.00	1.00
07/27/2024 09:00	1	1.5	10.3	14.3	21.1	737,829.3	0.00	1.00
07/27/2024 10:00	1	1.5	10.2	14.4	20.6	748,759.1	0.00	1.00
07/27/2024 11:00	1	1.5	10.1	14.4	20.3	751,708.6	0.00	1.00
07/27/2024 12:00	1	1.5	9.9	14.4	21.3	751,919.3	0.00	1.00
07/27/2024 13:00	1	1.5	9.6	14.4	18.1	751,287.3	0.00	1.00
07/27/2024 14:00	1	1.4	9.5	14.4	19.0	750,444.6	0.00	1.00
07/27/2024 15:00	1	1.5	9.6	14.4	19.1	747,916.4	0.00	1.00
07/27/2024 16:00	1	1.5	9.6	14.4	18.8	748,548.4	0.00	1.00
07/27/2024 17:00	1	1.5	9.6	14.4	19.6	748,127.1	0.00	1.00
07/27/2024 18:00	1	1.5	9.6	14.4	19.1	747,495.0	0.00	1.00
07/27/2024 19:00	1	1.5	9.7	14.4	19.4	747,073.7	0.00	1.00
07/27/2024 20:00	1	1.5	9.7	14.4	19.2	746,652.3	0.00	1.00
07/27/2024 21:00	1	1.5	9.8	14.3	19.4	734,924.4	0.00	1.00
07/27/2024 22:00	1	1.5	10.0	14.3	20.7	735,339.4	0.00	1.00
07/27/2024 23:00	1	1.6	10.2	14.3	19.6	735,546.9	0.00	1.00
Average/Sum#:	1	1.5	10.0	14.3	20.1	741,959.2	0.00 #	24.00 #
Minimum:	1	1.4	9.5	14.3	18.1	733,887.0	0.00	1.00
Maximum:	1	1.6	10.7	14.4	21.4	751,919.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2024 00:00	1	1.6	10.1	14.3	20.6	735,961.9	0.00	1.00
07/28/2024 01:00	1	1.5	10.1	14.3	20.7	736,376.8	0.00	1.00
07/28/2024 02:00	1	1.6	10.6	14.3	19.2	735,961.9	0.00	1.00
07/28/2024 03:00	1	1.6	10.4	14.3	21.7	735,339.4	0.00	1.00
07/28/2024 04:00	1	1.5	10.3	14.3	20.8	735,961.9	0.00	1.00
07/28/2024 05:00	1	1.6	10.2	14.3	20.3	736,169.4	0.00	1.00
07/28/2024 06:00	1	1.6	10.2	14.3	18.8	737,414.3	0.00	1.00
07/28/2024 07:00	1	1.7	10.1	14.3	19.7	738,451.7	0.00	1.00
07/28/2024 08:00	1	1.6	10.1	14.3	19.7	737,829.3	0.00	1.00
07/28/2024 09:00	1	1.6	10.2	14.3	19.1	738,244.2	0.00	1.00
07/28/2024 10:00	1	1.6	10.2	14.4	19.8	749,180.5	0.00	1.00
07/28/2024 11:00	1	1.6	9.9	14.4	19.3	749,391.2	0.00	1.00
07/28/2024 12:00	1	1.6	9.6	14.4	17.4	749,601.8	0.00	1.00
07/28/2024 13:00	1	1.5	9.3	14.4	17.9	751,919.3	0.00	1.00
07/28/2024 14:00	1	1.6	9.3	14.3	15.8	742,186.5	0.00	1.00
07/28/2024 15:00	1	1.6	9.3	14.3	16.4	741,564.1	0.00	1.00
07/28/2024 16:00	1	1.7	9.4	14.3	16.4	740,941.6	0.00	1.00
07/28/2024 17:00	1	1.5	9.1	14.3	16.8	759,200.6	0.00	1.00
07/28/2024 18:00	0	1.5	8.1	14.5	14.4	760,672.5	0.00	1.00
07/28/2024 19:00	1	1.6	9.5	14.5	18.4	756,820.9	0.00	1.00
07/28/2024 20:00	1	1.6	9.4	14.4	17.8	746,441.6	0.00	1.00
07/28/2024 21:00	1	1.6	9.5	14.4	18.1	747,284.4	0.00	1.00
07/28/2024 22:00	1	1.6	9.7	14.4	17.9	747,916.4	0.00	1.00
07/28/2024 23:00	1	1.7	9.9	14.4	18.4	748,337.8	0.00	1.00
Average/Sum#:	1	1.6	9.8	14.4	18.6	744,132.1	0.00 #	24.00 #
Minimum:	0	1.5	8.1	14.3	14.4	735,339.4	0.00	1.00
Maximum:	1	1.7	10.6	14.5	21.7	760,672.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2024 00:00	1	1.6	9.9	14.3	19.3	737,414.3	0.00	1.00
07/29/2024 01:00	1	1.7	10.2	14.3	19.2	738,244.2	0.00	1.00
07/29/2024 02:00	1	1.5	10.5	14.3	20.2	738,659.2	0.00	1.00
07/29/2024 03:00	1	1.7	10.2	14.3	19.7	738,451.7	0.00	1.00
07/29/2024 04:00	1	1.6	10.2	14.3	19.3	738,659.2	0.00	1.00
07/29/2024 05:00	1	1.6	10.1	14.3	19.5	738,866.7	0.00	1.00
07/29/2024 06:00	1	1.6	10.0	14.3	19.6	739,904.1	0.00	1.00
07/29/2024 07:00	1	1.6	10.0	14.3	20.1	740,941.6	0.00	1.00
07/29/2024 08:00	1	1.6	10.0	14.3	18.4	738,659.2	0.00	1.00
07/29/2024 09:00	1	1.6	10.1	14.3	19.6	737,829.3	0.00	1.00
07/29/2024 10:00	1	1.6	10.0	14.4	19.1	749,391.2	0.00	1.00
07/29/2024 11:00	1	1.6	10.0	14.4	19.1	751,708.6	0.00	1.00
07/29/2024 12:00	1	1.6	9.5	14.4	17.9	750,444.6	0.00	1.00
07/29/2024 13:00	1	1.6	9.5	14.5	17.9	762,384.2	0.00	1.00
07/29/2024 14:00	1	1.6	9.5	14.5	18.2	761,528.3	0.00	1.00
07/29/2024 15:00	0	1.5	9.0	14.5	16.1	760,030.5	0.00	1.00
07/29/2024 16:00	0	1.5	7.1	14.6	11.2	802,526.2	0.00	1.00
07/29/2024 17:00	1	1.7	9.0	13.9	20.1	896,190.4	0.00	1.00
07/29/2024 18:00	1	2.1	11.5	13.0	26.1	972,811.3	0.00	1.00
07/29/2024 19:00	1	1.8	8.7	13.8	21.6	970,748.3	0.00	1.00
07/29/2024 20:00	1	1.8	8.5	13.8	21.3	966,312.1	0.00	1.00
07/29/2024 21:00	1	1.7	8.3	14.1	19.6	881,869.0	0.00	1.00
07/29/2024 22:00	1	1.6	9.6	14.4	19.7	746,230.9	0.00	1.00
07/29/2024 23:00	1	1.7	9.8	14.4	19.0	746,020.3	0.00	1.00
Average/Sum#:	1	1.6	9.6	14.2	19.2	787,742.7	0.00 #	24.00 #
Minimum:	0	1.5	7.1	13.0	11.2	737,414.3	0.00	1.00
Maximum:	1	2.1	11.5	14.6	26.1	972,811.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2024 00:00	1	1.7	9.8	14.3	19.1	734,924.4	0.00	1.00
07/30/2024 01:00	1	1.6	9.9	14.3	19.4	734,716.9	0.00	1.00
07/30/2024 02:00	1	1.6	10.3	14.3	20.3	734,716.9	0.00	1.00
07/30/2024 03:00	1	1.7	10.2	14.3	18.9	734,509.4	0.00	1.00
07/30/2024 04:00	1	1.7	10.1	14.3	18.4	735,131.9	0.00	1.00
07/30/2024 05:00	1	1.5	8.3	14.4	17.1	813,227.4	0.00	1.00
07/30/2024 06:00	1	1.6	9.9	14.3	18.8	736,169.4	0.00	1.00
07/30/2024 07:00	1	1.6	9.9	14.3	18.3	737,829.3	0.00	1.00
07/30/2024 08:00	1	1.5	9.9	14.4	19.4	746,863.0	0.00	1.00
07/30/2024 09:00	1	1.6	9.7	14.4	18.1	747,073.7	0.00	1.00
07/30/2024 10:00	1	1.7	9.4	14.4	17.5	746,230.9	0.00	1.00
07/30/2024 11:00	1	1.6	9.2	14.5	18.0	760,030.5	0.00	1.00
07/30/2024 12:00	1	1.5	8.5	14.5	16.0	764,524.0	0.00	1.00
07/30/2024 13:00	0	1.6	8.9	14.5	15.7	760,458.5	0.00	1.00
07/30/2024 14:00	0	1.5	7.2	14.5	11.2	759,388.6	0.00	1.00
07/30/2024 15:00	0	1.6	7.5	14.3	13.6	848,835.6	0.00	1.00
07/30/2024 16:00	1	2.0	11.0	13.1	24.9	968,955.5	0.00	1.00
07/30/2024 17:00	1	2.2	12.9	12.4	30.0	967,780.3	0.00	1.00
07/30/2024 18:00	1	2.3	13.2	12.3	30.7	964,011.1	0.00	1.00
07/30/2024 19:00	1	2.2	12.7	12.5	29.5	965,933.3	0.00	1.00
07/30/2024 20:00	1	2.1	12.0	12.8	28.1	970,769.7	0.00	1.00
07/30/2024 21:00	1	1.9	9.5	13.6	20.9	925,768.4	0.00	1.00
07/30/2024 22:00	1	1.6	9.1	14.4	18.3	748,127.1	0.00	1.00
07/30/2024 23:00	1	1.6	8.7	14.4	16.6	767,299.0	0.00	1.00
Average/Sum#:	1	1.7	9.9	14.0	20.0	807,219.8	0.00 #	24.00 #
Minimum:	0	1.5	7.2	12.3	11.2	734,509.4	0.00	1.00
Maximum:	1	2.3	13.2	14.5	30.7	970,769.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2024 00:00	1	1.6	9.3	14.4	17.6	743,070.7	0.00	1.00
07/31/2024 01:00	1	1.6	9.3	14.4	17.3	742,860.1	0.00	1.00
07/31/2024 02:00	1	1.5	9.9	14.3	18.4	732,434.6	0.00	1.00
07/31/2024 03:00	1	1.6	9.4	14.3	17.2	740,319.1	0.00	1.00
07/31/2024 04:00	0	1.5	7.7	14.5	15.4	858,671.9	0.00	1.00
07/31/2024 05:00	1	1.5	7.8	14.4	17.3	854,099.5	0.00	1.00
07/31/2024 06:00	1	1.5	9.8	14.3	19.7	735,546.9	0.00	1.00
07/31/2024 07:00	1	1.5	9.7	14.4	19.8	747,495.0	0.00	1.00
07/31/2024 08:00	1	1.5	9.6	14.4	18.7	745,598.9	0.00	1.00
07/31/2024 09:00	1	1.5	9.6	14.4	18.1	744,756.2	0.00	1.00
07/31/2024 10:00	1	1.5	9.3	14.5	17.9	755,323.1	0.00	1.00
07/31/2024 11:00	1	1.4	8.8	14.5	16.4	764,737.9	0.00	1.00
07/31/2024 12:00	0	1.4	6.6	14.6	10.1	800,352.5	0.00	1.00
07/31/2024 13:00	0	1.4	6.8	14.5	10.7	759,816.6	0.00	1.00
07/31/2024 14:00	0	1.4	7.8	14.5	14.2	797,047.8	0.00	1.00
07/31/2024 15:00	0	1.6	7.4	14.3	14.1	851,533.0	0.00	1.00
07/31/2024 16:00	1	2.0	11.4	12.8	26.7	957,075.5	0.00	1.00
07/31/2024 17:00	1	1.9	10.8	12.9	25.4	950,551.7	0.00	1.00
07/31/2024 18:00	1	2.0	12.4	12.5	30.2	961,857.6	0.00	1.00
07/31/2024 19:00	1	1.9	10.8	13.1	26.0	961,581.7	0.00	1.00
07/31/2024 20:00	1	2.1	12.5	12.6	30.4	965,361.7	0.00	1.00
07/31/2024 21:00	1	2.0	11.9	12.7	27.6	951,582.9	0.00	1.00
07/31/2024 22:00	1	2.0	10.9	13.0	26.2	962,757.3	0.00	1.00
07/31/2024 23:00	1	1.7	9.7	13.5	22.7	928,987.9	0.00	1.00
Average/Sum#:	1	1.7	9.6	13.9	19.9	833,892.5	0.00 #	24.00 #
Minimum:	0	1.4	6.6	12.5	10.1	732,434.6	0.00	1.00
Maximum:	1	2.1	12.5	14.6	30.4	965,361.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2024 00:00	0	1.4	7.1	14.5	15.2	877,501.5	0.00	1.00
08/01/2024 01:00	1	1.6	8.9	14.3	17.0	759,408.1	0.00	1.00
08/01/2024 02:00	1	1.5	9.9	14.3	18.8	738,866.7	0.00	1.00
08/01/2024 03:00	1	1.6	9.3	14.3	16.8	755,880.8	0.00	1.00
08/01/2024 04:00	1	1.4	8.3	14.4	16.7	799,533.2	0.00	1.00
08/01/2024 05:00	0	1.5	7.3	14.5	15.1	905,959.8	0.00	1.00
08/01/2024 06:00	1	1.4	9.2	14.4	19.3	762,874.7	0.00	1.00
08/01/2024 07:00	1	1.4	8.9	14.4	17.9	788,367.1	0.00	1.00
08/01/2024 08:00	1	1.5	9.4	14.5	19.3	775,864.5	0.00	1.00
08/01/2024 09:00	1	1.5	9.3	14.5	18.8	775,650.5	0.00	1.00
08/01/2024 10:00	0	1.4	7.3	14.5	11.6	776,720.4	0.00	1.00
08/01/2024 11:00	0	1.5	6.8	14.6	12.8	896,864.3	0.00	1.00
08/01/2024 12:00	0	1.4	7.7	14.5	15.6	846,475.4	0.00	1.00
08/01/2024 13:00	0	1.5	7.0	14.6	14.5	962,944.4	0.00	1.00
08/01/2024 14:00	1	1.4	7.9	14.5	18.1	916,872.4	0.00	1.00
08/01/2024 15:00	1	1.4	8.0	14.4	16.9	870,743.2	0.00	1.00
08/01/2024 16:00	1	2.1	13.0	12.5	31.3	971,639.2	0.00	1.00
08/01/2024 17:00	1	2.0	12.4	12.6	30.4	963,876.8	0.00	1.00
08/01/2024 18:00	1	2.0	13.2	12.4	33.0	968,585.8	0.00	1.00
08/01/2024 19:00	1	1.9	11.7	12.8	28.5	961,133.0	0.00	1.00
08/01/2024 20:00	1	2.0	12.9	12.5	31.6	974,247.6	0.00	1.00
08/01/2024 21:00	1	2.0	12.6	12.5	30.9	969,682.9	0.00	1.00
08/01/2024 22:00	1	1.9	11.5	12.9	27.4	971,264.2	0.00	1.00
08/01/2024 23:00	1	1.6	8.6	13.8	21.2	969,398.2	0.00	1.00
Average/Sum#:	1	1.6	9.5	13.9	20.8	873,348.1	0.00 #	24.00 #
Minimum:	0	1.4	6.8	12.4	11.6	738,866.7	0.00	1.00
Maximum:	1	2.1	13.2	14.6	33.0	974,247.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2024 00:00	0	1.3	6.9	14.4	14.9	877,906.4	0.00	1.00
08/02/2024 01:00	1	1.5	8.4	14.4	16.9	795,951.6	0.00	1.00
08/02/2024 02:00	1	1.5	9.6	14.3	17.9	739,904.1	0.00	1.00
08/02/2024 03:00	0	1.4	8.8	14.5	16.4	796,833.8	0.00	1.00
08/02/2024 04:00	0	1.4	7.1	14.6	15.4	927,295.9	0.00	1.00
08/02/2024 05:00	0	1.3	7.2	14.5	15.8	911,523.1	0.00	1.00
08/02/2024 06:00	0	1.4	7.0	14.5	15.0	905,531.9	0.00	1.00
08/02/2024 07:00	0	1.3	7.0	14.6	16.4	921,861.7	0.00	1.00
08/02/2024 08:00	0	1.4	7.0	14.5	15.4	922,007.8	0.00	1.00
08/02/2024 09:00	1	1.5	8.0	14.2	19.2	958,392.7	0.00	1.00
08/02/2024 10:00	1	2.0	12.7	12.4	31.1	969,874.7	0.00	1.00
08/02/2024 11:00	1	2.1	12.8	12.3	32.0	967,195.8	0.00	1.00
08/02/2024 12:00	1	2.1	12.8	12.3	32.2	965,921.9	0.00	1.00
08/02/2024 13:00	1	2.1	12.8	12.3	32.7	968,151.2	0.00	1.00
08/02/2024 14:00	1	2.1	12.5	12.4	30.8	962,624.8	0.00	1.00
08/02/2024 15:00	1	1.9	11.4	12.8	28.6	962,992.8	0.00	1.00
08/02/2024 16:00	1	1.6	8.9	13.6	21.4	961,223.4	0.00	1.00
08/02/2024 17:00	1	1.6	9.2	13.4	23.5	964,257.4	0.00	1.00
08/02/2024 18:00	1	1.9	11.0	13.0	27.5	966,744.3	0.00	1.00
08/02/2024 19:00	1	1.6	8.6	13.8	22.8	974,413.0	0.00	1.00
08/02/2024 20:00	1	1.6	8.5	13.8	22.2	974,027.2	0.00	1.00
08/02/2024 21:00	1	1.5	8.2	13.9	21.2	938,251.3	0.00	1.00
08/02/2024 22:00	0	1.4	6.6	14.5	13.9	908,527.5	0.00	1.00
08/02/2024 23:00	0	1.4	6.8	14.5	15.1	894,619.3	0.00	1.00
Average/Sum#:	1	1.6	9.2	13.7	21.6	922,334.7	0.00 #	24.00 #
Minimum:	0	1.3	6.6	12.3	13.9	739,904.1	0.00	1.00
Maximum:	1	2.1	12.8	14.6	32.7	974,413.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2024 00:00	0	1.4	7.1	14.4	14.5	840,194.5	0.00	1.00
08/03/2024 01:00	1	1.5	8.6	14.4	17.2	766,877.7	0.00	1.00
08/03/2024 02:00	1	1.3	9.9	14.4	20.0	746,863.0	0.00	1.00
08/03/2024 03:00	1	1.5	9.6	14.4	17.5	747,073.7	0.00	1.00
08/03/2024 04:00	1	1.5	9.6	14.4	18.7	746,441.6	0.00	1.00
08/03/2024 05:00	1	1.5	9.8	14.4	18.7	747,705.7	0.00	1.00
08/03/2024 06:00	1	1.5	9.7	14.4	18.6	747,916.4	0.00	1.00
08/03/2024 07:00	1	1.5	9.8	14.4	19.4	747,916.4	0.00	1.00
08/03/2024 08:00	1	1.5	9.7	14.4	19.2	747,073.7	0.00	1.00
08/03/2024 09:00	1	1.4	9.3	14.5	17.6	758,746.7	0.00	1.00
08/03/2024 10:00	0	1.5	7.0	14.5	9.3	758,104.8	0.00	1.00
08/03/2024 11:00	0	1.3	6.9	14.5	11.2	760,672.5	0.00	1.00
08/03/2024 12:00	0	1.4	6.6	14.6	9.9	774,050.8	0.00	1.00
08/03/2024 13:00	0	1.3	6.4	14.6	9.6	774,702.9	0.00	1.00
08/03/2024 14:00	0	1.4	6.3	14.6	9.8	774,485.6	0.00	1.00
08/03/2024 15:00	0	1.4	6.4	14.6	9.7	772,529.2	0.00	1.00
08/03/2024 16:00	0	1.3	6.4	14.6	9.7	771,877.1	0.00	1.00
08/03/2024 17:00	0	1.3	6.8	14.5	14.1	856,746.1	0.00	1.00
08/03/2024 18:00	1	2.1	12.7	12.4	30.8	957,791.5	0.00	1.00
08/03/2024 19:00	1	1.9	11.7	12.9	27.5	962,534.2	0.00	1.00
08/03/2024 20:00	1	1.6	8.5	13.9	17.8	883,670.0	0.00	1.00
08/03/2024 21:00	0	1.4	7.4	14.4	15.0	840,194.5	0.00	1.00
08/03/2024 22:00	0	1.4	7.2	14.6	14.7	895,560.1	0.00	1.00
08/03/2024 23:00	1	1.4	8.9	14.5	18.7	786,563.1	0.00	1.00
Average/Sum#:	1	1.5	8.4	14.3	16.2	798,595.5	0.00 #	24.00 #
Minimum:	0	1.3	6.3	12.4	9.3	746,441.6	0.00	1.00
Maximum:	1	2.1	12.7	14.6	30.8	962,534.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2024 00:00	1	1.5	9.6	14.5	18.7	757,248.9	0.00	1.00
08/04/2024 01:00	1	1.5	9.5	14.5	19.0	757,248.9	0.00	1.00
08/04/2024 02:00	1	1.5	9.8	14.4	18.6	746,441.6	0.00	1.00
08/04/2024 03:00	1	1.6	9.7	14.4	18.1	746,230.9	0.00	1.00
08/04/2024 04:00	1	1.5	9.6	14.4	18.6	746,230.9	0.00	1.00
08/04/2024 05:00	1	1.5	9.6	14.4	19.4	746,863.0	0.00	1.00
08/04/2024 06:00	1	1.5	9.6	14.4	18.2	749,180.5	0.00	1.00
08/04/2024 07:00	1	1.5	9.5	14.4	18.1	750,655.2	0.00	1.00
08/04/2024 08:00	1	1.4	9.5	14.4	19.0	748,127.1	0.00	1.00
08/04/2024 09:00	1	1.5	9.4	14.5	18.2	759,388.6	0.00	1.00
08/04/2024 10:00	1	1.4	9.4	14.5	18.4	759,816.6	0.00	1.00
08/04/2024 11:00	0	1.4	8.1	14.5	13.8	762,170.3	0.00	1.00
08/04/2024 12:00	0	1.4	6.7	14.6	11.0	774,050.8	0.00	1.00
08/04/2024 13:00	0	1.5	6.7	14.6	9.9	774,268.2	0.00	1.00
08/04/2024 14:00	0	1.4	6.5	14.6	9.6	773,833.5	0.00	1.00
08/04/2024 15:00	0	1.4	6.4	14.6	10.4	771,877.1	0.00	1.00
08/04/2024 16:00	0	1.3	6.4	14.6	11.3	771,225.0	0.00	1.00
08/04/2024 17:00	1	1.5	8.8	13.9	19.1	876,627.2	0.00	1.00
08/04/2024 18:00	1	2.1	13.0	12.4	30.9	959,080.4	0.00	1.00
08/04/2024 19:00	1	1.8	9.8	13.4	22.6	958,231.9	0.00	1.00
08/04/2024 20:00	1	1.8	8.7	13.6	21.6	952,218.9	0.00	1.00
08/04/2024 21:00	0	1.4	6.8	14.5	14.0	913,020.9	0.00	1.00
08/04/2024 22:00	0	1.4	6.9	14.5	15.2	893,763.4	0.00	1.00
08/04/2024 23:00	1	1.5	7.9	14.4	16.2	818,705.1	0.00	1.00
Average/Sum#:	1	1.5	8.7	14.3	17.1	802,771.0	0.00 #	24.00 #
Minimum:	0	1.3	6.4	12.4	9.6	746,230.9	0.00	1.00
Maximum:	1	2.1	13.0	14.6	30.9	959,080.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2024 00:00	1	1.4	8.9	14.4	17.9	763,928.1	0.00	1.00
08/05/2024 01:00	1	1.5	9.5	14.4	18.1	745,598.9	0.00	1.00
08/05/2024 02:00	1	1.5	9.9	14.4	19.3	745,598.9	0.00	1.00
08/05/2024 03:00	1	1.6	9.7	14.4	19.4	745,809.6	0.00	1.00
08/05/2024 04:00	0	1.4	7.7	14.5	14.7	860,383.7	0.00	1.00
08/05/2024 05:00	1	1.4	7.7	14.4	16.7	853,046.1	0.00	1.00
08/05/2024 06:00	1	1.4	8.7	14.4	17.9	801,429.3	0.00	1.00
08/05/2024 07:00	1	1.5	9.6	14.4	18.7	751,919.3	0.00	1.00
08/05/2024 08:00	1	1.5	9.5	14.4	19.0	749,812.5	0.00	1.00
08/05/2024 09:00	1	1.5	9.5	14.4	18.7	750,023.2	0.00	1.00
08/05/2024 10:00	1	1.5	9.4	14.4	18.9	750,233.9	0.00	1.00
08/05/2024 11:00	1	1.5	9.4	14.5	18.5	764,096.0	0.00	1.00
08/05/2024 12:00	0	1.3	7.4	14.6	13.5	870,562.6	0.00	1.00
08/05/2024 13:00	1	1.4	8.6	14.4	16.4	759,925.2	0.00	1.00
08/05/2024 14:00	0	1.4	7.7	14.5	14.9	831,711.3	0.00	1.00
08/05/2024 15:00	1	1.5	9.4	14.4	19.2	754,658.2	0.00	1.00
08/05/2024 16:00	1	1.4	9.4	14.4	17.6	754,658.2	0.00	1.00
08/05/2024 17:00	0	1.4	8.5	14.4	15.8	800,375.9	0.00	1.00
08/05/2024 18:00	1	1.7	9.9	13.6	23.0	948,654.7	0.00	1.00
08/05/2024 19:00	1	1.6	9.0	14.1	19.3	816,620.0	0.00	1.00
08/05/2024 20:00	1	1.4	8.0	14.5	16.7	815,663.4	0.00	1.00
08/05/2024 21:00	0	1.5	7.8	14.6	16.1	871,649.5	0.00	1.00
08/05/2024 22:00	1	1.4	7.7	14.5	16.6	858,030.0	0.00	1.00
08/05/2024 23:00	1	1.5	9.4	14.4	18.5	748,548.4	0.00	1.00
Average/Sum#:	1	1.5	8.8	14.4	17.7	796,372.4	0.00 #	24.00 #
Minimum:	0	1.3	7.4	13.6	13.5	745,598.9	0.00	1.00
Maximum:	1	1.7	9.9	14.6	23.0	948,654.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2024 00:00	1	1.4	9.5	14.4	20.3	746,230.9	0.00	1.00
08/06/2024 01:00	1	1.5	9.5	14.4	18.5	746,441.6	0.00	1.00
08/06/2024 02:00	1	1.6	10.0	14.4	18.4	746,652.3	0.00	1.00
08/06/2024 03:00	1	1.6	10.0	14.4	19.1	746,863.0	0.00	1.00
08/06/2024 04:00	1	1.5	9.9	14.4	19.3	747,284.4	0.00	1.00
08/06/2024 05:00	1	1.5	9.6	14.4	19.3	754,868.9	0.00	1.00
08/06/2024 06:00	1	1.5	9.7	14.4	19.0	762,242.7	0.00	1.00
08/06/2024 07:00	1	1.5	10.1	14.4	21.1	750,655.2	0.00	1.00
08/06/2024 08:00	1	1.5	10.2	14.4	19.8	747,916.4	0.00	1.00
08/06/2024 09:00	1	1.5	9.9	14.4	19.9	747,073.7	0.00	1.00
08/06/2024 10:00	1	1.5	9.5	14.5	18.2	758,746.7	0.00	1.00
08/06/2024 11:00	0	1.3	8.5	14.5	15.6	761,314.4	0.00	1.00
08/06/2024 12:00	0	1.4	6.9	14.5	10.7	761,742.3	0.00	1.00
08/06/2024 13:00	0	1.4	6.9	14.6	11.6	774,268.2	0.00	1.00
08/06/2024 14:00	0	1.4	6.7	14.6	9.2	773,616.1	0.00	1.00
08/06/2024 15:00	0	1.4	6.7	14.6	10.4	771,659.8	0.00	1.00
08/06/2024 16:00	0	1.4	7.1	14.6	12.8	810,351.4	0.00	1.00
08/06/2024 17:00	1	1.4	8.0	14.3	16.8	843,026.0	0.00	1.00
08/06/2024 18:00	1	2.0	12.9	12.5	30.6	962,020.6	0.00	1.00
08/06/2024 19:00	1	1.7	9.1	13.7	21.9	964,112.8	0.00	1.00
08/06/2024 20:00	1	1.5	8.2	14.1	19.3	884,889.8	0.00	1.00
08/06/2024 21:00	0	1.4	6.9	14.5	13.1	911,523.1	0.00	1.00
08/06/2024 22:00	1	1.5	7.2	14.5	16.0	887,558.2	0.00	1.00
08/06/2024 23:00	1	1.4	8.4	14.5	18.0	812,453.8	0.00	1.00
Average/Sum#:	1	1.5	8.8	14.3	17.5	798,896.3	0.00 #	24.00 #
Minimum:	0	1.3	6.7	12.5	9.2	746,230.9	0.00	1.00
Maximum:	1	2.0	12.9	14.6	30.6	964,112.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2024 00:00	1	1.5	9.7	14.5	19.5	757,248.9	0.00	1.00
08/07/2024 01:00	1	1.4	9.7	14.5	20.7	756,607.0	0.00	1.00
08/07/2024 02:00	1	1.4	10.2	14.5	20.8	757,248.9	0.00	1.00
08/07/2024 03:00	1	1.5	10.0	14.5	19.5	757,676.8	0.00	1.00
08/07/2024 04:00	1	1.5	10.0	14.4	20.9	745,809.6	0.00	1.00
08/07/2024 05:00	1	1.5	9.6	14.4	18.8	750,444.6	0.00	1.00
08/07/2024 06:00	1	1.5	9.0	14.5	18.8	800,257.4	0.00	1.00
08/07/2024 07:00	1	1.5	9.6	14.5	19.4	761,100.4	0.00	1.00
08/07/2024 08:00	1	1.5	9.5	14.5	19.7	758,746.7	0.00	1.00
08/07/2024 09:00	1	1.4	9.1	14.5	18.4	758,960.7	0.00	1.00
08/07/2024 10:00	0	1.3	7.0	14.5	11.6	759,388.6	0.00	1.00
08/07/2024 11:00	0	1.4	6.9	14.5	10.5	761,528.3	0.00	1.00
08/07/2024 12:00	0	1.5	6.8	14.6	9.8	773,616.1	0.00	1.00
08/07/2024 13:00	0	1.3	6.6	14.6	11.2	773,616.1	0.00	1.00
08/07/2024 14:00	0	1.3	6.6	14.7	10.5	785,872.9	0.00	1.00
08/07/2024 15:00	0	1.4	6.7	14.7	10.6	784,105.9	0.00	1.00
08/07/2024 16:00	0	1.4	6.6	14.7	10.3	783,001.5	0.00	1.00
08/07/2024 17:00	0	1.3	6.8	14.6	12.7	815,568.3	0.00	1.00
08/07/2024 18:00	0	1.3	7.3	14.4	13.8	804,168.1	0.00	1.00
08/07/2024 19:00	1	1.5	7.5	14.4	15.5	825,868.2	0.00	1.00
08/07/2024 20:00	0	1.3	7.5	14.4	13.9	782,257.3	0.00	1.00
08/07/2024 21:00	1	1.5	9.1	14.3	17.8	747,581.2	0.00	1.00
08/07/2024 22:00	1	1.5	9.1	14.3	17.1	746,958.8	0.00	1.00
08/07/2024 23:00	1	1.5	9.7	14.3	19.5	738,244.2	0.00	1.00
Average/Sum#:	1	1.4	8.4	14.5	15.9	770,244.9	0.00 #	24.00 #
Minimum:	0	1.3	6.6	14.3	9.8	738,244.2	0.00	1.00
Maximum:	1	1.5	10.2	14.7	20.9	825,868.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2024 00:00	1	1.5	9.8	14.3	18.7	737,621.8	0.00	1.00
08/08/2024 01:00	1	1.6	9.9	14.3	19.3	738,866.7	0.00	1.00
08/08/2024 02:00	1	1.4	10.5	14.3	21.3	738,866.7	0.00	1.00
08/08/2024 03:00	1	1.5	10.3	14.3	21.7	738,451.7	0.00	1.00
08/08/2024 04:00	1	1.6	10.3	14.4	21.5	747,073.7	0.00	1.00
08/08/2024 05:00	1	1.5	10.2	14.4	20.5	751,708.6	0.00	1.00
08/08/2024 06:00	1	1.5	9.1	14.4	18.4	787,103.0	0.00	1.00
08/08/2024 07:00	1	1.5	9.7	14.4	20.8	747,705.7	0.00	1.00
08/08/2024 08:00	1	1.4	9.6	14.4	19.9	747,284.4	0.00	1.00
08/08/2024 09:00	1	1.5	9.6	14.4	18.4	746,652.3	0.00	1.00
08/08/2024 10:00	0	0.0	0.0	0.0	19.3	232,605.6	0.00	1.00
08/08/2024 11:00	1	1.5	9.9	14.5	18.8	762,598.2	0.00	1.00
08/08/2024 12:00	0	1.4	7.7	14.5	11.9	761,742.3	0.00	1.00
08/08/2024 13:00	0	1.4	6.9	14.5	10.2	762,170.3	0.00	1.00
08/08/2024 14:00	0	1.5	7.0	14.5	10.1	761,956.3	0.00	1.00
08/08/2024 15:00	0	1.4	6.9	14.5	11.3	760,672.5	0.00	1.00
08/08/2024 16:00	0	1.4	6.8	14.6	10.8	771,877.1	0.00	1.00
08/08/2024 17:00	0	1.4	6.8	14.6	11.5	776,224.5	0.00	1.00
08/08/2024 18:00	0	1.4	7.0	14.5	11.4	769,231.4	0.00	1.00
08/08/2024 19:00	0	1.4	7.1	14.5	12.2	757,034.9	0.00	1.00
08/08/2024 20:00	1	1.5	7.8	14.5	15.1	793,838.2	0.00	1.00
08/08/2024 21:00	1	1.4	9.0	14.5	18.2	786,349.2	0.00	1.00
08/08/2024 22:00	1	1.5	9.7	14.4	19.8	745,388.2	0.00	1.00
08/08/2024 23:00	1	1.5	9.7	14.4	19.4	746,230.9	0.00	1.00
Average/Sum#:	1	1.5	8.8	14.4	16.7	758,115.2	0.00 #	24.00 #
Minimum:	0	1.4	6.8	14.3	10.1	737,621.8	0.00	1.00
Maximum:	1	1.6	10.5	14.6	21.7	793,838.2	0.00	1.00
%SI	4.17	4.17	4.17	4.17	0.00	4.17	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2024 00:00	1	1.5	9.7	14.4	19.0	746,020.3	0.00	1.00
08/09/2024 01:00	1	1.5	9.8	14.3	19.6	734,924.4	0.00	1.00
08/09/2024 02:00	1	1.5	10.3	14.3	18.8	734,716.9	0.00	1.00
08/09/2024 03:00	1	1.6	10.2	14.3	19.6	734,924.4	0.00	1.00
08/09/2024 04:00	1	1.5	10.1	14.3	19.6	734,509.4	0.00	1.00
08/09/2024 05:00	1	1.5	9.9	14.3	19.1	739,281.7	0.00	1.00
08/09/2024 06:00	1	1.5	8.7	14.3	18.0	819,372.3	0.00	1.00
08/09/2024 07:00	1	1.5	10.3	14.3	21.3	739,489.2	0.00	1.00
08/09/2024 08:00	1	1.5	10.2	14.4	20.0	748,337.8	0.00	1.00
08/09/2024 09:00	1	1.5	9.9	14.4	19.3	746,652.3	0.00	1.00
08/09/2024 10:00	1	1.5	9.7	14.4	19.4	746,652.3	0.00	1.00
08/09/2024 11:00	1	1.4	9.5	14.5	19.4	760,672.5	0.00	1.00
08/09/2024 12:00	0	1.4	7.3	14.5	10.8	760,886.4	0.00	1.00
08/09/2024 13:00	0	1.4	6.8	14.5	10.1	761,528.3	0.00	1.00
08/09/2024 14:00	0	1.3	6.8	14.6	11.3	773,398.7	0.00	1.00
08/09/2024 15:00	0	1.3	6.6	14.6	11.7	771,225.0	0.00	1.00
08/09/2024 16:00	0	1.4	6.7	14.6	10.0	770,790.3	0.00	1.00
08/09/2024 17:00	1	1.4	8.4	14.4	17.2	784,574.8	0.00	1.00
08/09/2024 18:00	1	1.5	9.1	14.3	17.2	757,125.7	0.00	1.00
08/09/2024 19:00	1	1.5	9.3	14.3	18.6	738,036.7	0.00	1.00
08/09/2024 20:00	1	1.5	9.5	14.4	18.7	748,127.1	0.00	1.00
08/09/2024 21:00	1	1.5	10.0	14.4	20.2	745,598.9	0.00	1.00
08/09/2024 22:00	1	1.5	10.1	14.4	20.2	745,598.9	0.00	1.00
08/09/2024 23:00	1	1.5	10.2	14.4	19.7	745,177.5	0.00	1.00
Average/Sum#:	1	1.5	9.1	14.4	17.5	753,650.9	0.00 #	24.00 #
Minimum:	0	1.3	6.6	14.3	10.0	734,509.4	0.00	1.00
Maximum:	1	1.6	10.3	14.6	21.3	819,372.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2024 00:00	1	1.6	10.2	14.3	19.6	735,339.4	0.00	1.00
08/10/2024 01:00	1	1.5	10.1	14.3	20.5	735,961.9	0.00	1.00
08/10/2024 02:00	1	1.5	10.5	14.3	19.8	735,754.4	0.00	1.00
08/10/2024 03:00	1	1.6	10.4	14.3	20.3	734,716.9	0.00	1.00
08/10/2024 04:00	1	1.5	10.2	14.3	19.9	733,679.5	0.00	1.00
08/10/2024 05:00	1	1.5	10.1	14.3	20.0	734,302.0	0.00	1.00
08/10/2024 06:00	1	1.5	10.0	14.3	19.5	737,206.8	0.00	1.00
08/10/2024 07:00	1	1.6	10.0	14.3	18.7	738,659.2	0.00	1.00
08/10/2024 08:00	1	1.5	10.0	14.3	20.1	736,169.4	0.00	1.00
08/10/2024 09:00	1	1.6	9.9	14.3	19.4	736,169.4	0.00	1.00
08/10/2024 10:00	1	1.6	9.9	14.4	19.5	748,759.1	0.00	1.00
08/10/2024 11:00	1	1.5	9.8	14.4	19.2	752,130.0	0.00	1.00
08/10/2024 12:00	1	1.5	9.6	14.5	18.7	763,668.1	0.00	1.00
08/10/2024 13:00	0	1.4	7.8	14.5	13.1	789,344.8	0.00	1.00
08/10/2024 14:00	0	1.4	7.2	14.5	11.3	763,026.1	0.00	1.00
08/10/2024 15:00	0	1.3	7.1	14.5	13.2	760,672.5	0.00	1.00
08/10/2024 16:00	0	1.3	6.9	14.5	11.2	759,602.6	0.00	1.00
08/10/2024 17:00	0	1.4	7.0	14.5	11.6	805,392.7	0.00	1.00
08/10/2024 18:00	1	1.4	8.6	14.4	18.1	751,287.3	0.00	1.00
08/10/2024 19:00	0	1.4	7.6	14.5	12.7	757,676.8	0.00	1.00
08/10/2024 20:00	1	1.3	8.0	14.5	15.2	757,248.9	0.00	1.00
08/10/2024 21:00	1	1.5	9.6	14.4	18.7	744,334.8	0.00	1.00
08/10/2024 22:00	1	1.5	9.7	14.4	19.1	744,756.2	0.00	1.00
08/10/2024 23:00	1	1.5	9.8	14.4	19.3	744,966.9	0.00	1.00
Average/Sum#:	1	1.5	9.2	14.4	17.4	750,034.4	0.00 #	24.00 #
Minimum:	0	1.3	6.9	14.3	11.2	733,679.5	0.00	1.00
Maximum:	1	1.6	10.5	14.5	20.5	805,392.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2024 00:00	1	1.4	9.8	14.4	19.4	745,598.9	0.00	1.00
08/11/2024 01:00	1	1.5	9.8	14.4	18.8	745,809.6	0.00	1.00
08/11/2024 02:00	0	1.5	10.3	14.3	18.9	734,924.4	0.00	1.00
08/11/2024 03:00	1	1.5	10.1	14.3	21.4	734,924.4	0.00	1.00
08/11/2024 04:00	1	1.6	10.0	14.3	19.2	735,131.9	0.00	1.00
08/11/2024 05:00	1	1.5	10.2	14.3	19.9	735,339.4	0.00	1.00
08/11/2024 06:00	1	1.5	10.1	14.3	19.8	738,244.2	0.00	1.00
08/11/2024 07:00	1	1.6	10.0	14.3	19.3	739,074.2	0.00	1.00
08/11/2024 08:00	1	1.5	10.1	14.3	20.0	736,584.3	0.00	1.00
08/11/2024 09:00	1	1.5	10.0	14.4	20.0	747,073.7	0.00	1.00
08/11/2024 10:00	1	1.5	9.9	14.4	19.3	747,073.7	0.00	1.00
08/11/2024 11:00	1	1.4	9.8	14.4	20.2	749,601.8	0.00	1.00
08/11/2024 12:00	0	1.4	7.8	14.5	13.5	842,837.9	0.00	1.00
08/11/2024 13:00	0	1.5	7.0	14.5	14.1	935,702.0	0.00	1.00
08/11/2024 14:00	0	1.4	7.1	14.5	16.0	936,985.8	0.00	1.00
08/11/2024 15:00	0	1.3	7.0	14.5	15.0	930,352.7	0.00	1.00
08/11/2024 16:00	0	1.4	6.9	14.5	14.4	916,658.4	0.00	1.00
08/11/2024 17:00	0	1.4	7.0	14.5	13.8	874,719.8	0.00	1.00
08/11/2024 18:00	1	1.5	7.4	14.3	17.1	919,174.2	0.00	1.00
08/11/2024 19:00	1	1.7	9.3	13.7	22.7	964,873.6	0.00	1.00
08/11/2024 20:00	1	1.9	11.2	13.0	27.6	962,237.3	0.00	1.00
08/11/2024 21:00	1	1.7	8.8	13.9	22.7	971,313.2	0.00	1.00
08/11/2024 22:00	1	1.6	8.3	14.2	21.0	962,684.9	0.00	1.00
08/11/2024 23:00	1	1.5	9.8	14.3	21.4	786,796.6	0.00	1.00
Average/Sum#:	1	1.5	9.1	14.3	19.0	828,904.9	0.00 #	24.00 #
Minimum:	0	1.3	6.9	13.0	13.5	734,924.4	0.00	1.00
Maximum:	1	1.9	11.2	14.5	27.6	971,313.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2024 00:00	1	1.5	10.1	14.3	20.4	738,036.7	0.00	1.00
08/12/2024 01:00	1	1.6	10.2	14.3	20.1	738,036.7	0.00	1.00
08/12/2024 02:00	1	1.6	10.8	14.3	19.7	738,036.7	0.00	1.00
08/12/2024 03:00	1	1.6	10.6	14.3	19.7	738,244.2	0.00	1.00
08/12/2024 04:00	1	1.5	9.6	14.3	18.5	771,649.9	0.00	1.00
08/12/2024 05:00	1	1.5	8.3	14.3	16.1	803,395.6	0.00	1.00
08/12/2024 06:00	1	1.5	9.4	14.3	19.0	740,526.6	0.00	1.00
08/12/2024 07:00	1	1.5	10.4	14.3	21.0	741,979.0	0.00	1.00
08/12/2024 08:00	1	1.5	10.3	14.3	19.4	739,904.1	0.00	1.00
08/12/2024 09:00	1	1.5	10.3	14.3	21.3	739,074.2	0.00	1.00
08/12/2024 10:00	1	1.5	9.9	14.4	19.6	749,601.8	0.00	1.00
08/12/2024 11:00	1	1.5	9.6	14.4	18.0	750,865.9	0.00	1.00
08/12/2024 12:00	1	1.5	9.4	14.5	18.6	762,598.2	0.00	1.00
08/12/2024 13:00	0	1.4	8.3	14.5	14.1	762,384.2	0.00	1.00
08/12/2024 14:00	0	1.4	7.1	14.5	11.0	760,030.5	0.00	1.00
08/12/2024 15:00	0	1.4	7.7	14.5	13.5	758,960.7	0.00	1.00
08/12/2024 16:00	0	1.4	7.1	14.5	11.4	758,532.7	0.00	1.00
08/12/2024 17:00	1	1.4	7.9	14.3	17.2	846,553.3	0.00	1.00
08/12/2024 18:00	1	1.7	9.4	13.7	21.6	966,585.4	0.00	1.00
08/12/2024 19:00	1	1.6	9.0	14.0	21.9	932,796.3	0.00	1.00
08/12/2024 20:00	1	1.5	9.6	14.4	20.4	770,037.9	0.00	1.00
08/12/2024 21:00	1	1.5	10.2	14.4	20.7	744,545.5	0.00	1.00
08/12/2024 22:00	1	1.5	10.3	14.4	20.8	745,388.2	0.00	1.00
08/12/2024 23:00	1	1.5	10.3	14.3	19.9	733,887.0	0.00	1.00
Average/Sum#:	1	1.5	9.4	14.3	18.5	772,152.1	0.00 #	24.00 #
Minimum:	0	1.4	7.1	13.7	11.0	733,887.0	0.00	1.00
Maximum:	1	1.7	10.8	14.5	21.9	966,585.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2024 00:00	1	1.5	10.4	14.3	21.1	733,679.5	0.00	1.00
08/13/2024 01:00	1	1.6	10.4	14.3	20.4	733,472.0	0.00	1.00
08/13/2024 02:00	1	1.5	10.8	14.3	21.3	733,887.0	0.00	1.00
08/13/2024 03:00	1	1.6	10.9	14.3	21.8	733,679.5	0.00	1.00
08/13/2024 04:00	1	1.5	10.5	14.3	20.9	734,094.5	0.00	1.00
08/13/2024 05:00	1	1.5	10.6	14.3	21.9	739,074.2	0.00	1.00
08/13/2024 06:00	1	1.5	10.9	14.3	22.9	737,829.3	0.00	1.00
08/13/2024 07:00	1	1.5	10.9	14.3	21.6	738,659.2	0.00	1.00
08/13/2024 08:00	1	1.5	10.9	14.3	22.4	736,584.3	0.00	1.00
08/13/2024 09:00	1	1.5	10.9	14.4	22.1	747,705.7	0.00	1.00
08/13/2024 10:00	1	1.5	10.7	14.4	21.6	747,916.4	0.00	1.00
08/13/2024 11:00	1	1.5	10.2	14.4	20.9	749,180.5	0.00	1.00
08/13/2024 12:00	1	1.5	10.0	14.4	20.7	749,601.8	0.00	1.00
08/13/2024 13:00	1	1.5	10.0	14.5	20.0	762,170.3	0.00	1.00
08/13/2024 14:00	1	1.4	10.1	14.5	20.5	762,384.2	0.00	1.00
08/13/2024 15:00	1	1.5	10.0	14.5	20.5	760,672.5	0.00	1.00
08/13/2024 16:00	0	1.4	8.3	14.5	13.7	759,388.6	0.00	1.00
08/13/2024 17:00	1	1.7	9.2	13.8	19.4	884,146.7	0.00	1.00
08/13/2024 18:00	1	1.8	10.3	13.3	25.1	968,687.6	0.00	1.00
08/13/2024 19:00	1	1.5	8.5	14.0	20.8	870,676.1	0.00	1.00
08/13/2024 20:00	1	1.5	9.6	14.3	18.6	742,394.0	0.00	1.00
08/13/2024 21:00	1	1.5	9.2	14.4	18.7	756,554.3	0.00	1.00
08/13/2024 22:00	1	1.4	9.8	14.4	18.9	744,966.9	0.00	1.00
08/13/2024 23:00	1	1.5	9.9	14.4	19.5	745,177.5	0.00	1.00
Average/Sum#:	1	1.5	10.1	14.3	20.6	765,524.3	0.00 #	24.00 #
Minimum:	0	1.4	8.3	13.3	13.7	733,472.0	0.00	1.00
Maximum:	1	1.8	10.9	14.5	25.1	968,687.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2024 00:00	1	1.5	9.8	14.3	19.2	733,887.0	0.00	1.00
08/14/2024 01:00	1	1.5	9.8	14.3	19.4	734,924.4	0.00	1.00
08/14/2024 02:00	1	1.5	10.4	14.3	20.0	735,339.4	0.00	1.00
08/14/2024 03:00	1	1.5	10.1	14.3	19.5	735,546.9	0.00	1.00
08/14/2024 04:00	1	1.6	10.0	14.3	19.4	736,169.4	0.00	1.00
08/14/2024 05:00	1	1.5	10.1	14.3	20.1	735,339.4	0.00	1.00
08/14/2024 06:00	1	1.5	9.9	14.3	19.5	737,621.8	0.00	1.00
08/14/2024 07:00	1	1.5	9.9	14.3	19.2	738,659.2	0.00	1.00
08/14/2024 08:00	1	1.5	9.8	14.3	19.9	736,169.4	0.00	1.00
08/14/2024 09:00	1	1.5	9.9	14.4	19.4	746,441.6	0.00	1.00
08/14/2024 10:00	1	1.5	9.9	14.4	20.1	747,284.4	0.00	1.00
08/14/2024 11:00	1	1.5	9.9	14.4	20.0	749,812.5	0.00	1.00
08/14/2024 12:00	1	1.4	9.3	14.5	18.7	761,742.3	0.00	1.00
08/14/2024 13:00	0	1.4	7.7	14.5	11.9	762,384.2	0.00	1.00
08/14/2024 14:00	0	1.4	7.2	14.5	10.8	761,100.4	0.00	1.00
08/14/2024 15:00	0	1.5	7.2	14.5	11.2	759,816.6	0.00	1.00
08/14/2024 16:00	0	1.4	7.0	14.5	12.0	766,235.7	0.00	1.00
08/14/2024 17:00	1	1.8	10.1	13.4	23.3	921,531.3	0.00	1.00
08/14/2024 18:00	1	2.2	13.1	12.3	32.7	968,151.2	0.00	1.00
08/14/2024 19:00	1	2.2	13.1	12.2	34.4	960,485.9	0.00	1.00
08/14/2024 20:00	1	1.8	10.0	13.4	23.1	919,157.6	0.00	1.00
08/14/2024 21:00	0	1.4	7.6	14.6	16.2	893,821.1	0.00	1.00
08/14/2024 22:00	1	1.5	9.8	14.4	19.0	754,868.9	0.00	1.00
08/14/2024 23:00	1	1.4	7.7	14.5	16.8	871,724.2	0.00	1.00
Average/Sum#:	1	1.6	9.6	14.1	19.4	790,342.3	0.00 #	24.00 #
Minimum:	0	1.4	7.0	12.2	10.8	733,887.0	0.00	1.00
Maximum:	1	2.2	13.1	14.6	34.4	968,151.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2024 00:00	1	1.6	10.1	14.3	19.3	733,679.5	0.00	1.00
08/15/2024 01:00	1	1.5	10.1	14.3	20.1	734,302.0	0.00	1.00
08/15/2024 02:00	1	1.6	10.3	14.3	17.9	735,131.9	0.00	1.00
08/15/2024 03:00	1	1.6	10.2	14.3	20.8	735,339.4	0.00	1.00
08/15/2024 04:00	1	1.5	9.4	14.3	17.3	767,085.1	0.00	1.00
08/15/2024 05:00	1	1.5	9.0	14.4	19.7	825,025.5	0.00	1.00
08/15/2024 06:00	1	1.5	10.4	14.3	20.8	738,451.7	0.00	1.00
08/15/2024 07:00	1	1.5	10.5	14.3	20.8	738,866.7	0.00	1.00
08/15/2024 08:00	1	1.5	10.5	14.4	20.6	748,127.1	0.00	1.00
08/15/2024 09:00	1	1.5	10.4	14.4	21.1	746,863.0	0.00	1.00
08/15/2024 10:00	1	1.5	10.1	14.4	19.7	746,652.3	0.00	1.00
08/15/2024 11:00	1	1.4	9.9	14.4	20.2	750,023.2	0.00	1.00
08/15/2024 12:00	1	1.5	9.7	14.5	19.2	758,532.7	0.00	1.00
08/15/2024 13:00	1	1.5	9.7	14.5	18.4	757,890.8	0.00	1.00
08/15/2024 14:00	0	1.4	8.4	14.5	13.5	757,890.8	0.00	1.00
08/15/2024 15:00	0	1.4	7.7	14.3	15.9	839,083.7	0.00	1.00
08/15/2024 16:00	1	1.7	9.9	13.5	22.7	950,454.5	0.00	1.00
08/15/2024 17:00	1	1.9	11.7	12.9	28.2	963,218.9	0.00	1.00
08/15/2024 18:00	1	2.1	13.0	12.4	32.3	956,986.0	0.00	1.00
08/15/2024 19:00	1	2.0	11.9	12.8	29.3	961,978.4	0.00	1.00
08/15/2024 20:00	1	1.5	8.3	14.0	19.1	861,546.6	0.00	1.00
08/15/2024 21:00	1	1.5	9.2	14.3	18.2	734,924.4	0.00	1.00
08/15/2024 22:00	1	1.5	9.5	14.4	19.3	743,492.1	0.00	1.00
08/15/2024 23:00	1	1.5	9.3	14.4	18.5	753,394.1	0.00	1.00
Average/Sum#:	1	1.6	10.0	14.1	20.5	793,289.2	0.00 #	24.00 #
Minimum:	0	1.4	7.7	12.4	13.5	733,679.5	0.00	1.00
Maximum:	1	2.1	13.0	14.5	32.3	963,218.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2024 00:00	1	1.5	9.6	14.4	19.7	743,913.5	0.00	1.00
08/16/2024 01:00	1	1.5	9.7	14.4	19.2	744,334.8	0.00	1.00
08/16/2024 02:00	1	1.5	10.2	14.3	19.8	733,264.5	0.00	1.00
08/16/2024 03:00	1	1.6	10.0	14.3	19.1	733,057.0	0.00	1.00
08/16/2024 04:00	1	1.5	8.6	14.4	16.4	807,117.7	0.00	1.00
08/16/2024 05:00	1	1.5	8.2	14.4	17.7	834,295.5	0.00	1.00
08/16/2024 06:00	1	1.6	10.1	14.3	20.7	737,414.3	0.00	1.00
08/16/2024 07:00	1	1.5	10.1	14.4	20.4	748,337.8	0.00	1.00
08/16/2024 08:00	1	1.5	10.0	14.4	18.6	745,388.2	0.00	1.00
08/16/2024 09:00	1	1.5	9.7	14.4	19.3	745,177.5	0.00	1.00
08/16/2024 10:00	1	1.5	9.5	14.4	18.9	744,966.9	0.00	1.00
08/16/2024 11:00	1	1.5	9.5	14.4	19.2	746,863.0	0.00	1.00
08/16/2024 12:00	0	1.4	7.4	14.5	11.1	758,318.8	0.00	1.00
08/16/2024 13:00	0	1.4	6.7	14.5	10.3	767,947.5	0.00	1.00
08/16/2024 14:00	0	1.3	7.0	14.5	11.8	759,174.6	0.00	1.00
08/16/2024 15:00	0	1.5	7.0	14.5	10.7	757,034.9	0.00	1.00
08/16/2024 16:00	0	1.4	7.0	14.5	10.7	754,467.2	0.00	1.00
08/16/2024 17:00	0	1.4	6.9	14.5	11.3	760,886.4	0.00	1.00
08/16/2024 18:00	0	1.6	7.5	14.4	12.7	744,966.9	0.00	1.00
08/16/2024 19:00	1	1.5	9.5	14.4	19.7	748,127.1	0.00	1.00
08/16/2024 20:00	1	1.5	9.7	14.4	19.8	743,492.1	0.00	1.00
08/16/2024 21:00	0	1.4	7.1	14.5	13.5	906,173.8	0.00	1.00
08/16/2024 22:00	0	1.5	7.2	14.4	14.2	870,743.2	0.00	1.00
08/16/2024 23:00	1	1.4	7.6	14.5	16.9	864,021.2	0.00	1.00
Average/Sum#:	1	1.5	8.6	14.4	16.3	770,811.9	0.00 #	24.00 #
Minimum:	0	1.3	6.7	14.3	10.3	733,057.0	0.00	1.00
Maximum:	1	1.6	10.2	14.5	20.7	906,173.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2024 00:00	1	1.5	8.6	14.4	19.0	816,387.6	0.00	1.00
08/17/2024 01:00	1	1.5	9.6	14.3	19.0	731,812.1	0.00	1.00
08/17/2024 02:00	1	1.5	10.0	14.3	19.8	732,227.1	0.00	1.00
08/17/2024 03:00	1	1.6	9.8	14.3	18.6	732,849.5	0.00	1.00
08/17/2024 04:00	1	1.5	9.7	14.3	18.5	733,679.5	0.00	1.00
08/17/2024 05:00	1	1.5	8.1	14.4	16.3	816,598.3	0.00	1.00
08/17/2024 06:00	1	1.6	9.6	14.3	19.3	736,376.8	0.00	1.00
08/17/2024 07:00	1	1.5	9.5	14.3	18.1	736,169.4	0.00	1.00
08/17/2024 08:00	1	1.4	9.5	14.3	19.0	733,472.0	0.00	1.00
08/17/2024 09:00	1	1.5	9.3	14.3	17.7	732,849.5	0.00	1.00
08/17/2024 10:00	1	1.5	9.2	14.4	17.9	743,702.8	0.00	1.00
08/17/2024 11:00	1	1.5	9.2	14.4	18.6	746,441.6	0.00	1.00
08/17/2024 12:00	1	1.5	9.1	14.4	17.1	747,073.7	0.00	1.00
08/17/2024 13:00	1	1.5	9.1	14.4	17.9	747,705.7	0.00	1.00
08/17/2024 14:00	1	1.4	9.1	14.4	17.7	747,916.4	0.00	1.00
08/17/2024 15:00	1	1.5	9.0	14.4	17.5	747,284.4	0.00	1.00
08/17/2024 16:00	1	1.4	9.1	14.4	18.2	745,388.2	0.00	1.00
08/17/2024 17:00	1	1.5	8.7	14.4	16.3	755,290.2	0.00	1.00
08/17/2024 18:00	1	1.5	9.0	14.3	17.7	735,754.4	0.00	1.00
08/17/2024 19:00	1	1.5	9.1	14.3	18.1	733,057.0	0.00	1.00
08/17/2024 20:00	1	1.5	9.3	14.3	18.2	732,849.5	0.00	1.00
08/17/2024 21:00	1	1.5	9.4	14.3	18.4	732,642.0	0.00	1.00
08/17/2024 22:00	1	1.6	9.5	14.3	18.7	731,604.6	0.00	1.00
08/17/2024 23:00	1	1.5	9.6	14.3	18.8	732,434.6	0.00	1.00
Average/Sum#:	1	1.5	9.3	14.3	18.2	745,065.3	0.00 #	24.00 #
Minimum:	1	1.4	8.1	14.3	16.3	731,604.6	0.00	1.00
Maximum:	1	1.6	10.0	14.4	19.8	816,598.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2024 00:00	1	1.5	9.6	14.3	19.2	732,849.5	0.00	1.00
08/18/2024 01:00	1	1.5	9.7	14.3	18.1	732,227.1	0.00	1.00
08/18/2024 02:00	1	1.4	10.1	14.3	20.4	732,227.1	0.00	1.00
08/18/2024 03:00	1	1.6	9.8	14.2	18.9	722,115.9	0.00	1.00
08/18/2024 04:00	1	1.5	10.1	14.2	20.1	722,933.4	0.00	1.00
08/18/2024 05:00	1	1.5	10.0	14.2	19.5	723,546.6	0.00	1.00
08/18/2024 06:00	1	1.5	10.0	14.2	19.8	725,999.3	0.00	1.00
08/18/2024 07:00	1	1.5	10.0	14.3	20.0	736,791.8	0.00	1.00
08/18/2024 08:00	1	1.4	10.1	14.3	20.4	735,131.9	0.00	1.00
08/18/2024 09:00	1	1.5	10.2	14.3	20.8	734,716.9	0.00	1.00
08/18/2024 10:00	1	1.5	10.3	14.3	20.9	734,716.9	0.00	1.00
08/18/2024 11:00	1	1.5	10.0	14.4	19.4	746,441.6	0.00	1.00
08/18/2024 12:00	1	1.5	9.9	14.4	19.9	747,073.7	0.00	1.00
08/18/2024 13:00	1	1.5	10.0	14.4	20.7	748,127.1	0.00	1.00
08/18/2024 14:00	1	1.5	10.0	14.4	19.9	747,705.7	0.00	1.00
08/18/2024 15:00	1	1.5	10.1	14.5	21.4	758,104.8	0.00	1.00
08/18/2024 16:00	1	1.4	9.6	14.5	18.7	771,799.0	0.00	1.00
08/18/2024 17:00	1	1.4	9.4	14.5	19.9	772,440.9	0.00	1.00
08/18/2024 18:00	1	1.5	10.0	14.5	20.8	757,890.8	0.00	1.00
08/18/2024 19:00	1	1.4	10.0	14.4	20.1	744,756.2	0.00	1.00
08/18/2024 20:00	1	1.5	10.0	14.4	21.0	744,545.5	0.00	1.00
08/18/2024 21:00	1	1.4	9.7	14.4	19.6	748,337.8	0.00	1.00
08/18/2024 22:00	1	1.5	10.0	14.3	19.4	732,849.5	0.00	1.00
08/18/2024 23:00	1	1.4	9.8	14.3	20.3	741,564.1	0.00	1.00
Average/Sum#:	1	1.5	9.9	14.3	20.0	741,453.9	0.00 #	24.00 #
Minimum:	1	1.4	9.4	14.2	18.1	722,115.9	0.00	1.00
Maximum:	1	1.6	10.3	14.5	21.4	772,440.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2024 00:00	1	1.5	10.0	14.3	19.6	733,057.0	0.00	1.00
08/19/2024 01:00	1	1.5	10.0	14.3	20.5	733,057.0	0.00	1.00
08/19/2024 02:00	1	1.5	10.4	14.3	19.2	732,849.5	0.00	1.00
08/19/2024 03:00	1	1.6	10.2	14.3	18.8	733,472.0	0.00	1.00
08/19/2024 04:00	1	1.5	8.4	14.4	16.4	834,927.5	0.00	1.00
08/19/2024 05:00	1	1.4	8.3	14.4	19.1	850,939.2	0.00	1.00
08/19/2024 06:00	1	1.5	10.2	14.3	20.6	736,791.8	0.00	1.00
08/19/2024 07:00	1	1.5	10.2	14.3	19.9	737,621.8	0.00	1.00
08/19/2024 08:00	1	1.5	10.2	14.3	20.7	736,169.4	0.00	1.00
08/19/2024 09:00	1	1.5	10.2	14.3	20.4	735,961.9	0.00	1.00
08/19/2024 10:00	1	1.4	10.0	14.4	19.8	746,441.6	0.00	1.00
08/19/2024 11:00	1	1.5	9.8	14.4	19.4	747,705.7	0.00	1.00
08/19/2024 12:00	1	1.4	9.6	14.4	19.4	748,127.1	0.00	1.00
08/19/2024 13:00	1	1.4	9.8	14.5	19.9	760,244.5	0.00	1.00
08/19/2024 14:00	1	1.4	10.0	14.5	20.6	760,030.5	0.00	1.00
08/19/2024 15:00	1	1.4	9.2	14.5	17.3	758,104.8	0.00	1.00
08/19/2024 16:00	0	1.4	8.5	14.5	14.8	755,965.1	0.00	1.00
08/19/2024 17:00	1	1.4	9.6	14.5	20.0	757,248.9	0.00	1.00
08/19/2024 18:00	1	1.5	9.9	14.5	19.6	757,676.8	0.00	1.00
08/19/2024 19:00	1	1.5	9.9	14.4	20.1	744,545.5	0.00	1.00
08/19/2024 20:00	1	1.5	10.1	14.4	19.5	743,913.5	0.00	1.00
08/19/2024 21:00	1	1.3	8.3	14.5	18.4	835,348.9	0.00	1.00
08/19/2024 22:00	1	1.5	10.0	14.4	19.7	743,702.8	0.00	1.00
08/19/2024 23:00	1	1.5	10.2	14.4	19.5	743,702.8	0.00	1.00
Average/Sum#:	1	1.5	9.7	14.4	19.3	756,983.6	0.00 #	24.00 #
Minimum:	0	1.3	8.3	14.3	14.8	732,849.5	0.00	1.00
Maximum:	1	1.6	10.4	14.5	20.7	850,939.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2024 00:00	1	1.5	10.1	14.3	19.9	732,227.1	0.00	1.00
08/20/2024 01:00	1	1.5	10.2	14.3	20.3	732,642.0	0.00	1.00
08/20/2024 02:00	1	1.6	10.6	14.3	19.8	732,434.6	0.00	1.00
08/20/2024 03:00	1	1.5	10.4	14.3	21.2	732,642.0	0.00	1.00
08/20/2024 04:00	1	1.5	10.3	14.3	20.3	733,057.0	0.00	1.00
08/20/2024 05:00	1	1.5	10.6	14.3	22.1	734,302.0	0.00	1.00
08/20/2024 06:00	1	1.5	10.6	14.3	21.6	736,791.8	0.00	1.00
08/20/2024 07:00	1	1.5	10.6	14.3	21.3	737,206.8	0.00	1.00
08/20/2024 08:00	1	1.5	10.6	14.3	20.4	736,376.8	0.00	1.00
08/20/2024 09:00	1	1.5	10.4	14.4	21.2	748,759.1	0.00	1.00
08/20/2024 10:00	1	1.5	10.1	14.4	20.9	747,495.0	0.00	1.00
08/20/2024 11:00	1	1.5	9.9	14.4	19.1	749,391.2	0.00	1.00
08/20/2024 12:00	1	1.5	9.6	14.5	18.6	761,956.3	0.00	1.00
08/20/2024 13:00	1	1.4	9.4	14.5	18.7	761,742.3	0.00	1.00
08/20/2024 14:00	0	1.3	7.3	14.5	9.7	761,956.3	0.00	1.00
08/20/2024 15:00	0	1.4	7.3	14.5	11.0	760,244.5	0.00	1.00
08/20/2024 16:00	0	1.3	7.3	14.5	12.4	758,746.7	0.00	1.00
08/20/2024 17:00	0	1.3	7.4	14.5	14.5	799,829.4	0.00	1.00
08/20/2024 18:00	1	1.4	8.6	14.5	16.9	760,458.5	0.00	1.00
08/20/2024 19:00	1	1.4	9.6	14.4	19.0	746,863.0	0.00	1.00
08/20/2024 20:00	1	1.4	9.7	14.4	19.5	744,756.2	0.00	1.00
08/20/2024 21:00	1	1.5	9.9	14.4	19.1	737,593.0	0.00	1.00
08/20/2024 22:00	1	1.5	9.9	14.3	19.9	728,492.3	0.00	1.00
08/20/2024 23:00	1	1.5	9.9	14.3	19.6	728,284.8	0.00	1.00
Average/Sum#:	1	1.5	9.6	14.4	18.6	746,010.4	0.00 #	24.00 #
Minimum:	0	1.3	7.3	14.3	9.7	728,284.8	0.00	1.00
Maximum:	1	1.6	10.6	14.5	22.1	799,829.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2024 00:00	1	1.5	10.0	14.3	19.8	727,662.3	0.00	1.00
08/21/2024 01:00	1	1.4	10.0	14.3	20.5	728,077.3	0.00	1.00
08/21/2024 02:00	1	1.6	10.4	14.3	18.8	728,284.8	0.00	1.00
08/21/2024 03:00	1	1.5	10.1	14.3	20.7	729,114.7	0.00	1.00
08/21/2024 04:00	1	1.5	10.0	14.3	19.6	729,529.7	0.00	1.00
08/21/2024 05:00	1	1.5	10.0	14.3	19.5	731,812.1	0.00	1.00
08/21/2024 06:00	1	1.5	10.0	14.3	19.9	733,264.5	0.00	1.00
08/21/2024 07:00	1	1.5	10.0	14.3	20.5	735,131.9	0.00	1.00
08/21/2024 08:00	1	1.5	9.9	14.3	19.4	733,887.0	0.00	1.00
08/21/2024 09:00	1	1.6	10.0	14.4	19.8	744,334.8	0.00	1.00
08/21/2024 10:00	1	1.5	10.1	14.4	20.5	744,124.1	0.00	1.00
08/21/2024 11:00	1	1.5	10.1	14.4	20.3	746,020.3	0.00	1.00
08/21/2024 12:00	1	1.5	10.0	14.5	19.7	758,104.8	0.00	1.00
08/21/2024 13:00	1	1.5	9.9	14.5	20.2	758,318.8	0.00	1.00
08/21/2024 14:00	0	1.3	7.9	14.5	11.2	757,248.9	0.00	1.00
08/21/2024 15:00	0	1.5	7.4	14.5	10.9	755,965.1	0.00	1.00
08/21/2024 16:00	0	1.5	7.4	14.5	12.2	773,296.8	0.00	1.00
08/21/2024 17:00	1	1.3	9.1	14.5	19.6	775,008.6	0.00	1.00
08/21/2024 18:00	1	1.4	9.8	14.4	19.9	745,809.6	0.00	1.00
08/21/2024 19:00	1	1.5	9.6	14.4	19.1	740,963.9	0.00	1.00
08/21/2024 20:00	1	1.5	9.6	14.4	19.1	736,961.0	0.00	1.00
08/21/2024 21:00	1	1.4	9.3	14.4	17.7	740,542.6	0.00	1.00
08/21/2024 22:00	1	1.5	9.8	14.3	19.0	723,927.5	0.00	1.00
08/21/2024 23:00	1	1.5	9.8	14.3	18.7	723,512.5	0.00	1.00
Average/Sum#:	1	1.5	9.6	14.4	18.6	741,704.3	0.00 #	24.00 #
Minimum:	0	1.3	7.4	14.3	10.9	723,512.5	0.00	1.00
Maximum:	1	1.6	10.4	14.5	20.7	775,008.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2024 00:00	1	1.5	9.7	14.3	19.2	724,757.5	0.00	1.00
08/22/2024 01:00	1	1.5	9.7	14.3	17.8	726,624.9	0.00	1.00
08/22/2024 02:00	1	1.4	10.1	14.3	20.1	727,869.8	0.00	1.00
08/22/2024 03:00	1	1.5	9.8	14.3	19.2	728,699.8	0.00	1.00
08/22/2024 04:00	1	1.5	9.8	14.3	19.0	729,944.7	0.00	1.00
08/22/2024 05:00	1	1.5	9.5	14.3	18.6	755,465.8	0.00	1.00
08/22/2024 06:00	1	1.4	10.1	14.3	21.1	734,716.9	0.00	1.00
08/22/2024 07:00	1	1.5	10.0	14.3	19.4	735,546.9	0.00	1.00
08/22/2024 08:00	1	1.5	10.1	14.3	19.6	733,472.0	0.00	1.00
08/22/2024 09:00	1	1.5	10.1	14.3	20.4	732,642.0	0.00	1.00
08/22/2024 10:00	1	1.5	10.2	14.3	19.5	733,057.0	0.00	1.00
08/22/2024 11:00	1	1.5	10.1	14.3	20.0	735,546.9	0.00	1.00
08/22/2024 12:00	1	1.5	9.6	14.4	18.4	747,284.4	0.00	1.00
08/22/2024 13:00	1	1.5	9.6	14.4	18.8	747,705.7	0.00	1.00
08/22/2024 14:00	1	1.4	9.6	14.4	19.3	746,652.3	0.00	1.00
08/22/2024 15:00	1	1.5	9.6	14.4	17.7	745,809.6	0.00	1.00
08/22/2024 16:00	1	1.5	9.5	14.4	18.5	744,545.5	0.00	1.00
08/22/2024 17:00	1	1.5	9.6	14.4	19.4	745,177.5	0.00	1.00
08/22/2024 18:00	1	1.5	9.7	14.4	18.3	744,756.2	0.00	1.00
08/22/2024 19:00	1	1.5	9.8	14.3	19.7	732,227.1	0.00	1.00
08/22/2024 20:00	1	1.5	9.8	14.3	19.3	733,264.5	0.00	1.00
08/22/2024 21:00	1	1.5	9.8	14.3	18.8	733,264.5	0.00	1.00
08/22/2024 22:00	1	1.5	9.8	14.3	19.0	734,094.5	0.00	1.00
08/22/2024 23:00	1	1.5	9.9	14.3	19.1	734,302.0	0.00	1.00
Average/Sum#:	1	1.5	9.8	14.3	19.2	736,976.2	0.00 #	24.00 #
Minimum:	1	1.4	9.5	14.3	17.7	724,757.5	0.00	1.00
Maximum:	1	1.5	10.2	14.4	21.1	755,465.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2024 00:00	1	1.5	10.3	14.3	20.6	734,302.0	0.00	1.00
08/23/2024 01:00	1	1.5	10.4	14.3	21.1	734,924.4	0.00	1.00
08/23/2024 02:00	1	1.6	10.7	14.3	18.8	734,716.9	0.00	1.00
08/23/2024 03:00	1	1.6	10.6	14.3	22.2	734,716.9	0.00	1.00
08/23/2024 04:00	1	1.5	10.5	14.3	20.7	735,131.9	0.00	1.00
08/23/2024 05:00	1	1.5	10.4	14.2	21.0	724,773.0	0.00	1.00
08/23/2024 06:00	1	1.5	10.3	14.3	20.9	737,206.8	0.00	1.00
08/23/2024 07:00	1	1.6	10.3	14.3	19.9	737,414.3	0.00	1.00
08/23/2024 08:00	1	1.5	10.3	14.3	20.6	735,754.4	0.00	1.00
08/23/2024 09:00	1	1.5	10.3	14.3	21.3	735,339.4	0.00	1.00
08/23/2024 10:00	1	1.5	10.5	14.3	20.9	735,961.9	0.00	1.00
08/23/2024 11:00	1	1.5	10.6	14.4	22.0	748,969.8	0.00	1.00
08/23/2024 12:00	1	1.5	10.7	14.4	21.3	748,548.4	0.00	1.00
08/23/2024 13:00	1	1.5	10.6	14.4	22.0	747,705.7	0.00	1.00
08/23/2024 14:00	1	1.5	10.6	14.4	21.0	747,284.4	0.00	1.00
08/23/2024 15:00	1	1.5	10.6	14.4	20.7	747,705.7	0.00	1.00
08/23/2024 16:00	1	1.5	10.5	14.3	20.7	735,961.9	0.00	1.00
08/23/2024 17:00	1	1.5	10.5	14.3	20.8	735,339.4	0.00	1.00
08/23/2024 18:00	1	1.5	10.5	14.3	21.4	735,339.4	0.00	1.00
08/23/2024 19:00	1	1.5	10.5	14.3	20.4	735,546.9	0.00	1.00
08/23/2024 20:00	1	1.6	10.4	14.3	20.3	735,339.4	0.00	1.00
08/23/2024 21:00	1	1.5	10.5	14.3	21.0	735,131.9	0.00	1.00
08/23/2024 22:00	1	1.5	10.5	14.3	20.9	734,924.4	0.00	1.00
08/23/2024 23:00	1	1.5	8.9	14.4	17.0	797,847.7	0.00	1.00
Average/Sum#:	1	1.5	10.4	14.3	20.7	740,245.3	0.00 #	24.00 #
Minimum:	1	1.5	8.9	14.2	17.0	724,773.0	0.00	1.00
Maximum:	1	1.6	10.7	14.4	22.2	797,847.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/24/2024 00:00	1	1.6	10.1	14.3	19.5	734,302.0	0.00	1.00
08/24/2024 01:00	1	1.5	10.2	14.3	20.8	735,961.9	0.00	1.00
08/24/2024 02:00	1	1.6	10.6	14.3	18.0	735,961.9	0.00	1.00
08/24/2024 03:00	1	1.6	10.4	14.3	20.0	735,961.9	0.00	1.00
08/24/2024 04:00	1	1.5	10.1	14.3	19.1	742,186.5	0.00	1.00
08/24/2024 05:00	1	1.6	8.9	14.3	17.3	778,704.5	0.00	1.00
08/24/2024 06:00	0	1.5	8.8	14.3	15.1	754,843.3	0.00	1.00
08/24/2024 07:00	0	1.6	7.9	14.2	12.2	724,568.6	0.00	1.00
08/24/2024 08:00	0	1.4	7.8	14.2	12.2	724,977.4	0.00	1.00
08/24/2024 09:00	0	1.4	7.9	14.3	13.7	738,244.2	0.00	1.00
08/24/2024 10:00	0	1.4	7.9	14.3	12.7	738,036.7	0.00	1.00
08/24/2024 11:00	0	1.4	7.9	14.3	14.0	738,451.7	0.00	1.00
08/24/2024 12:00	0	1.4	7.9	14.3	11.9	738,244.2	0.00	1.00
08/24/2024 13:00	1	1.6	10.1	14.3	20.3	736,791.8	0.00	1.00
08/24/2024 14:00	1	1.5	10.0	14.3	19.8	734,924.4	0.00	1.00
08/24/2024 15:00	1	1.5	10.0	14.3	20.0	738,244.2	0.00	1.00
08/24/2024 16:00	1	1.5	10.3	14.3	20.1	736,791.8	0.00	1.00
08/24/2024 17:00	1	1.5	10.3	14.3	20.5	736,169.4	0.00	1.00
08/24/2024 18:00	1	1.5	10.1	14.3	20.0	735,754.4	0.00	1.00
08/24/2024 19:00	1	1.5	10.1	14.3	20.7	734,716.9	0.00	1.00
08/24/2024 20:00	1	1.5	10.1	14.3	20.3	735,131.9	0.00	1.00
08/24/2024 21:00	1	1.5	10.2	14.3	20.2	737,621.8	0.00	1.00
08/24/2024 22:00	1	1.6	10.6	14.3	21.2	737,621.8	0.00	1.00
08/24/2024 23:00	1	1.5	10.3	14.2	20.7	726,816.9	0.00	1.00
Average/Sum#:	1	1.5	9.5	14.3	17.9	737,959.6	0.00 #	24.00 #
Minimum:	0	1.4	7.8	14.2	11.9	724,568.6	0.00	1.00
Maximum:	1	1.6	10.6	14.3	21.2	778,704.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2024 00:00	1	1.5	10.3	14.2	20.5	727,021.3	0.00	1.00
08/25/2024 01:00	1	1.6	10.5	14.2	20.5	727,021.3	0.00	1.00
08/25/2024 02:00	1	1.4	10.9	14.2	23.0	727,634.4	0.00	1.00
08/25/2024 03:00	1	1.6	10.8	14.2	20.9	729,065.2	0.00	1.00
08/25/2024 04:00	1	1.6	11.4	14.2	23.1	731,313.5	0.00	1.00
08/25/2024 05:00	1	1.6	11.0	14.2	22.8	730,904.7	0.00	1.00
08/25/2024 06:00	1	1.5	10.9	14.2	21.5	732,131.1	0.00	1.00
08/25/2024 07:00	1	1.6	10.7	14.2	21.5	731,313.5	0.00	1.00
08/25/2024 08:00	1	1.5	10.7	14.3	21.8	741,356.6	0.00	1.00
08/25/2024 09:00	1	1.5	10.8	14.3	21.8	741,979.0	0.00	1.00
08/25/2024 10:00	1	1.6	10.9	14.4	22.3	754,026.1	0.00	1.00
08/25/2024 11:00	1	1.5	10.7	14.4	21.3	754,868.9	0.00	1.00
08/25/2024 12:00	1	1.5	10.5	14.4	21.9	753,604.8	0.00	1.00
08/25/2024 13:00	1	1.5	10.6	14.4	22.6	750,655.2	0.00	1.00
08/25/2024 14:00	1	1.5	10.8	14.5	21.7	761,742.3	0.00	1.00
08/25/2024 15:00	1	1.5	10.9	14.5	23.0	762,384.2	0.00	1.00
08/25/2024 16:00	1	1.5	10.0	14.4	19.6	758,239.7	0.00	1.00
08/25/2024 17:00	0	1.4	8.4	14.5	15.5	849,471.1	0.00	1.00
08/25/2024 18:00	0	1.5	7.5	14.6	15.5	927,513.3	0.00	1.00
08/25/2024 19:00	0	1.4	7.6	14.6	17.0	925,991.7	0.00	1.00
08/25/2024 20:00	1	1.4	8.4	14.5	19.0	867,872.7	0.00	1.00
08/25/2024 21:00	1	1.5	10.2	14.4	20.1	749,391.2	0.00	1.00
08/25/2024 22:00	1	1.5	10.0	14.4	20.3	750,023.2	0.00	1.00
08/25/2024 23:00	1	1.5	9.6	14.4	19.3	762,453.4	0.00	1.00
Average/Sum#:	1	1.5	10.2	14.4	20.7	768,665.8	0.00 #	24.00 #
Minimum:	0	1.4	7.5	14.2	15.5	727,021.3	0.00	1.00
Maximum:	1	1.6	11.4	14.6	23.1	927,513.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2024 00:00	1	1.5	10.0	14.3	20.0	739,281.7	0.00	1.00
08/26/2024 01:00	1	1.5	10.0	14.3	18.2	739,281.7	0.00	1.00
08/26/2024 02:00	1	1.6	10.2	14.3	18.6	739,281.7	0.00	1.00
08/26/2024 03:00	1	1.6	10.2	14.3	18.4	739,696.7	0.00	1.00
08/26/2024 04:00	0	1.5	8.8	14.4	16.5	819,547.8	0.00	1.00
08/26/2024 05:00	0	1.5	7.7	14.4	15.7	891,179.3	0.00	1.00
08/26/2024 06:00	1	1.5	10.1	14.2	21.9	746,234.1	0.00	1.00
08/26/2024 07:00	1	1.4	10.2	14.2	20.3	733,970.6	0.00	1.00
08/26/2024 08:00	1	1.5	10.3	14.2	20.3	734,583.8	0.00	1.00
08/26/2024 09:00	1	1.5	10.3	14.4	20.2	754,658.2	0.00	1.00
08/26/2024 10:00	1	1.5	10.3	14.4	21.3	749,812.5	0.00	1.00
08/26/2024 11:00	1	1.5	10.2	14.5	21.0	762,598.2	0.00	1.00
08/26/2024 12:00	1	1.5	10.1	14.5	20.0	762,812.2	0.00	1.00
08/26/2024 13:00	1	1.5	10.2	14.5	19.9	759,602.6	0.00	1.00
08/26/2024 14:00	1	1.3	9.5	14.5	18.9	759,602.6	0.00	1.00
08/26/2024 15:00	0	1.3	7.4	14.5	11.6	758,960.7	0.00	1.00
08/26/2024 16:00	0	1.3	7.2	14.5	11.7	801,541.2	0.00	1.00
08/26/2024 17:00	0	1.5	8.0	14.4	14.8	834,716.8	0.00	1.00
08/26/2024 18:00	0	1.4	7.3	14.4	14.4	855,995.6	0.00	1.00
08/26/2024 19:00	1	1.4	8.5	14.4	16.8	780,361.2	0.00	1.00
08/26/2024 20:00	1	1.4	9.2	14.5	19.1	780,357.9	0.00	1.00
08/26/2024 21:00	1	1.4	9.9	14.4	19.3	746,020.3	0.00	1.00
08/26/2024 22:00	1	1.5	9.9	14.4	19.0	745,809.6	0.00	1.00
08/26/2024 23:00	1	1.4	9.9	14.4	19.2	745,388.2	0.00	1.00
Average/Sum#:	1	1.5	9.4	14.4	18.2	770,054.0	0.00 #	24.00 #
Minimum:	0	1.3	7.2	14.2	11.6	733,970.6	0.00	1.00
Maximum:	1	1.6	10.3	14.5	21.9	891,179.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2024 00:00	1	1.5	9.8	14.4	18.6	747,073.7	0.00	1.00
08/27/2024 01:00	1	1.5	9.8	14.4	18.4	747,495.0	0.00	1.00
08/27/2024 02:00	0	1.3	10.1	14.3	20.2	735,131.9	0.00	1.00
08/27/2024 03:00	1	1.6	10.0	14.3	18.7	734,509.4	0.00	1.00
08/27/2024 04:00	1	1.5	10.2	14.3	18.9	734,924.4	0.00	1.00
08/27/2024 05:00	1	1.6	10.1	14.3	18.5	735,961.9	0.00	1.00
08/27/2024 06:00	1	1.5	9.9	14.3	19.9	738,659.2	0.00	1.00
08/27/2024 07:00	1	1.5	9.8	14.3	17.8	738,659.2	0.00	1.00
08/27/2024 08:00	1	1.5	9.8	14.3	19.2	736,999.3	0.00	1.00
08/27/2024 09:00	1	1.5	9.8	14.4	19.5	748,127.1	0.00	1.00
08/27/2024 10:00	1	1.5	9.6	14.4	18.2	748,337.8	0.00	1.00
08/27/2024 11:00	0	1.4	8.8	14.5	14.6	763,026.1	0.00	1.00
08/27/2024 12:00	0	1.3	7.1	14.5	11.0	763,026.1	0.00	1.00
08/27/2024 13:00	0	1.4	7.2	14.5	10.1	759,816.6	0.00	1.00
08/27/2024 14:00	0	1.5	7.3	14.5	10.1	759,174.6	0.00	1.00
08/27/2024 15:00	0	1.4	7.3	14.5	11.1	759,174.6	0.00	1.00
08/27/2024 16:00	0	1.4	7.4	14.6	12.3	777,528.7	0.00	1.00
08/27/2024 17:00	0	1.3	7.1	14.6	12.0	834,044.7	0.00	1.00
08/27/2024 18:00	1	1.4	7.8	14.5	17.0	877,715.4	0.00	1.00
08/27/2024 19:00	0	1.3	7.9	14.5	13.1	757,676.8	0.00	1.00
08/27/2024 20:00	1	1.5	9.8	14.5	19.1	757,890.8	0.00	1.00
08/27/2024 21:00	1	1.5	9.9	14.5	20.1	758,318.8	0.00	1.00
08/27/2024 22:00	1	1.5	9.9	14.4	19.2	746,020.3	0.00	1.00
08/27/2024 23:00	1	1.5	9.7	14.4	19.0	747,916.4	0.00	1.00
Average/Sum#:	1	1.5	9.0	14.4	16.5	758,633.7	0.00 #	24.00 #
Minimum:	0	1.3	7.1	14.3	10.1	734,509.4	0.00	1.00
Maximum:	1	1.6	10.2	14.6	20.2	877,715.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2024 00:00	1	1.5	9.7	14.4	18.6	747,916.4	0.00	1.00
08/28/2024 01:00	1	1.5	9.8	14.4	18.3	747,705.7	0.00	1.00
08/28/2024 02:00	1	1.4	10.2	14.4	18.9	748,337.8	0.00	1.00
08/28/2024 03:00	1	1.5	10.1	14.3	19.3	737,206.8	0.00	1.00
08/28/2024 04:00	1	1.4	9.9	14.4	20.2	759,293.2	0.00	1.00
08/28/2024 05:00	0	1.5	8.4	14.4	15.5	842,090.7	0.00	1.00
08/28/2024 06:00	0	1.4	8.0	14.2	13.1	750,935.1	0.00	1.00
08/28/2024 07:00	0	1.5	7.8	14.2	11.6	729,269.6	0.00	1.00
08/28/2024 08:00	0	1.4	7.8	14.3	11.7	739,904.1	0.00	1.00
08/28/2024 09:00	1	1.6	9.9	14.3	19.1	740,319.1	0.00	1.00
08/28/2024 10:00	1	1.5	9.9	14.3	18.7	740,941.6	0.00	1.00
08/28/2024 11:00	0	1.3	7.8	14.5	12.7	762,170.3	0.00	1.00
08/28/2024 12:00	0	1.4	7.1	14.5	8.8	761,742.3	0.00	1.00
08/28/2024 13:00	0	1.3	7.1	14.5	12.2	758,960.7	0.00	1.00
08/28/2024 14:00	0	1.3	7.1	14.5	9.7	758,318.8	0.00	1.00
08/28/2024 15:00	0	1.3	7.0	14.5	11.4	758,532.7	0.00	1.00
08/28/2024 16:00	0	1.3	7.0	14.5	9.5	764,310.0	0.00	1.00
08/28/2024 17:00	0	1.2	7.1	14.6	12.1	777,528.7	0.00	1.00
08/28/2024 18:00	0	1.3	7.2	14.5	10.3	761,956.3	0.00	1.00
08/28/2024 19:00	0	1.5	7.9	14.5	13.3	758,104.8	0.00	1.00
08/28/2024 20:00	1	1.5	10.2	14.5	20.0	759,388.6	0.00	1.00
08/28/2024 21:00	1	1.5	9.7	14.5	18.3	758,746.7	0.00	1.00
08/28/2024 22:00	1	1.4	9.7	14.4	19.1	748,969.8	0.00	1.00
08/28/2024 23:00	1	1.5	9.8	14.4	18.4	749,601.8	0.00	1.00
Average/Sum#:	0	1.4	8.6	14.4	15.0	756,760.5	0.00 #	24.00 #
Minimum:	0	1.2	7.0	14.2	8.8	729,269.6	0.00	1.00
Maximum:	1	1.6	10.2	14.6	20.2	842,090.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2024 00:00	1	1.4	9.9	14.4	19.3	748,548.4	0.00	1.00
08/29/2024 01:00	1	1.5	10.0	14.3	19.7	736,791.8	0.00	1.00
08/29/2024 02:00	1	1.4	10.1	14.3	19.7	744,883.9	0.00	1.00
08/29/2024 03:00	1	1.5	10.3	14.3	21.5	734,924.4	0.00	1.00
08/29/2024 04:00	1	1.5	10.2	14.3	19.0	735,339.4	0.00	1.00
08/29/2024 05:00	1	1.5	10.1	14.3	19.2	735,546.9	0.00	1.00
08/29/2024 06:00	0	1.5	8.5	14.4	18.8	952,066.0	0.00	1.00
08/29/2024 07:00	1	1.4	8.6	14.4	20.4	969,131.1	0.00	1.00
08/29/2024 08:00	1	1.4	8.4	14.4	20.9	965,760.2	0.00	1.00
08/29/2024 09:00	1	1.5	9.0	14.4	19.1	822,497.4	0.00	1.00
08/29/2024 10:00	1	1.5	9.7	14.4	18.6	756,132.9	0.00	1.00
08/29/2024 11:00	1	1.5	9.8	14.5	19.4	760,672.5	0.00	1.00
08/29/2024 12:00	0	1.4	9.0	14.5	15.4	760,672.5	0.00	1.00
08/29/2024 13:00	0	1.4	7.1	14.5	9.6	758,532.7	0.00	1.00
08/29/2024 14:00	0	1.4	7.2	14.5	9.9	758,532.7	0.00	1.00
08/29/2024 15:00	0	1.4	7.5	14.5	10.5	757,890.8	0.00	1.00
08/29/2024 16:00	0	1.2	7.5	14.5	13.6	757,462.9	0.00	1.00
08/29/2024 17:00	0	1.3	7.3	14.5	10.0	758,960.7	0.00	1.00
08/29/2024 18:00	0	1.5	8.3	14.5	14.9	759,388.6	0.00	1.00
08/29/2024 19:00	1	1.4	9.5	14.4	18.4	747,495.0	0.00	1.00
08/29/2024 20:00	1	1.5	9.4	14.4	17.3	746,652.3	0.00	1.00
08/29/2024 21:00	1	1.5	9.6	14.4	17.3	746,652.3	0.00	1.00
08/29/2024 22:00	1	1.4	9.7	14.4	19.2	747,284.4	0.00	1.00
08/29/2024 23:00	1	1.4	9.8	14.4	19.3	747,705.7	0.00	1.00
Average/Sum#:	1	1.4	9.0	14.4	17.1	779,563.6	0.00 #	24.00 #
Minimum:	0	1.2	7.1	14.3	9.6	734,924.4	0.00	1.00
Maximum:	1	1.5	10.3	14.5	21.5	969,131.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2024 00:00	1	1.5	9.9	14.3	18.5	736,584.3	0.00	1.00
08/30/2024 01:00	1	1.5	10.1	14.3	18.8	736,169.4	0.00	1.00
08/30/2024 02:00	1	1.5	10.6	14.3	19.8	736,376.8	0.00	1.00
08/30/2024 03:00	1	1.6	10.2	14.3	18.9	736,169.4	0.00	1.00
08/30/2024 04:00	1	1.6	10.1	14.3	18.3	738,036.7	0.00	1.00
08/30/2024 05:00	1	1.5	10.5	14.3	20.3	737,414.3	0.00	1.00
08/30/2024 06:00	1	1.5	10.5	14.3	21.1	739,074.2	0.00	1.00
08/30/2024 07:00	1	1.5	10.4	14.3	19.3	739,696.7	0.00	1.00
08/30/2024 08:00	1	1.5	10.4	14.3	21.0	738,451.7	0.00	1.00
08/30/2024 09:00	1	1.5	10.5	14.4	19.8	749,601.8	0.00	1.00
08/30/2024 10:00	1	1.5	10.4	14.4	20.2	749,601.8	0.00	1.00
08/30/2024 11:00	1	1.4	10.0	14.4	18.4	749,812.5	0.00	1.00
08/30/2024 12:00	0	1.4	8.3	14.5	12.5	761,528.3	0.00	1.00
08/30/2024 13:00	0	1.3	7.4	14.5	10.7	759,174.6	0.00	1.00
08/30/2024 14:00	0	1.2	7.4	14.5	12.0	759,388.6	0.00	1.00
08/30/2024 15:00	0	1.4	7.4	14.5	10.4	759,174.6	0.00	1.00
08/30/2024 16:00	0	1.4	7.3	14.6	10.8	785,788.8	0.00	1.00
08/30/2024 17:00	0	1.5	7.4	14.5	9.6	761,100.4	0.00	1.00
08/30/2024 18:00	0	1.5	8.3	14.5	14.5	760,886.4	0.00	1.00
08/30/2024 19:00	1	1.5	9.8	14.4	18.2	748,969.8	0.00	1.00
08/30/2024 20:00	1	1.5	9.8	14.4	18.5	747,705.7	0.00	1.00
08/30/2024 21:00	1	1.5	9.6	14.4	18.1	752,130.0	0.00	1.00
08/30/2024 22:00	1	1.4	9.9	14.4	18.7	747,284.4	0.00	1.00
08/30/2024 23:00	1	1.5	9.9	14.4	18.0	748,548.4	0.00	1.00
Average/Sum#:	1	1.5	9.4	14.4	16.9	749,111.2	0.00 #	24.00 #
Minimum:	0	1.2	7.3	14.3	9.6	736,169.4	0.00	1.00
Maximum:	1	1.6	10.6	14.6	21.1	785,788.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2024 00:00	1	1.6	10.2	14.3	19.8	738,451.7	0.00	1.00
08/31/2024 01:00	1	1.5	10.1	14.3	19.1	736,999.3	0.00	1.00
08/31/2024 02:00	1	1.6	10.7	14.3	19.3	737,206.8	0.00	1.00
08/31/2024 03:00	1	1.6	10.5	14.3	19.5	737,206.8	0.00	1.00
08/31/2024 04:00	1	1.6	10.5	14.3	19.4	736,584.3	0.00	1.00
08/31/2024 05:00	1	1.5	10.3	14.3	19.1	736,584.3	0.00	1.00
08/31/2024 06:00	1	1.5	10.1	14.3	19.3	738,244.2	0.00	1.00
08/31/2024 07:00	1	1.5	10.1	14.3	19.3	738,659.2	0.00	1.00
08/31/2024 08:00	1	1.5	10.0	14.3	18.9	737,621.8	0.00	1.00
08/31/2024 09:00	1	1.5	10.0	14.4	19.1	748,337.8	0.00	1.00
08/31/2024 10:00	1	1.5	10.0	14.4	20.2	748,548.4	0.00	1.00
08/31/2024 11:00	1	1.5	10.1	14.4	19.6	750,655.2	0.00	1.00
08/31/2024 12:00	0	1.3	8.3	14.5	12.8	762,598.2	0.00	1.00
08/31/2024 13:00	0	1.3	7.3	14.5	9.8	762,598.2	0.00	1.00
08/31/2024 14:00	0	1.3	7.4	14.5	11.5	763,454.1	0.00	1.00
08/31/2024 15:00	0	1.3	7.2	14.5	10.0	781,427.8	0.00	1.00
08/31/2024 16:00	0	1.4	8.6	14.2	17.0	855,788.0	0.00	1.00
08/31/2024 17:00	1	2.0	12.7	12.5	30.7	963,977.0	0.00	1.00
08/31/2024 18:00	1	2.0	12.6	12.6	29.4	967,671.6	0.00	1.00
08/31/2024 19:00	1	2.0	13.0	12.5	31.4	970,498.0	0.00	1.00
08/31/2024 20:00	1	1.8	9.9	13.5	22.3	938,425.8	0.00	1.00
08/31/2024 21:00	0	1.4	6.9	14.5	12.9	910,667.2	0.00	1.00
08/31/2024 22:00	0	1.4	7.0	14.6	14.1	929,252.3	0.00	1.00
08/31/2024 23:00	0	1.5	7.5	14.5	15.3	878,785.3	0.00	1.00
Average/Sum#:	1	1.5	9.6	14.1	18.7	807,093.5	0.00 #	24.00 #
Minimum:	0	1.3	6.9	12.5	9.8	736,584.3	0.00	1.00
Maximum:	1	2.0	13.0	14.6	31.4	970,498.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2024 00:00	1	1.5	9.7	14.3	18.8	749,033.6	0.00	1.00
09/01/2024 01:00	1	1.5	10.0	14.3	18.3	741,771.5	0.00	1.00
09/01/2024 02:00	1	1.5	10.3	14.3	18.8	741,771.5	0.00	1.00
09/01/2024 03:00	1	1.6	10.1	14.3	18.1	741,979.0	0.00	1.00
09/01/2024 04:00	1	1.5	10.0	14.3	18.0	741,771.5	0.00	1.00
09/01/2024 05:00	1	1.5	9.9	14.3	18.9	742,601.5	0.00	1.00
09/01/2024 06:00	1	1.5	10.2	14.3	19.9	744,883.9	0.00	1.00
09/01/2024 07:00	1	1.6	10.2	14.3	19.2	744,676.4	0.00	1.00
09/01/2024 08:00	1	1.5	10.3	14.3	20.1	743,016.5	0.00	1.00
09/01/2024 09:00	1	1.5	10.3	14.4	18.9	753,604.8	0.00	1.00
09/01/2024 10:00	1	1.5	10.1	14.4	19.1	752,551.4	0.00	1.00
09/01/2024 11:00	1	1.5	9.9	14.4	18.2	754,026.1	0.00	1.00
09/01/2024 12:00	1	1.5	9.9	14.5	18.6	765,593.8	0.00	1.00
09/01/2024 13:00	0	1.3	7.7	14.5	9.9	763,026.1	0.00	1.00
09/01/2024 14:00	0	1.4	7.5	14.5	10.1	762,812.2	0.00	1.00
09/01/2024 15:00	0	1.4	8.4	14.4	14.8	753,183.4	0.00	1.00
09/01/2024 16:00	0	1.4	8.9	14.3	15.3	774,554.7	0.00	1.00
09/01/2024 17:00	0	1.4	7.7	14.4	12.8	822,708.0	0.00	1.00
09/01/2024 18:00	1	1.5	8.9	14.3	15.7	746,543.8	0.00	1.00
09/01/2024 19:00	1	1.5	9.9	14.3	18.1	742,601.5	0.00	1.00
09/01/2024 20:00	1	1.4	10.1	14.3	19.2	742,809.0	0.00	1.00
09/01/2024 21:00	1	1.5	9.9	14.3	18.6	756,918.2	0.00	1.00
09/01/2024 22:00	1	1.4	10.2	14.3	18.7	750,278.6	0.00	1.00
09/01/2024 23:00	1	1.5	10.1	14.2	19.8	744,190.2	0.00	1.00
Average/Sum#:	1	1.5	9.6	14.3	17.4	753,204.5	0.00 #	24.00 #
Minimum:	0	1.3	7.5	14.2	9.9	741,771.5	0.00	1.00
Maximum:	1	1.6	10.3	14.5	20.1	822,708.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/02/2024 00:00	1	1.5	9.7	14.3	19.2	763,765.3	0.00	1.00
09/02/2024 01:00	1	1.6	10.4	14.2	19.0	732,335.5	0.00	1.00
09/02/2024 02:00	1	1.5	10.7	14.2	19.6	732,335.5	0.00	1.00
09/02/2024 03:00	1	1.6	10.6	14.2	18.7	732,335.5	0.00	1.00
09/02/2024 04:00	1	1.5	10.7	14.2	21.5	732,335.5	0.00	1.00
09/02/2024 05:00	1	1.6	10.8	14.2	20.6	732,539.8	0.00	1.00
09/02/2024 06:00	1	1.5	10.4	14.2	18.7	733,766.2	0.00	1.00
09/02/2024 07:00	1	1.5	10.1	14.2	19.3	733,357.4	0.00	1.00
09/02/2024 08:00	1	1.6	10.1	14.2	18.7	732,948.6	0.00	1.00
09/02/2024 09:00	1	1.6	9.9	14.2	17.8	733,153.0	0.00	1.00
09/02/2024 10:00	1	1.5	9.9	14.2	18.7	733,766.2	0.00	1.00
09/02/2024 11:00	1	1.6	9.9	14.3	18.0	747,581.2	0.00	1.00
09/02/2024 12:00	1	1.5	9.9	14.3	18.0	748,203.7	0.00	1.00
09/02/2024 13:00	1	1.5	9.9	14.3	17.9	746,336.3	0.00	1.00
09/02/2024 14:00	0	1.4	8.7	14.4	14.3	788,156.4	0.00	1.00
09/02/2024 15:00	0	1.3	7.7	14.5	11.8	780,144.0	0.00	1.00
09/02/2024 16:00	0	1.4	7.6	14.5	13.6	839,200.4	0.00	1.00
09/02/2024 17:00	0	1.5	7.6	14.4	13.1	841,037.3	0.00	1.00
09/02/2024 18:00	0	1.3	7.7	14.4	14.1	848,200.4	0.00	1.00
09/02/2024 19:00	1	1.4	8.4	14.4	16.4	786,681.6	0.00	1.00
09/02/2024 20:00	1	1.4	8.7	14.4	16.5	777,833.1	0.00	1.00
09/02/2024 21:00	1	1.5	9.8	14.3	17.7	739,281.7	0.00	1.00
09/02/2024 22:00	1	1.5	9.9	14.3	18.9	739,904.1	0.00	1.00
09/02/2024 23:00	1	1.5	9.8	14.3	18.0	740,111.6	0.00	1.00
Average/Sum#:	1	1.5	9.5	14.3	17.5	758,971.3	0.00 #	24.00 #
Minimum:	0	1.3	7.6	14.2	11.8	732,335.5	0.00	1.00
Maximum:	1	1.6	10.8	14.5	21.5	848,200.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2024 00:00	1	1.5	10.0	14.3	18.3	740,111.6	0.00	1.00
09/03/2024 01:00	1	1.5	9.9	14.3	19.3	740,319.1	0.00	1.00
09/03/2024 02:00	1	1.4	10.7	14.3	21.2	741,771.5	0.00	1.00
09/03/2024 03:00	1	1.5	10.7	14.3	21.8	741,149.1	0.00	1.00
09/03/2024 04:00	1	1.5	10.7	14.3	21.0	739,489.2	0.00	1.00
09/03/2024 05:00	1	1.5	9.5	14.4	18.0	805,642.9	0.00	1.00
09/03/2024 06:00	1	1.5	9.6	14.3	18.9	762,520.4	0.00	1.00
09/03/2024 07:00	1	1.5	9.8	14.4	19.3	791,105.9	0.00	1.00
09/03/2024 08:00	1	1.5	10.6	14.4	21.4	751,919.3	0.00	1.00
09/03/2024 09:00	1	1.5	10.3	14.4	19.7	749,812.5	0.00	1.00
09/03/2024 10:00	1	1.5	10.2	14.4	19.2	749,601.8	0.00	1.00
09/03/2024 11:00	1	1.5	9.9	14.4	17.6	752,972.7	0.00	1.00
09/03/2024 12:00	0	1.3	7.5	14.5	10.1	764,096.0	0.00	1.00
09/03/2024 13:00	0	1.4	7.4	14.5	11.9	843,907.8	0.00	1.00
09/03/2024 14:00	0	1.4	7.7	14.4	14.3	864,212.1	0.00	1.00
09/03/2024 15:00	0	1.4	7.3	14.4	11.5	842,512.0	0.00	1.00
09/03/2024 16:00	1	1.6	9.0	13.9	19.2	889,930.2	0.00	1.00
09/03/2024 17:00	1	2.1	12.5	12.5	31.7	972,943.4	0.00	1.00
09/03/2024 18:00	1	2.1	13.3	12.4	32.9	972,935.7	0.00	1.00
09/03/2024 19:00	1	1.8	10.2	13.4	24.3	953,302.0	0.00	1.00
09/03/2024 20:00	0	1.4	7.0	14.5	14.1	940,837.3	0.00	1.00
09/03/2024 21:00	0	1.4	7.1	14.5	15.7	942,763.1	0.00	1.00
09/03/2024 22:00	1	1.4	8.2	14.4	16.2	830,924.6	0.00	1.00
09/03/2024 23:00	0	1.4	7.9	14.6	17.6	941,207.6	0.00	1.00
Average/Sum#:	1	1.5	9.5	14.2	19.0	826,082.8	0.00 #	24.00 #
Minimum:	0	1.3	7.0	12.4	10.1	739,489.2	0.00	1.00
Maximum:	1	2.1	13.3	14.6	32.9	972,943.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2024 00:00	0	1.5	8.1	14.5	15.6	838,558.5	0.00	1.00
09/04/2024 01:00	1	1.4	8.2	14.4	16.4	823,972.1	0.00	1.00
09/04/2024 02:00	1	1.4	10.4	14.4	21.3	754,026.1	0.00	1.00
09/04/2024 03:00	0	1.4	7.5	14.5	14.1	876,003.7	0.00	1.00
09/04/2024 04:00	0	1.3	7.7	14.4	15.7	869,479.1	0.00	1.00
09/04/2024 05:00	0	1.5	7.4	14.5	14.6	930,994.6	0.00	1.00
09/04/2024 06:00	1	1.5	9.3	14.3	19.5	772,687.3	0.00	1.00
09/04/2024 07:00	1	1.5	10.0	14.3	17.7	741,149.1	0.00	1.00
09/04/2024 08:00	1	1.5	10.0	14.4	17.6	751,076.6	0.00	1.00
09/04/2024 09:00	1	1.5	9.9	14.4	19.0	750,444.6	0.00	1.00
09/04/2024 10:00	0	1.3	8.2	14.5	12.4	761,742.3	0.00	1.00
09/04/2024 11:00	0	1.2	7.4	14.5	11.3	763,454.1	0.00	1.00
09/04/2024 12:00	0	0.0	0.0	0.0	11.0	233,719.5	0.00	1.00
09/04/2024 13:00	0	0.0	6.3	0.0	20.6	254,359.1	0.00	1.00
09/04/2024 14:00	0	0.9	7.0	14.6	10.8	879,909.5	0.00	1.00
09/04/2024 15:00	0	1.4	8.6	14.5	14.5	770,943.1	0.00	1.00
09/04/2024 16:00	0	1.6	9.0	14.0	17.4	895,682.9	0.00	1.00
09/04/2024 17:00	1	2.2	13.2	12.2	34.3	977,643.1	0.00	1.00
09/04/2024 18:00	1	2.1	13.0	12.4	33.8	981,313.4	0.00	1.00
09/04/2024 19:00	1	2.1	13.0	12.6	31.7	985,160.6	0.00	1.00
09/04/2024 20:00	1	2.0	13.0	12.7	32.4	995,504.7	0.00	1.00
09/04/2024 21:00	1	2.0	12.7	12.7	31.2	987,488.6	0.00	1.00
09/04/2024 22:00	1	1.9	12.0	12.9	29.4	988,210.9	0.00	1.00
09/04/2024 23:00	1	1.7	9.9	13.6	23.4	945,090.4	0.00	1.00
Average/Sum#:	1	1.6	9.6	13.9	20.2	865,478.9	0.00 #	24.00 #
Minimum:	0	0.9	6.3	12.2	10.8	741,149.1	0.00	1.00
Maximum:	1	2.2	13.2	14.6	34.3	995,504.7	0.00	1.00
%SI	8.33	8.33	4.17	8.33	0.00	8.33	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2024 00:00	0	1.4	7.8	14.6	15.1	853,825.2	0.00	1.00
09/05/2024 01:00	1	1.5	8.5	14.5	16.1	782,711.6	0.00	1.00
09/05/2024 02:00	1	1.4	10.1	14.5	18.8	763,026.1	0.00	1.00
09/05/2024 03:00	1	1.5	9.9	14.5	19.8	762,812.2	0.00	1.00
09/05/2024 04:00	0	1.4	7.9	14.6	14.0	835,566.2	0.00	1.00
09/05/2024 05:00	0	1.4	7.4	14.7	14.0	943,135.8	0.00	1.00
09/05/2024 06:00	1	1.4	9.1	14.6	20.3	832,523.1	0.00	1.00
09/05/2024 07:00	1	1.5	9.8	14.5	18.2	764,310.0	0.00	1.00
09/05/2024 08:00	1	1.5	9.7	14.5	19.3	763,240.1	0.00	1.00
09/05/2024 09:00	0	1.4	9.2	14.6	17.1	798,396.2	0.00	1.00
09/05/2024 10:00	0	1.3	7.1	14.6	11.8	888,821.6	0.00	1.00
09/05/2024 11:00	0	1.3	7.2	14.6	11.7	824,915.2	0.00	1.00
09/05/2024 12:00	0	1.4	6.9	14.7	12.2	954,842.2	0.00	1.00
09/05/2024 13:00	1	1.5	8.7	14.0	19.9	923,666.8	0.00	1.00
09/05/2024 14:00	1	2.2	13.1	12.2	34.4	974,652.4	0.00	1.00
09/05/2024 15:00	1	2.0	12.3	12.6	30.1	970,311.4	0.00	1.00
09/05/2024 16:00	1	2.1	12.8	12.5	33.0	972,291.3	0.00	1.00
09/05/2024 17:00	2	2.2	13.5	12.3	35.9	977,227.6	0.00	1.00
09/05/2024 18:00	1	2.1	13.5	12.4	34.7	976,157.9	0.00	1.00
09/05/2024 19:00	1	2.0	13.1	12.6	32.9	983,180.7	0.00	1.00
09/05/2024 20:00	1	2.0	12.9	12.8	32.1	994,607.9	0.00	1.00
09/05/2024 21:00	1	2.0	12.4	12.9	30.3	992,319.1	0.00	1.00
09/05/2024 22:00	1	1.9	11.5	13.1	28.8	990,550.3	0.00	1.00
09/05/2024 23:00	1	1.8	10.5	13.4	24.7	988,359.2	0.00	1.00
Average/Sum#:	1	1.7	10.2	13.8	22.7	896,310.4	0.00 #	24.00 #
Minimum:	0	1.3	6.9	12.2	11.7	762,812.2	0.00	1.00
Maximum:	2	2.2	13.5	14.7	35.9	994,607.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2024 00:00	1	1.5	8.6	14.6	18.1	851,216.8	0.00	1.00
09/06/2024 01:00	1	1.4	10.0	14.6	20.8	773,398.7	0.00	1.00
09/06/2024 02:00	0	1.5	10.1	14.5	17.5	761,528.3	0.00	1.00
09/06/2024 03:00	0	1.4	9.8	14.5	20.3	761,528.3	0.00	1.00
09/06/2024 04:00	0	1.4	8.8	14.6	16.5	828,393.1	0.00	1.00
09/06/2024 05:00	0	1.4	7.6	14.7	15.5	938,939.2	0.00	1.00
09/06/2024 06:00	1	1.4	8.3	14.6	18.0	874,475.3	0.00	1.00
09/06/2024 07:00	1	1.4	8.4	14.6	17.5	853,390.5	0.00	1.00
09/06/2024 08:00	1	1.5	10.1	14.5	20.1	760,886.4	0.00	1.00
09/06/2024 09:00	1	1.4	9.7	14.6	19.3	773,398.7	0.00	1.00
09/06/2024 10:00	0	1.3	7.3	14.6	8.8	774,268.2	0.00	1.00
09/06/2024 11:00	0	1.3	7.1	14.7	11.4	818,120.6	0.00	1.00
09/06/2024 12:00	0	1.3	6.8	14.7	11.2	921,931.8	0.00	1.00
09/06/2024 13:00	1	1.7	9.2	13.9	20.6	923,578.9	0.00	1.00
09/06/2024 14:00	1	2.1	13.5	12.4	34.6	975,835.7	0.00	1.00
09/06/2024 15:00	2	2.2	13.4	12.2	36.3	970,717.3	0.00	1.00
09/06/2024 16:00	1	2.0	12.4	12.6	31.7	966,681.6	0.00	1.00
09/06/2024 17:00	2	2.2	13.2	12.3	35.8	980,730.8	0.00	1.00
09/06/2024 18:00	2	2.2	13.3	12.1	37.9	971,824.5	0.00	1.00
09/06/2024 19:00	1	2.0	13.0	12.6	32.5	977,076.0	0.00	1.00
09/06/2024 20:00	1	2.0	12.9	12.7	31.5	985,818.6	0.00	1.00
09/06/2024 21:00	1	2.1	13.3	12.5	33.4	978,975.4	0.00	1.00
09/06/2024 22:00	1	2.0	12.9	12.6	31.4	974,106.2	0.00	1.00
09/06/2024 23:00	1	2.1	13.3	12.6	32.5	986,150.5	0.00	1.00
Average/Sum#:	1	1.7	10.5	13.7	23.9	890,957.1	0.00 #	24.00 #
Minimum:	0	1.3	6.8	12.1	8.8	760,886.4	0.00	1.00
Maximum:	2	2.2	13.5	14.7	37.9	986,150.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2024 00:00	1	2.0	12.7	12.8	31.0	989,874.0	0.00	1.00
09/07/2024 01:00	1	1.7	9.8	13.7	21.9	948,897.0	0.00	1.00
09/07/2024 02:00	1	1.4	9.8	14.4	19.3	756,132.9	0.00	1.00
09/07/2024 03:00	1	1.5	9.9	14.4	18.0	761,189.3	0.00	1.00
09/07/2024 04:00	1	1.5	10.3	14.4	19.7	751,708.6	0.00	1.00
09/07/2024 05:00	1	1.4	10.5	14.5	22.4	760,458.5	0.00	1.00
09/07/2024 06:00	1	1.4	10.5	14.5	21.5	761,528.3	0.00	1.00
09/07/2024 07:00	1	1.5	10.4	14.6	20.8	774,268.2	0.00	1.00
09/07/2024 08:00	1	1.4	10.4	14.6	22.0	773,833.5	0.00	1.00
09/07/2024 09:00	0	1.4	9.5	14.6	16.7	773,833.5	0.00	1.00
09/07/2024 10:00	0	1.5	7.7	14.7	10.0	786,535.5	0.00	1.00
09/07/2024 11:00	0	1.4	7.5	14.7	10.8	788,081.6	0.00	1.00
09/07/2024 12:00	0	1.3	7.6	14.7	15.9	903,157.5	0.00	1.00
09/07/2024 13:00	0	1.3	7.7	14.7	16.5	970,524.3	0.00	1.00
09/07/2024 14:00	1	1.8	10.9	13.2	24.4	970,512.8	0.00	1.00
09/07/2024 15:00	1	1.8	10.8	13.3	25.0	979,498.8	0.00	1.00
09/07/2024 16:00	1	1.7	9.9	13.5	23.6	974,512.0	0.00	1.00
09/07/2024 17:00	1	2.0	12.8	12.7	33.1	984,983.5	0.00	1.00
09/07/2024 18:00	1	2.1	13.3	12.6	33.5	980,705.8	0.00	1.00
09/07/2024 19:00	1	2.0	12.8	12.8	32.6	983,956.8	0.00	1.00
09/07/2024 20:00	1	2.0	13.2	12.7	33.1	985,651.6	0.00	1.00
09/07/2024 21:00	1	2.0	13.2	12.8	33.1	995,115.1	0.00	1.00
09/07/2024 22:00	1	2.0	13.6	12.8	35.1	1,003,061.1	0.00	1.00
09/07/2024 23:00	1	1.9	12.1	13.2	30.3	996,656.4	0.00	1.00
Average/Sum#:	1	1.7	10.7	13.8	23.8	889,778.2	0.00 #	24.00 #
Minimum:	0	1.3	7.5	12.6	10.0	751,708.6	0.00	1.00
Maximum:	1	2.1	13.6	14.7	35.1	1,003,061.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2024 00:00	1	1.3	8.4	14.5	17.5	866,802.8	0.00	1.00
09/08/2024 01:00	1	1.5	10.1	14.4	19.6	753,394.1	0.00	1.00
09/08/2024 02:00	1	1.3	10.7	14.4	20.8	754,447.5	0.00	1.00
09/08/2024 03:00	1	1.5	10.6	14.4	21.4	755,079.5	0.00	1.00
09/08/2024 04:00	1	1.5	10.6	14.4	21.0	755,290.2	0.00	1.00
09/08/2024 05:00	1	1.5	10.6	14.4	20.3	755,079.5	0.00	1.00
09/08/2024 06:00	1	1.5	10.5	14.4	20.6	755,290.2	0.00	1.00
09/08/2024 07:00	1	1.5	10.4	14.5	21.4	765,379.8	0.00	1.00
09/08/2024 08:00	1	1.5	10.4	14.5	21.1	764,524.0	0.00	1.00
09/08/2024 09:00	1	1.5	10.2	14.6	20.4	774,702.9	0.00	1.00
09/08/2024 10:00	1	1.4	10.3	14.6	21.0	774,702.9	0.00	1.00
09/08/2024 11:00	0	1.3	7.7	14.6	12.6	776,441.9	0.00	1.00
09/08/2024 12:00	0	1.2	7.1	14.7	10.1	808,181.3	0.00	1.00
09/08/2024 13:00	0	1.5	7.7	14.5	14.8	910,881.2	0.00	1.00
09/08/2024 14:00	1	1.9	11.5	13.1	27.9	984,581.0	0.00	1.00
09/08/2024 15:00	1	2.0	12.3	12.8	30.7	983,956.8	0.00	1.00
09/08/2024 16:00	2	2.2	13.4	12.3	35.4	976,749.9	0.00	1.00
09/08/2024 17:00	2	2.2	13.4	12.2	37.1	981,263.4	0.00	1.00
09/08/2024 18:00	1	2.1	13.4	12.4	35.0	985,180.0	0.00	1.00
09/08/2024 19:00	1	2.1	13.4	12.5	34.0	985,659.5	0.00	1.00
09/08/2024 20:00	1	2.1	13.3	12.6	33.5	990,440.3	0.00	1.00
09/08/2024 21:00	1	1.8	10.1	13.6	23.7	935,148.0	0.00	1.00
09/08/2024 22:00	0	1.3	8.0	14.5	16.4	874,719.8	0.00	1.00
09/08/2024 23:00	1	1.4	8.9	14.5	17.3	813,309.7	0.00	1.00
Average/Sum#:	1	1.6	10.5	13.9	23.1	853,383.6	0.00 #	24.00 #
Minimum:	0	1.2	7.1	12.2	10.1	753,394.1	0.00	1.00
Maximum:	2	2.2	13.4	14.7	37.1	990,440.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2024 00:00	1	1.5	9.6	14.4	17.8	755,079.5	0.00	1.00
09/09/2024 01:00	1	1.5	9.7	14.5	19.0	765,379.8	0.00	1.00
09/09/2024 02:00	1	1.5	10.3	14.5	18.7	765,379.8	0.00	1.00
09/09/2024 03:00	1	1.5	10.0	14.5	20.9	764,737.9	0.00	1.00
09/09/2024 04:00	0	1.5	8.9	14.5	15.5	813,737.6	0.00	1.00
09/09/2024 05:00	0	1.5	8.0	14.5	16.4	897,614.9	0.00	1.00
09/09/2024 06:00	1	1.5	10.2	14.4	21.1	777,411.7	0.00	1.00
09/09/2024 07:00	1	1.5	10.1	14.4	20.3	758,661.1	0.00	1.00
09/09/2024 08:00	1	1.4	10.1	14.4	19.9	756,765.0	0.00	1.00
09/09/2024 09:00	1	1.4	10.0	14.6	19.5	776,224.5	0.00	1.00
09/09/2024 10:00	0	1.4	9.3	14.6	15.7	777,746.1	0.00	1.00
09/09/2024 11:00	0	1.3	7.4	14.6	9.9	777,746.1	0.00	1.00
09/09/2024 12:00	0	1.3	7.0	14.7	11.4	827,176.5	0.00	1.00
09/09/2024 13:00	0	1.3	7.7	14.6	11.9	810,134.1	0.00	1.00
09/09/2024 14:00	0	1.3	7.2	14.7	10.3	786,756.4	0.00	1.00
09/09/2024 15:00	0	1.4	6.9	14.7	8.9	834,907.1	0.00	1.00
09/09/2024 16:00	0	1.3	7.0	14.6	12.5	885,561.1	0.00	1.00
09/09/2024 17:00	1	1.5	9.2	14.0	19.1	892,507.5	0.00	1.00
09/09/2024 18:00	1	1.9	11.7	13.0	26.9	981,651.9	0.00	1.00
09/09/2024 19:00	1	1.5	9.2	14.0	21.0	888,736.6	0.00	1.00
09/09/2024 20:00	1	1.3	8.7	14.6	17.7	811,003.6	0.00	1.00
09/09/2024 21:00	0	1.4	9.0	14.6	16.0	795,353.0	0.00	1.00
09/09/2024 22:00	1	1.4	9.5	14.5	18.4	763,668.1	0.00	1.00
09/09/2024 23:00	0	1.3	7.8	14.6	15.1	872,301.6	0.00	1.00
Average/Sum#:	1	1.4	8.9	14.4	16.8	814,010.1	0.00 #	24.00 #
Minimum:	0	1.3	6.9	13.0	8.9	755,079.5	0.00	1.00
Maximum:	1	1.9	11.7	14.7	26.9	981,651.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2024 00:00	1	1.4	9.1	14.5	17.4	794,052.2	0.00	1.00
09/10/2024 01:00	1	1.5	10.0	14.5	18.5	763,668.1	0.00	1.00
09/10/2024 02:00	0	1.3	10.5	14.4	20.9	752,130.0	0.00	1.00
09/10/2024 03:00	1	1.6	10.5	14.4	18.9	752,130.0	0.00	1.00
09/10/2024 04:00	1	1.5	10.5	14.4	19.7	752,340.7	0.00	1.00
09/10/2024 05:00	0	1.4	8.3	14.5	13.8	841,126.1	0.00	1.00
09/10/2024 06:00	1	1.5	10.2	14.4	22.0	769,616.5	0.00	1.00
09/10/2024 07:00	1	1.5	10.5	14.4	19.7	754,236.8	0.00	1.00
09/10/2024 08:00	1	1.5	10.4	14.4	19.8	753,183.4	0.00	1.00
09/10/2024 09:00	1	1.5	10.6	14.5	19.4	764,310.0	0.00	1.00
09/10/2024 10:00	1	1.5	10.5	14.5	20.9	764,096.0	0.00	1.00
09/10/2024 11:00	1	1.5	10.1	14.5	18.4	764,310.0	0.00	1.00
09/10/2024 12:00	1	1.4	9.9	14.5	19.6	763,882.0	0.00	1.00
09/10/2024 13:00	1	1.4	9.8	14.6	18.4	774,702.9	0.00	1.00
09/10/2024 14:00	1	1.4	9.8	14.6	18.7	776,224.5	0.00	1.00
09/10/2024 15:00	1	1.4	9.7	14.6	19.2	775,572.4	0.00	1.00
09/10/2024 16:00	1	1.4	9.7	14.6	18.4	774,268.2	0.00	1.00
09/10/2024 17:00	1	1.4	9.7	14.6	18.0	773,181.4	0.00	1.00
09/10/2024 18:00	1	1.4	9.7	14.5	19.4	761,100.4	0.00	1.00
09/10/2024 19:00	1	1.4	9.7	14.5	18.9	761,314.4	0.00	1.00
09/10/2024 20:00	1	1.5	9.8	14.4	18.0	749,601.8	0.00	1.00
09/10/2024 21:00	1	1.5	10.1	14.4	19.2	749,601.8	0.00	1.00
09/10/2024 22:00	1	1.5	10.2	14.4	18.6	749,180.5	0.00	1.00
09/10/2024 23:00	1	1.4	10.4	14.4	20.6	750,233.9	0.00	1.00
Average/Sum#:	1	1.5	10.0	14.5	19.0	766,002.7	0.00 #	24.00 #
Minimum:	0	1.3	8.3	14.4	13.8	749,180.5	0.00	1.00
Maximum:	1	1.6	10.6	14.6	22.0	841,126.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2024 00:00	1	1.5	10.4	14.4	19.1	750,444.6	0.00	1.00
09/11/2024 01:00	1	1.5	10.5	14.4	19.6	750,023.2	0.00	1.00
09/11/2024 02:00	1	1.5	10.9	14.4	19.8	749,601.8	0.00	1.00
09/11/2024 03:00	1	1.6	10.7	14.4	18.8	749,601.8	0.00	1.00
09/11/2024 04:00	1	1.5	10.6	14.4	20.4	749,601.8	0.00	1.00
09/11/2024 05:00	0	1.4	9.2	14.5	16.3	825,292.2	0.00	1.00
09/11/2024 06:00	1	1.5	9.7	14.4	20.1	778,465.1	0.00	1.00
09/11/2024 07:00	1	1.5	10.5	14.4	19.2	750,023.2	0.00	1.00
09/11/2024 08:00	1	1.5	10.6	14.4	20.1	750,444.6	0.00	1.00
09/11/2024 09:00	1	1.5	10.8	14.4	20.6	750,444.6	0.00	1.00
09/11/2024 10:00	1	1.5	10.7	14.5	21.0	763,668.1	0.00	1.00
09/11/2024 11:00	1	1.5	10.6	14.5	20.3	765,593.8	0.00	1.00
09/11/2024 12:00	1	1.5	10.3	14.5	19.8	764,524.0	0.00	1.00
09/11/2024 13:00	1	1.5	10.1	14.6	19.4	773,181.4	0.00	1.00
09/11/2024 14:00	1	1.4	10.1	14.6	19.4	772,094.5	0.00	1.00
09/11/2024 15:00	1	1.5	10.0	14.6	18.7	772,094.5	0.00	1.00
09/11/2024 16:00	1	1.4	10.0	14.6	19.7	772,311.9	0.00	1.00
09/11/2024 17:00	1	1.4	10.3	14.6	20.7	771,225.0	0.00	1.00
09/11/2024 18:00	1	1.4	10.2	14.5	19.4	759,388.6	0.00	1.00
09/11/2024 19:00	1	1.4	10.2	14.5	20.0	760,244.5	0.00	1.00
09/11/2024 20:00	1	1.5	10.3	14.5	20.4	760,672.5	0.00	1.00
09/11/2024 21:00	1	1.5	10.3	14.5	19.6	761,100.4	0.00	1.00
09/11/2024 22:00	1	1.5	10.0	14.4	18.9	748,759.1	0.00	1.00
09/11/2024 23:00	1	1.5	9.9	14.4	18.4	748,969.8	0.00	1.00
Average/Sum#:	1	1.5	10.3	14.5	19.6	762,407.1	0.00 #	24.00 #
Minimum:	0	1.4	9.2	14.4	16.3	748,759.1	0.00	1.00
Maximum:	1	1.6	10.9	14.6	21.0	825,292.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/12/2024 00:00	1	1.5	9.9	14.4	18.3	749,391.2	0.00	1.00
09/12/2024 01:00	1	1.5	10.0	14.4	19.5	748,969.8	0.00	1.00
09/12/2024 02:00	1	1.5	10.4	14.4	18.4	749,812.5	0.00	1.00
09/12/2024 03:00	1	1.6	10.6	14.4	20.1	750,655.2	0.00	1.00
09/12/2024 04:00	1	1.4	10.5	14.4	21.3	750,233.9	0.00	1.00
09/12/2024 05:00	1	1.5	10.5	14.4	19.8	750,233.9	0.00	1.00
09/12/2024 06:00	1	1.5	10.5	14.4	19.9	752,340.7	0.00	1.00
09/12/2024 07:00	1	1.4	10.4	14.4	21.2	752,130.0	0.00	1.00
09/12/2024 08:00	1	1.5	10.4	14.4	23.7	752,762.0	0.00	1.00
09/12/2024 09:00	0	1.4	10.3	14.3	20.3	740,941.6	0.00	1.00
09/12/2024 10:00	1	1.5	10.2	14.4	19.2	753,183.4	0.00	1.00
09/12/2024 11:00	1	1.5	10.1	14.4	19.3	751,287.3	0.00	1.00
09/12/2024 12:00	1	1.4	10.1	14.4	21.1	751,708.6	0.00	1.00
09/12/2024 13:00	1	1.5	10.0	14.5	17.7	760,672.5	0.00	1.00
09/12/2024 14:00	1	1.5	10.0	14.5	19.4	760,886.4	0.00	1.00
09/12/2024 15:00	1	1.5	10.1	14.5	19.4	760,886.4	0.00	1.00
09/12/2024 16:00	1	1.4	10.1	14.5	21.2	760,672.5	0.00	1.00
09/12/2024 17:00	1	1.5	10.1	14.5	20.1	759,816.6	0.00	1.00
09/12/2024 18:00	1	1.5	10.0	14.5	19.8	760,030.5	0.00	1.00
09/12/2024 19:00	1	1.4	10.1	14.4	19.6	748,969.8	0.00	1.00
09/12/2024 20:00	1	1.5	10.1	14.4	20.3	748,337.8	0.00	1.00
09/12/2024 21:00	1	1.5	10.2	14.4	20.0	749,180.5	0.00	1.00
09/12/2024 22:00	1	1.5	10.3	14.4	20.2	748,969.8	0.00	1.00
09/12/2024 23:00	1	1.4	9.9	14.3	18.0	741,149.1	0.00	1.00
Average/Sum#:	1	1.5	10.2	14.4	19.9	752,217.6	0.00 #	24.00 #
Minimum:	0	1.4	9.9	14.3	17.7	740,941.6	0.00	1.00
Maximum:	1	1.6	10.6	14.5	23.7	760,886.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2024 00:00	1	1.5	9.9	14.3	18.6	738,244.2	0.00	1.00
09/13/2024 01:00	1	1.5	10.0	14.3	18.1	738,451.7	0.00	1.00
09/13/2024 02:00	1	1.4	10.5	14.3	20.1	737,829.3	0.00	1.00
09/13/2024 03:00	1	1.4	10.4	14.3	20.7	737,414.3	0.00	1.00
09/13/2024 04:00	1	1.5	9.8	14.3	18.3	749,863.6	0.00	1.00
09/13/2024 05:00	0	1.4	8.6	14.5	16.2	881,780.9	0.00	1.00
09/13/2024 06:00	1	1.4	9.7	14.4	22.0	818,073.1	0.00	1.00
09/13/2024 07:00	1	1.5	10.6	14.3	19.4	740,941.6	0.00	1.00
09/13/2024 08:00	1	1.5	10.5	14.4	19.6	751,287.3	0.00	1.00
09/13/2024 09:00	1	1.5	10.1	14.4	20.0	749,180.5	0.00	1.00
09/13/2024 10:00	1	1.5	10.0	14.4	18.8	749,601.8	0.00	1.00
09/13/2024 11:00	1	1.4	9.7	14.5	19.7	768,375.5	0.00	1.00
09/13/2024 12:00	0	1.4	8.4	14.5	13.5	793,410.3	0.00	1.00
09/13/2024 13:00	0	1.4	8.1	14.5	15.8	865,305.0	0.00	1.00
09/13/2024 14:00	0	1.4	8.4	14.5	16.3	877,073.5	0.00	1.00
09/13/2024 15:00	1	1.4	8.5	14.5	17.4	868,300.6	0.00	1.00
09/13/2024 16:00	0	1.4	8.1	14.4	17.3	933,947.4	0.00	1.00
09/13/2024 17:00	2	2.3	13.8	12.1	37.6	981,939.5	0.00	1.00
09/13/2024 18:00	2	2.1	13.3	12.3	37.2	975,635.3	0.00	1.00
09/13/2024 19:00	1	1.5	9.0	14.2	19.7	843,115.8	0.00	1.00
09/13/2024 20:00	1	1.5	9.2	14.3	16.5	747,373.7	0.00	1.00
09/13/2024 21:00	1	1.6	9.5	14.3	17.0	738,451.7	0.00	1.00
09/13/2024 22:00	1	1.4	9.0	14.4	16.2	764,770.8	0.00	1.00
09/13/2024 23:00	0	1.4	8.0	14.5	14.8	830,855.5	0.00	1.00
Average/Sum#:	1	1.5	9.7	14.2	19.6	807,551.0	0.00 #	24.00 #
Minimum:	0	1.4	8.0	12.1	13.5	737,414.3	0.00	1.00
Maximum:	2	2.3	13.8	14.5	37.6	981,939.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2024 00:00	0	1.4	7.8	14.5	15.6	837,274.6	0.00	1.00
09/14/2024 01:00	1	1.4	9.0	14.4	17.3	758,871.8	0.00	1.00
09/14/2024 02:00	1	1.5	10.1	14.4	17.9	748,969.8	0.00	1.00
09/14/2024 03:00	0	1.5	7.7	14.6	14.6	916,427.5	0.00	1.00
09/14/2024 04:00	1	1.4	8.8	14.5	18.6	893,549.4	0.00	1.00
09/14/2024 05:00	1	1.4	8.3	14.6	19.9	975,117.1	0.00	1.00
09/14/2024 06:00	1	1.5	9.6	14.4	19.4	791,948.7	0.00	1.00
09/14/2024 07:00	1	1.5	9.7	14.4	18.6	750,444.6	0.00	1.00
09/14/2024 08:00	1	1.4	9.7	14.4	18.5	748,969.8	0.00	1.00
09/14/2024 09:00	1	1.5	9.6	14.5	17.9	760,458.5	0.00	1.00
09/14/2024 10:00	1	1.5	9.6	14.5	19.1	761,314.4	0.00	1.00
09/14/2024 11:00	1	1.5	9.6	14.5	17.6	765,593.8	0.00	1.00
09/14/2024 12:00	0	1.3	7.2	14.5	9.0	767,091.6	0.00	1.00
09/14/2024 13:00	0	1.4	7.1	14.5	10.4	765,807.8	0.00	1.00
09/14/2024 14:00	0	1.3	7.2	14.5	9.2	766,449.7	0.00	1.00
09/14/2024 15:00	0	1.3	7.2	14.5	11.2	763,668.1	0.00	1.00
09/14/2024 16:00	0	1.4	7.1	14.6	10.5	819,698.3	0.00	1.00
09/14/2024 17:00	0	1.3	7.9	14.5	15.9	893,977.4	0.00	1.00
09/14/2024 18:00	1	1.4	8.6	14.4	17.2	846,725.6	0.00	1.00
09/14/2024 19:00	1	1.4	9.4	14.3	18.0	737,621.8	0.00	1.00
09/14/2024 20:00	1	1.5	9.6	14.4	18.4	747,073.7	0.00	1.00
09/14/2024 21:00	1	1.5	9.6	14.4	18.0	747,495.0	0.00	1.00
09/14/2024 22:00	1	1.5	9.7	14.4	18.1	747,916.4	0.00	1.00
09/14/2024 23:00	1	1.5	9.6	14.4	19.1	752,340.7	0.00	1.00
Average/Sum#:	1	1.4	8.7	14.5	16.3	794,366.9	0.00 #	24.00 #
Minimum:	0	1.3	7.1	14.3	9.0	737,621.8	0.00	1.00
Maximum:	1	1.5	10.1	14.6	19.9	975,117.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2024 00:00	1	1.5	9.7	14.4	18.2	752,340.7	0.00	1.00
09/15/2024 01:00	1	1.5	9.7	14.4	18.5	752,551.4	0.00	1.00
09/15/2024 02:00	1	1.5	10.2	14.3	18.0	741,149.1	0.00	1.00
09/15/2024 03:00	1	1.6	10.0	14.3	17.7	740,941.6	0.00	1.00
09/15/2024 04:00	1	1.6	9.9	14.3	19.3	741,149.1	0.00	1.00
09/15/2024 05:00	1	1.5	10.0	14.3	18.4	741,564.1	0.00	1.00
09/15/2024 06:00	1	1.5	10.0	14.3	19.8	741,564.1	0.00	1.00
09/15/2024 07:00	1	1.5	10.0	14.3	18.6	741,979.0	0.00	1.00
09/15/2024 08:00	1	1.5	9.9	14.3	17.3	740,941.6	0.00	1.00
09/15/2024 09:00	1	1.4	9.9	14.3	20.0	740,941.6	0.00	1.00
09/15/2024 10:00	1	1.5	9.8	14.3	18.4	739,074.2	0.00	1.00
09/15/2024 11:00	1	1.5	9.9	14.3	18.4	740,319.1	0.00	1.00
09/15/2024 12:00	1	1.5	9.9	14.4	18.0	750,023.2	0.00	1.00
09/15/2024 13:00	1	1.5	9.9	14.4	18.8	747,916.4	0.00	1.00
09/15/2024 14:00	1	1.5	9.9	14.4	18.1	748,127.1	0.00	1.00
09/15/2024 15:00	1	1.4	9.9	14.4	18.6	748,337.8	0.00	1.00
09/15/2024 16:00	0	1.5	9.0	14.4	15.8	800,797.2	0.00	1.00
09/15/2024 17:00	1	1.5	10.0	14.3	19.2	738,659.2	0.00	1.00
09/15/2024 18:00	1	1.5	10.1	14.3	18.5	736,584.3	0.00	1.00
09/15/2024 19:00	1	1.4	10.0	14.3	20.3	736,791.8	0.00	1.00
09/15/2024 20:00	1	1.5	10.1	14.3	18.6	736,999.3	0.00	1.00
09/15/2024 21:00	1	1.5	10.1	14.3	18.9	737,206.8	0.00	1.00
09/15/2024 22:00	1	1.5	10.3	14.3	19.8	738,036.7	0.00	1.00
09/15/2024 23:00	1	1.5	10.5	14.3	20.4	738,244.2	0.00	1.00
Average/Sum#:	1	1.5	9.9	14.3	18.7	744,676.7	0.00 #	24.00 #
Minimum:	0	1.4	9.0	14.3	15.8	736,584.3	0.00	1.00
Maximum:	1	1.6	10.5	14.4	20.4	800,797.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2024 00:00	1	1.5	10.5	14.3	19.8	738,659.2	0.00	1.00
09/16/2024 01:00	1	1.5	10.6	14.3	20.1	738,866.7	0.00	1.00
09/16/2024 02:00	1	1.5	11.0	14.3	20.7	739,074.2	0.00	1.00
09/16/2024 03:00	1	1.6	10.8	14.3	21.3	738,659.2	0.00	1.00
09/16/2024 04:00	1	1.5	10.6	14.3	20.3	738,244.2	0.00	1.00
09/16/2024 05:00	1	1.5	9.2	14.4	17.3	823,550.8	0.00	1.00
09/16/2024 06:00	1	1.5	9.2	14.4	19.0	821,022.6	0.00	1.00
09/16/2024 07:00	0	1.4	7.9	14.5	16.1	922,649.7	0.00	1.00
09/16/2024 08:00	1	1.5	8.5	14.3	20.0	954,654.8	0.02	1.00
09/16/2024 09:00	0	1.4	7.7	14.5	17.0	962,662.5	0.00	1.00
09/16/2024 10:00	0	1.4	7.7	14.6	17.3	975,117.1	0.00	1.00
09/16/2024 11:00	0	1.4	7.7	14.6	18.2	975,117.1	0.00	1.00
09/16/2024 12:00	1	1.3	8.1	14.5	17.2	856,318.2	0.00	1.00
09/16/2024 13:00	1	1.5	9.8	14.4	19.9	750,444.6	0.00	1.00
09/16/2024 14:00	1	1.5	9.9	14.4	18.0	749,180.5	0.00	1.00
09/16/2024 15:00	1	1.5	10.1	14.4	18.9	749,812.5	0.00	1.00
09/16/2024 16:00	1	1.5	9.3	14.5	17.3	816,305.3	0.00	1.00
09/16/2024 17:00	1	1.4	9.7	14.3	20.0	748,203.7	0.00	1.00
09/16/2024 18:00	1	1.5	10.0	14.4	19.6	755,079.5	0.00	1.00
09/16/2024 19:00	1	1.5	10.0	14.4	18.9	755,500.9	0.00	1.00
09/16/2024 20:00	0	1.4	8.0	14.5	14.8	897,828.9	0.00	1.00
09/16/2024 21:00	1	1.4	8.3	14.4	17.0	839,141.1	0.00	1.00
09/16/2024 22:00	0	1.4	8.0	14.5	15.8	890,125.8	0.00	1.00
09/16/2024 23:00	1	1.5	9.8	14.4	20.2	772,566.0	0.00	1.00
Average/Sum#:	1	1.5	9.3	14.4	18.5	821,199.4	0.02 #	24.00 #
Minimum:	0	1.3	7.7	14.3	14.8	738,244.2	0.00	1.00
Maximum:	1	1.6	11.0	14.6	21.3	975,117.1	0.02	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2024 00:00	1	1.5	10.1	14.4	18.4	749,601.8	0.00	1.00
09/17/2024 01:00	1	1.5	10.1	14.3	19.0	739,489.2	0.00	1.00
09/17/2024 02:00	1	1.6	10.5	14.3	17.5	739,074.2	0.00	1.00
09/17/2024 03:00	1	1.5	10.7	14.3	21.9	740,111.6	0.00	1.00
09/17/2024 04:00	0	1.4	9.5	14.4	16.7	791,948.7	0.00	1.00
09/17/2024 05:00	0	1.4	8.4	14.4	16.9	882,752.0	0.00	1.00
09/17/2024 06:00	1	1.5	10.1	14.3	21.4	780,156.9	0.00	1.00
09/17/2024 07:00	1	1.5	10.7	14.3	20.3	743,638.9	0.00	1.00
09/17/2024 08:00	1	1.5	10.6	14.3	21.0	744,676.4	0.00	1.00
09/17/2024 09:00	1	1.5	10.6	14.3	20.6	746,751.3	0.00	1.00
09/17/2024 10:00	1	1.5	10.7	14.4	21.5	754,658.2	0.00	1.00
09/17/2024 11:00	1	1.5	10.3	14.4	19.0	757,607.7	0.00	1.00
09/17/2024 12:00	1	1.5	10.0	14.4	20.1	758,239.7	0.00	1.00
09/17/2024 13:00	1	1.5	10.0	14.4	19.4	757,397.0	0.00	1.00
09/17/2024 14:00	1	1.5	9.9	14.4	19.1	757,818.4	0.00	1.00
09/17/2024 15:00	1	1.5	9.9	14.4	20.3	757,818.4	0.00	1.00
09/17/2024 16:00	1	1.5	10.0	14.4	19.7	757,186.3	0.00	1.00
09/17/2024 17:00	1	1.5	10.2	14.4	20.0	753,183.4	0.00	1.00
09/17/2024 18:00	1	1.5	10.3	14.4	18.8	751,708.6	0.00	1.00
09/17/2024 19:00	1	1.5	10.3	14.4	19.4	752,551.4	0.00	1.00
09/17/2024 20:00	1	1.4	10.1	14.4	20.2	756,132.9	0.00	1.00
09/17/2024 21:00	1	1.5	10.2	14.3	19.3	745,921.3	0.00	1.00
09/17/2024 22:00	1	1.4	10.2	14.3	19.8	745,506.3	0.00	1.00
09/17/2024 23:00	1	1.5	10.3	14.3	20.7	742,186.5	0.00	1.00
Average/Sum#:	1	1.5	10.2	14.4	19.6	758,588.2	0.00 #	24.00 #
Minimum:	0	1.4	8.4	14.3	16.7	739,074.2	0.00	1.00
Maximum:	1	1.6	10.7	14.4	21.9	882,752.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/18/2024 00:00	1	1.5	10.3	14.3	18.8	741,771.5	0.00	1.00
09/18/2024 01:00	1	1.5	10.2	14.3	19.2	742,394.0	0.00	1.00
09/18/2024 02:00	1	1.3	10.7	14.3	21.4	739,904.1	0.00	1.00
09/18/2024 03:00	1	1.5	10.5	14.3	21.2	739,281.7	0.00	1.00
09/18/2024 04:00	1	1.5	10.4	14.3	20.0	739,696.7	0.00	1.00
09/18/2024 05:00	1	1.5	10.4	14.3	19.3	748,618.7	0.00	1.00
09/18/2024 06:00	1	1.4	9.6	14.4	18.6	802,061.3	0.00	1.00
09/18/2024 07:00	1	1.5	10.4	14.3	19.8	740,734.1	0.00	1.00
09/18/2024 08:00	1	1.5	10.7	14.3	20.6	740,734.1	0.00	1.00
09/18/2024 09:00	1	1.5	10.6	14.3	21.3	742,809.0	0.00	1.00
09/18/2024 10:00	1	1.4	10.6	14.3	20.9	743,016.5	0.00	1.00
09/18/2024 11:00	1	1.5	10.6	14.4	20.5	755,711.6	0.00	1.00
09/18/2024 12:00	1	1.5	10.3	14.4	20.4	754,868.9	0.00	1.00
09/18/2024 13:00	1	1.4	10.0	14.4	19.6	754,658.2	0.00	1.00
09/18/2024 14:00	1	1.4	10.1	14.4	20.3	754,236.8	0.00	1.00
09/18/2024 15:00	1	1.5	10.0	14.4	18.7	752,551.4	0.00	1.00
09/18/2024 16:00	0	1.3	8.8	14.5	17.1	847,331.3	0.00	1.00
09/18/2024 17:00	0	1.3	8.0	14.5	15.1	854,606.4	0.00	1.00
09/18/2024 18:00	1	1.5	9.7	14.4	18.5	751,287.3	0.00	1.00
09/18/2024 19:00	1	1.5	9.5	14.4	18.1	752,130.0	0.00	1.00
09/18/2024 20:00	0	1.4	7.8	14.5	14.6	951,963.9	0.00	1.00
09/18/2024 21:00	0	1.4	7.9	14.5	17.0	959,453.0	0.00	1.00
09/18/2024 22:00	0	1.4	7.7	14.5	16.0	959,239.0	0.00	1.00
09/18/2024 23:00	0	1.5	7.5	14.5	14.6	953,675.7	0.00	1.00
Average/Sum#:	1	1.4	9.7	14.4	18.8	792,614.0	0.00 #	24.00 #
Minimum:	0	1.3	7.5	14.3	14.6	739,281.7	0.00	1.00
Maximum:	1	1.5	10.7	14.5	21.4	959,453.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/19/2024 00:00	0	1.4	7.5	14.5	15.8	958,597.1	0.00	1.00
09/19/2024 01:00	0	1.4	7.5	14.5	16.1	940,409.4	0.00	1.00
09/19/2024 02:00	0	1.6	7.5	14.5	12.6	917,086.4	0.00	1.00
09/19/2024 03:00	0	1.5	7.8	14.5	17.9	955,387.5	0.00	1.00
09/19/2024 04:00	0	1.5	7.8	14.5	15.8	958,169.1	0.00	1.00
09/19/2024 05:00	0	1.5	7.7	14.5	16.5	953,247.8	0.00	1.00
09/19/2024 06:00	1	1.5	9.3	14.4	19.9	819,758.5	0.00	1.00
09/19/2024 07:00	0	1.4	7.3	14.5	13.6	934,418.2	0.00	1.00
09/19/2024 08:00	1	1.4	8.3	14.3	16.1	772,687.3	0.00	1.00
09/19/2024 09:00	1	1.5	9.8	14.4	18.1	748,548.4	0.00	1.00
09/19/2024 10:00	1	1.5	9.9	14.4	18.9	749,180.5	0.00	1.00
09/19/2024 11:00	1	1.4	9.9	14.4	17.9	747,916.4	0.00	1.00
09/19/2024 12:00	1	1.5	9.8	14.4	19.4	750,023.2	0.00	1.00
09/19/2024 13:00	1	1.5	9.8	14.5	18.6	757,890.8	0.00	1.00
09/19/2024 14:00	1	1.5	9.9	14.5	19.2	757,676.8	0.00	1.00
09/19/2024 15:00	1	1.5	9.9	14.5	19.0	758,960.7	0.00	1.00
09/19/2024 16:00	0	1.4	8.5	14.6	14.8	854,477.3	0.00	1.00
09/19/2024 17:00	0	1.4	8.0	14.3	16.2	930,793.6	0.00	1.00
09/19/2024 18:00	1	2.0	11.8	12.8	27.3	969,586.3	0.00	1.00
09/19/2024 19:00	1	1.8	9.5	13.5	22.4	966,924.6	0.00	1.00
09/19/2024 20:00	0	1.4	7.3	14.5	14.4	956,885.3	0.00	1.00
09/19/2024 21:00	0	1.5	7.4	14.5	14.3	936,771.9	0.00	1.00
09/19/2024 22:00	1	1.4	9.0	14.4	17.6	756,554.3	0.00	1.00
09/19/2024 23:00	1	1.4	9.5	14.4	16.8	753,604.8	0.00	1.00
Average/Sum#:	1	1.5	8.8	14.3	17.5	858,564.8	0.00 #	24.00 #
Minimum:	0	1.4	7.3	12.8	12.6	747,916.4	0.00	1.00
Maximum:	1	2.0	11.8	14.6	27.3	969,586.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2024 00:00	1	1.5	9.9	14.3	19.2	731,604.6	0.00	1.00
09/20/2024 01:00	1	1.4	10.0	14.3	18.0	730,359.7	0.00	1.00
09/20/2024 02:00	1	1.6	10.8	14.3	19.4	732,019.6	0.00	1.00
09/20/2024 03:00	1	1.5	10.7	14.3	20.1	729,529.7	0.00	1.00
09/20/2024 04:00	1	1.4	9.9	14.3	19.5	745,091.4	0.00	1.00
09/20/2024 05:00	0	1.5	9.2	14.4	15.4	799,322.5	0.00	1.00
09/20/2024 06:00	0	1.6	8.4	14.3	17.1	757,540.7	0.00	1.00
09/20/2024 07:00	0	0.0	0.0	0.0	38.7	231,229.6	0.00	1.00
09/20/2024 08:00	0	1.3	10.4	14.3	13.1	729,737.2	0.00	1.00
09/20/2024 09:00	1	1.5	10.3	14.4	19.5	746,863.0	0.00	1.00
09/20/2024 10:00	0	1.4	9.0	14.5	15.8	808,816.3	0.00	1.00
09/20/2024 11:00	0	1.5	7.3	14.5	13.0	933,348.3	0.00	1.00
09/20/2024 12:00	0	1.4	7.6	14.5	16.1	937,199.8	0.00	1.00
09/20/2024 13:00	0	1.4	7.2	14.5	11.0	850,540.9	0.00	1.00
09/20/2024 14:00	0	1.5	8.0	14.4	13.9	823,761.4	0.00	1.00
09/20/2024 15:00	0	1.3	8.2	14.5	13.3	753,825.3	0.00	1.00
09/20/2024 16:00	0	1.4	6.9	14.6	9.3	807,090.9	0.00	1.00
09/20/2024 17:00	0	1.3	7.6	14.5	13.4	810,100.1	0.00	1.00
09/20/2024 18:00	1	1.5	9.3	14.5	17.9	752,969.4	0.00	1.00
09/20/2024 19:00	1	1.5	9.5	14.5	17.4	751,471.6	0.00	1.00
09/20/2024 20:00	1	1.4	9.4	14.4	17.6	740,331.9	0.00	1.00
09/20/2024 21:00	1	1.5	9.6	14.4	18.3	740,963.9	0.00	1.00
09/20/2024 22:00	1	1.4	9.8	14.4	18.7	739,278.5	0.00	1.00
09/20/2024 23:00	1	1.5	9.7	14.4	17.8	739,910.5	0.00	1.00
Average/Sum#:	1	1.4	9.1	14.4	17.2	777,899.0	0.00 #	24.00 #
Minimum:	0	1.3	6.9	14.3	9.3	729,529.7	0.00	1.00
Maximum:	1	1.6	10.8	14.6	38.7	937,199.8	0.00	1.00
%SI	4.17	4.17	4.17	4.17	0.00	4.17	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/21/2024 00:00	1	1.4	9.8	14.4	18.3	740,121.2	0.00	1.00
09/21/2024 01:00	1	1.5	9.9	14.4	19.0	739,489.2	0.00	1.00
09/21/2024 02:00	1	1.6	10.4	14.4	17.0	741,596.0	0.00	1.00
09/21/2024 03:00	1	1.3	9.0	14.5	18.9	800,257.4	0.00	1.00
09/21/2024 04:00	1	1.4	8.7	14.4	17.7	834,716.8	0.00	1.00
09/21/2024 05:00	1	1.5	9.7	14.4	20.0	755,711.6	0.00	1.00
09/21/2024 06:00	1	1.5	9.1	14.4	16.8	796,583.6	0.00	1.00
09/21/2024 07:00	1	1.5	10.0	14.3	18.4	733,057.0	0.00	1.00
09/21/2024 08:00	1	1.4	9.9	14.4	19.8	744,334.8	0.00	1.00
09/21/2024 09:00	1	1.4	9.8	14.4	20.3	743,281.4	0.00	1.00
09/21/2024 10:00	1	1.4	9.8	14.4	18.9	744,334.8	0.00	1.00
09/21/2024 11:00	0	1.4	8.5	14.5	15.1	825,506.1	0.00	1.00
09/21/2024 12:00	0	1.4	8.0	14.5	14.7	877,287.5	0.00	1.00
09/21/2024 13:00	0	1.4	7.8	14.5	15.9	940,837.3	0.00	1.00
09/21/2024 14:00	0	1.3	7.7	14.5	16.1	931,636.5	0.00	1.00
09/21/2024 15:00	0	1.4	8.3	14.5	14.5	820,370.8	0.00	1.00
09/21/2024 16:00	1	1.8	10.5	13.3	24.0	957,515.9	0.00	1.00
09/21/2024 17:00	1	2.1	12.8	12.5	31.2	957,455.9	0.00	1.00
09/21/2024 18:00	1	1.8	10.2	13.3	24.4	951,389.6	0.00	1.00
09/21/2024 19:00	1	1.6	8.7	13.8	20.6	922,914.9	0.00	1.00
09/21/2024 20:00	1	1.4	8.5	14.5	17.3	793,838.2	0.00	1.00
09/21/2024 21:00	0	1.4	8.4	14.5	14.5	776,078.5	0.00	1.00
09/21/2024 22:00	1	1.4	8.7	14.4	16.6	756,554.3	0.00	1.00
09/21/2024 23:00	1	1.4	9.5	14.4	17.5	742,017.3	0.00	1.00
Average/Sum#:	1	1.5	9.3	14.2	18.6	817,786.9	0.00 #	24.00 #
Minimum:	0	1.3	7.7	12.5	14.5	733,057.0	0.00	1.00
Maximum:	1	2.1	12.8	14.5	31.2	957,515.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/22/2024 00:00	1	1.5	9.6	14.4	16.9	741,596.0	0.00	1.00
09/22/2024 01:00	1	1.5	9.7	14.4	18.7	740,753.3	0.00	1.00
09/22/2024 02:00	1	1.5	10.1	14.4	18.4	741,385.3	0.00	1.00
09/22/2024 03:00	1	1.6	9.9	14.4	15.5	743,281.4	0.00	1.00
09/22/2024 04:00	1	1.5	10.0	14.3	18.3	729,944.7	0.00	1.00
09/22/2024 05:00	1	1.5	10.1	14.3	19.2	728,907.3	0.00	1.00
09/22/2024 06:00	1	1.5	9.9	14.3	18.2	731,604.6	0.00	1.00
09/22/2024 07:00	1	1.5	9.9	14.3	18.0	732,434.6	0.00	1.00
09/22/2024 08:00	1	1.5	9.9	14.4	18.6	742,228.0	0.00	1.00
09/22/2024 09:00	1	1.5	9.9	14.4	18.8	744,756.2	0.00	1.00
09/22/2024 10:00	1	1.5	9.9	14.5	18.7	757,462.9	0.00	1.00
09/22/2024 11:00	1	1.4	9.8	14.5	18.6	757,462.9	0.00	1.00
09/22/2024 12:00	0	1.4	9.3	14.5	16.1	756,393.0	0.00	1.00
09/22/2024 13:00	0	1.4	7.6	14.6	13.5	930,121.7	0.00	1.00
09/22/2024 14:00	0	1.5	8.4	14.5	15.6	830,855.5	0.00	1.00
09/22/2024 15:00	1	1.4	9.2	14.4	16.8	745,388.2	0.00	1.00
09/22/2024 16:00	0	1.4	8.2	14.5	13.5	820,798.7	0.00	1.00
09/22/2024 17:00	0	1.4	7.8	14.5	11.4	757,676.8	0.00	1.00
09/22/2024 18:00	0	1.3	7.1	14.5	10.8	753,611.4	0.00	1.00
09/22/2024 19:00	1	1.4	8.7	14.5	15.6	752,327.5	0.00	1.00
09/22/2024 20:00	1	1.4	9.7	14.5	18.0	747,620.1	0.00	1.00
09/22/2024 21:00	1	1.5	9.6	14.4	17.3	737,803.7	0.00	1.00
09/22/2024 22:00	1	1.4	9.6	14.4	18.1	739,489.2	0.00	1.00
09/22/2024 23:00	1	1.5	9.6	14.4	17.0	742,860.1	0.00	1.00
Average/Sum#:	1	1.5	9.3	14.4	16.7	758,615.1	0.00 #	24.00 #
Minimum:	0	1.3	7.1	14.3	10.8	728,907.3	0.00	1.00
Maximum:	1	1.6	10.1	14.6	19.2	930,121.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2024 00:00	1	1.5	9.8	14.4	18.1	741,174.6	0.00	1.00
09/23/2024 01:00	1	1.5	9.8	14.4	18.2	742,438.7	0.00	1.00
09/23/2024 02:00	0	1.3	10.2	14.4	20.4	741,385.3	0.00	1.00
09/23/2024 03:00	1	1.5	10.2	14.4	19.6	743,281.4	0.00	1.00
09/23/2024 04:00	1	1.4	10.3	14.3	20.4	730,982.1	0.00	1.00
09/23/2024 05:00	1	1.5	10.5	14.3	19.7	728,907.3	0.00	1.00
09/23/2024 06:00	1	1.4	9.8	14.3	18.3	734,302.0	0.00	1.00
09/23/2024 07:00	1	1.5	10.0	14.4	17.6	740,963.9	0.00	1.00
09/23/2024 08:00	1	1.5	10.1	14.4	18.8	739,699.8	0.00	1.00
09/23/2024 09:00	1	1.5	10.1	14.5	21.4	752,755.5	0.00	1.00
09/23/2024 10:00	0	1.4	10.7	14.5	19.5	755,323.1	0.00	1.00
09/23/2024 11:00	0	1.3	8.2	14.5	9.5	755,537.1	0.00	1.00
09/23/2024 12:00	0	1.3	7.6	14.5	9.6	767,947.5	0.00	1.00
09/23/2024 13:00	0	1.3	7.1	14.6	10.6	832,305.7	0.00	1.00
09/23/2024 14:00	0	1.4	8.1	14.5	12.5	829,785.6	0.00	1.00
09/23/2024 15:00	0	1.4	8.4	14.4	13.3	828,607.1	0.00	1.00
09/23/2024 16:00	1	1.7	9.3	13.7	19.7	920,177.1	0.00	1.00
09/23/2024 17:00	1	2.0	13.0	12.5	30.1	945,391.9	0.00	1.00
09/23/2024 18:00	1	1.9	11.8	12.9	25.7	943,875.8	0.00	1.00
09/23/2024 19:00	1	1.8	10.4	13.4	22.1	909,297.8	0.00	1.00
09/23/2024 20:00	0	1.4	7.2	14.5	12.9	926,929.1	0.00	1.00
09/23/2024 21:00	0	1.3	7.5	14.5	14.9	924,361.5	0.00	1.00
09/23/2024 22:00	0	1.4	7.3	14.5	13.5	910,881.2	0.00	1.00
09/23/2024 23:00	0	1.4	7.7	14.4	14.7	856,416.9	0.00	1.00
Average/Sum#:	1	1.5	9.4	14.2	17.5	812,613.7	0.00 #	24.00 #
Minimum:	0	1.3	7.1	12.5	9.5	728,907.3	0.00	1.00
Maximum:	1	2.0	13.0	14.6	30.1	945,391.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2024 00:00	0	1.4	7.2	14.5	10.6	862,951.3	0.00	1.00
09/24/2024 01:00	1	1.6	9.9	14.4	19.5	750,865.9	0.00	1.00
09/24/2024 02:00	1	1.5	10.5	14.4	17.3	741,806.7	0.00	1.00
09/24/2024 03:00	1	1.3	9.5	14.5	17.7	787,419.0	0.00	1.00
09/24/2024 04:00	0	1.4	7.9	14.5	13.9	892,051.6	0.00	1.00
09/24/2024 05:00	0	1.4	7.8	14.5	15.0	925,217.3	0.00	1.00
09/24/2024 06:00	1	1.4	9.6	14.4	18.1	787,735.0	0.00	1.00
09/24/2024 07:00	1	1.5	10.4	14.4	19.0	738,646.4	0.00	1.00
09/24/2024 08:00	1	1.5	10.4	14.4	19.4	734,854.2	0.00	1.00
09/24/2024 09:00	1	1.5	10.3	14.5	18.7	750,615.7	0.00	1.00
09/24/2024 10:00	0	1.5	8.8	14.5	12.1	754,039.3	0.00	1.00
09/24/2024 11:00	0	1.3	7.5	14.6	10.3	765,573.4	0.00	1.00
09/24/2024 12:00	0	1.3	7.2	14.6	10.2	835,566.2	0.00	1.00
09/24/2024 13:00	0	1.3	7.5	14.5	12.6	881,994.9	0.00	1.00
09/24/2024 14:00	0	1.4	7.1	14.6	10.5	901,863.8	0.00	1.00
09/24/2024 15:00	0	1.4	8.7	14.5	14.3	802,825.0	0.00	1.00
09/24/2024 16:00	1	1.5	9.0	14.2	16.1	828,399.6	0.00	1.00
09/24/2024 17:00	1	1.8	10.5	13.2	23.2	936,544.0	0.00	1.00
09/24/2024 18:00	1	1.6	8.9	13.9	18.2	849,630.0	0.00	1.00
09/24/2024 19:00	0	1.4	7.7	14.5	9.5	752,327.5	0.00	1.00
09/24/2024 20:00	1	1.5	8.7	14.5	15.6	753,183.4	0.00	1.00
09/24/2024 21:00	1	1.5	9.8	14.4	16.8	742,649.4	0.00	1.00
09/24/2024 22:00	1	1.4	9.8	14.4	16.6	739,489.2	0.00	1.00
09/24/2024 23:00	0	1.5	9.9	14.4	16.5	739,910.5	0.00	1.00
Average/Sum#:	1	1.5	8.9	14.4	15.5	802,340.0	0.00 #	24.00 #
Minimum:	0	1.3	7.1	13.2	9.5	734,854.2	0.00	1.00
Maximum:	1	1.8	10.5	14.6	23.2	936,544.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/25/2024 00:00	1	1.5	10.1	14.4	18.0	743,492.1	0.00	1.00
09/25/2024 01:00	1	1.4	10.2	14.4	18.6	742,438.7	0.00	1.00
09/25/2024 02:00	1	1.6	10.6	14.4	16.4	744,124.1	0.00	1.00
09/25/2024 03:00	1	1.5	10.3	14.4	19.2	745,598.9	0.00	1.00
09/25/2024 04:00	0	1.4	9.2	14.4	15.5	775,936.9	0.00	1.00
09/25/2024 05:00	0	1.4	8.3	14.4	13.9	830,924.6	0.00	1.00
09/25/2024 06:00	1	1.5	10.0	14.3	19.7	758,163.1	0.00	1.00
09/25/2024 07:00	1	1.5	10.8	14.3	20.4	728,907.3	0.00	1.00
09/25/2024 08:00	0	1.5	8.8	14.5	13.1	864,663.1	0.00	1.00
09/25/2024 09:00	1	1.5	9.7	14.4	18.3	770,248.5	0.00	1.00
09/25/2024 10:00	1	1.4	9.8	14.4	17.7	745,177.5	0.00	1.00
09/25/2024 11:00	1	1.4	10.0	14.4	17.7	738,225.1	0.00	1.00
09/25/2024 12:00	1	1.4	10.0	14.4	17.7	735,275.6	0.00	1.00
09/25/2024 13:00	1	1.4	9.9	14.5	17.0	749,545.9	0.00	1.00
09/25/2024 14:00	1	1.4	9.9	14.5	17.4	747,834.1	0.00	1.00
09/25/2024 15:00	0	1.5	10.0	14.5	16.9	748,904.0	0.00	1.00
09/25/2024 16:00	0	1.4	9.3	14.5	14.8	787,847.0	0.00	1.00
09/25/2024 17:00	1	1.4	9.6	14.3	16.5	734,716.9	0.00	1.00
09/25/2024 18:00	0	1.5	9.8	14.3	15.9	730,774.6	0.00	1.00
09/25/2024 19:00	1	1.5	9.9	14.3	17.1	729,737.2	0.00	1.00
09/25/2024 20:00	1	1.4	10.1	14.3	16.9	730,152.2	0.00	1.00
09/25/2024 21:00	1	1.5	10.6	14.3	19.1	728,699.8	0.00	1.00
09/25/2024 22:00	1	1.4	10.7	14.3	19.5	728,284.8	0.00	1.00
09/25/2024 23:00	1	1.5	10.7	14.3	18.7	728,077.3	0.00	1.00
Average/Sum#:	1	1.5	9.9	14.4	17.3	752,822.9	0.00 #	24.00 #
Minimum:	0	1.4	8.3	14.3	13.1	728,077.3	0.00	1.00
Maximum:	1	1.6	10.8	14.5	20.4	864,663.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/26/2024 00:00	1	1.5	10.7	14.2	18.4	717,006.1	0.00	1.00
09/26/2024 01:00	1	1.5	10.7	14.3	19.7	727,869.8	0.00	1.00
09/26/2024 02:00	0	1.4	11.2	14.2	20.6	717,006.1	0.00	1.00
09/26/2024 03:00	1	1.6	11.0	14.2	20.5	717,006.1	0.00	1.00
09/26/2024 04:00	1	1.5	11.0	14.2	20.6	716,392.9	0.00	1.00
09/26/2024 05:00	1	1.5	11.1	14.2	19.6	716,801.7	0.00	1.00
09/26/2024 06:00	1	1.6	10.9	14.2	19.3	717,210.5	0.00	1.00
09/26/2024 07:00	1	1.5	10.9	14.2	20.1	718,436.8	0.00	1.00
09/26/2024 08:00	1	1.5	10.9	14.3	20.1	729,114.7	0.00	1.00
09/26/2024 09:00	1	1.5	10.8	14.3	19.2	728,492.3	0.00	1.00
09/26/2024 10:00	1	1.5	10.8	14.4	20.5	739,067.8	0.00	1.00
09/26/2024 11:00	1	1.4	10.7	14.4	20.5	739,910.5	0.00	1.00
09/26/2024 12:00	1	1.4	10.2	14.4	18.8	742,228.0	0.00	1.00
09/26/2024 13:00	1	1.5	10.1	14.5	18.0	756,179.0	0.00	1.00
09/26/2024 14:00	1	1.4	10.2	14.5	20.3	754,467.2	0.00	1.00
09/26/2024 15:00	1	1.4	10.2	14.5	19.6	752,969.4	0.00	1.00
09/26/2024 16:00	0	1.4	8.8	14.3	14.1	853,400.4	0.00	1.00
09/26/2024 17:00	1	1.9	10.6	13.3	22.6	965,083.8	0.00	1.00
09/26/2024 18:00	1	1.8	10.6	13.3	25.4	967,786.6	0.00	1.00
09/26/2024 19:00	1	1.8	10.3	13.4	25.2	966,083.3	0.00	1.00
09/26/2024 20:00	1	1.8	10.7	13.3	26.4	969,768.7	0.00	1.00
09/26/2024 21:00	1	1.6	8.8	14.0	20.1	885,164.2	0.00	1.00
09/26/2024 22:00	1	1.3	8.0	14.4	15.9	812,384.7	0.00	1.00
09/26/2024 23:00	1	1.4	9.7	14.4	17.1	751,076.6	0.00	1.00
Average/Sum#:	1	1.5	10.4	14.1	20.1	785,871.1	0.00 #	24.00 #
Minimum:	0	1.3	8.0	13.3	14.1	716,392.9	0.00	1.00
Maximum:	1	1.9	11.2	14.5	26.4	969,768.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/27/2024 00:00	1	1.5	10.3	14.3	18.2	726,832.4	0.00	1.00
09/27/2024 01:00	1	1.5	10.6	14.3	20.3	727,869.8	0.00	1.00
09/27/2024 02:00	1	1.5	11.4	14.4	20.3	739,067.8	0.00	1.00
09/27/2024 03:00	1	1.5	11.2	14.3	19.6	728,907.3	0.00	1.00
09/27/2024 04:00	1	1.4	9.2	14.4	17.4	838,719.8	0.00	1.00
09/27/2024 05:00	0	1.3	8.2	14.5	16.1	895,475.2	0.00	1.00
09/27/2024 06:00	1	1.4	9.2	14.4	18.3	801,429.3	0.00	1.00
09/27/2024 07:00	1	1.5	11.5	14.3	22.5	727,869.8	0.00	1.00
09/27/2024 08:00	1	1.5	11.1	14.4	20.9	739,278.5	0.00	1.00
09/27/2024 09:00	1	1.5	11.0	14.4	20.7	739,067.8	0.00	1.00
09/27/2024 10:00	1	1.5	10.5	14.5	18.6	751,043.7	0.00	1.00
09/27/2024 11:00	1	1.4	10.3	14.5	20.7	751,899.6	0.00	1.00
09/27/2024 12:00	1	1.4	9.7	14.5	16.6	748,690.0	0.00	1.00
09/27/2024 13:00	0	1.2	7.7	14.5	9.0	747,620.1	0.00	1.00
09/27/2024 14:00	0	1.4	7.5	14.6	8.1	759,052.4	0.00	1.00
09/27/2024 15:00	0	1.3	7.5	14.6	8.9	766,008.2	0.00	1.00
09/27/2024 16:00	0	1.5	8.7	14.2	16.8	845,159.7	0.00	1.00
09/27/2024 17:00	1	1.7	10.0	13.6	20.2	957,096.3	0.00	1.00
09/27/2024 18:00	1	1.7	9.9	13.6	21.8	953,156.9	0.00	1.00
09/27/2024 19:00	1	1.6	9.4	13.8	21.6	922,722.0	0.00	1.00
09/27/2024 20:00	0	1.4	7.6	14.5	14.5	924,575.4	0.00	1.00
09/27/2024 21:00	0	1.4	7.7	14.5	14.2	891,409.7	0.00	1.00
09/27/2024 22:00	0	1.4	7.9	14.6	15.5	900,776.9	0.00	1.00
09/27/2024 23:00	0	1.4	8.1	14.5	16.3	943,405.0	0.00	1.00
Average/Sum#:	1	1.5	9.4	14.3	17.4	813,630.6	0.00 #	24.00 #
Minimum:	0	1.2	7.5	13.6	8.1	726,832.4	0.00	1.00
Maximum:	1	1.7	11.5	14.6	22.5	957,096.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/28/2024 00:00	0	1.4	8.2	14.5	17.2	910,453.2	0.00	1.00
09/28/2024 01:00	1	1.5	9.6	14.4	18.2	792,580.7	0.00	1.00
09/28/2024 02:00	1	1.5	11.2	14.4	20.8	736,118.3	0.00	1.00
09/28/2024 03:00	1	1.5	11.2	14.4	21.2	737,803.7	0.00	1.00
09/28/2024 04:00	1	1.4	11.3	14.3	21.7	728,284.8	0.00	1.00
09/28/2024 05:00	1	1.5	11.0	14.3	20.4	730,982.1	0.00	1.00
09/28/2024 06:00	1	1.5	11.5	14.3	22.1	728,699.8	0.00	1.00
09/28/2024 07:00	1	1.5	11.6	14.4	22.3	736,539.6	0.00	1.00
09/28/2024 08:00	1	1.5	11.5	14.4	22.7	736,118.3	0.00	1.00
09/28/2024 09:00	1	1.5	11.2	14.5	21.7	746,550.3	0.00	1.00
09/28/2024 10:00	1	1.5	10.9	14.5	21.5	746,550.3	0.00	1.00
09/28/2024 11:00	0	1.3	9.6	14.5	15.9	747,192.2	0.00	1.00
09/28/2024 12:00	0	1.3	7.5	14.5	9.5	748,690.0	0.00	1.00
09/28/2024 13:00	0	1.3	7.4	14.6	8.4	766,008.2	0.00	1.00
09/28/2024 14:00	0	1.3	7.4	14.6	10.9	803,830.4	0.00	1.00
09/28/2024 15:00	0	1.3	8.8	14.5	14.9	811,597.9	0.00	1.00
09/28/2024 16:00	1	1.5	9.2	14.2	17.6	841,276.2	0.00	1.00
09/28/2024 17:00	1	1.6	9.9	13.6	21.6	954,470.0	0.00	1.00
09/28/2024 18:00	1	1.7	9.9	13.6	21.1	949,592.6	0.00	1.00
09/28/2024 19:00	0	1.6	9.2	13.9	18.6	930,817.3	0.00	1.00
09/28/2024 20:00	1	1.5	9.9	14.4	19.0	742,228.0	0.00	1.00
09/28/2024 21:00	1	1.4	10.2	14.4	18.5	736,118.3	0.00	1.00
09/28/2024 22:00	1	1.4	10.3	14.4	18.5	736,329.0	0.00	1.00
09/28/2024 23:00	1	1.5	10.3	14.3	16.5	726,002.4	0.00	1.00
Average/Sum#:	1	1.5	10.0	14.3	18.4	784,368.1	0.00 #	24.00 #
Minimum:	0	1.3	7.4	13.6	8.4	726,002.4	0.00	1.00
Maximum:	1	1.7	11.6	14.6	22.7	954,470.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/29/2024 00:00	1	1.5	10.3	14.3	18.5	726,209.9	0.00	1.00
09/29/2024 01:00	1	1.5	10.5	14.3	18.3	726,209.9	0.00	1.00
09/29/2024 02:00	1	1.5	11.2	14.3	18.2	726,832.4	0.00	1.00
09/29/2024 03:00	1	1.5	11.0	14.3	20.2	727,247.3	0.00	1.00
09/29/2024 04:00	1	1.5	10.8	14.3	19.1	727,454.8	0.00	1.00
09/29/2024 05:00	1	1.5	10.8	14.3	18.5	727,247.3	0.00	1.00
09/29/2024 06:00	1	1.5	10.8	14.3	18.8	727,454.8	0.00	1.00
09/29/2024 07:00	1	1.5	10.8	14.3	19.7	727,662.3	0.00	1.00
09/29/2024 08:00	1	1.6	10.9	14.3	19.2	727,039.9	0.00	1.00
09/29/2024 09:00	1	1.5	10.9	14.3	19.6	728,077.3	0.00	1.00
09/29/2024 10:00	1	1.5	10.8	14.4	19.7	739,067.8	0.00	1.00
09/29/2024 11:00	1	1.5	10.8	14.4	20.2	738,225.1	0.00	1.00
09/29/2024 12:00	1	1.5	10.5	14.5	18.6	749,759.9	0.00	1.00
09/29/2024 13:00	1	1.5	10.2	14.5	18.9	748,262.0	0.00	1.00
09/29/2024 14:00	1	1.4	10.2	14.5	17.5	749,759.9	0.00	1.00
09/29/2024 15:00	1	1.5	10.1	14.5	17.9	748,904.0	0.00	1.00
09/29/2024 16:00	0	1.3	8.7	14.4	15.3	827,553.7	0.00	1.00
09/29/2024 17:00	1	1.4	9.9	14.4	18.6	747,495.0	0.00	1.00
09/29/2024 18:00	0	1.5	10.1	14.5	16.8	749,331.9	0.00	1.00
09/29/2024 19:00	1	1.4	9.5	14.5	16.3	753,825.3	0.00	1.00
09/29/2024 20:00	1	1.5	10.1	14.4	17.1	736,539.6	0.00	1.00
09/29/2024 21:00	1	1.5	10.2	14.4	17.6	736,750.3	0.00	1.00
09/29/2024 22:00	1	1.4	10.2	14.4	18.7	737,171.7	0.00	1.00
09/29/2024 23:00	1	1.4	10.3	14.3	17.4	727,247.3	0.00	1.00
Average/Sum#:	1	1.5	10.4	14.4	18.4	740,055.4	0.00 #	24.00 #
Minimum:	0	1.3	8.7	14.3	15.3	726,209.9	0.00	1.00
Maximum:	1	1.6	11.2	14.5	20.2	827,553.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2024 00:00 To: 09/30/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/11/2024 09:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2024 00:00	1	1.5	10.3	14.3	18.7	727,662.3	0.00	1.00
09/30/2024 01:00	1	1.5	10.3	14.3	17.5	727,247.3	0.00	1.00
09/30/2024 02:00	1	1.4	10.6	14.3	18.1	727,662.3	0.00	1.00
09/30/2024 03:00	1	1.6	10.8	14.3	17.7	729,322.2	0.00	1.00
09/30/2024 04:00	1	1.5	11.0	14.3	19.9	729,529.7	0.00	1.00
09/30/2024 05:00	1	1.5	10.6	14.3	18.9	737,414.3	0.00	1.00
09/30/2024 06:00	1	1.4	9.8	14.4	18.5	808,592.4	0.00	1.00
09/30/2024 07:00	1	1.4	10.8	14.3	19.9	729,114.7	0.00	1.00
09/30/2024 08:00	1	1.5	10.8	14.4	20.0	739,489.2	0.00	1.00
09/30/2024 09:00	1	1.5	10.8	14.4	19.6	740,753.3	0.00	1.00
09/30/2024 10:00	1	1.4	10.6	14.4	18.8	742,228.0	0.00	1.00
09/30/2024 11:00	1	1.3	10.3	14.5	19.4	752,969.4	0.00	1.00
09/30/2024 12:00	1	1.4	10.2	14.5	18.7	754,253.3	0.00	1.00
09/30/2024 13:00	0	1.3	7.8	14.5	8.7	755,537.1	0.00	1.00
09/30/2024 14:00	0	1.4	7.5	14.5	8.5	755,965.1	0.00	1.00
09/30/2024 15:00	0	1.5	8.6	14.2	14.9	854,561.7	0.00	1.00
09/30/2024 16:00	1	2.2	13.5	12.3	33.6	970,062.0	0.00	1.00
09/30/2024 17:00	1	2.1	13.9	12.4	33.9	969,069.1	0.00	1.00
09/30/2024 18:00	1	2.0	13.1	12.6	31.9	964,866.7	0.00	1.00
09/30/2024 19:00	1	2.1	13.5	12.6	33.8	974,106.2	0.00	1.00
09/30/2024 20:00	1	2.0	13.7	12.5	34.7	972,454.3	0.00	1.00
09/30/2024 21:00	1	2.0	13.5	12.6	33.7	978,726.0	0.00	1.00
09/30/2024 22:00	1	1.8	11.2	13.3	27.3	982,381.8	0.00	1.00
09/30/2024 23:00	0	1.3	7.6	14.5	16.9	944,260.9	0.00	1.00
Average/Sum#:	1	1.6	10.9	13.9	21.8	823,676.2	0.00 #	24.00 #
Minimum:	0	1.3	7.5	12.3	8.5	727,247.3	0.00	1.00
Maximum:	1	2.2	13.9	14.5	34.7	982,381.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00