

DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	261236
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q4 2024 - Part 4 - searchable
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	1/22/2025 11:14:01 AM
Docketed Date:	1/22/2025

AQ-54 thru 63 & 71

AQ54-63 & 71: Fuel use emission and operational data -
Hourly/Daily/Quarterly

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/01/24 16:02	415591.7			0.5			1.4			0.46			2.29			0		
10/01/24 16:03	415372.2			0.5			1.4			0.46			2.29			0		
10/01/24 16:04	415100.7			0.5			1.4			0.46			2.29			0		
10/01/24 16:05	414413.3			0.5			1.4			0.46			2.29			0		
10/01/24 16:06	415042.9			0.5			1.4			0.46			2.29			0		
10/01/24 16:07	419646.6			0.5			1.4			0.47			2.31			1		
10/01/24 16:08	416590.9			0.5			1.57			0.46			2.56			0		
10/01/24 16:09	414563.5			0.5			1.5			0.46			2.44			0		
10/01/24 16:10	414921.6			0.5			1.4			0.46			2.29			0		
10/01/24 16:11	415100.7			0.5			1.31			0.46			2.14			0		
10/01/24 16:12	415175.8			0.5			1.31			0.46			2.14			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/02/24 11:31	394895.5			0.5			1.33			0.45			2.07			0		
10/02/24 11:32	411363.5			0.4			1.16			0.38			1.87			0		
10/02/24 11:33	415776.5			0.3			1.05			0.28			1.71			0		
10/02/24 11:34	417232.1			0.3			1.22			0.28			1.99			0		
10/02/24 11:35	417445.8			0.4			1.5			0.37			2.46			0		
10/02/24 11:36	424111.5			0.4			1.5			0.38			2.5			1		
10/02/24 11:37	418809			0.4			1.84			0.37			3.03			0		
10/02/24 11:38	417804			0.5			1.5			0.47			2.46			0		
10/02/24 11:39	418993.8			0.5			1.4			0.47			2.31			0		
10/02/24 11:40	419230.7			0.4			1.31			0.37			2.16			0		
10/02/24 11:41	418710.8			0.4			1.31			0.37			2.16			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/24 9:48	338311.9			0.9			1.43			0.72			1.9			0		
10/29/24 9:49	338542.9			0.9			1.43			0.72			1.9			0		
10/29/24 9:50	338311.9			0.9			1.43			0.72			1.9			0		
10/29/24 9:51	338352.3			0.9			1.52			0.72			2.02			0		
10/29/24 9:52	338467.9			0.9			1.52			0.72			2.02			0		
10/29/24 9:53	335550.9			0.9			1.52			0.72			2			1		
10/29/24 9:54	318499.6			0.9			1.52			0.68			1.9			1		
10/29/24 9:55	294124			0.9			1.59			0.62			1.83			1		
10/29/24 9:56	271712.3			0.9			1.88			0.58			2.01			1		
10/29/24 9:57	248832.8			0.8			3.04			0.49			2.98			1		
10/29/24 9:58	225635.6			0.8			5.61			0.42			4.97			1		
10/29/24 9:59	203853.6			0.5			13.28			0.26			10.63			1		
10/29/24 10:00	178686.7			4.3			16.31			1.83			11.45			1		
10/29/24 10:01	157903.9			128.2			18.88			48.31			11.71			1		
10/29/24 10:02	139385.4			874.7			20.21			290.95			11.06			1		
10/29/24 10:03	62440.7			1758.4			20.73			262.14			5.09			1		
10/29/24 10:04	0			0			22.05			2.56			0.03			0		
10/29/24 10:05	0			0			0.2			0			0			0		
10/29/24 10:06	0			0			0.1			0			0			0		
10/29/24 10:07	0			0			0.1			0			0			0		
10/29/24 10:08	0			0			0			0			0			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/06/24 9:57	0			0			0			0			0			0		
11/06/24 9:58	0			0			0			0			0			0		
11/06/24 9:59	0			0			0			0			0			0		
11/06/24 10:00	0			0			0			0			0			0		
11/06/24 10:01	0			0			0			0			0			0		
11/06/24 10:02	0			0			0			0			0			1		
11/06/24 10:03	0			-0.1			0			0			0			1		
11/06/24 10:04	9819.5			1958.8			35.4			45.16			1.34			1		
11/06/24 10:05	34351.1			1230.6			14.26			99.72			1.9			1		
11/06/24 10:06	50356.9			779.1			17.7			92.61			3.46			1		
11/06/24 10:07	70879.7			415.4			22.42			69.45			6.17			1		
11/06/24 10:08	116760.1			263.9			27.62			72.66			12.52			1		
11/06/24 10:09	138299.5			175.1			40.59			57.11			21.79			1		
11/06/24 10:10	139425.9			390.7			51.2			128.48			27.71			1		
11/06/24 10:11	144301			1923.4			37.61			654.86			21.08			1		
11/06/24 10:12	148575.4			1865.1			37.55			653.8			21.66			1		
11/06/24 10:13	164893.1			1810.1			38			704.2			24.33			1		
11/06/24 10:14	187114.1			1709.7			49.17			754.7			35.72			1		
11/06/24 10:15	211264.4			472.3			64.47			235.33			52.87			1		
11/06/24 10:16	231966.3			27			69.67			14.77			62.73			1		
11/06/24 10:17	256474.8			3.6			84.19			2.2			83.83			1		
11/06/24 10:18	283414.9			2.4			87.38			1.63			96.12			1		
11/06/24 10:19	303406.4			2.3			41.48			1.65			48.86			1		
11/06/24 10:20	322265.7			2.3			19.44			1.71			24.32			1		
11/06/24 10:21	338716.3			2.2			12.91			1.78			16.98			1		
11/06/24 10:22	346375.5			2.1			10.67			1.7			14.35			1		
11/06/24 10:23	348686			1.8			9.02			1.5			12.21			1		
11/06/24 10:24	351845.5			1.7			8.33			1.44			11.38			1		
11/06/24 10:25	355155.3			1.6			7.13			1.33			9.84			1		
11/06/24 10:26	354185			1.4			6.69			1.18			9.2			1		
11/06/24 10:27	353740.1			1.2			6.08			1.03			8.34			1		
11/06/24 10:28	353647.8			1.1			5.81			0.96			7.98			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/06/24 10:29	356911.3			1.1			5.63			0.9			7.8			1		
11/06/24 10:30	358829			1			5.18			0.83			7.22			1		
11/06/24 10:31	359481.7			1			5.27			0.83			7.36			1		
11/06/24 10:32	359320			0.9			5.27			0.76			7.36			1		
11/06/24 10:33	359429.7			0.9			5.1			0.76			7.11			1		
11/06/24 10:34	364010.2			0.8			5.26			0.7			7.44			1		
11/06/24 10:35	365650.7			0.8			5.17			0.7			7.34			1		
11/06/24 10:36	365431.2			0.8			4.36			0.7			6.18			1		
11/06/24 10:37	365061.5			0.8			4.27			0.7			6.05			1		
11/06/24 10:38	366251.4			0.8			4.08			0.71			5.81			1		
11/06/24 10:39	368232.6			0.7			3.99			0.63			5.71			1		
11/06/24 10:40	367464.4			0.7			4.18			0.63			5.96			1		
11/06/24 10:41	366003			0.7			4.08			0.63			5.8			1		
11/06/24 10:42	367574.1			0.7			4.08			0.63			5.83			1		
11/06/24 10:43	369913.5			0.7			4.08			0.63			5.87			1		
11/06/24 10:44	362416			0.7			4.36			0.62			6.13			1		
11/06/24 10:45	358390			0.7			4.54			0.61			6.31			1		
11/06/24 10:46	353688.2			0.7			4.99			0.61			6.85			1		
11/06/24 10:47	348870.8			0.7			3.22			0.59			4.36			1		
11/06/24 10:48	344787			0.7			2.23			0.58			2.99			1		
11/06/24 10:49	340957.4			0.7			2.15			0.58			2.84			1		
11/06/24 10:50	341165.4			0.7			2.59			0.58			3.43			1		
11/06/24 10:51	340940.1			0.7			2.68			0.58			3.55			1		
11/06/24 10:52	339952.3			0.7			2.86			0.57			3.77			1		
11/06/24 10:53	339796.4			0.7			3.04			0.57			4.01			1		
11/06/24 10:54	340576.2			0.7			3.04			0.57			4.02			1		
11/06/24 10:55	340749.5			0.7			2.77			0.57			3.67			1		
11/06/24 10:56	340784.1			0.7			2.41			0.57			3.19			1		
11/06/24 10:57	339409.3			0.7			2.32			0.57			3.06			1		
11/06/24 10:58	339519.1			0.7			2.15			0.57			2.83			1		
11/06/24 10:59	340021.7			0.7			2.06			0.57			2.71			1		
11/06/24 11:00	340483.8			0.7			2.06			0.57			2.72			1		
11/06/24 11:01	340391.3			0.8			1.97			0.65			2.6			1		
11/06/24 11:02	339305.4			0.7			1.88			0.57			2.47			1		
11/06/24 11:03	339432.5			0.7			1.88			0.57			2.47			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/06/24 11:04	340073.7			0.8			1.88			0.65			2.48			1		
11/06/24 11:05	340697.5			0.8			1.79			0.65			2.36			1		
11/06/24 11:06	340194.9			0.7			1.7			0.57			2.24			1		
11/06/24 11:07	339519.1			0.7			1.7			0.57			2.24			1		
11/06/24 11:08	339062.8			0.7			1.61			0.57			2.12			1		
11/06/24 11:09	339767.5			0.7			1.61			0.57			2.12			1		
11/06/24 11:10	340501.1			0.7			1.61			0.57			2.13			1		
11/06/24 11:11	340085.2			0.7			1.61			0.57			2.12			0		
11/06/24 11:12	339357.4			0.7			1.61			0.57			2.12			0		
11/06/24 11:13	339784.8			0.7			1.52			0.57			2			0		
11/06/24 11:14	344688.8			0.7			1.52			0.58			2.03			0		
11/06/24 11:15	349361.8			0.7			1.54			0.6			2.09			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 15:16	438794.7			1.2			1.5			1.33			2.67			0		
11/15/24 15:17	439170.1			1.2			1.5			1.34			2.67			0		
11/15/24 15:18	439458.9			1.2			1.41			1.34			2.51			0		
11/15/24 15:19	440775.9			1.2			1.41			1.34			2.52			0		
11/15/24 15:20	440631.5			1.2			1.41			1.34			2.52			0		
11/15/24 15:21	440695			1.2			1.41			1.34			2.52			1		
11/15/24 15:22	398783			1.2			1.32			1.2			2.12			1		
11/15/24 15:23	150550.8			1.3			2.43			0.48			1.47			1		
11/15/24 15:24	51489			0			3.88			1.66			0.85			0		
11/15/24 15:25	48445			0			0.1			0			0			0		
11/15/24 15:26	46845			0			0			0			0			0		
11/15/24 15:27	47087.6			0			0			0			0			0		
11/15/24 15:28	46764.1			0			0			0			0			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/24 16:39	86908.7			0			0			0			0			0		
11/20/24 16:40	86972.2			0			0			0			0			0		
11/20/24 16:41	86885.6			0			0			0			0			0		
11/20/24 16:42	86879.8			0			0			0			0			0		
11/20/24 16:43	86458.1			0			0			0			0			0		
11/20/24 16:44	83483.4			0.1			0			0			0			1		
11/20/24 16:45	73577.2			0.1			0			0			0			1		
11/20/24 16:46	60523			48.5			0.5			0			0			1		
11/20/24 16:47	75287			1666.5			13.95			295.82			4.07			1		
11/20/24 16:48	84193.9			980.5			18.07			194.68			5.9			1		
11/20/24 16:49	97398.3			523.2			23.6			120.17			8.92			1		
11/20/24 16:50	132731.3			358.5			28.94			112.27			14.91			1		
11/20/24 16:51	154888.8			234.8			38.6			85.77			23.2			1		
11/20/24 16:52	163356.7			418.5			49.36			161.23			31.3			1		
11/20/24 16:53	179755.3			1928.9			36.14			817.8			25.21			1		
11/20/24 16:54	201144.5			1762.9			43.49			836.6			33.97			1		
11/20/24 16:55	222759.1			690.4			50.8			362.74			43.92			1		
11/20/24 16:56	242184.4			38.9			51.05			22.2			47.99			1		
11/20/24 16:57	264295.7			3.6			62.18			2.26			63.79			1		
11/20/24 16:58	291195.4			2.1			78.67			1.42			88.94			1		
11/20/24 16:59	312555.8			1.9			47.11			1.38			57.16			1		
11/20/24 17:00	330698.9			1.9			26.85			1.47			34.47			1		
11/20/24 17:01	346127.1			2.1			18.13			1.68			24.36			1		
11/20/24 17:02	352440.5			2			13.51			1.64			18.48			1		
11/20/24 17:03	354086.7			1.8			11.28			1.52			15.5			1		
11/20/24 17:04	354543			1.7			9.37			1.45			12.9			1		
11/20/24 17:05	354392.8			1.6			7.98			1.38			10.98			1		
11/20/24 17:06	354427.5			1.6			6.77			1.31			9.31			1		
11/20/24 17:07	354398.6			1.5			6.07			1.23			8.36			1		
11/20/24 17:08	353757.5			1.3			5.47			1.09			7.51			1		
11/20/24 17:09	352856.4			1.2			5.21			1.01			7.13			1		
11/20/24 17:10	352492.5			1.1			5.11			0.95			6.99			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/24 17:11	352342.3			1.1			4.84			0.88			6.62			1		
11/20/24 17:12	351972.6			1.1			4.67			0.88			6.38			1		
11/20/24 17:13	351556.8			1.1			4.58			0.88			6.25			1		
11/20/24 17:14	351285.3			1.1			4.49			0.88			6.13			1		
11/20/24 17:15	350956			1.1			4.4			0.87			6			1		
11/20/24 17:16	350753.8			1.1			4.4			0.87			6			1		
11/20/24 17:17	350210.9			1.1			4.31			0.87			5.87			1		
11/20/24 17:18	350725			1.1			4.31			0.88			5.88			1		
11/20/24 17:19	350418.8			1			4.31			0.8			5.87			1		
11/20/24 17:20	350234			1			4.4			0.8			5.99			1		
11/20/24 17:21	350124.3			0.9			4.47			0.74			6.07			1		
11/20/24 17:22	349754.6			0.9			4.56			0.74			6.2			1		
11/20/24 17:23	349748.8			0.9			4.65			0.74			6.32			1		
11/20/24 17:24	349639			0.9			4.65			0.74			6.31			1		
11/20/24 17:25	349650.6			0.8			4.83			0.66			6.55			1		
11/20/24 17:26	349552.4			0.8			4.92			0.66			6.67			1		
11/20/24 17:27	349217.4			0.8			4.92			0.66			6.67			1		
11/20/24 17:28	348859.3			0.8			4.93			0.65			6.69			1		
11/20/24 17:29	348951.6			0.8			4.56			0.66			6.18			1		
11/20/24 17:30	348905.5			0.8			3.58			0.66			4.84			1		
11/20/24 17:31	346924.2			0.8			3.13			0.66			4.21			1		
11/20/24 17:32	348553.1			0.8			2.59			0.66			3.51			1		
11/20/24 17:33	348576.2			0.8			2.59			0.66			3.51			1		
11/20/24 17:34	348720.7			0.8			2.59			0.66			3.51			1		
11/20/24 17:35	348697.5			0.8			2.59			0.66			3.51			1		
11/20/24 17:36	348691.8			0.8			2.68			0.66			3.63			1		
11/20/24 17:37	348772.6			0.8			2.68			0.66			3.63			1		
11/20/24 17:38	348957.5			0.8			2.77			0.66			3.75			1		
11/20/24 17:39	348893.9			0.8			2.77			0.66			3.76			1		
11/20/24 17:40	348824.6			0.8			2.77			0.66			3.75			1		
11/20/24 17:41	348553.1			0.8			2.68			0.66			3.63			1		
11/20/24 17:42	348853.5			0.8			2.41			0.66			3.27			1		
11/20/24 17:43	348512.7			0.8			2.23			0.66			3.02			1		
11/20/24 17:44	348322.1			0.8			2.06			0.66			2.78			1		
11/20/24 17:45	348154.5			0.8			1.88			0.66			2.54			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/24 17:46	348189.2			0.8			1.88			0.66			2.54			1		
11/20/24 17:47	348183.5			0.8			1.88			0.66			2.54			1		
11/20/24 17:48	348385.6			0.8			1.88			0.66			2.54			1		
11/20/24 17:49	348247			0.8			1.97			0.66			2.66			1		
11/20/24 17:50	348143			0.8			1.97			0.66			2.66			1		
11/20/24 17:51	348091			0.8			1.97			0.66			2.66			1		
11/20/24 17:52	348096.8			0.8			1.88			0.66			2.54			1		
11/20/24 17:53	348102.5			0.8			1.79			0.66			2.42			1		
11/20/24 17:54	347328.6			0.8			1.7			0.66			2.29			1		
11/20/24 17:55	346323.5			0.8			1.61			0.66			2.16			0		
11/20/24 17:56	347484.5			0.8			1.61			0.66			2.17			0		
11/20/24 17:57	347940.8			0.8			1.43			0.66			1.93			0		
11/20/24 17:58	348021.7			0.8			1.25			0.66			1.69			0		
11/20/24 17:59	347842.6			0.8			1.16			0.66			1.57			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/24 18:15	347022.4			3	X		2.98	X		2.44	X		4.01	X		0		
11/20/24 18:16	346814.5			4.2	X		3.99	X		3.46	X		5.37	X		0		
11/20/24 18:17	346508.3			6.2	X		4.44	X		5.06	X		5.97	X		0		
11/20/24 18:18	346404.4			3.3	X		2.11	X		2.73	X		2.84	X		0		
11/20/24 18:19	346941.6			1.4	X		1.76	X		1.15	X		2.37	X		0		
11/20/24 18:20	342996.4			1.3	X		1.67	X		1.07	X		2.23	X		1		
11/20/24 18:21	325419.5			1.2			1.59			0.95			2			1		
11/20/24 18:22	302332			1.1			1.67			0.82			1.96			1		
11/20/24 18:23	280451.8			1.1			1.97			0.71			2.14			1		
11/20/24 18:24	259062.5			0.9			3.78			0.56			3.8			1		
11/20/24 18:25	237124.5			0.8			5.61			0.43			5.17			1		
11/20/24 18:26	215509.9			0.6			13.38			0.32			11.19			1		
11/20/24 18:27	192636.2			6			16.66			2.73			12.46			1		
11/20/24 18:28	173661.4			144.1			19.4			59.15			13.11			1		
11/20/24 18:29	157505.4			988.8			22.84			368.3			14			1		
11/20/24 18:30	110365.8			1757			23.6			457.41			10.11			1		
11/20/24 18:31	75778			0			26.71			511.34			7.9			0		
11/20/24 18:32	75333.2			0			0.3			0			0			0		
11/20/24 18:33	75419.8			0			0.3			0			0			0		
11/20/24 18:34	75662.4			0			0.2			0			0			0		
11/20/24 18:35	75951.2			0			0.2			0			0			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/21/24 23:39	74432.1			0			0			0			0			0		
11/21/24 23:40	74819.1			0			0			0			0			0		
11/21/24 23:41	75027			0			0			0			0			0		
11/21/24 23:42	75356.3			0			0			0			0			0		
11/21/24 23:43	75223.4			0			0			0			0			0		
11/21/24 23:44	70365.6			0			0			0			0			1		
11/21/24 23:45	56704.9			2.6			0.1			0			0			1		
11/21/24 23:46	62897			1508.7			18.54			223.91			4.53			1		
11/21/24 23:47	76800.3			1174.1			13.77			212.62			4.1			1		
11/21/24 23:48	85580.1			633.3			19.67			127.86			6.54			1		
11/21/24 23:49	108465.4			383.2			25.67			98.05			10.81			1		
11/21/24 23:50	151041.8			218.6			36.47			77.89			21.39			1		
11/21/24 23:51	104936.2			47.9			63.37			11.85			25.82			1		
11/21/24 23:52	70781.5			0			65.74			99.65			18.07			0		
11/21/24 23:53	70279			0			2.4			0			0			0		
11/21/24 23:54	70215.5			0			2.7			0			0			0		
11/21/24 23:55	70469.6			0			3.5			0			0			0		
11/21/24 23:56	70585.1			0			4			0			0			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/21/24 23:39	74432.1			0			0			0			0			0		
11/21/24 23:40	74819.1			0			0			0			0			0		
11/21/24 23:41	75027			0			0			0			0			0		
11/21/24 23:42	75356.3			0			0			0			0			0		
11/21/24 23:43	75223.4			0			0			0			0			0		
11/21/24 23:44	70365.6			0			0			0			0			1		
11/21/24 23:45	56704.9			2.6			0.1			0			0			1		
11/21/24 23:46	62897			1508.7			18.54			223.91			4.53			1		
11/21/24 23:47	76800.3			1174.1			13.77			212.62			4.1			1		
11/21/24 23:48	85580.1			633.3			19.67			127.86			6.54			1		
11/21/24 23:49	108465.4			383.2			25.67			98.05			10.81			1		
11/21/24 23:50	151041.8			218.6			36.47			77.89			21.39			1		
11/21/24 23:51	104936.2			47.9			63.37			11.85			25.82			1		
11/21/24 23:52	70781.5			0			65.74			99.65			18.07			0		
11/21/24 23:53	70279			0			2.4			0			0			0		
11/21/24 23:54	70215.5			0			2.7			0			0			0		
11/21/24 23:55	70469.6			0			3.5			0			0			0		
11/21/24 23:56	70585.1			0			4			0			0			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/22/24 0:01	72081.2			0			1			0			0			0		
11/22/24 0:02	72450.8			0			1.1			0			0			0		
11/22/24 0:03	72791.6			0			1.4			0			0			0		
11/22/24 0:04	73005.4			0			1.6			0			0			0		
11/22/24 0:05	73028.5			0			1.7			0			0			0		
11/22/24 0:06	73317.3			0.3			1.8			0			0			1		
11/22/24 0:07	64837.8			0.3			1.7			0			0			1		
11/22/24 0:08	52921.5			16.5			4			0			0			1		
11/22/24 0:09	69857.3			1093.5			37.86			180.15			10.26			1		
11/22/24 0:10	77909.4			892.7			32.82			164.07			9.93			1		
11/22/24 0:11	89144.1			493.1			33.85			103.65			11.71			1		
11/22/24 0:12	120376			336.9			39.83			95.7			18.62			1		
11/22/24 0:13	150712.5			215.2			51.3			76.5			30.01			1		
11/22/24 0:14	156044			197.8			68.16			72.77			41.28			1		
11/22/24 0:15	173753.8			1883.8			59			772.1			39.8			1		
11/22/24 0:16	194444.1			1764.6			60.35			809.36			45.55			1		
11/22/24 0:17	215879.6			731.3			59.44			372.42			49.82			1		
11/22/24 0:18	235692			45.9			57.85			25.53			52.93			1		
11/22/24 0:19	258011.2			4.2			66.29			2.53			66.4			1		
11/22/24 0:20	283975.2			2			79.65			1.34			87.79			1		
11/22/24 0:21	307022.3			1.9			42.44			1.38			50.58			1		
11/22/24 0:22	325922			1.8			19.96			1.4			25.25			1		
11/22/24 0:23	342921.3			2			11.63			1.61			15.48			1		
11/22/24 0:24	359464.4			2			9.98			1.69			13.92			1		
11/22/24 0:25	378121.4			1.9			8.31			1.67			12.2			1		
11/22/24 0:26	398771.4			1.6			6.99			1.54			10.82			1		
11/22/24 0:27	420709.4			1.4			5.53			1.37			9.03			1		
11/22/24 0:28	442329.7			1.1			5.24			1.17			9.01			1		
11/22/24 0:29	448816.3			1			5.71			1.09			9.95			1		
11/22/24 0:30	445697.2			0.9			6.18			0.97			10.69			1		
11/22/24 0:31	444622.8			0.9			5.62			0.97			9.71			1		
11/22/24 0:32	443773.8			0.9			5.44			0.96			9.37			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/22/24 0:33	443848.8			0.9			5.44			0.97			9.37			1		
11/22/24 0:34	444022.1			0.8			5.43			0.88			9.36			1		
11/22/24 0:35	444154.9			0.8			5.25			0.87			9.06			1		
11/22/24 0:36	444224.3			0.8			5.16			0.87			8.9			1		
11/22/24 0:37	444131.9			0.7			5.24			0.78			9.04			1		
11/22/24 0:38	444253.1			0.7			5.15			0.79			8.88			1		
11/22/24 0:39	444605.5			0.7			5.24			0.79			9.05			1		
11/22/24 0:40	444807.7			0.7			5.34			0.79			9.22			1		
11/22/24 0:41	444738.3			0.7			5.25			0.77			9.07			1		
11/22/24 0:42	444622.8			0.7			5.43			0.79			9.37			1		
11/22/24 0:43	444530.4			0.7			5.25			0.77			9.07			1		
11/22/24 0:44	444721			0.7			4.03			0.79			6.95			1		
11/22/24 0:45	445009.8			0.7			3.09			0.79			5.34			1		
11/22/24 0:46	445136.9			0.7			3			0.79			5.18			1		
11/22/24 0:47	445408.4			0.7			3.23			0.77			5.58			1		
11/22/24 0:48	445668.4			0.7			3.84			0.79			6.64			1		
11/22/24 0:49	445697.3			0.7			3.87			0.78			6.7			1		
11/22/24 0:50	445362.2			0.7			2.95			0.77			5.1			1		
11/22/24 0:51	445217.8			0.7			2.58			0.77			4.46			1		
11/22/24 0:52	445015.6			0.7			2.49			0.77			4.3			1		
11/22/24 0:53	444940.5			0.7			2.4			0.77			4.14			1		
11/22/24 0:54	444877			0.7			2.34			0.79			4.04			1		
11/22/24 0:55	444749.9			0.7			2.21			0.77			3.82			1		
11/22/24 0:56	444882.8			0.7			1.94			0.77			3.34			1		
11/22/24 0:57	445541.3			0.7			1.87			0.79			3.24			1		
11/22/24 0:58	445754.9			0.7			1.66			0.78			2.87			1		
11/22/24 0:59	445968.7			0.7			1.57			0.78			2.71			1		
11/22/24 1:00	446142			0.7			1.48			0.78			2.55			1		
11/22/24 1:01	446009.1			0.7			1.48			0.78			2.55			1		
11/22/24 1:02	445899.4			0.8			1.57			0.87			2.71			1		
11/22/24 1:03	445708.8			0.7			1.57			0.78			2.71			1		
11/22/24 1:04	445864.8			0.7			1.59			0.79			2.76			1		
11/22/24 1:05	446165.1			0.7			1.57			0.78			2.71			1		
11/22/24 1:06	445859			0.7			1.48			0.78			2.55			1		
11/22/24 1:07	445489.3			0.7			1.48			0.77			2.55			0		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/22/24 1:08	445437.3			0.7			1.48			0.77			2.55			0		
11/22/24 1:09	445235.1			0.7			1.38			0.77			2.39			0		
11/22/24 1:10	445495.1			0.7			1.29			0.78			2.23			0		
11/22/24 1:11	445275.5			0.7			1.29			0.77			2.23			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/30/24 16:52	450630.1			0.6			1.48			0.68			2.57			0		
12/30/24 16:53	450358.6			0.6			1.38			0.68			2.41			0		
12/30/24 16:54	450347			0.6			1.38			0.68			2.41			0		
12/30/24 16:55	450462.6			0.6			1.38			0.68			2.41			0		
12/30/24 16:56	450266.2			0.6			1.38			0.68			2.41			0		
12/30/24 16:57	450572.3			0.6			1.38			0.68			2.41			1		
12/30/24 16:58	450087.1			0.7			1.38			0.78			2.41			1		
12/30/24 16:59	442913.1			0.6			1.38			0.67			2.37			1		
12/30/24 17:00	424539			0.6			1.38			0.64			2.27			1		
12/30/24 17:01	402554.8			0.6			2			0.6			3.11			1		
12/30/24 17:02	379652.2			0.7			2.41			0.64			3.54			1		
12/30/24 17:03	358563.3			0.8			2.55			0.67			3.54			1		
12/30/24 17:04	336503.9			0.8			3.26			0.63			4.24			1		
12/30/24 17:05	312295.9			0.8			3.35			0.58			4.04			1		
12/30/24 17:06	289959.4			0.8			3.08			0.54			3.46			1		
12/30/24 17:07	268633.6			0.7			3.18			0.46			3.3			1		
12/30/24 17:08	245448			0.7			4.57			0.38			4.34			1		
12/30/24 17:09	226346.1			0.4			10.99			0.22			9.62			1		
12/30/24 17:10	203691.9			0.7			16.7			0.32			13.16			1		
12/30/24 17:11	183504			55.1			19.08			23.77			13.55			1		
12/30/24 17:12	167896.8			533.3			21.01			210.46			13.65			1		
12/30/24 17:13	145941.4			1592.5			21.14			546.12			11.93			1		
12/30/24 17:14	84269			0			21.89			390.16			7.14			0		
12/30/24 17:15	83899.3			0			33.43			1153.06			10.85			0		
12/30/24 17:16	83789.5			0			0.2			0			0			0		
12/30/24 17:17	83310.1			0			0.2			0			0			0		
12/30/24 17:18	82524.5			0			0.1			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/17/24 10:02	369942.4			0.9			1.45			0.8			2.11			0		
10/17/24 10:03	369913.5			0.9			1.45			0.8			2.11			0		
10/17/24 10:04	367614.5			0.9			1.54			0.8			2.23			0		
10/17/24 10:05	369601.5			0.9			1.54			0.8			2.24			0		
10/17/24 10:06	370381.3			0.9			1.54			0.8			2.24			0		
10/17/24 10:07	368284.6			1			1.63			0.88			2.36			1		
10/17/24 10:08	358996.5			0.9			1.63			0.78			2.3			1		
10/17/24 10:09	338150.2			0.9			1.63			0.73			2.17			1		
10/17/24 10:10	314733.5			1			2.15			0.74			2.65			1		
10/17/24 10:11	290392.6			1			2.54			0.69			2.9			1		
10/17/24 10:12	266063.2			0.9			3.47			0.59			3.62			1		
10/17/24 10:13	240399.6			0.8			6.87			0.44			6.48			1		
10/17/24 10:14	218195.9			0.6			21.24			0.34			18.2			1		
10/17/24 10:15	191631.1			9.6			29.74			4.37			22.38			1		
10/17/24 10:16	170178.3			187.4			33.56			76.08			22.43			1		
10/17/24 10:17	150441.1			793			38.88			284.73			22.97			1		
10/17/24 10:18	102498.6			1423.1			40.29			348.18			16.22			1		
10/17/24 10:19	0			0			44.25			0			0			0		
10/17/24 10:20	0			0			29.5			0			0			0		
10/17/24 10:21	0			0			0.3			0			0			0		
10/17/24 10:22	0			0			0.2			0			0			0		
10/17/24 10:23	0			0			0.1			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 7:46	0			0			0			0			0			0		
10/28/24 7:47	0			0			0			0			0			0		
10/28/24 7:48	0			0			0			0			0			0		
10/28/24 7:49	0			0			0			0			0			0		
10/28/24 7:50	2102.5			0			0			0.07			0			0		
10/28/24 7:51	8340.8			29.5			0			0.59			0			1		
10/28/24 7:52	24727.9			32.5			0			1.92			0			1		
10/28/24 7:53	39532.3			1083.4			14.75			102.1			2.29			1		
10/28/24 7:54	51899.1			1009.6			13.19			124.97			2.69			1		
10/28/24 7:55	64214			677			17.41			103.66			4.39			1		
10/28/24 7:56	83552.7			470.7			20.65			93.87			6.78			1		
10/28/24 7:57	131437.4			385.3			25.4			120.83			13.11			1		
10/28/24 7:58	153941.5			273.8			35.18			100.58			21.27			1		
10/28/24 7:59	160058.4			467.2			40.23			178.4			25.28			1		
10/28/24 8:00	177693.2			1768			35.58			749.58			24.82			1		
10/28/24 8:01	199042			1432.6			37.53			680.47			29.34			1		
10/28/24 8:02	223302			586.5			45.9			312.48			40.25			1		
10/28/24 8:03	246684.1			110			51.3			64.79			49.71			1		
10/28/24 8:04	270880.6			8.4			54.12			5.43			57.56			1		
10/28/24 8:05	298831.6			2.6			52.38			1.84			61.45			1		
10/28/24 8:06	325096			2.2			27.35			1.74			34.91			1		
10/28/24 8:07	346606.5			2.3			19.35			1.87			26.34			1		
10/28/24 8:08	364576.3			2.3			15.22			2.01			21.79			1		
10/28/24 8:09	383793.7			2.3			14.02			2.11			21.13			1		
10/28/24 8:10	389708.5			2.2			9.8			2.02			15			1		
10/28/24 8:11	323322.7			2			10.39			1.56			13.19			1		
10/28/24 8:12	313930.6			1.8			11.71			1.34			14.44			1		
10/28/24 8:13	331640.4			1.8			12.33			1.39			16.06			1		
10/28/24 8:14	350493.9			1.6			10.39			1.33			14.3			1		
10/28/24 8:15	368972			1.5			10.04			1.32			14.55			1		
10/28/24 8:16	375008.1			1.5			8.63			1.34			12.71			1		
10/28/24 8:17	376319.3			1.5			7.93			1.34			11.71			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 8:18	389587.3			1.4			7.49			1.31			11.45			1		
10/28/24 8:19	412258.8			1.5			6.35			1.43			10.29			1		
10/28/24 8:20	434081.3			1.4			6.26			1.41			10.68			1		
10/28/24 8:21	443271.2			1.4			6.36			1.46			11.07			1		
10/28/24 8:22	383106.3			1.4			6.99			1.24			10.52			1		
10/28/24 8:23	352342.3			1.3			9.54			1.09			13.21			1		
10/28/24 8:24	362589.3			1.3			9.2			1.13			13.1			1		
10/28/24 8:25	360989.3			1.3			8.28			1.14			11.73			1		
10/28/24 8:26	313399.2			1.3			8.4			1			10.34			1		
10/28/24 8:27	319054			1.3			9.33			1.01			11.7			1		
10/28/24 8:28	339484.5			1.3			10.01			1.01			13.35			1		
10/28/24 8:29	354502.6			1.3			9.65			1.06			13.44			1		
10/28/24 8:30	345058.5			1.2			8.98			1.02			12.17			1		
10/28/24 8:31	335862.8			1.2			9.86			0.99			13.01			1		
10/28/24 8:32	332229.6			1.3			9.69			1.05			12.64			1		
10/28/24 8:33	333621.6			1.2			9.25			0.98			12.11			1		
10/28/24 8:34	332524.1			1.2			8.58			0.92			11.21			1		
10/28/24 8:35	333217.3			1.1			3.75			0.85			4.91			1		
10/28/24 8:36	330970.4			1.2			2.41			0.92			3.14			1		
10/28/24 8:37	331097.4			1.2			2.41			0.92			3.14			1		
10/28/24 8:38	332737.9			1.2			2.63			0.94			3.44			1		
10/28/24 8:39	333269.3			1.2			2.86			0.92			3.74			1		
10/28/24 8:40	332980.5			1.2			3.04			0.92			3.97			1		
10/28/24 8:41	332027.4			1.1			3.22			0.85			4.2			1		
10/28/24 8:42	333454.2			1.1			3.4			0.85			4.45			1		
10/28/24 8:43	332899.6			1.1			3.49			0.85			4.56			1		
10/28/24 8:44	332004.3			1.2			3.72			0.93			4.85			1		
10/28/24 8:45	331871.5			1.2			3.13			0.92			4.08			1		
10/28/24 8:46	333286.6			1.2			2.5			0.92			3.28			1		
10/28/24 8:47	332350.9			1.1			1.79			0.85			2.33			1		
10/28/24 8:48	331039.7			1.1			1.67			0.83			2.18			1		
10/28/24 8:49	331033.9			1.2			1.61			0.92			2.09			1		
10/28/24 8:50	331380.5			1.2			1.61			0.92			2.09			1		
10/28/24 8:51	333442.5			1.2			1.52			0.92			1.99			1		
10/28/24 8:52	331900.3			1.1			1.41			0.91			1.84			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 8:53	332258.5			1.1			1.45			0.86			1.9			1		
10/28/24 8:54	331802.2			1.1			1.34			0.85			1.75			1		
10/28/24 8:55	333373.3			1.1			1.34			0.85			1.76			1		
10/28/24 8:56	331998.5			1.1			1.34			0.85			1.75			1		
10/28/24 8:57	332547.3			1.1			1.25			0.85			1.63			1		
10/28/24 8:58	332194.9			1.1			1.25			0.85			1.63			0		
10/28/24 8:59	331403.6			1.1			1.16			0.85			1.51			0		
10/28/24 9:00	332166.1			1.1			1.16			0.85			1.52			0		
10/28/24 9:01	332033.2			1.2			1.16			0.92			1.52			0		
10/28/24 9:02	332633.9			1.2			1.07			0.92			1.4			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 7:46	0			0			0			0			0			0		
10/28/24 7:47	0			0			0			0			0			0		
10/28/24 7:48	0			0			0			0			0			0		
10/28/24 7:49	0			0			0			0			0			0		
10/28/24 7:50	2102.5			0			0			0.07			0			0		
10/28/24 7:51	8340.8			29.5			0			0.59			0			1		
10/28/24 7:52	24727.9			32.5			0			1.92			0			1		
10/28/24 7:53	39532.3			1083.4			14.75			102.1			2.29			1		
10/28/24 7:54	51899.1			1009.6			13.19			124.97			2.69			1		
10/28/24 7:55	64214			677			17.41			103.66			4.39			1		
10/28/24 7:56	83552.7			470.7			20.65			93.87			6.78			1		
10/28/24 7:57	131437.4			385.3			25.4			120.83			13.11			1		
10/28/24 7:58	153941.5			273.8			35.18			100.58			21.27			1		
10/28/24 7:59	160058.4			467.2			40.23			178.4			25.28			1		
10/28/24 8:00	177693.2			1768			35.58			749.58			24.82			1		
10/28/24 8:01	199042			1432.6			37.53			680.47			29.34			1		
10/28/24 8:02	223302			586.5			45.9			312.48			40.25			1		
10/28/24 8:03	246684.1			110			51.3			64.79			49.71			1		
10/28/24 8:04	270880.6			8.4			54.12			5.43			57.56			1		
10/28/24 8:05	298831.6			2.6			52.38			1.84			61.45			1		
10/28/24 8:06	325096			2.2			27.35			1.74			34.91			1		
10/28/24 8:07	346606.5			2.3			19.35			1.87			26.34			1		
10/28/24 8:08	364576.3			2.3			15.22			2.01			21.79			1		
10/28/24 8:09	383793.7			2.3			14.02			2.11			21.13			1		
10/28/24 8:10	389708.5			2.2			9.8			2.02			15			1		
10/28/24 8:11	323322.7			2			10.39			1.56			13.19			1		
10/28/24 8:12	313930.6			1.8			11.71			1.34			14.44			1		
10/28/24 8:13	331640.4			1.8			12.33			1.39			16.06			1		
10/28/24 8:14	350493.9			1.6			10.39			1.33			14.3			1		
10/28/24 8:15	368972			1.5			10.04			1.32			14.55			1		
10/28/24 8:16	375008.1			1.5			8.63			1.34			12.71			1		
10/28/24 8:17	376319.3			1.5			7.93			1.34			11.71			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 8:18	389587.3			1.4			7.49			1.31			11.45			1		
10/28/24 8:19	412258.8			1.5			6.35			1.43			10.29			1		
10/28/24 8:20	434081.3			1.4			6.26			1.41			10.68			1		
10/28/24 8:21	443271.2			1.4			6.36			1.46			11.07			1		
10/28/24 8:22	383106.3			1.4			6.99			1.24			10.52			1		
10/28/24 8:23	352342.3			1.3			9.54			1.09			13.21			1		
10/28/24 8:24	362589.3			1.3			9.2			1.13			13.1			1		
10/28/24 8:25	360989.3			1.3			8.28			1.14			11.73			1		
10/28/24 8:26	313399.2			1.3			8.4			1			10.34			1		
10/28/24 8:27	319054			1.3			9.33			1.01			11.7			1		
10/28/24 8:28	339484.5			1.3			10.01			1.01			13.35			1		
10/28/24 8:29	354502.6			1.3			9.65			1.06			13.44			1		
10/28/24 8:30	345058.5			1.2			8.98			1.02			12.17			1		
10/28/24 8:31	335862.8			1.2			9.86			0.99			13.01			1		
10/28/24 8:32	332229.6			1.3			9.69			1.05			12.64			1		
10/28/24 8:33	333621.6			1.2			9.25			0.98			12.11			1		
10/28/24 8:34	332524.1			1.2			8.58			0.92			11.21			1		
10/28/24 8:35	333217.3			1.1			3.75			0.85			4.91			1		
10/28/24 8:36	330970.4			1.2			2.41			0.92			3.14			1		
10/28/24 8:37	331097.4			1.2			2.41			0.92			3.14			1		
10/28/24 8:38	332737.9			1.2			2.63			0.94			3.44			1		
10/28/24 8:39	333269.3			1.2			2.86			0.92			3.74			1		
10/28/24 8:40	332980.5			1.2			3.04			0.92			3.97			1		
10/28/24 8:41	332027.4			1.1			3.22			0.85			4.2			1		
10/28/24 8:42	333454.2			1.1			3.4			0.85			4.45			1		
10/28/24 8:43	332899.6			1.1			3.49			0.85			4.56			1		
10/28/24 8:44	332004.3			1.2			3.72			0.93			4.85			1		
10/28/24 8:45	331871.5			1.2			3.13			0.92			4.08			1		
10/28/24 8:46	333286.6			1.2			2.5			0.92			3.28			1		
10/28/24 8:47	332350.9			1.1			1.79			0.85			2.33			1		
10/28/24 8:48	331039.7			1.1			1.67			0.83			2.18			1		
10/28/24 8:49	331033.9			1.2			1.61			0.92			2.09			1		
10/28/24 8:50	331380.5			1.2			1.61			0.92			2.09			1		
10/28/24 8:51	333442.5			1.2			1.52			0.92			1.99			1		
10/28/24 8:52	331900.3			1.1			1.41			0.91			1.84			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 8:53	332258.5			1.1			1.45			0.86			1.9			1		
10/28/24 8:54	331802.2			1.1			1.34			0.85			1.75			1		
10/28/24 8:55	333373.3			1.1			1.34			0.85			1.76			1		
10/28/24 8:56	331998.5			1.1			1.34			0.85			1.75			1		
10/28/24 8:57	332547.3			1.1			1.25			0.85			1.63			1		
10/28/24 8:58	332194.9			1.1			1.25			0.85			1.63			0		
10/28/24 8:59	331403.6			1.1			1.16			0.85			1.51			0		
10/28/24 9:00	332166.1			1.1			1.16			0.85			1.52			0		
10/28/24 9:01	332033.2			1.2			1.16			0.92			1.52			0		
10/28/24 9:02	332633.9			1.2			1.07			0.92			1.4			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 7:46	0			0			0			0			0			0		
10/28/24 7:47	0			0			0			0			0			0		
10/28/24 7:48	0			0			0			0			0			0		
10/28/24 7:49	0			0			0			0			0			0		
10/28/24 7:50	2102.5			0			0			0.07			0			0		
10/28/24 7:51	8340.8			29.5			0			0.59			0			1		
10/28/24 7:52	24727.9			32.5			0			1.92			0			1		
10/28/24 7:53	39532.3			1083.4			14.75			102.1			2.29			1		
10/28/24 7:54	51899.1			1009.6			13.19			124.97			2.69			1		
10/28/24 7:55	64214			677			17.41			103.66			4.39			1		
10/28/24 7:56	83552.7			470.7			20.65			93.87			6.78			1		
10/28/24 7:57	131437.4			385.3			25.4			120.83			13.11			1		
10/28/24 7:58	153941.5			273.8			35.18			100.58			21.27			1		
10/28/24 7:59	160058.4			467.2			40.23			178.4			25.28			1		
10/28/24 8:00	177693.2			1768			35.58			749.58			24.82			1		
10/28/24 8:01	199042			1432.6			37.53			680.47			29.34			1		
10/28/24 8:02	223302			586.5			45.9			312.48			40.25			1		
10/28/24 8:03	246684.1			110			51.3			64.79			49.71			1		
10/28/24 8:04	270880.6			8.4			54.12			5.43			57.56			1		
10/28/24 8:05	298831.6			2.6			52.38			1.84			61.45			1		
10/28/24 8:06	325096			2.2			27.35			1.74			34.91			1		
10/28/24 8:07	346606.5			2.3			19.35			1.87			26.34			1		
10/28/24 8:08	364576.3			2.3			15.22			2.01			21.79			1		
10/28/24 8:09	383793.7			2.3			14.02			2.11			21.13			1		
10/28/24 8:10	389708.5			2.2			9.8			2.02			15			1		
10/28/24 8:11	323322.7			2			10.39			1.56			13.19			1		
10/28/24 8:12	313930.6			1.8			11.71			1.34			14.44			1		
10/28/24 8:13	331640.4			1.8			12.33			1.39			16.06			1		
10/28/24 8:14	350493.9			1.6			10.39			1.33			14.3			1		
10/28/24 8:15	368972			1.5			10.04			1.32			14.55			1		
10/28/24 8:16	375008.1			1.5			8.63			1.34			12.71			1		
10/28/24 8:17	376319.3			1.5			7.93			1.34			11.71			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 8:18	389587.3			1.4			7.49			1.31			11.45			1		
10/28/24 8:19	412258.8			1.5			6.35			1.43			10.29			1		
10/28/24 8:20	434081.3			1.4			6.26			1.41			10.68			1		
10/28/24 8:21	443271.2			1.4			6.36			1.46			11.07			1		
10/28/24 8:22	383106.3			1.4			6.99			1.24			10.52			1		
10/28/24 8:23	352342.3			1.3			9.54			1.09			13.21			1		
10/28/24 8:24	362589.3			1.3			9.2			1.13			13.1			1		
10/28/24 8:25	360989.3			1.3			8.28			1.14			11.73			1		
10/28/24 8:26	313399.2			1.3			8.4			1			10.34			1		
10/28/24 8:27	319054			1.3			9.33			1.01			11.7			1		
10/28/24 8:28	339484.5			1.3			10.01			1.01			13.35			1		
10/28/24 8:29	354502.6			1.3			9.65			1.06			13.44			1		
10/28/24 8:30	345058.5			1.2			8.98			1.02			12.17			1		
10/28/24 8:31	335862.8			1.2			9.86			0.99			13.01			1		
10/28/24 8:32	332229.6			1.3			9.69			1.05			12.64			1		
10/28/24 8:33	333621.6			1.2			9.25			0.98			12.11			1		
10/28/24 8:34	332524.1			1.2			8.58			0.92			11.21			1		
10/28/24 8:35	333217.3			1.1			3.75			0.85			4.91			1		
10/28/24 8:36	330970.4			1.2			2.41			0.92			3.14			1		
10/28/24 8:37	331097.4			1.2			2.41			0.92			3.14			1		
10/28/24 8:38	332737.9			1.2			2.63			0.94			3.44			1		
10/28/24 8:39	333269.3			1.2			2.86			0.92			3.74			1		
10/28/24 8:40	332980.5			1.2			3.04			0.92			3.97			1		
10/28/24 8:41	332027.4			1.1			3.22			0.85			4.2			1		
10/28/24 8:42	333454.2			1.1			3.4			0.85			4.45			1		
10/28/24 8:43	332899.6			1.1			3.49			0.85			4.56			1		
10/28/24 8:44	332004.3			1.2			3.72			0.93			4.85			1		
10/28/24 8:45	331871.5			1.2			3.13			0.92			4.08			1		
10/28/24 8:46	333286.6			1.2			2.5			0.92			3.28			1		
10/28/24 8:47	332350.9			1.1			1.79			0.85			2.33			1		
10/28/24 8:48	331039.7			1.1			1.67			0.83			2.18			1		
10/28/24 8:49	331033.9			1.2			1.61			0.92			2.09			1		
10/28/24 8:50	331380.5			1.2			1.61			0.92			2.09			1		
10/28/24 8:51	333442.5			1.2			1.52			0.92			1.99			1		
10/28/24 8:52	331900.3			1.1			1.41			0.91			1.84			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 8:53	332258.5			1.1			1.45			0.86			1.9			1		
10/28/24 8:54	331802.2			1.1			1.34			0.85			1.75			1		
10/28/24 8:55	333373.3			1.1			1.34			0.85			1.76			1		
10/28/24 8:56	331998.5			1.1			1.34			0.85			1.75			1		
10/28/24 8:57	332547.3			1.1			1.25			0.85			1.63			1		
10/28/24 8:58	332194.9			1.1			1.25			0.85			1.63			0		
10/28/24 8:59	331403.6			1.1			1.16			0.85			1.51			0		
10/28/24 9:00	332166.1			1.1			1.16			0.85			1.52			0		
10/28/24 9:01	332033.2			1.2			1.16			0.92			1.52			0		
10/28/24 9:02	332633.9			1.2			1.07			0.92			1.4			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 7:46	0			0			0			0			0			0		
10/28/24 7:47	0			0			0			0			0			0		
10/28/24 7:48	0			0			0			0			0			0		
10/28/24 7:49	0			0			0			0			0			0		
10/28/24 7:50	2102.5			0			0			0.07			0			0		
10/28/24 7:51	8340.8			29.5			0			0.59			0			1		
10/28/24 7:52	24727.9			32.5			0			1.92			0			1		
10/28/24 7:53	39532.3			1083.4			14.75			102.1			2.29			1		
10/28/24 7:54	51899.1			1009.6			13.19			124.97			2.69			1		
10/28/24 7:55	64214			677			17.41			103.66			4.39			1		
10/28/24 7:56	83552.7			470.7			20.65			93.87			6.78			1		
10/28/24 7:57	131437.4			385.3			25.4			120.83			13.11			1		
10/28/24 7:58	153941.5			273.8			35.18			100.58			21.27			1		
10/28/24 7:59	160058.4			467.2			40.23			178.4			25.28			1		
10/28/24 8:00	177693.2			1768			35.58			749.58			24.82			1		
10/28/24 8:01	199042			1432.6			37.53			680.47			29.34			1		
10/28/24 8:02	223302			586.5			45.9			312.48			40.25			1		
10/28/24 8:03	246684.1			110			51.3			64.79			49.71			1		
10/28/24 8:04	270880.6			8.4			54.12			5.43			57.56			1		
10/28/24 8:05	298831.6			2.6			52.38			1.84			61.45			1		
10/28/24 8:06	325096			2.2			27.35			1.74			34.91			1		
10/28/24 8:07	346606.5			2.3			19.35			1.87			26.34			1		
10/28/24 8:08	364576.3			2.3			15.22			2.01			21.79			1		
10/28/24 8:09	383793.7			2.3			14.02			2.11			21.13			1		
10/28/24 8:10	389708.5			2.2			9.8			2.02			15			1		
10/28/24 8:11	323322.7			2			10.39			1.56			13.19			1		
10/28/24 8:12	313930.6			1.8			11.71			1.34			14.44			1		
10/28/24 8:13	331640.4			1.8			12.33			1.39			16.06			1		
10/28/24 8:14	350493.9			1.6			10.39			1.33			14.3			1		
10/28/24 8:15	368972			1.5			10.04			1.32			14.55			1		
10/28/24 8:16	375008.1			1.5			8.63			1.34			12.71			1		
10/28/24 8:17	376319.3			1.5			7.93			1.34			11.71			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 8:18	389587.3			1.4			7.49			1.31			11.45			1		
10/28/24 8:19	412258.8			1.5			6.35			1.43			10.29			1		
10/28/24 8:20	434081.3			1.4			6.26			1.41			10.68			1		
10/28/24 8:21	443271.2			1.4			6.36			1.46			11.07			1		
10/28/24 8:22	383106.3			1.4			6.99			1.24			10.52			1		
10/28/24 8:23	352342.3			1.3			9.54			1.09			13.21			1		
10/28/24 8:24	362589.3			1.3			9.2			1.13			13.1			1		
10/28/24 8:25	360989.3			1.3			8.28			1.14			11.73			1		
10/28/24 8:26	313399.2			1.3			8.4			1			10.34			1		
10/28/24 8:27	319054			1.3			9.33			1.01			11.7			1		
10/28/24 8:28	339484.5			1.3			10.01			1.01			13.35			1		
10/28/24 8:29	354502.6			1.3			9.65			1.06			13.44			1		
10/28/24 8:30	345058.5			1.2			8.98			1.02			12.17			1		
10/28/24 8:31	335862.8			1.2			9.86			0.99			13.01			1		
10/28/24 8:32	332229.6			1.3			9.69			1.05			12.64			1		
10/28/24 8:33	333621.6			1.2			9.25			0.98			12.11			1		
10/28/24 8:34	332524.1			1.2			8.58			0.92			11.21			1		
10/28/24 8:35	333217.3			1.1			3.75			0.85			4.91			1		
10/28/24 8:36	330970.4			1.2			2.41			0.92			3.14			1		
10/28/24 8:37	331097.4			1.2			2.41			0.92			3.14			1		
10/28/24 8:38	332737.9			1.2			2.63			0.94			3.44			1		
10/28/24 8:39	333269.3			1.2			2.86			0.92			3.74			1		
10/28/24 8:40	332980.5			1.2			3.04			0.92			3.97			1		
10/28/24 8:41	332027.4			1.1			3.22			0.85			4.2			1		
10/28/24 8:42	333454.2			1.1			3.4			0.85			4.45			1		
10/28/24 8:43	332899.6			1.1			3.49			0.85			4.56			1		
10/28/24 8:44	332004.3			1.2			3.72			0.93			4.85			1		
10/28/24 8:45	331871.5			1.2			3.13			0.92			4.08			1		
10/28/24 8:46	333286.6			1.2			2.5			0.92			3.28			1		
10/28/24 8:47	332350.9			1.1			1.79			0.85			2.33			1		
10/28/24 8:48	331039.7			1.1			1.67			0.83			2.18			1		
10/28/24 8:49	331033.9			1.2			1.61			0.92			2.09			1		
10/28/24 8:50	331380.5			1.2			1.61			0.92			2.09			1		
10/28/24 8:51	333442.5			1.2			1.52			0.92			1.99			1		
10/28/24 8:52	331900.3			1.1			1.41			0.91			1.84			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 8:53	332258.5			1.1			1.45			0.86			1.9			1		
10/28/24 8:54	331802.2			1.1			1.34			0.85			1.75			1		
10/28/24 8:55	333373.3			1.1			1.34			0.85			1.76			1		
10/28/24 8:56	331998.5			1.1			1.34			0.85			1.75			1		
10/28/24 8:57	332547.3			1.1			1.25			0.85			1.63			1		
10/28/24 8:58	332194.9			1.1			1.25			0.85			1.63			0		
10/28/24 8:59	331403.6			1.1			1.16			0.85			1.51			0		
10/28/24 9:00	332166.1			1.1			1.16			0.85			1.52			0		
10/28/24 9:01	332033.2			1.2			1.16			0.92			1.52			0		
10/28/24 9:02	332633.9			1.2			1.07			0.92			1.4			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 8:59	331403.6			1.1			1.16			0.85			1.51			0		
10/28/24 9:00	332166.1			1.1			1.16			0.85			1.52			0		
10/28/24 9:01	332033.2			1.2			1.16			0.92			1.52			0		
10/28/24 9:02	332633.9			1.2			1.07			0.92			1.4			0		
10/28/24 9:03	330600.7			1.2			1.09			0.93			1.41			0		
10/28/24 9:04	330814.4			1.2			1.07			0.92			1.39			1		
10/28/24 9:05	316166			1.2			1.07			0.88			1.33			1		
10/28/24 9:06	292882.1			1.2			1.18			0.82			1.36			1		
10/28/24 9:07	268610.5			1.2			1.75			0.77			1.85			1		
10/28/24 9:08	244876.1			1.1			4.74			0.62			4.56			1		
10/28/24 9:09	220258			0.9			12.52			0.49			10.83			1		
10/28/24 9:10	193889.6			14.3			19.55			6.64			14.89			1		
10/28/24 9:11	172939.4			199.6			25.7			82.32			17.45			1		
10/28/24 9:12	152751.6			722.6			30.68			263.33			18.4			1		
10/28/24 9:13	93060.3			1313.3			36.75			291.63			13.43			1		
10/28/24 9:14	0			0			40.02			0			0			0		
10/28/24 9:15	0			0			11.8			0			0			0		
10/28/24 9:16	0			0			5.9			0			0			0		
10/28/24 9:17	0			0			5.9			0			0			0		
10/28/24 9:18	0			0			5.9			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/24 8:40	0			0	X		0	X		0	X		0	X		0		
10/29/24 8:41	0			0	X		0	X		0	X		0	X		0		
10/29/24 8:42	0			0	X		0	X		0	X		0	X		0		
10/29/24 8:43	0			0	X		0	X		0	X		0	X		0		
10/29/24 8:44	0			0	X		0	X		0	X		0	X		0		
10/29/24 8:45	3737.2			29.5	X		0	X		0.26	X		0	X		1		
10/29/24 8:46	20494			29.5	X		0	X		1.44	X		0	X		1		
10/29/24 8:47	36176.3			1331.9	X		19.18	X		115.08	X		2.73	X		1		
10/29/24 8:48	48144.6			1215	X		12.98	X		139.52	X		2.45	X		1		
10/29/24 8:49	60118.7			800.5	X		16.15	X		114.87	X		3.81	X		1		
10/29/24 8:50	74339.7			543.9	X		20.23	X		96.43	X		5.9	X		1		
10/29/24 8:51	111469.1			417.1	X		24.11	X		110.92	X		10.55	X		1		
10/29/24 8:52	154103.2			320	X		25.02	X		117.7	X		15.14	X		1		
10/29/24 8:53	163206.5			227.7	X		20.85	X		88.7	X		13.36	X		1		
10/29/24 8:54	173984.9			1378.5	X		18.39	X		572.41	X		12.57	X		1		
10/29/24 8:55	193288.9			1521.9	X		17.37	X		701.77	X		13.18	X		1		
10/29/24 8:56	217017.5			766.3	X		15.64	X		396.74	X		13.32	X		1		
10/29/24 8:57	240890.6			187.5	X		14.21	X		107.76	X		13.45	X		1		
10/29/24 8:58	263856.7			16	X		12.51	X		10.11	X		12.96	X		1		
10/29/24 8:59	290461.9			2.7	X		11.37	X		1.86	X		12.97	X		1		
10/29/24 9:00	317841.1			2	X		10.25	X		1.54	X		12.8	X		1		
10/29/24 9:01	338537.2			2.1	X		9.48	X		1.66	X		12.6	X		1		
10/29/24 9:02	337636.1			2.2	X		8.93	X		1.77	X		11.85	X		1		
10/29/24 9:03	335608.6			2.4	X		8.93	X		1.89	X		11.77	X		1		
10/29/24 9:04	334395.7			2.2	X		9.06	X		1.77	X		11.9	X		1		
10/29/24 9:05	332391.3			2.1	X		9.06	X		1.63	X		11.83	X		1		
10/29/24 9:06	333771.8			1.9	X		9.06	X		1.5	X		11.88	X		1		
10/29/24 9:07	332703.2			1.7	X		9.2	X		1.38	X		12.01	X		1		
10/29/24 9:08	333119.1			1.6	X		9.2	X		1.24	X		12.03	X		1		
10/29/24 9:09	330271.5			1.5	X		9.33	X		1.18	X		12.11	X		1		
10/29/24 9:10	331790.6			1.4	X		9.33	X		1.12	X		12.16	X		1		
10/29/24 9:11	332044.7			1.3	X		9.33	X		1.05	X		12.17	X		1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/24 9:12	337208.7			1.4	X		9.33	X		1.13	X		12.36	X		1		
10/29/24 9:13	355611.6			1.4	X		9.33	X		1.2	X		13.04	X		1		
10/29/24 9:14	371969.8			1.3	X		9.33	X		1.17	X		13.63	X		1		
10/29/24 9:15	375227.6			1.3	X		8.54	X		1.18	X		12.59	X		1		
10/29/24 9:16	373182.8			1.3	X		8.01	X		1.18	X		11.74	X		1		
10/29/24 9:17	374326.5			1.3	X		8.1	X		1.18	X		11.91	X		1		
10/29/24 9:18	374586.5			1.2	X		8.1	X		1.1	X		11.92	X		1		
10/29/24 9:19	373702.7			1.2	X		8.01	X		1.1	X		11.76	X		1		
10/29/24 9:20	372189.3			1.2	X		7.93	X		1.09	X		11.58	X		1		
10/29/24 9:21	371663.7			1.3	X		7.75	X		1.17	X		11.31	X		1		
10/29/24 9:22	371686.8			1.2	X		7.75	X		1.09	X		11.31	X		1		
10/29/24 9:23	372507			1.1	X		7.66	X		1.02	X		11.21	X		1		
10/29/24 9:24	371964			1.2	X		7.66	X		1.09	X		11.19	X		1		
10/29/24 9:25	379744.6			1.2	X		7.46	X		1.1	X		11.13	X		1		
10/29/24 9:26	399204.6			1.2	X		6.52	X		1.17	X		10.21	X		1		
10/29/24 9:27	405350.5			1.2	X		6.17	X		1.12	X		9.82	X		1		
10/29/24 9:28	407695.6			1.2	X		5.27	X		1.13	X		8.44	X		1		
10/29/24 9:29	407181.5			1.2	X		3.49	X		1.13	X		5.57	X		1		
10/29/24 9:30	411386.6			1.2	X		2.59	X		1.14	X		4.19	X		1		
10/29/24 9:31	427744.8			1.1	X		2.06	X		1.09	X		3.45	X		1		
10/29/24 9:32	443092.1			1.1	X		1.54	X		1.15	X		2.68	X		1		
10/29/24 9:33	445564.4			1.1	X		1.48	X		1.18	X		2.58	X		1		
10/29/24 9:34	448192.5			1.1	X		1.45	X		1.16	X		2.56	X		1		
10/29/24 9:35	446113.1			1.1	X		1.45	X		1.16	X		2.54	X		1		
10/29/24 9:36	446552.1			1.1	X		1.27	X		1.16	X		2.23	X		1		
10/29/24 9:37	445477.7			1.1	X		1.18	X		1.16	X		2.06	X		1		
10/29/24 9:38	445945.6			1.2	X		1.09	X		1.26	X		1.91	X		1		
10/29/24 9:39	445206.2			1.1	X		1.09	X		1.16	X		1.9	X		1		
10/29/24 9:40	443652.4			1.1	X		1	X		1.15	X		1.74	X		1		
10/29/24 9:41	444796.1			1	X		0.91	X		1.06	X		1.59	X		1		
10/29/24 9:42	445206.3			1	X		0.91	X		1.06	X		1.59	X		0		
10/29/24 9:43	451710.3			0.9	X		0.82	X		0.98	X		1.45	X		0		
10/29/24 9:44	468264.8			1	X		0.82	X		1.12	X		1.5	X		0		
10/29/24 9:45	475987.6			1	X		0.73	X		1.13	X		1.36	X		0		
10/29/24 9:46	479568.9			1	X		0.73	X		1.14	X		1.37	X		0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/05/24 9:54	370260			0.9			1.16			0.78			1.67			0		
11/05/24 9:55	373275.2			1			1.16			0.87			1.68			0		
11/05/24 9:56	375164			1.1			1.16			0.95			1.69			0		
11/05/24 9:57	377370.5			1.1			1.16			0.95			1.7			0		
11/05/24 9:58	375747.5			1.1			1.16			0.95			1.7			0		
11/05/24 9:59	106703.7			25.4			1.25			6.39			0.52			1		
11/05/24 10:00	0			0			0.98			0			0			0		
11/05/24 10:01	0			0			0			0			0			0		
11/05/24 10:02	0			0			0			0			0			0		
11/05/24 10:03	0			0			0			0			0			0		
11/05/24 10:04	0			0			0			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/05/24 10:14	0			0			0			0			0			0		
11/05/24 10:15	0			0			0			0			0			0		
11/05/24 10:16	0			0			0			0			0			0		
11/05/24 10:17	0			0			0			0			0			0		
11/05/24 10:18	3771.9			0			0			0			0			0		
11/05/24 10:19	7745.9			0.2			0			0			0			1		
11/05/24 10:20	22694.7			0.9			0			0			0			1		
11/05/24 10:21	38232.7			775.1			0.74			69.92			0.11			1		
11/05/24 10:22	50836.3			755.6			4.33			90.66			0.85			1		
11/05/24 10:23	62729.5			480.5			6.56			71.1			1.6			1		
11/05/24 10:24	86019.1			305.2			9.01			61.91			3.01			1		
11/05/24 10:25	132841			223.4			13.2			70			6.81			1		
11/05/24 10:26	156176.8			166.3			20.2			61.29			12.25			1		
11/05/24 10:27	189037.6			693.9			24.36			309.42			17.88			1		
11/05/24 10:28	214943.9			774.3			27.11			392.6			22.62			1		
11/05/24 10:29	239435			110			30.44			62.1			28.29			1		
11/05/24 10:30	264653.8			5.8			32.33			3.61			33.22			1		
11/05/24 10:31	291732.7			1.3			29.93			0.89			33.89			1		
11/05/24 10:32	317685.1			1.1			13.25			0.8			16.34			1		
11/05/24 10:33	339911.9			1			9.65			0.79			12.74			1		
11/05/24 10:34	359250.7			1.1			7.49			0.97			10.44			1		
11/05/24 10:35	372986.5			1.1			7.2			0.99			10.43			1		
11/05/24 10:36	372911.3			1.2			6.25			1.07			9.04			1		
11/05/24 10:37	373009.5			1.1			6.16			0.99			8.92			1		
11/05/24 10:38	373055.8			1.1			6.25			1.01			9.05			1		
11/05/24 10:39	371496.2			1.1			6.08			0.93			8.76			1		
11/05/24 10:40	375348.9			1			5.99			0.86			8.72			1		
11/05/24 10:41	372518.6			0.9			5.99			0.77			8.66			1		
11/05/24 10:42	370733.7			0.9			5.01			0.78			7.21			1		
11/05/24 10:43	372293.3			1			2.91			0.85			4.2			1		
11/05/24 10:44	372102.7			1			2.38			0.85			3.43			1		
11/05/24 10:45	372616.8			1			2.41			0.86			3.49			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/05/24 10:46	371698.3			1			2.41			0.86			3.48			1		
11/05/24 10:47	371276.7			1			2.41			0.86			3.48			1		
11/05/24 10:48	371230.5			0.9			2.41			0.78			3.48			1		
11/05/24 10:49	372021.8			0.9			2.32			0.78			3.36			1		
11/05/24 10:50	369364.7			0.8			2.32			0.7			3.33			1		
11/05/24 10:51	372131.6			0.9			2.23			0.78			3.23			1		
11/05/24 10:52	370629.8			0.9			2.15			0.78			3.09			1		
11/05/24 10:53	370618.2			1			2.15			0.86			3.09			1		
11/05/24 10:54	371605.9			0.9			2.06			0.78			2.97			1		
11/05/24 10:55	369722.9			0.9			2.06			0.78			2.95			1		
11/05/24 10:56	370606.6			1			2.06			0.86			2.96			1		
11/05/24 10:57	370358.3			1			1.97			0.86			2.83			1		
11/05/24 10:58	371057.2			1			1.97			0.86			2.83			1		
11/05/24 10:59	370745.3			1			1.97			0.86			2.83			1		
11/05/24 11:00	370572			0.9			1.88			0.78			2.7			1		
11/05/24 11:01	370433.3			0.9			1.88			0.78			2.7			1		
11/05/24 11:02	371704.1			0.8			1.88			0.71			2.71			1		
11/05/24 11:03	369087.5			0.8			1.91			0.71			2.73			1		
11/05/24 11:04	369613.2			0.9			1.88			0.78			2.69			1		
11/05/24 11:05	368504.1			0.9			1.82			0.79			2.6			1		
11/05/24 11:06	369809.5			1			1.79			0.86			2.57			0		
11/05/24 11:07	370208.1			1			1.7			0.86			2.44			0		
11/05/24 11:08	369249.2			1			1.7			0.86			2.43			0		
11/05/24 11:09	370837.7			1			1.61			0.86			2.32			0		
11/05/24 11:10	369243.4			1			1.52			0.86			2.18			0		
11/05/24 11:11	369445.6			0.9			1.52			0.78			2.18			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/06/24 11:40	377803.8			1			1.45			0.89			2.13			0		
11/06/24 11:41	377953.9			1			1.48			0.9			2.16			0		
11/06/24 11:42	378133			1			1.38			0.9			2.03			0		
11/06/24 11:43	378167.7			1			1.36			0.89			2			0		
11/06/24 11:44	378768.4			1			1.36			0.89			2			0		
11/06/24 11:45	375424			1			1.36			0.88			1.98			1		
11/06/24 11:46	356397.2			0.9			1.36			0.76			1.88			1		
11/06/24 11:47	332119.8			1			1.45			0.78			1.87			1		
11/06/24 11:48	308616.5			1			2			0.73			2.39			1		
11/06/24 11:49	285246			1			2.3			0.68			2.55			1		
11/06/24 11:50	261009.1			0.9			3.56			0.58			3.61			1		
11/06/24 11:51	236506.4			0.9			7.77			0.49			7.13			1		
11/06/24 11:52	211830.5			0.7			21.96			0.33			18.06			1		
11/06/24 11:53	185826			17.2			29.26			7.55			21.11			1		
11/06/24 11:54	165782.7			231			33.25			90.35			21.4			1		
11/06/24 11:55	145797			864.5			38.35			297.24			21.7			1		
11/06/24 11:56	68245.8			1464.8			40.23			235.75			10.66			1		
11/06/24 11:57	0			0			41.3			0			0			0		
11/06/24 11:58	0			0			17.7			0			0			0		
11/06/24 11:59	0			0			0.2			0			0			0		
11/06/24 12:00	0			0			0.2			0			0			0		
11/06/24 12:01	0			0			0.1			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/24 14:17	0			0			0			0			0			0		
11/07/24 14:18	0			0			0			0			0			0		
11/07/24 14:19	0			0			0			0			0			0		
11/07/24 14:20	0			0			0			0			0			0		
11/07/24 14:21	0			0			0			0			0			0		
11/07/24 14:22	5117.7			0.2			0			0			0			1		
11/07/24 14:23	14683.1			0.3			0			0			0			1		
11/07/24 14:24	30787.1			24.9			0.6			0			0			1		
11/07/24 14:25	44297.7			1323.2			17.16			138.32			2.95			1		
11/07/24 14:26	56329.5			916			19.18			121.79			4.2			1		
11/07/24 14:27	68546.1			549.9			23.91			88.88			6.36			1		
11/07/24 14:28	98894.3			388.6			27.81			90.63			10.68			1		
11/07/24 14:29	145346.5			251.9			36.94			86.39			20.85			1		
11/07/24 14:30	154594.2			166			53.1			60.55			31.87			1		
11/07/24 14:31	168878.7			1004.7			55.5			400.3			36.39			1		
11/07/24 14:32	191232.6			1373.3			56.57			619.43			41.99			1		
11/07/24 14:33	215013.2			604.4			63.35			306.59			52.88			1		
11/07/24 14:34	239336.8			99.8			64.63			56.32			60.05			1		
11/07/24 14:35	263238.7			6.5			59.94			4.03			61.26			1		
11/07/24 14:36	291461.2			2			59			1.4			66.75			1		
11/07/24 14:37	316223.8			1.8			32.16			1.32			39.47			1		
11/07/24 14:38	339143.7			1.7			18.42			1.36			24.25			1		
11/07/24 14:39	360556			1.8			14.09			1.57			19.72			1		
11/07/24 14:40	375920.8			1.9			13.19			1.69			19.24			1		
11/07/24 14:41	378052.2			1.9			10.41			1.7			15.28			1		
11/07/24 14:42	378404.5			1.8			10.04			1.57			14.75			1		
11/07/24 14:43	378496.9			1.7			9.69			1.49			14.23			1		
11/07/24 14:44	375915			1.6			8.81			1.41			12.85			1		
11/07/24 14:45	377815.3			1.5			8.72			1.33			12.79			1		
11/07/24 14:46	376434.8			1.3			8.58			1.19			12.54			1		
11/07/24 14:47	375666.6			1.3			8.13			1.19			11.86			1		
11/07/24 14:48	374759.7			1.3			7.78			1.11			11.31			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/24 14:49	373298.3			1.3			7.51			1.1			10.88			1		
11/07/24 14:50	375568.4			1.2			7.33			1.03			10.69			1		
11/07/24 14:51	374274.5			1.2			7.24			1.03			10.52			1		
11/07/24 14:52	372293.3			1.1			7.15			0.94			10.34			1		
11/07/24 14:53	373743.1			1.2			7.17			1.04			10.4			1		
11/07/24 14:54	372541.6			1.1			7.17			0.96			10.37			1		
11/07/24 14:55	371611.7			1			7.08			0.88			10.21			1		
11/07/24 14:56	372229.8			1			7.08			0.88			10.23			1		
11/07/24 14:57	371756.1			1			7.08			0.88			10.22			1		
11/07/24 14:58	370808.8			1			7.08			0.87			10.19			1		
11/07/24 14:59	370444.9			1			7.08			0.87			10.18			1		
11/07/24 15:00	371247.8			1			7.08			0.87			10.2			1		
11/07/24 15:01	369324.3			1			7.17			0.87			10.28			1		
11/07/24 15:02	371438.4			1			7.08			0.87			10.21			1		
11/07/24 15:03	369751.8			1			4.72			0.87			6.77			1		
11/07/24 15:04	369387.8			1.2			2.54			1.03			3.64			1		
11/07/24 15:05	370676			1.2			2.36			1.03			3.4			1		
11/07/24 15:06	367995.8			1.1			2.36			0.95			3.37			1		
11/07/24 15:07	369110.6			1			2.45			0.87			3.51			1		
11/07/24 15:08	369821.1			1.1			2.54			0.95			3.65			1		
11/07/24 15:09	370410.3			1.1			2.63			0.95			3.78			1		
11/07/24 15:10	369203			1.1			2.63			0.95			3.77			1		
11/07/24 15:11	369676.7			1.1			2.72			0.95			3.91			1		
11/07/24 15:12	369636.3			1			2.63			0.87			3.78			1		
11/07/24 15:13	369174.2			1			2.09			0.87			2.99			1		
11/07/24 15:14	369624.7			1			1.82			0.87			2.6			1		
11/07/24 15:15	369093.3			1			1.63			0.87			2.34			1		
11/07/24 15:16	368498.3			1			1.45			0.87			2.08			1		
11/07/24 15:17	368977.8			1			1.18			0.87			1.69			1		
11/07/24 15:18	368198			1.1			1			0.95			1.43			1		
11/07/24 15:19	368608.1			1.1			0.91			0.95			1.3			1		
11/07/24 15:20	367574.1			1.1			0.73			0.94			1.04			1		
11/07/24 15:21	367949.6			1.1			0.73			0.95			1.04			1		
11/07/24 15:22	368354			1			0.64			0.87			0.91			1		
11/07/24 15:23	369595.8			1			0.54			0.87			0.78			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/24 15:24	368590.8			1			0.54			0.87			0.78			0		
11/07/24 15:25	369457.2			1.1			0.54			0.95			0.78			0		
11/07/24 15:26	369018.2			1.1			0.54			0.95			0.78			0		
11/07/24 15:27	367972.7			1.1			0.54			0.95			0.78			0		
11/07/24 15:28	368977.8			1			0.54			0.87			0.78			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/08/24 8:45	370762.6			1.1			0.79			1			1.14			0		
11/08/24 8:46	371455.8			1.1			0.79			1			1.14			0		
11/08/24 8:47	371559.8			1.2			0.8			1.02			1.16			0		
11/08/24 8:48	370855			1.1			0.8			0.94			1.16			0		
11/08/24 8:49	370733.7			1.1			0.8			0.94			1.16			0		
11/08/24 8:50	369116.4			1.2			0.8			1.01			1.15			1		
11/08/24 8:51	354693.2			1.2			0.8			0.97			1.11			1		
11/08/24 8:52	333020.9			1.1			0.88			0.9			1.14			1		
11/08/24 8:53	310072.1			1.1			1.07			0.78			1.29			1		
11/08/24 8:54	285113.1			1.1			1.45			0.73			1.61			1		
11/08/24 8:55	259669			1			3			0.63			3.02			1		
11/08/24 8:56	235755.5			0.8			9.56			0.45			8.75			1		
11/08/24 8:57	211281.8			2.1			16.03			1.05			13.15			1		
11/08/24 8:58	186652.1			67.1			19.67			29.55			14.25			1		
11/08/24 8:59	167059.2			437.2			23.6			172.23			15.3			1		
11/08/24 9:00	147079.3			1067.7			26.95			370.47			15.39			1		
11/08/24 9:01	34004.5			1424			30.04			114.12			3.96			1		
11/08/24 9:02	0			0			29.5			0			0			0		
11/08/24 9:03	0			0			11.8			0			0			0		
11/08/24 9:04	0			0			0.1			0			0			0		
11/08/24 9:05	0			0			0.1			0			0			0		
11/08/24 9:06	0			0			5.9			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/08/24 18:16	0			0			0			0			0			0		
11/08/24 18:17	0			0			0			0			0			0		
11/08/24 18:18	0			0			0			0			0			0		
11/08/24 18:19	0			0			0			0			0			0		
11/08/24 18:20	0			0			0			0			0			0		
11/08/24 18:21	8647			17.7			0			0.36			0			1		
11/08/24 18:22	25236.2			2.2			0.1			0			0			1		
11/08/24 18:23	39948.2			1212.1			13.11			114.23			2.03			1		
11/08/24 18:24	52320.8			1081.7			12.98			133.41			2.63			1		
11/08/24 18:25	64167.8			644.1			17.04			97.46			4.24			1		
11/08/24 18:26	83564.3			418.6			20.65			82.55			6.7			1		
11/08/24 18:27	131015.7			277			25.21			85.64			12.83			1		
11/08/24 18:28	156101.7			192			38.12			70.69			23.1			1		
11/08/24 18:29	179472.3			516.6			42.96			218.68			29.93			1		
11/08/24 18:30	201635.5			1127.1			46.19			536.12			36.16			1		
11/08/24 18:31	226964.1			334			46.19			178.84			40.71			1		
11/08/24 18:32	250975.8			32.3			46.7			19.1			45.5			1		
11/08/24 18:33	274710.2			2.6			48.79			1.69			52.03			1		
11/08/24 18:34	302672.8			1.9			39.33			1.33			46.21			1		
11/08/24 18:35	328013			1.5			18.25			1.14			23.24			1		
11/08/24 18:36	348737.9			1.4			12.75			1.14			17.27			1		
11/08/24 18:37	370774.2			1.6			11.02			1.37			15.86			1		
11/08/24 18:38	378485.4			1.6			10.09			1.45			14.82			1		
11/08/24 18:39	379340.3			1.6			8.85			1.47			13.03			1		
11/08/24 18:40	380079.6			1.6			8.42			1.4			12.42			1		
11/08/24 18:41	378202.3			1.5			8.33			1.32			12.23			1		
11/08/24 18:42	375995.8			1.5			8.16			1.31			11.9			1		
11/08/24 18:43	376330.8			1.4			7.98			1.23			11.66			1		
11/08/24 18:44	377041.3			1.4			7.93			1.25			11.6			1		
11/08/24 18:45	376717.8			1.4			7.84			1.25			11.46			1		
11/08/24 18:46	375239.2			1.3			7.84			1.17			11.42			1		
11/08/24 18:47	374742.4			1.2			7.75			1.09			11.27			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/08/24 18:48	374904.1			1.2			7.66			1.09			11.15			1		
11/08/24 18:49	374286.1			1.3			7.6			1.1			11.04			1		
11/08/24 18:50	372726.5			1.3			5.27			1.1			7.63			1		
11/08/24 18:51	373390.8			1.3			2.59			1.1			3.76			1		
11/08/24 18:52	371981.4			1.3			2.5			1.1			3.61			1		
11/08/24 18:53	371854.3			1.3			2.41			1.1			3.48			1		
11/08/24 18:54	371681			1.3			2.41			1.1			3.48			1		
11/08/24 18:55	371530.8			1.3			2.41			1.18			3.48			1		
11/08/24 18:56	371831.2			1.3			2.41			1.1			3.48			1		
11/08/24 18:57	372264.4			1.2			2.41			1.02			3.49			1		
11/08/24 18:58	371958.3			1.2			2.32			1.02			3.36			1		
11/08/24 18:59	369850			1.2			2.32			1.01			3.34			1		
11/08/24 19:00	370872.3			1.2			2.23			1.02			3.22			1		
11/08/24 19:01	371461.5			1.3			2.23			1.1			3.22			1		
11/08/24 19:02	370641.3			1.3			2.23			1.17			3.22			1		
11/08/24 19:03	369087.5			1.3			2.23			1.17			3.2			1		
11/08/24 19:04	370791.5			1.3			2.15			1.09			3.09			1		
11/08/24 19:05	368359.7			1.2			2.15			1.01			3.07			1		
11/08/24 19:06	371455.7			1.1			2.06			0.94			2.96			1		
11/08/24 19:07	384845			1.2			2.09			1.07			3.12			1		
11/08/24 19:08	410329.5			1.1			2			1.05			3.18			1		
11/08/24 19:09	430679.1			1.1			1.75			1.12			2.93			1		
11/08/24 19:10	456204.1			1.1			1.69			1.21			2.99			1		
11/08/24 19:11	464856.9			1.2			1.69			1.34			3.04			1		
11/08/24 19:12	468963.8			1.2			1.81			1.37			3.29			1		
11/08/24 19:13	463516.8			1.1			1.87			1.23			3.37			1		
11/08/24 19:14	442283.5			1.1			1.97			1.17			3.38			1		
11/08/24 19:15	426196.8			1.1			2.03			1.11			3.36			1		
11/08/24 19:16	427363.6			1.2			2			1.19			3.31			1		
11/08/24 19:17	427109.5			1.3			1.75			1.3			2.9			1		
11/08/24 19:18	436455.3			1.2			1.48			1.23			2.5			0		
11/08/24 19:19	456562.3			1.2			1.48			1.29			2.61			0		
11/08/24 19:20	467496.5			1.2			1.48			1.32			2.68			0		
11/08/24 19:21	467785.4			1.3			1.5			1.45			2.72			0		
11/08/24 19:22	471066.3			1.3			1.5			1.46			2.74			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/09/24 6:43	399551.2			1			1.07			0.93			1.66			0		
11/09/24 6:44	383834.1			1			0.98			0.89			1.47			0		
11/09/24 6:45	377907.8			1			0.95			0.93			1.4			0		
11/09/24 6:46	375891.9			1.1			0.97			1.02			1.41			0		
11/09/24 6:47	376278.8			1.1			0.88			1.02			1.29			0		
11/09/24 6:48	374823.3			1.2			0.88			1.09			1.28			1		
11/09/24 6:49	364195			1.3			0.89			1.08			1.26			1		
11/09/24 6:50	343978.4			1.3			0.89			1.02			1.19			1		
11/09/24 6:51	319857			1.1			0.95			0.85			1.19			1		
11/09/24 6:52	295920.4			1.2			1.18			0.82			1.36			1		
11/09/24 6:53	271591.1			1.1			2.12			0.71			2.24			1		
11/09/24 6:54	247931.8			1			5.71			0.57			5.49			1		
11/09/24 6:55	223175			0.9			14.01			0.5			12.14			1		
11/09/24 6:56	197857.9			16.8			19.47			7.82			14.96			1		
11/09/24 6:57	176491.7			218.8			22.29			91.11			15.27			1		
11/09/24 6:58	155333.5			793			25.81			290.57			15.57			1		
11/09/24 6:59	94221.3			1362.9			30.01			302.94			10.98			1		
11/09/24 7:00	0			0			31.04			0			0			0		
11/09/24 7:01	0			0			17.7			0			0			0		
11/09/24 7:02	0			0			11.8			0			0			0		
11/09/24 7:03	0			0			0.1			0			0			0		
11/09/24 7:04	0			0			5.9			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 12:44	0			0			0			0			0			0		
11/15/24 12:45	0			0			0			0			0			0		
11/15/24 12:46	0			0			0			0			0			0		
11/15/24 12:47	0			0			0			0			0			0		
11/15/24 12:48	0			0			0			0			0			0		
11/15/24 12:49	17732.9			0.3			0			0			0			1		
11/15/24 12:50	23555.3			0.2			0			0			0			1		
11/15/24 12:51	38042			1271.5			17.7			114.13			2.61			1		
11/15/24 12:52	50755.4			434.5			8.68			52.04			1.71			1		
11/15/24 12:53	19777.7			118			9.24			5.49			0.71			1		
11/15/24 12:54	0			0			9.12			0			0			0		
11/15/24 12:55	0			0			7.94			0			0			0		
11/15/24 12:56	0			0			9.69			0			0			0		
11/15/24 12:57	0			0			13.77			0			0			0		
11/15/24 12:58	0			0			18.44			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 12:44	0			0			0			0			0			0		
11/15/24 12:45	0			0			0			0			0			0		
11/15/24 12:46	0			0			0			0			0			0		
11/15/24 12:47	0			0			0			0			0			0		
11/15/24 12:48	0			0			0			0			0			0		
11/15/24 12:49	17732.9			0.3			0			0			0			1		
11/15/24 12:50	23555.3			0.2			0			0			0			1		
11/15/24 12:51	38042			1271.5			17.7			114.13			2.61			1		
11/15/24 12:52	50755.4			434.5			8.68			52.04			1.71			1		
11/15/24 12:53	19777.7			118			9.24			5.49			0.71			1		
11/15/24 12:54	0			0			9.12			0			0			0		
11/15/24 12:55	0			0			7.94			0			0			0		
11/15/24 12:56	0			0			9.69			0			0			0		
11/15/24 12:57	0			0			13.77			0			0			0		
11/15/24 12:58	0			0			18.44			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 13:18	0			0			0.1			0			0			0		
11/15/24 13:19	0			0			0.1			0			0			0		
11/15/24 13:20	0			0			0			0			0			0		
11/15/24 13:21	0			0			0			0			0			0		
11/15/24 13:22	0			0			0			0			0			0		
11/15/24 13:23	1530.7			0.4			0			0			0			1		
11/15/24 13:24	19795			0.4			0			0			0			1		
11/15/24 13:25	34691.8			1174.1			17.7			96.19			2.39			1		
11/15/24 13:26	47676.7			527.8			11.8			59.31			2.18			1		
11/15/24 13:27	28470.9			165.9			12.89			11.14			1.42			1		
11/15/24 13:28	0			0			13.91			0			0			0		
11/15/24 13:29	0			0			12.63			0			0			0		
11/15/24 13:30	0			0			17.25			0			0			0		
11/15/24 13:31	0			0			19.97			0			0			0		
11/15/24 13:32	0			0			21.63			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 13:18	0			0			0.1			0			0			0		
11/15/24 13:19	0			0			0.1			0			0			0		
11/15/24 13:20	0			0			0			0			0			0		
11/15/24 13:21	0			0			0			0			0			0		
11/15/24 13:22	0			0			0			0			0			0		
11/15/24 13:23	1530.7			0.4			0			0			0			1		
11/15/24 13:24	19795			0.4			0			0			0			1		
11/15/24 13:25	34691.8			1174.1			17.7			96.19			2.39			1		
11/15/24 13:26	47676.7			527.8			11.8			59.31			2.18			1		
11/15/24 13:27	28470.9			165.9			12.89			11.14			1.42			1		
11/15/24 13:28	0			0			13.91			0			0			0		
11/15/24 13:29	0			0			12.63			0			0			0		
11/15/24 13:30	0			0			17.25			0			0			0		
11/15/24 13:31	0			0			19.97			0			0			0		
11/15/24 13:32	0			0			21.63			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 13:42	0			0			0.4			0			0			0		
11/15/24 13:43	0			0			0.3			0			0			0		
11/15/24 13:44	0			0			0.2			0			0			0		
11/15/24 13:45	0			0			0.1			0			0			0		
11/15/24 13:46	0			0			0.1			0			0			0		
11/15/24 13:47	8612.3			0.3			0.1			0			0			1		
11/15/24 13:48	22238.4			0.5			0.1			0			0			1		
11/15/24 13:49	36800.2			1476.5			28.03			128.24			4.01			1		
11/15/24 13:50	49946.8			1087.2			18.09			128.01			3.51			1		
11/15/24 13:51	61834.2			629.7			22.36			91.91			5.37			1		
11/15/24 13:52	74045.1			284			27.89			49.59			8.01			1		
11/15/24 13:53	87717.3			94.2			31.32			19.48			10.66			1		
11/15/24 13:54	104012			33.5			37.72			8.22			15.23			1		
11/15/24 13:55	147131.3			15.9			43.46			5.53			24.82			1		
11/15/24 13:56	211091.2			5.9			58.82			2.94			48.19			1		
11/15/24 13:57	260564.3			2.2			86.49			1.33			87.49			1		
11/15/24 13:58	241075.4			15.9			96.12			9.02			89.94			1		
11/15/24 13:59	234548.3			1.9			91.12			1.03			82.98			1		
11/15/24 14:00	254106.5			2.9			92.78			1.73			91.53			1		
11/15/24 14:01	279435.1			2.4			101.97			1.61			110.63			1		
11/15/24 14:02	306571.7			1.6			95.38			1.19			113.53			1		
11/15/24 14:03	334257			1.1			85.11			0.86			110.43			1		
11/15/24 14:04	368434.8			1			69.27			0.85			99.06			1		
11/15/24 14:05	0			5.9			41.75			0			0			1		
11/15/24 14:06	0			0			63.72			0			0			0		
11/15/24 14:07	0			0			153.4			0			0			0		
11/15/24 14:08	0			0			129.8			0			0			0		
11/15/24 14:09	0			0			106.2			0			0			0		
11/15/24 14:10	0			0			1.7			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 13:42	0			0			0.4			0			0			0		
11/15/24 13:43	0			0			0.3			0			0			0		
11/15/24 13:44	0			0			0.2			0			0			0		
11/15/24 13:45	0			0			0.1			0			0			0		
11/15/24 13:46	0			0			0.1			0			0			0		
11/15/24 13:47	8612.3			0.3			0.1			0			0			1		
11/15/24 13:48	22238.4			0.5			0.1			0			0			1		
11/15/24 13:49	36800.2			1476.5			28.03			128.24			4.01			1		
11/15/24 13:50	49946.8			1087.2			18.09			128.01			3.51			1		
11/15/24 13:51	61834.2			629.7			22.36			91.91			5.37			1		
11/15/24 13:52	74045.1			284			27.89			49.59			8.01			1		
11/15/24 13:53	87717.3			94.2			31.32			19.48			10.66			1		
11/15/24 13:54	104012			33.5			37.72			8.22			15.23			1		
11/15/24 13:55	147131.3			15.9			43.46			5.53			24.82			1		
11/15/24 13:56	211091.2			5.9			58.82			2.94			48.19			1		
11/15/24 13:57	260564.3			2.2			86.49			1.33			87.49			1		
11/15/24 13:58	241075.4			15.9			96.12			9.02			89.94			1		
11/15/24 13:59	234548.3			1.9			91.12			1.03			82.98			1		
11/15/24 14:00	254106.5			2.9			92.78			1.73			91.53			1		
11/15/24 14:01	279435.1			2.4			101.97			1.61			110.63			1		
11/15/24 14:02	306571.7			1.6			95.38			1.19			113.53			1		
11/15/24 14:03	334257			1.1			85.11			0.86			110.43			1		
11/15/24 14:04	368434.8			1			69.27			0.85			99.06			1		
11/15/24 14:05	0			5.9			41.75			0			0			1		
11/15/24 14:06	0			0			63.72			0			0			0		
11/15/24 14:07	0			0			153.4			0			0			0		
11/15/24 14:08	0			0			129.8			0			0			0		
11/15/24 14:09	0			0			106.2			0			0			0		
11/15/24 14:10	0			0			1.7			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 13:42	0			0			0.4			0			0			0		
11/15/24 13:43	0			0			0.3			0			0			0		
11/15/24 13:44	0			0			0.2			0			0			0		
11/15/24 13:45	0			0			0.1			0			0			0		
11/15/24 13:46	0			0			0.1			0			0			0		
11/15/24 13:47	8612.3			0.3			0.1			0			0			1		
11/15/24 13:48	22238.4			0.5			0.1			0			0			1		
11/15/24 13:49	36800.2			1476.5			28.03			128.24			4.01			1		
11/15/24 13:50	49946.8			1087.2			18.09			128.01			3.51			1		
11/15/24 13:51	61834.2			629.7			22.36			91.91			5.37			1		
11/15/24 13:52	74045.1			284			27.89			49.59			8.01			1		
11/15/24 13:53	87717.3			94.2			31.32			19.48			10.66			1		
11/15/24 13:54	104012			33.5			37.72			8.22			15.23			1		
11/15/24 13:55	147131.3			15.9			43.46			5.53			24.82			1		
11/15/24 13:56	211091.2			5.9			58.82			2.94			48.19			1		
11/15/24 13:57	260564.3			2.2			86.49			1.33			87.49			1		
11/15/24 13:58	241075.4			15.9			96.12			9.02			89.94			1		
11/15/24 13:59	234548.3			1.9			91.12			1.03			82.98			1		
11/15/24 14:00	254106.5			2.9			92.78			1.73			91.53			1		
11/15/24 14:01	279435.1			2.4			101.97			1.61			110.63			1		
11/15/24 14:02	306571.7			1.6			95.38			1.19			113.53			1		
11/15/24 14:03	334257			1.1			85.11			0.86			110.43			1		
11/15/24 14:04	368434.8			1			69.27			0.85			99.06			1		
11/15/24 14:05	0			5.9			41.75			0			0			1		
11/15/24 14:06	0			0			63.72			0			0			0		
11/15/24 14:07	0			0			153.4			0			0			0		
11/15/24 14:08	0			0			129.8			0			0			0		
11/15/24 14:09	0			0			106.2			0			0			0		
11/15/24 14:10	0			0			1.7			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 14:51	0			0			0.5			0			0			0		
11/15/24 14:52	0			0			0.2			0			0			0		
11/15/24 14:53	0			0			0.2			0			0			0		
11/15/24 14:54	0			0			0.2			0			0			0		
11/15/24 14:55	0			0			0.2			0			0			0		
11/15/24 14:56	1126.4			0.2			0.2			0			0			1		
11/15/24 14:57	13556.7			0.2			0.1			0			0			1		
11/15/24 14:58	31318.5			1398.3			64.9			103.29			7.89			1		
11/15/24 14:59	44915.7			1005.3			17.7			106.44			3.08			1		
11/15/24 15:00	56982.2			654.2			20.98			87.87			4.64			1		
11/15/24 15:01	69210.4			265.8			26.69			43.37			7.17			1		
11/15/24 15:02	82195.3			77.9			30.24			15.11			9.65			1		
11/15/24 15:03	96595.4			28			33.65			6.37			12.62			1		
11/15/24 15:04	130778.9			16.1			37.23			4.96			18.9			1		
11/15/24 15:05	199082.4			7			49.29			3.31			38.1			1		
11/15/24 15:06	206296.9			2.1			72.77			1.03			58.28			1		
11/15/24 15:07	230031.3			37.3			71.6			20.23			63.94			1		
11/15/24 15:08	260541.2			14.9			77.2			9.18			78.07			1		
11/15/24 15:09	285211.3			1.1			85.38			0.75			94.52			1		
11/15/24 15:10	314115.4			0.8			78.42			0.56			95.62			1		
11/15/24 15:11	341078.7			0.8			71.23			0.6			94.31			1		
11/15/24 15:12	249595.3			0.7			59.66			0.39			57.8			1		
11/15/24 15:13	0			0			32.61			0			0			0		
11/15/24 15:14	0			0			76.7			0			0			0		
11/15/24 15:15	0			0			1.1			0			0			0		
11/15/24 15:16	0			0			1			0			0			0		
11/15/24 15:17	0			0			0.8			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 14:51	0			0			0.5			0			0			0		
11/15/24 14:52	0			0			0.2			0			0			0		
11/15/24 14:53	0			0			0.2			0			0			0		
11/15/24 14:54	0			0			0.2			0			0			0		
11/15/24 14:55	0			0			0.2			0			0			0		
11/15/24 14:56	1126.4			0.2			0.2			0			0			1		
11/15/24 14:57	13556.7			0.2			0.1			0			0			1		
11/15/24 14:58	31318.5			1398.3			64.9			103.29			7.89			1		
11/15/24 14:59	44915.7			1005.3			17.7			106.44			3.08			1		
11/15/24 15:00	56982.2			654.2			20.98			87.87			4.64			1		
11/15/24 15:01	69210.4			265.8			26.69			43.37			7.17			1		
11/15/24 15:02	82195.3			77.9			30.24			15.11			9.65			1		
11/15/24 15:03	96595.4			28			33.65			6.37			12.62			1		
11/15/24 15:04	130778.9			16.1			37.23			4.96			18.9			1		
11/15/24 15:05	199082.4			7			49.29			3.31			38.1			1		
11/15/24 15:06	206296.9			2.1			72.77			1.03			58.28			1		
11/15/24 15:07	230031.3			37.3			71.6			20.23			63.94			1		
11/15/24 15:08	260541.2			14.9			77.2			9.18			78.07			1		
11/15/24 15:09	285211.3			1.1			85.38			0.75			94.52			1		
11/15/24 15:10	314115.4			0.8			78.42			0.56			95.62			1		
11/15/24 15:11	341078.7			0.8			71.23			0.6			94.31			1		
11/15/24 15:12	249595.3			0.7			59.66			0.39			57.8			1		
11/15/24 15:13	0			0			32.61			0			0			0		
11/15/24 15:14	0			0			76.7			0			0			0		
11/15/24 15:15	0			0			1.1			0			0			0		
11/15/24 15:16	0			0			1			0			0			0		
11/15/24 15:17	0			0			0.8			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 15:29	0			0			0.2			0			0			0		
11/15/24 15:30	0			0			0.2			0			0			0		
11/15/24 15:31	0			0			0.2			0			0			0		
11/15/24 15:32	0			0			0.2			0			0			0		
11/15/24 15:33	2899.7			0			0.1			0			0			0		
11/15/24 15:34	5868.6			0.2			0.1			0			0			1		
11/15/24 15:35	23122.1			0.5			0.2			0			0			1		
11/15/24 15:36	38556.1			355.3			24.91			32.29			3.73			1		
11/15/24 15:37	51818.3			355.1			20.65			43.4			4.15			1		
11/15/24 15:38	63561.3			126			26.26			18.89			6.48			1		
11/15/24 15:39	76049.4			50.5			30.27			9.06			8.93			1		
11/15/24 15:40	89259.6			25.5			35.64			5.37			12.35			1		
11/15/24 15:41	109684.2			11.2			38.98			2.89			16.6			1		
11/15/24 15:42	170796.4			6.1			46.61			2.46			30.91			1		
11/15/24 15:43	206707			4.2			67.26			2.05			53.97			1		
11/15/24 15:44	247902.9			12.1			83.42			7.06			80.27			1		
11/15/24 15:45	293309.5			21.7			93.4			15.03			106.35			1		
11/15/24 15:46	323218.7			1			91.45			0.75			114.75			1		
11/15/24 15:47	353070.1			0.8			80.78			0.63			110.73			1		
11/15/24 15:48	225254.4			0.8			63.01			0.41			55.1			1		
11/15/24 15:49	0			0			31.76			0			0			0		
11/15/24 15:50	0			0			76.7			0			0			0		
11/15/24 15:51	0			0			1			0			0			0		
11/15/24 15:52	0			0			0.9			0			0			0		
11/15/24 15:53	0			0			0.8			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 15:29	0			0			0.2			0			0			0		
11/15/24 15:30	0			0			0.2			0			0			0		
11/15/24 15:31	0			0			0.2			0			0			0		
11/15/24 15:32	0			0			0.2			0			0			0		
11/15/24 15:33	2899.7			0			0.1			0			0			0		
11/15/24 15:34	5868.6			0.2			0.1			0			0			1		
11/15/24 15:35	23122.1			0.5			0.2			0			0			1		
11/15/24 15:36	38556.1			355.3			24.91			32.29			3.73			1		
11/15/24 15:37	51818.3			355.1			20.65			43.4			4.15			1		
11/15/24 15:38	63561.3			126			26.26			18.89			6.48			1		
11/15/24 15:39	76049.4			50.5			30.27			9.06			8.93			1		
11/15/24 15:40	89259.6			25.5			35.64			5.37			12.35			1		
11/15/24 15:41	109684.2			11.2			38.98			2.89			16.6			1		
11/15/24 15:42	170796.4			6.1			46.61			2.46			30.91			1		
11/15/24 15:43	206707			4.2			67.26			2.05			53.97			1		
11/15/24 15:44	247902.9			12.1			83.42			7.06			80.27			1		
11/15/24 15:45	293309.5			21.7			93.4			15.03			106.35			1		
11/15/24 15:46	323218.7			1			91.45			0.75			114.75			1		
11/15/24 15:47	353070.1			0.8			80.78			0.63			110.73			1		
11/15/24 15:48	225254.4			0.8			63.01			0.41			55.1			1		
11/15/24 15:49	0			0			31.76			0			0			0		
11/15/24 15:50	0			0			76.7			0			0			0		
11/15/24 15:51	0			0			1			0			0			0		
11/15/24 15:52	0			0			0.9			0			0			0		
11/15/24 15:53	0			0			0.8			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 20:49	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:50	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:51	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:52	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:53	9444.1			0	X		0	X		0	X		0	X		0		
11/15/24 20:54	10784.2			0.2	X		0	X		0	X		0	X		1		
11/15/24 20:55	28187.8			7.4	X		0.4	X		0	X		0	X		1		
11/15/24 20:56	42368.4			1306.3	X		27.14	X		130.41	X		4.46	X		1		
11/15/24 20:57	54094.1			928.7	X		23.95	X		118.5	X		5.03	X		1		
11/15/24 20:58	65877.5			488.2	X		30.68	X		75.85	X		7.84	X		1		
11/15/24 20:59	78914.4			190.8	X		26.06	X		35.53	X		7.99	X		1		
11/15/24 21:00	92448.1			66.9	X		24.05	X		14.6	X		8.63	X		1		
11/15/24 21:01	114755.7			29.5	X		22.34	X		7.98	X		9.95	X		1		
11/15/24 21:02	178421			16.5	X		20.85	X		6.95	X		14.44	X		1		
11/15/24 21:03	210028.4			5.6	X		17.87	X		2.76	X		14.57	X		1		
11/15/24 21:04	217323.7			26.2	X		14.54	X		13.43	X		12.27	X		1		
11/15/24 21:05	223723.7			56.4	X		13.9	X		29.75	X		12.07	X		1		
11/15/24 21:06	220107.8			15.9	X		13.31	X		8.28	X		11.37	X		1		
11/15/24 21:07	219432			21.2	X		13.31	X		10.98	X		11.33	X		1		
11/15/24 21:08	219073.9			19.8	X		13.31	X		10.25	X		11.31	X		1		
11/15/24 21:09	217733.8			19.1	X		13.31	X		9.8	X		11.25	X		1		
11/15/24 21:10	218091.9			18.5	X		13.31	X		9.49	X		11.26	X		1		
11/15/24 21:11	216769.2			18.3	X		13.31	X		9.37	X		11.2	X		1		
11/15/24 21:12	217294.8			18.3	X		13.31	X		9.39	X		11.23	X		1		
11/15/24 21:13	216185.8			18.9	X		13.6	X		9.61	X		11.41	X		1		
11/15/24 21:14	220766.3			19.1	X		13.6	X		9.95	X		11.65	X		1		
11/15/24 21:15	227137.4			13.7	X		13.31	X		7.33	X		11.74	X		1		
11/15/24 21:16	233629.9			7.4	X		13.03	X		4.06	X		11.82	X		1		
11/15/24 21:17	242871.8			4.8	X		12.51	X		2.77	X		11.79	X		1		
11/15/24 21:18	246089.1			3.2	X		12.26	X		1.88	X		11.71	X		1		
11/15/24 21:19	253852.4			1.9	X		12.03	X		1.15	X		11.85	X		1		
11/15/24 21:20	260604.7			1.4	X		12.03	X		0.84	X		12.17	X		1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 21:21	265953.5			1.4	X		12.03	X		0.85	X		12.41	X		1		
11/15/24 21:22	273624.3			1.2	X		12.03	X		0.81	X		12.77	X		1		
11/15/24 21:23	280815.6			1	X		11.8	X		0.66	X		12.86	X		1		
11/15/24 21:24	284391.1			0.9	X		11.8	X		0.6	X		13.03	X		1		
11/15/24 21:25	290381			0.8	X		11.8	X		0.53	X		13.3	X		1		
11/15/24 21:26	293615.7			0.7	X		11.8	X		0.46	X		13.45	X		1		
11/15/24 21:27	300957.2			0.6	X		11.8	X		0.4	X		13.78	X		1		
11/15/24 21:28	302632.4			0.5	X		11.58	X		0.39	X		13.61	X		1		
11/15/24 21:29	310511			0.5	X		11.58	X		0.4	X		13.96	X		1		
11/15/24 21:30	315374.6			0.6	X		11.8	X		0.41	X		14.45	X		1		
11/15/24 21:31	322150.1			0.6	X		11.8	X		0.42	X		14.76	X		1		
11/15/24 21:32	321953.8			0.6	X		11.8	X		0.42	X		14.75	X		1		
11/15/24 21:33	327244.7			0.6	X		11.8	X		0.43	X		14.99	X		1		
11/15/24 21:34	329584.1			0.4	X		11.8	X		0.35	X		15.1	X		1		
11/15/24 21:35	336382.7			0.6	X		12.03	X		0.45	X		15.71	X		1		
11/15/24 21:36	350372.6			0.6	X		12.03	X		0.47	X		16.36	X		1		
11/15/24 21:37	335140.8			0.6	X		12.03	X		0.45	X		15.65	X		1		
11/15/24 21:38	0			5.5	X		29.38	X		0	X		0	X		1		
11/15/24 21:39	0			0	X		45.23	X		0	X		0	X		0		
11/15/24 21:40	0			0	X		1	X		0	X		0	X		0		
11/15/24 21:41	0			0	X		0.9	X		0	X		0	X		0		
11/15/24 21:42	0			0	X		0.8	X		0	X		0	X		0		
11/15/24 21:43	0			0	X		0.6	X		0	X		0	X		0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 20:49	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:50	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:51	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:52	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:53	9444.1			0	X		0	X		0	X		0	X		0		
11/15/24 20:54	10784.2			0.2	X		0	X		0	X		0	X		1		
11/15/24 20:55	28187.8			7.4	X		0.4	X		0	X		0	X		1		
11/15/24 20:56	42368.4			1306.3	X		27.14	X		130.41	X		4.46	X		1		
11/15/24 20:57	54094.1			928.7	X		23.95	X		118.5	X		5.03	X		1		
11/15/24 20:58	65877.5			488.2	X		30.68	X		75.85	X		7.84	X		1		
11/15/24 20:59	78914.4			190.8	X		26.06	X		35.53	X		7.99	X		1		
11/15/24 21:00	92448.1			66.9	X		24.05	X		14.6	X		8.63	X		1		
11/15/24 21:01	114755.7			29.5	X		22.34	X		7.98	X		9.95	X		1		
11/15/24 21:02	178421			16.5	X		20.85	X		6.95	X		14.44	X		1		
11/15/24 21:03	210028.4			5.6	X		17.87	X		2.76	X		14.57	X		1		
11/15/24 21:04	217323.7			26.2	X		14.54	X		13.43	X		12.27	X		1		
11/15/24 21:05	223723.7			56.4	X		13.9	X		29.75	X		12.07	X		1		
11/15/24 21:06	220107.8			15.9	X		13.31	X		8.28	X		11.37	X		1		
11/15/24 21:07	219432			21.2	X		13.31	X		10.98	X		11.33	X		1		
11/15/24 21:08	219073.9			19.8	X		13.31	X		10.25	X		11.31	X		1		
11/15/24 21:09	217733.8			19.1	X		13.31	X		9.8	X		11.25	X		1		
11/15/24 21:10	218091.9			18.5	X		13.31	X		9.49	X		11.26	X		1		
11/15/24 21:11	216769.2			18.3	X		13.31	X		9.37	X		11.2	X		1		
11/15/24 21:12	217294.8			18.3	X		13.31	X		9.39	X		11.23	X		1		
11/15/24 21:13	216185.8			18.9	X		13.6	X		9.61	X		11.41	X		1		
11/15/24 21:14	220766.3			19.1	X		13.6	X		9.95	X		11.65	X		1		
11/15/24 21:15	227137.4			13.7	X		13.31	X		7.33	X		11.74	X		1		
11/15/24 21:16	233629.9			7.4	X		13.03	X		4.06	X		11.82	X		1		
11/15/24 21:17	242871.8			4.8	X		12.51	X		2.77	X		11.79	X		1		
11/15/24 21:18	246089.1			3.2	X		12.26	X		1.88	X		11.71	X		1		
11/15/24 21:19	253852.4			1.9	X		12.03	X		1.15	X		11.85	X		1		
11/15/24 21:20	260604.7			1.4	X		12.03	X		0.84	X		12.17	X		1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 21:21	265953.5			1.4	X		12.03	X		0.85	X		12.41	X		1		
11/15/24 21:22	273624.3			1.2	X		12.03	X		0.81	X		12.77	X		1		
11/15/24 21:23	280815.6			1	X		11.8	X		0.66	X		12.86	X		1		
11/15/24 21:24	284391.1			0.9	X		11.8	X		0.6	X		13.03	X		1		
11/15/24 21:25	290381			0.8	X		11.8	X		0.53	X		13.3	X		1		
11/15/24 21:26	293615.7			0.7	X		11.8	X		0.46	X		13.45	X		1		
11/15/24 21:27	300957.2			0.6	X		11.8	X		0.4	X		13.78	X		1		
11/15/24 21:28	302632.4			0.5	X		11.58	X		0.39	X		13.61	X		1		
11/15/24 21:29	310511			0.5	X		11.58	X		0.4	X		13.96	X		1		
11/15/24 21:30	315374.6			0.6	X		11.8	X		0.41	X		14.45	X		1		
11/15/24 21:31	322150.1			0.6	X		11.8	X		0.42	X		14.76	X		1		
11/15/24 21:32	321953.8			0.6	X		11.8	X		0.42	X		14.75	X		1		
11/15/24 21:33	327244.7			0.6	X		11.8	X		0.43	X		14.99	X		1		
11/15/24 21:34	329584.1			0.4	X		11.8	X		0.35	X		15.1	X		1		
11/15/24 21:35	336382.7			0.6	X		12.03	X		0.45	X		15.71	X		1		
11/15/24 21:36	350372.6			0.6	X		12.03	X		0.47	X		16.36	X		1		
11/15/24 21:37	335140.8			0.6	X		12.03	X		0.45	X		15.65	X		1		
11/15/24 21:38	0			5.5	X		29.38	X		0	X		0	X		1		
11/15/24 21:39	0			0	X		45.23	X		0	X		0	X		0		
11/15/24 21:40	0			0	X		1	X		0	X		0	X		0		
11/15/24 21:41	0			0	X		0.9	X		0	X		0	X		0		
11/15/24 21:42	0			0	X		0.8	X		0	X		0	X		0		
11/15/24 21:43	0			0	X		0.6	X		0	X		0	X		0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 20:49	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:50	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:51	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:52	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:53	9444.1			0	X		0	X		0	X		0	X		0		
11/15/24 20:54	10784.2			0.2	X		0	X		0	X		0	X		1		
11/15/24 20:55	28187.8			7.4	X		0.4	X		0	X		0	X		1		
11/15/24 20:56	42368.4			1306.3	X		27.14	X		130.41	X		4.46	X		1		
11/15/24 20:57	54094.1			928.7	X		23.95	X		118.5	X		5.03	X		1		
11/15/24 20:58	65877.5			488.2	X		30.68	X		75.85	X		7.84	X		1		
11/15/24 20:59	78914.4			190.8	X		26.06	X		35.53	X		7.99	X		1		
11/15/24 21:00	92448.1			66.9	X		24.05	X		14.6	X		8.63	X		1		
11/15/24 21:01	114755.7			29.5	X		22.34	X		7.98	X		9.95	X		1		
11/15/24 21:02	178421			16.5	X		20.85	X		6.95	X		14.44	X		1		
11/15/24 21:03	210028.4			5.6	X		17.87	X		2.76	X		14.57	X		1		
11/15/24 21:04	217323.7			26.2	X		14.54	X		13.43	X		12.27	X		1		
11/15/24 21:05	223723.7			56.4	X		13.9	X		29.75	X		12.07	X		1		
11/15/24 21:06	220107.8			15.9	X		13.31	X		8.28	X		11.37	X		1		
11/15/24 21:07	219432			21.2	X		13.31	X		10.98	X		11.33	X		1		
11/15/24 21:08	219073.9			19.8	X		13.31	X		10.25	X		11.31	X		1		
11/15/24 21:09	217733.8			19.1	X		13.31	X		9.8	X		11.25	X		1		
11/15/24 21:10	218091.9			18.5	X		13.31	X		9.49	X		11.26	X		1		
11/15/24 21:11	216769.2			18.3	X		13.31	X		9.37	X		11.2	X		1		
11/15/24 21:12	217294.8			18.3	X		13.31	X		9.39	X		11.23	X		1		
11/15/24 21:13	216185.8			18.9	X		13.6	X		9.61	X		11.41	X		1		
11/15/24 21:14	220766.3			19.1	X		13.6	X		9.95	X		11.65	X		1		
11/15/24 21:15	227137.4			13.7	X		13.31	X		7.33	X		11.74	X		1		
11/15/24 21:16	233629.9			7.4	X		13.03	X		4.06	X		11.82	X		1		
11/15/24 21:17	242871.8			4.8	X		12.51	X		2.77	X		11.79	X		1		
11/15/24 21:18	246089.1			3.2	X		12.26	X		1.88	X		11.71	X		1		
11/15/24 21:19	253852.4			1.9	X		12.03	X		1.15	X		11.85	X		1		
11/15/24 21:20	260604.7			1.4	X		12.03	X		0.84	X		12.17	X		1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 21:21	265953.5			1.4	X		12.03	X		0.85	X		12.41	X		1		
11/15/24 21:22	273624.3			1.2	X		12.03	X		0.81	X		12.77	X		1		
11/15/24 21:23	280815.6			1	X		11.8	X		0.66	X		12.86	X		1		
11/15/24 21:24	284391.1			0.9	X		11.8	X		0.6	X		13.03	X		1		
11/15/24 21:25	290381			0.8	X		11.8	X		0.53	X		13.3	X		1		
11/15/24 21:26	293615.7			0.7	X		11.8	X		0.46	X		13.45	X		1		
11/15/24 21:27	300957.2			0.6	X		11.8	X		0.4	X		13.78	X		1		
11/15/24 21:28	302632.4			0.5	X		11.58	X		0.39	X		13.61	X		1		
11/15/24 21:29	310511			0.5	X		11.58	X		0.4	X		13.96	X		1		
11/15/24 21:30	315374.6			0.6	X		11.8	X		0.41	X		14.45	X		1		
11/15/24 21:31	322150.1			0.6	X		11.8	X		0.42	X		14.76	X		1		
11/15/24 21:32	321953.8			0.6	X		11.8	X		0.42	X		14.75	X		1		
11/15/24 21:33	327244.7			0.6	X		11.8	X		0.43	X		14.99	X		1		
11/15/24 21:34	329584.1			0.4	X		11.8	X		0.35	X		15.1	X		1		
11/15/24 21:35	336382.7			0.6	X		12.03	X		0.45	X		15.71	X		1		
11/15/24 21:36	350372.6			0.6	X		12.03	X		0.47	X		16.36	X		1		
11/15/24 21:37	335140.8			0.6	X		12.03	X		0.45	X		15.65	X		1		
11/15/24 21:38	0			5.5	X		29.38	X		0	X		0	X		1		
11/15/24 21:39	0			0	X		45.23	X		0	X		0	X		0		
11/15/24 21:40	0			0	X		1	X		0	X		0	X		0		
11/15/24 21:41	0			0	X		0.9	X		0	X		0	X		0		
11/15/24 21:42	0			0	X		0.8	X		0	X		0	X		0		
11/15/24 21:43	0			0	X		0.6	X		0	X		0	X		0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/16/24 8:28	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:29	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:30	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:31	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:32	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:33	1259.2			0.2	X		0	X		0	X		0	X		1		
11/16/24 8:34	13360.3			0.2	X		0	X		0	X		0	X		1		
11/16/24 8:35	31330.1			36	X		0.7	X		0	X		0	X		1		
11/16/24 8:36	45216.1			1358	X		19.18	X		145	X		3.37	X		1		
11/16/24 8:37	58703.5			879.4	X		21.86	X		121.86	X		4.99	X		1		
11/16/24 8:38	70065.3			450.9	X		26.69	X		74.49	X		7.26	X		1		
11/16/24 8:39	81271.1			213.2	X		27.19	X		40.85	X		8.57	X		1		
11/16/24 8:40	96520.3			89	X		24.05	X		20.25	X		9.01	X		1		
11/16/24 8:41	122166.6			42.2	X		23.16	X		12.15	X		10.98	X		1		
11/16/24 8:42	190233.3			19.7	X		20.85	X		8.83	X		15.4	X		1		
11/16/24 8:43	215752.5			6.6	X		17.37	X		3.34	X		14.55	X		1		
11/16/24 8:44	222585.8			25.7	X		14.21	X		13.52	X		12.28	X		1		
11/16/24 8:45	226236.3			36.3	X		13.9	X		19.38	X		12.21	X		1		
11/16/24 8:46	222949.7			18.1	X		13.31	X		9.5	X		11.51	X		1		
11/16/24 8:47	221112.8			21.2	X		13.31	X		11.06	X		11.42	X		1		
11/16/24 8:48	220419.7			22.1	X		13.31	X		11.49	X		11.39	X		1		
11/16/24 8:49	219033.4			25.1	X		13.6	X		12.99	X		11.56	X		1		
11/16/24 8:50	221534.5			24.9	X		13.6	X		13	X		11.69	X		1		
11/16/24 8:51	219547.5			21.4	X		13.6	X		11.09	X		11.59	X		1		
11/16/24 8:52	218623.3			17.2	X		13.31	X		8.87	X		11.29	X		1		
11/16/24 8:53	217889.8			21	X		13.6	X		10.81	X		11.5	X		1		
11/16/24 8:54	232896.3			22.6	X		13.6	X		12.4	X		12.29	X		1		
11/16/24 8:55	243628.5			9.3	X		13.31	X		5.34	X		12.58	X		1		
11/16/24 8:56	246707.2			1.9	X		12.26	X		1.08	X		11.75	X		1		
11/16/24 8:57	247539			1.7	X		12.03	X		0.99	X		11.56	X		1		
11/16/24 8:58	245944.8			1.4	X		12.03	X		0.79	X		11.48	X		1		
11/16/24 8:59	247510.1			1.3	X		12.26	X		0.74	X		11.78	X		1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/16/24 9:00	247631.4			1.4	X		12.26	X		0.81	X		11.79	X		1		
11/16/24 9:01	246285.5			1.5	X		12.26	X		0.87	X		11.72	X		1		
11/16/24 9:02	258721.7			1.5	X		12.26	X		0.92	X		12.31	X		1		
11/16/24 9:03	282277			1.5	X		12.26	X		1	X		13.44	X		1		
11/16/24 9:04	290704.5			1.4	X		12.03	X		0.93	X		13.57	X		1		
11/16/24 9:05	295406.3			1	X		11.8	X		0.7	X		13.53	X		1		
11/16/24 9:06	312324.8			0.8	X		11.8	X		0.57	X		14.31	X		1		
11/16/24 9:07	327354.5			0.7	X		11.8	X		0.52	X		14.99	X		1		
11/16/24 9:08	333176.9			0.7	X		12.03	X		0.54	X		15.56	X		1		
11/16/24 9:09	333881.5			0.7	X		12.03	X		0.54	X		15.59	X		1		
11/16/24 9:10	335868.6			0.6	X		12.03	X		0.45	X		15.68	X		1		
11/16/24 9:11	335152.3			0.6	X		11.8	X		0.44	X		15.35	X		1		
11/16/24 9:12	335522			0.6	X		11.8	X		0.44	X		15.37	X		1		
11/16/24 9:13	333558.1			0.6	X		11.8	X		0.44	X		15.28	X		1		
11/16/24 9:14	334955.9			0.4	X		11.8	X		0.35	X		15.35	X		1		
11/16/24 9:15	335706.8			0.4	X		11.8	X		0.35	X		15.38	X		1		
11/16/24 9:16	339680.9			0.5	X		12.03	X		0.36	X		15.86	X		1		
11/16/24 9:17	342771.1			0.4	X		11.8	X		0.36	X		15.7	X		1		
11/16/24 9:18	342245.5			0.5	X		12.03	X		0.37	X		15.98	X		1		
11/16/24 9:19	344729.3			0.6	X		12.03	X		0.46	X		16.1	X		1		
11/16/24 9:20	344781.3			0.6	X		12.03	X		0.46	X		16.1	X		1		
11/16/24 9:21	345526.4			0.6	X		11.8	X		0.45	X		15.83	X		1		
11/16/24 9:22	356039			0.5	X		12.03	X		0.38	X		16.62	X		1		
11/16/24 9:23	379675.3			0.5	X		12.26	X		0.41	X		18.07	X		1		
11/16/24 9:24	386346.8			0.5	X		12.51	X		0.43	X		18.76	X		1		
11/16/24 9:25	317823.8			0.5	X		12.51	X		0.35	X		15.43	X		1		
11/16/24 9:26	0			0	X		30.84	X		0	X		0	X		0		
11/16/24 9:27	0			0	X		76.7	X		0	X		0	X		0		
11/16/24 9:28	0			0	X		0.5	X		0	X		0	X		0		
11/16/24 9:29	0			0	X		0.5	X		0	X		0	X		0		
11/16/24 9:30	0			0	X		0.4	X		0	X		0	X		0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/16/24 8:28	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:29	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:30	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:31	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:32	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:33	1259.2			0.2	X		0	X		0	X		0	X		1		
11/16/24 8:34	13360.3			0.2	X		0	X		0	X		0	X		1		
11/16/24 8:35	31330.1			36	X		0.7	X		0	X		0	X		1		
11/16/24 8:36	45216.1			1358	X		19.18	X		145	X		3.37	X		1		
11/16/24 8:37	58703.5			879.4	X		21.86	X		121.86	X		4.99	X		1		
11/16/24 8:38	70065.3			450.9	X		26.69	X		74.49	X		7.26	X		1		
11/16/24 8:39	81271.1			213.2	X		27.19	X		40.85	X		8.57	X		1		
11/16/24 8:40	96520.3			89	X		24.05	X		20.25	X		9.01	X		1		
11/16/24 8:41	122166.6			42.2	X		23.16	X		12.15	X		10.98	X		1		
11/16/24 8:42	190233.3			19.7	X		20.85	X		8.83	X		15.4	X		1		
11/16/24 8:43	215752.5			6.6	X		17.37	X		3.34	X		14.55	X		1		
11/16/24 8:44	222585.8			25.7	X		14.21	X		13.52	X		12.28	X		1		
11/16/24 8:45	226236.3			36.3	X		13.9	X		19.38	X		12.21	X		1		
11/16/24 8:46	222949.7			18.1	X		13.31	X		9.5	X		11.51	X		1		
11/16/24 8:47	221112.8			21.2	X		13.31	X		11.06	X		11.42	X		1		
11/16/24 8:48	220419.7			22.1	X		13.31	X		11.49	X		11.39	X		1		
11/16/24 8:49	219033.4			25.1	X		13.6	X		12.99	X		11.56	X		1		
11/16/24 8:50	221534.5			24.9	X		13.6	X		13	X		11.69	X		1		
11/16/24 8:51	219547.5			21.4	X		13.6	X		11.09	X		11.59	X		1		
11/16/24 8:52	218623.3			17.2	X		13.31	X		8.87	X		11.29	X		1		
11/16/24 8:53	217889.8			21	X		13.6	X		10.81	X		11.5	X		1		
11/16/24 8:54	232896.3			22.6	X		13.6	X		12.4	X		12.29	X		1		
11/16/24 8:55	243628.5			9.3	X		13.31	X		5.34	X		12.58	X		1		
11/16/24 8:56	246707.2			1.9	X		12.26	X		1.08	X		11.75	X		1		
11/16/24 8:57	247539			1.7	X		12.03	X		0.99	X		11.56	X		1		
11/16/24 8:58	245944.8			1.4	X		12.03	X		0.79	X		11.48	X		1		
11/16/24 8:59	247510.1			1.3	X		12.26	X		0.74	X		11.78	X		1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/16/24 9:00	247631.4			1.4	X		12.26	X		0.81	X		11.79	X		1		
11/16/24 9:01	246285.5			1.5	X		12.26	X		0.87	X		11.72	X		1		
11/16/24 9:02	258721.7			1.5	X		12.26	X		0.92	X		12.31	X		1		
11/16/24 9:03	282277			1.5	X		12.26	X		1	X		13.44	X		1		
11/16/24 9:04	290704.5			1.4	X		12.03	X		0.93	X		13.57	X		1		
11/16/24 9:05	295406.3			1	X		11.8	X		0.7	X		13.53	X		1		
11/16/24 9:06	312324.8			0.8	X		11.8	X		0.57	X		14.31	X		1		
11/16/24 9:07	327354.5			0.7	X		11.8	X		0.52	X		14.99	X		1		
11/16/24 9:08	333176.9			0.7	X		12.03	X		0.54	X		15.56	X		1		
11/16/24 9:09	333881.5			0.7	X		12.03	X		0.54	X		15.59	X		1		
11/16/24 9:10	335868.6			0.6	X		12.03	X		0.45	X		15.68	X		1		
11/16/24 9:11	335152.3			0.6	X		11.8	X		0.44	X		15.35	X		1		
11/16/24 9:12	335522			0.6	X		11.8	X		0.44	X		15.37	X		1		
11/16/24 9:13	333558.1			0.6	X		11.8	X		0.44	X		15.28	X		1		
11/16/24 9:14	334955.9			0.4	X		11.8	X		0.35	X		15.35	X		1		
11/16/24 9:15	335706.8			0.4	X		11.8	X		0.35	X		15.38	X		1		
11/16/24 9:16	339680.9			0.5	X		12.03	X		0.36	X		15.86	X		1		
11/16/24 9:17	342771.1			0.4	X		11.8	X		0.36	X		15.7	X		1		
11/16/24 9:18	342245.5			0.5	X		12.03	X		0.37	X		15.98	X		1		
11/16/24 9:19	344729.3			0.6	X		12.03	X		0.46	X		16.1	X		1		
11/16/24 9:20	344781.3			0.6	X		12.03	X		0.46	X		16.1	X		1		
11/16/24 9:21	345526.4			0.6	X		11.8	X		0.45	X		15.83	X		1		
11/16/24 9:22	356039			0.5	X		12.03	X		0.38	X		16.62	X		1		
11/16/24 9:23	379675.3			0.5	X		12.26	X		0.41	X		18.07	X		1		
11/16/24 9:24	386346.8			0.5	X		12.51	X		0.43	X		18.76	X		1		
11/16/24 9:25	317823.8			0.5	X		12.51	X		0.35	X		15.43	X		1		
11/16/24 9:26	0			0	X		30.84	X		0	X		0	X		0		
11/16/24 9:27	0			0	X		76.7	X		0	X		0	X		0		
11/16/24 9:28	0			0	X		0.5	X		0	X		0	X		0		
11/16/24 9:29	0			0	X		0.5	X		0	X		0	X		0		
11/16/24 9:30	0			0	X		0.4	X		0	X		0	X		0		

Monthly Summary By Day Report

Units CT1 and CT2

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 09:57 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:					
	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2
	CO, Lb	NOx, Lb	SO2, Lb	PM10, Lb	VOC, Lb
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2024	33.68	105.65	12.15	24.27	40.45
10/02/2024	27.69	119.29	13.50	26.98	44.96
10/03/2024	28.93	130.97	14.82	29.64	49.34
10/04/2024	28.99	105.22	12.20	24.43	40.69
10/05/2024	22.96	121.72	13.90	27.81	46.40
10/06/2024	23.03	157.18	17.41	34.81	58.01
10/07/2024	17.82	162.72	18.01	36.02	60.00
10/08/2024	32.29	124.50	14.14	28.27	47.13
10/09/2024	30.38	95.38	10.89	21.86	36.45
10/10/2024	32.57	96.56	11.23	22.52	37.58
10/11/2024	35.00	117.28	13.28	26.62	44.39
10/12/2024	32.14	98.01	11.22	22.50	37.56
10/13/2024	32.83	99.89	11.64	23.31	38.83
10/14/2024	33.67	103.96	12.07	24.16	40.26
10/15/2024	31.58	94.78	10.95	21.92	36.52
10/16/2024	31.59	95.94	10.95	21.92	36.52
10/17/2024	40.19	66.76	7.73	15.47	25.78
10/18/2024	15.33	45.02	5.45	10.89	18.12
10/19/2024	15.92	43.87	5.28	10.54	17.52
10/20/2024	16.34	44.17	5.29	10.52	17.49
10/21/2024	18.67	54.71	6.54	13.06	21.70
10/22/2024	25.25	65.94	7.74	15.41	25.68
10/23/2024	25.57	66.94	7.74	15.43	25.77
10/24/2024	25.95	63.25	7.35	14.67	24.48
10/25/2024	26.52	56.60	6.71	13.38	22.28
10/26/2024	17.59	44.06	5.28	10.56	17.52
10/27/2024	15.48	42.75	5.29	10.57	17.56
10/28/2024	82.18	69.10	6.63	13.33	22.20
10/29/2024	50.95	62.15	7.38	14.76	24.60
10/30/2024	31.31	67.39	7.47	14.90	24.89
10/31/2024	25.95	57.96	6.44	12.82	21.29
Monthly Avg/Sum:	908.35 sum	2,679.72 sum	306.68 sum	613.35 sum	1,021.97 sum
Daily Min:	15.33	42.75	5.28	10.52	17.49
Daily Max:	82.18	162.72	18.01	36.02	60.00
Oct 2024 - Oct 2024	908.35 sum	2,679.72 sum	306.68 sum	613.35 sum	1,021.97 sum
QTD:	908.35 sum	2,679.72 sum	306.68 sum	613.35 sum	1,021.97 sum
YTD 2024:	8,236.49 sum	21,342.81 sum	2,387.34 sum	4,776.83 sum	7,959.36 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 09:57 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:						
	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	
	CO, Lb	NOx, Lb	SO2, Lb	PM10, Lb	VOC, Lb	
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	
11/01/2024	21.02	50.66	5.57	11.26	18.75	
11/02/2024	20.43	51.73	5.52	11.28	18.72	
11/03/2024	21.34	51.73	5.72	11.59	19.24	
11/04/2024	22.19	54.41	6.03	12.14	20.20	
11/05/2024	42.52	51.43	5.72	11.49	19.10	
11/06/2024	106.31	67.55	6.31	12.57	21.01	
11/07/2024	62.03	85.03	8.62	17.34	28.85	
11/08/2024	74.98	96.10	10.26	20.58	34.30	
11/09/2024	47.68	62.69	7.75	15.54	25.88	
11/10/2024	27.90	60.26	7.02	13.97	23.35	
11/11/2024	27.88	66.51	7.69	15.30	25.50	
11/12/2024	28.43	61.56	7.09	14.24	23.80	
11/13/2024	26.04	66.46	7.58	15.19	25.31	
11/14/2024	22.13	63.33	7.28	14.55	24.31	
11/15/2024	40.90	76.83	5.00	10.04	16.70	
11/16/2024	2.13	0.00	0.14	0.28	0.45	
11/17/2024	0.00	0.00	0.00	0.00	0.00	
11/18/2024	0.00	0.00	0.00	0.00	0.00	
11/19/2024	0.00	0.00	0.00	0.00	0.00	
11/20/2024	119.95	19.76	0.35	0.70	1.17	
11/21/2024	14.16	1.63	0.01	0.01	0.02	
11/22/2024	82.30	74.80	7.07	14.18	23.59	
11/23/2024	26.64	56.03	6.64	13.29	22.17	
11/24/2024	30.20	58.76	6.85	13.79	22.98	
11/25/2024	32.26	64.45	7.45	14.94	24.96	
11/26/2024	31.19	65.12	7.44	14.91	24.85	
11/27/2024	31.16	65.74	7.50	15.06	25.10	
11/28/2024	33.38	65.56	7.47	14.95	24.88	
11/29/2024	34.28	67.04	7.62	15.27	25.48	
11/30/2024	33.88	66.92	7.64	15.26	25.45	
Monthly Avg/Sum:	1,063.31 sum	1,572.09 sum	169.34 sum	339.72 sum	566.12 sum	
Daily Min:	0.00	0.00	0.00	0.00	0.00	
Daily Max:	119.95	96.10	10.26	20.58	34.30	
Oct 2024 - Nov 2024	1,971.66 sum	4,251.81 sum	476.02 sum	953.07 sum	1,588.09 sum	
QTD:	1,971.66 sum	4,251.81 sum	476.02 sum	953.07 sum	1,588.09 sum	
YTD 2024:	9,299.80 sum	22,914.90 sum	2,556.68 sum	5,116.55 sum	8,525.48 sum	

Monthly Summary By Day Report

Units CT1 and CT2

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 09:57 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:					
	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2	Units CT1 & CT2
	CO, Lb	NOx, Lb	SO2, Lb	PM10, Lb	VOC, Lb
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2024	32.72	60.85	7.10	14.23	23.71
12/02/2024	34.02	65.19	7.47	15.01	25.03
12/03/2024	34.05	59.77	7.10	14.20	23.69
12/04/2024	30.13	62.56	7.34	14.70	24.47
12/05/2024	32.60	62.47	7.54	15.09	25.12
12/06/2024	31.37	59.53	7.32	14.60	24.32
12/07/2024	26.72	53.99	6.53	13.01	21.68
12/08/2024	18.60	45.40	5.44	10.77	17.98
12/09/2024	22.14	57.49	6.75	13.48	22.49
12/10/2024	32.59	65.48	7.58	15.20	25.33
12/11/2024	31.30	67.65	7.67	15.34	25.58
12/12/2024	26.63	69.04	7.82	15.58	25.99
12/13/2024	29.55	66.24	7.53	15.03	25.01
12/14/2024	22.72	53.19	6.31	12.58	20.98
12/15/2024	21.34	49.12	5.95	11.97	19.90
12/16/2024	33.58	64.91	7.44	14.85	24.73
12/17/2024	32.65	65.58	7.48	14.98	24.96
12/18/2024	28.90	64.74	7.37	14.71	24.49
12/19/2024	29.34	62.07	7.06	14.15	23.50
12/20/2024	32.10	65.74	7.44	14.81	24.65
12/21/2024	31.04	64.40	7.33	14.64	24.43
12/22/2024	30.87	65.29	7.45	14.98	24.93
12/23/2024	27.77	60.09	6.96	13.94	23.28
12/24/2024	29.64	65.08	7.41	14.73	24.58
12/25/2024	17.84	47.41	5.70	11.50	19.11
12/26/2024	27.10	63.00	7.17	14.35	23.88
12/27/2024	23.56	58.54	6.79	13.56	22.60
12/28/2024	24.28	59.47	6.84	13.72	22.87
12/29/2024	23.39	57.96	6.70	13.42	22.43
12/30/2024	30.87	40.64	4.52	9.08	15.10
12/31/2024	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum:	849.41 sum	1,802.89 sum	209.11 sum	418.21 sum	696.82 sum
Daily Min:	0.00	0.00	0.00	0.00	0.00
Daily Max:	34.05	69.04	7.82	15.58	25.99
Oct 2024 - Dec 2024	2,821.07 sum	6,054.70 sum	685.13 sum	1,371.28 sum	2,284.91 sum
QTD:	2,821.07 sum	6,054.70 sum	685.13 sum	1,371.28 sum	2,284.91 sum
YTD 2024:	10,149.21 sum	24,717.79 sum	2,765.79 sum	5,534.76 sum	9,222.30 sum

Monthly Summary By Day Report



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 09:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1		Unit CT1		Unit CT2		Unit CT2	
	CO_SUSD, LbPerHr		NOX_SUSD, LbPerHr		CO_SUSD, LbPerHr		NOX_SUSD, LbPerHr	
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
10/01/2024	0.0		0.0		0.0		0.0	
10/02/2024	0.0		0.0		0.0		0.0	
10/03/2024	0.0		0.0		0.0		0.0	
10/04/2024	0.0		0.0		0.0		0.0	
10/05/2024	0.0		0.0		0.0		0.0	
10/06/2024	0.0		0.0		0.0		0.0	
10/07/2024	0.0		0.0		0.0		0.0	
10/08/2024	0.0		0.0		0.0		0.0	
10/09/2024	0.0		0.0		0.0		0.0	
10/10/2024	0.0		0.0		0.0		0.0	
10/11/2024	0.0		0.0		0.0		0.0	
10/12/2024	0.0		0.0		0.0		0.0	
10/13/2024	0.0		0.0		0.0		0.0	
10/14/2024	0.0		0.0		0.0		0.0	
10/15/2024	0.0		0.0		0.0		0.0	
10/16/2024	0.0		0.0		0.0		0.0	
10/17/2024	0.0		0.0		12.0		2.0	
10/18/2024	0.0		0.0		0.0		0.0	
10/19/2024	0.0		0.0		0.0		0.0	
10/20/2024	0.0		0.0		0.0		0.0	
10/21/2024	0.0		0.0		0.0		0.0	
10/22/2024	0.0		0.0		0.0		0.0	
10/23/2024	0.0		0.0		0.0		0.0	
10/24/2024	0.0		0.0		0.0		0.0	
10/25/2024	0.0		0.0		0.0		0.0	
10/26/2024	0.0		0.0		0.0		0.0	
10/27/2024	0.0		0.0		0.0		0.0	
10/28/2024	0.0		0.0		55.8		15.2	
10/29/2024	10.2		1.1		0.0		0.0	
10/30/2024	0.0		0.0		0.0		0.0	
10/31/2024	0.0		0.0		0.0		0.0	
Monthly Avg/Sum:	10.2	sum	1.1	sum	67.8	sum	17.2	sum
Daily Min:	0.0		0.0		0.0		0.0	
Daily Max:	10.2		1.1		55.8		15.2	
Oct 2024 - Oct 2024	10.2	sum	1.1	sum	67.8	sum	17.2	sum
QTD:	10.2	sum	1.1	sum	67.8	sum	17.2	sum
YTD 2024:	1,026.4	sum	137.6	sum	728.8	sum	240.9	sum

Monthly Summary By Day Report



From: 10/01/2024 00:00 To: 12/31/2024 23:59

Generated: 01/02/2025 09:56

Facility Name: ROSEVILLE ENERGY

Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2024	0.0	0.0	0.0	0.0
11/02/2024	0.0	0.0	0.0	0.0
11/03/2024	0.0	0.0	0.0	0.0
11/04/2024	0.0	0.0	0.0	0.0
11/05/2024	0.0	0.0	20.4	5.6
11/06/2024	60.5	13.7	10.6	1.9
11/07/2024	0.0	0.0	33.8	13.5
11/08/2024	0.0	0.0	38.1	11.2
11/09/2024	0.0	0.0	11.6	1.4
11/10/2024	0.0	0.0	0.0	0.0
11/11/2024	0.0	0.0	0.0	0.0
11/12/2024	0.0	0.0	0.0	0.0
11/13/2024	0.0	0.0	0.0	0.0
11/14/2024	0.0	0.0	0.0	0.0
11/15/2024	0.1	0.1	22.3	36.0
11/16/2024	0.0	0.0	0.0	0.0
11/17/2024	0.0	0.0	0.0	0.0
11/18/2024	0.0	0.0	0.0	0.0
11/19/2024	0.0	0.0	0.0	0.0
11/20/2024	74.4	14.8	0.0	0.0
11/21/2024	14.2	1.5	0.0	0.0
11/22/2024	45.3	14.0	0.0	0.0
11/23/2024	0.0	0.0	0.0	0.0
11/24/2024	0.0	0.0	0.0	0.0
11/25/2024	0.0	0.0	0.0	0.0
11/26/2024	0.0	0.0	0.0	0.0
11/27/2024	0.0	0.0	0.0	0.0
11/28/2024	0.0	0.0	0.0	0.0
11/29/2024	0.0	0.0	0.0	0.0
11/30/2024	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	194.5 sum	44.1 sum	136.8 sum	69.6 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	74.4	14.8	38.1	36.0
Oct 2024 - Nov 2024	204.7 sum	45.2 sum	204.6 sum	86.8 sum
QTD:	204.7 sum	45.2 sum	204.6 sum	86.8 sum
YTD 2024:	1,220.9 sum	181.7 sum	865.6 sum	310.5 sum

Monthly Summary By Day Report



From: 10/01/2024 00:00

To: 12/31/2024 23:59

Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 09:56

Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1		Unit CT2	
	CO_SUSD, LbPerHr		NOX_SUSD, LbPerHr	
	1 Hour(s)		1 Hour(s)	
12/01/2024	0.0	0.0	0.0	0.0
12/02/2024	0.0	0.0	0.0	0.0
12/03/2024	0.0	0.0	0.0	0.0
12/04/2024	0.0	0.0	0.0	0.0
12/05/2024	0.0	0.0	0.0	0.0
12/06/2024	0.0	0.0	0.0	0.0
12/07/2024	0.0	0.0	0.0	0.0
12/08/2024	0.0	0.0	0.0	0.0
12/09/2024	0.0	0.0	0.0	0.0
12/10/2024	0.0	0.0	0.0	0.0
12/11/2024	0.0	0.0	0.0	0.0
12/12/2024	0.0	0.0	0.0	0.0
12/13/2024	0.0	0.0	0.0	0.0
12/14/2024	0.0	0.0	0.0	0.0
12/15/2024	0.0	0.0	0.0	0.0
12/16/2024	0.0	0.0	0.0	0.0
12/17/2024	0.0	0.0	0.0	0.0
12/18/2024	0.0	0.0	0.0	0.0
12/19/2024	0.0	0.0	0.0	0.0
12/20/2024	0.0	0.0	0.0	0.0
12/21/2024	0.0	0.0	0.0	0.0
12/22/2024	0.0	0.0	0.0	0.0
12/23/2024	0.0	0.0	0.0	0.0
12/24/2024	0.0	0.0	0.0	0.0
12/25/2024	0.0	0.0	0.0	0.0
12/26/2024	0.0	0.0	0.0	0.0
12/27/2024	0.0	0.0	0.0	0.0
12/28/2024	0.0	0.0	0.0	0.0
12/29/2024	0.0	0.0	0.0	0.0
12/30/2024	38.8	2.0	0.0	0.0
12/31/2024	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	38.8 sum	2.0 sum	-	-
Daily Min:	0.0	0.0	-	-
Daily Max:	38.8	2.0	-	-
Oct 2024 - Dec 2024	243.5 sum	47.2 sum	204.6 sum	86.8 sum
QTD:	243.5 sum	47.2 sum	204.6 sum	86.8 sum
YTD 2024:	1,259.7 sum	183.7 sum	865.6 sum	310.5 sum

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:19 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2024	0.4543	4.1404	1.3401	10.6951	0.3068	2.3923	0.1533	1.1956	0.5110	3.9847
Nov 2024	0.5318	4.6383	0.7862	11.4528	0.1699	2.5575	0.0846	1.2779	0.2833	4.2602
Dec 2024	0.4250	5.0633	0.9013	12.3541	0.2093	2.7668	0.1049	1.3828	0.3485	4.6087
Sum/Avg	5.0633		12.3541		2.7668		1.3828		4.6087	
Limit Value										

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/01/2024 00:00	0.8	1.3	1	0.44	0.21894	0.73
10/01/2024 01:00	0.8	1.3	1	0.43	0.21462	0.72
10/01/2024 02:00	0.8	1.4	1	0.43	0.21540	0.72
10/01/2024 03:00	0.8	1.3	1	0.43	0.21534	0.72
10/01/2024 04:00	0.8	1.4	1	0.43	0.21690	0.72
10/01/2024 05:00	0.7	1.4	0	0.52	0.25902	0.86
10/01/2024 06:00	0.8	1.4	1	0.45	0.22512	0.75
10/01/2024 07:00	0.8	1.4	1	0.43	0.21462	0.72
10/01/2024 08:00	0.7	1.3	1	0.43	0.21438	0.71
10/01/2024 09:00	0.6	1.3	1	0.43	0.21414	0.71
10/01/2024 10:00	0.6	1.4	1	0.43	0.21396	0.71
10/01/2024 11:00	0.5	1.2	0	0.43	0.21432	0.71
10/01/2024 12:00	0.5	1.2	0	0.49	0.24678	0.82
10/01/2024 13:00	0.4	1.3	0	0.53	0.26580	0.89
10/01/2024 14:00	0.4	1.4	0	0.53	0.26574	0.89
10/01/2024 15:00	0.5	1.3	0	0.49	0.24588	0.82
10/01/2024 16:00	0.5	1.3	0	0.54	0.26880	0.90
10/01/2024 17:00	0.1	1.5	1	0.73	0.36660	1.22
10/01/2024 18:00	0.4	1.3	1	0.66	0.32790	1.09
10/01/2024 19:00	0.7	1.4	1	0.62	0.30996	1.03
10/01/2024 20:00	0.7	1.3	1	0.54	0.26814	0.89
10/01/2024 21:00	1.0	1.4	1	0.43	0.21702	0.72
10/01/2024 22:00	0.8	1.3	1	0.43	0.21456	0.72
10/01/2024 23:00	0.7	1.3	1	0.43	0.21474	0.72
Average/Sum#:	0.6	1.3	1	0.49	0.24370	0.81
Minimum:	0.1	1.2	0	0.43	0.21396	0.71
Maximum:	1.0	1.5	1	0.73	0.36660	1.22
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/02/2024 00:00	0.8	1.3	1	0.43	0.21498	0.72
10/02/2024 01:00	0.7	1.4	1	0.43	0.21474	0.72
10/02/2024 02:00	0.8	1.3	1	0.43	0.21612	0.72
10/02/2024 03:00	0.8	1.4	1	0.43	0.21666	0.72
10/02/2024 04:00	0.7	1.3	1	0.43	0.21696	0.72
10/02/2024 05:00	0.7	1.3	1	0.43	0.21612	0.72
10/02/2024 06:00	0.8	1.3	1	0.43	0.21558	0.72
10/02/2024 07:00	0.7	1.3	1	0.43	0.21612	0.72
10/02/2024 08:00	0.6	1.3	1	0.43	0.21564	0.72
10/02/2024 09:00	0.6	1.3	1	0.43	0.21498	0.72
10/02/2024 10:00	0.5	1.3	0	0.43	0.21582	0.72
10/02/2024 11:00	0.5	1.3	0	0.50	0.24858	0.83
10/02/2024 12:00	0.2	1.4	1	0.72	0.35928	1.20
10/02/2024 13:00	0.0	1.5	2	0.78	0.38808	1.29
10/02/2024 14:00	0.0	1.5	2	0.77	0.38292	1.28
10/02/2024 15:00	0.0	1.5	2	0.74	0.37140	1.24
10/02/2024 16:00	0.1	1.5	1	0.71	0.35448	1.18
10/02/2024 17:00	0.0	1.5	2	0.76	0.38088	1.27
10/02/2024 18:00	0.4	1.3	1	0.64	0.31896	1.06
10/02/2024 19:00	0.6	1.3	1	0.62	0.31236	1.04
10/02/2024 20:00	0.6	1.3	1	0.62	0.31152	1.04
10/02/2024 21:00	0.7	1.3	1	0.54	0.26982	0.90
10/02/2024 22:00	0.6	1.3	1	0.44	0.21936	0.73
10/02/2024 23:00	0.6	1.2	0	0.46	0.23016	0.77
Average/Sum#:	0.5	1.4	1	0.54	0.27173	0.91
Minimum:	0.0	1.2	0	0.43	0.21474	0.72
Maximum:	0.8	1.5	2	0.78	0.38808	1.29
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/03/2024 00:00	0.6	1.4	1	0.43	0.21462	0.72
10/03/2024 01:00	0.6	1.3	1	0.43	0.21486	0.72
10/03/2024 02:00	0.6	1.2	1	0.43	0.21438	0.71
10/03/2024 03:00	0.6	1.3	1	0.43	0.21492	0.72
10/03/2024 04:00	0.6	1.3	1	0.43	0.21726	0.72
10/03/2024 05:00	0.6	1.3	0	0.52	0.26076	0.87
10/03/2024 06:00	0.7	1.3	0	0.54	0.27018	0.90
10/03/2024 07:00	0.7	1.4	1	0.64	0.32088	1.07
10/03/2024 08:00	0.8	1.4	1	0.62	0.30876	1.03
10/03/2024 09:00	0.7	1.4	1	0.62	0.31002	1.03
10/03/2024 10:00	0.6	1.4	1	0.62	0.31236	1.04
10/03/2024 11:00	0.4	1.3	1	0.65	0.32358	1.08
10/03/2024 12:00	0.1	1.5	2	0.77	0.38736	1.29
10/03/2024 13:00	0.1	1.5	2	0.79	0.39354	1.31
10/03/2024 14:00	0.0	1.5	2	0.78	0.38910	1.30
10/03/2024 15:00	0.0	1.5	2	0.78	0.38928	1.30
10/03/2024 16:00	0.0	1.5	2	0.77	0.38532	1.28
10/03/2024 17:00	0.0	1.4	2	0.75	0.37338	1.24
10/03/2024 18:00	0.4	1.4	1	0.63	0.31638	1.05
10/03/2024 19:00	0.6	1.4	1	0.62	0.31200	1.04
10/03/2024 20:00	0.6	1.3	1	0.62	0.31134	1.04
10/03/2024 21:00	0.7	1.3	1	0.59	0.29418	0.98
10/03/2024 22:00	0.6	1.3	0	0.44	0.21864	0.73
10/03/2024 23:00	0.5	1.3	0	0.43	0.21666	0.72
Average/Sum#:	0.5	1.4	1	0.60	0.29874	1.00
Minimum:	0.0	1.2	0	0.43	0.21438	0.71
Maximum:	0.8	1.5	2	0.79	0.39354	1.31
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/04/2024 00:00	0.5	1.3	0	0.43	0.21636	0.72
10/04/2024 01:00	0.5	1.3	1	0.43	0.21660	0.72
10/04/2024 02:00	0.6	1.4	0	0.43	0.21660	0.72
10/04/2024 03:00	0.6	1.3	0	0.43	0.21648	0.72
10/04/2024 04:00	0.6	1.4	0	0.43	0.21558	0.72
10/04/2024 05:00	0.5	1.2	0	0.45	0.22458	0.75
10/04/2024 06:00	0.6	1.3	0	0.47	0.23274	0.78
10/04/2024 07:00	0.6	1.3	1	0.44	0.21756	0.73
10/04/2024 08:00	0.6	1.3	1	0.43	0.21576	0.72
10/04/2024 09:00	0.6	1.2	1	0.43	0.21576	0.72
10/04/2024 10:00	0.5	1.2	0	0.43	0.21588	0.72
10/04/2024 11:00	0.5	1.2	0	0.44	0.21774	0.73
10/04/2024 12:00	0.5	1.2	0	0.45	0.22410	0.75
10/04/2024 13:00	0.5	1.2	0	0.47	0.23730	0.79
10/04/2024 14:00	0.2	1.4	1	0.71	0.35508	1.18
10/04/2024 15:00	0.1	1.4	1	0.69	0.34632	1.15
10/04/2024 16:00	0.2	1.4	1	0.66	0.33078	1.10
10/04/2024 17:00	0.3	1.4	1	0.65	0.32430	1.08
10/04/2024 18:00	0.6	1.4	1	0.63	0.31266	1.04
10/04/2024 19:00	0.7	1.3	1	0.54	0.26922	0.90
10/04/2024 20:00	0.7	1.4	1	0.43	0.21624	0.72
10/04/2024 21:00	0.7	1.4	1	0.43	0.21636	0.72
10/04/2024 22:00	0.6	1.4	1	0.43	0.21588	0.72
10/04/2024 23:00	0.6	1.2	1	0.44	0.21762	0.73
Average/Sum#:	0.5	1.3	1	0.49	0.24531	0.82
Minimum:	0.1	1.2	0	0.43	0.21558	0.72
Maximum:	0.7	1.4	1	0.71	0.35508	1.18
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/05/2024 00:00	0.6	1.2	1	0.43	0.21636	0.72
10/05/2024 01:00	0.6	1.3	0	0.43	0.21564	0.72
10/05/2024 02:00	0.7	1.3	0	0.43	0.21594	0.72
10/05/2024 03:00	0.8	1.3	1	0.43	0.21600	0.72
10/05/2024 04:00	0.7	1.3	1	0.43	0.21624	0.72
10/05/2024 05:00	0.6	1.3	1	0.43	0.21720	0.72
10/05/2024 06:00	0.6	1.3	1	0.43	0.21738	0.72
10/05/2024 07:00	0.6	1.3	1	0.43	0.21714	0.72
10/05/2024 08:00	0.6	1.3	0	0.43	0.21606	0.72
10/05/2024 09:00	0.6	1.3	1	0.43	0.21522	0.72
10/05/2024 10:00	0.6	1.3	1	0.43	0.21504	0.72
10/05/2024 11:00	0.6	1.2	0	0.43	0.21582	0.72
10/05/2024 12:00	0.5	1.2	0	0.50	0.24792	0.83
10/05/2024 13:00	0.5	1.4	0	0.57	0.28302	0.94
10/05/2024 14:00	0.0	1.4	1	0.72	0.36102	1.20
10/05/2024 15:00	0.1	1.4	1	0.71	0.35634	1.19
10/05/2024 16:00	0.0	1.5	2	0.75	0.37734	1.26
10/05/2024 17:00	0.0	1.4	1	0.74	0.37062	1.24
10/05/2024 18:00	0.1	1.4	1	0.71	0.35490	1.18
10/05/2024 19:00	0.0	1.4	1	0.74	0.36756	1.23
10/05/2024 20:00	0.1	1.4	1	0.73	0.36672	1.22
10/05/2024 21:00	0.1	1.5	1	0.73	0.36552	1.22
10/05/2024 22:00	0.1	1.4	1	0.72	0.35802	1.19
10/05/2024 23:00	0.4	1.4	1	0.67	0.33618	1.12
Average/Sum#:	0.4	1.3	1	0.56	0.28080	0.94
Minimum:	0.0	1.2	0	0.43	0.21504	0.72
Maximum:	0.8	1.5	2	0.75	0.37734	1.26
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/06/2024 00:00	0.6	1.4	1	0.65	0.32742	1.09
10/06/2024 01:00	0.6	1.4	1	0.66	0.32886	1.10
10/06/2024 02:00	0.7	1.4	1	0.65	0.32394	1.08
10/06/2024 03:00	0.9	1.4	1	0.63	0.31662	1.06
10/06/2024 04:00	0.6	1.4	1	0.65	0.32652	1.09
10/06/2024 05:00	0.6	1.4	1	0.66	0.32802	1.09
10/06/2024 06:00	0.5	1.4	1	0.67	0.33732	1.12
10/06/2024 07:00	0.7	1.4	1	0.65	0.32400	1.08
10/06/2024 08:00	0.8	1.4	1	0.64	0.31902	1.06
10/06/2024 09:00	0.2	1.4	1	0.71	0.35490	1.18
10/06/2024 10:00	0.0	1.5	1	0.74	0.36876	1.23
10/06/2024 11:00	0.0	1.5	1	0.74	0.36942	1.23
10/06/2024 12:00	0.0	1.5	2	0.75	0.37746	1.26
10/06/2024 13:00	0.0	1.5	2	0.75	0.37674	1.26
10/06/2024 14:00	0.0	1.5	2	0.76	0.37938	1.26
10/06/2024 15:00	0.0	1.4	2	0.75	0.37296	1.24
10/06/2024 16:00	0.3	1.3	1	0.64	0.31980	1.07
10/06/2024 17:00	0.1	1.5	2	0.76	0.37944	1.26
10/06/2024 18:00	0.0	1.5	2	0.76	0.38046	1.27
10/06/2024 19:00	0.0	1.5	2	0.77	0.38526	1.28
10/06/2024 20:00	0.1	1.4	1	0.74	0.37206	1.24
10/06/2024 21:00	0.1	1.5	1	0.74	0.37176	1.24
10/06/2024 22:00	0.1	1.4	1	0.73	0.36552	1.22
10/06/2024 23:00	0.1	1.4	1	0.71	0.35538	1.18
Average/Sum#:	0.3	1.4	1	0.70	0.35254	1.17
Minimum:	0.0	1.3	1	0.63	0.31662	1.06
Maximum:	0.9	1.5	2	0.77	0.38526	1.28
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/07/2024 00:00	0.1	1.4	1	0.71	0.35562	1.19
10/07/2024 01:00	0.2	1.4	1	0.70	0.35100	1.17
10/07/2024 02:00	0.6	1.4	1	0.66	0.32916	1.10
10/07/2024 03:00	0.5	1.4	1	0.67	0.33480	1.12
10/07/2024 04:00	0.2	1.4	1	0.71	0.35484	1.18
10/07/2024 05:00	0.1	1.5	1	0.73	0.36468	1.22
10/07/2024 06:00	0.1	1.4	1	0.72	0.36204	1.21
10/07/2024 07:00	0.5	1.4	1	0.68	0.33840	1.13
10/07/2024 08:00	0.1	1.4	1	0.73	0.36336	1.21
10/07/2024 09:00	0.1	1.5	1	0.73	0.36474	1.22
10/07/2024 10:00	0.0	1.5	1	0.75	0.37320	1.24
10/07/2024 11:00	0.0	1.5	2	0.76	0.37872	1.26
10/07/2024 12:00	0.0	1.5	2	0.76	0.38004	1.27
10/07/2024 13:00	0.0	1.5	2	0.76	0.38064	1.27
10/07/2024 14:00	0.0	1.5	2	0.76	0.38136	1.27
10/07/2024 15:00	0.0	1.5	2	0.76	0.38142	1.27
10/07/2024 16:00	0.0	1.5	2	0.76	0.38106	1.27
10/07/2024 17:00	0.0	1.5	2	0.76	0.38034	1.27
10/07/2024 18:00	0.0	1.5	2	0.76	0.37914	1.26
10/07/2024 19:00	0.0	1.5	2	0.76	0.37776	1.26
10/07/2024 20:00	0.0	1.4	2	0.75	0.37494	1.25
10/07/2024 21:00	0.1	1.5	1	0.73	0.36720	1.22
10/07/2024 22:00	0.2	1.4	1	0.72	0.35826	1.19
10/07/2024 23:00	0.4	1.4	1	0.70	0.34878	1.16
Average/Sum#:	0.1	1.5	1	0.73	0.36506	1.22
Minimum:	0.0	1.4	1	0.66	0.32916	1.10
Maximum:	0.6	1.5	2	0.76	0.38142	1.27
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/08/2024 00:00	1.1	1.4	1	0.58	0.29232	0.97
10/08/2024 01:00	0.6	1.3	1	0.44	0.21966	0.73
10/08/2024 02:00	0.6	1.1	1	0.44	0.21888	0.73
10/08/2024 03:00	0.8	1.4	1	0.44	0.21828	0.73
10/08/2024 04:00	0.6	1.3	1	0.46	0.23166	0.77
10/08/2024 05:00	0.6	1.3	0	0.49	0.24552	0.82
10/08/2024 06:00	0.6	1.3	0	0.51	0.25278	0.84
10/08/2024 07:00	0.6	1.3	1	0.43	0.21648	0.72
10/08/2024 08:00	0.8	1.3	0	0.50	0.24918	0.83
10/08/2024 09:00	0.8	1.4	1	0.62	0.30834	1.03
10/08/2024 10:00	0.7	1.3	1	0.54	0.26952	0.90
10/08/2024 11:00	0.6	1.3	0	0.50	0.24870	0.83
10/08/2024 12:00	0.2	1.4	1	0.68	0.34050	1.14
10/08/2024 13:00	0.2	1.4	1	0.69	0.34338	1.14
10/08/2024 14:00	0.0	1.5	2	0.75	0.37404	1.25
10/08/2024 15:00	0.0	1.4	1	0.72	0.36204	1.21
10/08/2024 16:00	0.0	1.5	2	0.75	0.37626	1.25
10/08/2024 17:00	0.0	1.4	2	0.73	0.36684	1.22
10/08/2024 18:00	0.1	1.4	1	0.71	0.35676	1.19
10/08/2024 19:00	0.3	1.4	1	0.68	0.34056	1.14
10/08/2024 20:00	0.5	1.4	1	0.65	0.32256	1.08
10/08/2024 21:00	0.7	1.3	1	0.50	0.24762	0.83
10/08/2024 22:00	0.6	1.3	1	0.43	0.21690	0.72
10/08/2024 23:00	0.5	1.3	1	0.43	0.21666	0.72
Average/Sum#:	0.5	1.4	1	0.57	0.28481	0.95
Minimum:	0.0	1.1	0	0.43	0.21648	0.72
Maximum:	1.1	1.5	2	0.75	0.37626	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/09/2024 00:00	0.5	1.3	1	0.43	0.21684	0.72
10/09/2024 01:00	0.5	1.3	1	0.43	0.21696	0.72
10/09/2024 02:00	0.5	1.3	1	0.43	0.21702	0.72
10/09/2024 03:00	0.6	1.4	1	0.43	0.21726	0.72
10/09/2024 04:00	0.5	1.3	0	0.43	0.21714	0.72
10/09/2024 05:00	0.5	1.3	0	0.46	0.22824	0.76
10/09/2024 06:00	0.6	1.4	1	0.46	0.23160	0.77
10/09/2024 07:00	0.6	1.4	1	0.44	0.21768	0.73
10/09/2024 08:00	0.6	1.4	1	0.44	0.21762	0.73
10/09/2024 09:00	0.5	1.3	1	0.44	0.21756	0.73
10/09/2024 10:00	0.5	1.3	1	0.44	0.21780	0.73
10/09/2024 11:00	0.5	1.3	1	0.44	0.21798	0.73
10/09/2024 12:00	0.5	1.3	0	0.44	0.21780	0.73
10/09/2024 13:00	0.5	1.3	0	0.43	0.21732	0.72
10/09/2024 14:00	0.5	1.3	1	0.43	0.21732	0.72
10/09/2024 15:00	0.5	1.3	0	0.43	0.21732	0.72
10/09/2024 16:00	0.5	1.3	0	0.47	0.23328	0.78
10/09/2024 17:00	0.5	1.3	1	0.44	0.21870	0.73
10/09/2024 18:00	0.6	1.4	0	0.43	0.21654	0.72
10/09/2024 19:00	0.6	1.3	0	0.43	0.21660	0.72
10/09/2024 20:00	0.6	1.3	1	0.43	0.21708	0.72
10/09/2024 21:00	0.6	1.3	1	0.43	0.21738	0.72
10/09/2024 22:00	0.6	1.3	0	0.43	0.21726	0.72
10/09/2024 23:00	0.5	1.3	0	0.43	0.21738	0.72
Average/Sum#:	0.5	1.3	1	0.44	0.21907	0.73
Minimum:	0.5	1.3	0	0.43	0.21654	0.72
Maximum:	0.6	1.4	1	0.47	0.23328	0.78
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/10/2024 00:00	0.6	1.3	1	0.44	0.21750	0.73
10/10/2024 01:00	0.6	1.3	0	0.44	0.21756	0.73
10/10/2024 02:00	0.5	1.2	0	0.43	0.21726	0.72
10/10/2024 03:00	0.6	1.4	1	0.43	0.21720	0.72
10/10/2024 04:00	0.6	1.3	1	0.44	0.21768	0.73
10/10/2024 05:00	0.6	1.3	0	0.48	0.24198	0.81
10/10/2024 06:00	0.6	1.3	1	0.49	0.24264	0.81
10/10/2024 07:00	0.6	1.3	1	0.44	0.21780	0.73
10/10/2024 08:00	0.6	1.4	1	0.44	0.21810	0.73
10/10/2024 09:00	0.6	1.3	0	0.48	0.23886	0.80
10/10/2024 10:00	0.5	1.2	0	0.47	0.23664	0.79
10/10/2024 11:00	0.5	1.2	1	0.47	0.23250	0.78
10/10/2024 12:00	0.5	1.2	0	0.47	0.23718	0.79
10/10/2024 13:00	0.5	1.2	0	0.45	0.22320	0.74
10/10/2024 14:00	0.6	1.3	1	0.44	0.21888	0.73
10/10/2024 15:00	0.5	1.2	0	0.45	0.22518	0.75
10/10/2024 16:00	0.5	1.3	0	0.46	0.23124	0.77
10/10/2024 17:00	0.5	1.2	0	0.46	0.23016	0.77
10/10/2024 18:00	0.6	1.3	1	0.45	0.22374	0.75
10/10/2024 19:00	0.5	1.4	1	0.43	0.21696	0.72
10/10/2024 20:00	0.6	1.3	0	0.44	0.21936	0.73
10/10/2024 21:00	0.7	1.3	1	0.44	0.21846	0.73
10/10/2024 22:00	0.6	1.3	1	0.43	0.21732	0.72
10/10/2024 23:00	0.6	1.3	0	0.46	0.23082	0.77
Average/Sum#:	0.6	1.3	1	0.45	0.22534	0.75
Minimum:	0.5	1.2	0	0.43	0.21696	0.72
Maximum:	0.7	1.4	1	0.49	0.24264	0.81
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/11/2024 00:00	0.6	1.3	1	0.44	0.22068	0.74
10/11/2024 01:00	0.6	1.3	1	0.43	0.21714	0.72
10/11/2024 02:00	0.6	1.2	1	0.43	0.21702	0.72
10/11/2024 03:00	0.7	1.3	1	0.44	0.22146	0.74
10/11/2024 04:00	0.6	1.3	0	0.46	0.23166	0.77
10/11/2024 05:00	0.6	1.3	0	0.47	0.23622	0.79
10/11/2024 06:00	0.6	1.2	0	0.46	0.23142	0.77
10/11/2024 07:00	0.6	1.1	1	0.46	0.22764	0.76
10/11/2024 08:00	0.6	1.3	1	0.44	0.22044	0.73
10/11/2024 09:00	0.5	1.3	0	0.47	0.23472	0.78
10/11/2024 10:00	0.6	1.4	1	0.43	0.21720	0.72
10/11/2024 11:00	0.5	1.3	1	0.43	0.21708	0.72
10/11/2024 12:00	0.5	1.2	1	0.44	0.21870	0.73
10/11/2024 13:00	0.5	1.3	0	0.51	0.25392	0.85
10/11/2024 14:00	0.5	1.3	0	0.55	0.27426	0.91
10/11/2024 15:00	0.1	1.5	1	0.75	0.37254	1.24
10/11/2024 16:00	0.6	1.3	0	0.56	0.27840	0.93
10/11/2024 17:00	0.3	1.4	1	0.68	0.34182	1.14
10/11/2024 18:00	0.5	1.4	1	0.66	0.32850	1.10
10/11/2024 19:00	0.5	1.4	1	0.67	0.33564	1.12
10/11/2024 20:00	0.2	1.4	1	0.71	0.35574	1.19
10/11/2024 21:00	0.4	1.5	1	0.69	0.34362	1.15
10/11/2024 22:00	0.5	1.4	1	0.67	0.33408	1.11
10/11/2024 23:00	0.9	1.4	1	0.58	0.29010	0.97
Average/Sum#:	0.5	1.3	1	0.53	0.26750	0.89
Minimum:	0.1	1.1	0	0.43	0.21702	0.72
Maximum:	0.9	1.5	1	0.75	0.37254	1.24
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/12/2024 00:00	0.6	1.3	1	0.44	0.21768	0.73
10/12/2024 01:00	0.6	1.3	1	0.43	0.21738	0.72
10/12/2024 02:00	0.6	1.4	1	0.44	0.21756	0.73
10/12/2024 03:00	0.7	1.4	0	0.43	0.21744	0.72
10/12/2024 04:00	0.6	1.4	1	0.44	0.21750	0.73
10/12/2024 05:00	0.6	1.3	1	0.43	0.21744	0.72
10/12/2024 06:00	0.6	1.4	1	0.44	0.21816	0.73
10/12/2024 07:00	0.6	1.2	1	0.46	0.22794	0.76
10/12/2024 08:00	0.6	1.3	1	0.44	0.21852	0.73
10/12/2024 09:00	0.5	1.3	1	0.44	0.21966	0.73
10/12/2024 10:00	0.5	1.4	1	0.44	0.21780	0.73
10/12/2024 11:00	0.5	1.3	1	0.44	0.21768	0.73
10/12/2024 12:00	0.5	1.3	1	0.43	0.21732	0.72
10/12/2024 13:00	0.5	1.3	1	0.43	0.21744	0.72
10/12/2024 14:00	0.5	1.3	0	0.44	0.22182	0.74
10/12/2024 15:00	0.5	1.4	1	0.44	0.21816	0.73
10/12/2024 16:00	0.5	1.3	0	0.50	0.24762	0.83
10/12/2024 17:00	0.6	1.3	1	0.44	0.21924	0.73
10/12/2024 18:00	0.6	1.3	1	0.43	0.21720	0.72
10/12/2024 19:00	0.6	1.3	0	0.46	0.23160	0.77
10/12/2024 20:00	0.5	1.3	0	0.54	0.27228	0.91
10/12/2024 21:00	0.5	1.3	0	0.52	0.26040	0.87
10/12/2024 22:00	0.6	1.4	1	0.44	0.21816	0.73
10/12/2024 23:00	0.6	1.2	1	0.49	0.24426	0.81
Average/Sum#:	0.6	1.3	1	0.45	0.22543	0.75
Minimum:	0.5	1.2	0	0.43	0.21720	0.72
Maximum:	0.7	1.4	1	0.54	0.27228	0.91
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/13/2024 00:00	0.6	1.3	1	0.44	0.21750	0.73
10/13/2024 01:00	0.6	1.3	1	0.44	0.21804	0.73
10/13/2024 02:00	0.6	1.2	1	0.43	0.21720	0.72
10/13/2024 03:00	0.7	1.4	1	0.43	0.21714	0.72
10/13/2024 04:00	0.6	1.3	1	0.44	0.21912	0.73
10/13/2024 05:00	0.6	1.2	0	0.51	0.25362	0.85
10/13/2024 06:00	0.6	1.3	1	0.49	0.24390	0.81
10/13/2024 07:00	0.6	1.3	1	0.43	0.21738	0.72
10/13/2024 08:00	0.6	1.4	1	0.43	0.21726	0.72
10/13/2024 09:00	0.6	1.3	1	0.43	0.21702	0.72
10/13/2024 10:00	0.6	1.3	1	0.43	0.21702	0.72
10/13/2024 11:00	0.5	1.3	1	0.44	0.21762	0.73
10/13/2024 12:00	0.5	1.3	1	0.43	0.21720	0.72
10/13/2024 13:00	0.5	1.3	1	0.43	0.21672	0.72
10/13/2024 14:00	0.5	1.2	0	0.47	0.23688	0.79
10/13/2024 15:00	0.5	1.2	0	0.47	0.23418	0.78
10/13/2024 16:00	0.5	1.3	0	0.54	0.26868	0.90
10/13/2024 17:00	0.4	1.2	0	0.55	0.27372	0.91
10/13/2024 18:00	0.4	1.3	0	0.55	0.27342	0.91
10/13/2024 19:00	0.5	1.3	0	0.55	0.27270	0.91
10/13/2024 20:00	0.5	1.3	0	0.54	0.27246	0.91
10/13/2024 21:00	0.6	1.3	1	0.46	0.22782	0.76
10/13/2024 22:00	0.7	1.4	1	0.43	0.21744	0.72
10/13/2024 23:00	0.7	1.3	1	0.44	0.21756	0.73
Average/Sum#:	0.6	1.3	1	0.47	0.23340	0.78
Minimum:	0.4	1.2	0	0.43	0.21672	0.72
Maximum:	0.7	1.4	1	0.55	0.27372	0.91
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/14/2024 00:00	0.6	1.3	1	0.43	0.21732	0.72
10/14/2024 01:00	0.6	1.4	1	0.43	0.21666	0.72
10/14/2024 02:00	0.6	1.3	1	0.43	0.21684	0.72
10/14/2024 03:00	0.7	1.2	1	0.43	0.21690	0.72
10/14/2024 04:00	0.6	1.3	0	0.46	0.22788	0.76
10/14/2024 05:00	0.5	1.3	0	0.55	0.27318	0.91
10/14/2024 06:00	0.6	1.3	0	0.53	0.26616	0.89
10/14/2024 07:00	0.5	1.3	0	0.53	0.26316	0.88
10/14/2024 08:00	0.6	1.2	1	0.43	0.21696	0.72
10/14/2024 09:00	0.5	1.3	0	0.45	0.22584	0.75
10/14/2024 10:00	0.5	1.3	1	0.43	0.21690	0.72
10/14/2024 11:00	0.5	1.3	1	0.43	0.21660	0.72
10/14/2024 12:00	0.5	1.3	1	0.43	0.21648	0.72
10/14/2024 13:00	0.5	1.3	0	0.47	0.23742	0.79
10/14/2024 14:00	0.5	1.3	0	0.46	0.23190	0.77
10/14/2024 15:00	0.5	1.4	0	0.46	0.22752	0.76
10/14/2024 16:00	0.6	1.3	0	0.51	0.25296	0.84
10/14/2024 17:00	0.3	1.4	1	0.68	0.33762	1.13
10/14/2024 18:00	0.7	1.4	1	0.63	0.31482	1.05
10/14/2024 19:00	0.7	1.3	0	0.49	0.24618	0.82
10/14/2024 20:00	0.6	1.2	0	0.54	0.26814	0.89
10/14/2024 21:00	0.6	1.3	0	0.50	0.25062	0.84
10/14/2024 22:00	0.6	1.3	1	0.44	0.21876	0.73
10/14/2024 23:00	0.6	1.3	0	0.47	0.23460	0.78
Average/Sum#:	0.6	1.3	0	0.48	0.24214	0.81
Minimum:	0.3	1.2	0	0.43	0.21648	0.72
Maximum:	0.7	1.4	1	0.68	0.33762	1.13
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/15/2024 00:00	0.6	1.3	1	0.43	0.21594	0.72
10/15/2024 01:00	0.6	1.3	1	0.43	0.21678	0.72
10/15/2024 02:00	0.6	1.3	1	0.43	0.21684	0.72
10/15/2024 03:00	0.7	1.4	1	0.43	0.21690	0.72
10/15/2024 04:00	0.6	1.3	1	0.44	0.22104	0.74
10/15/2024 05:00	0.6	1.3	0	0.49	0.24720	0.82
10/15/2024 06:00	0.6	1.2	1	0.49	0.24630	0.82
10/15/2024 07:00	0.6	1.4	1	0.43	0.21696	0.72
10/15/2024 08:00	0.6	1.3	1	0.43	0.21732	0.72
10/15/2024 09:00	0.6	1.4	1	0.43	0.21732	0.72
10/15/2024 10:00	0.5	1.3	1	0.43	0.21690	0.72
10/15/2024 11:00	0.5	1.3	1	0.43	0.21684	0.72
10/15/2024 12:00	0.5	1.3	1	0.43	0.21732	0.72
10/15/2024 13:00	0.6	1.3	1	0.44	0.21756	0.73
10/15/2024 14:00	0.6	1.3	1	0.44	0.21768	0.73
10/15/2024 15:00	0.6	1.2	1	0.44	0.21780	0.73
10/15/2024 16:00	0.5	1.2	0	0.44	0.22128	0.74
10/15/2024 17:00	0.6	1.3	0	0.43	0.21696	0.72
10/15/2024 18:00	0.5	1.4	1	0.43	0.21654	0.72
10/15/2024 19:00	0.5	1.3	1	0.43	0.21678	0.72
10/15/2024 20:00	0.5	1.3	1	0.43	0.21672	0.72
10/15/2024 21:00	0.5	1.3	0	0.43	0.21678	0.72
10/15/2024 22:00	0.5	1.4	1	0.43	0.21696	0.72
10/15/2024 23:00	0.6	1.3	0	0.43	0.21684	0.72
Average/Sum#:	0.6	1.3	1	0.44	0.21982	0.73
Minimum:	0.5	1.2	0	0.43	0.21594	0.72
Maximum:	0.7	1.4	1	0.49	0.24720	0.82
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/16/2024 00:00	0.6	1.4	1	0.43	0.21690	0.72
10/16/2024 01:00	0.5	1.3	1	0.43	0.21684	0.72
10/16/2024 02:00	0.5	1.2	1	0.43	0.21672	0.72
10/16/2024 03:00	0.6	1.3	1	0.43	0.21660	0.72
10/16/2024 04:00	0.6	1.3	1	0.44	0.21900	0.73
10/16/2024 05:00	0.5	1.3	0	0.51	0.25260	0.84
10/16/2024 06:00	0.6	1.3	0	0.49	0.24342	0.81
10/16/2024 07:00	0.6	1.3	1	0.44	0.21780	0.73
10/16/2024 08:00	0.8	1.3	1	0.43	0.21648	0.72
10/16/2024 09:00	0.6	1.3	1	0.43	0.21726	0.72
10/16/2024 10:00	0.6	1.3	1	0.43	0.21744	0.72
10/16/2024 11:00	0.6	1.2	1	0.44	0.21762	0.73
10/16/2024 12:00	0.6	1.4	1	0.44	0.21774	0.73
10/16/2024 13:00	0.5	1.3	1	0.43	0.21696	0.72
10/16/2024 14:00	0.5	1.4	0	0.43	0.21672	0.72
10/16/2024 15:00	0.5	1.3	1	0.43	0.21654	0.72
10/16/2024 16:00	0.5	1.3	1	0.43	0.21666	0.72
10/16/2024 17:00	0.5	1.3	0	0.43	0.21672	0.72
10/16/2024 18:00	0.5	1.3	1	0.43	0.21660	0.72
10/16/2024 19:00	0.6	1.3	1	0.43	0.21684	0.72
10/16/2024 20:00	0.6	1.3	1	0.43	0.21696	0.72
10/16/2024 21:00	0.6	1.4	1	0.43	0.21660	0.72
10/16/2024 22:00	0.7	1.3	1	0.43	0.21696	0.72
10/16/2024 23:00	0.7	1.3	1	0.43	0.21678	0.72
Average/Sum#:	0.6	1.3	1	0.44	0.21962	0.73
Minimum:	0.5	1.2	0	0.43	0.21648	0.72
Maximum:	0.8	1.4	1	0.51	0.25260	0.84
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/17/2024 00:00	0.7	1.4	1	0.43	0.21708	0.72
10/17/2024 01:00	0.6	1.4	1	0.43	0.21744	0.72
10/17/2024 02:00	0.6	1.4	1	0.44	0.21768	0.73
10/17/2024 03:00	0.7	1.3	1	0.44	0.21792	0.73
10/17/2024 04:00	0.6	1.3	1	0.44	0.21816	0.73
10/17/2024 05:00	0.6	1.4	1	0.44	0.21870	0.73
10/17/2024 06:00	0.5	1.3	0	0.49	0.24426	0.81
10/17/2024 07:00	0.8	1.4	1	0.44	0.21852	0.73
10/17/2024 08:00	0.9	1.3	1	0.44	0.21810	0.73
10/17/2024 09:00	1.1	2.0	2	0.43	0.21720	0.72
10/17/2024 10:00	0.7	1.1	0	0.46	0.23034	0.77
10/17/2024 11:00	0.7	1.4	1	0.45	0.22362	0.75
10/17/2024 12:00	0.7	1.3	0	0.45	0.22266	0.74
10/17/2024 13:00	0.7	1.4	1	0.45	0.22266	0.74
10/17/2024 14:00	0.7	1.4	1	0.44	0.21966	0.73
10/17/2024 15:00	0.7	1.4	1	0.43	0.21678	0.72
10/17/2024 16:00	0.7	1.3	1	0.46	0.22794	0.76
10/17/2024 17:00	0.7	1.4	1	0.43	0.21720	0.72
10/17/2024 18:00	0.7	1.4	1	0.43	0.21612	0.72
10/17/2024 19:00	0.7	1.4	1	0.43	0.21636	0.72
10/17/2024 20:00	0.7	1.4	1	0.43	0.21600	0.72
10/17/2024 21:00	0.8	1.4	1	0.43	0.21672	0.72
10/17/2024 22:00	0.8	1.4	1	0.44	0.21816	0.73
10/17/2024 23:00	0.8	1.4	1	0.44	0.21882	0.73
Average/Sum#:	0.7	1.4	1	0.44	0.22034	0.73
Minimum:	0.5	1.1	0	0.43	0.21600	0.72
Maximum:	0.9	1.4	2	0.49	0.24426	0.81
%SI	4.17	4.17	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/18/2024 00:00	0.8	1.4	1	0.44	0.21972	0.73
10/18/2024 01:00	0.8	1.4	1	0.44	0.21930	0.73
10/18/2024 02:00	0.8	1.4	1	0.44	0.21876	0.73
10/18/2024 03:00	0.9	1.5	1	0.44	0.21918	0.73
10/18/2024 04:00	0.8	1.4	1	0.44	0.21834	0.73
10/18/2024 05:00	0.8	1.4	1	0.44	0.21846	0.73
10/18/2024 06:00	0.7	1.3	1	0.52	0.25950	0.87
10/18/2024 07:00	0.7	1.3	1	0.47	0.23730	0.79
10/18/2024 08:00	0.7	1.3	1	0.52	0.25890	0.86
10/18/2024 09:00	0.7	1.4	1	0.52	0.25962	0.87
10/18/2024 10:00	0.7	1.3	1	0.46	0.22956	0.77
10/18/2024 11:00	0.7	1.4	1	0.44	0.21804	0.73
10/18/2024 12:00	0.7	1.3	1	0.44	0.21780	0.73
10/18/2024 13:00	0.7	1.4	1	0.44	0.21816	0.73
10/18/2024 14:00	0.7	1.4	1	0.44	0.21810	0.73
10/18/2024 15:00	0.7	1.3	1	0.45	0.22254	0.74
10/18/2024 16:00	0.7	1.3	1	0.47	0.23556	0.79
10/18/2024 17:00	0.7	1.4	1	0.44	0.21936	0.73
10/18/2024 18:00	0.7	1.4	1	0.44	0.21774	0.73
10/18/2024 19:00	0.8	1.4	1	0.44	0.21888	0.73
10/18/2024 20:00	0.8	1.4	1	0.44	0.22158	0.74
10/18/2024 21:00	0.7	1.4	1	0.44	0.22176	0.74
10/18/2024 22:00	0.7	1.4	1	0.44	0.21984	0.73
10/18/2024 23:00	0.7	1.4	1	0.44	0.21996	0.73
Average/Sum#:	0.7	1.4	1	0.45	0.22617	0.76
Minimum:	0.7	1.3	1	0.44	0.21774	0.73
Maximum:	0.9	1.5	1	0.52	0.25962	0.87
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/19/2024 00:00	0.7	1.4	1	0.44	0.22074	0.74
10/19/2024 01:00	0.8	1.4	1	0.44	0.22032	0.73
10/19/2024 02:00	0.8	1.3	1	0.44	0.22020	0.73
10/19/2024 03:00	0.9	1.4	1	0.44	0.21990	0.73
10/19/2024 04:00	0.8	1.4	1	0.44	0.21990	0.73
10/19/2024 05:00	0.8	1.4	1	0.44	0.21984	0.73
10/19/2024 06:00	0.9	1.4	1	0.44	0.22008	0.73
10/19/2024 07:00	0.9	1.4	1	0.44	0.21972	0.73
10/19/2024 08:00	0.8	1.4	1	0.44	0.21984	0.73
10/19/2024 09:00	0.8	1.4	1	0.44	0.21852	0.73
10/19/2024 10:00	0.8	1.4	1	0.44	0.21810	0.73
10/19/2024 11:00	0.7	1.4	1	0.44	0.21828	0.73
10/19/2024 12:00	0.7	1.4	1	0.44	0.21834	0.73
10/19/2024 13:00	0.7	1.4	1	0.44	0.21834	0.73
10/19/2024 14:00	0.7	1.4	1	0.44	0.21852	0.73
10/19/2024 15:00	0.7	1.4	1	0.43	0.21660	0.72
10/19/2024 16:00	0.7	1.3	1	0.45	0.22386	0.75
10/19/2024 17:00	0.7	1.3	1	0.43	0.21678	0.72
10/19/2024 18:00	0.8	1.3	1	0.43	0.21672	0.72
10/19/2024 19:00	0.8	1.3	1	0.44	0.21810	0.73
10/19/2024 20:00	0.9	1.4	1	0.44	0.21780	0.73
10/19/2024 21:00	0.9	1.4	1	0.44	0.21816	0.73
10/19/2024 22:00	0.9	1.4	1	0.44	0.21798	0.73
10/19/2024 23:00	0.9	1.3	1	0.44	0.21750	0.73
Average/Sum#:	0.8	1.4	1	0.44	0.21892	0.73
Minimum:	0.7	1.3	1	0.43	0.21660	0.72
Maximum:	0.9	1.4	1	0.45	0.22386	0.75
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/20/2024 00:00	0.9	1.3	1	0.43	0.21744	0.72
10/20/2024 01:00	0.9	1.4	1	0.44	0.21762	0.73
10/20/2024 02:00	0.9	1.2	1	0.43	0.21744	0.72
10/20/2024 03:00	0.9	1.4	1	0.44	0.21750	0.73
10/20/2024 04:00	0.9	1.3	1	0.44	0.21786	0.73
10/20/2024 05:00	0.9	1.4	1	0.44	0.21858	0.73
10/20/2024 06:00	0.9	1.4	1	0.44	0.21930	0.73
10/20/2024 07:00	0.9	1.4	1	0.44	0.21978	0.73
10/20/2024 08:00	0.8	1.4	1	0.44	0.22026	0.73
10/20/2024 09:00	0.8	1.4	1	0.44	0.21810	0.73
10/20/2024 10:00	0.8	1.4	1	0.44	0.21846	0.73
10/20/2024 11:00	0.7	1.4	1	0.44	0.21954	0.73
10/20/2024 12:00	0.7	1.4	1	0.44	0.21942	0.73
10/20/2024 13:00	0.7	1.4	1	0.44	0.21774	0.73
10/20/2024 14:00	0.7	1.4	1	0.43	0.21744	0.72
10/20/2024 15:00	0.7	1.4	1	0.44	0.21768	0.73
10/20/2024 16:00	0.7	1.3	1	0.45	0.22542	0.75
10/20/2024 17:00	0.7	1.4	1	0.44	0.21822	0.73
10/20/2024 18:00	0.8	1.3	1	0.43	0.21654	0.72
10/20/2024 19:00	0.9	1.3	1	0.43	0.21714	0.72
10/20/2024 20:00	0.9	1.4	1	0.44	0.21846	0.73
10/20/2024 21:00	0.8	1.4	1	0.44	0.21864	0.73
10/20/2024 22:00	0.9	1.4	1	0.44	0.21900	0.73
10/20/2024 23:00	0.9	1.3	1	0.44	0.21888	0.73
Average/Sum#:	0.8	1.4	1	0.44	0.21860	0.73
Minimum:	0.7	1.2	1	0.43	0.21654	0.72
Maximum:	0.9	1.4	1	0.45	0.22542	0.75
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/21/2024 00:00	0.8	1.4	1	0.44	0.21852	0.73
10/21/2024 01:00	0.8	1.4	1	0.44	0.21852	0.73
10/21/2024 02:00	0.8	1.4	1	0.44	0.21786	0.73
10/21/2024 03:00	0.9	1.5	1	0.44	0.21786	0.73
10/21/2024 04:00	0.8	1.3	1	0.44	0.21798	0.73
10/21/2024 05:00	0.8	1.4	1	0.44	0.21852	0.73
10/21/2024 06:00	0.8	1.2	1	0.49	0.24546	0.82
10/21/2024 07:00	0.8	1.3	1	0.45	0.22506	0.75
10/21/2024 08:00	0.9	1.4	0	0.54	0.26760	0.89
10/21/2024 09:00	0.7	1.4	1	0.64	0.31884	1.06
10/21/2024 10:00	0.8	1.4	1	0.50	0.24846	0.83
10/21/2024 11:00	0.7	1.4	1	0.44	0.21816	0.73
10/21/2024 12:00	0.7	1.4	1	0.44	0.21816	0.73
10/21/2024 13:00	0.7	1.4	1	0.54	0.27108	0.90
10/21/2024 14:00	0.5	1.4	1	0.65	0.32478	1.08
10/21/2024 15:00	0.5	1.4	1	0.65	0.32280	1.08
10/21/2024 16:00	0.5	1.4	1	0.66	0.32832	1.09
10/21/2024 17:00	0.6	1.4	1	0.64	0.32070	1.07
10/21/2024 18:00	0.7	1.4	1	0.64	0.31872	1.06
10/21/2024 19:00	0.8	1.4	1	0.64	0.31782	1.06
10/21/2024 20:00	0.9	1.4	1	0.63	0.31728	1.06
10/21/2024 21:00	1.0	1.4	1	0.63	0.31548	1.05
10/21/2024 22:00	1.0	1.4	1	0.60	0.30024	1.00
10/21/2024 23:00	1.0	1.4	1	0.64	0.31830	1.06
Average/Sum#:	0.8	1.4	1	0.54	0.27111	0.90
Minimum:	0.5	1.2	0	0.44	0.21786	0.73
Maximum:	1.0	1.5	1	0.66	0.32832	1.09
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/22/2024 00:00	1.0	1.4	1	0.64	0.31764	1.06
10/22/2024 01:00	1.0	1.4	1	0.63	0.31668	1.06
10/22/2024 02:00	1.0	1.4	1	0.63	0.31590	1.05
10/22/2024 03:00	1.2	1.4	1	0.63	0.31548	1.05
10/22/2024 04:00	1.1	1.4	1	0.63	0.31512	1.05
10/22/2024 05:00	1.1	1.4	1	0.64	0.31770	1.06
10/22/2024 06:00	0.7	1.4	1	0.68	0.33966	1.13
10/22/2024 07:00	0.8	1.4	1	0.67	0.33714	1.12
10/22/2024 08:00	1.1	1.4	1	0.63	0.31626	1.05
10/22/2024 09:00	1.0	1.4	1	0.64	0.31938	1.06
10/22/2024 10:00	1.0	1.4	1	0.63	0.31554	1.05
10/22/2024 11:00	0.8	1.4	1	0.65	0.32424	1.08
10/22/2024 12:00	0.7	1.4	1	0.65	0.32322	1.08
10/22/2024 13:00	0.6	1.4	1	0.64	0.32196	1.07
10/22/2024 14:00	0.6	1.4	1	0.64	0.32244	1.07
10/22/2024 15:00	0.6	1.4	1	0.65	0.32382	1.08
10/22/2024 16:00	0.4	1.4	1	0.68	0.33750	1.13
10/22/2024 17:00	0.6	1.4	1	0.64	0.32190	1.07
10/22/2024 18:00	0.7	1.4	1	0.64	0.31944	1.06
10/22/2024 19:00	0.9	1.4	1	0.63	0.31662	1.06
10/22/2024 20:00	1.1	1.4	1	0.63	0.31506	1.05
10/22/2024 21:00	1.0	1.4	1	0.64	0.32190	1.07
10/22/2024 22:00	1.1	1.4	1	0.64	0.31830	1.06
10/22/2024 23:00	1.2	1.4	1	0.63	0.31698	1.06
Average/Sum#:	0.9	1.4	1	0.64	0.32125	1.07
Minimum:	0.4	1.4	1	0.63	0.31506	1.05
Maximum:	1.2	1.4	1	0.68	0.33966	1.13
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/23/2024 00:00	1.2	1.4	1	0.63	0.31650	1.06
10/23/2024 01:00	1.2	1.4	1	0.63	0.31506	1.05
10/23/2024 02:00	1.3	1.5	1	0.63	0.31386	1.05
10/23/2024 03:00	1.3	1.4	1	0.63	0.31650	1.06
10/23/2024 04:00	1.2	1.4	1	0.63	0.31734	1.06
10/23/2024 05:00	0.9	1.4	1	0.68	0.33786	1.13
10/23/2024 06:00	0.8	1.4	1	0.68	0.34050	1.14
10/23/2024 07:00	1.3	1.4	1	0.62	0.31194	1.04
10/23/2024 08:00	1.1	1.4	1	0.64	0.32088	1.07
10/23/2024 09:00	1.0	1.4	1	0.64	0.31986	1.07
10/23/2024 10:00	0.7	1.4	1	0.65	0.32412	1.08
10/23/2024 11:00	0.6	1.4	1	0.65	0.32616	1.09
10/23/2024 12:00	0.6	1.4	1	0.65	0.32328	1.08
10/23/2024 13:00	0.6	1.4	1	0.65	0.32580	1.09
10/23/2024 14:00	0.6	1.4	1	0.65	0.32412	1.08
10/23/2024 15:00	0.6	1.4	1	0.65	0.32424	1.08
10/23/2024 16:00	0.5	1.4	1	0.67	0.33552	1.12
10/23/2024 17:00	0.6	1.4	1	0.65	0.32472	1.08
10/23/2024 18:00	0.6	1.4	1	0.64	0.32202	1.07
10/23/2024 19:00	0.9	1.4	1	0.64	0.31932	1.06
10/23/2024 20:00	1.1	1.4	1	0.63	0.31584	1.05
10/23/2024 21:00	1.0	1.4	1	0.63	0.31596	1.05
10/23/2024 22:00	1.0	1.4	1	0.63	0.31584	1.05
10/23/2024 23:00	1.0	1.4	1	0.63	0.31728	1.06
Average/Sum#:	0.9	1.4	1	0.64	0.32186	1.07
Minimum:	0.5	1.4	1	0.62	0.31194	1.04
Maximum:	1.3	1.5	1	0.68	0.34050	1.14
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/24/2024 00:00	1.0	1.4	1	0.63	0.31710	1.06
10/24/2024 01:00	1.0	1.4	1	0.63	0.31632	1.05
10/24/2024 02:00	1.1	1.4	1	0.63	0.31572	1.05
10/24/2024 03:00	1.2	1.4	1	0.63	0.31530	1.05
10/24/2024 04:00	1.1	1.4	1	0.63	0.31482	1.05
10/24/2024 05:00	1.1	1.4	1	0.63	0.31452	1.05
10/24/2024 06:00	1.2	1.4	1	0.63	0.31644	1.05
10/24/2024 07:00	1.1	1.4	1	0.63	0.31722	1.06
10/24/2024 08:00	1.1	1.4	1	0.64	0.31872	1.06
10/24/2024 09:00	1.0	1.4	1	0.64	0.31866	1.06
10/24/2024 10:00	0.9	1.4	1	0.64	0.32046	1.07
10/24/2024 11:00	1.0	1.3	1	0.47	0.23316	0.78
10/24/2024 12:00	0.8	1.3	1	0.44	0.22188	0.74
10/24/2024 13:00	0.8	1.4	1	0.44	0.22200	0.74
10/24/2024 14:00	0.8	1.4	0	0.54	0.27228	0.91
10/24/2024 15:00	0.6	1.4	1	0.64	0.32088	1.07
10/24/2024 16:00	0.6	1.4	1	0.65	0.32688	1.09
10/24/2024 17:00	0.6	1.4	1	0.65	0.32424	1.08
10/24/2024 18:00	0.8	1.4	1	0.64	0.32244	1.07
10/24/2024 19:00	0.9	1.4	1	0.64	0.32160	1.07
10/24/2024 20:00	0.8	1.4	1	0.67	0.33372	1.11
10/24/2024 21:00	0.9	1.4	1	0.66	0.32832	1.09
10/24/2024 22:00	1.1	1.4	1	0.64	0.31902	1.06
10/24/2024 23:00	1.2	1.4	1	0.63	0.31728	1.06
Average/Sum#:	0.9	1.4	1	0.61	0.30621	1.02
Minimum:	0.6	1.3	0	0.44	0.22188	0.74
Maximum:	1.2	1.4	1	0.67	0.33372	1.11
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/25/2024 00:00	1.2	1.4	1	0.63	0.31632	1.05
10/25/2024 01:00	1.3	1.4	1	0.63	0.31602	1.05
10/25/2024 02:00	1.4	1.4	1	0.63	0.31584	1.05
10/25/2024 03:00	1.3	1.5	1	0.63	0.31656	1.06
10/25/2024 04:00	1.3	1.4	1	0.63	0.31614	1.05
10/25/2024 05:00	1.2	1.4	1	0.66	0.32784	1.09
10/25/2024 06:00	1.1	1.4	1	0.68	0.33870	1.13
10/25/2024 07:00	1.4	1.4	1	0.64	0.32220	1.07
10/25/2024 08:00	1.1	1.4	1	0.66	0.32898	1.10
10/25/2024 09:00	0.7	1.4	1	0.67	0.33564	1.12
10/25/2024 10:00	0.9	1.4	1	0.64	0.32154	1.07
10/25/2024 11:00	0.7	1.4	1	0.65	0.32442	1.08
10/25/2024 12:00	0.7	1.4	1	0.64	0.32028	1.07
10/25/2024 13:00	0.9	1.4	1	0.50	0.24840	0.83
10/25/2024 14:00	0.9	1.3	1	0.45	0.22302	0.74
10/25/2024 15:00	0.8	1.3	1	0.46	0.23058	0.77
10/25/2024 16:00	1.1	1.4	1	0.48	0.24216	0.81
10/25/2024 17:00	1.0	1.3	1	0.44	0.21786	0.73
10/25/2024 18:00	1.0	1.4	1	0.44	0.21942	0.73
10/25/2024 19:00	1.0	1.3	1	0.46	0.22782	0.76
10/25/2024 20:00	1.1	1.4	1	0.44	0.21852	0.73
10/25/2024 21:00	1.0	1.4	1	0.44	0.21846	0.73
10/25/2024 22:00	1.0	1.4	1	0.44	0.21900	0.73
10/25/2024 23:00	1.0	1.4	1	0.44	0.21894	0.73
Average/Sum#:	1.0	1.4	1	0.56	0.27853	0.93
Minimum:	0.7	1.3	1	0.44	0.21786	0.73
Maximum:	1.4	1.5	1	0.68	0.33870	1.13
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/26/2024 00:00	1.0	1.4	1	0.44	0.21876	0.73
10/26/2024 01:00	1.0	1.4	1	0.44	0.21876	0.73
10/26/2024 02:00	1.0	1.3	1	0.44	0.21834	0.73
10/26/2024 03:00	1.0	1.4	1	0.44	0.21960	0.73
10/26/2024 04:00	0.9	1.4	1	0.44	0.21906	0.73
10/26/2024 05:00	1.0	1.4	1	0.44	0.21852	0.73
10/26/2024 06:00	1.0	1.3	1	0.44	0.21804	0.73
10/26/2024 07:00	1.1	1.4	1	0.44	0.21906	0.73
10/26/2024 08:00	1.0	1.4	1	0.44	0.21996	0.73
10/26/2024 09:00	0.9	1.4	1	0.44	0.21846	0.73
10/26/2024 10:00	0.9	1.4	1	0.44	0.21846	0.73
10/26/2024 11:00	0.8	1.4	1	0.44	0.21942	0.73
10/26/2024 12:00	0.7	1.4	1	0.44	0.21990	0.73
10/26/2024 13:00	0.7	1.3	1	0.44	0.21978	0.73
10/26/2024 14:00	0.7	1.4	1	0.44	0.21978	0.73
10/26/2024 15:00	0.7	1.4	1	0.44	0.21978	0.73
10/26/2024 16:00	0.8	1.3	1	0.44	0.21894	0.73
10/26/2024 17:00	0.8	1.3	1	0.44	0.21870	0.73
10/26/2024 18:00	0.9	1.4	1	0.44	0.21882	0.73
10/26/2024 19:00	0.9	1.4	1	0.44	0.21954	0.73
10/26/2024 20:00	0.9	1.4	1	0.44	0.21954	0.73
10/26/2024 21:00	0.9	1.4	1	0.44	0.21966	0.73
10/26/2024 22:00	0.9	1.4	1	0.44	0.21966	0.73
10/26/2024 23:00	0.9	1.3	1	0.44	0.21930	0.73
Average/Sum#:	0.9	1.4	1	0.44	0.21916	0.73
Minimum:	0.7	1.3	1	0.44	0.21804	0.73
Maximum:	1.1	1.4	1	0.44	0.21996	0.73
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/27/2024 00:00	0.8	1.4	1	0.44	0.21990	0.73
10/27/2024 01:00	0.8	1.4	1	0.44	0.22014	0.73
10/27/2024 02:00	0.8	1.4	1	0.44	0.22032	0.73
10/27/2024 03:00	0.9	1.4	1	0.44	0.21996	0.73
10/27/2024 04:00	0.9	1.3	1	0.44	0.22026	0.73
10/27/2024 05:00	0.9	1.3	1	0.44	0.21960	0.73
10/27/2024 06:00	0.9	1.3	1	0.44	0.21960	0.73
10/27/2024 07:00	0.9	1.4	1	0.44	0.21948	0.73
10/27/2024 08:00	0.8	1.3	1	0.44	0.21966	0.73
10/27/2024 09:00	0.8	1.3	1	0.44	0.22008	0.73
10/27/2024 10:00	0.8	1.3	1	0.44	0.22044	0.73
10/27/2024 11:00	0.7	1.3	1	0.44	0.22080	0.74
10/27/2024 12:00	0.7	1.3	1	0.44	0.22068	0.74
10/27/2024 13:00	0.7	1.3	1	0.44	0.21846	0.73
10/27/2024 14:00	0.7	1.3	1	0.44	0.21810	0.73
10/27/2024 15:00	0.7	1.3	0	0.45	0.22560	0.75
10/27/2024 16:00	0.7	1.3	1	0.44	0.21822	0.73
10/27/2024 17:00	0.7	1.3	0	0.44	0.21816	0.73
10/27/2024 18:00	0.7	1.3	1	0.44	0.21840	0.73
10/27/2024 19:00	0.7	1.4	1	0.44	0.21906	0.73
10/27/2024 20:00	0.7	1.4	1	0.44	0.22032	0.73
10/27/2024 21:00	0.7	1.3	1	0.44	0.22038	0.73
10/27/2024 22:00	0.8	1.3	1	0.44	0.22014	0.73
10/27/2024 23:00	0.8	1.3	1	0.44	0.21978	0.73
Average/Sum#:	0.8	1.3	1	0.44	0.21990	0.73
Minimum:	0.7	1.3	0	0.44	0.21810	0.73
Maximum:	0.9	1.4	1	0.45	0.22560	0.75
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/28/2024 00:00	0.8	1.4	1	0.44	0.21966	0.73
10/28/2024 01:00	0.8	1.4	1	0.44	0.21966	0.73
10/28/2024 02:00	0.9	1.4	1	0.44	0.21942	0.73
10/28/2024 03:00	0.9	1.4	1	0.44	0.21894	0.73
10/28/2024 04:00	0.9	1.4	1	0.44	0.21870	0.73
10/28/2024 05:00	0.8	1.3	0	0.50	0.25206	0.84
10/28/2024 06:00	0.8	1.3	1	0.54	0.26982	0.90
10/28/2024 07:00	0.8	1.3	1	0.51	0.25392	0.85
10/28/2024 08:00	0.8	1.3	0	0.51	0.25530	0.85
10/28/2024 09:00	0.9	1.4	1	0.59	0.29454	0.98
10/28/2024 10:00	0.9	1.3	1	0.60	0.30240	1.01
10/28/2024 11:00	0.8	1.2	0	0.44	0.21960	0.73
10/28/2024 12:00	0.8	1.4	1	0.44	0.22050	0.74
10/28/2024 13:00	0.8	1.3	1	0.44	0.22080	0.74
10/28/2024 14:00	0.7	1.3	1	0.44	0.22050	0.74
10/28/2024 15:00	0.8	1.3	1	0.55	0.27462	0.92
10/28/2024 16:00	0.8	1.4	1	0.64	0.32184	1.07
10/28/2024 17:00	0.8	1.4	1	0.63	0.31746	1.06
10/28/2024 18:00	1.0	1.4	1	0.63	0.31470	1.05
10/28/2024 19:00	1.1	1.4	1	0.63	0.31344	1.04
10/28/2024 20:00	1.2	1.4	1	0.62	0.31224	1.04
10/28/2024 21:00	1.2	1.4	1	0.63	0.31278	1.04
10/28/2024 22:00	1.2	1.4	1	0.63	0.31320	1.04
10/28/2024 23:00	1.2	1.4	1	0.63	0.31266	1.04
Average/Sum#:	0.9	1.4	1	0.53	0.26662	0.89
Minimum:	0.7	1.2	0	0.44	0.21870	0.73
Maximum:	1.2	1.4	1	0.64	0.32184	1.07
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/29/2024 00:00	1.2	1.4	1	0.62	0.31194	1.04
10/29/2024 01:00	1.3	1.4	1	0.62	0.31146	1.04
10/29/2024 02:00	1.3	1.4	1	0.63	0.31374	1.05
10/29/2024 03:00	1.3	1.4	1	0.63	0.31398	1.05
10/29/2024 04:00	1.3	1.4	1	0.63	0.31386	1.05
10/29/2024 05:00	1.3	1.4	1	0.63	0.31344	1.04
10/29/2024 06:00	1.4	1.4	1	0.63	0.31278	1.04
10/29/2024 07:00	1.3	1.4	1	0.63	0.31314	1.04
10/29/2024 08:00	1.2	1.4	1	0.63	0.31470	1.05
10/29/2024 09:00	0.9	1.3	1	0.46	0.23220	0.77
10/29/2024 10:00	0.0	0.0	0	0.17	0.08610	0.29
10/29/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
10/29/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
10/29/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
10/29/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
10/29/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
10/29/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
10/29/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
10/29/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
10/29/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
10/29/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
10/29/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
10/29/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
10/29/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	1.1	1.3	1	0.57	0.28521	0.95
Minimum:	0.0	0.0	1	0.17	0.08610	0.29
Maximum:	1.4	1.4	1	0.63	0.31470	1.05
%SI	54.17	54.17	58.33	54.17	54.17	54.17

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/30/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
10/30/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
10/31/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
10/31/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/01/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
11/01/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/02/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
11/02/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/03/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
11/03/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/04/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
11/04/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/05/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
11/05/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/06/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
11/06/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
11/06/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
11/06/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
11/06/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
11/06/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
11/06/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
11/06/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
11/06/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
11/06/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
11/06/2024 10:00	0.0	0.0	0	0.36	0.18120	0.60
11/06/2024 11:00	0.6	1.4	1	0.46	0.23040	0.77
11/06/2024 12:00	0.7	1.3	1	0.46	0.22920	0.76
11/06/2024 13:00	0.6	1.3	1	0.44	0.22092	0.74
11/06/2024 14:00	0.6	1.4	1	0.44	0.22152	0.74
11/06/2024 15:00	0.6	1.3	1	0.46	0.23010	0.77
11/06/2024 16:00	0.6	1.2	1	0.51	0.25710	0.86
11/06/2024 17:00	0.6	1.4	1	0.44	0.22248	0.74
11/06/2024 18:00	0.6	1.4	1	0.44	0.22080	0.74
11/06/2024 19:00	0.6	1.4	1	0.44	0.22134	0.74
11/06/2024 20:00	0.7	1.4	1	0.46	0.22914	0.76
11/06/2024 21:00	0.7	1.4	1	0.45	0.22260	0.74
11/06/2024 22:00	0.7	1.4	2	0.45	0.22326	0.74
11/06/2024 23:00	0.8	1.4	2	0.45	0.22362	0.75
Average/Sum#:	0.6	1.3	1	0.45	0.22383	0.75
Minimum:	0.0	0.0	1	0.36	0.18120	0.60
Maximum:	0.8	1.4	2	0.51	0.25710	0.86
%SI	41.67	41.67	45.83	41.67	41.67	41.67

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/07/2024 00:00	0.9	1.4	2	0.45	0.22428	0.75
11/07/2024 01:00	0.9	1.4	2	0.45	0.22392	0.75
11/07/2024 02:00	0.8	1.3	1	0.45	0.22350	0.75
11/07/2024 03:00	0.8	1.3	2	0.45	0.22386	0.75
11/07/2024 04:00	0.8	1.4	2	0.45	0.22284	0.74
11/07/2024 05:00	0.7	1.4	1	0.53	0.26436	0.88
11/07/2024 06:00	0.7	1.4	1	0.57	0.28704	0.96
11/07/2024 07:00	0.7	1.3	2	0.52	0.25974	0.87
11/07/2024 08:00	0.7	1.4	2	0.45	0.22398	0.75
11/07/2024 09:00	0.7	1.4	2	0.45	0.22374	0.75
11/07/2024 10:00	0.7	1.4	1	0.45	0.22356	0.75
11/07/2024 11:00	0.6	1.4	1	0.45	0.22374	0.75
11/07/2024 12:00	0.6	1.3	1	0.44	0.22164	0.74
11/07/2024 13:00	0.6	1.4	1	0.44	0.22176	0.74
11/07/2024 14:00	0.6	1.3	1	0.46	0.22812	0.76
11/07/2024 15:00	0.6	1.3	0	0.49	0.24288	0.81
11/07/2024 16:00	0.6	1.3	0	0.54	0.26850	0.90
11/07/2024 17:00	0.6	1.4	0	0.55	0.27360	0.91
11/07/2024 18:00	0.7	1.3	0	0.55	0.27318	0.91
11/07/2024 19:00	0.8	1.3	1	0.55	0.27258	0.91
11/07/2024 20:00	0.8	1.3	1	0.55	0.27378	0.91
11/07/2024 21:00	0.7	1.3	1	0.55	0.27426	0.91
11/07/2024 22:00	0.7	1.3	1	0.55	0.27420	0.91
11/07/2024 23:00	0.6	1.4	1	0.55	0.27432	0.91
Average/Sum#:	0.7	1.4	1	0.50	0.24681	0.82
Minimum:	0.6	1.3	0	0.44	0.22164	0.74
Maximum:	0.9	1.4	2	0.57	0.28704	0.96
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/08/2024 00:00	0.7	1.3	1	0.55	0.27558	0.92
11/08/2024 01:00	0.6	1.4	1	0.55	0.27540	0.92
11/08/2024 02:00	0.6	1.3	1	0.55	0.27540	0.92
11/08/2024 03:00	0.7	1.4	1	0.55	0.27552	0.92
11/08/2024 04:00	0.6	1.3	1	0.55	0.27570	0.92
11/08/2024 05:00	0.6	1.3	1	0.55	0.27594	0.92
11/08/2024 06:00	0.6	1.4	1	0.55	0.27594	0.92
11/08/2024 07:00	0.7	1.4	1	0.49	0.24444	0.81
11/08/2024 08:00	0.8	1.4	1	0.45	0.22386	0.75
11/08/2024 09:00	0.7	1.3	1	0.47	0.23250	0.78
11/08/2024 10:00	0.7	1.4	1	0.45	0.22380	0.75
11/08/2024 11:00	0.7	1.4	1	0.45	0.22254	0.74
11/08/2024 12:00	0.6	1.4	1	0.44	0.22152	0.74
11/08/2024 13:00	0.7	1.3	1	0.44	0.22146	0.74
11/08/2024 14:00	0.6	1.3	1	0.44	0.22128	0.74
11/08/2024 15:00	0.7	1.3	1	0.48	0.23916	0.80
11/08/2024 16:00	0.7	1.3	0	0.52	0.26058	0.87
11/08/2024 17:00	0.7	1.4	0	0.56	0.28218	0.94
11/08/2024 18:00	0.9	1.4	1	0.50	0.25158	0.84
11/08/2024 19:00	1.4	1.3	1	0.53	0.26280	0.88
11/08/2024 20:00	0.9	1.3	1	0.55	0.27348	0.91
11/08/2024 21:00	0.9	1.2	1	0.55	0.27360	0.91
11/08/2024 22:00	0.8	1.3	1	0.55	0.27264	0.91
11/08/2024 23:00	0.8	1.3	1	0.55	0.27330	0.91
Average/Sum#:	0.7	1.3	1	0.51	0.25543	0.85
Minimum:	0.6	1.2	0	0.44	0.22128	0.74
Maximum:	1.4	1.4	1	0.56	0.28218	0.94
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/09/2024 00:00	0.8	1.3	1	0.55	0.27342	0.91
11/09/2024 01:00	0.9	1.4	1	0.46	0.23094	0.77
11/09/2024 02:00	0.8	1.5	1	0.47	0.23436	0.78
11/09/2024 03:00	0.9	1.5	2	0.44	0.22044	0.73
11/09/2024 04:00	0.7	1.3	1	0.50	0.25128	0.84
11/09/2024 05:00	0.8	1.3	1	0.49	0.24312	0.81
11/09/2024 06:00	0.8	1.4	1	0.53	0.26250	0.88
11/09/2024 07:00	0.9	1.4	2	0.47	0.23364	0.78
11/09/2024 08:00	0.9	1.4	2	0.45	0.22326	0.74
11/09/2024 09:00	0.8	1.4	1	0.46	0.22770	0.76
11/09/2024 10:00	0.8	1.4	1	0.45	0.22458	0.75
11/09/2024 11:00	0.7	1.3	1	0.45	0.22278	0.74
11/09/2024 12:00	0.7	1.4	1	0.44	0.22224	0.74
11/09/2024 13:00	0.7	1.4	1	0.44	0.22224	0.74
11/09/2024 14:00	0.6	1.4	1	0.44	0.22248	0.74
11/09/2024 15:00	0.7	1.3	1	0.48	0.24090	0.80
11/09/2024 16:00	0.7	1.3	1	0.52	0.25854	0.86
11/09/2024 17:00	0.6	1.4	0	0.55	0.27576	0.92
11/09/2024 18:00	0.7	1.4	1	0.55	0.27732	0.92
11/09/2024 19:00	0.9	1.3	1	0.53	0.26388	0.88
11/09/2024 20:00	0.9	1.3	1	0.56	0.27990	0.93
11/09/2024 21:00	0.9	1.4	1	0.56	0.28122	0.94
11/09/2024 22:00	0.9	1.4	1	0.57	0.28320	0.94
11/09/2024 23:00	0.8	1.3	1	0.51	0.25692	0.86
Average/Sum#:	0.8	1.4	1	0.49	0.24719	0.82
Minimum:	0.6	1.3	0	0.44	0.22044	0.73
Maximum:	0.9	1.5	2	0.57	0.28320	0.94
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/10/2024 00:00	1.7	1.4	1	0.62	0.31146	1.04
11/10/2024 01:00	1.2	1.4	1	0.63	0.31710	1.06
11/10/2024 02:00	1.2	1.3	1	0.63	0.31746	1.06
11/10/2024 03:00	1.3	1.4	1	0.63	0.31674	1.06
11/10/2024 04:00	1.2	1.4	1	0.63	0.31656	1.06
11/10/2024 05:00	1.2	1.4	1	0.63	0.31644	1.05
11/10/2024 06:00	1.3	1.4	1	0.63	0.31548	1.05
11/10/2024 07:00	1.3	1.4	1	0.63	0.31386	1.05
11/10/2024 08:00	1.1	1.4	1	0.47	0.23508	0.78
11/10/2024 09:00	0.9	1.4	1	0.45	0.22416	0.75
11/10/2024 10:00	0.8	1.4	1	0.45	0.22428	0.75
11/10/2024 11:00	0.9	1.4	1	0.44	0.22104	0.74
11/10/2024 12:00	0.7	1.3	1	0.44	0.22188	0.74
11/10/2024 13:00	0.7	1.4	1	0.44	0.22224	0.74
11/10/2024 14:00	0.9	1.4	1	0.52	0.25974	0.87
11/10/2024 15:00	0.8	1.4	1	0.64	0.32214	1.07
11/10/2024 16:00	0.7	1.4	1	0.66	0.32802	1.09
11/10/2024 17:00	1.0	1.4	1	0.63	0.31704	1.06
11/10/2024 18:00	1.1	1.4	1	0.63	0.31614	1.05
11/10/2024 19:00	1.1	1.4	1	0.63	0.31572	1.05
11/10/2024 20:00	0.9	1.4	1	0.64	0.32106	1.07
11/10/2024 21:00	1.1	1.4	1	0.64	0.31770	1.06
11/10/2024 22:00	1.1	1.4	1	0.63	0.31542	1.05
11/10/2024 23:00	1.1	1.4	1	0.63	0.31482	1.05
Average/Sum#:	1.1	1.4	1	0.58	0.29173	0.97
Minimum:	0.7	1.3	1	0.44	0.22104	0.74
Maximum:	1.7	1.4	1	0.66	0.32802	1.09
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/11/2024 00:00	1.1	1.4	1	0.63	0.31410	1.05
11/11/2024 01:00	1.1	1.4	1	0.63	0.31584	1.05
11/11/2024 02:00	1.0	1.5	1	0.64	0.31848	1.06
11/11/2024 03:00	1.0	1.5	1	0.64	0.31944	1.06
11/11/2024 04:00	0.9	1.4	1	0.64	0.32004	1.07
11/11/2024 05:00	0.9	1.4	1	0.64	0.32064	1.07
11/11/2024 06:00	0.7	1.4	1	0.66	0.32982	1.10
11/11/2024 07:00	1.0	1.4	1	0.64	0.31770	1.06
11/11/2024 08:00	0.9	1.4	1	0.65	0.32280	1.08
11/11/2024 09:00	0.8	1.4	1	0.66	0.32988	1.10
11/11/2024 10:00	1.1	1.4	1	0.63	0.31716	1.06
11/11/2024 11:00	1.0	1.4	1	0.64	0.31914	1.06
11/11/2024 12:00	1.1	1.4	1	0.63	0.31566	1.05
11/11/2024 13:00	1.1	1.4	1	0.63	0.31518	1.05
11/11/2024 14:00	1.0	1.4	1	0.63	0.31728	1.06
11/11/2024 15:00	0.9	1.4	1	0.63	0.31734	1.06
11/11/2024 16:00	0.9	1.4	1	0.64	0.31890	1.06
11/11/2024 17:00	1.0	1.4	1	0.63	0.31692	1.06
11/11/2024 18:00	1.0	1.4	1	0.63	0.31632	1.05
11/11/2024 19:00	1.0	1.4	1	0.64	0.31848	1.06
11/11/2024 20:00	1.0	1.4	1	0.64	0.31878	1.06
11/11/2024 21:00	1.1	1.4	1	0.64	0.31776	1.06
11/11/2024 22:00	1.1	1.4	1	0.63	0.31734	1.06
11/11/2024 23:00	1.1	1.4	1	0.63	0.31608	1.05
Average/Sum#:	1.0	1.4	1	0.64	0.31880	1.06
Minimum:	0.7	1.4	1	0.63	0.31410	1.05
Maximum:	1.1	1.5	1	0.66	0.32988	1.10
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/12/2024 00:00	1.1	1.4	1	0.63	0.31506	1.05
11/12/2024 01:00	1.2	1.4	1	0.63	0.31440	1.05
11/12/2024 02:00	1.2	1.4	1	0.63	0.31404	1.05
11/12/2024 03:00	1.3	1.4	1	0.63	0.31392	1.05
11/12/2024 04:00	1.2	1.4	1	0.63	0.31380	1.05
11/12/2024 05:00	1.2	1.4	1	0.63	0.31380	1.05
11/12/2024 06:00	1.3	1.4	1	0.62	0.31224	1.04
11/12/2024 07:00	1.2	1.4	1	0.62	0.31194	1.04
11/12/2024 08:00	1.2	1.4	1	0.63	0.31284	1.04
11/12/2024 09:00	1.1	1.4	1	0.63	0.31482	1.05
11/12/2024 10:00	1.0	1.4	1	0.63	0.31566	1.05
11/12/2024 11:00	0.8	1.4	1	0.47	0.23628	0.79
11/12/2024 12:00	0.8	1.4	1	0.44	0.22164	0.74
11/12/2024 13:00	0.9	1.4	1	0.44	0.22134	0.74
11/12/2024 14:00	0.8	1.4	1	0.44	0.22110	0.74
11/12/2024 15:00	0.8	1.3	1	0.51	0.25434	0.85
11/12/2024 16:00	0.6	1.5	1	0.67	0.33690	1.12
11/12/2024 17:00	0.9	1.4	1	0.63	0.31494	1.05
11/12/2024 18:00	1.1	1.4	1	0.63	0.31368	1.05
11/12/2024 19:00	1.1	1.4	1	0.62	0.31218	1.04
11/12/2024 20:00	1.2	1.4	1	0.62	0.31152	1.04
11/12/2024 21:00	1.2	1.4	1	0.62	0.31146	1.04
11/12/2024 22:00	1.2	1.4	1	0.62	0.31116	1.04
11/12/2024 23:00	1.3	1.4	1	0.62	0.31086	1.04
Average/Sum#:	1.1	1.4	1	0.59	0.29708	0.99
Minimum:	0.6	1.3	1	0.44	0.22110	0.74
Maximum:	1.3	1.5	1	0.67	0.33690	1.12
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/13/2024 00:00	1.2	1.4	1	0.62	0.31218	1.04
11/13/2024 01:00	1.2	1.4	1	0.63	0.31392	1.05
11/13/2024 02:00	1.2	1.5	1	0.63	0.31470	1.05
11/13/2024 03:00	1.2	1.4	1	0.63	0.31542	1.05
11/13/2024 04:00	1.2	1.4	1	0.63	0.31536	1.05
11/13/2024 05:00	1.1	1.4	1	0.65	0.32358	1.08
11/13/2024 06:00	0.5	1.5	2	0.71	0.35400	1.18
11/13/2024 07:00	1.2	1.4	1	0.63	0.31404	1.05
11/13/2024 08:00	0.7	1.5	1	0.68	0.33834	1.13
11/13/2024 09:00	1.1	1.4	1	0.63	0.31734	1.06
11/13/2024 10:00	1.0	1.3	1	0.56	0.27810	0.93
11/13/2024 11:00	0.8	1.4	1	0.44	0.22098	0.74
11/13/2024 12:00	1.2	1.4	1	0.52	0.25932	0.86
11/13/2024 13:00	0.5	1.5	1	0.70	0.34884	1.16
11/13/2024 14:00	0.4	1.5	2	0.71	0.35640	1.19
11/13/2024 15:00	0.5	1.5	2	0.70	0.35172	1.17
11/13/2024 16:00	0.7	1.4	1	0.66	0.33018	1.10
11/13/2024 17:00	0.8	1.4	1	0.65	0.32250	1.08
11/13/2024 18:00	1.0	1.4	1	0.63	0.31494	1.05
11/13/2024 19:00	0.9	1.4	1	0.64	0.32178	1.07
11/13/2024 20:00	1.0	1.4	1	0.64	0.31758	1.06
11/13/2024 21:00	1.0	1.4	1	0.64	0.31800	1.06
11/13/2024 22:00	1.1	1.4	1	0.63	0.31500	1.05
11/13/2024 23:00	1.1	1.4	1	0.63	0.31380	1.05
Average/Sum#:	0.9	1.4	1	0.63	0.31617	1.05
Minimum:	0.4	1.3	1	0.44	0.22098	0.74
Maximum:	1.2	1.5	2	0.71	0.35640	1.19
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/14/2024 00:00	1.2	1.4	1	0.63	0.31302	1.04
11/14/2024 01:00	1.1	1.4	1	0.63	0.31692	1.06
11/14/2024 02:00	1.1	1.4	1	0.63	0.31740	1.06
11/14/2024 03:00	0.9	1.5	2	0.66	0.33078	1.10
11/14/2024 04:00	0.4	1.5	2	0.73	0.36570	1.22
11/14/2024 05:00	0.3	1.5	2	0.77	0.38652	1.29
11/14/2024 06:00	0.3	1.5	3	0.80	0.39936	1.33
11/14/2024 07:00	1.0	1.4	1	0.65	0.32340	1.08
11/14/2024 08:00	1.0	1.4	1	0.63	0.31710	1.06
11/14/2024 09:00	0.9	1.4	1	0.56	0.27756	0.93
11/14/2024 10:00	0.8	1.4	1	0.44	0.22134	0.74
11/14/2024 11:00	0.7	1.5	1	0.44	0.22134	0.74
11/14/2024 12:00	0.7	1.3	1	0.44	0.22122	0.74
11/14/2024 13:00	0.7	1.4	1	0.44	0.22152	0.74
11/14/2024 14:00	0.7	1.4	1	0.44	0.22146	0.74
11/14/2024 15:00	1.1	1.4	1	0.52	0.25986	0.87
11/14/2024 16:00	0.7	1.4	1	0.65	0.32256	1.08
11/14/2024 17:00	0.8	1.4	1	0.64	0.32028	1.07
11/14/2024 18:00	0.9	1.4	1	0.64	0.32022	1.07
11/14/2024 19:00	0.9	1.4	1	0.64	0.32022	1.07
11/14/2024 20:00	0.9	1.4	1	0.65	0.32370	1.08
11/14/2024 21:00	1.0	1.4	1	0.64	0.31974	1.07
11/14/2024 22:00	1.0	1.4	1	0.64	0.31956	1.07
11/14/2024 23:00	1.1	1.4	1	0.64	0.31890	1.06
Average/Sum#:	0.8	1.4	1	0.61	0.30332	1.01
Minimum:	0.3	1.3	1	0.44	0.22122	0.74
Maximum:	1.2	1.5	3	0.80	0.39936	1.33
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/15/2024 00:00	1.1	1.4	1	0.64	0.31854	1.06
11/15/2024 01:00	1.0	1.4	1	0.64	0.31920	1.06
11/15/2024 02:00	1.1	1.4	1	0.64	0.31788	1.06
11/15/2024 03:00	1.1	1.4	1	0.63	0.31710	1.06
11/15/2024 04:00	1.1	1.4	1	0.63	0.31686	1.06
11/15/2024 05:00	0.9	1.4	1	0.65	0.32466	1.08
11/15/2024 06:00	0.8	1.4	2	0.67	0.33348	1.11
11/15/2024 07:00	0.4	1.5	2	0.72	0.36174	1.21
11/15/2024 08:00	0.7	1.5	1	0.67	0.33444	1.11
11/15/2024 09:00	1.0	1.4	1	0.64	0.31776	1.06
11/15/2024 10:00	0.9	1.5	1	0.64	0.31752	1.06
11/15/2024 11:00	0.7	1.4	1	0.56	0.28080	0.94
11/15/2024 12:00	0.6	1.4	1	0.56	0.27972	0.93
11/15/2024 13:00	0.6	1.4	1	0.56	0.27918	0.93
11/15/2024 14:00	1.7	1.4	1	0.57	0.28356	0.95
11/15/2024 15:00	1.4	1.5	1	0.57	0.28302	0.94
11/15/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
11/15/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
11/15/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
11/15/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
11/15/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
11/15/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
11/15/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
11/15/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.9	1.4	1	0.62	0.31159	1.04
Minimum:	0.4	1.4	1	0.56	0.27918	0.93
Maximum:	1.7	1.5	2	0.72	0.36174	1.21
%SI	33.33	33.33	33.33	33.33	33.33	33.33

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/16/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/17/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/18/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/19/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/20/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 16:00	0.0	0.0	0	0.21	0.10452	0.35
11/20/2024 17:00	0.8	1.4	2	0.44	0.22140	0.74
11/20/2024 18:00	0.0	1.2	2	0.39	0.19512	0.65
11/20/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.3	0.9	2	0.35	0.17368	0.58
Minimum:	0.0	0.0	2	0.21	0.10452	0.35
Maximum:	0.8	1.4	2	0.44	0.22140	0.74
%SI	87.50	87.50	91.67	87.50	87.50	87.50

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/21/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 23:00	0.0	0.0	0	0.11	0.05676	0.19
Average/Sum#:	0.0	0.0	0	0.11	0.05676	0.19
Minimum:	0.0	0.0	0	0.11	0.05676	0.19
Maximum:	0.0	0.0	0	0.11	0.05676	0.19
%SI	95.83	95.83	100.00	95.83	95.83	95.83

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/22/2024 00:00	0.0	0.0	0	0.45	0.22278	0.74
11/22/2024 01:00	0.6	1.4	1	0.56	0.28224	0.94
11/22/2024 02:00	0.8	1.4	1	0.50	0.24912	0.83
11/22/2024 03:00	0.8	1.4	1	0.45	0.22602	0.75
11/22/2024 04:00	0.7	1.3	1	0.45	0.22272	0.74
11/22/2024 05:00	1.1	1.3	1	0.51	0.25566	0.85
11/22/2024 06:00	2.2	1.4	1	0.59	0.29610	0.99
11/22/2024 07:00	1.4	1.4	1	0.59	0.29718	0.99
11/22/2024 08:00	1.4	1.3	1	0.59	0.29652	0.99
11/22/2024 09:00	1.3	1.4	1	0.59	0.29682	0.99
11/22/2024 10:00	1.2	1.3	1	0.62	0.30828	1.03
11/22/2024 11:00	0.9	1.4	1	0.65	0.32268	1.08
11/22/2024 12:00	1.1	1.4	1	0.63	0.31374	1.05
11/22/2024 13:00	1.0	1.4	1	0.65	0.32310	1.08
11/22/2024 14:00	0.6	1.4	1	0.67	0.33654	1.12
11/22/2024 15:00	0.8	1.4	1	0.66	0.32766	1.09
11/22/2024 16:00	1.0	1.4	1	0.63	0.31734	1.06
11/22/2024 17:00	0.9	1.4	1	0.65	0.32382	1.08
11/22/2024 18:00	1.1	1.4	1	0.63	0.31260	1.04
11/22/2024 19:00	1.0	1.4	1	0.63	0.31458	1.05
11/22/2024 20:00	1.0	1.4	1	0.63	0.31476	1.05
11/22/2024 21:00	1.1	1.4	1	0.63	0.31314	1.04
11/22/2024 22:00	1.2	1.4	1	0.63	0.31326	1.04
11/22/2024 23:00	1.2	1.4	1	0.63	0.31278	1.04
Average/Sum#:	1.0	1.3	1	0.59	0.29581	0.99
Minimum:	0.0	0.0	1	0.45	0.22272	0.74
Maximum:	2.2	1.4	1	0.67	0.33654	1.12
%SI	0.00	0.00	4.17	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/23/2024 00:00	1.2	1.4	1	0.62	0.31188	1.04
11/23/2024 01:00	1.1	1.4	1	0.62	0.31224	1.04
11/23/2024 02:00	1.2	1.4	1	0.62	0.31092	1.04
11/23/2024 03:00	1.2	1.4	1	0.62	0.31110	1.04
11/23/2024 04:00	1.2	1.4	1	0.62	0.31074	1.04
11/23/2024 05:00	1.1	1.4	1	0.62	0.31044	1.03
11/23/2024 06:00	1.1	1.4	1	0.62	0.30990	1.03
11/23/2024 07:00	1.0	1.3	1	0.54	0.27168	0.91
11/23/2024 08:00	0.8	1.3	1	0.44	0.22056	0.74
11/23/2024 09:00	0.8	1.4	1	0.44	0.22026	0.73
11/23/2024 10:00	0.8	1.3	1	0.44	0.22026	0.73
11/23/2024 11:00	0.8	1.3	1	0.44	0.22080	0.74
11/23/2024 12:00	0.8	1.3	1	0.44	0.22038	0.73
11/23/2024 13:00	0.7	1.3	1	0.44	0.22032	0.73
11/23/2024 14:00	0.7	1.4	1	0.44	0.22020	0.73
11/23/2024 15:00	0.7	1.4	1	0.44	0.22092	0.74
11/23/2024 16:00	1.4	1.4	1	0.52	0.26040	0.87
11/23/2024 17:00	1.2	1.4	1	0.63	0.31506	1.05
11/23/2024 18:00	1.2	1.4	1	0.62	0.31122	1.04
11/23/2024 19:00	1.2	1.4	1	0.62	0.30942	1.03
11/23/2024 20:00	1.2	1.4	1	0.62	0.30930	1.03
11/23/2024 21:00	1.2	1.4	1	0.62	0.30948	1.03
11/23/2024 22:00	1.3	1.4	1	0.63	0.31272	1.04
11/23/2024 23:00	1.2	1.4	1	0.63	0.31314	1.04
Average/Sum#:	1.0	1.4	1	0.55	0.27722	0.92
Minimum:	0.7	1.3	1	0.44	0.22020	0.73
Maximum:	1.4	1.4	1	0.63	0.31506	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/24/2024 00:00	1.2	1.4	1	0.63	0.31314	1.04
11/24/2024 01:00	1.2	1.4	1	0.63	0.31368	1.05
11/24/2024 02:00	1.2	1.4	1	0.63	0.31308	1.04
11/24/2024 03:00	1.3	1.4	1	0.63	0.31296	1.04
11/24/2024 04:00	1.2	1.4	1	0.62	0.31236	1.04
11/24/2024 05:00	1.3	1.4	1	0.62	0.31134	1.04
11/24/2024 06:00	1.3	1.4	1	0.62	0.31104	1.04
11/24/2024 07:00	1.3	1.4	1	0.62	0.31080	1.04
11/24/2024 08:00	1.3	1.4	1	0.62	0.31062	1.04
11/24/2024 09:00	1.2	1.4	1	0.62	0.31146	1.04
11/24/2024 10:00	0.9	1.3	1	0.47	0.23328	0.78
11/24/2024 11:00	0.8	1.3	2	0.45	0.22338	0.74
11/24/2024 12:00	0.8	1.4	1	0.45	0.22332	0.74
11/24/2024 13:00	0.7	1.4	1	0.45	0.22296	0.74
11/24/2024 14:00	0.7	1.4	1	0.45	0.22284	0.74
11/24/2024 15:00	0.8	1.4	1	0.47	0.23592	0.79
11/24/2024 16:00	0.7	1.4	1	0.48	0.24036	0.80
11/24/2024 17:00	2.1	1.4	1	0.60	0.29856	1.00
11/24/2024 18:00	1.2	1.4	1	0.63	0.31254	1.04
11/24/2024 19:00	1.3	1.4	1	0.62	0.31236	1.04
11/24/2024 20:00	1.3	1.4	1	0.62	0.31218	1.04
11/24/2024 21:00	1.2	1.4	1	0.62	0.31146	1.04
11/24/2024 22:00	1.3	1.4	1	0.62	0.31062	1.04
11/24/2024 23:00	1.3	1.4	1	0.62	0.31068	1.04
Average/Sum#:	1.2	1.4	1	0.57	0.28712	0.96
Minimum:	0.7	1.3	1	0.45	0.22284	0.74
Maximum:	2.1	1.4	2	0.63	0.31368	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/25/2024 00:00	1.2	1.4	1	0.62	0.31194	1.04
11/25/2024 01:00	1.2	1.4	1	0.62	0.31062	1.04
11/25/2024 02:00	1.2	1.5	1	0.62	0.31068	1.04
11/25/2024 03:00	1.3	1.4	1	0.62	0.31116	1.04
11/25/2024 04:00	1.2	1.4	1	0.62	0.31104	1.04
11/25/2024 05:00	1.2	1.4	1	0.62	0.31134	1.04
11/25/2024 06:00	1.1	1.4	1	0.62	0.31068	1.04
11/25/2024 07:00	1.1	1.4	1	0.62	0.30984	1.03
11/25/2024 08:00	1.2	1.4	1	0.62	0.31074	1.04
11/25/2024 09:00	1.2	1.4	1	0.63	0.31284	1.04
11/25/2024 10:00	1.1	1.4	1	0.62	0.31140	1.04
11/25/2024 11:00	1.1	1.4	1	0.62	0.31134	1.04
11/25/2024 12:00	1.1	1.4	1	0.63	0.31272	1.04
11/25/2024 13:00	1.1	1.4	1	0.63	0.31344	1.04
11/25/2024 14:00	1.1	1.4	1	0.63	0.31278	1.04
11/25/2024 15:00	1.0	1.4	1	0.63	0.31596	1.05
11/25/2024 16:00	1.1	1.4	1	0.62	0.31236	1.04
11/25/2024 17:00	1.2	1.4	1	0.62	0.31188	1.04
11/25/2024 18:00	1.2	1.4	1	0.62	0.31188	1.04
11/25/2024 19:00	1.2	1.4	1	0.62	0.31176	1.04
11/25/2024 20:00	1.2	1.4	1	0.62	0.31206	1.04
11/25/2024 21:00	1.2	1.4	1	0.63	0.31254	1.04
11/25/2024 22:00	1.2	1.4	1	0.62	0.31212	1.04
11/25/2024 23:00	1.2	1.4	1	0.62	0.31092	1.04
Average/Sum#:	1.2	1.4	1	0.62	0.31184	1.04
Minimum:	1.0	1.4	1	0.62	0.30984	1.03
Maximum:	1.3	1.5	1	0.63	0.31596	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/26/2024 00:00	1.2	1.4	1	0.61	0.30714	1.02
11/26/2024 01:00	1.1	1.4	1	0.62	0.30942	1.03
11/26/2024 02:00	1.1	1.5	1	0.62	0.30984	1.03
11/26/2024 03:00	1.2	1.5	1	0.62	0.30996	1.03
11/26/2024 04:00	1.2	1.4	1	0.62	0.31008	1.03
11/26/2024 05:00	1.2	1.3	1	0.62	0.30966	1.03
11/26/2024 06:00	1.2	1.4	1	0.62	0.31044	1.03
11/26/2024 07:00	1.2	1.4	1	0.62	0.31038	1.03
11/26/2024 08:00	1.1	1.4	1	0.62	0.31068	1.04
11/26/2024 09:00	1.2	1.4	1	0.62	0.31092	1.04
11/26/2024 10:00	1.0	1.3	1	0.62	0.31086	1.04
11/26/2024 11:00	1.0	1.4	1	0.62	0.31134	1.04
11/26/2024 12:00	1.0	1.4	1	0.62	0.31200	1.04
11/26/2024 13:00	1.0	1.4	1	0.63	0.31254	1.04
11/26/2024 14:00	1.0	1.4	1	0.62	0.31236	1.04
11/26/2024 15:00	0.9	1.4	1	0.62	0.31176	1.04
11/26/2024 16:00	0.9	1.4	1	0.62	0.31146	1.04
11/26/2024 17:00	1.0	1.4	1	0.62	0.31080	1.04
11/26/2024 18:00	1.1	1.4	1	0.62	0.31056	1.04
11/26/2024 19:00	1.2	1.4	1	0.62	0.30960	1.03
11/26/2024 20:00	1.4	1.4	1	0.62	0.30900	1.03
11/26/2024 21:00	1.2	1.4	1	0.63	0.31296	1.04
11/26/2024 22:00	1.2	1.4	1	0.63	0.31314	1.04
11/26/2024 23:00	1.2	1.4	1	0.63	0.31326	1.04
Average/Sum#:	1.1	1.4	1	0.62	0.31084	1.04
Minimum:	0.9	1.3	1	0.61	0.30714	1.02
Maximum:	1.4	1.5	1	0.63	0.31326	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/27/2024 00:00	1.2	1.4	1	0.63	0.31452	1.05
11/27/2024 01:00	1.1	1.4	1	0.63	0.31464	1.05
11/27/2024 02:00	1.1	1.4	1	0.63	0.31404	1.05
11/27/2024 03:00	1.2	1.4	1	0.63	0.31326	1.04
11/27/2024 04:00	1.2	1.4	1	0.62	0.31188	1.04
11/27/2024 05:00	1.2	1.4	1	0.62	0.31200	1.04
11/27/2024 06:00	1.2	1.4	1	0.63	0.31254	1.04
11/27/2024 07:00	1.2	1.4	1	0.63	0.31494	1.05
11/27/2024 08:00	0.7	1.5	2	0.69	0.34554	1.15
11/27/2024 09:00	1.1	1.4	1	0.63	0.31584	1.05
11/27/2024 10:00	1.1	1.4	1	0.62	0.31056	1.04
11/27/2024 11:00	1.0	1.4	1	0.62	0.31026	1.03
11/27/2024 12:00	1.0	1.4	1	0.62	0.30816	1.03
11/27/2024 13:00	1.0	1.4	1	0.61	0.30630	1.02
11/27/2024 14:00	0.9	1.4	1	0.63	0.31392	1.05
11/27/2024 15:00	0.9	1.4	1	0.63	0.31302	1.04
11/27/2024 16:00	0.9	1.5	1	0.63	0.31488	1.05
11/27/2024 17:00	1.1	1.4	1	0.62	0.30954	1.03
11/27/2024 18:00	1.0	1.4	1	0.62	0.30978	1.03
11/27/2024 19:00	1.2	1.4	1	0.62	0.31116	1.04
11/27/2024 20:00	1.2	1.4	1	0.62	0.31158	1.04
11/27/2024 21:00	1.3	1.4	1	0.63	0.31746	1.06
11/27/2024 22:00	1.3	1.4	1	0.63	0.31494	1.05
11/27/2024 23:00	1.3	1.4	1	0.62	0.30984	1.03
Average/Sum#:	1.1	1.4	1	0.63	0.31378	1.05
Minimum:	0.7	1.4	1	0.61	0.30630	1.02
Maximum:	1.3	1.5	2	0.69	0.34554	1.15
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/28/2024 00:00	1.4	1.4	1	0.62	0.30798	1.03
11/28/2024 01:00	1.5	1.4	1	0.62	0.30954	1.03
11/28/2024 02:00	1.5	1.4	1	0.62	0.31014	1.03
11/28/2024 03:00	1.4	1.5	2	0.62	0.31134	1.04
11/28/2024 04:00	1.4	1.5	1	0.62	0.31002	1.03
11/28/2024 05:00	1.4	1.4	1	0.62	0.31014	1.03
11/28/2024 06:00	1.3	1.4	1	0.63	0.31602	1.05
11/28/2024 07:00	1.4	1.4	1	0.63	0.31470	1.05
11/28/2024 08:00	1.2	1.4	2	0.58	0.28752	0.96
11/28/2024 09:00	1.2	1.3	1	0.52	0.26004	0.87
11/28/2024 10:00	1.2	1.4	1	0.62	0.31230	1.04
11/28/2024 11:00	1.1	1.4	1	0.62	0.30936	1.03
11/28/2024 12:00	1.0	1.4	1	0.62	0.30990	1.03
11/28/2024 13:00	1.0	1.4	1	0.63	0.31308	1.04
11/28/2024 14:00	1.0	1.4	1	0.62	0.31206	1.04
11/28/2024 15:00	0.9	1.4	1	0.64	0.31938	1.06
11/28/2024 16:00	0.9	1.4	1	0.63	0.31512	1.05
11/28/2024 17:00	1.1	1.4	1	0.63	0.31302	1.04
11/28/2024 18:00	1.1	1.4	1	0.62	0.31098	1.04
11/28/2024 19:00	1.1	1.4	1	0.62	0.31152	1.04
11/28/2024 20:00	1.4	1.4	1	0.63	0.31590	1.05
11/28/2024 21:00	1.0	1.4	2	0.66	0.33132	1.10
11/28/2024 22:00	1.1	1.4	2	0.66	0.32802	1.09
11/28/2024 23:00	1.0	1.5	2	0.67	0.33270	1.11
Average/Sum#:	1.2	1.4	1	0.62	0.31134	1.04
Minimum:	0.9	1.3	1	0.52	0.26004	0.87
Maximum:	1.5	1.5	2	0.67	0.33270	1.11
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/29/2024 00:00	1.4	1.4	1	0.63	0.31440	1.05
11/29/2024 01:00	1.6	1.4	1	0.62	0.31134	1.04
11/29/2024 02:00	1.6	1.4	1	0.62	0.31134	1.04
11/29/2024 03:00	1.6	1.4	1	0.63	0.31296	1.04
11/29/2024 04:00	1.5	1.4	1	0.63	0.31566	1.05
11/29/2024 05:00	1.5	1.4	1	0.63	0.31266	1.04
11/29/2024 06:00	1.5	1.4	1	0.63	0.31428	1.05
11/29/2024 07:00	1.5	1.4	1	0.62	0.31200	1.04
11/29/2024 08:00	1.4	1.4	1	0.62	0.31116	1.04
11/29/2024 09:00	1.2	1.4	1	0.63	0.31386	1.05
11/29/2024 10:00	1.1	1.4	1	0.63	0.31506	1.05
11/29/2024 11:00	1.3	1.4	1	0.62	0.31152	1.04
11/29/2024 12:00	1.2	1.4	1	0.63	0.31632	1.05
11/29/2024 13:00	0.9	1.4	1	0.64	0.31782	1.06
11/29/2024 14:00	0.8	1.4	1	0.65	0.32286	1.08
11/29/2024 15:00	0.7	1.5	1	0.66	0.32952	1.10
11/29/2024 16:00	0.7	1.4	1	0.65	0.32706	1.09
11/29/2024 17:00	1.0	1.5	1	0.63	0.31392	1.05
11/29/2024 18:00	1.0	1.4	1	0.64	0.31992	1.07
11/29/2024 19:00	1.2	1.4	1	0.63	0.31746	1.06
11/29/2024 20:00	1.2	1.4	1	0.65	0.32304	1.08
11/29/2024 21:00	1.0	1.5	1	0.66	0.33216	1.11
11/29/2024 22:00	1.0	1.4	1	0.66	0.33036	1.10
11/29/2024 23:00	1.1	1.5	1	0.66	0.32874	1.10
Average/Sum#:	1.2	1.4	1	0.64	0.31814	1.06
Minimum:	0.7	1.4	1	0.62	0.31116	1.04
Maximum:	1.6	1.5	1	0.66	0.33216	1.11
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
11/30/2024 00:00	1.3	1.4	1	0.64	0.31884	1.06
11/30/2024 01:00	1.5	1.4	1	0.62	0.30876	1.03
11/30/2024 02:00	1.4	1.5	1	0.62	0.30960	1.03
11/30/2024 03:00	1.4	1.5	1	0.62	0.31080	1.04
11/30/2024 04:00	1.4	1.4	1	0.62	0.31194	1.04
11/30/2024 05:00	1.4	1.4	1	0.62	0.31194	1.04
11/30/2024 06:00	1.4	1.5	1	0.64	0.31752	1.06
11/30/2024 07:00	1.5	1.4	1	0.63	0.31332	1.04
11/30/2024 08:00	0.7	1.5	2	0.70	0.35184	1.17
11/30/2024 09:00	0.9	1.4	2	0.66	0.33000	1.10
11/30/2024 10:00	1.6	1.4	1	0.62	0.30870	1.03
11/30/2024 11:00	1.2	1.4	1	0.63	0.31530	1.05
11/30/2024 12:00	1.1	1.4	1	0.63	0.31632	1.05
11/30/2024 13:00	1.0	1.4	1	0.63	0.31722	1.06
11/30/2024 14:00	1.0	1.4	1	0.64	0.31758	1.06
11/30/2024 15:00	0.8	1.5	1	0.67	0.33426	1.11
11/30/2024 16:00	0.9	1.4	1	0.64	0.31782	1.06
11/30/2024 17:00	1.1	1.4	1	0.62	0.31176	1.04
11/30/2024 18:00	1.2	1.4	1	0.62	0.31050	1.04
11/30/2024 19:00	1.2	1.4	1	0.63	0.31668	1.06
11/30/2024 20:00	1.2	1.4	1	0.64	0.32094	1.07
11/30/2024 21:00	1.2	1.4	1	0.64	0.31968	1.07
11/30/2024 22:00	1.2	1.4	1	0.64	0.32130	1.07
11/30/2024 23:00	1.2	1.4	1	0.64	0.32100	1.07
Average/Sum#:	1.2	1.4	1	0.64	0.31807	1.06
Minimum:	0.7	1.4	1	0.62	0.30870	1.03
Maximum:	1.6	1.5	2	0.70	0.35184	1.17
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/01/2024 00:00	1.5	1.4	1	0.62	0.31074	1.04
12/01/2024 01:00	1.5	1.4	1	0.61	0.30708	1.02
12/01/2024 02:00	1.5	1.4	1	0.61	0.30726	1.02
12/01/2024 03:00	1.5	1.4	1	0.62	0.31056	1.04
12/01/2024 04:00	1.4	1.4	1	0.62	0.31050	1.04
12/01/2024 05:00	1.4	1.4	1	0.62	0.31092	1.04
12/01/2024 06:00	1.3	1.4	1	0.62	0.31224	1.04
12/01/2024 07:00	1.2	1.4	1	0.63	0.31272	1.04
12/01/2024 08:00	1.2	1.4	1	0.63	0.31260	1.04
12/01/2024 09:00	1.2	1.4	1	0.63	0.31278	1.04
12/01/2024 10:00	1.2	1.4	1	0.62	0.31026	1.03
12/01/2024 11:00	1.1	1.2	1	0.54	0.27132	0.90
12/01/2024 12:00	0.9	1.3	1	0.44	0.22020	0.73
12/01/2024 13:00	0.9	1.4	1	0.44	0.21978	0.73
12/01/2024 14:00	0.9	1.4	1	0.44	0.21996	0.73
12/01/2024 15:00	1.3	1.4	1	0.52	0.25950	0.87
12/01/2024 16:00	1.2	1.4	1	0.63	0.31344	1.04
12/01/2024 17:00	1.2	1.4	1	0.62	0.31092	1.04
12/01/2024 18:00	1.2	1.4	1	0.62	0.31056	1.04
12/01/2024 19:00	1.1	1.4	1	0.64	0.31944	1.06
12/01/2024 20:00	1.1	1.4	1	0.64	0.31998	1.07
12/01/2024 21:00	1.2	1.4	1	0.63	0.31344	1.04
12/01/2024 22:00	1.3	1.4	1	0.62	0.30804	1.03
12/01/2024 23:00	1.2	1.4	1	0.62	0.31116	1.04
Average/Sum#:	1.2	1.4	1	0.59	0.29648	0.99
Minimum:	0.9	1.2	1	0.44	0.21978	0.73
Maximum:	1.5	1.4	1	0.64	0.31998	1.07
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/02/2024 00:00	1.3	1.4	1	0.63	0.31272	1.04
12/02/2024 01:00	1.3	1.4	1	0.62	0.31248	1.04
12/02/2024 02:00	1.3	1.4	1	0.63	0.31284	1.04
12/02/2024 03:00	1.4	1.5	1	0.63	0.31290	1.04
12/02/2024 04:00	1.4	1.4	1	0.63	0.31428	1.05
12/02/2024 05:00	1.3	1.4	1	0.64	0.31788	1.06
12/02/2024 06:00	1.3	1.4	1	0.64	0.32124	1.07
12/02/2024 07:00	1.4	1.4	1	0.62	0.31122	1.04
12/02/2024 08:00	1.4	1.4	1	0.62	0.31200	1.04
12/02/2024 09:00	1.4	1.4	1	0.62	0.30798	1.03
12/02/2024 10:00	1.2	1.4	1	0.62	0.31104	1.04
12/02/2024 11:00	1.1	1.4	1	0.62	0.31032	1.03
12/02/2024 12:00	1.0	1.4	1	0.62	0.31116	1.04
12/02/2024 13:00	1.0	1.4	1	0.62	0.31212	1.04
12/02/2024 14:00	1.0	1.4	1	0.62	0.31218	1.04
12/02/2024 15:00	0.9	1.4	1	0.63	0.31434	1.05
12/02/2024 16:00	1.0	1.4	1	0.62	0.31236	1.04
12/02/2024 17:00	1.0	1.4	1	0.63	0.31422	1.05
12/02/2024 18:00	1.0	1.4	1	0.64	0.31764	1.06
12/02/2024 19:00	1.2	1.4	1	0.63	0.31260	1.04
12/02/2024 20:00	1.3	1.4	1	0.62	0.31044	1.03
12/02/2024 21:00	1.3	1.4	1	0.62	0.31122	1.04
12/02/2024 22:00	1.3	1.4	1	0.62	0.31116	1.04
12/02/2024 23:00	1.4	1.4	1	0.62	0.31074	1.04
Average/Sum#:	1.2	1.4	1	0.63	0.31280	1.04
Minimum:	0.9	1.4	1	0.62	0.30798	1.03
Maximum:	1.4	1.5	1	0.64	0.32124	1.07
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/03/2024 00:00	1.4	1.4	1	0.62	0.31134	1.04
12/03/2024 01:00	1.4	1.4	1	0.62	0.31122	1.04
12/03/2024 02:00	1.4	1.4	1	0.62	0.31206	1.04
12/03/2024 03:00	1.4	1.5	1	0.62	0.31134	1.04
12/03/2024 04:00	1.4	1.4	1	0.62	0.31044	1.03
12/03/2024 05:00	1.4	1.4	1	0.62	0.30954	1.03
12/03/2024 06:00	1.3	1.4	1	0.62	0.31212	1.04
12/03/2024 07:00	1.4	1.4	1	0.62	0.30828	1.03
12/03/2024 08:00	1.5	1.4	1	0.62	0.30822	1.03
12/03/2024 09:00	1.3	1.4	1	0.62	0.31008	1.03
12/03/2024 10:00	1.4	1.4	1	0.61	0.30630	1.02
12/03/2024 11:00	1.1	1.4	1	0.59	0.29268	0.98
12/03/2024 12:00	0.9	1.2	1	0.44	0.22062	0.74
12/03/2024 13:00	0.9	1.2	1	0.44	0.22164	0.74
12/03/2024 14:00	0.9	1.2	1	0.44	0.22080	0.74
12/03/2024 15:00	1.2	1.3	1	0.52	0.25860	0.86
12/03/2024 16:00	1.1	1.4	1	0.62	0.30906	1.03
12/03/2024 17:00	1.2	1.4	1	0.62	0.30936	1.03
12/03/2024 18:00	1.2	1.4	1	0.62	0.30804	1.03
12/03/2024 19:00	1.3	1.4	1	0.62	0.30852	1.03
12/03/2024 20:00	1.3	1.4	1	0.62	0.31116	1.04
12/03/2024 21:00	1.4	1.4	1	0.62	0.31074	1.04
12/03/2024 22:00	1.4	1.4	1	0.62	0.31008	1.03
12/03/2024 23:00	1.4	1.4	1	0.62	0.31044	1.03
Average/Sum#:	1.3	1.4	1	0.59	0.29595	0.99
Minimum:	0.9	1.2	1	0.44	0.22062	0.74
Maximum:	1.5	1.5	1	0.62	0.31212	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/04/2024 00:00	1.4	1.4	1	0.62	0.31002	1.03
12/04/2024 01:00	1.5	1.4	1	0.62	0.30966	1.03
12/04/2024 02:00	1.4	1.4	1	0.62	0.30900	1.03
12/04/2024 03:00	1.5	1.4	1	0.62	0.30834	1.03
12/04/2024 04:00	1.5	1.4	1	0.62	0.30780	1.03
12/04/2024 05:00	1.6	1.4	1	0.61	0.30732	1.02
12/04/2024 06:00	1.2	1.4	1	0.66	0.32904	1.10
12/04/2024 07:00	1.3	1.4	1	0.65	0.32736	1.09
12/04/2024 08:00	1.2	1.4	1	0.64	0.31992	1.07
12/04/2024 09:00	1.3	1.4	1	0.62	0.30750	1.03
12/04/2024 10:00	1.0	1.3	1	0.51	0.25338	0.84
12/04/2024 11:00	0.8	1.2	1	0.45	0.22560	0.75
12/04/2024 12:00	0.7	1.3	1	0.51	0.25380	0.85
12/04/2024 13:00	1.1	1.4	1	0.58	0.29088	0.97
12/04/2024 14:00	1.4	1.3	1	0.57	0.28614	0.95
12/04/2024 15:00	0.9	1.2	1	0.53	0.26484	0.88
12/04/2024 16:00	0.8	1.4	1	0.59	0.29256	0.98
12/04/2024 17:00	1.0	1.4	1	0.63	0.31398	1.05
12/04/2024 18:00	1.1	1.4	1	0.63	0.31476	1.05
12/04/2024 19:00	0.8	1.5	2	0.68	0.33822	1.13
12/04/2024 20:00	0.6	1.5	2	0.71	0.35406	1.18
12/04/2024 21:00	0.7	1.5	2	0.70	0.34842	1.16
12/04/2024 22:00	0.8	1.4	1	0.67	0.33630	1.12
12/04/2024 23:00	1.0	1.4	1	0.66	0.32940	1.10
Average/Sum#:	1.1	1.4	1	0.61	0.30576	1.02
Minimum:	0.6	1.2	1	0.45	0.22560	0.75
Maximum:	1.6	1.5	2	0.71	0.35406	1.18
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/05/2024 00:00	1.3	1.4	1	0.63	0.31338	1.04
12/05/2024 01:00	1.5	1.4	1	0.62	0.30786	1.03
12/05/2024 02:00	1.4	1.4	1	0.62	0.30846	1.03
12/05/2024 03:00	1.4	1.4	1	0.62	0.30942	1.03
12/05/2024 04:00	1.3	1.4	1	0.62	0.31026	1.03
12/05/2024 05:00	1.1	1.4	1	0.65	0.32418	1.08
12/05/2024 06:00	0.7	1.5	2	0.71	0.35322	1.18
12/05/2024 07:00	1.2	1.4	1	0.64	0.32034	1.07
12/05/2024 08:00	1.3	1.4	1	0.63	0.31494	1.05
12/05/2024 09:00	1.3	1.4	1	0.62	0.30798	1.03
12/05/2024 10:00	0.0	0.0	0	0.62	0.30894	1.03
12/05/2024 11:00	1.2	1.4	1	0.62	0.31098	1.04
12/05/2024 12:00	1.2	1.4	1	0.62	0.30984	1.03
12/05/2024 13:00	1.2	1.4	1	0.62	0.30888	1.03
12/05/2024 14:00	1.1	1.4	1	0.62	0.30936	1.03
12/05/2024 15:00	1.0	1.4	1	0.63	0.31584	1.05
12/05/2024 16:00	1.0	1.4	1	0.63	0.31620	1.05
12/05/2024 17:00	1.2	1.4	1	0.62	0.31008	1.03
12/05/2024 18:00	1.3	1.4	1	0.62	0.30774	1.03
12/05/2024 19:00	1.3	1.4	1	0.62	0.30828	1.03
12/05/2024 20:00	1.3	1.4	1	0.62	0.31134	1.04
12/05/2024 21:00	1.3	1.4	1	0.62	0.31200	1.04
12/05/2024 22:00	1.3	1.4	2	0.64	0.31842	1.06
12/05/2024 23:00	1.3	1.4	1	0.63	0.31674	1.06
Average/Sum#:	1.2	1.4	1	0.63	0.31395	1.05
Minimum:	0.7	1.4	1	0.62	0.30774	1.03
Maximum:	1.5	1.5	2	0.71	0.35322	1.18
%SI	4.17	4.17	4.17	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/06/2024 00:00	1.3	1.4	1	0.62	0.30828	1.03
12/06/2024 01:00	1.3	1.4	1	0.61	0.30744	1.02
12/06/2024 02:00	1.3	1.4	1	0.62	0.30804	1.03
12/06/2024 03:00	1.4	1.4	1	0.62	0.30816	1.03
12/06/2024 04:00	1.4	1.4	1	0.61	0.30738	1.02
12/06/2024 05:00	1.4	1.4	1	0.61	0.30654	1.02
12/06/2024 06:00	1.3	1.4	1	0.61	0.30618	1.02
12/06/2024 07:00	1.3	1.4	1	0.62	0.30834	1.03
12/06/2024 08:00	1.4	1.4	1	0.62	0.30786	1.03
12/06/2024 09:00	1.2	1.4	1	0.59	0.29688	0.99
12/06/2024 10:00	1.0	1.2	1	0.51	0.25686	0.86
12/06/2024 11:00	0.0	0.0	0	0.62	0.30816	1.03
12/06/2024 12:00	1.2	1.3	1	0.62	0.30822	1.03
12/06/2024 13:00	1.2	1.4	1	0.62	0.30876	1.03
12/06/2024 14:00	0.9	1.2	1	0.46	0.22986	0.77
12/06/2024 15:00	0.9	1.3	1	0.51	0.25506	0.85
12/06/2024 16:00	1.1	1.4	1	0.63	0.31470	1.05
12/06/2024 17:00	1.1	1.4	1	0.63	0.31350	1.05
12/06/2024 18:00	1.2	1.4	1	0.63	0.31332	1.04
12/06/2024 19:00	1.2	1.4	1	0.63	0.31380	1.05
12/06/2024 20:00	1.3	1.4	1	0.63	0.31320	1.04
12/06/2024 21:00	1.1	1.4	2	0.65	0.32592	1.09
12/06/2024 22:00	1.1	1.4	2	0.66	0.32760	1.09
12/06/2024 23:00	0.9	1.4	2	0.67	0.33516	1.12
Average/Sum#:	1.2	1.4	1	0.61	0.30372	1.01
Minimum:	0.9	1.2	1	0.46	0.22986	0.77
Maximum:	1.4	1.4	2	0.67	0.33516	1.12
%SI	4.17	4.17	4.17	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/07/2024 00:00	1.3	1.4	1	0.64	0.31800	1.06
12/07/2024 01:00	1.3	1.4	1	0.63	0.31710	1.06
12/07/2024 02:00	1.4	1.4	1	0.63	0.31650	1.06
12/07/2024 03:00	1.5	1.4	2	0.63	0.31500	1.05
12/07/2024 04:00	1.3	1.4	2	0.63	0.31584	1.05
12/07/2024 05:00	1.3	1.4	2	0.63	0.31746	1.06
12/07/2024 06:00	1.4	1.4	2	0.64	0.31950	1.07
12/07/2024 07:00	1.3	1.4	2	0.63	0.31656	1.06
12/07/2024 08:00	1.3	1.4	1	0.63	0.31422	1.05
12/07/2024 09:00	1.1	1.3	1	0.51	0.25344	0.84
12/07/2024 10:00	1.0	1.3	2	0.45	0.22542	0.75
12/07/2024 11:00	1.0	1.3	2	0.45	0.22554	0.75
12/07/2024 12:00	0.9	1.4	1	0.45	0.22458	0.75
12/07/2024 13:00	0.9	1.3	2	0.45	0.22326	0.74
12/07/2024 14:00	0.9	1.4	1	0.45	0.22362	0.75
12/07/2024 15:00	0.8	1.3	1	0.51	0.25548	0.85
12/07/2024 16:00	0.8	1.3	1	0.51	0.25308	0.84
12/07/2024 17:00	0.8	1.3	1	0.51	0.25404	0.85
12/07/2024 18:00	0.8	1.2	1	0.52	0.25836	0.86
12/07/2024 19:00	0.9	1.3	1	0.55	0.27720	0.92
12/07/2024 20:00	0.9	1.3	1	0.54	0.27012	0.90
12/07/2024 21:00	0.9	1.3	1	0.52	0.25764	0.86
12/07/2024 22:00	1.0	1.3	2	0.45	0.22548	0.75
12/07/2024 23:00	1.0	1.4	2	0.45	0.22602	0.75
Average/Sum#:	1.1	1.3	1	0.54	0.27098	0.90
Minimum:	0.8	1.2	1	0.45	0.22326	0.74
Maximum:	1.5	1.4	2	0.64	0.31950	1.07
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/08/2024 00:00	1.0	1.4	2	0.45	0.22542	0.75
12/08/2024 01:00	1.0	1.4	2	0.45	0.22548	0.75
12/08/2024 02:00	1.0	1.5	2	0.45	0.22632	0.75
12/08/2024 03:00	1.1	1.4	2	0.45	0.22584	0.75
12/08/2024 04:00	1.1	1.4	2	0.45	0.22560	0.75
12/08/2024 05:00	1.0	1.4	2	0.45	0.22554	0.75
12/08/2024 06:00	1.0	1.4	2	0.45	0.22572	0.75
12/08/2024 07:00	1.0	1.4	2	0.45	0.22560	0.75
12/08/2024 08:00	1.0	1.4	2	0.45	0.22500	0.75
12/08/2024 09:00	1.0	1.3	2	0.45	0.22512	0.75
12/08/2024 10:00	1.0	1.3	2	0.45	0.22500	0.75
12/08/2024 11:00	0.9	1.4	2	0.45	0.22536	0.75
12/08/2024 12:00	0.8	1.4	2	0.45	0.22482	0.75
12/08/2024 13:00	0.8	1.4	1	0.45	0.22416	0.75
12/08/2024 14:00	0.8	1.3	1	0.44	0.22200	0.74
12/08/2024 15:00	0.8	1.3	1	0.44	0.22182	0.74
12/08/2024 16:00	0.8	1.4	1	0.44	0.22248	0.74
12/08/2024 17:00	0.8	1.3	1	0.45	0.22440	0.75
12/08/2024 18:00	0.8	1.3	2	0.45	0.22500	0.75
12/08/2024 19:00	0.9	1.4	2	0.45	0.22464	0.75
12/08/2024 20:00	1.0	1.4	2	0.45	0.22446	0.75
12/08/2024 21:00	1.0	1.3	2	0.45	0.22500	0.75
12/08/2024 22:00	1.0	1.4	2	0.45	0.22716	0.76
12/08/2024 23:00	1.0	1.4	2	0.45	0.22548	0.75
Average/Sum#:	0.9	1.4	2	0.45	0.22489	0.75
Minimum:	0.8	1.3	1	0.44	0.22182	0.74
Maximum:	1.1	1.5	2	0.45	0.22716	0.76
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/09/2024 00:00	1.0	1.4	2	0.45	0.22554	0.75
12/09/2024 01:00	1.0	1.4	2	0.45	0.22548	0.75
12/09/2024 02:00	1.3	1.4	2	0.45	0.22506	0.75
12/09/2024 03:00	1.1	1.5	2	0.45	0.22530	0.75
12/09/2024 04:00	1.0	1.4	2	0.45	0.22482	0.75
12/09/2024 05:00	0.9	1.4	2	0.45	0.22446	0.75
12/09/2024 06:00	0.8	1.4	1	0.50	0.24954	0.83
12/09/2024 07:00	0.8	1.4	2	0.53	0.26652	0.89
12/09/2024 08:00	0.8	1.4	1	0.57	0.28272	0.94
12/09/2024 09:00	1.1	1.4	1	0.57	0.28596	0.95
12/09/2024 10:00	1.5	1.4	2	0.62	0.30990	1.03
12/09/2024 11:00	1.2	1.4	1	0.62	0.31122	1.04
12/09/2024 12:00	1.0	1.3	2	0.50	0.25134	0.84
12/09/2024 13:00	0.8	1.3	2	0.44	0.22176	0.74
12/09/2024 14:00	0.8	1.4	2	0.44	0.22104	0.74
12/09/2024 15:00	1.1	1.4	1	0.52	0.25842	0.86
12/09/2024 16:00	1.0	1.3	1	0.64	0.32076	1.07
12/09/2024 17:00	0.8	1.3	2	0.65	0.32412	1.08
12/09/2024 18:00	0.7	1.4	2	0.67	0.33534	1.12
12/09/2024 19:00	0.5	1.4	2	0.70	0.35076	1.17
12/09/2024 20:00	0.3	1.5	2	0.74	0.37188	1.24
12/09/2024 21:00	0.5	1.5	2	0.72	0.36126	1.20
12/09/2024 22:00	0.8	1.4	2	0.68	0.34200	1.14
12/09/2024 23:00	1.0	1.4	2	0.67	0.33252	1.11
Average/Sum#:	0.9	1.4	2	0.56	0.28116	0.94
Minimum:	0.3	1.3	1	0.44	0.22104	0.74
Maximum:	1.5	1.5	2	0.74	0.37188	1.24
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/10/2024 00:00	1.2	1.4	2	0.64	0.32022	1.07
12/10/2024 01:00	1.3	1.4	1	0.62	0.30960	1.03
12/10/2024 02:00	1.2	1.3	2	0.64	0.31842	1.06
12/10/2024 03:00	1.3	1.4	2	0.62	0.30924	1.03
12/10/2024 04:00	1.2	1.4	1	0.63	0.31422	1.05
12/10/2024 05:00	0.8	1.4	2	0.68	0.33972	1.13
12/10/2024 06:00	0.8	1.5	2	0.69	0.34458	1.15
12/10/2024 07:00	0.9	1.4	2	0.67	0.33372	1.11
12/10/2024 08:00	1.1	1.4	2	0.65	0.32466	1.08
12/10/2024 09:00	1.3	1.4	2	0.62	0.31248	1.04
12/10/2024 10:00	1.2	1.4	1	0.63	0.31302	1.04
12/10/2024 11:00	1.1	1.4	1	0.62	0.31032	1.03
12/10/2024 12:00	1.2	1.4	1	0.62	0.31128	1.04
12/10/2024 13:00	1.2	1.4	1	0.62	0.31176	1.04
12/10/2024 14:00	1.1	1.4	1	0.62	0.31206	1.04
12/10/2024 15:00	1.1	1.4	1	0.63	0.31686	1.06
12/10/2024 16:00	0.9	1.4	2	0.65	0.32544	1.08
12/10/2024 17:00	1.2	1.4	1	0.62	0.31248	1.04
12/10/2024 18:00	1.2	1.4	1	0.62	0.31086	1.04
12/10/2024 19:00	1.2	1.4	1	0.62	0.30912	1.03
12/10/2024 20:00	1.4	1.4	2	0.62	0.30864	1.03
12/10/2024 21:00	1.4	1.4	1	0.62	0.30906	1.03
12/10/2024 22:00	1.4	1.4	2	0.62	0.30876	1.03
12/10/2024 23:00	1.3	1.4	2	0.63	0.31410	1.05
Average/Sum#:	1.2	1.4	2	0.63	0.31669	1.06
Minimum:	0.8	1.3	1	0.62	0.30864	1.03
Maximum:	1.4	1.5	2	0.69	0.34458	1.15
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/11/2024 00:00	1.4	1.4	2	0.63	0.31368	1.05
12/11/2024 01:00	1.3	1.4	2	0.63	0.31524	1.05
12/11/2024 02:00	1.3	1.4	2	0.63	0.31452	1.05
12/11/2024 03:00	1.3	1.5	2	0.63	0.31464	1.05
12/11/2024 04:00	1.3	1.4	2	0.63	0.31518	1.05
12/11/2024 05:00	1.3	1.4	2	0.63	0.31620	1.05
12/11/2024 06:00	1.0	1.5	2	0.67	0.33684	1.12
12/11/2024 07:00	0.7	1.5	2	0.70	0.35208	1.17
12/11/2024 08:00	1.2	1.4	2	0.64	0.32010	1.07
12/11/2024 09:00	1.3	1.4	2	0.62	0.31170	1.04
12/11/2024 10:00	1.2	1.4	1	0.62	0.31128	1.04
12/11/2024 11:00	1.1	1.4	1	0.63	0.31290	1.04
12/11/2024 12:00	1.1	1.4	1	0.63	0.31344	1.04
12/11/2024 13:00	1.0	1.4	2	0.63	0.31524	1.05
12/11/2024 14:00	1.0	1.4	2	0.63	0.31524	1.05
12/11/2024 15:00	1.1	1.4	2	0.63	0.31452	1.05
12/11/2024 16:00	1.1	1.4	2	0.63	0.31488	1.05
12/11/2024 17:00	1.1	1.4	2	0.63	0.31608	1.05
12/11/2024 18:00	1.1	1.4	2	0.64	0.32136	1.07
12/11/2024 19:00	0.9	1.4	2	0.66	0.33246	1.11
12/11/2024 20:00	0.9	1.5	2	0.67	0.33444	1.11
12/11/2024 21:00	0.9	1.5	2	0.65	0.32580	1.09
12/11/2024 22:00	1.0	1.4	2	0.64	0.32034	1.07
12/11/2024 23:00	1.0	1.5	2	0.64	0.31794	1.06
Average/Sum#:	1.1	1.4	2	0.64	0.31984	1.07
Minimum:	0.7	1.4	1	0.62	0.31128	1.04
Maximum:	1.4	1.5	2	0.70	0.35208	1.17
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/12/2024 00:00	1.1	1.4	2	0.63	0.31380	1.05
12/12/2024 01:00	1.0	1.5	2	0.64	0.32010	1.07
12/12/2024 02:00	1.2	1.5	2	0.63	0.31590	1.05
12/12/2024 03:00	1.2	1.5	2	0.63	0.31572	1.05
12/12/2024 04:00	1.0	1.5	2	0.64	0.32118	1.07
12/12/2024 05:00	0.7	1.5	2	0.68	0.33804	1.13
12/12/2024 06:00	0.4	1.5	2	0.75	0.37596	1.25
12/12/2024 07:00	0.4	1.4	3	0.76	0.37812	1.26
12/12/2024 08:00	0.9	1.4	2	0.64	0.32124	1.07
12/12/2024 09:00	0.8	1.5	2	0.65	0.32718	1.09
12/12/2024 10:00	1.0	1.5	2	0.63	0.31674	1.06
12/12/2024 11:00	1.1	1.4	2	0.62	0.31164	1.04
12/12/2024 12:00	1.1	1.4	2	0.63	0.31332	1.04
12/12/2024 13:00	1.0	1.4	2	0.63	0.31638	1.05
12/12/2024 14:00	0.9	1.5	2	0.64	0.32010	1.07
12/12/2024 15:00	1.0	1.5	2	0.64	0.31830	1.06
12/12/2024 16:00	0.9	1.5	2	0.65	0.32520	1.08
12/12/2024 17:00	0.8	1.5	2	0.65	0.32646	1.09
12/12/2024 18:00	0.9	1.5	2	0.65	0.32574	1.09
12/12/2024 19:00	0.9	1.4	2	0.65	0.32586	1.09
12/12/2024 20:00	0.9	1.5	2	0.65	0.32292	1.08
12/12/2024 21:00	1.1	1.4	2	0.63	0.31440	1.05
12/12/2024 22:00	1.1	1.4	2	0.63	0.31458	1.05
12/12/2024 23:00	1.1	1.4	2	0.63	0.31554	1.05
Average/Sum#:	0.9	1.5	2	0.65	0.32477	1.08
Minimum:	0.4	1.4	2	0.62	0.31164	1.04
Maximum:	1.2	1.5	3	0.76	0.37812	1.26
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/13/2024 00:00	1.1	1.5	2	0.63	0.31548	1.05
12/13/2024 01:00	1.1	1.4	2	0.63	0.31536	1.05
12/13/2024 02:00	1.1	1.4	2	0.63	0.31566	1.05
12/13/2024 03:00	1.2	1.5	2	0.63	0.31476	1.05
12/13/2024 04:00	1.1	1.4	2	0.63	0.31476	1.05
12/13/2024 05:00	1.1	1.4	2	0.63	0.31488	1.05
12/13/2024 06:00	1.0	1.5	2	0.65	0.32262	1.08
12/13/2024 07:00	0.8	1.5	2	0.66	0.32772	1.09
12/13/2024 08:00	1.1	1.4	2	0.63	0.31428	1.05
12/13/2024 09:00	1.1	1.5	2	0.63	0.31584	1.05
12/13/2024 10:00	1.1	1.4	2	0.62	0.30978	1.03
12/13/2024 11:00	1.2	1.4	2	0.62	0.30780	1.03
12/13/2024 12:00	1.1	1.5	2	0.63	0.31314	1.04
12/13/2024 13:00	1.0	1.5	2	0.63	0.31572	1.05
12/13/2024 14:00	1.0	1.4	2	0.63	0.31560	1.05
12/13/2024 15:00	1.0	1.4	1	0.63	0.31284	1.04
12/13/2024 16:00	1.1	1.4	1	0.62	0.30822	1.03
12/13/2024 17:00	1.1	1.4	1	0.61	0.30618	1.02
12/13/2024 18:00	1.1	1.4	1	0.61	0.30744	1.02
12/13/2024 19:00	1.1	1.4	1	0.62	0.30900	1.03
12/13/2024 20:00	1.1	1.4	1	0.62	0.30762	1.03
12/13/2024 21:00	1.0	1.4	1	0.61	0.30684	1.02
12/13/2024 22:00	1.0	1.4	1	0.61	0.30720	1.02
12/13/2024 23:00	1.0	1.4	1	0.62	0.30858	1.03
Average/Sum#:	1.1	1.4	2	0.63	0.31281	1.04
Minimum:	0.8	1.4	1	0.61	0.30618	1.02
Maximum:	1.2	1.5	2	0.66	0.32772	1.09
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/14/2024 00:00	1.0	1.4	1	0.62	0.31026	1.03
12/14/2024 01:00	1.1	1.4	1	0.62	0.31002	1.03
12/14/2024 02:00	1.1	1.4	1	0.61	0.30702	1.02
12/14/2024 03:00	1.2	1.5	2	0.61	0.30666	1.02
12/14/2024 04:00	1.1	1.4	1	0.61	0.30684	1.02
12/14/2024 05:00	1.1	1.4	1	0.62	0.30894	1.03
12/14/2024 06:00	1.1	1.4	1	0.62	0.30846	1.03
12/14/2024 07:00	1.1	1.5	1	0.61	0.30714	1.02
12/14/2024 08:00	1.1	1.4	1	0.61	0.30468	1.02
12/14/2024 09:00	1.1	1.4	1	0.61	0.30666	1.02
12/14/2024 10:00	1.1	1.5	1	0.61	0.30726	1.02
12/14/2024 11:00	1.0	1.3	1	0.54	0.26982	0.90
12/14/2024 12:00	0.8	1.3	1	0.44	0.22008	0.73
12/14/2024 13:00	0.8	1.3	1	0.44	0.21942	0.73
12/14/2024 14:00	0.8	1.4	1	0.44	0.21840	0.73
12/14/2024 15:00	0.8	1.4	1	0.44	0.21966	0.73
12/14/2024 16:00	0.8	1.4	1	0.44	0.22038	0.73
12/14/2024 17:00	0.8	1.3	1	0.44	0.21900	0.73
12/14/2024 18:00	0.8	1.4	1	0.44	0.22074	0.74
12/14/2024 19:00	0.8	1.3	1	0.44	0.22158	0.74
12/14/2024 20:00	0.8	1.3	1	0.44	0.22146	0.74
12/14/2024 21:00	0.8	1.3	1	0.44	0.22176	0.74
12/14/2024 22:00	0.8	1.3	1	0.45	0.22254	0.74
12/14/2024 23:00	0.8	1.3	1	0.44	0.22230	0.74
Average/Sum#:	0.9	1.4	1	0.52	0.26255	0.87
Minimum:	0.8	1.3	1	0.44	0.21840	0.73
Maximum:	1.2	1.5	2	0.62	0.31026	1.03
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/15/2024 00:00	0.8	1.2	1	0.44	0.22230	0.74
12/15/2024 01:00	0.8	1.3	1	0.44	0.22206	0.74
12/15/2024 02:00	0.8	1.1	1	0.44	0.22188	0.74
12/15/2024 03:00	0.8	1.3	1	0.44	0.22248	0.74
12/15/2024 04:00	0.8	1.4	1	0.44	0.22248	0.74
12/15/2024 05:00	0.8	1.2	2	0.45	0.22362	0.75
12/15/2024 06:00	0.8	1.2	2	0.45	0.22338	0.74
12/15/2024 07:00	0.8	1.3	2	0.45	0.22380	0.75
12/15/2024 08:00	0.8	1.2	2	0.45	0.22344	0.74
12/15/2024 09:00	0.8	1.4	2	0.45	0.22332	0.74
12/15/2024 10:00	0.8	1.4	2	0.45	0.22332	0.74
12/15/2024 11:00	0.7	1.4	2	0.45	0.22308	0.74
12/15/2024 12:00	0.7	1.3	2	0.45	0.22278	0.74
12/15/2024 13:00	0.7	1.4	1	0.45	0.22254	0.74
12/15/2024 14:00	0.7	1.2	2	0.45	0.22260	0.74
12/15/2024 15:00	0.7	1.3	1	0.45	0.22290	0.74
12/15/2024 16:00	1.1	1.5	1	0.52	0.25992	0.87
12/15/2024 17:00	1.2	1.4	1	0.61	0.30570	1.02
12/15/2024 18:00	1.3	1.4	1	0.61	0.30648	1.02
12/15/2024 19:00	1.3	1.4	1	0.61	0.30708	1.02
12/15/2024 20:00	1.2	1.4	1	0.62	0.30768	1.03
12/15/2024 21:00	1.2	1.4	1	0.62	0.30756	1.03
12/15/2024 22:00	1.3	1.4	1	0.61	0.30732	1.02
12/15/2024 23:00	1.3	1.4	1	0.62	0.30762	1.03
Average/Sum#:	0.9	1.3	1	0.50	0.24897	0.83
Minimum:	0.7	1.1	1	0.44	0.22188	0.74
Maximum:	1.3	1.5	2	0.62	0.30768	1.03
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/16/2024 00:00	1.3	1.4	1	0.61	0.30744	1.02
12/16/2024 01:00	1.3	1.4	1	0.61	0.30708	1.02
12/16/2024 02:00	1.3	1.4	1	0.61	0.30714	1.02
12/16/2024 03:00	1.5	1.4	1	0.61	0.30720	1.02
12/16/2024 04:00	1.4	1.4	1	0.61	0.30684	1.02
12/16/2024 05:00	1.3	1.4	1	0.63	0.31254	1.04
12/16/2024 06:00	1.2	1.4	1	0.62	0.30906	1.03
12/16/2024 07:00	1.2	1.4	1	0.62	0.30852	1.03
12/16/2024 08:00	1.2	1.4	1	0.62	0.30936	1.03
12/16/2024 09:00	1.2	1.4	1	0.63	0.31446	1.05
12/16/2024 10:00	1.2	1.4	1	0.62	0.31026	1.03
12/16/2024 11:00	1.2	1.4	1	0.62	0.31074	1.04
12/16/2024 12:00	1.3	1.4	1	0.62	0.31014	1.03
12/16/2024 13:00	1.2	1.4	1	0.62	0.31014	1.03
12/16/2024 14:00	1.2	1.4	1	0.62	0.31020	1.03
12/16/2024 15:00	1.1	1.4	1	0.62	0.31104	1.04
12/16/2024 16:00	1.1	1.4	1	0.62	0.31164	1.04
12/16/2024 17:00	1.1	1.4	1	0.62	0.31014	1.03
12/16/2024 18:00	1.1	1.4	1	0.62	0.30966	1.03
12/16/2024 19:00	1.1	1.4	1	0.62	0.30936	1.03
12/16/2024 20:00	1.2	1.4	1	0.62	0.30918	1.03
12/16/2024 21:00	1.3	1.4	1	0.62	0.30918	1.03
12/16/2024 22:00	1.3	1.4	1	0.62	0.30900	1.03
12/16/2024 23:00	1.2	1.4	1	0.62	0.30900	1.03
Average/Sum#:	1.2	1.4	1	0.62	0.30956	1.03
Minimum:	1.1	1.4	1	0.61	0.30684	1.02
Maximum:	1.5	1.4	1	0.63	0.31446	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/17/2024 00:00	1.2	1.4	1	0.62	0.30828	1.03
12/17/2024 01:00	1.2	1.4	2	0.62	0.30762	1.03
12/17/2024 02:00	1.3	1.4	1	0.62	0.30792	1.03
12/17/2024 03:00	1.3	1.4	2	0.62	0.30918	1.03
12/17/2024 04:00	1.2	1.4	1	0.63	0.31326	1.04
12/17/2024 05:00	1.2	1.5	1	0.63	0.31422	1.05
12/17/2024 06:00	1.2	1.5	2	0.64	0.31788	1.06
12/17/2024 07:00	0.9	1.4	2	0.66	0.32922	1.10
12/17/2024 08:00	1.2	1.4	2	0.64	0.31800	1.06
12/17/2024 09:00	1.2	1.4	1	0.62	0.30990	1.03
12/17/2024 10:00	1.2	1.4	1	0.62	0.30960	1.03
12/17/2024 11:00	1.1	1.4	1	0.62	0.30972	1.03
12/17/2024 12:00	1.2	1.4	1	0.62	0.31062	1.04
12/17/2024 13:00	1.2	1.4	1	0.62	0.31206	1.04
12/17/2024 14:00	1.1	1.4	1	0.62	0.31248	1.04
12/17/2024 15:00	1.1	1.4	1	0.62	0.30912	1.03
12/17/2024 16:00	1.2	1.4	1	0.62	0.30846	1.03
12/17/2024 17:00	1.2	1.4	1	0.62	0.30834	1.03
12/17/2024 18:00	1.2	1.4	1	0.62	0.31080	1.04
12/17/2024 19:00	1.2	1.4	1	0.62	0.31110	1.04
12/17/2024 20:00	1.2	1.4	1	0.62	0.31134	1.04
12/17/2024 21:00	1.2	1.4	2	0.62	0.31098	1.04
12/17/2024 22:00	1.2	1.4	2	0.62	0.31050	1.04
12/17/2024 23:00	1.2	1.4	1	0.62	0.31014	1.03
Average/Sum#:	1.2	1.4	1	0.62	0.31170	1.04
Minimum:	0.9	1.4	1	0.62	0.30762	1.03
Maximum:	1.3	1.5	2	0.66	0.32922	1.10
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/18/2024 00:00	1.2	1.4	1	0.62	0.30912	1.03
12/18/2024 01:00	1.2	1.4	1	0.62	0.30906	1.03
12/18/2024 02:00	1.2	1.3	1	0.62	0.30852	1.03
12/18/2024 03:00	1.2	1.5	2	0.62	0.30852	1.03
12/18/2024 04:00	1.1	1.4	1	0.62	0.30882	1.03
12/18/2024 05:00	0.9	1.5	2	0.66	0.33144	1.10
12/18/2024 06:00	0.4	1.5	2	0.74	0.36870	1.23
12/18/2024 07:00	0.4	1.5	2	0.74	0.37140	1.24
12/18/2024 08:00	1.2	1.4	1	0.61	0.30732	1.02
12/18/2024 09:00	1.1	1.4	1	0.62	0.30972	1.03
12/18/2024 10:00	1.2	1.4	1	0.62	0.30840	1.03
12/18/2024 11:00	1.2	1.4	1	0.62	0.30852	1.03
12/18/2024 12:00	1.2	1.4	1	0.62	0.31122	1.04
12/18/2024 13:00	0.9	1.3	1	0.47	0.23520	0.78
12/18/2024 14:00	0.8	1.3	1	0.44	0.22008	0.73
12/18/2024 15:00	0.8	1.3	1	0.46	0.22962	0.77
12/18/2024 16:00	0.9	1.5	1	0.63	0.31566	1.05
12/18/2024 17:00	1.2	1.4	1	0.63	0.31428	1.05
12/18/2024 18:00	1.3	1.4	1	0.62	0.30906	1.03
12/18/2024 19:00	1.3	1.4	1	0.62	0.30822	1.03
12/18/2024 20:00	1.3	1.4	2	0.62	0.30918	1.03
12/18/2024 21:00	1.3	1.4	2	0.62	0.31056	1.04
12/18/2024 22:00	1.1	1.5	2	0.65	0.32514	1.08
12/18/2024 23:00	1.3	1.5	1	0.62	0.30918	1.03
Average/Sum#:	1.1	1.4	1	0.61	0.30612	1.02
Minimum:	0.4	1.3	1	0.44	0.22008	0.73
Maximum:	1.3	1.5	2	0.74	0.37140	1.24
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/19/2024 00:00	1.3	1.4	2	0.62	0.30858	1.03
12/19/2024 01:00	1.3	1.4	2	0.62	0.30900	1.03
12/19/2024 02:00	1.3	1.5	1	0.62	0.30978	1.03
12/19/2024 03:00	1.3	1.5	2	0.62	0.31014	1.03
12/19/2024 04:00	1.2	1.4	1	0.62	0.30978	1.03
12/19/2024 05:00	1.2	1.4	2	0.62	0.30996	1.03
12/19/2024 06:00	1.2	1.4	2	0.62	0.31026	1.03
12/19/2024 07:00	1.2	1.4	1	0.62	0.30816	1.03
12/19/2024 08:00	1.2	1.4	2	0.61	0.30738	1.02
12/19/2024 09:00	1.3	1.4	2	0.62	0.30786	1.03
12/19/2024 10:00	0.9	1.4	1	0.51	0.25368	0.85
12/19/2024 11:00	0.7	1.3	2	0.45	0.22338	0.74
12/19/2024 12:00	0.7	1.3	2	0.45	0.22284	0.74
12/19/2024 13:00	0.8	1.5	2	0.45	0.22302	0.74
12/19/2024 14:00	1.0	1.4	1	0.52	0.25812	0.86
12/19/2024 15:00	1.1	1.4	1	0.62	0.31242	1.04
12/19/2024 16:00	1.1	1.4	1	0.62	0.30810	1.03
12/19/2024 17:00	1.1	1.4	1	0.62	0.30816	1.03
12/19/2024 18:00	1.1	1.4	1	0.62	0.30804	1.03
12/19/2024 19:00	1.1	1.4	1	0.62	0.30804	1.03
12/19/2024 20:00	1.1	1.4	1	0.62	0.30858	1.03
12/19/2024 21:00	1.1	1.4	1	0.62	0.30828	1.03
12/19/2024 22:00	1.1	1.4	1	0.62	0.30948	1.03
12/19/2024 23:00	1.1	1.4	1	0.62	0.30822	1.03
Average/Sum#:	1.1	1.4	1	0.59	0.29380	0.98
Minimum:	0.7	1.3	1	0.45	0.22284	0.74
Maximum:	1.3	1.5	2	0.62	0.31242	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/20/2024 00:00	1.1	1.4	1	0.62	0.30810	1.03
12/20/2024 01:00	1.1	1.4	1	0.62	0.30834	1.03
12/20/2024 02:00	1.1	1.4	1	0.62	0.30804	1.03
12/20/2024 03:00	1.2	1.4	2	0.62	0.30798	1.03
12/20/2024 04:00	1.1	1.4	1	0.62	0.30762	1.03
12/20/2024 05:00	1.2	1.4	1	0.62	0.30768	1.03
12/20/2024 06:00	1.2	1.5	1	0.62	0.30780	1.03
12/20/2024 07:00	1.2	1.4	1	0.62	0.30780	1.03
12/20/2024 08:00	1.3	1.4	1	0.61	0.30726	1.02
12/20/2024 09:00	1.3	1.5	1	0.61	0.30690	1.02
12/20/2024 10:00	1.2	1.4	1	0.61	0.30744	1.02
12/20/2024 11:00	1.2	1.4	1	0.62	0.30768	1.03
12/20/2024 12:00	1.1	1.4	1	0.62	0.30792	1.03
12/20/2024 13:00	1.1	1.5	1	0.62	0.30858	1.03
12/20/2024 14:00	1.2	1.4	1	0.62	0.30804	1.03
12/20/2024 15:00	1.2	1.4	1	0.62	0.30870	1.03
12/20/2024 16:00	1.1	1.4	1	0.62	0.30774	1.03
12/20/2024 17:00	1.1	1.4	1	0.62	0.30822	1.03
12/20/2024 18:00	1.1	1.4	1	0.61	0.30714	1.02
12/20/2024 19:00	1.1	1.4	1	0.61	0.30744	1.02
12/20/2024 20:00	1.1	1.4	1	0.61	0.30732	1.02
12/20/2024 21:00	1.1	1.5	1	0.61	0.30738	1.02
12/20/2024 22:00	1.1	1.4	1	0.62	0.30810	1.03
12/20/2024 23:00	1.1	1.4	1	0.62	0.30828	1.03
Average/Sum#:	1.2	1.4	1	0.62	0.30781	1.03
Minimum:	1.1	1.4	1	0.61	0.30690	1.02
Maximum:	1.3	1.5	2	0.62	0.30870	1.03
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/21/2024 00:00	1.2	1.4	1	0.62	0.30900	1.03
12/21/2024 01:00	1.2	1.4	1	0.62	0.30900	1.03
12/21/2024 02:00	1.1	1.4	1	0.62	0.30846	1.03
12/21/2024 03:00	1.2	1.5	1	0.61	0.30726	1.02
12/21/2024 04:00	1.1	1.4	1	0.61	0.30714	1.02
12/21/2024 05:00	1.1	1.4	1	0.62	0.30792	1.03
12/21/2024 06:00	1.1	1.4	1	0.62	0.30858	1.03
12/21/2024 07:00	1.2	1.4	1	0.62	0.30972	1.03
12/21/2024 08:00	1.1	1.4	1	0.62	0.30810	1.03
12/21/2024 09:00	1.2	1.4	1	0.62	0.30834	1.03
12/21/2024 10:00	1.2	1.4	1	0.62	0.30954	1.03
12/21/2024 11:00	1.2	1.4	1	0.62	0.30984	1.03
12/21/2024 12:00	1.2	1.4	1	0.62	0.31080	1.04
12/21/2024 13:00	1.1	1.4	1	0.62	0.31176	1.04
12/21/2024 14:00	0.9	1.3	1	0.50	0.25008	0.83
12/21/2024 15:00	1.3	1.4	1	0.52	0.25986	0.87
12/21/2024 16:00	1.0	1.4	1	0.62	0.31224	1.04
12/21/2024 17:00	1.1	1.4	1	0.62	0.31200	1.04
12/21/2024 18:00	1.1	1.4	1	0.62	0.31122	1.04
12/21/2024 19:00	1.1	1.4	1	0.62	0.31128	1.04
12/21/2024 20:00	1.1	1.4	1	0.62	0.31068	1.04
12/21/2024 21:00	1.2	1.4	1	0.62	0.31026	1.03
12/21/2024 22:00	1.1	1.4	1	0.62	0.31146	1.04
12/21/2024 23:00	1.1	1.4	1	0.62	0.31104	1.04
Average/Sum#:	1.1	1.4	1	0.61	0.30523	1.02
Minimum:	0.9	1.3	1	0.50	0.25008	0.83
Maximum:	1.3	1.5	1	0.62	0.31224	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/22/2024 00:00	1.1	1.4	1	0.62	0.31116	1.04
12/22/2024 01:00	1.1	1.4	1	0.62	0.31080	1.04
12/22/2024 02:00	1.2	1.4	1	0.62	0.30996	1.03
12/22/2024 03:00	1.2	1.5	1	0.62	0.31002	1.03
12/22/2024 04:00	1.1	1.4	1	0.62	0.30996	1.03
12/22/2024 05:00	1.2	1.4	1	0.62	0.30936	1.03
12/22/2024 06:00	1.2	1.4	1	0.62	0.30966	1.03
12/22/2024 07:00	1.2	1.4	1	0.62	0.30972	1.03
12/22/2024 08:00	1.2	1.4	1	0.62	0.30996	1.03
12/22/2024 09:00	1.2	1.4	1	0.62	0.30972	1.03
12/22/2024 10:00	1.2	1.4	1	0.62	0.30936	1.03
12/22/2024 11:00	1.1	1.4	1	0.62	0.31098	1.04
12/22/2024 12:00	1.0	1.4	1	0.63	0.31278	1.04
12/22/2024 13:00	0.9	1.4	1	0.63	0.31368	1.05
12/22/2024 14:00	1.0	1.4	1	0.63	0.31482	1.05
12/22/2024 15:00	0.9	1.4	1	0.64	0.31794	1.06
12/22/2024 16:00	1.1	1.4	1	0.63	0.31470	1.05
12/22/2024 17:00	1.1	1.4	1	0.63	0.31320	1.04
12/22/2024 18:00	1.2	1.4	1	0.63	0.31266	1.04
12/22/2024 19:00	1.1	1.4	1	0.63	0.31368	1.05
12/22/2024 20:00	1.1	1.4	1	0.63	0.31386	1.05
12/22/2024 21:00	1.1	1.4	1	0.62	0.31182	1.04
12/22/2024 22:00	1.2	1.4	1	0.62	0.30984	1.03
12/22/2024 23:00	1.2	1.4	1	0.62	0.31080	1.04
Average/Sum#:	1.1	1.4	1	0.62	0.31169	1.04
Minimum:	0.9	1.4	1	0.62	0.30936	1.03
Maximum:	1.2	1.5	1	0.64	0.31794	1.06
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/23/2024 00:00	1.2	1.4	1	0.62	0.31110	1.04
12/23/2024 01:00	1.1	1.4	1	0.63	0.31362	1.05
12/23/2024 02:00	1.2	1.4	1	0.62	0.30888	1.03
12/23/2024 03:00	1.3	1.5	1	0.62	0.30912	1.03
12/23/2024 04:00	1.2	1.4	1	0.62	0.30912	1.03
12/23/2024 05:00	1.2	1.4	1	0.62	0.30966	1.03
12/23/2024 06:00	1.2	1.4	1	0.62	0.30954	1.03
12/23/2024 07:00	1.2	1.4	1	0.62	0.31020	1.03
12/23/2024 08:00	1.2	1.4	1	0.62	0.30990	1.03
12/23/2024 09:00	1.1	1.4	1	0.62	0.31110	1.04
12/23/2024 10:00	1.0	1.3	1	0.50	0.24876	0.83
12/23/2024 11:00	0.8	1.3	1	0.44	0.22152	0.74
12/23/2024 12:00	0.8	1.3	1	0.44	0.22212	0.74
12/23/2024 13:00	0.8	1.3	1	0.44	0.22206	0.74
12/23/2024 14:00	0.8	1.3	1	0.44	0.22242	0.74
12/23/2024 15:00	1.0	1.4	1	0.51	0.25494	0.85
12/23/2024 16:00	1.0	1.4	1	0.62	0.31152	1.04
12/23/2024 17:00	1.0	1.4	1	0.62	0.31074	1.04
12/23/2024 18:00	1.1	1.4	1	0.62	0.31062	1.04
12/23/2024 19:00	1.1	1.4	1	0.62	0.31044	1.03
12/23/2024 20:00	1.1	1.4	1	0.62	0.31032	1.03
12/23/2024 21:00	1.1	1.4	1	0.62	0.31212	1.04
12/23/2024 22:00	1.1	1.4	1	0.62	0.31194	1.04
12/23/2024 23:00	1.0	1.4	1	0.62	0.31200	1.04
Average/Sum#:	1.1	1.4	1	0.58	0.29099	0.97
Minimum:	0.8	1.3	1	0.44	0.22152	0.74
Maximum:	1.3	1.5	1	0.63	0.31362	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/24/2024 00:00	1.0	1.4	1	0.62	0.31230	1.04
12/24/2024 01:00	1.0	1.4	1	0.62	0.31170	1.04
12/24/2024 02:00	1.0	1.3	1	0.62	0.31158	1.04
12/24/2024 03:00	1.1	1.5	1	0.62	0.31110	1.04
12/24/2024 04:00	1.1	1.4	1	0.62	0.31050	1.04
12/24/2024 05:00	1.1	1.4	1	0.62	0.30966	1.03
12/24/2024 06:00	1.1	1.4	1	0.62	0.30792	1.03
12/24/2024 07:00	1.1	1.4	1	0.61	0.30678	1.02
12/24/2024 08:00	1.1	1.5	1	0.61	0.30684	1.02
12/24/2024 09:00	1.1	1.4	1	0.62	0.30762	1.03
12/24/2024 10:00	1.1	1.4	1	0.62	0.30972	1.03
12/24/2024 11:00	1.1	1.4	1	0.61	0.30546	1.02
12/24/2024 12:00	1.1	1.4	1	0.61	0.30660	1.02
12/24/2024 13:00	1.1	1.4	1	0.61	0.30732	1.02
12/24/2024 14:00	1.1	1.4	1	0.62	0.30822	1.03
12/24/2024 15:00	1.1	1.5	1	0.62	0.30822	1.03
12/24/2024 16:00	1.1	1.4	1	0.62	0.30756	1.03
12/24/2024 17:00	1.1	1.4	1	0.61	0.30690	1.02
12/24/2024 18:00	1.0	1.4	1	0.61	0.30552	1.02
12/24/2024 19:00	1.0	1.4	1	0.61	0.30630	1.02
12/24/2024 20:00	1.1	1.5	1	0.62	0.30870	1.03
12/24/2024 21:00	1.1	1.5	1	0.62	0.31020	1.03
12/24/2024 22:00	1.1	1.4	2	0.62	0.31008	1.03
12/24/2024 23:00	1.0	1.4	1	0.55	0.27726	0.92
Average/Sum#:	1.1	1.4	1	0.61	0.30725	1.02
Minimum:	1.0	1.3	1	0.55	0.27726	0.92
Maximum:	1.1	1.5	2	0.62	0.31230	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/25/2024 00:00	0.8	1.3	1	0.44	0.22236	0.74
12/25/2024 01:00	0.9	1.4	1	0.45	0.22290	0.74
12/25/2024 02:00	0.9	1.3	2	0.45	0.22338	0.74
12/25/2024 03:00	0.9	1.3	2	0.45	0.22326	0.74
12/25/2024 04:00	0.8	1.3	2	0.45	0.22392	0.75
12/25/2024 05:00	0.8	1.3	2	0.45	0.22386	0.75
12/25/2024 06:00	0.8	1.4	2	0.45	0.22320	0.74
12/25/2024 07:00	0.8	1.3	2	0.45	0.22350	0.75
12/25/2024 08:00	0.7	1.3	2	0.45	0.22302	0.74
12/25/2024 09:00	0.7	1.4	2	0.45	0.22314	0.74
12/25/2024 10:00	0.7	1.3	2	0.45	0.22284	0.74
12/25/2024 11:00	0.7	1.4	2	0.44	0.22230	0.74
12/25/2024 12:00	0.6	1.3	1	0.44	0.22236	0.74
12/25/2024 13:00	0.6	1.3	1	0.44	0.22230	0.74
12/25/2024 14:00	0.6	1.4	1	0.45	0.22254	0.74
12/25/2024 15:00	0.6	1.3	1	0.47	0.23520	0.78
12/25/2024 16:00	0.6	1.3	2	0.45	0.22350	0.75
12/25/2024 17:00	0.7	1.2	1	0.44	0.22158	0.74
12/25/2024 18:00	0.7	1.3	1	0.44	0.22134	0.74
12/25/2024 19:00	1.1	1.3	1	0.52	0.25854	0.86
12/25/2024 20:00	1.1	1.4	1	0.62	0.30870	1.03
12/25/2024 21:00	1.1	1.5	1	0.62	0.30852	1.03
12/25/2024 22:00	1.1	1.4	1	0.62	0.30816	1.03
12/25/2024 23:00	1.0	1.4	1	0.61	0.30744	1.02
Average/Sum#:	0.8	1.3	1	0.48	0.23908	0.80
Minimum:	0.6	1.2	1	0.44	0.22134	0.74
Maximum:	1.1	1.5	2	0.62	0.30870	1.03
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/26/2024 00:00	1.0	1.4	1	0.62	0.30816	1.03
12/26/2024 01:00	1.0	1.5	1	0.61	0.30732	1.02
12/26/2024 02:00	1.0	1.4	1	0.62	0.30756	1.03
12/26/2024 03:00	1.1	1.5	1	0.62	0.30792	1.03
12/26/2024 04:00	1.0	1.4	1	0.62	0.30828	1.03
12/26/2024 05:00	1.0	1.4	1	0.62	0.30804	1.03
12/26/2024 06:00	1.1	1.4	1	0.62	0.30792	1.03
12/26/2024 07:00	1.1	1.4	1	0.61	0.30738	1.02
12/26/2024 08:00	1.1	1.4	1	0.62	0.30750	1.03
12/26/2024 09:00	1.0	1.4	1	0.61	0.30738	1.02
12/26/2024 10:00	1.0	1.4	1	0.62	0.30828	1.03
12/26/2024 11:00	1.0	1.4	1	0.62	0.30918	1.03
12/26/2024 12:00	0.9	1.4	1	0.55	0.27258	0.91
12/26/2024 13:00	0.7	1.3	1	0.44	0.21984	0.73
12/26/2024 14:00	0.7	1.4	1	0.44	0.22062	0.74
12/26/2024 15:00	0.8	1.5	1	0.52	0.25950	0.87
12/26/2024 16:00	0.9	1.5	1	0.63	0.31416	1.05
12/26/2024 17:00	1.0	1.5	1	0.63	0.31410	1.05
12/26/2024 18:00	1.0	1.4	1	0.63	0.31344	1.04
12/26/2024 19:00	1.0	1.5	1	0.62	0.31206	1.04
12/26/2024 20:00	1.1	1.4	1	0.62	0.30870	1.03
12/26/2024 21:00	1.1	1.4	1	0.62	0.30852	1.03
12/26/2024 22:00	1.1	1.4	1	0.62	0.30858	1.03
12/26/2024 23:00	1.1	1.4	1	0.62	0.30792	1.03
Average/Sum#:	1.0	1.4	1	0.60	0.29812	1.00
Minimum:	0.7	1.3	1	0.44	0.21984	0.73
Maximum:	1.1	1.5	1	0.63	0.31416	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/27/2024 00:00	0.7	1.3	1	0.52	0.25986	0.87
12/27/2024 01:00	0.6	1.2	1	0.47	0.23748	0.79
12/27/2024 02:00	0.6	1.4	1	0.45	0.22332	0.74
12/27/2024 03:00	0.7	1.4	1	0.45	0.22314	0.74
12/27/2024 04:00	0.6	1.4	1	0.45	0.22596	0.75
12/27/2024 05:00	0.5	1.3	1	0.49	0.24540	0.82
12/27/2024 06:00	0.6	1.4	1	0.45	0.22686	0.76
12/27/2024 07:00	0.5	1.4	1	0.51	0.25356	0.85
12/27/2024 08:00	1.1	1.4	1	0.61	0.30696	1.02
12/27/2024 09:00	1.0	1.4	1	0.62	0.31032	1.03
12/27/2024 10:00	1.0	1.4	1	0.62	0.31008	1.03
12/27/2024 11:00	1.0	1.4	1	0.62	0.31056	1.04
12/27/2024 12:00	0.9	1.4	1	0.62	0.31080	1.04
12/27/2024 13:00	1.0	1.4	1	0.58	0.29202	0.97
12/27/2024 14:00	1.1	1.3	1	0.52	0.25902	0.86
12/27/2024 15:00	1.0	1.4	1	0.62	0.30852	1.03
12/27/2024 16:00	1.0	1.4	1	0.62	0.30912	1.03
12/27/2024 17:00	1.0	1.4	1	0.62	0.31188	1.04
12/27/2024 18:00	1.0	1.4	1	0.62	0.31026	1.03
12/27/2024 19:00	1.1	1.5	1	0.62	0.31104	1.04
12/27/2024 20:00	1.1	1.4	1	0.62	0.30990	1.03
12/27/2024 21:00	1.1	1.4	1	0.62	0.30996	1.03
12/27/2024 22:00	1.1	1.4	1	0.62	0.30990	1.03
12/27/2024 23:00	1.1	1.4	1	0.62	0.30966	1.03
Average/Sum#:	0.9	1.4	1	0.57	0.28273	0.94
Minimum:	0.5	1.2	1	0.45	0.22314	0.74
Maximum:	1.1	1.5	1	0.62	0.31188	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/28/2024 00:00	1.1	1.4	1	0.62	0.30954	1.03
12/28/2024 01:00	1.1	1.4	1	0.62	0.30972	1.03
12/28/2024 02:00	1.1	1.4	1	0.62	0.30972	1.03
12/28/2024 03:00	1.2	1.4	1	0.62	0.30990	1.03
12/28/2024 04:00	1.1	1.4	1	0.62	0.30996	1.03
12/28/2024 05:00	1.1	1.4	1	0.62	0.31014	1.03
12/28/2024 06:00	1.1	1.4	1	0.62	0.30990	1.03
12/28/2024 07:00	1.0	1.4	1	0.63	0.31584	1.05
12/28/2024 08:00	1.0	1.4	1	0.63	0.31398	1.05
12/28/2024 09:00	1.0	1.4	1	0.59	0.29484	0.98
12/28/2024 10:00	0.7	1.3	1	0.44	0.22104	0.74
12/28/2024 11:00	0.6	1.4	1	0.44	0.22128	0.74
12/28/2024 12:00	0.6	1.4	1	0.45	0.22302	0.74
12/28/2024 13:00	0.6	1.3	1	0.45	0.22296	0.74
12/28/2024 14:00	0.6	1.4	1	0.45	0.22272	0.74
12/28/2024 15:00	0.6	1.3	1	0.45	0.22626	0.75
12/28/2024 16:00	0.8	1.4	1	0.51	0.25470	0.85
12/28/2024 17:00	1.0	1.4	1	0.62	0.31194	1.04
12/28/2024 18:00	0.9	1.4	1	0.62	0.31188	1.04
12/28/2024 19:00	0.9	1.4	1	0.62	0.31176	1.04
12/28/2024 20:00	0.9	1.4	1	0.62	0.31122	1.04
12/28/2024 21:00	1.0	1.4	1	0.62	0.31122	1.04
12/28/2024 22:00	1.0	1.4	1	0.62	0.31128	1.04
12/28/2024 23:00	1.0	1.4	1	0.62	0.31104	1.04
Average/Sum#:	0.9	1.4	1	0.57	0.28608	0.95
Minimum:	0.6	1.3	1	0.44	0.22104	0.74
Maximum:	1.2	1.4	1	0.63	0.31584	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/29/2024 00:00	1.0	1.4	1	0.62	0.31092	1.04
12/29/2024 01:00	1.0	1.4	1	0.62	0.31152	1.04
12/29/2024 02:00	1.0	1.4	1	0.62	0.31182	1.04
12/29/2024 03:00	1.1	1.4	1	0.62	0.31164	1.04
12/29/2024 04:00	1.0	1.4	1	0.62	0.31170	1.04
12/29/2024 05:00	1.0	1.4	1	0.62	0.31128	1.04
12/29/2024 06:00	1.0	1.4	1	0.62	0.31080	1.04
12/29/2024 07:00	1.1	1.4	1	0.62	0.30990	1.03
12/29/2024 08:00	0.9	1.3	1	0.50	0.24852	0.83
12/29/2024 09:00	0.7	1.3	1	0.44	0.22248	0.74
12/29/2024 10:00	0.7	1.3	1	0.45	0.22302	0.74
12/29/2024 11:00	0.6	1.4	1	0.45	0.22374	0.75
12/29/2024 12:00	0.6	1.4	1	0.45	0.22404	0.75
12/29/2024 13:00	0.6	1.4	1	0.45	0.22404	0.75
12/29/2024 14:00	0.5	1.3	1	0.45	0.22422	0.75
12/29/2024 15:00	0.5	1.4	1	0.45	0.22404	0.75
12/29/2024 16:00	0.8	1.4	1	0.51	0.25668	0.86
12/29/2024 17:00	1.0	1.4	1	0.62	0.31122	1.04
12/29/2024 18:00	1.1	1.4	1	0.62	0.30798	1.03
12/29/2024 19:00	1.1	1.4	1	0.61	0.30732	1.02
12/29/2024 20:00	1.1	1.4	1	0.61	0.30708	1.02
12/29/2024 21:00	1.0	1.5	1	0.61	0.30684	1.02
12/29/2024 22:00	1.0	1.5	1	0.62	0.30762	1.03
12/29/2024 23:00	1.1	1.5	1	0.62	0.31062	1.04
Average/Sum#:	0.9	1.4	1	0.56	0.27996	0.93
Minimum:	0.5	1.3	1	0.44	0.22248	0.74
Maximum:	1.1	1.5	1	0.62	0.31182	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/30/2024 00:00	1.1	1.5	2	0.62	0.31080	1.04
12/30/2024 01:00	1.1	1.5	2	0.62	0.31002	1.03
12/30/2024 02:00	1.2	1.5	2	0.62	0.30936	1.03
12/30/2024 03:00	1.2	1.5	2	0.62	0.30882	1.03
12/30/2024 04:00	1.1	1.5	2	0.62	0.30882	1.03
12/30/2024 05:00	1.1	1.5	2	0.62	0.30912	1.03
12/30/2024 06:00	1.2	1.5	2	0.62	0.30768	1.03
12/30/2024 07:00	1.2	1.5	2	0.59	0.29670	0.99
12/30/2024 08:00	0.7	1.3	2	0.45	0.22290	0.74
12/30/2024 09:00	0.7	1.4	2	0.45	0.22308	0.74
12/30/2024 10:00	0.7	1.3	2	0.45	0.22308	0.74
12/30/2024 11:00	0.7	1.3	2	0.45	0.22278	0.74
12/30/2024 12:00	0.6	1.4	2	0.45	0.22278	0.74
12/30/2024 13:00	0.6	1.3	1	0.44	0.22212	0.74
12/30/2024 14:00	0.6	1.4	1	0.44	0.22194	0.74
12/30/2024 15:00	0.6	1.4	2	0.44	0.22230	0.74
12/30/2024 16:00	0.6	1.4	1	0.50	0.24888	0.83
12/30/2024 17:00	0.0	0.0	0	0.36	0.17754	0.59
12/30/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
12/30/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
12/30/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
12/30/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
12/30/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
12/30/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.8	1.3	2	0.52	0.25937	0.86
Minimum:	0.0	0.0	1	0.36	0.17754	0.59
Maximum:	1.2	1.5	2	0.62	0.31080	1.04
%SI	25.00	25.00	29.17	25.00	25.00	25.00

AQ57 CT1 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:25 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
12/31/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00