

DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	261237
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q4 2024 - Part 5 - searchable
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	1/22/2025 11:14:01 AM
Docketed Date:	1/22/2025

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/01/2024 00:00	1.1	1.3	-1	0.47	0.23466	0.78
10/01/2024 01:00	1.1	1.3	-1	0.47	0.23298	0.78
10/01/2024 02:00	1.1	1.4	-1	0.47	0.23334	0.78
10/01/2024 03:00	1.0	1.3	-1	0.47	0.23340	0.78
10/01/2024 04:00	1.1	1.4	-1	0.47	0.23592	0.79
10/01/2024 05:00	1.0	1.4	-1	0.56	0.28098	0.94
10/01/2024 06:00	1.1	1.4	-1	0.49	0.24414	0.81
10/01/2024 07:00	1.0	1.4	-1	0.47	0.23280	0.78
10/01/2024 08:00	0.9	1.3	-1	0.46	0.23214	0.77
10/01/2024 09:00	0.8	1.3	-1	0.46	0.23130	0.77
10/01/2024 10:00	0.8	1.4	-1	0.46	0.23094	0.77
10/01/2024 11:00	0.8	1.2	-1	0.46	0.23064	0.77
10/01/2024 12:00	0.8	1.2	-1	0.53	0.26526	0.88
10/01/2024 13:00	0.7	1.3	-1	0.57	0.28536	0.95
10/01/2024 14:00	0.7	1.4	-1	0.57	0.28542	0.95
10/01/2024 15:00	0.7	1.3	-1	0.53	0.26400	0.88
10/01/2024 16:00	0.8	1.3	-1	0.58	0.28926	0.96
10/01/2024 17:00	0.3	1.5	1	0.77	0.38526	1.28
10/01/2024 18:00	0.5	1.3	0	0.69	0.34728	1.16
10/01/2024 19:00	0.8	1.4	0	0.66	0.32928	1.10
10/01/2024 20:00	0.9	1.3	0	0.57	0.28686	0.96
10/01/2024 21:00	1.2	1.4	-1	0.47	0.23460	0.78
10/01/2024 22:00	1.0	1.3	-1	0.46	0.23184	0.77
10/01/2024 23:00	0.9	1.3	-1	0.46	0.23220	0.77
Average/Sum#:	0.9	1.3	-1	0.52	0.26208	0.87
Minimum:	0.3	1.2	-1	0.46	0.23064	0.77
Maximum:	1.2	1.5	1	0.77	0.38526	1.28
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/02/2024 00:00	1.0	1.3	-1	0.46	0.23244	0.77
10/02/2024 01:00	1.0	1.4	-1	0.47	0.23280	0.78
10/02/2024 02:00	1.1	1.3	-1	0.47	0.23448	0.78
10/02/2024 03:00	1.1	1.4	-1	0.47	0.23484	0.78
10/02/2024 04:00	1.0	1.3	-1	0.47	0.23502	0.78
10/02/2024 05:00	1.0	1.3	-1	0.47	0.23442	0.78
10/02/2024 06:00	1.0	1.3	-1	0.47	0.23370	0.78
10/02/2024 07:00	0.9	1.3	-1	0.47	0.23364	0.78
10/02/2024 08:00	0.9	1.3	-1	0.47	0.23310	0.78
10/02/2024 09:00	0.8	1.3	-1	0.46	0.23232	0.77
10/02/2024 10:00	0.7	1.3	-1	0.47	0.23262	0.78
10/02/2024 11:00	0.8	1.3	-1	0.54	0.26808	0.89
10/02/2024 12:00	0.3	1.4	0	0.76	0.37932	1.26
10/02/2024 13:00	0.2	1.5	1	0.81	0.40668	1.36
10/02/2024 14:00	0.1	1.5	1	0.80	0.40158	1.34
10/02/2024 15:00	0.2	1.5	1	0.78	0.39006	1.30
10/02/2024 16:00	0.3	1.5	0	0.75	0.37332	1.24
10/02/2024 17:00	0.1	1.5	1	0.80	0.40044	1.33
10/02/2024 18:00	0.5	1.3	0	0.68	0.33942	1.13
10/02/2024 19:00	0.7	1.3	0	0.67	0.33294	1.11
10/02/2024 20:00	0.8	1.3	0	0.66	0.33132	1.10
10/02/2024 21:00	0.9	1.3	0	0.58	0.28986	0.97
10/02/2024 22:00	0.9	1.3	-1	0.47	0.23688	0.79
10/02/2024 23:00	0.9	1.2	-1	0.50	0.24822	0.83
Average/Sum#:	0.7	1.4	0	0.58	0.29031	0.97
Minimum:	0.1	1.2	-1	0.46	0.23232	0.77
Maximum:	1.1	1.5	1	0.81	0.40668	1.36
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/03/2024 00:00	0.8	1.4	-1	0.46	0.23202	0.77
10/03/2024 01:00	0.8	1.3	-1	0.46	0.23226	0.77
10/03/2024 02:00	0.8	1.2	-1	0.46	0.23220	0.77
10/03/2024 03:00	0.8	1.3	-1	0.47	0.23262	0.78
10/03/2024 04:00	0.8	1.3	-1	0.47	0.23532	0.78
10/03/2024 05:00	0.8	1.3	-1	0.57	0.28296	0.94
10/03/2024 06:00	1.0	1.3	-1	0.59	0.29268	0.98
10/03/2024 07:00	0.8	1.4	0	0.69	0.34260	1.14
10/03/2024 08:00	1.0	1.4	0	0.66	0.33006	1.10
10/03/2024 09:00	0.9	1.4	0	0.66	0.33120	1.10
10/03/2024 10:00	0.8	1.4	0	0.67	0.33330	1.11
10/03/2024 11:00	0.6	1.3	0	0.69	0.34404	1.15
10/03/2024 12:00	0.2	1.5	1	0.81	0.40560	1.35
10/03/2024 13:00	0.2	1.5	1	0.82	0.40932	1.36
10/03/2024 14:00	0.2	1.5	1	0.82	0.40752	1.36
10/03/2024 15:00	0.2	1.5	1	0.82	0.40770	1.36
10/03/2024 16:00	0.2	1.5	1	0.81	0.40458	1.35
10/03/2024 17:00	0.2	1.4	1	0.79	0.39348	1.31
10/03/2024 18:00	0.6	1.4	0	0.68	0.33852	1.13
10/03/2024 19:00	0.7	1.4	0	0.67	0.33444	1.11
10/03/2024 20:00	0.8	1.3	0	0.67	0.33384	1.11
10/03/2024 21:00	0.8	1.3	0	0.63	0.31584	1.05
10/03/2024 22:00	0.9	1.3	-1	0.47	0.23550	0.79
10/03/2024 23:00	0.8	1.3	-1	0.47	0.23370	0.78
Average/Sum#:	0.7	1.4	0	0.64	0.31839	1.06
Minimum:	0.2	1.2	-1	0.46	0.23202	0.77
Maximum:	1.0	1.5	1	0.82	0.40932	1.36
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/04/2024 00:00	0.8	1.3	-1	0.47	0.23394	0.78
10/04/2024 01:00	0.8	1.3	-1	0.47	0.23400	0.78
10/04/2024 02:00	0.9	1.4	-1	0.47	0.23400	0.78
10/04/2024 03:00	0.9	1.3	-1	0.47	0.23418	0.78
10/04/2024 04:00	0.9	1.4	-1	0.47	0.23322	0.78
10/04/2024 05:00	0.8	1.2	-1	0.49	0.24300	0.81
10/04/2024 06:00	0.8	1.3	-1	0.50	0.25062	0.84
10/04/2024 07:00	0.9	1.3	-1	0.47	0.23520	0.78
10/04/2024 08:00	0.8	1.3	-1	0.47	0.23304	0.78
10/04/2024 09:00	0.8	1.2	-1	0.46	0.23244	0.77
10/04/2024 10:00	0.8	1.2	-1	0.46	0.23226	0.77
10/04/2024 11:00	0.8	1.2	-1	0.47	0.23406	0.78
10/04/2024 12:00	0.8	1.2	-1	0.48	0.24066	0.80
10/04/2024 13:00	0.8	1.2	-1	0.51	0.25518	0.85
10/04/2024 14:00	0.4	1.4	0	0.75	0.37476	1.25
10/04/2024 15:00	0.3	1.4	0	0.73	0.36588	1.22
10/04/2024 16:00	0.5	1.4	0	0.70	0.35070	1.17
10/04/2024 17:00	0.6	1.4	0	0.69	0.34386	1.15
10/04/2024 18:00	0.8	1.4	0	0.67	0.33282	1.11
10/04/2024 19:00	0.9	1.3	0	0.58	0.28866	0.96
10/04/2024 20:00	0.9	1.4	-1	0.47	0.23310	0.78
10/04/2024 21:00	0.9	1.4	-1	0.47	0.23364	0.78
10/04/2024 22:00	0.9	1.4	-1	0.47	0.23328	0.78
10/04/2024 23:00	0.8	1.2	-1	0.47	0.23502	0.78
Average/Sum#:	0.8	1.3	-1	0.53	0.26323	0.88
Minimum:	0.3	1.2	-1	0.46	0.23226	0.77
Maximum:	0.9	1.4	0	0.75	0.37476	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/05/2024 00:00	0.8	1.2	-1	0.47	0.23376	0.78
10/05/2024 01:00	0.8	1.3	-1	0.47	0.23352	0.78
10/05/2024 02:00	0.9	1.3	-1	0.47	0.23370	0.78
10/05/2024 03:00	1.0	1.3	-1	0.47	0.23382	0.78
10/05/2024 04:00	0.9	1.3	-1	0.47	0.23436	0.78
10/05/2024 05:00	0.9	1.3	-1	0.47	0.23538	0.78
10/05/2024 06:00	0.9	1.3	-1	0.47	0.23562	0.79
10/05/2024 07:00	0.9	1.3	-1	0.47	0.23538	0.78
10/05/2024 08:00	0.8	1.3	-1	0.47	0.23382	0.78
10/05/2024 09:00	0.8	1.3	-1	0.47	0.23280	0.78
10/05/2024 10:00	0.8	1.3	-1	0.46	0.23220	0.77
10/05/2024 11:00	0.7	1.2	-1	0.46	0.23214	0.77
10/05/2024 12:00	0.7	1.2	-1	0.53	0.26622	0.89
10/05/2024 13:00	0.7	1.4	0	0.61	0.30312	1.01
10/05/2024 14:00	0.2	1.4	0	0.76	0.38028	1.27
10/05/2024 15:00	0.3	1.4	0	0.75	0.37518	1.25
10/05/2024 16:00	0.2	1.5	1	0.79	0.39642	1.32
10/05/2024 17:00	0.2	1.4	0	0.78	0.38976	1.30
10/05/2024 18:00	0.3	1.4	0	0.75	0.37332	1.24
10/05/2024 19:00	0.2	1.4	0	0.77	0.38664	1.29
10/05/2024 20:00	0.2	1.4	0	0.77	0.38568	1.29
10/05/2024 21:00	0.3	1.5	0	0.77	0.38412	1.28
10/05/2024 22:00	0.4	1.4	0	0.75	0.37662	1.26
10/05/2024 23:00	0.6	1.4	0	0.71	0.35556	1.19
Average/Sum#:	0.6	1.3	-1	0.60	0.29914	1.00
Minimum:	0.2	1.2	-1	0.46	0.23214	0.77
Maximum:	1.0	1.5	1	0.79	0.39642	1.32
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/06/2024 00:00	0.7	1.4	0	0.70	0.34776	1.16
10/06/2024 01:00	0.8	1.4	0	0.70	0.34944	1.16
10/06/2024 02:00	0.8	1.4	0	0.69	0.34500	1.15
10/06/2024 03:00	1.0	1.4	0	0.68	0.33756	1.13
10/06/2024 04:00	0.8	1.4	0	0.70	0.34794	1.16
10/06/2024 05:00	0.8	1.4	0	0.70	0.34914	1.16
10/06/2024 06:00	0.7	1.4	0	0.72	0.35886	1.20
10/06/2024 07:00	0.9	1.4	0	0.69	0.34548	1.15
10/06/2024 08:00	0.9	1.4	0	0.68	0.34020	1.13
10/06/2024 09:00	0.4	1.4	0	0.75	0.37512	1.25
10/06/2024 10:00	0.2	1.5	0	0.78	0.38856	1.30
10/06/2024 11:00	0.2	1.5	0	0.78	0.38886	1.30
10/06/2024 12:00	0.2	1.5	1	0.79	0.39702	1.32
10/06/2024 13:00	0.2	1.5	1	0.79	0.39594	1.32
10/06/2024 14:00	0.2	1.5	1	0.80	0.39804	1.33
10/06/2024 15:00	0.2	1.4	1	0.78	0.39216	1.31
10/06/2024 16:00	0.5	1.3	0	0.68	0.34020	1.13
10/06/2024 17:00	0.3	1.5	1	0.79	0.39714	1.32
10/06/2024 18:00	0.2	1.5	1	0.80	0.39930	1.33
10/06/2024 19:00	0.2	1.5	1	0.81	0.40446	1.35
10/06/2024 20:00	0.3	1.4	0	0.79	0.39282	1.31
10/06/2024 21:00	0.3	1.5	0	0.78	0.39174	1.31
10/06/2024 22:00	0.3	1.4	0	0.77	0.38640	1.29
10/06/2024 23:00	0.4	1.4	0	0.75	0.37578	1.25
Average/Sum#:	0.5	1.4	0	0.75	0.37271	1.24
Minimum:	0.2	1.3	0	0.68	0.33756	1.13
Maximum:	1.0	1.5	1	0.81	0.40446	1.35
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/07/2024 00:00	0.4	1.4	0	0.75	0.37554	1.25
10/07/2024 01:00	0.4	1.4	0	0.74	0.37158	1.24
10/07/2024 02:00	0.7	1.4	0	0.70	0.35034	1.17
10/07/2024 03:00	0.7	1.4	0	0.71	0.35628	1.19
10/07/2024 04:00	0.5	1.4	0	0.75	0.37524	1.25
10/07/2024 05:00	0.4	1.5	0	0.77	0.38604	1.29
10/07/2024 06:00	0.4	1.4	0	0.77	0.38340	1.28
10/07/2024 07:00	0.7	1.4	0	0.72	0.35976	1.20
10/07/2024 08:00	0.4	1.4	0	0.77	0.38400	1.28
10/07/2024 09:00	0.4	1.5	0	0.77	0.38484	1.28
10/07/2024 10:00	0.3	1.5	0	0.79	0.39270	1.31
10/07/2024 11:00	0.3	1.5	0	0.80	0.39792	1.33
10/07/2024 12:00	0.3	1.5	1	0.80	0.39894	1.33
10/07/2024 13:00	0.3	1.5	1	0.80	0.39954	1.33
10/07/2024 14:00	0.3	1.5	1	0.80	0.40008	1.33
10/07/2024 15:00	0.3	1.5	1	0.80	0.40020	1.33
10/07/2024 16:00	0.3	1.5	1	0.80	0.40020	1.33
10/07/2024 17:00	0.3	1.5	1	0.80	0.39900	1.33
10/07/2024 18:00	0.3	1.5	1	0.80	0.39810	1.33
10/07/2024 19:00	0.3	1.5	1	0.79	0.39642	1.32
10/07/2024 20:00	0.3	1.4	1	0.79	0.39438	1.31
10/07/2024 21:00	0.4	1.5	0	0.77	0.38658	1.29
10/07/2024 22:00	0.4	1.4	0	0.76	0.37842	1.26
10/07/2024 23:00	0.6	1.4	0	0.74	0.36870	1.23
Average/Sum#:	0.4	1.5	0	0.77	0.38493	1.28
Minimum:	0.3	1.4	0	0.70	0.35034	1.17
Maximum:	0.7	1.5	1	0.80	0.40020	1.33
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/08/2024 00:00	1.3	1.4	0	0.63	0.31314	1.04
10/08/2024 01:00	1.1	1.3	-1	0.47	0.23736	0.79
10/08/2024 02:00	1.0	1.1	-1	0.47	0.23670	0.79
10/08/2024 03:00	1.1	1.4	-1	0.47	0.23604	0.79
10/08/2024 04:00	1.1	1.3	-1	0.50	0.25116	0.84
10/08/2024 05:00	1.0	1.3	-1	0.53	0.26568	0.89
10/08/2024 06:00	1.0	1.3	-1	0.55	0.27324	0.91
10/08/2024 07:00	1.0	1.3	-1	0.47	0.23418	0.78
10/08/2024 08:00	1.1	1.3	-1	0.54	0.26892	0.90
10/08/2024 09:00	1.1	1.4	0	0.66	0.32868	1.10
10/08/2024 10:00	1.0	1.3	-1	0.58	0.28854	0.96
10/08/2024 11:00	0.9	1.3	0	0.54	0.26760	0.89
10/08/2024 12:00	0.6	1.4	0	0.72	0.36036	1.20
10/08/2024 13:00	0.5	1.4	0	0.73	0.36270	1.21
10/08/2024 14:00	0.3	1.5	1	0.79	0.39276	1.31
10/08/2024 15:00	0.4	1.4	0	0.76	0.38088	1.27
10/08/2024 16:00	0.3	1.5	1	0.79	0.39546	1.32
10/08/2024 17:00	0.4	1.4	1	0.77	0.38610	1.29
10/08/2024 18:00	0.4	1.4	0	0.75	0.37710	1.26
10/08/2024 19:00	0.6	1.4	0	0.72	0.36144	1.20
10/08/2024 20:00	0.8	1.4	0	0.69	0.34446	1.15
10/08/2024 21:00	1.0	1.3	-1	0.53	0.26688	0.89
10/08/2024 22:00	1.0	1.3	-1	0.47	0.23400	0.78
10/08/2024 23:00	0.9	1.3	-1	0.47	0.23436	0.78
Average/Sum#:	0.8	1.4	0	0.61	0.30407	1.01
Minimum:	0.3	1.1	-1	0.47	0.23400	0.78
Maximum:	1.3	1.5	1	0.79	0.39546	1.32
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/09/2024 00:00	0.9	1.3	-1	0.47	0.23460	0.78
10/09/2024 01:00	0.9	1.3	-1	0.47	0.23484	0.78
10/09/2024 02:00	0.9	1.3	-1	0.47	0.23496	0.78
10/09/2024 03:00	0.9	1.4	-1	0.47	0.23538	0.78
10/09/2024 04:00	0.9	1.3	-1	0.47	0.23586	0.79
10/09/2024 05:00	0.9	1.3	-1	0.50	0.24768	0.83
10/09/2024 06:00	1.0	1.4	-1	0.50	0.25050	0.84
10/09/2024 07:00	0.9	1.4	-1	0.47	0.23562	0.79
10/09/2024 08:00	0.9	1.4	-1	0.47	0.23556	0.79
10/09/2024 09:00	0.9	1.3	-1	0.47	0.23520	0.78
10/09/2024 10:00	0.9	1.3	-1	0.47	0.23472	0.78
10/09/2024 11:00	0.9	1.3	-1	0.47	0.23502	0.78
10/09/2024 12:00	0.9	1.3	-1	0.47	0.23460	0.78
10/09/2024 13:00	0.9	1.3	-1	0.47	0.23412	0.78
10/09/2024 14:00	0.9	1.3	-1	0.47	0.23406	0.78
10/09/2024 15:00	0.9	1.3	-1	0.47	0.23430	0.78
10/09/2024 16:00	0.9	1.3	-1	0.50	0.25092	0.84
10/09/2024 17:00	0.9	1.3	-1	0.47	0.23550	0.79
10/09/2024 18:00	1.0	1.4	-1	0.47	0.23412	0.78
10/09/2024 19:00	0.9	1.3	-1	0.47	0.23424	0.78
10/09/2024 20:00	1.0	1.3	-1	0.47	0.23514	0.78
10/09/2024 21:00	0.9	1.3	-1	0.47	0.23544	0.78
10/09/2024 22:00	0.9	1.3	-1	0.47	0.23568	0.79
10/09/2024 23:00	0.9	1.3	-1	0.47	0.23568	0.79
Average/Sum#:	0.9	1.3	-1	0.47	0.23682	0.79
Minimum:	0.9	1.3	-1	0.47	0.23406	0.78
Maximum:	1.0	1.4	-1	0.50	0.25092	0.84
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/10/2024 00:00	1.0	1.3	-1	0.47	0.23580	0.79
10/10/2024 01:00	0.9	1.3	-1	0.47	0.23568	0.79
10/10/2024 02:00	0.9	1.2	-1	0.47	0.23568	0.79
10/10/2024 03:00	1.0	1.4	-1	0.47	0.23592	0.79
10/10/2024 04:00	1.0	1.3	-1	0.47	0.23598	0.79
10/10/2024 05:00	1.0	1.3	-1	0.53	0.26298	0.88
10/10/2024 06:00	1.0	1.3	-1	0.53	0.26268	0.88
10/10/2024 07:00	1.0	1.3	-1	0.47	0.23580	0.79
10/10/2024 08:00	1.0	1.4	-1	0.47	0.23616	0.79
10/10/2024 09:00	1.0	1.3	-1	0.52	0.25764	0.86
10/10/2024 10:00	0.9	1.2	-1	0.51	0.25464	0.85
10/10/2024 11:00	0.9	1.2	-1	0.50	0.25044	0.83
10/10/2024 12:00	0.9	1.2	-1	0.51	0.25566	0.85
10/10/2024 13:00	0.9	1.2	-1	0.48	0.23994	0.80
10/10/2024 14:00	1.0	1.3	-1	0.47	0.23550	0.79
10/10/2024 15:00	0.9	1.2	-1	0.48	0.24240	0.81
10/10/2024 16:00	0.9	1.3	-1	0.50	0.24918	0.83
10/10/2024 17:00	0.9	1.2	-1	0.50	0.24828	0.83
10/10/2024 18:00	1.0	1.3	-1	0.48	0.24180	0.81
10/10/2024 19:00	1.0	1.4	-1	0.47	0.23442	0.78
10/10/2024 20:00	1.0	1.3	-1	0.48	0.23760	0.79
10/10/2024 21:00	1.0	1.3	-1	0.47	0.23658	0.79
10/10/2024 22:00	1.0	1.3	-1	0.47	0.23550	0.79
10/10/2024 23:00	0.9	1.3	-1	0.50	0.25008	0.83
Average/Sum#:	1.0	1.3	-1	0.49	0.24360	0.81
Minimum:	0.9	1.2	-1	0.47	0.23442	0.78
Maximum:	1.0	1.4	-1	0.53	0.26298	0.88
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/11/2024 00:00	1.0	1.3	-1	0.48	0.23928	0.80
10/11/2024 01:00	1.0	1.3	-1	0.47	0.23574	0.79
10/11/2024 02:00	1.0	1.2	-1	0.47	0.23574	0.79
10/11/2024 03:00	1.0	1.3	-1	0.48	0.24024	0.80
10/11/2024 04:00	1.0	1.3	-1	0.50	0.25122	0.84
10/11/2024 05:00	1.0	1.3	-1	0.51	0.25662	0.86
10/11/2024 06:00	1.0	1.2	-1	0.50	0.25104	0.84
10/11/2024 07:00	1.0	1.1	-1	0.49	0.24678	0.82
10/11/2024 08:00	1.0	1.3	-1	0.48	0.23904	0.80
10/11/2024 09:00	1.0	1.3	-1	0.51	0.25332	0.84
10/11/2024 10:00	1.0	1.4	-1	0.47	0.23466	0.78
10/11/2024 11:00	1.0	1.3	-1	0.47	0.23412	0.78
10/11/2024 12:00	0.9	1.2	-1	0.47	0.23592	0.79
10/11/2024 13:00	0.9	1.3	-1	0.55	0.27360	0.91
10/11/2024 14:00	0.8	1.3	-1	0.59	0.29472	0.98
10/11/2024 15:00	0.5	1.5	0	0.78	0.39126	1.30
10/11/2024 16:00	1.0	1.3	0	0.60	0.29802	0.99
10/11/2024 17:00	0.7	1.4	0	0.73	0.36306	1.21
10/11/2024 18:00	0.9	1.4	0	0.70	0.35064	1.17
10/11/2024 19:00	0.8	1.4	0	0.72	0.35820	1.19
10/11/2024 20:00	0.5	1.4	0	0.76	0.37842	1.26
10/11/2024 21:00	0.7	1.5	0	0.73	0.36690	1.22
10/11/2024 22:00	0.8	1.4	0	0.71	0.35724	1.19
10/11/2024 23:00	1.2	1.4	-1	0.62	0.31176	1.04
Average/Sum#:	0.9	1.3	-1	0.57	0.28740	0.96
Minimum:	0.5	1.1	-1	0.47	0.23412	0.78
Maximum:	1.2	1.5	0	0.78	0.39126	1.30
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/12/2024 00:00	1.0	1.3	-1	0.47	0.23568	0.79
10/12/2024 01:00	1.0	1.3	-1	0.47	0.23568	0.79
10/12/2024 02:00	1.0	1.4	-1	0.47	0.23592	0.79
10/12/2024 03:00	1.0	1.4	-1	0.47	0.23598	0.79
10/12/2024 04:00	1.0	1.4	-1	0.47	0.23598	0.79
10/12/2024 05:00	1.0	1.3	-1	0.47	0.23580	0.79
10/12/2024 06:00	1.0	1.4	-1	0.47	0.23658	0.79
10/12/2024 07:00	1.0	1.2	-1	0.49	0.24690	0.82
10/12/2024 08:00	1.0	1.3	-1	0.47	0.23694	0.79
10/12/2024 09:00	0.9	1.3	-1	0.47	0.23700	0.79
10/12/2024 10:00	0.9	1.4	-1	0.47	0.23508	0.78
10/12/2024 11:00	0.9	1.3	-1	0.47	0.23478	0.78
10/12/2024 12:00	0.9	1.3	-1	0.47	0.23424	0.78
10/12/2024 13:00	0.9	1.3	-1	0.47	0.23472	0.78
10/12/2024 14:00	0.9	1.3	-1	0.48	0.23982	0.80
10/12/2024 15:00	0.9	1.4	-1	0.47	0.23538	0.78
10/12/2024 16:00	0.9	1.3	-1	0.53	0.26658	0.89
10/12/2024 17:00	0.9	1.3	-1	0.47	0.23682	0.79
10/12/2024 18:00	0.9	1.3	-1	0.47	0.23490	0.78
10/12/2024 19:00	0.9	1.3	-1	0.50	0.25086	0.84
10/12/2024 20:00	0.8	1.3	-1	0.59	0.29472	0.98
10/12/2024 21:00	0.9	1.3	-1	0.56	0.28170	0.94
10/12/2024 22:00	1.0	1.4	-1	0.47	0.23598	0.79
10/12/2024 23:00	0.9	1.2	-1	0.53	0.26442	0.88
Average/Sum#:	0.9	1.3	-1	0.49	0.24385	0.81
Minimum:	0.8	1.2	-1	0.47	0.23424	0.78
Maximum:	1.0	1.4	-1	0.59	0.29472	0.98
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/13/2024 00:00	1.0	1.3	-1	0.47	0.23550	0.79
10/13/2024 01:00	1.0	1.3	-1	0.47	0.23628	0.79
10/13/2024 02:00	0.9	1.2	-1	0.47	0.23550	0.79
10/13/2024 03:00	1.0	1.4	-1	0.47	0.23568	0.79
10/13/2024 04:00	1.0	1.3	-1	0.48	0.23778	0.79
10/13/2024 05:00	0.9	1.2	-1	0.55	0.27510	0.92
10/13/2024 06:00	1.0	1.3	-1	0.53	0.26394	0.88
10/13/2024 07:00	1.0	1.3	-1	0.47	0.23532	0.78
10/13/2024 08:00	1.0	1.4	-1	0.47	0.23544	0.78
10/13/2024 09:00	1.0	1.3	-1	0.47	0.23508	0.78
10/13/2024 10:00	1.0	1.3	-1	0.47	0.23472	0.78
10/13/2024 11:00	0.9	1.3	-1	0.47	0.23538	0.78
10/13/2024 12:00	0.9	1.3	-1	0.47	0.23430	0.78
10/13/2024 13:00	0.9	1.3	-1	0.47	0.23388	0.78
10/13/2024 14:00	0.9	1.2	-1	0.51	0.25506	0.85
10/13/2024 15:00	0.9	1.2	-1	0.50	0.25200	0.84
10/13/2024 16:00	0.8	1.3	-1	0.58	0.28932	0.96
10/13/2024 17:00	0.8	1.2	-1	0.59	0.29436	0.98
10/13/2024 18:00	0.8	1.3	-1	0.59	0.29442	0.98
10/13/2024 19:00	0.8	1.3	-1	0.59	0.29424	0.98
10/13/2024 20:00	0.9	1.3	-1	0.59	0.29442	0.98
10/13/2024 21:00	1.0	1.3	-1	0.49	0.24600	0.82
10/13/2024 22:00	1.0	1.4	-1	0.47	0.23538	0.78
10/13/2024 23:00	1.0	1.3	-1	0.47	0.23556	0.79
Average/Sum#:	0.9	1.3	-1	0.50	0.25228	0.84
Minimum:	0.8	1.2	-1	0.47	0.23388	0.78
Maximum:	1.0	1.4	-1	0.59	0.29442	0.98
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/14/2024 00:00	1.0	1.3	-1	0.47	0.23562	0.79
10/14/2024 01:00	1.0	1.4	-1	0.47	0.23496	0.78
10/14/2024 02:00	1.0	1.3	-1	0.47	0.23520	0.78
10/14/2024 03:00	1.0	1.2	-1	0.47	0.23550	0.79
10/14/2024 04:00	0.9	1.3	-1	0.50	0.24750	0.83
10/14/2024 05:00	0.9	1.3	-1	0.59	0.29574	0.99
10/14/2024 06:00	0.9	1.3	-1	0.58	0.28794	0.96
10/14/2024 07:00	0.9	1.3	-1	0.57	0.28464	0.95
10/14/2024 08:00	1.0	1.2	-1	0.47	0.23484	0.78
10/14/2024 09:00	0.9	1.3	-1	0.49	0.24414	0.81
10/14/2024 10:00	0.9	1.3	-1	0.47	0.23418	0.78
10/14/2024 11:00	0.9	1.3	-1	0.47	0.23394	0.78
10/14/2024 12:00	0.9	1.3	-1	0.47	0.23364	0.78
10/14/2024 13:00	0.8	1.3	-1	0.51	0.25560	0.85
10/14/2024 14:00	0.9	1.3	-1	0.50	0.24918	0.83
10/14/2024 15:00	0.9	1.4	-1	0.49	0.24480	0.82
10/14/2024 16:00	1.0	1.3	-1	0.54	0.27150	0.91
10/14/2024 17:00	0.6	1.4	0	0.72	0.35760	1.19
10/14/2024 18:00	0.9	1.4	0	0.67	0.33486	1.12
10/14/2024 19:00	1.0	1.3	-1	0.53	0.26460	0.88
10/14/2024 20:00	0.9	1.2	-1	0.58	0.28962	0.97
10/14/2024 21:00	0.9	1.3	-1	0.54	0.27072	0.90
10/14/2024 22:00	1.0	1.3	-1	0.47	0.23688	0.79
10/14/2024 23:00	0.9	1.3	-1	0.51	0.25356	0.85
Average/Sum#:	0.9	1.3	-1	0.52	0.26112	0.87
Minimum:	0.6	1.2	-1	0.47	0.23364	0.78
Maximum:	1.0	1.4	0	0.72	0.35760	1.19
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/15/2024 00:00	1.0	1.3	-1	0.47	0.23400	0.78
10/15/2024 01:00	1.0	1.3	-1	0.47	0.23496	0.78
10/15/2024 02:00	0.9	1.3	-1	0.47	0.23496	0.78
10/15/2024 03:00	1.0	1.4	-1	0.47	0.23526	0.78
10/15/2024 04:00	1.0	1.3	-1	0.48	0.23958	0.80
10/15/2024 05:00	0.9	1.3	-1	0.54	0.26814	0.89
10/15/2024 06:00	1.0	1.2	-1	0.53	0.26682	0.89
10/15/2024 07:00	1.0	1.4	-1	0.47	0.23532	0.78
10/15/2024 08:00	1.0	1.3	-1	0.47	0.23532	0.78
10/15/2024 09:00	1.0	1.4	-1	0.47	0.23502	0.78
10/15/2024 10:00	1.0	1.3	-1	0.47	0.23436	0.78
10/15/2024 11:00	0.9	1.3	-1	0.47	0.23418	0.78
10/15/2024 12:00	0.9	1.3	-1	0.47	0.23466	0.78
10/15/2024 13:00	0.9	1.3	-1	0.47	0.23442	0.78
10/15/2024 14:00	0.9	1.3	-1	0.47	0.23442	0.78
10/15/2024 15:00	0.9	1.2	-1	0.47	0.23436	0.78
10/15/2024 16:00	0.9	1.2	-1	0.48	0.23838	0.79
10/15/2024 17:00	0.9	1.3	-1	0.47	0.23406	0.78
10/15/2024 18:00	0.9	1.4	-1	0.47	0.23388	0.78
10/15/2024 19:00	0.9	1.3	-1	0.47	0.23424	0.78
10/15/2024 20:00	0.9	1.3	-1	0.47	0.23466	0.78
10/15/2024 21:00	0.9	1.3	-1	0.47	0.23490	0.78
10/15/2024 22:00	0.9	1.4	-1	0.47	0.23514	0.78
10/15/2024 23:00	1.0	1.3	-1	0.47	0.23526	0.78
Average/Sum#:	0.9	1.3	-1	0.48	0.23776	0.79
Minimum:	0.9	1.2	-1	0.47	0.23388	0.78
Maximum:	1.0	1.4	-1	0.54	0.26814	0.89
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/16/2024 00:00	1.0	1.4	-1	0.47	0.23520	0.78
10/16/2024 01:00	0.9	1.3	-1	0.47	0.23508	0.78
10/16/2024 02:00	0.9	1.2	-1	0.47	0.23496	0.78
10/16/2024 03:00	0.9	1.3	-1	0.47	0.23478	0.78
10/16/2024 04:00	0.9	1.3	-1	0.47	0.23742	0.79
10/16/2024 05:00	0.9	1.3	-1	0.55	0.27312	0.91
10/16/2024 06:00	0.9	1.3	-1	0.53	0.26292	0.88
10/16/2024 07:00	1.0	1.3	-1	0.47	0.23598	0.79
10/16/2024 08:00	0.9	1.3	-1	0.47	0.23448	0.78
10/16/2024 09:00	0.9	1.3	-1	0.47	0.23484	0.78
10/16/2024 10:00	0.9	1.3	-1	0.47	0.23526	0.78
10/16/2024 11:00	0.9	1.2	-1	0.47	0.23580	0.79
10/16/2024 12:00	0.9	1.4	-1	0.47	0.23574	0.79
10/16/2024 13:00	0.9	1.3	-1	0.47	0.23448	0.78
10/16/2024 14:00	0.9	1.4	-1	0.47	0.23472	0.78
10/16/2024 15:00	0.9	1.3	-1	0.47	0.23502	0.78
10/16/2024 16:00	0.9	1.3	-1	0.47	0.23490	0.78
10/16/2024 17:00	0.9	1.3	-1	0.47	0.23418	0.78
10/16/2024 18:00	0.9	1.3	-1	0.47	0.23388	0.78
10/16/2024 19:00	0.9	1.3	-1	0.47	0.23406	0.78
10/16/2024 20:00	0.9	1.3	-1	0.47	0.23442	0.78
10/16/2024 21:00	1.0	1.4	-1	0.47	0.23466	0.78
10/16/2024 22:00	1.0	1.3	-1	0.47	0.23478	0.78
10/16/2024 23:00	1.0	1.3	-1	0.47	0.23472	0.78
Average/Sum#:	0.9	1.3	-1	0.48	0.23773	0.79
Minimum:	0.9	1.2	-1	0.47	0.23388	0.78
Maximum:	1.0	1.4	-1	0.55	0.27312	0.91
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/17/2024 00:00	0.9	1.4	-1	0.47	0.23484	0.78
10/17/2024 01:00	0.9	1.4	-1	0.47	0.23544	0.78
10/17/2024 02:00	0.9	1.4	-1	0.47	0.23568	0.79
10/17/2024 03:00	1.0	1.3	-1	0.47	0.23598	0.79
10/17/2024 04:00	0.9	1.3	-1	0.47	0.23634	0.79
10/17/2024 05:00	0.9	1.4	-1	0.47	0.23688	0.79
10/17/2024 06:00	0.9	1.3	-1	0.53	0.26424	0.88
10/17/2024 07:00	1.0	1.4	-1	0.47	0.23616	0.79
10/17/2024 08:00	1.0	1.3	-1	0.47	0.23622	0.79
10/17/2024 09:00	1.0	2.0	-1	0.47	0.23532	0.78
10/17/2024 10:00	0.9	1.1	-1	0.38	0.18852	0.63
10/17/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
10/17/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
10/17/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
10/17/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
10/17/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
10/17/2024 16:00	0.0	1.3	0	0.00	0.00000	0.00
10/17/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
10/17/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
10/17/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
10/17/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
10/17/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
10/17/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
10/17/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.9	1.4	-1	0.47	0.23415	0.78
Minimum:	0.9	1.1	-1	0.38	0.18852	0.63
Maximum:	1.0	1.4	-1	0.53	0.26424	0.88
%SI	54.17	4.17	54.17	54.17	54.17	54.17

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/18/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
10/18/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
10/18/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
10/18/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
10/18/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
10/18/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
10/18/2024 06:00	0.0	1.3	0	0.00	0.00000	0.00
10/18/2024 07:00	0.0	1.3	0	0.00	0.00000	0.00
10/18/2024 08:00	0.0	1.3	0	0.00	0.00000	0.00
10/18/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
10/18/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
10/18/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
10/18/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
10/18/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
10/18/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
10/18/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
10/18/2024 16:00	0.0	1.3	0	0.00	0.00000	0.00
10/18/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
10/18/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
10/18/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
10/18/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
10/18/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
10/18/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
10/18/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/19/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
10/19/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
10/19/2024 02:00	0.0	1.3	0	0.00	0.00000	0.00
10/19/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
10/19/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
10/19/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
10/19/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
10/19/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
10/19/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
10/19/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
10/19/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
10/19/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
10/19/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
10/19/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
10/19/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
10/19/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
10/19/2024 16:00	0.0	1.3	0	0.00	0.00000	0.00
10/19/2024 17:00	0.0	1.3	0	0.00	0.00000	0.00
10/19/2024 18:00	0.0	1.3	0	0.00	0.00000	0.00
10/19/2024 19:00	0.0	1.3	0	0.00	0.00000	0.00
10/19/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
10/19/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
10/19/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
10/19/2024 23:00	0.0	1.3	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.4	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/20/2024 00:00	0.0	1.3	0	0.00	0.00000	0.00
10/20/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
10/20/2024 02:00	0.0	1.2	0	0.00	0.00000	0.00
10/20/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
10/20/2024 04:00	0.0	1.3	0	0.00	0.00000	0.00
10/20/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
10/20/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
10/20/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
10/20/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
10/20/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
10/20/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
10/20/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
10/20/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
10/20/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
10/20/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
10/20/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
10/20/2024 16:00	0.0	1.3	0	0.00	0.00000	0.00
10/20/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
10/20/2024 18:00	0.0	1.3	0	0.00	0.00000	0.00
10/20/2024 19:00	0.0	1.3	0	0.00	0.00000	0.00
10/20/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
10/20/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
10/20/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
10/20/2024 23:00	0.0	1.3	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.2	0	0.00	0.00000	0.00
Maximum:	0.0	1.4	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/21/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
10/21/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
10/21/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
10/21/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
10/21/2024 04:00	0.0	1.3	0	0.00	0.00000	0.00
10/21/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
10/21/2024 06:00	0.0	1.2	0	0.00	0.00000	0.00
10/21/2024 07:00	0.0	1.3	0	0.00	0.00000	0.00
10/21/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
10/21/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
10/21/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
10/21/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
10/21/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
10/21/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
10/21/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
10/21/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
10/21/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
10/21/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
10/21/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
10/21/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
10/21/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
10/21/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
10/21/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
10/21/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.2	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/22/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
10/22/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.4	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/23/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
10/23/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
10/23/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/24/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 11:00	0.0	1.3	0	0.00	0.00000	0.00
10/24/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
10/24/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
10/24/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.4	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/25/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
10/25/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
10/25/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
10/25/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
10/25/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
10/25/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
10/25/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
10/25/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
10/25/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
10/25/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
10/25/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
10/25/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
10/25/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
10/25/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
10/25/2024 14:00	0.0	1.3	0	0.00	0.00000	0.00
10/25/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
10/25/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
10/25/2024 17:00	0.0	1.3	0	0.00	0.00000	0.00
10/25/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
10/25/2024 19:00	0.0	1.3	0	0.00	0.00000	0.00
10/25/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
10/25/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
10/25/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
10/25/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/26/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
10/26/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
10/26/2024 02:00	0.0	1.3	0	0.00	0.00000	0.00
10/26/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
10/26/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
10/26/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
10/26/2024 06:00	0.0	1.3	0	0.00	0.00000	0.00
10/26/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
10/26/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
10/26/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
10/26/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
10/26/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
10/26/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
10/26/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
10/26/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
10/26/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
10/26/2024 16:00	0.0	1.3	0	0.00	0.00000	0.00
10/26/2024 17:00	0.0	1.3	0	0.00	0.00000	0.00
10/26/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
10/26/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
10/26/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
10/26/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
10/26/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
10/26/2024 23:00	0.0	1.3	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.4	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/27/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
10/27/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
10/27/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
10/27/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
10/27/2024 04:00	0.0	1.3	0	0.00	0.00000	0.00
10/27/2024 05:00	0.0	1.3	0	0.00	0.00000	0.00
10/27/2024 06:00	0.0	1.3	0	0.00	0.00000	0.00
10/27/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
10/27/2024 08:00	0.0	1.3	0	0.00	0.00000	0.00
10/27/2024 09:00	0.0	1.3	0	0.00	0.00000	0.00
10/27/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
10/27/2024 11:00	0.0	1.3	0	0.00	0.00000	0.00
10/27/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
10/27/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
10/27/2024 14:00	0.0	1.3	0	0.00	0.00000	0.00
10/27/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
10/27/2024 16:00	0.0	1.3	0	0.00	0.00000	0.00
10/27/2024 17:00	0.0	1.3	0	0.00	0.00000	0.00
10/27/2024 18:00	0.0	1.3	0	0.00	0.00000	0.00
10/27/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
10/27/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
10/27/2024 21:00	0.0	1.3	0	0.00	0.00000	0.00
10/27/2024 22:00	0.0	1.3	0	0.00	0.00000	0.00
10/27/2024 23:00	0.0	1.3	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.3	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.4	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/28/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
10/28/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
10/28/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
10/28/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
10/28/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
10/28/2024 05:00	0.0	1.3	0	0.00	0.00000	0.00
10/28/2024 06:00	0.0	1.3	0	0.00	0.00000	0.00
10/28/2024 07:00	0.0	1.3	0	0.10	0.05100	0.17
10/28/2024 08:00	1.1	1.3	0	0.43	0.21444	0.71
10/28/2024 09:00	1.2	1.4	-1	0.33	0.16512	0.55
10/28/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
10/28/2024 11:00	0.0	1.2	0	0.00	0.00000	0.00
10/28/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
10/28/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
10/28/2024 14:00	0.0	1.3	0	0.00	0.00000	0.00
10/28/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
10/28/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
10/28/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
10/28/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
10/28/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
10/28/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
10/28/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
10/28/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
10/28/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.8	1.4	-1	0.29	0.14352	0.48
Minimum:	0.0	1.2	-1	0.10	0.05100	0.17
Maximum:	1.2	1.4	0	0.43	0.21444	0.71
%SI	87.50	0.00	91.67	87.50	87.50	87.50

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/29/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
10/29/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
10/29/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
10/29/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
10/29/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
10/29/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
10/29/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
10/29/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
10/29/2024 08:00	0.0	1.4	0	0.17	0.08748	0.29
10/29/2024 09:00	0.0	1.3	0	0.52	0.26238	0.87
10/29/2024 10:00	1.2	0.0	0	0.67	0.33606	1.12
10/29/2024 11:00	1.2	0.0	-1	0.67	0.33738	1.12
10/29/2024 12:00	1.1	0.0	0	0.68	0.34020	1.13
10/29/2024 13:00	1.0	0.0	0	0.68	0.34176	1.14
10/29/2024 14:00	1.0	0.0	0	0.68	0.33972	1.13
10/29/2024 15:00	1.1	0.0	0	0.67	0.33642	1.12
10/29/2024 16:00	1.1	0.0	0	0.67	0.33552	1.12
10/29/2024 17:00	1.2	0.0	-1	0.48	0.24138	0.80
10/29/2024 18:00	1.2	0.0	-1	0.48	0.23892	0.80
10/29/2024 19:00	1.2	0.0	-1	0.48	0.23784	0.79
10/29/2024 20:00	1.3	0.0	-1	0.47	0.23748	0.79
10/29/2024 21:00	1.2	0.0	-1	0.48	0.23814	0.79
10/29/2024 22:00	1.2	0.0	-1	0.48	0.23946	0.80
10/29/2024 23:00	1.2	0.0	-1	0.49	0.24594	0.82
Average/Sum#:	1.2	1.3	-1	0.55	0.27476	0.91
Minimum:	1.0	0.0	-1	0.17	0.08748	0.29
Maximum:	1.3	1.4	0	0.68	0.34176	1.14
%SI	41.67	54.17	41.67	33.33	33.33	33.33

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/30/2024 00:00	1.2	0.0	-1	0.48	0.23994	0.80
10/30/2024 01:00	1.2	0.0	0	0.48	0.24012	0.80
10/30/2024 02:00	1.2	0.0	-1	0.48	0.24006	0.80
10/30/2024 03:00	1.2	0.0	0	0.48	0.23964	0.80
10/30/2024 04:00	1.2	0.0	0	0.48	0.24000	0.80
10/30/2024 05:00	1.2	0.0	0	0.55	0.27618	0.92
10/30/2024 06:00	1.2	0.0	-1	0.56	0.27786	0.93
10/30/2024 07:00	1.1	0.0	-1	0.59	0.29496	0.98
10/30/2024 08:00	1.4	0.0	-1	0.65	0.32382	1.08
10/30/2024 09:00	1.3	0.0	-1	0.68	0.34050	1.14
10/30/2024 10:00	1.2	0.0	0	0.69	0.34404	1.15
10/30/2024 11:00	1.0	0.0	0	0.68	0.34104	1.14
10/30/2024 12:00	1.0	0.0	0	0.68	0.34146	1.14
10/30/2024 13:00	1.0	0.0	0	0.68	0.34212	1.14
10/30/2024 14:00	1.0	0.0	0	0.68	0.34206	1.14
10/30/2024 15:00	1.0	0.0	0	0.68	0.34122	1.14
10/30/2024 16:00	1.0	0.0	0	0.68	0.34164	1.14
10/30/2024 17:00	1.0	0.0	0	0.68	0.33768	1.13
10/30/2024 18:00	1.1	0.0	0	0.67	0.33672	1.12
10/30/2024 19:00	1.1	0.0	0	0.67	0.33672	1.12
10/30/2024 20:00	1.1	0.0	0	0.67	0.33666	1.12
10/30/2024 21:00	1.1	0.0	-1	0.67	0.33690	1.12
10/30/2024 22:00	1.2	0.0	-1	0.67	0.33630	1.12
10/30/2024 23:00	1.2	0.0	-1	0.67	0.33618	1.12
Average/Sum#:	1.1	0.0	0	0.62	0.31099	1.04
Minimum:	1.0	0.0	-1	0.48	0.23964	0.80
Maximum:	1.4	0.0	0	0.69	0.34404	1.15
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
10/31/2024 00:00	1.2	0.0	-1	0.67	0.33504	1.12
10/31/2024 01:00	1.2	0.0	-1	0.67	0.33726	1.12
10/31/2024 02:00	1.2	0.0	-1	0.67	0.33726	1.12
10/31/2024 03:00	1.3	0.0	-1	0.67	0.33468	1.12
10/31/2024 04:00	1.2	0.0	-1	0.68	0.33768	1.13
10/31/2024 05:00	1.2	0.0	-1	0.68	0.33972	1.13
10/31/2024 06:00	1.2	0.0	-1	0.64	0.32046	1.07
10/31/2024 07:00	1.1	0.0	-1	0.48	0.23958	0.80
10/31/2024 08:00	1.0	0.0	-1	0.50	0.24756	0.83
10/31/2024 09:00	1.1	0.0	-1	0.48	0.23772	0.79
10/31/2024 10:00	1.0	0.0	-1	0.48	0.23784	0.79
10/31/2024 11:00	1.0	0.0	0	0.48	0.23790	0.79
10/31/2024 12:00	1.0	0.0	-1	0.48	0.23778	0.79
10/31/2024 13:00	1.0	0.0	-1	0.48	0.23802	0.79
10/31/2024 14:00	1.0	0.0	-1	0.48	0.23772	0.79
10/31/2024 15:00	1.0	0.0	-1	0.48	0.23802	0.79
10/31/2024 16:00	1.0	0.0	-1	0.48	0.23790	0.79
10/31/2024 17:00	1.0	0.0	-1	0.48	0.23760	0.79
10/31/2024 18:00	1.0	0.0	-1	0.47	0.23634	0.79
10/31/2024 19:00	1.1	0.0	-1	0.48	0.23784	0.79
10/31/2024 20:00	1.1	0.0	-1	0.48	0.23832	0.79
10/31/2024 21:00	1.1	0.0	-1	0.47	0.23682	0.79
10/31/2024 22:00	1.1	0.0	-1	0.47	0.23640	0.79
10/31/2024 23:00	1.1	0.0	-1	0.47	0.23670	0.79
Average/Sum#:	1.1	0.0	-1	0.53	0.26634	0.89
Minimum:	1.0	0.0	-1	0.47	0.23634	0.79
Maximum:	1.3	0.0	0	0.68	0.33972	1.13
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/01/2024 00:00	1.0	0.0	-1	0.47	0.23436	0.78
11/01/2024 01:00	1.0	0.0	-1	0.47	0.23484	0.78
11/01/2024 02:00	1.1	0.0	0	0.47	0.23454	0.78
11/01/2024 03:00	1.1	0.0	0	0.47	0.23424	0.78
11/01/2024 04:00	1.1	0.0	0	0.47	0.23442	0.78
11/01/2024 05:00	1.1	0.0	-1	0.47	0.23400	0.78
11/01/2024 06:00	1.0	0.0	-1	0.47	0.23406	0.78
11/01/2024 07:00	1.0	0.0	-1	0.50	0.24768	0.83
11/01/2024 08:00	1.0	0.0	-1	0.47	0.23700	0.79
11/01/2024 09:00	1.0	0.0	-1	0.47	0.23736	0.79
11/01/2024 10:00	1.0	0.0	-1	0.47	0.23730	0.79
11/01/2024 11:00	1.0	0.0	-1	0.47	0.23424	0.78
11/01/2024 12:00	1.0	0.0	-1	0.47	0.23262	0.78
11/01/2024 13:00	1.0	0.0	-1	0.46	0.23238	0.77
11/01/2024 14:00	1.0	0.0	-1	0.46	0.23226	0.77
11/01/2024 15:00	1.0	0.0	-1	0.46	0.23226	0.77
11/01/2024 16:00	1.0	0.0	-1	0.46	0.23226	0.77
11/01/2024 17:00	1.0	0.0	-1	0.46	0.23232	0.77
11/01/2024 18:00	1.0	0.0	-1	0.47	0.23286	0.78
11/01/2024 19:00	1.0	0.0	-1	0.47	0.23310	0.78
11/01/2024 20:00	1.0	0.0	-1	0.47	0.23322	0.78
11/01/2024 21:00	1.0	0.0	-1	0.47	0.23316	0.78
11/01/2024 22:00	1.0	0.0	0	0.47	0.23304	0.78
11/01/2024 23:00	1.0	0.0	0	0.47	0.23310	0.78
Average/Sum#:	1.0	0.0	-1	0.47	0.23444	0.78
Minimum:	1.0	0.0	-1	0.46	0.23226	0.77
Maximum:	1.1	0.0	0	0.50	0.24768	0.83
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/02/2024 00:00	1.0	0.0	0	0.47	0.23322	0.78
11/02/2024 01:00	1.0	0.0	-1	0.47	0.23340	0.78
11/02/2024 02:00	1.0	0.0	0	0.47	0.23364	0.78
11/02/2024 03:00	1.0	0.0	-1	0.47	0.23316	0.78
11/02/2024 04:00	1.0	0.0	-1	0.47	0.23328	0.78
11/02/2024 05:00	1.0	0.0	-1	0.47	0.23364	0.78
11/02/2024 06:00	1.0	0.0	-1	0.47	0.23436	0.78
11/02/2024 07:00	1.0	0.0	-1	0.47	0.23316	0.78
11/02/2024 08:00	1.0	0.0	-1	0.47	0.23334	0.78
11/02/2024 09:00	1.0	0.0	-1	0.47	0.23334	0.78
11/02/2024 10:00	1.0	0.0	-1	0.47	0.23316	0.78
11/02/2024 11:00	1.0	0.0	-1	0.47	0.23316	0.78
11/02/2024 12:00	1.0	0.0	-1	0.47	0.23298	0.78
11/02/2024 13:00	1.0	0.0	-1	0.47	0.23280	0.78
11/02/2024 14:00	1.0	0.0	-1	0.47	0.23280	0.78
11/02/2024 15:00	0.9	0.0	-1	0.47	0.23286	0.78
11/02/2024 16:00	1.0	0.0	-1	0.47	0.23304	0.78
11/02/2024 17:00	0.9	0.0	-1	0.47	0.23322	0.78
11/02/2024 18:00	1.0	0.0	-1	0.47	0.23322	0.78
11/02/2024 19:00	1.0	0.0	-1	0.47	0.23340	0.78
11/02/2024 20:00	1.0	0.0	-1	0.47	0.23370	0.78
11/02/2024 21:00	1.0	0.0	-1	0.47	0.23394	0.78
11/02/2024 22:00	1.0	0.0	0	0.47	0.23406	0.78
11/02/2024 23:00	1.0	0.0	0	0.47	0.23412	0.78
Average/Sum#:	1.0	0.0	-1	0.47	0.23338	0.78
Minimum:	0.9	0.0	-1	0.47	0.23280	0.78
Maximum:	1.0	0.0	0	0.47	0.23436	0.78
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/03/2024 00:00	1.0	0.0	-1	0.47	0.23484	0.78
11/03/2024 01:00	1.1	0.0	0	0.47	0.23466	0.78
11/03/2024 02:00	1.0	0.0	0	0.47	0.23442	0.78
11/03/2024 03:00	1.1	0.0	0	0.47	0.23472	0.78
11/03/2024 04:00	1.1	0.0	0	0.52	0.26016	0.87
11/03/2024 05:00	1.0	0.0	-1	0.60	0.29796	0.99
11/03/2024 06:00	1.1	0.0	0	0.48	0.23778	0.79
11/03/2024 07:00	1.0	0.0	-1	0.54	0.26844	0.89
11/03/2024 08:00	1.0	0.0	0	0.47	0.23400	0.78
11/03/2024 09:00	1.0	0.0	-1	0.47	0.23454	0.78
11/03/2024 10:00	1.0	0.0	-1	0.47	0.23388	0.78
11/03/2024 11:00	0.9	0.0	-1	0.47	0.23310	0.78
11/03/2024 12:00	0.9	0.0	-1	0.47	0.23298	0.78
11/03/2024 13:00	1.0	0.0	-1	0.47	0.23286	0.78
11/03/2024 14:00	1.0	0.0	-1	0.47	0.23286	0.78
11/03/2024 15:00	0.9	0.0	-1	0.48	0.24084	0.80
11/03/2024 16:00	0.9	0.0	-1	0.51	0.25734	0.86
11/03/2024 17:00	1.0	0.0	-1	0.47	0.23538	0.78
11/03/2024 18:00	1.0	0.0	-1	0.47	0.23466	0.78
11/03/2024 19:00	1.0	0.0	-1	0.47	0.23484	0.78
11/03/2024 20:00	1.0	0.0	-1	0.47	0.23484	0.78
11/03/2024 21:00	1.0	0.0	-1	0.47	0.23496	0.78
11/03/2024 22:00	1.0	0.0	-1	0.47	0.23406	0.78
11/03/2024 23:00	1.0	0.0	-1	0.47	0.23394	0.78
Average/Sum#:	1.0	0.0	-1	0.48	0.24075	0.80
Minimum:	0.9	0.0	-1	0.47	0.23286	0.78
Maximum:	1.1	0.0	0	0.60	0.29796	0.99
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/04/2024 00:00	1.0	0.0	-1	0.47	0.23424	0.78
11/04/2024 01:00	1.0	0.0	-1	0.47	0.23454	0.78
11/04/2024 02:00	1.0	0.0	-1	0.47	0.23436	0.78
11/04/2024 03:00	1.0	0.0	0	0.47	0.23454	0.78
11/04/2024 04:00	1.0	0.0	-1	0.47	0.23442	0.78
11/04/2024 05:00	0.9	0.0	-1	0.53	0.26568	0.89
11/04/2024 06:00	1.0	0.0	-1	0.58	0.28758	0.96
11/04/2024 07:00	1.1	0.0	0	0.50	0.25158	0.84
11/04/2024 08:00	1.0	0.0	0	0.47	0.23394	0.78
11/04/2024 09:00	1.0	0.0	0	0.47	0.23400	0.78
11/04/2024 10:00	1.0	0.0	-1	0.47	0.23388	0.78
11/04/2024 11:00	1.0	0.0	-1	0.47	0.23484	0.78
11/04/2024 12:00	1.0	0.0	-1	0.47	0.23508	0.78
11/04/2024 13:00	1.0	0.0	-1	0.47	0.23496	0.78
11/04/2024 14:00	0.9	0.0	-1	0.47	0.23526	0.78
11/04/2024 15:00	0.9	0.0	-1	0.50	0.24912	0.83
11/04/2024 16:00	0.9	0.0	-1	0.54	0.27120	0.90
11/04/2024 17:00	0.9	0.0	-1	0.58	0.28986	0.97
11/04/2024 18:00	0.9	0.0	-1	0.58	0.28980	0.97
11/04/2024 19:00	1.0	0.0	-1	0.57	0.28638	0.95
11/04/2024 20:00	1.0	0.0	-1	0.55	0.27282	0.91
11/04/2024 21:00	1.0	0.0	-1	0.58	0.29016	0.97
11/04/2024 22:00	1.0	0.0	-1	0.52	0.26148	0.87
11/04/2024 23:00	1.1	0.0	-1	0.47	0.23340	0.78
Average/Sum#:	1.0	0.0	-1	0.51	0.25263	0.84
Minimum:	0.9	0.0	-1	0.47	0.23340	0.78
Maximum:	1.1	0.0	0	0.58	0.29016	0.97
%SI	0.00	100.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/05/2024 00:00	1.1	0.0	-1	0.47	0.23364	0.78
11/05/2024 01:00	1.1	0.0	-1	0.47	0.23376	0.78
11/05/2024 02:00	1.1	0.0	-1	0.47	0.23400	0.78
11/05/2024 03:00	1.2	0.0	0	0.47	0.23430	0.78
11/05/2024 04:00	1.2	0.0	-1	0.47	0.23448	0.78
11/05/2024 05:00	1.1	0.0	-1	0.48	0.23772	0.79
11/05/2024 06:00	1.1	0.0	-1	0.48	0.23790	0.79
11/05/2024 07:00	1.3	0.0	0	0.47	0.23742	0.79
11/05/2024 08:00	1.1	0.0	0	0.57	0.28452	0.95
11/05/2024 09:00	1.0	0.0	0	0.47	0.23490	0.78
11/05/2024 10:00	0.0	0.0	0	0.37	0.18612	0.62
11/05/2024 11:00	0.9	0.0	-1	0.47	0.23472	0.78
11/05/2024 12:00	0.9	0.0	-1	0.47	0.23628	0.79
11/05/2024 13:00	0.9	0.0	-1	0.47	0.23496	0.78
11/05/2024 14:00	0.9	0.0	-1	0.48	0.24180	0.81
11/05/2024 15:00	0.8	0.0	-1	0.52	0.25926	0.86
11/05/2024 16:00	0.9	0.0	-1	0.56	0.28056	0.94
11/05/2024 17:00	0.9	0.0	0	0.48	0.23760	0.79
11/05/2024 18:00	0.9	0.0	0	0.50	0.24828	0.83
11/05/2024 19:00	0.9	0.0	0	0.47	0.23538	0.78
11/05/2024 20:00	0.9	0.0	0	0.49	0.24342	0.81
11/05/2024 21:00	1.0	0.0	0	0.47	0.23514	0.78
11/05/2024 22:00	0.9	0.0	0	0.48	0.24036	0.80
11/05/2024 23:00	0.9	0.0	-1	0.56	0.27996	0.93
Average/Sum#:	1.0	0.0	-1	0.48	0.24152	0.80
Minimum:	0.0	0.0	-1	0.37	0.18612	0.62
Maximum:	1.3	0.0	0	0.57	0.28452	0.95
%SI	0.00	100.00	4.17	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/06/2024 00:00	0.9	0.0	0	0.47	0.23682	0.79
11/06/2024 01:00	0.9	0.0	-1	0.47	0.23640	0.79
11/06/2024 02:00	1.0	0.0	0	0.47	0.23676	0.79
11/06/2024 03:00	1.0	0.0	0	0.47	0.23742	0.79
11/06/2024 04:00	0.9	0.0	0	0.54	0.27210	0.91
11/06/2024 05:00	0.9	0.0	-1	0.55	0.27552	0.92
11/06/2024 06:00	0.9	0.0	-1	0.59	0.29604	0.99
11/06/2024 07:00	0.9	0.0	-1	0.57	0.28464	0.95
11/06/2024 08:00	0.9	0.0	-1	0.58	0.29196	0.97
11/06/2024 09:00	0.9	0.0	0	0.67	0.33594	1.12
11/06/2024 10:00	1.0	0.0	-1	0.52	0.26244	0.87
11/06/2024 11:00	1.0	1.4	-1	0.44	0.21966	0.73
11/06/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
11/06/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
11/06/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
11/06/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
11/06/2024 16:00	0.0	1.2	0	0.00	0.00000	0.00
11/06/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
11/06/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
11/06/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
11/06/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
11/06/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
11/06/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
11/06/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.9	1.3	-1	0.53	0.26548	0.89
Minimum:	0.9	0.0	-1	0.44	0.21966	0.73
Maximum:	1.0	1.4	0	0.67	0.33594	1.12
%SI	50.00	41.67	50.00	50.00	50.00	50.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/07/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
11/07/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
11/07/2024 02:00	0.0	1.3	0	0.00	0.00000	0.00
11/07/2024 03:00	0.0	1.3	0	0.00	0.00000	0.00
11/07/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
11/07/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
11/07/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
11/07/2024 07:00	0.0	1.3	0	0.00	0.00000	0.00
11/07/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
11/07/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
11/07/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
11/07/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
11/07/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
11/07/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
11/07/2024 14:00	0.0	1.3	0	0.35	0.17466	0.58
11/07/2024 15:00	0.9	1.3	0	0.52	0.26172	0.87
11/07/2024 16:00	0.9	1.3	-1	0.58	0.28812	0.96
11/07/2024 17:00	0.9	1.4	-1	0.59	0.29520	0.98
11/07/2024 18:00	1.0	1.3	-1	0.59	0.29442	0.98
11/07/2024 19:00	1.1	1.3	-1	0.59	0.29352	0.98
11/07/2024 20:00	1.0	1.3	-1	0.59	0.29496	0.98
11/07/2024 21:00	1.0	1.3	-1	0.59	0.29538	0.98
11/07/2024 22:00	1.0	1.3	-1	0.59	0.29550	0.99
11/07/2024 23:00	1.0	1.4	-1	0.59	0.29580	0.99
Average/Sum#:	0.9	1.4	-1	0.56	0.27893	0.93
Minimum:	0.0	1.3	-1	0.35	0.17466	0.58
Maximum:	1.1	1.4	0	0.59	0.29580	0.99
%SI	58.33	0.00	62.50	58.33	58.33	58.33

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/08/2024 00:00	1.0	1.3	-1	0.59	0.29712	0.99
11/08/2024 01:00	1.0	1.4	-1	0.59	0.29664	0.99
11/08/2024 02:00	1.0	1.3	0	0.59	0.29688	0.99
11/08/2024 03:00	1.0	1.4	0	0.60	0.29754	0.99
11/08/2024 04:00	1.0	1.3	0	0.59	0.29736	0.99
11/08/2024 05:00	1.0	1.3	-1	0.60	0.29754	0.99
11/08/2024 06:00	1.0	1.4	0	0.60	0.29784	0.99
11/08/2024 07:00	1.1	1.4	0	0.53	0.26370	0.88
11/08/2024 08:00	1.1	1.4	0	0.45	0.22416	0.75
11/08/2024 09:00	0.0	1.3	0	0.11	0.05724	0.19
11/08/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
11/08/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
11/08/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
11/08/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
11/08/2024 14:00	0.0	1.3	0	0.00	0.00000	0.00
11/08/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
11/08/2024 16:00	0.0	1.3	0	0.00	0.00000	0.00
11/08/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
11/08/2024 18:00	0.0	1.4	0	0.37	0.18300	0.61
11/08/2024 19:00	1.5	1.3	-1	0.57	0.28446	0.95
11/08/2024 20:00	1.1	1.3	-1	0.59	0.29454	0.98
11/08/2024 21:00	1.1	1.2	-1	0.59	0.29466	0.98
11/08/2024 22:00	1.1	1.3	-1	0.59	0.29460	0.98
11/08/2024 23:00	1.1	1.3	-1	0.59	0.29472	0.98
Average/Sum#:	0.9	1.3	-1	0.53	0.26700	0.89
Minimum:	0.0	1.2	-1	0.11	0.05724	0.19
Maximum:	1.5	1.4	0	0.60	0.29784	0.99
%SI	33.33	0.00	41.67	33.33	33.33	33.33

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/09/2024 00:00	1.0	1.3	-1	0.59	0.29472	0.98
11/09/2024 01:00	1.1	1.4	0	0.50	0.24966	0.83
11/09/2024 02:00	1.1	1.5	0	0.51	0.25404	0.85
11/09/2024 03:00	1.1	1.5	0	0.48	0.23922	0.80
11/09/2024 04:00	1.0	1.3	0	0.54	0.27162	0.91
11/09/2024 05:00	1.1	1.3	0	0.53	0.26304	0.88
11/09/2024 06:00	1.1	1.4	0	0.52	0.26136	0.87
11/09/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
11/09/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
11/09/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
11/09/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
11/09/2024 11:00	0.0	1.3	0	0.00	0.00000	0.00
11/09/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
11/09/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
11/09/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
11/09/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
11/09/2024 16:00	0.0	1.3	0	0.00	0.00000	0.00
11/09/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
11/09/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
11/09/2024 19:00	0.0	1.3	0	0.00	0.00000	0.00
11/09/2024 20:00	0.0	1.3	0	0.00	0.00000	0.00
11/09/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
11/09/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
11/09/2024 23:00	0.0	1.3	0	0.00	0.00000	0.00
Average/Sum#:	1.1	1.4	0	0.52	0.26195	0.87
Minimum:	1.0	1.3	-1	0.48	0.23922	0.80
Maximum:	1.1	1.5	0	0.59	0.29472	0.98
%SI	70.83	0.00	70.83	70.83	70.83	70.83

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/10/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 02:00	0.0	1.3	0	0.00	0.00000	0.00
11/10/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
11/10/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
11/10/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.4	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/11/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
11/11/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
11/11/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
11/11/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/12/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
11/12/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
11/12/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
11/12/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/13/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
11/13/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
11/13/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
11/13/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
11/13/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
11/13/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
11/13/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
11/13/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
11/13/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
11/13/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
11/13/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
11/13/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
11/13/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
11/13/2024 13:00	0.0	1.5	0	0.00	0.00000	0.00
11/13/2024 14:00	0.0	1.5	0	0.00	0.00000	0.00
11/13/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
11/13/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
11/13/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
11/13/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
11/13/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
11/13/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
11/13/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
11/13/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
11/13/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/14/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
11/14/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
11/14/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
11/14/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
11/14/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
11/14/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
11/14/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
11/14/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
11/14/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
11/14/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
11/14/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
11/14/2024 11:00	0.0	1.5	0	0.00	0.00000	0.00
11/14/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
11/14/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
11/14/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
11/14/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
11/14/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
11/14/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
11/14/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
11/14/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
11/14/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
11/14/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
11/14/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
11/14/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/15/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
11/15/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
11/15/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
11/15/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
11/15/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
11/15/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
11/15/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
11/15/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
11/15/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
11/15/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
11/15/2024 10:00	0.0	1.5	0	0.00	0.00000	0.00
11/15/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
11/15/2024 12:00	0.0	1.4	0	0.04	0.01896	0.06
11/15/2024 13:00	0.0	1.4	0	0.12	0.05874	0.20
11/15/2024 14:00	0.0	1.4	0	0.21	0.10332	0.34
11/15/2024 15:00	0.0	1.5	0	0.22	0.10842	0.36
11/15/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
11/15/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
11/15/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
11/15/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
11/15/2024 20:00	0.0	0.0	0	0.06	0.02952	0.10
11/15/2024 21:00	0.0	0.0	0	0.31	0.15744	0.52
11/15/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
11/15/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.16	0.07940	0.26
Minimum:	0.0	1.4	0	0.04	0.01896	0.06
Maximum:	0.0	1.5	0	0.31	0.15744	0.52
%SI	83.33	33.33	100.00	75.00	75.00	75.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/16/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 08:00	0.0	0.0	0	0.22	0.10776	0.36
11/16/2024 09:00	0.0	0.0	0	0.41	0.20526	0.68
11/16/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
11/16/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.32	0.15651	0.52
Minimum:	0.0	0.0	0	0.22	0.10776	0.36
Maximum:	0.0	0.0	0	0.41	0.20526	0.68
%SI	100.00	100.00	100.00	91.67	91.67	91.67

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/17/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
11/17/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/18/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
11/18/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/19/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
11/19/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/20/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
11/20/2024 18:00	0.0	1.2	0	0.00	0.00000	0.00
11/20/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
11/20/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.9	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	1.4	0	0.00	0.00000	0.00
%SI	100.00	87.50	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/21/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
11/21/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	95.83	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/22/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
11/22/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
11/22/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
11/22/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
11/22/2024 04:00	0.0	1.3	0	0.00	0.00000	0.00
11/22/2024 05:00	0.0	1.3	0	0.00	0.00000	0.00
11/22/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
11/22/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
11/22/2024 08:00	0.0	1.3	0	0.00	0.00000	0.00
11/22/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
11/22/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
11/22/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
11/22/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
11/22/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
11/22/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
11/22/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
11/22/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
11/22/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
11/22/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
11/22/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
11/22/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
11/22/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
11/22/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
11/22/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.3	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	1.4	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/23/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
11/23/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
11/23/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
11/23/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
11/23/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
11/23/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
11/23/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
11/23/2024 07:00	0.0	1.3	0	0.00	0.00000	0.00
11/23/2024 08:00	0.0	1.3	0	0.00	0.00000	0.00
11/23/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
11/23/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
11/23/2024 11:00	0.0	1.3	0	0.00	0.00000	0.00
11/23/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
11/23/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
11/23/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
11/23/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
11/23/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
11/23/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
11/23/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
11/23/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
11/23/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
11/23/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
11/23/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
11/23/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.4	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/24/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
11/24/2024 11:00	0.0	1.3	0	0.00	0.00000	0.00
11/24/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
11/24/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.4	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/25/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
11/25/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
11/25/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/26/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
11/26/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
11/26/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
11/26/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
11/26/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
11/26/2024 05:00	0.0	1.3	0	0.00	0.00000	0.00
11/26/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
11/26/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
11/26/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
11/26/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
11/26/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
11/26/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
11/26/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
11/26/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
11/26/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
11/26/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
11/26/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
11/26/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
11/26/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
11/26/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
11/26/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
11/26/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
11/26/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
11/26/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/27/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
11/27/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
11/27/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
11/27/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/28/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
11/28/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
11/28/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 09:00	0.0	1.3	0	0.00	0.00000	0.00
11/28/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
11/28/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/29/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
11/29/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 17:00	0.0	1.5	0	0.00	0.00000	0.00
11/29/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
11/29/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
11/29/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
11/30/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
11/30/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
11/30/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
11/30/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
11/30/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
11/30/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
11/30/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
11/30/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
11/30/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
11/30/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
11/30/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
11/30/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
11/30/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
11/30/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
11/30/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
11/30/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
11/30/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
11/30/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
11/30/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
11/30/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
11/30/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
11/30/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
11/30/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
11/30/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/01/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 11:00	0.0	1.2	0	0.00	0.00000	0.00
12/01/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
12/01/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/01/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.2	0	0.00	0.00000	0.00
Maximum:	0.0	1.4	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/02/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
12/02/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/02/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/03/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/03/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/03/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/03/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
12/03/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/03/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/03/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/03/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/03/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/03/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/03/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
12/03/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/03/2024 12:00	0.0	1.2	0	0.00	0.00000	0.00
12/03/2024 13:00	0.0	1.2	0	0.00	0.00000	0.00
12/03/2024 14:00	0.0	1.2	0	0.00	0.00000	0.00
12/03/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
12/03/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/03/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/03/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/03/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/03/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/03/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
12/03/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/03/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.2	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/04/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/04/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/04/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/04/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
12/04/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/04/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/04/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/04/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/04/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/04/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/04/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
12/04/2024 11:00	0.0	1.2	0	0.00	0.00000	0.00
12/04/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
12/04/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
12/04/2024 14:00	0.0	1.3	0	0.00	0.00000	0.00
12/04/2024 15:00	0.0	1.2	0	0.00	0.00000	0.00
12/04/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/04/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/04/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/04/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
12/04/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
12/04/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
12/04/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/04/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.2	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/05/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
12/05/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
12/05/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/05/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	4.17	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/06/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/06/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/06/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/06/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
12/06/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/06/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/06/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/06/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/06/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/06/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/06/2024 10:00	0.0	1.2	0	0.00	0.00000	0.00
12/06/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
12/06/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
12/06/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
12/06/2024 14:00	0.0	1.2	0	0.00	0.00000	0.00
12/06/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
12/06/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/06/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/06/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/06/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/06/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/06/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
12/06/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/06/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.2	0	0.00	0.00000	0.00
Maximum:	0.0	1.4	0	0.00	0.00000	0.00
%SI	100.00	4.17	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/07/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/07/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/07/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/07/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
12/07/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/07/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/07/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/07/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/07/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/07/2024 09:00	0.0	1.3	0	0.00	0.00000	0.00
12/07/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
12/07/2024 11:00	0.0	1.3	0	0.00	0.00000	0.00
12/07/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
12/07/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
12/07/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
12/07/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
12/07/2024 16:00	0.0	1.3	0	0.00	0.00000	0.00
12/07/2024 17:00	0.0	1.3	0	0.00	0.00000	0.00
12/07/2024 18:00	0.0	1.2	0	0.00	0.00000	0.00
12/07/2024 19:00	0.0	1.3	0	0.00	0.00000	0.00
12/07/2024 20:00	0.0	1.3	0	0.00	0.00000	0.00
12/07/2024 21:00	0.0	1.3	0	0.00	0.00000	0.00
12/07/2024 22:00	0.0	1.3	0	0.00	0.00000	0.00
12/07/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.3	0	0.00	0.00000	0.00
Minimum:	0.0	1.2	0	0.00	0.00000	0.00
Maximum:	0.0	1.4	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/08/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/08/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/08/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
12/08/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
12/08/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/08/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/08/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/08/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/08/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/08/2024 09:00	0.0	1.3	0	0.00	0.00000	0.00
12/08/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
12/08/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/08/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
12/08/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
12/08/2024 14:00	0.0	1.3	0	0.00	0.00000	0.00
12/08/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
12/08/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/08/2024 17:00	0.0	1.3	0	0.00	0.00000	0.00
12/08/2024 18:00	0.0	1.3	0	0.00	0.00000	0.00
12/08/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/08/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/08/2024 21:00	0.0	1.3	0	0.00	0.00000	0.00
12/08/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/08/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/09/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/09/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/09/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/09/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
12/09/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/09/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/09/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/09/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/09/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/09/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/09/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
12/09/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/09/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
12/09/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
12/09/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
12/09/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
12/09/2024 16:00	0.0	1.3	0	0.00	0.00000	0.00
12/09/2024 17:00	0.0	1.3	0	0.00	0.00000	0.00
12/09/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/09/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/09/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
12/09/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
12/09/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/09/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/10/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 02:00	0.0	1.3	0	0.00	0.00000	0.00
12/10/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
12/10/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/10/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/11/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/11/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/11/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/11/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
12/11/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/11/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/11/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
12/11/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
12/11/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/11/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/11/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
12/11/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/11/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
12/11/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
12/11/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
12/11/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
12/11/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/11/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/11/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/11/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/11/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
12/11/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
12/11/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/11/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/12/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/12/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
12/12/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
12/12/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
12/12/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
12/12/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
12/12/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
12/12/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/12/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/12/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
12/12/2024 10:00	0.0	1.5	0	0.00	0.00000	0.00
12/12/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/12/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
12/12/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
12/12/2024 14:00	0.0	1.5	0	0.00	0.00000	0.00
12/12/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
12/12/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
12/12/2024 17:00	0.0	1.5	0	0.00	0.00000	0.00
12/12/2024 18:00	0.0	1.5	0	0.00	0.00000	0.00
12/12/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/12/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
12/12/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
12/12/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/12/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.5	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/13/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
12/13/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/13/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/13/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
12/13/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/13/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/13/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
12/13/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
12/13/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/13/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
12/13/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
12/13/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/13/2024 12:00	0.0	1.5	0	0.00	0.00000	0.00
12/13/2024 13:00	0.0	1.5	0	0.00	0.00000	0.00
12/13/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
12/13/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
12/13/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/13/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/13/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/13/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/13/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/13/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
12/13/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/13/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/14/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/14/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/14/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/14/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
12/14/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/14/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/14/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/14/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
12/14/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/14/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/14/2024 10:00	0.0	1.5	0	0.00	0.00000	0.00
12/14/2024 11:00	0.0	1.3	0	0.00	0.00000	0.00
12/14/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
12/14/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
12/14/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
12/14/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
12/14/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/14/2024 17:00	0.0	1.3	0	0.00	0.00000	0.00
12/14/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/14/2024 19:00	0.0	1.3	0	0.00	0.00000	0.00
12/14/2024 20:00	0.0	1.3	0	0.00	0.00000	0.00
12/14/2024 21:00	0.0	1.3	0	0.00	0.00000	0.00
12/14/2024 22:00	0.0	1.3	0	0.00	0.00000	0.00
12/14/2024 23:00	0.0	1.3	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/15/2024 00:00	0.0	1.2	0	0.00	0.00000	0.00
12/15/2024 01:00	0.0	1.3	0	0.00	0.00000	0.00
12/15/2024 02:00	0.0	1.1	0	0.00	0.00000	0.00
12/15/2024 03:00	0.0	1.3	0	0.00	0.00000	0.00
12/15/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/15/2024 05:00	0.0	1.2	0	0.00	0.00000	0.00
12/15/2024 06:00	0.0	1.2	0	0.00	0.00000	0.00
12/15/2024 07:00	0.0	1.3	0	0.00	0.00000	0.00
12/15/2024 08:00	0.0	1.2	0	0.00	0.00000	0.00
12/15/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/15/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
12/15/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/15/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
12/15/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
12/15/2024 14:00	0.0	1.2	0	0.00	0.00000	0.00
12/15/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
12/15/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
12/15/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/15/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/15/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/15/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/15/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
12/15/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/15/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.3	0	0.00	0.00000	0.00
Minimum:	0.0	1.1	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/16/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/16/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.4	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/17/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
12/17/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
12/17/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/17/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/18/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/18/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/18/2024 02:00	0.0	1.3	0	0.00	0.00000	0.00
12/18/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
12/18/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/18/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
12/18/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
12/18/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
12/18/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/18/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/18/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
12/18/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/18/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
12/18/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
12/18/2024 14:00	0.0	1.3	0	0.00	0.00000	0.00
12/18/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
12/18/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
12/18/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/18/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/18/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/18/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/18/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
12/18/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
12/18/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/19/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/19/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/19/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
12/19/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
12/19/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/19/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/19/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/19/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/19/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/19/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/19/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
12/19/2024 11:00	0.0	1.3	0	0.00	0.00000	0.00
12/19/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
12/19/2024 13:00	0.0	1.5	0	0.00	0.00000	0.00
12/19/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
12/19/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
12/19/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/19/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/19/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/19/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/19/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/19/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
12/19/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/19/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/20/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/20/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/20/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/20/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
12/20/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/20/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/20/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
12/20/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/20/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/20/2024 09:00	0.0	1.5	0	0.00	0.00000	0.00
12/20/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
12/20/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/20/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
12/20/2024 13:00	0.0	1.5	0	0.00	0.00000	0.00
12/20/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
12/20/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
12/20/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/20/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/20/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/20/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/20/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/20/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
12/20/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/20/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/21/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
12/21/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 14:00	0.0	1.3	0	0.00	0.00000	0.00
12/21/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/21/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/22/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
12/22/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/22/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.4	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/23/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/23/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/23/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/23/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
12/23/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/23/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/23/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/23/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/23/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/23/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/23/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
12/23/2024 11:00	0.0	1.3	0	0.00	0.00000	0.00
12/23/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
12/23/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
12/23/2024 14:00	0.0	1.3	0	0.00	0.00000	0.00
12/23/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
12/23/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/23/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/23/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/23/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/23/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/23/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
12/23/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/23/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/24/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/24/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/24/2024 02:00	0.0	1.3	0	0.00	0.00000	0.00
12/24/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
12/24/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/24/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/24/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/24/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/24/2024 08:00	0.0	1.5	0	0.00	0.00000	0.00
12/24/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/24/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
12/24/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/24/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
12/24/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
12/24/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
12/24/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
12/24/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/24/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/24/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/24/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/24/2024 20:00	0.0	1.5	0	0.00	0.00000	0.00
12/24/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
12/24/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/24/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/25/2024 00:00	0.0	1.3	0	0.00	0.00000	0.00
12/25/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/25/2024 02:00	0.0	1.3	0	0.00	0.00000	0.00
12/25/2024 03:00	0.0	1.3	0	0.00	0.00000	0.00
12/25/2024 04:00	0.0	1.3	0	0.00	0.00000	0.00
12/25/2024 05:00	0.0	1.3	0	0.00	0.00000	0.00
12/25/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/25/2024 07:00	0.0	1.3	0	0.00	0.00000	0.00
12/25/2024 08:00	0.0	1.3	0	0.00	0.00000	0.00
12/25/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/25/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
12/25/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/25/2024 12:00	0.0	1.3	0	0.00	0.00000	0.00
12/25/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
12/25/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
12/25/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
12/25/2024 16:00	0.0	1.3	0	0.00	0.00000	0.00
12/25/2024 17:00	0.0	1.2	0	0.00	0.00000	0.00
12/25/2024 18:00	0.0	1.3	0	0.00	0.00000	0.00
12/25/2024 19:00	0.0	1.3	0	0.00	0.00000	0.00
12/25/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/25/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
12/25/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/25/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.3	0	0.00	0.00000	0.00
Minimum:	0.0	1.2	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/26/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/26/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
12/26/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/26/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
12/26/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/26/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/26/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/26/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/26/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/26/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/26/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
12/26/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/26/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
12/26/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
12/26/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
12/26/2024 15:00	0.0	1.5	0	0.00	0.00000	0.00
12/26/2024 16:00	0.0	1.5	0	0.00	0.00000	0.00
12/26/2024 17:00	0.0	1.5	0	0.00	0.00000	0.00
12/26/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/26/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
12/26/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/26/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
12/26/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/26/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/27/2024 00:00	0.0	1.3	0	0.00	0.00000	0.00
12/27/2024 01:00	0.0	1.2	0	0.00	0.00000	0.00
12/27/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/27/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
12/27/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/27/2024 05:00	0.0	1.3	0	0.00	0.00000	0.00
12/27/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/27/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/27/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/27/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/27/2024 10:00	0.0	1.4	0	0.00	0.00000	0.00
12/27/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/27/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
12/27/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
12/27/2024 14:00	0.0	1.3	0	0.00	0.00000	0.00
12/27/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
12/27/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/27/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/27/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/27/2024 19:00	0.0	1.5	0	0.00	0.00000	0.00
12/27/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/27/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
12/27/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/27/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.2	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/28/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 08:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
12/28/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
12/28/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 15:00	0.0	1.3	0	0.00	0.00000	0.00
12/28/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 21:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 22:00	0.0	1.4	0	0.00	0.00000	0.00
12/28/2024 23:00	0.0	1.4	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.4	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/29/2024 00:00	0.0	1.4	0	0.00	0.00000	0.00
12/29/2024 01:00	0.0	1.4	0	0.00	0.00000	0.00
12/29/2024 02:00	0.0	1.4	0	0.00	0.00000	0.00
12/29/2024 03:00	0.0	1.4	0	0.00	0.00000	0.00
12/29/2024 04:00	0.0	1.4	0	0.00	0.00000	0.00
12/29/2024 05:00	0.0	1.4	0	0.00	0.00000	0.00
12/29/2024 06:00	0.0	1.4	0	0.00	0.00000	0.00
12/29/2024 07:00	0.0	1.4	0	0.00	0.00000	0.00
12/29/2024 08:00	0.0	1.3	0	0.00	0.00000	0.00
12/29/2024 09:00	0.0	1.3	0	0.00	0.00000	0.00
12/29/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
12/29/2024 11:00	0.0	1.4	0	0.00	0.00000	0.00
12/29/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
12/29/2024 13:00	0.0	1.4	0	0.00	0.00000	0.00
12/29/2024 14:00	0.0	1.3	0	0.00	0.00000	0.00
12/29/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
12/29/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/29/2024 17:00	0.0	1.4	0	0.00	0.00000	0.00
12/29/2024 18:00	0.0	1.4	0	0.00	0.00000	0.00
12/29/2024 19:00	0.0	1.4	0	0.00	0.00000	0.00
12/29/2024 20:00	0.0	1.4	0	0.00	0.00000	0.00
12/29/2024 21:00	0.0	1.5	0	0.00	0.00000	0.00
12/29/2024 22:00	0.0	1.5	0	0.00	0.00000	0.00
12/29/2024 23:00	0.0	1.5	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.4	0	0.00	0.00000	0.00
Minimum:	0.0	1.3	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	0.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/30/2024 00:00	0.0	1.5	0	0.00	0.00000	0.00
12/30/2024 01:00	0.0	1.5	0	0.00	0.00000	0.00
12/30/2024 02:00	0.0	1.5	0	0.00	0.00000	0.00
12/30/2024 03:00	0.0	1.5	0	0.00	0.00000	0.00
12/30/2024 04:00	0.0	1.5	0	0.00	0.00000	0.00
12/30/2024 05:00	0.0	1.5	0	0.00	0.00000	0.00
12/30/2024 06:00	0.0	1.5	0	0.00	0.00000	0.00
12/30/2024 07:00	0.0	1.5	0	0.00	0.00000	0.00
12/30/2024 08:00	0.0	1.3	0	0.00	0.00000	0.00
12/30/2024 09:00	0.0	1.4	0	0.00	0.00000	0.00
12/30/2024 10:00	0.0	1.3	0	0.00	0.00000	0.00
12/30/2024 11:00	0.0	1.3	0	0.00	0.00000	0.00
12/30/2024 12:00	0.0	1.4	0	0.00	0.00000	0.00
12/30/2024 13:00	0.0	1.3	0	0.00	0.00000	0.00
12/30/2024 14:00	0.0	1.4	0	0.00	0.00000	0.00
12/30/2024 15:00	0.0	1.4	0	0.00	0.00000	0.00
12/30/2024 16:00	0.0	1.4	0	0.00	0.00000	0.00
12/30/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
12/30/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
12/30/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
12/30/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
12/30/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
12/30/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
12/30/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	1.3	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	1.5	0	0.00	0.00000	0.00
%SI	100.00	25.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:26 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
12/31/2024 00:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 01:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 02:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 03:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 04:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 05:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 06:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 07:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 08:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 09:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 10:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 11:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 12:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 13:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 14:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 15:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 16:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 17:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 18:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 19:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 20:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 21:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 22:00	0.0	0.0	0	0.00	0.00000	0.00
12/31/2024 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

Monthly Summary By Day Report

Unit CT1

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:35 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
10/01/2024	13.31	47.98	5.7	11.70	19.49
10/02/2024	10.67	54.79	6.4	13.03	21.75
10/03/2024	11.08	60.58	7.1	14.33	23.89
10/04/2024	11.05	47.27	5.5	11.77	19.63
10/05/2024	8.36	56.31	6.8	13.45	22.46
10/06/2024	7.89	74.54	8.6	16.91	28.19
10/07/2024	4.15	77.41	9.2	17.53	29.21
10/08/2024	11.20	57.08	6.6	13.67	22.79
10/09/2024	10.71	42.81	4.8	10.49	17.50
10/10/2024	11.48	42.47	4.8	10.83	18.05
10/11/2024	12.46	53.09	6.1	12.83	21.40
10/12/2024	11.68	43.79	5.0	10.83	18.04
10/13/2024	11.82	44.47	5.4	11.20	18.66
10/14/2024	12.20	46.07	5.6	11.61	19.35
10/15/2024	11.44	41.89	4.8	10.49	17.55
10/16/2024	11.86	42.68	4.9	10.50	17.53
10/17/2024	13.68	41.73	4.8	10.59	17.62
10/18/2024	15.33	45.02	5.1	10.89	18.12
10/19/2024	15.92	43.87	4.8	10.54	17.52
10/20/2024	16.34	44.17	4.8	10.52	17.49
10/21/2024	18.67	54.71	6.1	13.06	21.70
10/22/2024	25.25	65.94	7.2	15.41	25.68
10/23/2024	25.57	66.94	7.2	15.43	25.77
10/24/2024	25.95	63.25	6.9	14.67	24.48
10/25/2024	26.52	56.60	6.1	13.38	22.28
10/26/2024	17.59	44.06	4.8	10.56	17.52
10/27/2024	15.48	42.75	4.8	10.57	17.56
10/28/2024	22.00	53.58	6.3	12.80	21.33
10/29/2024	27.58	27.35	2.9	6.12	10.19
10/30/2024	0.00	0.00	0.0	0.00	0.00
10/31/2024	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum:	437.24 sum	1,483.20 sum	169.1 sum	355.71 sum	592.75 sum
Daily Min:	4.15	27.35	2.9	6.12	10.19
Daily Max:	27.58	77.41	9.2	17.53	29.21
Oct 2024 - Oct 2024	437.24 sum	1,483.20 sum	169.1 sum	355.71 sum	592.75 sum
QTD:	437.24 sum	1,483.20 sum	169.1 sum	355.71 sum	592.75 sum
YTD 2024:	4,081.69 sum	11,398.68 sum	1,256.2 sum	2,620.61 sum	4,364.76 sum

Monthly Summary By Day Report

Unit CT1

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:35 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
11/01/2024	0.00	0.00	0.0	0.00	0.00
11/02/2024	0.00	0.00	0.0	0.00	0.00
11/03/2024	0.00	0.00	0.0	0.00	0.00
11/04/2024	0.00	0.00	0.0	0.00	0.00
11/05/2024	0.00	0.00	0.0	0.00	0.00
11/06/2024	75.29	39.02	2.9	6.25	10.43
11/07/2024	15.82	48.50	5.9	11.89	19.77
11/08/2024	17.43	49.67	6.3	12.27	20.46
11/09/2024	17.64	49.31	5.9	11.87	19.76
11/10/2024	27.90	60.26	6.6	13.97	23.35
11/11/2024	27.88	66.51	7.2	15.30	25.50
11/12/2024	28.43	61.56	6.8	14.24	23.80
11/13/2024	26.04	66.46	7.4	15.19	25.31
11/14/2024	22.13	63.33	7.0	14.55	24.31
11/15/2024	16.55	42.16	4.7	9.65	16.06
11/16/2024	0.00	0.00	0.0	0.00	0.00
11/17/2024	0.00	0.00	0.0	0.00	0.00
11/18/2024	0.00	0.00	0.0	0.00	0.00
11/19/2024	0.00	0.00	0.0	0.00	0.00
11/20/2024	119.95	19.76	0.3	0.70	1.17
11/21/2024	14.16	1.63	0.0	0.01	0.02
11/22/2024	82.30	74.80	6.8	14.18	23.59
11/23/2024	26.64	56.03	6.4	13.29	22.17
11/24/2024	30.20	58.76	6.5	13.79	22.98
11/25/2024	32.26	64.45	7.2	14.94	24.96
11/26/2024	31.19	65.12	7.2	14.91	24.85
11/27/2024	31.16	65.74	7.2	15.06	25.10
11/28/2024	33.38	65.56	7.2	14.95	24.88
11/29/2024	34.28	67.04	7.2	15.27	25.48
11/30/2024	33.88	66.92	7.3	15.26	25.45
Monthly Avg/Sum:	744.51 sum	1,152.59 sum	124.0 sum	257.54 sum	429.40 sum
Daily Min:	14.16	1.63	0.0	0.01	0.02
Daily Max:	119.95	74.80	7.4	15.30	25.50
Oct 2024 - Nov 2024	1,181.75 sum	2,635.79 sum	293.1 sum	613.25 sum	1,022.15 sum
QTD:	1,181.75 sum	2,635.79 sum	293.1 sum	613.25 sum	1,022.15 sum
YTD 2024:	4,826.20 sum	12,551.27 sum	1,380.2 sum	2,878.15 sum	4,794.16 sum

Monthly Summary By Day Report

Unit CT1

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:35 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:					
	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
12/01/2024	32.72	60.85	6.9	14.23	23.71
12/02/2024	34.02	65.19	7.2	15.01	25.03
12/03/2024	34.05	59.77	6.9	14.20	23.69
12/04/2024	30.13	62.56	7.2	14.70	24.47
12/05/2024	32.60	62.47	7.3	15.09	25.12
12/06/2024	31.37	59.53	7.1	14.60	24.32
12/07/2024	26.72	53.99	6.5	13.01	21.68
12/08/2024	18.60	45.40	4.8	10.77	17.98
12/09/2024	22.14	57.49	6.6	13.48	22.49
12/10/2024	32.59	65.48	7.2	15.20	25.33
12/11/2024	31.30	67.65	7.3	15.34	25.58
12/12/2024	26.63	69.04	7.4	15.58	25.99
12/13/2024	29.55	66.24	7.2	15.03	25.01
12/14/2024	22.72	53.19	6.0	12.58	20.98
12/15/2024	21.34	49.12	5.6	11.97	19.90
12/16/2024	33.58	64.91	7.2	14.85	24.73
12/17/2024	32.65	65.58	7.2	14.98	24.96
12/18/2024	28.90	64.74	7.1	14.71	24.49
12/19/2024	29.34	62.07	6.9	14.15	23.50
12/20/2024	32.10	65.74	7.2	14.81	24.65
12/21/2024	31.04	64.40	7.2	14.64	24.43
12/22/2024	30.87	65.29	7.2	14.98	24.93
12/23/2024	27.77	60.09	6.7	13.94	23.28
12/24/2024	29.64	65.08	7.2	14.73	24.58
12/25/2024	17.84	47.41	5.3	11.50	19.11
12/26/2024	27.10	63.00	7.0	14.35	23.88
12/27/2024	23.56	58.54	6.6	13.56	22.60
12/28/2024	24.28	59.47	6.6	13.72	22.87
12/29/2024	23.39	57.96	6.4	13.42	22.43
12/30/2024	30.87	40.64	4.2	9.08	15.10
12/31/2024	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum:	849.41 sum	1,802.89 sum	201.2 sum	418.21 sum	696.82 sum
Daily Min:	17.84	40.64	4.2	9.08	15.10
Daily Max:	34.05	69.04	7.4	15.58	25.99
Oct 2024 - Dec 2024	2,031.16 sum	4,438.68 sum	494.3 sum	1,031.46 sum	1,718.97 sum
QTD:	2,031.16 sum	4,438.68 sum	494.3 sum	1,031.46 sum	1,718.97 sum
YTD 2024:	5,675.61 sum	14,354.16 sum	1,581.4 sum	3,296.36 sum	5,490.98 sum

Startup / Shutdown Events

CT1



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 08:32 Location: Roseville, CA

Unit offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/29/2024 11:00	11/06/2024 09:00	191
11/15/2024 16:00	11/20/2024 15:00	120
11/20/2024 19:00	11/21/2024 22:00	28
12/30/2024 18:00	12/31/2024 23:00	30

Startup / Shutdown Events

CT1



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 08:32 Location: Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	369.00 Hour(s)
Offline Percentage:	16.71 %
Total Online:	1,839.00 Hour(s)
Online Percentage:	83.29 %

Startup / Shutdown Events

CT1



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 08:32 Location: Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/01/2024 16:07	10/01/2024 16:07	Shutdown	1
2	10/02/2024 11:36	10/02/2024 11:36	Shutdown	1
3	10/29/2024 09:53	10/29/2024 10:03	Shutdown	11
4	11/06/2024 10:02	11/06/2024 11:10	cold Startup	69
5	11/15/2024 15:21	11/15/2024 15:23	Shutdown	3
6	11/20/2024 16:44	11/20/2024 17:54	cold Startup	71
7	11/20/2024 18:20	11/20/2024 18:30	Shutdown	11
8	11/21/2024 23:44	11/21/2024 23:51	cold Startup	8
9	11/21/2024 23:51	11/21/2024 23:51	Shutdown	1
10	11/22/2024 00:06	11/22/2024 01:06	cold Startup	61
11	12/30/2024 16:57	12/30/2024 17:13	Shutdown	17

Startup / Shutdown Events

CT1



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 08:32 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	4	209	0.19
Warm Startup	0		0.00
Shutdown	7	45	0.04
Total Process Events:	11	254	0.23

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	1,834.48 Hour(s)
Total Startup Time:	209 Minute(s)
Total Shutdown Time:	45 Minute(s)
Total Startup/Shutdown Time:	254 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.23 %

Monthly Summary By Day Report

Unit CT2

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:34 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
10/01/2024	20.37	57.67	5.9	12.57	20.96
10/02/2024	17.02	64.50	6.5	13.95	23.21
10/03/2024	17.85	70.39	7.1	15.31	25.45
10/04/2024	17.94	57.95	5.9	12.66	21.06
10/05/2024	14.60	65.41	7.0	14.36	23.94
10/06/2024	15.14	82.64	8.7	17.90	29.82
10/07/2024	13.67	85.31	9.6	18.49	30.79
10/08/2024	21.09	67.42	7.4	14.60	24.34
10/09/2024	19.67	52.57	5.0	11.37	18.95
10/10/2024	21.09	54.09	5.5	11.69	19.53
10/11/2024	22.54	64.19	7.0	13.79	22.99
10/12/2024	20.46	54.22	5.3	11.67	19.52
10/13/2024	21.01	55.42	5.7	12.11	20.17
10/14/2024	21.47	57.89	6.0	12.55	20.91
10/15/2024	20.14	52.89	5.0	11.43	18.97
10/16/2024	19.73	53.26	5.0	11.42	18.99
10/17/2024	26.51	25.03	2.2	4.88	8.16
10/18/2024	0.00	0.00	0.0	0.00	0.00
10/19/2024	0.00	0.00	0.0	0.00	0.00
10/20/2024	0.00	0.00	0.0	0.00	0.00
10/21/2024	0.00	0.00	0.0	0.00	0.00
10/22/2024	0.00	0.00	0.0	0.00	0.00
10/23/2024	0.00	0.00	0.0	0.00	0.00
10/24/2024	0.00	0.00	0.0	0.00	0.00
10/25/2024	0.00	0.00	0.0	0.00	0.00
10/26/2024	0.00	0.00	0.0	0.00	0.00
10/27/2024	0.00	0.00	0.0	0.00	0.00
10/28/2024	60.18	15.52	0.2	0.53	0.87
10/29/2024	17.35	34.80	3.8	8.64	14.41
10/30/2024	31.31	67.39	6.7	14.90	24.89
10/31/2024	25.95	57.96	5.5	12.82	21.29
Monthly Avg/Sum:	465.09 sum	1,196.52 sum	121.0 sum	257.64 sum	429.22 sum
Daily Min:	13.67	15.52	0.2	0.53	0.87
Daily Max:	60.18	85.31	9.6	18.49	30.79
Oct 2024 - Oct 2024	465.09 sum	1,196.52 sum	121.0 sum	257.64 sum	429.22 sum
QTD:	465.09 sum	1,196.52 sum	121.0 sum	257.64 sum	429.22 sum
YTD 2024:	4,054.72 sum	9,725.73 sum	1,001.0 sum	2,134.63 sum	3,556.29 sum

Monthly Summary By Day Report

Unit CT2

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 11:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission



Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
11/01/2024	21.02	50.66	4.8	11.26	18.75
11/02/2024	20.43	51.73	4.8	11.28	18.72
11/03/2024	21.34	51.73	5.2	11.59	19.24
11/04/2024	22.19	54.41	5.8	12.14	20.20
11/05/2024	42.52	51.43	5.1	11.49	19.10
11/06/2024	31.02	28.53	3.1	6.32	10.58
11/07/2024	46.21	36.53	2.8	5.45	9.08
11/08/2024	57.55	46.43	4.2	8.31	13.84
11/09/2024	30.04	13.38	1.9	3.67	6.12
11/10/2024	0.00	0.00	0.0	0.00	0.00
11/11/2024	0.00	0.00	0.0	0.00	0.00
11/12/2024	0.00	0.00	0.0	0.00	0.00
11/13/2024	0.00	0.00	0.0	0.00	0.00
11/14/2024	0.00	0.00	0.0	0.00	0.00
11/15/2024	23.16	34.67	0.2	0.39	0.64
11/16/2024	0.00	0.00	0.1	0.28	0.45
11/17/2024	0.00	0.00	0.0	0.00	0.00
11/18/2024	0.00	0.00	0.0	0.00	0.00
11/19/2024	0.00	0.00	0.0	0.00	0.00
11/20/2024	0.00	0.00	0.0	0.00	0.00
11/21/2024	0.00	0.00	0.0	0.00	0.00
11/22/2024	0.00	0.00	0.0	0.00	0.00
11/23/2024	0.00	0.00	0.0	0.00	0.00
11/24/2024	0.00	0.00	0.0	0.00	0.00
11/25/2024	0.00	0.00	0.0	0.00	0.00
11/26/2024	0.00	0.00	0.0	0.00	0.00
11/27/2024	0.00	0.00	0.0	0.00	0.00
11/28/2024	0.00	0.00	0.0	0.00	0.00
11/29/2024	0.00	0.00	0.0	0.00	0.00
11/30/2024	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum:	315.48 sum	419.50 sum	38.0 sum	82.18 sum	136.72 sum
Daily Min:	20.43	13.38	0.1	0.28	0.45
Daily Max:	57.55	54.41	5.8	12.14	20.20
Oct 2024 - Nov 2024	780.57 sum	1,616.02 sum	159.0 sum	339.82 sum	565.94 sum
QTD:	780.57 sum	1,616.02 sum	159.0 sum	339.82 sum	565.94 sum
YTD 2024:	4,370.20 sum	10,145.23 sum	1,039.0 sum	2,216.81 sum	3,693.01 sum

Monthly Summary By Day Report

Unit CT2

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:34 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
12/01/2024	0.00	0.00	0.0	0.00	0.00
12/02/2024	0.00	0.00	0.0	0.00	0.00
12/03/2024	0.00	0.00	0.0	0.00	0.00
12/04/2024	0.00	0.00	0.0	0.00	0.00
12/05/2024	0.00	0.00	0.0	0.00	0.00
12/06/2024	0.00	0.00	0.0	0.00	0.00
12/07/2024	0.00	0.00	0.0	0.00	0.00
12/08/2024	0.00	0.00	0.0	0.00	0.00
12/09/2024	0.00	0.00	0.0	0.00	0.00
12/10/2024	0.00	0.00	0.0	0.00	0.00
12/11/2024	0.00	0.00	0.0	0.00	0.00
12/12/2024	0.00	0.00	0.0	0.00	0.00
12/13/2024	0.00	0.00	0.0	0.00	0.00
12/14/2024	0.00	0.00	0.0	0.00	0.00
12/15/2024	0.00	0.00	0.0	0.00	0.00
12/16/2024	0.00	0.00	0.0	0.00	0.00
12/17/2024	0.00	0.00	0.0	0.00	0.00
12/18/2024	0.00	0.00	0.0	0.00	0.00
12/19/2024	0.00	0.00	0.0	0.00	0.00
12/20/2024	0.00	0.00	0.0	0.00	0.00
12/21/2024	0.00	0.00	0.0	0.00	0.00
12/22/2024	0.00	0.00	0.0	0.00	0.00
12/23/2024	0.00	0.00	0.0	0.00	0.00
12/24/2024	0.00	0.00	0.0	0.00	0.00
12/25/2024	0.00	0.00	0.0	0.00	0.00
12/26/2024	0.00	0.00	0.0	0.00	0.00
12/27/2024	0.00	0.00	0.0	0.00	0.00
12/28/2024	0.00	0.00	0.0	0.00	0.00
12/29/2024	0.00	0.00	0.0	0.00	0.00
12/30/2024	0.00	0.00	0.0	0.00	0.00
12/31/2024	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum:	-	-	-	-	-
Daily Min:	-	-	-	-	-
Daily Max:	-	-	-	-	-
Oct 2024 - Dec 2024	780.57 sum	1,616.02 sum	159.0 sum	339.82 sum	565.94 sum
QTD:	780.57 sum	1,616.02 sum	159.0 sum	339.82 sum	565.94 sum
YTD 2024:	4,370.20 sum	10,145.23 sum	1,039.0 sum	2,216.81 sum	3,693.01 sum

Startup / Shutdown Events

CT2



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 08:34 **Location:** Roseville, CA

Unit offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/17/2024 11:00	10/28/2024 06:00	260
10/28/2024 10:00	10/29/2024 07:00	22
11/06/2024 12:00	11/07/2024 13:00	26
11/08/2024 10:00	11/08/2024 17:00	8
11/09/2024 07:00	11/15/2024 11:00	149
11/15/2024 16:00	11/15/2024 19:00	4
11/15/2024 22:00	11/16/2024 07:00	10
11/16/2024 10:00	12/31/2024 23:00	1094

Startup / Shutdown Events

CT2



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 08:34 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	1,573.00 Hour(s)
Offline Percentage:	71.24 %
Total Online:	635.00 Hour(s)
Online Percentage:	28.76 %

Startup / Shutdown Events

CT2



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 08:34 Location: Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/17/2024 10:07	10/17/2024 10:18	Shutdown	12
2	10/28/2024 07:51	10/28/2024 08:57	cold Startup	67
3	10/28/2024 08:10	10/28/2024 08:10	Shutdown	1
4	10/28/2024 08:21	10/28/2024 08:22	Shutdown	2
5	10/28/2024 08:25	10/28/2024 08:25	Shutdown	1
6	10/28/2024 09:04	10/28/2024 09:13	Shutdown	10
7	10/29/2024 08:45	10/29/2024 09:41	cold Startup	57
8	11/05/2024 09:59	11/05/2024 09:59	Shutdown	1
9	11/05/2024 10:19	11/05/2024 11:05	cold Startup	47
10	11/06/2024 11:45	11/06/2024 11:56	Shutdown	12
11	11/07/2024 14:22	11/07/2024 15:23	cold Startup	62
12	11/08/2024 08:50	11/08/2024 09:01	Shutdown	12
13	11/08/2024 18:21	11/08/2024 19:17	cold Startup	57
14	11/09/2024 06:48	11/09/2024 06:59	Shutdown	12
15	11/15/2024 12:49	11/15/2024 12:53	cold Startup	5
16	11/15/2024 12:53	11/15/2024 12:53	Shutdown	1
17	11/15/2024 13:23	11/15/2024 13:27	cold Startup	5
18	11/15/2024 13:27	11/15/2024 13:27	Shutdown	1
19	11/15/2024 13:47	11/15/2024 14:05	cold Startup	19
20	11/15/2024 13:57	11/15/2024 13:58	Shutdown	2
21	11/15/2024 14:04	11/15/2024 14:05	Shutdown	2
22	11/15/2024 14:56	11/15/2024 15:12	cold Startup	17

Startup / Shutdown Events

CT2



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 08:34 **Location:** Roseville, CA

Number	Start Time	End Time	Event Type	Duration
23	11/15/2024 15:12	11/15/2024 15:12	Shutdown	1
24	11/15/2024 15:34	11/15/2024 15:48	Warm Startup	15
25	11/15/2024 15:48	11/15/2024 15:48	Shutdown	1
26	11/15/2024 20:54	11/15/2024 21:38	Cold Startup	45
27	11/15/2024 21:05	11/15/2024 21:05	Shutdown	1
28	11/15/2024 21:37	11/15/2024 21:38	Shutdown	2
29	11/16/2024 08:33	11/16/2024 09:25	Cold Startup	53
30	11/16/2024 09:24	11/16/2024 09:25	Shutdown	2

Startup / Shutdown Events

CT2



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 08:34 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	11	434	1.16
Warm Startup	1	15	0.04
Shutdown	18	76	0.20
Total Process Events:	30	525	1.4

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	624.55 Hour(s)
Total Startup Time:	449 Minute(s)
Total Shutdown Time:	76 Minute(s)
Total Startup/Shutdown Time:	525 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	1.40 %

Replace the dates with the ones you need

10/1/2024 0:00
12/31/2024 0:00

1D

TOWER AVG.

519-AIT-9504-1 4344

10/1/24 0:00 4396.8
10/2/24 0:00 5246.1
10/3/24 0:00 5369.5
10/4/24 0:00 5712.1
10/5/24 0:00 5103.1
10/6/24 0:00 5421.1
10/7/24 0:00 5331.1
10/8/24 0:00 4960.1
10/9/24 0:00 5643.4
10/10/24 0:00 5461.0
10/11/24 0:00 5338.3
10/12/24 0:00 5435.4
10/13/24 0:00 5460.4
10/14/24 0:00 5469.4
10/15/24 0:00 5698.7
10/16/24 0:00 5350.5
10/17/24 0:00 4985.0
10/18/24 0:00 5601.2
10/19/24 0:00 4625.8
10/20/24 0:00 4773.2
10/21/24 0:00 4555.3
10/22/24 0:00 4911.6
10/23/24 0:00 4494.3
10/24/24 0:00 4930.0
10/25/24 0:00 5004.7
10/26/24 0:00 4880.3
10/27/24 0:00 4788.0
10/28/24 0:00 4779.5
10/29/24 0:00 4638.7
10/30/24 0:00 3865.8
10/31/24 0:00 4514.1
11/1/24 0:00 4050.9
11/2/24 0:00 4368.7
11/3/24 0:00 3715.5
11/4/24 0:00 4328.7
11/5/24 0:00 4369.0
11/6/24 0:00 4865.2
11/7/24 0:00 4402.1
11/8/24 0:00 4300.9
11/9/24 0:00 4221.8
11/10/24 0:00 4172.0
11/11/24 0:00 4660.0
11/12/24 0:00 4236.0
11/13/24 0:00 4437.9
11/14/24 0:00 4078.3
11/15/24 0:00 4566.1
11/16/24 0:00 2815.5
11/17/24 0:00 2217.0
11/18/24 0:00 2039.6

11/19/24 0:00	1736.8
11/20/24 0:00	1628.8
11/21/24 0:00	1724.1
11/22/24 0:00	1564.9
11/23/24 0:00	2445.2
11/24/24 0:00	3030.1
11/25/24 0:00	3066.3
11/26/24 0:00	3613.9
11/27/24 0:00	3598.5
11/28/24 0:00	3779.7
11/29/24 0:00	3464.4
11/30/24 0:00	3611.2
12/1/24 0:00	3741.6
12/2/24 0:00	3759.3
12/3/24 0:00	3935.1
12/4/24 0:00	4226.1
12/5/24 0:00	4280.0
12/6/24 0:00	4525.5
12/7/24 0:00	4836.3
12/8/24 0:00	4821.7
12/9/24 0:00	4719.3
12/10/24 0:00	4314.2
12/11/24 0:00	4830.6
12/12/24 0:00	4087.8
12/13/24 0:00	4742.0
12/14/24 0:00	4247.7
12/15/24 0:00	4755.6
12/16/24 0:00	4372.7
12/17/24 0:00	5142.4
12/18/24 0:00	4733.4
12/19/24 0:00	5032.2
12/20/24 0:00	4377.1
12/21/24 0:00	4695.0
12/22/24 0:00	4552.5
12/23/24 0:00	5068.6
12/24/24 0:00	4127.3
12/25/24 0:00	4471.1
12/26/24 0:00	3928.9
12/27/24 0:00	4414.5
12/28/24 0:00	3893.3
12/29/24 0:00	4469.4

Resize to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	4344	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00278016	

<u>Design drift rate</u>	0.005%
--------------------------	---------------

PM-10 pounds per day	8.97
----------------------	-------------

92	Days in quarter
----	-----------------

PM-10 pounds this quarter	826	4Q24
---------------------------	------------	-------------

fill only these

AQ-70

AQ-70 PM-10 emission rates from the cooling tower shall not exceed the following limits

Cooling Tower Emissions Limitations					
Pollutant	Lbs/day	Quarter 1	Quarter 2	Quarter 3	Quarter 4
PM 10	16.3	1471	1487	1504	1504

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

10/1/2024 0:00
12/31/2024 0:00

1D

TOWER AVG.

519-AIT-9504-1 4344

10/1/24 0:00 4396.8
10/2/24 0:00 5246.1
10/3/24 0:00 5369.5
10/4/24 0:00 5712.1
10/5/24 0:00 5103.1
10/6/24 0:00 5421.1
10/7/24 0:00 5331.1
10/8/24 0:00 4960.1
10/9/24 0:00 5643.4
10/10/24 0:00 5461.0
10/11/24 0:00 5338.3
10/12/24 0:00 5435.4
10/13/24 0:00 5460.4
10/14/24 0:00 5469.4
10/15/24 0:00 5698.7
10/16/24 0:00 5350.5
10/17/24 0:00 4985.0
10/18/24 0:00 5601.2
10/19/24 0:00 4625.8
10/20/24 0:00 4773.2
10/21/24 0:00 4555.3
10/22/24 0:00 4911.6
10/23/24 0:00 4494.3
10/24/24 0:00 4930.0
10/25/24 0:00 5004.7
10/26/24 0:00 4880.3
10/27/24 0:00 4788.0
10/28/24 0:00 4779.5
10/29/24 0:00 4638.7
10/30/24 0:00 3865.8
10/31/24 0:00 4514.1
11/1/24 0:00 4050.9
11/2/24 0:00 4368.7
11/3/24 0:00 3715.5
11/4/24 0:00 4328.7
11/5/24 0:00 4369.0
11/6/24 0:00 4865.2
11/7/24 0:00 4402.1
11/8/24 0:00 4300.9
11/9/24 0:00 4221.8
11/10/24 0:00 4172.0
11/11/24 0:00 4660.0
11/12/24 0:00 4236.0
11/13/24 0:00 4437.9
11/14/24 0:00 4078.3
11/15/24 0:00 4566.1
11/16/24 0:00 2815.5
11/17/24 0:00 2217.0
11/18/24 0:00 2039.6

11/19/24 0:00	1736.8
11/20/24 0:00	1628.8
11/21/24 0:00	1724.1
11/22/24 0:00	1564.9
11/23/24 0:00	2445.2
11/24/24 0:00	3030.1
11/25/24 0:00	3066.3
11/26/24 0:00	3613.9
11/27/24 0:00	3598.5
11/28/24 0:00	3779.7
11/29/24 0:00	3464.4
11/30/24 0:00	3611.2
12/1/24 0:00	3741.6
12/2/24 0:00	3759.3
12/3/24 0:00	3935.1
12/4/24 0:00	4226.1
12/5/24 0:00	4280.0
12/6/24 0:00	4525.5
12/7/24 0:00	4836.3
12/8/24 0:00	4821.7
12/9/24 0:00	4719.3
12/10/24 0:00	4314.2
12/11/24 0:00	4830.6
12/12/24 0:00	4087.8
12/13/24 0:00	4742.0
12/14/24 0:00	4247.7
12/15/24 0:00	4755.6
12/16/24 0:00	4372.7
12/17/24 0:00	5142.4
12/18/24 0:00	4733.4
12/19/24 0:00	5032.2
12/20/24 0:00	4377.1
12/21/24 0:00	4695.0
12/22/24 0:00	4552.5
12/23/24 0:00	5068.6
12/24/24 0:00	4127.3
12/25/24 0:00	4471.1
12/26/24 0:00	3928.9
12/27/24 0:00	4414.5
12/28/24 0:00	3893.3
12/29/24 0:00	4469.4

Resize to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	4344	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00278016	

<u>Design drift rate</u>	0.005%
--------------------------	---------------

PM-10 pounds per day	8.97
----------------------	-------------

92	Days in quarter
----	-----------------

PM-10 pounds this quarter	826	4Q24
---------------------------	------------	-------------

fill only these

III. Emissions Deviations

AQ-34

AQ-34 the Project owner shall maintain the following records: occurrence, duration, and type of any startup, shutdown, or malfunction: performance testing, evaluations, calibrations, check, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any continuous emission monitor; emission measurements, total daily and rolling twelve month averages hours of operation, hourly quantity of fuel used and gross three hour average operating load.

Verification; The Project owner shall submit to the CPM all data identified in this condition as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

CO Ppmvdc EDS/CMS Summary Report



CT1

From: 10/01/2024 00:00 To: 12/31/2024 23:59

Generated: 01/02/2025 10:32

Facility Name: ROSEVILLE ENERGY

Location: Roseville, CA

Description: Electric Utility

CMS Data from:

EDS Data from:

Emission Limitation:

No Value Exclusions Allowed

Monitor Manufacturer and Model No.:

Date of Latest CMS Certification or Audit:

Process Unit(s) Description:

Operating time for EDS:

Operating time for CMS:

CT1_CO_Ppmvdc_1H, CT1_UnitOn_TF_1H

CT1_CO_Ppmvdc_3H, CT1_UnitOn_TF_1H

4

TELEDYNE MONITOR LABS INC, TML30

04/09/2006 14:00

1,839.00 Hour(s)

1,839.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	3
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	0.16
4. Total Availability as a percentage of operating time	99.84

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Lb/Hr EDS/CMS Summary Report

CT1

From: 10/01/2024 00:00 To: 12/31/2024 23:59
Generated: 01/02/2025 10:33

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA
Description: Electric Utility



CMS Data from: CT1_CO_3Hr_LbPerHr_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_CO_3Hr_LbPerHr_1H, CT1_UnitOn_TF_1H
Emission Limitation: 6.2
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 1,839.00 Hour(s)
Operating time for CMS: 1,839.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	15
2. Total CMS Downtime	15
3. Total Downtime as a percentage of operating time	0.82
4. Total Availability as a percentage of operating time	99.18

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO SUSD Lb/Hr EDS/CMS Summary Report



CT1

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:34 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_CO_SUSD_LbPerHr_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_CO_SUSD_LbPerHr_1H, CT1_UnitOn_TF_1H
Emission Limitation: 89.5
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 1,839.00 Hour(s)
Operating time for CMS: 1,839.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	104
2. Total CMS Downtime	104
3. Total Downtime as a percentage of operating time	5.66
4. Total Availability as a percentage of operating time	94.34

NOx Ppmvdc EDS/CMS Summary Report



CT1

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 10:34 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_NOx_Ppmvdc_1H, CT1_UnitOn_TF_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 1,839.00 Hour(s)
Operating time for CMS: 1,839.00 Hour(s)

Emission Data Summary	
-----------------------	--

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
-------------------------	--

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	3
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	0.16
4. Total Availability as a percentage of operating time	99.84

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Lb/Hr EDS/CMS Summary Report



CT1

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:00 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Norm_LbPerHr_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_NOx_Norm_LbPerHr_1H, CT1_UnitOn_TF_1H
Emission Limitation: 5.1
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 1,839.00 Hour(s)
Operating time for CMS: 1,839.00 Hour(s)

Emission Data Summary	
-----------------------	--

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
-------------------------	--

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	7
2. Total CMS Downtime	7
3. Total Downtime as a percentage of operating time	0.38
4. Total Availability as a percentage of operating time	99.62

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx SUSD Lb/Hr EDS/CMS Summary Report



CT1

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:01 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_NOx_SUSD_LbPerHr_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_NOx_SUSD_LbPerHr_1H, CT1_UnitOn_TF_1H
Emission Limitation: 37.1
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 1,839.00 Hour(s)
Operating time for CMS: 1,839.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	104
2. Total CMS Downtime	104
3. Total Downtime as a percentage of operating time	5.66
4. Total Availability as a percentage of operating time	94.34

CO Ppmvdc EDS/CMS Summary Report

CT2



From: 10/01/2024 00:00 To: 12/31/2024 23:59

Generated: 01/02/2025 11:02

Facility Name: ROSEVILLE ENERGY

Location: Roseville, CA

Description: Electric Utility

CMS Data from:

EDS Data from:

Emission Limitation:

No Value Exclusions Allowed

Monitor Manufacturer and Model No.:

Date of Latest CMS Certification or Audit:

Process Unit(s) Description:

Operating time for EDS:

Operating time for CMS:

CT2_CO_Ppmvdc_1H, CT2_UnitOn_TF_1H

CT2_CO_Ppmvdc_3H, CT2_UnitOn_TF_1H

4

TELEDYNE MONITOR LABS INC, TML30

04/10/2006 07:00

635.00 Hour(s)

635.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	6
2. Total CMS Downtime	6
3. Total Downtime as a percentage of operating time	0.94
4. Total Availability as a percentage of operating time	99.06

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Lb/Hr EDS/CMS Summary Report

CT2

From: 10/01/2024 00:00 To: 12/31/2024 23:59
Generated: 01/02/2025 11:03

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA
Description: Electric Utility



CMS Data from: CT2_CO_3Hr_LbPerHr_1H, CT2_UnitOn_TF_1H
EDS Data from: CT2_CO_3Hr_LbPerHr_1H, CT2_UnitOn_TF_1H
Emission Limitation: 6.2
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 635.00 Hour(s)
Operating time for CMS: 635.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	25
2. Total CMS Downtime	25
3. Total Downtime as a percentage of operating time	3.94
4. Total Availability as a percentage of operating time	96.06

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO SUSD Lb/Hr EDS/CMS Summary Report



CT2

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:04 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT2_CO_SUSD_LbPerHr_1H, CT2_UnitOn_TF_1H
EDS Data from: CT2_CO_SUSD_LbPerHr_1H, CT2_UnitOn_TF_1H
Emission Limitation: 89.5
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 635.00 Hour(s)
Operating time for CMS: 635.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	48
2. Total CMS Downtime	48
3. Total Downtime as a percentage of operating time	7.56
4. Total Availability as a percentage of operating time	92.44

NOx Ppmvdc EDS/CMS Summary Report



CT2

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:04 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H, CT2_UnitOn_TF_1H
EDS Data from: CT2_NOx_Ppmvdc_1H, CT2_UnitOn_TF_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 635.00 Hour(s)
Operating time for CMS: 635.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	6
2. Total CMS Downtime	6
3. Total Downtime as a percentage of operating time	0.94
4. Total Availability as a percentage of operating time	99.06

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Lb/Hr EDS/CMS Summary Report



CT2

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:05 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Norm_LbPerHr_1H, CT2_UnitOn_TF_1H
EDS Data from: CT2_NOx_Norm_LbPerHr_1H, CT2_UnitOn_TF_1H
Emission Limitation: 5.1
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 635.00 Hour(s)
Operating time for CMS: 635.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	15
2. Total CMS Downtime	15
3. Total Downtime as a percentage of operating time	2.36
4. Total Availability as a percentage of operating time	97.64

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx SUSD Lb/Hr EDS/CMS Summary Report



CT2

From: 10/01/2024 00:00 To: 12/31/2024 23:59

Generated: 01/02/2025 11:07

Facility Name: ROSEVILLE ENERGY

Location: Roseville, CA

Description: Electric Utility

CMS Data from:

EDS Data from:

Emission Limitation:

No Value Exclusions Allowed

Monitor Manufacturer and Model No.:

Date of Latest CMS Certification or Audit:

Process Unit(s) Description:

Operating time for EDS:

Operating time for CMS:

CT2_NOx_SUSD_LbPerHr_1H, CT2_UnitOn_TF_1H

CT2_NOx_SUSD_LbPerHr_1H, CT2_UnitOn_TF_1H

37.1

TELEDYNE MONITOR LABS INC, TML41-02

04/10/2006 07:00

635.00 Hour(s)

635.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	48
2. Total CMS Downtime	48
3. Total Downtime as a percentage of operating time	7.56
4. Total Availability as a percentage of operating time	92.44

CO Invalid Data

CT1



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:08 Location: Roseville, CA

Tag Name: CT1_CO_Ppm_1H
Total Operating Time: 1,839.00 Hour(s)
Non-Operating Time: 369.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/17/2024 09:00	10/17/2024 09:59	1	3 - Quality assurance calibration	
2	12/05/2024 10:00	12/05/2024 10:59	1	38 - Analyzer powered down for repair	
3	12/06/2024 11:00	12/06/2024 11:59	1	13 - Analyzer shutdown for repairs	

Total Operating Time:	1,839.00 Hour(s)
Total Monitor Downtime (Online only):	3.00 Hour(s)
Percent Monitor Availability:	99.84 %
Percent Monitor Downtime:	0.16 %

Report Code	Type	Text	Duration	Duration Percent
38	Reason	Analyzer powered down for repair	1	33.33
13	Reason	Analyzer shutdown for repairs	1	33.33
3	Reason	Quality assurance calibration	1	33.33

NOx Invalid Data

CT1

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:08 Location: Roseville, CA



Tag Name: CT1_NOx_Ppm_1H
Total Operating Time: 1,839.00 Hour(s)
Non-Operating Time: 369.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/17/2024 09:00	10/17/2024 09:59	1	3 - Quality assurance calibration	
2	12/05/2024 10:00	12/05/2024 10:59	1	38 - Analyzer powered down for repair	
3	12/06/2024 11:00	12/06/2024 11:59	1	13 - Analyzer shutdown for repairs	

Total Operating Time:	1,839.00 Hour(s)
Total Monitor Downtime (Online only):	3.00 Hour(s)
Percent Monitor Availability:	99.84 %
Percent Monitor Downtime:	0.16 %

Report Code	Type	Text	Duration	Duration Percent
38	Reason	Analyzer powered down for repair	1	33.33
13	Reason	Analyzer shutdown for repairs	1	33.33
3	Reason	Quality assurance calibration	1	33.33

NOx SCR Invalid Data



CT1

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:09 Location: Roseville, CA

Tag Name: CT1_NOx_SCR_Ppm_1H
Total Operating Time: 1,839.00 Hour(s)
Non-Operating Time: 369.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	12/05/2024 10:00	12/05/2024 10:59	1	38 - Analyzer powered down for repair	
2	12/06/2024 11:00	12/06/2024 11:59	1	13 - Analyzer shutdown for repairs	

Total Operating Time:	1,839.00 Hour(s)
Total Monitor Downtime (Online only):	2.00 Hour(s)
Percent Monitor Availability:	99.89 %
Percent Monitor Downtime:	0.11 %

Report Code	Type	Text	Duration	Duration Percent
38	Reason	Analyzer powered down for repair	1	50.00
13	Reason	Analyzer shutdown for repairs	1	50.00

02 Invalid Data

CT1



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:09 Location: Roseville, CA

Tag Name: CT1_O2Dry_Pct_1H
Total Operating Time: 1,839.00 Hour(s)
Non-Operating Time: 369.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/17/2024 09:00	10/17/2024 09:59	1	3 - Quality assurance calibration	
2	12/05/2024 10:00	12/05/2024 10:59	1	38 - Analyzer powered down for repair	
3	12/06/2024 11:00	12/06/2024 11:59	1	13 - Analyzer shutdown for repairs	

Total Operating Time:	1,839.00 Hour(s)
Total Monitor Downtime (Online only):	3.00 Hour(s)
Percent Monitor Availability:	99.84 %
Percent Monitor Downtime:	0.16 %

Report Code	Type	Text	Duration	Duration Percent
38	Reason	Analyzer powered down for repair	1	33.33
13	Reason	Analyzer shutdown for repairs	1	33.33
3	Reason	Quality assurance calibration	1	33.33

CO Invalid Data

CT2

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:10 Location: Roseville, CA



Tag Name: CT2_CO_Ppm_1H
Total Operating Time: 635.00 Hour(s)
Non-Operating Time: 1,573.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	635.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

NOx Invalid Data

CT2

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:10 Location: Roseville, CA



Tag Name: CT2_NOx_Ppm_1H
Total Operating Time: 635.00 Hour(s)
Non-Operating Time: 1,573.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/29/2024 08:00	10/29/2024 08:59	1		
2	10/29/2024 09:00	10/29/2024 09:59	1		
3	11/15/2024 20:00	11/15/2024 20:59	1		
4	11/15/2024 21:00	11/15/2024 21:59	1		
5	11/16/2024 08:00	11/16/2024 08:59	1		
6	11/16/2024 09:00	11/16/2024 09:59	1		

Total Operating Time:	635.00 Hour(s)
Total Monitor Downtime (Online only):	6.00 Hour(s)
Percent Monitor Availability:	99.06 %
Percent Monitor Downtime:	0.94 %

NOx SCR Invalid Data



CT2

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:11 Location: Roseville, CA

Tag Name: CT2_NOx_SCR_Ppm_1H
Total Operating Time: 635.00 Hour(s)
Non-Operating Time: 1,573.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	635.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

O2 Invalid Data

CT2

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:11 Location: Roseville, CA



Tag Name: CT2_O2Dry_Pct_1H
Total Operating Time: 635.00 Hour(s)
Non-Operating Time: 1,573.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/29/2024 08:00	10/29/2024 08:59	1		
2	10/29/2024 09:00	10/29/2024 09:59	1		
3	11/15/2024 20:00	11/15/2024 20:59	1		
4	11/15/2024 21:00	11/15/2024 21:59	1		
5	11/16/2024 08:00	11/16/2024 08:59	1		
6	11/16/2024 09:00	11/16/2024 09:59	1		

Total Operating Time:	635.00 Hour(s)
Total Monitor Downtime (Online only):	6.00 Hour(s)
Percent Monitor Availability:	99.06 %
Percent Monitor Downtime:	0.94 %

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/24 02:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	10/01/24 02:24	200.0	182.0	180.2	R-A /Span * 100		0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/24 02:19	30.0	21.3	21.1	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/24 02:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	10/01/24 02:24	200.0	179.7	179.3	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/24 02:19	30.0	21.2	21.2	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/24 03:14	200.0	0.0	0.5	R-A /Span * 100		0.3
	High	10/01/24 03:24	200.0	182.7	177.5	R-A /Span * 100		2.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/24 03:14	10.0	0.0	-0.2	R-A /Span * 100		2.0
	High	10/01/24 03:19	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/24 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	10/01/24 03:24	200.0	182.0	184.7	R-A /Span * 100		1.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/24 03:19	10.0	9.6	9.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/01/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	10/01/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/24 03:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	10/01/24 03:24	200.0	177.3	178.5	R-A /Span * 100		0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/24 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	10/01/24 03:19	10.0	9.0	9.3	R-A /Span * 100		3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/24 03:24	200.0	179.7	180.1	R-A /Span * 100		0.2

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/24 03:19	10.0	9.7	9.8	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/01/24 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	10/01/24 03:19	21.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/02/24 02:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	10/02/24 02:24	200.0	182.0	180.4	R-A /Span * 100		0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/02/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/24 02:19	30.0	21.3	21.1	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/02/24 02:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	10/02/24 02:24	200.0	179.7	179.2	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/02/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/24 02:19	30.0	21.2	21.2	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/02/24 03:14	200.0	0.0	0.4	R-A /Span * 100		0.2
	High	10/02/24 03:24	200.0	182.7	177.9	R-A /Span * 100		2.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/02/24 03:14	10.0	0.0	-0.2	R-A /Span * 100		2.0
	High	10/02/24 03:19	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/02/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/24 03:24	200.0	182.0	184.7	R-A /Span * 100		1.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/02/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/24 03:19	10.0	9.6	9.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/02/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	10/02/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/02/24 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/02/24 03:24	200.0	177.3	178.3	R-A /Span * 100		0.5

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/02/24 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	10/02/24 03:19	10.0	9.0	9.2	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/02/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	10/02/24 03:24	200.0	179.7	180.5	R-A /Span * 100	0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/02/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/02/24 03:19	10.0	9.7	9.9	R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/02/24 03:14	21.0	18.1	18.1	R-A	0.0
	Zero	10/02/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/24 02:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	10/03/24 02:24	200.0	182.0	180.8	R-A /Span * 100	0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/03/24 02:19	30.0	21.3	21.2	R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/24 02:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	10/03/24 02:24	200.0	179.7	180.9	R-A /Span * 100	0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/03/24 02:19	30.0	21.2	21.5	R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/24 03:14	200.0	0.0	0.5	R-A /Span * 100	0.3
	High	10/03/24 03:24	200.0	182.7	177.9	R-A /Span * 100	2.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/24 03:14	10.0	0.0	-0.2	R-A /Span * 100	2.0
	High	10/03/24 03:19	10.0	9.0	8.8	R-A /Span * 100	2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/03/24 03:24	200.0	182.0	185.3	R-A /Span * 100	1.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/03/24 03:19	10.0	9.6	9.7	R-A /Span * 100	1.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/03/24 03:14	18.0	18.0	R-A		0.0
	Zero	10/03/24 03:19	18.0	-0.1	R-A		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/24 03:14	200.0	-0.1	R-A /Span * 100		0.1
	High	10/03/24 03:24	200.0	177.3	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/24 03:14	10.0	-0.2	R-A /Span * 100		2.0
	High	10/03/24 03:19	10.0	9.3	R-A /Span * 100		3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/24 03:14	200.0	0.1	R-A /Span * 100		0.1
	High	10/03/24 03:24	200.0	179.7	R-A /Span * 100		1.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/03/24 03:19	10.0	9.7	R-A /Span * 100		3.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/03/24 03:14	21.0	18.1	R-A		0.0
	Zero	10/03/24 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/24 02:14	200.0	-0.1	R-A /Span * 100		0.1
	High	10/04/24 02:24	200.0	182.0	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/24 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/04/24 02:19	30.0	21.3	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/24 02:14	200.0	0.2	R-A /Span * 100		0.1
	High	10/04/24 02:24	200.0	179.7	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/24 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/04/24 02:19	30.0	21.2	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/24 03:14	200.0	0.5	R-A /Span * 100		0.3
	High	10/04/24 03:24	200.0	182.7	R-A /Span * 100		2.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/24 03:14	10.0	-0.3	R-A /Span * 100		3.0
	High	10/04/24 03:19	10.0	9.0	R-A /Span * 100		3.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/04/24 03:24	200.0	182.0		R-A /Span * 100	1.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/04/24 03:19	10.0	9.6		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/04/24 03:14	18.0	18.0		R-A	0.0
	Zero	10/04/24 03:19	18.0	-0.1		R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/04/24 03:24	200.0	177.3		R-A /Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/24 03:14	10.0	0.0		R-A /Span * 100	2.0
	High	10/04/24 03:19	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/04/24 03:24	200.0	179.7		R-A /Span * 100	1.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/04/24 03:19	10.0	9.7		R-A /Span * 100	3.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/04/24 03:14	21.0	18.1		R-A	0.0
	Zero	10/04/24 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/05/24 02:14	200.0	-0.1		R-A /Span * 100	0.1
	High	10/05/24 02:24	200.0	182.0		R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/05/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/05/24 02:19	30.0	21.3		R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/05/24 02:14	200.0	0.2		R-A /Span * 100	0.1
	High	10/05/24 02:24	200.0	179.7		R-A /Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/05/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/05/24 02:19	30.0	21.2		R-A /Span * 100	0.7

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/05/24 03:14	200.0	0.0	0.4	R-A /Span * 100	0.2
	High	10/05/24 03:24	200.0	182.7	177.2	R-A /Span * 100	2.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/05/24 03:14	10.0	0.0	-0.2	R-A /Span * 100	2.0
	High	10/05/24 03:19	10.0	9.0	8.8	R-A /Span * 100	2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/05/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	10/05/24 03:24	200.0	182.0	184.4	R-A /Span * 100	1.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/05/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/05/24 03:19	10.0	9.6	9.7	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/05/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	10/05/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/05/24 03:14	200.0	0.0	-0.3	R-A /Span * 100	0.2
	High	10/05/24 03:24	200.0	177.3	177.2	R-A /Span * 100	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/05/24 03:14	10.0	0.0	-0.3	R-A /Span * 100	3.0
	High	10/05/24 03:19	10.0	9.0	9.2	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/05/24 03:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	10/05/24 03:24	200.0	179.7	181.8	R-A /Span * 100	1.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/05/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/05/24 03:19	10.0	9.7	10.0	R-A /Span * 100	3.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/05/24 03:14	21.0	18.1	18.1	R-A	0.0
	Zero	10/05/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/06/24 02:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	10/06/24 02:24	200.0	182.0	180.4	R-A /Span * 100	0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/06/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/06/24 02:19	30.0	21.3	21.0	R-A /Span * 100	1.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/24 02:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	10/06/24 02:24	200.0	179.7	179.7	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/24 02:19	30.0	21.2	21.2	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/24 03:14	200.0	0.0	0.5	R-A /Span * 100		0.3
	High	10/06/24 03:24	200.0	182.7	177.3	R-A /Span * 100		2.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/24 03:14	10.0	0.0	-0.2	R-A /Span * 100		2.0
	High	10/06/24 03:19	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/24 03:24	200.0	182.0	184.4	R-A /Span * 100		1.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/24 03:19	10.0	9.6	9.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/06/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	10/06/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/24 03:24	200.0	177.3	178.2	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/24 03:14	10.0	0.0	-0.2	R-A /Span * 100		2.0
	High	10/06/24 03:19	10.0	9.0	9.3	R-A /Span * 100		3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/24 03:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	10/06/24 03:24	200.0	179.7	181.8	R-A /Span * 100		1.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/24 03:19	10.0	9.7	9.9	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/06/24 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	10/06/24 03:19	21.0	0.0	0.0	R-A		0.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/24 02:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	10/07/24 02:24	200.0	182.0	181.0	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/24 02:19	30.0	21.3	21.2	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/24 02:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	10/07/24 02:24	200.0	179.7	180.0	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/24 02:14	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	10/07/24 02:19	30.0	21.4	21.3	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/24 03:14	200.0	0.0	0.5	R-A /Span * 100		0.3
	High	10/07/24 03:24	200.0	182.7	177.5	R-A /Span * 100		2.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/24 03:14	10.0	0.0	-0.2	R-A /Span * 100		2.0
	High	10/07/24 03:19	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/24 03:24	200.0	182.0	184.8	R-A /Span * 100		1.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/24 03:19	10.0	9.6	9.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/07/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	10/07/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/24 03:24	200.0	177.3	178.5	R-A /Span * 100		0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/24 03:14	10.0	0.0	-0.2	R-A /Span * 100		2.0
	High	10/07/24 03:19	10.0	9.0	9.3	R-A /Span * 100		3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/24 03:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	10/07/24 03:24	200.0	179.7	182.4	R-A /Span * 100		1.4

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/07/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/07/24 03:19	10.0	9.7	10.0 >1x Alert R-A /Span * 100		3.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/07/24 03:14	21.0	18.1	R-A		0.0
	Zero	10/07/24 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/08/24 02:14	200.0	-0.1	R-A /Span * 100		0.1
	High	10/08/24 02:24	200.0	181.3	R-A /Span * 100		0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/08/24 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/08/24 02:19	30.0	21.3	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/08/24 02:14	200.0	0.2	R-A /Span * 100		0.1
	High	10/08/24 02:24	200.0	179.7	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/08/24 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/08/24 02:19	30.0	21.4	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/08/24 03:14	200.0	0.5	R-A /Span * 100		0.3
	High	10/08/24 03:24	200.0	182.7	R-A /Span * 100		2.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/08/24 03:14	10.0	-0.2	R-A /Span * 100		2.0
	High	10/08/24 03:19	10.0	9.0	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/08/24 03:14	200.0	-0.1	R-A /Span * 100		0.1
	High	10/08/24 03:24	200.0	182.0	R-A /Span * 100		1.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/08/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/08/24 03:19	10.0	9.6	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/08/24 03:14	18.0	18.0	R-A		0.0
	Zero	10/08/24 03:19	18.0	-0.1	R-A		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/08/24 03:14	200.0	-0.1	R-A /Span * 100		0.1
	High	10/08/24 03:24	200.0	177.3	R-A /Span * 100		0.2

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/08/24 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	10/08/24 03:19	10.0	9.0	8.9	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/08/24 03:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	10/08/24 03:24	200.0	179.7	179.9	R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/08/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/08/24 03:19	10.0	9.7	9.7	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/08/24 03:14	21.0	18.1	18.1	R-A	0.0
	Zero	10/08/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/09/24 02:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	10/09/24 02:24	200.0	182.0	181.1	R-A /Span * 100	0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/09/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/09/24 02:19	30.0	21.3	21.2	R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/09/24 02:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	10/09/24 02:24	200.0	179.7	180.7	R-A /Span * 100	0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/09/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/09/24 02:19	30.0	21.4	21.4	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/09/24 03:14	200.0	0.0	0.6	R-A /Span * 100	0.3
	High	10/09/24 03:24	200.0	182.7	177.6	R-A /Span * 100	2.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/09/24 03:14	10.0	0.0	-0.2	R-A /Span * 100	2.0
	High	10/09/24 03:19	10.0	9.0	8.8	R-A /Span * 100	2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/09/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/09/24 03:24	200.0	182.0	184.7	R-A /Span * 100	1.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/09/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/09/24 03:19	10.0	9.6	9.7	R-A /Span * 100	1.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/09/24 03:14	18.0	18.0	R-A		0.0
	Zero	10/09/24 03:19	18.0	-0.1	R-A		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/09/24 03:14	200.0	0.2	R-A /Span * 100		0.1
	High	10/09/24 03:24	200.0	176.4	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/09/24 03:14	10.0	0.1	R-A /Span * 100		1.0
	High	10/09/24 03:19	10.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/09/24 03:14	200.0	0.2	R-A /Span * 100		0.1
	High	10/09/24 03:24	200.0	180.1	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/09/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/09/24 03:19	10.0	9.7	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/09/24 03:14	21.0	18.1	R-A		0.0
	Zero	10/09/24 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/10/24 02:14	200.0	-0.1	R-A /Span * 100		0.1
	High	10/10/24 02:24	200.0	181.0	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/10/24 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/10/24 02:19	30.0	21.2	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/10/24 02:14	200.0	0.2	R-A /Span * 100		0.1
	High	10/10/24 02:24	200.0	179.5	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/10/24 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/10/24 02:19	30.0	21.3	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/10/24 03:14	200.0	0.5	R-A /Span * 100		0.3
	High	10/10/24 03:24	200.0	177.4	R-A /Span * 100		2.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/10/24 03:14	10.0	-0.2	R-A /Span * 100		2.0
	High	10/10/24 03:19	10.0	8.8	R-A /Span * 100		2.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/10/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/10/24 03:24	200.0	182.0		R-A /Span * 100	1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/10/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/10/24 03:19	10.0	9.6		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/10/24 03:14	18.0	18.0		R-A	0.0
	Zero	10/10/24 03:19	18.0	-0.1		R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/10/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/10/24 03:24	200.0	177.3		R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/10/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/10/24 03:19	10.0	9.1		R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/10/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/10/24 03:24	200.0	179.7		R-A /Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/10/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/10/24 03:19	10.0	9.6	>1x Alert	R-A /Span * 100	4.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/10/24 03:14	21.0	18.1		R-A	0.0
	Zero	10/10/24 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/11/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/11/24 02:24	200.0	182.0		R-A /Span * 100	0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/11/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/11/24 02:19	30.0	21.3		R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/11/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/11/24 02:24	200.0	179.7		R-A /Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/11/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/11/24 02:19	30.0	21.4		R-A /Span * 100	1.3

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/11/24 03:14	200.0	0.0	0.5	R-A /Span * 100		0.3
	High	10/11/24 03:24	200.0	182.7	178.3	R-A /Span * 100		2.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/11/24 03:14	10.0	0.0	-0.2	R-A /Span * 100		2.0
	High	10/11/24 03:19	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/11/24 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/11/24 03:24	200.0	182.0	184.3	R-A /Span * 100		1.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/11/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/11/24 03:19	10.0	9.6	9.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/11/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	10/11/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/11/24 03:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	10/11/24 03:24	200.0	177.3	176.3	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/11/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/11/24 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/11/24 03:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	10/11/24 03:24	200.0	179.7	179.8	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/11/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/11/24 03:19	10.0	9.6	9.7	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/11/24 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	10/11/24 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/12/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/12/24 02:24	200.0	182.0	180.4	R-A /Span * 100		0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/12/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/12/24 02:19	30.0	21.3	21.2	R-A /Span * 100		0.3

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/12/24 02:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	10/12/24 02:24	200.0	179.7	179.4	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/12/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/12/24 02:19	30.0	21.4	21.6	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/12/24 03:14	200.0	0.0	0.6	R-A /Span * 100		0.3
	High	10/12/24 03:24	200.0	182.7	178.0	R-A /Span * 100		2.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/12/24 03:14	10.0	0.0	-0.2	R-A /Span * 100		2.0
	High	10/12/24 03:19	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/12/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/12/24 03:24	200.0	182.0	184.0	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/12/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/12/24 03:19	10.0	9.6	9.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/12/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	10/12/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/12/24 03:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	10/12/24 03:24	200.0	177.3	176.9	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/12/24 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/12/24 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/12/24 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/12/24 03:24	200.0	179.7	180.1	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/12/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/12/24 03:19	10.0	9.6	9.7	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/12/24 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	10/12/24 03:19	21.0	0.0	0.0	R-A		0.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/13/24 02:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	10/13/24 02:24	200.0	182.0	179.5	R-A /Span * 100	1.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/13/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/13/24 02:19	30.0	21.3	21.0	R-A /Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/13/24 02:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	10/13/24 02:24	200.0	179.7	178.5	R-A /Span * 100	0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/13/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/13/24 02:19	30.0	21.4	21.4	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/13/24 03:14	200.0	0.0	0.4	R-A /Span * 100	0.2
	High	10/13/24 03:24	200.0	182.7	177.6	R-A /Span * 100	2.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/13/24 03:14	10.0	0.0	-0.2	R-A /Span * 100	2.0
	High	10/13/24 03:19	10.0	9.0	8.8	R-A /Span * 100	2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/13/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	10/13/24 03:24	200.0	182.0	183.7	R-A /Span * 100	0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/13/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/13/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/13/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	10/13/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/13/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	10/13/24 03:24	200.0	177.3	177.1	R-A /Span * 100	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/13/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	10/13/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/13/24 03:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	10/13/24 03:24	200.0	179.7	179.1	R-A /Span * 100	0.3

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/13/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/13/24 03:19	10.0	9.6	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/13/24 03:14	21.0	18.1	R-A		0.0
	Zero	10/13/24 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/14/24 02:14	200.0	-0.1	R-A /Span * 100		0.1
	High	10/14/24 02:24	200.0	179.7	R-A /Span * 100		1.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/14/24 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/14/24 02:19	30.0	21.3	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/14/24 02:14	200.0	0.2	R-A /Span * 100		0.1
	High	10/14/24 02:24	200.0	178.5	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/14/24 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/14/24 02:19	30.0	21.4	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/14/24 03:14	200.0	0.5	R-A /Span * 100		0.3
	High	10/14/24 03:24	200.0	182.7	R-A /Span * 100		2.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/14/24 03:14	10.0	-0.2	R-A /Span * 100		2.0
	High	10/14/24 03:19	10.0	9.0	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/14/24 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/14/24 03:24	200.0	182.0	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/14/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/14/24 03:19	10.0	9.6	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/14/24 03:14	18.0	18.0	R-A		0.0
	Zero	10/14/24 03:19	18.0	-0.1	R-A		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/14/24 03:14	200.0	0.1	R-A /Span * 100		0.1
	High	10/14/24 03:24	200.0	177.3	R-A /Span * 100		0.8

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/14/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/14/24 03:19	10.0	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/14/24 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/14/24 03:24	200.0	179.7	R-A /Span * 100		0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/14/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/14/24 03:19	10.0	9.6	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/14/24 03:14	21.0	18.1	R-A		0.0
	Zero	10/14/24 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/15/24 02:14	200.0	0.0	R-A /Span * 100		0.1
	High	10/15/24 02:24	200.0	182.0	R-A /Span * 100		1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/15/24 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/15/24 02:19	30.0	21.3	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/15/24 02:14	200.0	0.0	R-A /Span * 100		0.2
	High	10/15/24 02:24	200.0	179.7	R-A /Span * 100		0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/15/24 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/15/24 02:19	30.0	21.4	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/15/24 03:14	200.0	0.0	R-A /Span * 100		0.3
	High	10/15/24 03:24	200.0	182.7	R-A /Span * 100		2.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/15/24 03:14	10.0	0.0	R-A /Span * 100		2.0
	High	10/15/24 03:19	10.0	9.0	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/15/24 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/15/24 03:24	200.0	182.0	R-A /Span * 100		1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/15/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/15/24 03:19	10.0	9.6	R-A /Span * 100		0.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/15/24 03:14	18.0	18.0	R-A		0.0
	Zero	10/15/24 03:19	18.0	-0.1	R-A		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/15/24 03:14	200.0	0.2	R-A /Span * 100		0.1
	High	10/15/24 03:24	200.0	174.8	R-A /Span * 100		1.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/15/24 03:14	10.0	0.1	R-A /Span * 100		1.0
	High	10/15/24 03:19	10.0	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/15/24 03:14	200.0	-0.3	R-A /Span * 100		0.2
	High	10/15/24 03:24	200.0	179.6	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/15/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/15/24 03:19	10.0	9.6	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/15/24 03:14	21.0	18.0	R-A		0.1
	Zero	10/15/24 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/16/24 02:14	200.0	-0.1	R-A /Span * 100		0.1
	High	10/16/24 02:24	200.0	180.3	R-A /Span * 100		0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/16/24 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/16/24 02:19	30.0	21.1	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/16/24 02:14	200.0	0.2	R-A /Span * 100		0.1
	High	10/16/24 02:24	200.0	179.3	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/16/24 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/16/24 02:19	30.0	21.6	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/16/24 03:14	200.0	0.5	R-A /Span * 100		0.3
	High	10/16/24 03:24	200.0	177.5	R-A /Span * 100		2.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/16/24 03:14	10.0	-0.2	R-A /Span * 100		2.0
	High	10/16/24 03:19	10.0	8.8	R-A /Span * 100		2.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/16/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/16/24 03:24	200.0	182.0		R-A /Span * 100	1.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/16/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/16/24 03:19	10.0	9.6		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/16/24 03:14	18.0	18.0		R-A	0.0
	Zero	10/16/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/16/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/16/24 03:24	200.0	177.3		R-A /Span * 100	0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/16/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/16/24 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/16/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/16/24 03:24	200.0	179.7		R-A /Span * 100	0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/16/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/16/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/16/24 03:14	21.0	18.1		R-A	0.0
	Zero	10/16/24 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/17/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/17/24 02:24	200.0	182.0		R-A /Span * 100	0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/17/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/17/24 02:19	30.0	21.3		R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/17/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/17/24 02:24	200.0	179.7		R-A /Span * 100	0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/17/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/17/24 02:19	30.0	21.4		R-A /Span * 100	0.7

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/17/24 03:14	200.0	0.0	0.6	R-A /Span * 100		0.3
	High	10/17/24 03:24	200.0	182.7	178.3	R-A /Span * 100		2.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/17/24 03:14	10.0	0.0	-0.2	R-A /Span * 100		2.0
	High	10/17/24 03:19	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/17/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/17/24 03:24	200.0	182.0	184.3	R-A /Span * 100		1.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/17/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/17/24 03:19	10.0	9.6	9.6	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/17/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	10/17/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/17/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/17/24 03:24	200.0	177.3	175.6	R-A /Span * 100		0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/17/24 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	10/17/24 03:19	10.0	9.1	8.9	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/17/24 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/17/24 03:24	200.0	179.7	181.2	R-A /Span * 100		0.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/17/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/17/24 03:19	10.0	9.6	9.7	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/17/24 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	10/17/24 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/18/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/18/24 02:24	200.0	179.7	179.7	R-A /Span * 100		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/18/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/18/24 02:19	30.0	21.3	21.1	R-A /Span * 100		0.7

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/18/24 03:14	200.0	0.0	0.5	R-A /Span * 100		0.3
	High	10/18/24 03:24	200.0	177.3	177.9	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/18/24 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	10/18/24 03:19	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/18/24 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	10/18/24 03:24	200.0	179.7	179.6	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/18/24 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	10/18/24 03:19	10.0	9.6	9.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/18/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	10/18/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/19/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/19/24 02:24	200.0	179.7	180.1	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/19/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/19/24 02:19	30.0	21.3	21.2	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/19/24 03:14	200.0	0.0	0.5	R-A /Span * 100		0.3
	High	10/19/24 03:24	200.0	177.3	177.3	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/19/24 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	10/19/24 03:19	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/19/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/19/24 03:24	200.0	179.7	179.0	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/19/24 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	10/19/24 03:19	10.0	9.6	9.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/19/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	10/19/24 03:19	18.0	0.0	-0.1	R-A		0.1

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/20/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/20/24 02:24	200.0	179.7	179.6	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/20/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/20/24 02:19	30.0	21.3	21.2	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/20/24 03:14	200.0	0.0	0.5	R-A /Span * 100		0.3
	High	10/20/24 03:24	200.0	177.3	178.0	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/20/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/20/24 03:19	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/20/24 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	10/20/24 03:24	200.0	179.7	178.7	R-A /Span * 100		0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/20/24 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	10/20/24 03:19	10.0	9.6	9.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/20/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	10/20/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/21/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/24 02:24	200.0	179.7	179.7	R-A /Span * 100		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/21/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/24 02:19	30.0	21.3	21.2	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/21/24 03:14	200.0	0.0	0.5	R-A /Span * 100		0.3
	High	10/21/24 03:24	200.0	177.3	177.7	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/21/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/24 03:19	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/21/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/24 03:24	200.0	179.7	178.6	R-A /Span * 100		0.6

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/21/24 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	10/21/24 03:19	10.0	9.6	9.5	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/21/24 03:14	18.0	18.0		R-A	0.0
	Zero	10/21/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/22/24 02:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	10/22/24 02:24	200.0	179.7	179.3	R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/22/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/22/24 02:19	30.0	21.3	21.0	R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/22/24 03:14	200.0	0.0	0.5	R-A /Span * 100	0.3
	High	10/22/24 03:24	200.0	177.3	177.6	R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/22/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/22/24 03:19	10.0	9.0	8.9	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/22/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/22/24 03:24	200.0	179.7	178.7	R-A /Span * 100	0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/22/24 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	10/22/24 03:19	10.0	9.6	9.5	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/22/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	10/22/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/23/24 02:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	10/23/24 02:24	200.0	179.7	178.9	R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/23/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/23/24 02:19	30.0	21.3	20.9	R-A /Span * 100	1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/23/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	10/23/24 03:24	200.0	177.3	177.5	R-A /Span * 100	0.1

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/23/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/23/24 03:19	10.0	9.0		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/23/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/23/24 03:24	200.0	179.7		R-A /Span * 100	0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/23/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/23/24 03:19	10.0	9.6		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/23/24 03:14	18.0	18.0		R-A	0.0
	Zero	10/23/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT6_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Offline	Pass	
	Zero	10/23/24 12:53	1,000.0	0.0		R-A /Span * 100	0.0
	High	10/23/24 13:03	1,000.0	918.0		R-A /Span * 100	0.0
Part 60	CT6_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Offline	Pass	
	High	10/23/24 12:48	20.0	18.2		R-A /Span * 100	0.5
	Zero	10/23/24 12:53	20.0	0.0		R-A /Span * 100	0.0
Part 75	CT6_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Offline	Offline	
	Zero	10/23/24 12:48	500.0	0.0	off	R-A /Span * 100	0.0
	High	10/23/24 12:58	500.0	452.4	off	R-A /Span * 100	1.0
Part 75	CT6_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Offline	Offline	
	Zero	10/23/24 12:48	10.0	0.0	off	R-A /Span * 100	1.0
	High	10/23/24 12:53	10.0	9.0	off	R-A	0.8
Part 75	CT6_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Offline	Offline	
	High	10/23/24 12:48	25.0	22.5	off	R-A	0.0
	Zero	10/23/24 12:53	25.0	0.0	off	R-A	0.0
Part 60	CT5_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Offline	Pass	
	Zero	10/23/24 13:07	1,000.0	0.0		R-A /Span * 100	0.0
	High	10/23/24 13:17	1,000.0	910.9		R-A /Span * 100	0.2
Part 60	CT5_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Offline	Pass	
	High	10/23/24 13:02	20.0	18.1		R-A /Span * 100	0.0
	Zero	10/23/24 13:07	20.0	0.0		R-A /Span * 100	0.0
Part 75	CT5_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Offline	Offline	
	Zero	10/23/24 13:02	500.0	0.0	off	R-A /Span * 100	0.0
	High	10/23/24 13:12	500.0	456.1	off	R-A /Span * 100	0.4

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT5_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Offline	Offline	
	Zero	10/23/24 13:02	10.0	0.0	0.0	off	R-A /Span * 100	0.0
	High	10/23/24 13:07	10.0	9.6	9.7	off	R-A /Span * 100	1.0
Part 75	CT5_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Offline	
	High	10/23/24 13:02	25.0	22.5	22.5	off	R-A	0.0
	Zero	10/23/24 13:07	25.0	0.0	0.0	off	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/24/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/24/24 02:24	200.0	179.7	179.4	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/24/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/24/24 02:19	30.0	21.3	20.9	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/24/24 03:14	200.0	0.0	0.5	R-A /Span * 100		0.3
	High	10/24/24 03:24	200.0	177.3	178.3	R-A /Span * 100		0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/24/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/24/24 03:19	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/24/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/24/24 03:24	200.0	179.7	179.0	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/24/24 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	10/24/24 03:19	10.0	9.6	9.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/24/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	10/24/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/25/24 02:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	10/25/24 02:24	200.0	179.7	179.1	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/25/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/25/24 02:19	30.0	21.3	20.9	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/25/24 03:14	200.0	0.0	0.8	R-A /Span * 100		0.4
	High	10/25/24 03:24	200.0	177.3	179.3	R-A /Span * 100		1.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/25/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/25/24 03:19	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/25/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/25/24 03:24	200.0	179.7		R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/25/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/25/24 03:19	10.0	9.6		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/25/24 03:14	18.0	18.0		R-A	0.0
	Zero	10/25/24 03:19	18.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/26/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/26/24 02:24	200.0	179.7		R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/26/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/26/24 02:19	30.0	21.3		R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/26/24 03:14	200.0	0.0		R-A /Span * 100	0.5
	High	10/26/24 03:24	200.0	177.3		R-A /Span * 100	0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/26/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/26/24 03:19	10.0	9.0		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/26/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/26/24 03:24	200.0	179.7		R-A /Span * 100	0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/26/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/26/24 03:19	10.0	9.6		R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/26/24 03:14	18.0	18.0		R-A	0.0
	Zero	10/26/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/27/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/27/24 02:24	200.0	179.7		R-A /Span * 100	0.6

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/27/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/24 02:19	30.0	21.3	21.1	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/27/24 03:14	200.0	0.0	0.8	R-A /Span * 100		0.4
	High	10/27/24 03:24	200.0	177.3	179.0	R-A /Span * 100		0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/27/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/24 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/27/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/24 03:24	200.0	179.7	178.0	R-A /Span * 100		0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/27/24 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	10/27/24 03:19	10.0	9.6	9.4	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/27/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	10/27/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/28/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/28/24 02:24	200.0	179.7	179.2	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/28/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/28/24 02:19	30.0	21.3	21.1	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/28/24 03:14	200.0	0.0	0.8	R-A /Span * 100		0.4
	High	10/28/24 03:24	200.0	177.3	179.1	R-A /Span * 100		0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/28/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/28/24 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/28/24 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	10/28/24 03:24	200.0	179.7	178.7	R-A /Span * 100		0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/28/24 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	10/28/24 03:19	10.0	9.6	9.4	R-A /Span * 100		2.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/28/24 03:14	18.0	18.0	R-A		0.0
	Zero	10/28/24 03:19	18.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/29/24 02:14	200.0	-0.1	R-A /Span * 100		0.1
	High	10/29/24 02:24	200.0	179.5	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/29/24 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/29/24 02:19	30.0	21.0	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/29/24 03:14	200.0	0.9	R-A /Span * 100		0.5
	High	10/29/24 03:24	200.0	179.3	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/29/24 03:14	10.0	0.2	R-A /Span * 100		2.0
	High	10/29/24 03:19	10.0	9.0	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/29/24 03:14	200.0	-0.1	R-A /Span * 100		0.1
	High	10/29/24 03:24	200.0	178.8	R-A /Span * 100		0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/29/24 03:14	10.0	-0.1	R-A /Span * 100		1.0
	High	10/29/24 03:19	10.0	9.4	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/29/24 03:14	18.0	18.0	R-A		0.0
	Zero	10/29/24 03:19	18.0	-0.1	R-A		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/29/24 10:08	200.0	0.6	R-A /Span * 100		0.3
	High	10/29/24 10:18	200.0	180.6	R-A /Span * 100		1.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/29/24 10:08	10.0	0.2	R-A /Span * 100		2.0
	High	10/29/24 10:13	10.0	9.3	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/29/24 10:08	200.0	0.1	R-A /Span * 100		0.1
	High	10/29/24 10:18	200.0	175.4	>1x Alert R-A /Span * 100		3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/29/24 10:08	10.0	0.0	R-A /Span * 100		0.0
	High	10/29/24 10:13	10.0	9.3	>1x Alert R-A /Span * 100		3.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/29/24 10:08	21.0	18.1	18.0	R-A	0.1
	Zero	10/29/24 10:13	21.0	0.0	-0.1	R-A	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/29/24 12:05	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	10/29/24 12:15	200.0	181.4	176.5	R-A /Span * 100	2.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/29/24 12:05	30.0	0.0	0.1	R-A /Span * 100	0.3
	High	10/29/24 12:10	30.0	21.4	20.9	R-A /Span * 100	1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/30/24 02:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	10/30/24 02:24	200.0	181.4	172.8	>1x Alert R-A /Span * 100	4.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/30/24 02:14	30.0	0.0	0.1	R-A /Span * 100	0.3
	High	10/30/24 02:19	30.0	21.4	20.3	>1x Alert R-A /Span * 100	3.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/30/24 03:14	200.0	0.0	0.5	R-A /Span * 100	0.3
	High	10/30/24 03:24	200.0	176.9	177.7	R-A /Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/30/24 03:14	10.0	0.0	0.3	R-A /Span * 100	3.0
	High	10/30/24 03:19	10.0	9.1	9.3	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/30/24 03:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	10/30/24 03:24	200.0	181.4	175.4	>1x Alert R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/30/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/30/24 03:19	10.0	9.6	9.3	>1x Alert R-A /Span * 100	3.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/30/24 03:14	21.0	18.1	18.0	R-A	0.1
	Zero	10/30/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/31/24 02:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	10/31/24 02:24	200.0	181.4	179.3	R-A /Span * 100	1.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/31/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/31/24 02:19	30.0	21.4	21.1	R-A /Span * 100	1.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/31/24 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/31/24 03:24	200.0	176.9	R-A /Span * 100		1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/31/24 03:14	10.0	0.0	R-A /Span * 100		1.0
	High	10/31/24 03:19	10.0	9.1	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/31/24 03:14	200.0	0.0	R-A /Span * 100		0.1
	High	10/31/24 03:24	200.0	181.4	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/31/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/31/24 03:19	10.0	9.6	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/31/24 03:14	21.0	18.1	R-A		0.0
	Zero	10/31/24 03:19	21.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/01/24 02:14	200.0	0.0	R-A /Span * 100		0.1
	High	11/01/24 02:24	200.0	181.4	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/01/24 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	11/01/24 02:19	30.0	21.4	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/01/24 03:14	200.0	0.0	R-A /Span * 100		0.2
	High	11/01/24 03:24	200.0	176.9	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/01/24 03:14	10.0	0.0	R-A /Span * 100		3.0
	High	11/01/24 03:19	10.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/01/24 03:14	200.0	0.0	R-A /Span * 100		0.1
	High	11/01/24 03:24	200.0	181.4	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/01/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/01/24 03:19	10.0	9.6	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/01/24 03:14	21.0	18.0	R-A		0.1
	Zero	11/01/24 03:19	21.0	0.0	R-A		0.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/02/24 02:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	11/02/24 02:24	200.0	181.4	180.8	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/02/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/24 02:19	30.0	21.4	21.4	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/02/24 03:14	200.0	0.0	0.4	R-A /Span * 100		0.2
	High	11/02/24 03:24	200.0	176.9	177.4	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/02/24 03:14	10.0	0.0	0.4	R-A /Span * 100		4.0
	High	11/02/24 03:19	10.0	9.1	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/02/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/24 03:24	200.0	181.4	181.3	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/02/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/24 03:19	10.0	9.6	9.6	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/02/24 03:14	21.0	18.0	17.9	R-A		0.1
	Zero	11/02/24 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/03/24 02:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	11/03/24 02:24	200.0	181.4	180.6	R-A /Span * 100		0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/03/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/03/24 02:19	30.0	21.4	21.3	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/03/24 03:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	11/03/24 03:24	200.0	176.9	176.6	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/03/24 03:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	11/03/24 03:19	10.0	9.1	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/03/24 03:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	11/03/24 03:24	200.0	181.4	181.3	R-A /Span * 100		0.1

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/03/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/03/24 03:19	10.0	9.6	9.6	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/03/24 03:14	21.0	18.0	17.9	R-A		0.1
	Zero	11/03/24 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/04/24 02:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/04/24 02:24	200.0	181.4	180.8	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/04/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/04/24 02:19	30.0	21.4	21.3	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/04/24 03:14	200.0	0.0	0.4	R-A /Span * 100		0.2
	High	11/04/24 03:24	200.0	176.9	176.9	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/04/24 03:14	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	11/04/24 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/04/24 03:14	200.0	0.0	0.5	R-A /Span * 100		0.3
	High	11/04/24 03:24	200.0	181.4	181.7	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/04/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/04/24 03:19	10.0	9.6	9.6	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/04/24 03:14	21.0	18.0	18.0	R-A		0.0
	Zero	11/04/24 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/05/24 02:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	11/05/24 02:24	200.0	181.4	180.3	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/05/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/05/24 02:19	30.0	21.4	21.3	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/05/24 03:14	200.0	0.0	0.4	R-A /Span * 100		0.2
	High	11/05/24 03:24	200.0	176.9	175.6	R-A /Span * 100		0.7

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/05/24 03:14	10.0	0.0	0.3	R-A /Span * 100	3.0
	High	11/05/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/05/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/05/24 03:24	200.0	181.4	181.2	R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/05/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/05/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/05/24 03:14	21.0	18.0	17.9	R-A	0.1
	Zero	11/05/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/06/24 02:14	200.0	0.0	0.2	R-A /Span * 100	0.1
	High	11/06/24 02:24	200.0	181.4	181.4	R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/06/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/06/24 02:19	30.0	21.4	21.4	R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/06/24 03:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/06/24 03:24	200.0	176.9	175.8	R-A /Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/06/24 03:14	10.0	0.0	0.4	R-A /Span * 100	4.0
	High	11/06/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/06/24 03:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/06/24 03:24	200.0	181.4	182.3	R-A /Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/06/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/06/24 03:19	10.0	9.6	9.7	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/06/24 03:14	21.0	18.0	17.9	R-A	0.1
	Zero	11/06/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/06/24 12:07	200.0	0.0	0.6	R-A /Span * 100	0.3
	High	11/06/24 12:17	200.0	177.3	177.0	R-A /Span * 100	0.2

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/06/24 12:07	10.0	0.0		R-A /Span * 100	0.0
	High	11/06/24 12:12	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/06/24 12:07	200.0	0.1		R-A /Span * 100	0.1
	High	11/06/24 12:17	200.0	179.7		R-A /Span * 100	1.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/06/24 12:07	10.0	0.0		R-A /Span * 100	0.0
	High	11/06/24 12:12	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/06/24 12:07	18.0	18.0		R-A	0.0
	Zero	11/06/24 12:12	18.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/07/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/07/24 02:24	200.0	179.7	>1x Alert	R-A /Span * 100	3.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/07/24 02:14	30.0	0.1		R-A /Span * 100	0.3
	High	11/07/24 02:19	30.0	21.3	>1x Alert	R-A /Span * 100	4.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/07/24 03:14	200.0	0.0		R-A /Span * 100	0.5
	High	11/07/24 03:24	200.0	177.3		R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/07/24 03:14	10.0	0.1		R-A /Span * 100	1.0
	High	11/07/24 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/07/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/07/24 03:24	200.0	179.7		R-A /Span * 100	1.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/07/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/07/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/07/24 03:14	18.0	18.0		R-A	0.0
	Zero	11/07/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/07/24 16:27	200.0	0.0		R-A /Span * 100	0.2
	High	11/07/24 16:37	200.0	176.9		R-A /Span * 100	0.9

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/07/24 16:27	10.0	0.0	0.4	R-A /Span * 100		4.0
	High	11/07/24 16:32	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/07/24 16:27	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/07/24 16:37	200.0	181.4	181.8	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/07/24 16:27	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/07/24 16:32	10.0	9.6	9.6	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/07/24 16:27	21.0	18.0	17.9	R-A		0.1
	Zero	11/07/24 16:32	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/08/24 02:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	11/08/24 02:24	200.0	179.7	180.5	R-A /Span * 100		0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/08/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/08/24 02:19	30.0	21.3	21.3	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/08/24 02:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	11/08/24 02:24	200.0	181.4	181.6	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/08/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/08/24 02:19	30.0	21.2	21.4	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/08/24 03:14	200.0	0.0	0.5	R-A /Span * 100		0.3
	High	11/08/24 03:24	200.0	177.3	177.9	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/08/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/08/24 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/08/24 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/08/24 03:24	200.0	179.7	179.9	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/08/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/08/24 03:19	10.0	9.6	9.5	R-A /Span * 100		1.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/08/24 03:14	18.0	18.0	R-A		0.0
	Zero	11/08/24 03:19	18.0	-0.1	R-A		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/08/24 03:14	200.0	0.6	R-A /Span * 100		0.3
	High	11/08/24 03:24	200.0	177.7	R-A /Span * 100		0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/08/24 03:14	10.0	0.5	R-A /Span * 100		5.0
	High	11/08/24 03:19	10.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/08/24 03:14	200.0	0.1	R-A /Span * 100		0.1
	High	11/08/24 03:24	200.0	181.1	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/08/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/08/24 03:19	10.0	9.6	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/08/24 03:14	21.0	17.9	R-A		0.1
	Zero	11/08/24 03:19	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/08/24 21:25	200.0	0.5	R-A /Span * 100		0.3
	High	11/08/24 21:35	200.0	177.5	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/08/24 21:25	10.0	0.3	R-A /Span * 100		3.0
	High	11/08/24 21:30	10.0	9.2	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/08/24 21:25	200.0	0.2	R-A /Span * 100		0.1
	High	11/08/24 21:35	200.0	180.4	R-A /Span * 100		0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/08/24 21:25	10.0	0.0	R-A /Span * 100		0.0
	High	11/08/24 21:30	10.0	9.5	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/08/24 21:25	21.0	17.9	R-A		0.1
	Zero	11/08/24 21:30	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/09/24 02:14	200.0	-0.1	R-A /Span * 100		0.1
	High	11/09/24 02:24	200.0	180.5	R-A /Span * 100		0.4

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/09/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/09/24 02:19	30.0	21.3	21.3	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/09/24 02:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	11/09/24 02:24	200.0	181.4	181.8	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/09/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/09/24 02:19	30.0	21.2	21.4	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/09/24 03:14	200.0	0.0	0.9	R-A /Span * 100		0.5
	High	11/09/24 03:24	200.0	177.3	178.4	R-A /Span * 100		0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/09/24 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/09/24 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/09/24 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/09/24 03:24	200.0	179.7	179.8	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/09/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/09/24 03:19	10.0	9.6	9.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/09/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	11/09/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/09/24 03:14	200.0	0.0	0.5	R-A /Span * 100		0.3
	High	11/09/24 03:24	200.0	176.9	178.9	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/09/24 03:14	10.0	0.0	0.4	R-A /Span * 100		4.0
	High	11/09/24 03:19	10.0	9.1	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/09/24 03:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	11/09/24 03:24	200.0	181.4	180.9	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/09/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/09/24 03:19	10.0	9.6	9.6	R-A /Span * 100		0.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/09/24 03:14	21.0	18.0	17.9	R-A	0.1
	Zero	11/09/24 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/10/24 02:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/10/24 02:24	200.0	179.7	180.3	R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/10/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/10/24 02:19	30.0	21.3	21.2	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/10/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	11/10/24 03:24	200.0	177.3	178.6	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/10/24 03:14	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	11/10/24 03:19	10.0	9.1	9.3	R-A /Span * 100	2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/10/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/10/24 03:24	200.0	179.7	180.0	R-A /Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/10/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/10/24 03:19	10.0	9.6	9.5	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/10/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	11/10/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/11/24 02:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/11/24 02:24	200.0	179.7	180.1	R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/11/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/11/24 02:19	30.0	21.3	21.1	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/11/24 03:14	200.0	0.0	0.9	R-A /Span * 100	0.5
	High	11/11/24 03:24	200.0	177.3	179.5	R-A /Span * 100	1.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/11/24 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	11/11/24 03:19	10.0	9.1	9.2	R-A /Span * 100	1.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/11/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/11/24 03:24	200.0	179.7	179.6	R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/11/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/11/24 03:19	10.0	9.6	9.5	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/11/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	11/11/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/12/24 02:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/12/24 02:24	200.0	179.7	179.5	R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/12/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/12/24 02:19	30.0	21.3	20.9	R-A /Span * 100	1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/12/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	11/12/24 03:24	200.0	177.3	178.8	R-A /Span * 100	0.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/12/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/12/24 03:19	10.0	9.1	9.2	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/12/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/12/24 03:24	200.0	179.7	179.6	R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/12/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/12/24 03:19	10.0	9.6	9.5	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/12/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	11/12/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/13/24 02:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/13/24 02:24	200.0	179.7	179.5	R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/13/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/13/24 02:19	30.0	21.3	20.9	R-A /Span * 100	1.3

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/13/24 03:14	200.0	0.0	0.9	R-A /Span * 100		0.5
	High	11/13/24 03:24	200.0	177.3	179.6	R-A /Span * 100		1.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/13/24 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/13/24 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/13/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/13/24 03:24	200.0	179.7	179.5	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/13/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/13/24 03:19	10.0	9.6	9.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/13/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	11/13/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/14/24 02:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	11/14/24 02:24	200.0	179.7	179.0	R-A /Span * 100		0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/14/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/14/24 02:19	30.0	21.3	20.9	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/14/24 03:14	200.0	0.0	0.9	R-A /Span * 100		0.5
	High	11/14/24 03:24	200.0	177.3	178.9	R-A /Span * 100		0.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/14/24 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/14/24 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/14/24 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/14/24 03:24	200.0	179.7	179.5	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/14/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/14/24 03:19	10.0	9.6	9.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/14/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	11/14/24 03:19	18.0	0.0	-0.1	R-A		0.1

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/15/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/24 02:24	200.0	179.7	180.4	R-A /Span * 100		0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/15/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/24 02:19	30.0	21.3	21.1	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/15/24 03:14	200.0	0.0	0.9	R-A /Span * 100		0.5
	High	11/15/24 03:24	200.0	177.3	179.6	R-A /Span * 100		1.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/15/24 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/15/24 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/15/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/24 03:24	200.0	179.7	180.4	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/15/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/24 03:19	10.0	9.6	9.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/15/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	11/15/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/20/24 18:05	200.0	0.0	1.0	R-A /Span * 100		0.5
	High	11/20/24 18:15	200.0	177.3	182.0	R-A /Span * 100		2.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/20/24 18:05	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/20/24 18:10	10.0	9.1	9.3	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/20/24 18:05	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/20/24 18:15	200.0	179.7	180.1	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/20/24 18:05	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/20/24 18:10	10.0	9.6	9.6	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/20/24 18:05	18.0	18.0	18.1	R-A		0.1
	Zero	11/20/24 18:10	18.0	0.0	-0.1	R-A		0.1

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/22/24 02:11	200.0	0.0	0.9	R-A /Span * 100	0.5
	High	11/22/24 02:21	200.0	177.3	182.5	R-A /Span * 100	2.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/22/24 02:11	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/22/24 02:16	10.0	9.1	9.3	R-A /Span * 100	2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/22/24 02:11	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/22/24 02:21	200.0	179.7	180.3	R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/22/24 02:11	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/22/24 02:16	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/22/24 02:11	18.0	18.0	18.1	R-A	0.1
	Zero	11/22/24 02:16	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/22/24 02:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/22/24 02:24	200.0	179.7	185.1	>1x Alert R-A /Span * 100	2.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/22/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/22/24 02:19	30.0	21.3	22.0	R-A /Span * 100	2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/22/24 03:14	200.0	0.0	1.0	R-A /Span * 100	0.5
	High	11/22/24 03:24	200.0	177.3	182.8	R-A /Span * 100	2.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/22/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/22/24 03:19	10.0	9.1	9.4	R-A /Span * 100	3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/22/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/22/24 03:24	200.0	179.7	181.0	R-A /Span * 100	0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/22/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/22/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/22/24 03:14	18.0	18.0	18.1	R-A	0.1
	Zero	11/22/24 03:19	18.0	0.0	-0.1	R-A	0.1

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/23/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/24 02:24	200.0	179.7	182.1	R-A /Span * 100		1.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/23/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/24 02:19	30.0	21.3	21.2	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/23/24 03:14	200.0	0.0	1.0	R-A /Span * 100		0.5
	High	11/23/24 03:24	200.0	177.3	183.6	R-A /Span * 100		3.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/23/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/24 03:19	10.0	9.1	9.4	R-A /Span * 100		3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/23/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/24 03:24	200.0	179.7	181.2	R-A /Span * 100		0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/23/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/24 03:19	10.0	9.6	9.6	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/23/24 03:14	18.0	18.0	18.1	R-A		0.1
	Zero	11/23/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/24/24 02:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	11/24/24 02:24	200.0	179.7	183.2	R-A /Span * 100		1.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/24/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/24/24 02:19	30.0	21.3	21.4	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/24/24 03:14	200.0	0.0	1.1	R-A /Span * 100		0.6
	High	11/24/24 03:24	200.0	177.3	183.6	R-A /Span * 100		3.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/24/24 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/24/24 03:19	10.0	9.1	9.4	R-A /Span * 100		3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/24/24 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/24/24 03:24	200.0	179.7	181.0	R-A /Span * 100		0.7

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/24/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/24/24 03:19	10.0	9.6	9.6	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/24/24 03:14	18.0	18.0	18.1	R-A		0.1
	Zero	11/24/24 03:19	18.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/25/24 02:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	11/25/24 02:24	200.0	179.7	182.7	R-A /Span * 100		1.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/25/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/25/24 02:19	30.0	21.3	21.4	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/25/24 03:14	200.0	0.0	1.0	R-A /Span * 100		0.5
	High	11/25/24 03:24	200.0	177.3	182.9	R-A /Span * 100		2.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/25/24 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/25/24 03:19	10.0	9.1	9.4	R-A /Span * 100		3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/25/24 03:14	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	11/25/24 03:24	200.0	179.7	180.7	R-A /Span * 100		0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/25/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/25/24 03:19	10.0	9.6	9.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/25/24 03:14	18.0	18.0	18.1	R-A		0.1
	Zero	11/25/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/26/24 02:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	11/26/24 02:24	200.0	179.7	181.5	R-A /Span * 100		0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/26/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/26/24 02:19	30.0	21.3	21.1	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/26/24 03:14	200.0	0.0	1.1	R-A /Span * 100		0.6
	High	11/26/24 03:24	200.0	177.3	183.2	R-A /Span * 100		3.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/26/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	11/26/24 03:19	10.0	9.1		R-A /Span * 100	3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/26/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/26/24 03:24	200.0	179.7		R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/26/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/26/24 03:19	10.0	9.6		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/26/24 03:14	18.0	18.0		R-A	0.1
	Zero	11/26/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Offline	Pass	
	Zero	11/26/24 11:26	200.0	0.0		R-A /Span * 100	0.1
	High	11/26/24 11:36	200.0	176.9		R-A /Span * 100	0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Offline	Pass	
	Zero	11/26/24 11:26	10.0	0.0		R-A /Span * 100	0.0
	High	11/26/24 11:31	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Offline	Offline	
	Zero	11/26/24 11:26	200.0	0.0	off	R-A /Span * 100	0.1
	High	11/26/24 11:36	200.0	181.4	off	R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Offline	Offline	
	Zero	11/26/24 11:26	10.0	0.0	off	R-A /Span * 100	0.0
	High	11/26/24 11:31	10.0	9.6	off	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Offline	Offline	
	High	11/26/24 11:26	21.0	18.0	off	R-A	0.0
	Zero	11/26/24 11:31	21.0	0.0	off	R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Offline	Pass	
	Zero	11/26/24 14:25	200.0	0.0		R-A /Span * 100	0.0
	High	11/26/24 14:35	200.0	176.9		R-A /Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Offline	Pass	
	Zero	11/26/24 14:25	10.0	0.0		R-A /Span * 100	0.0
	High	11/26/24 14:30	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Offline	Offline	
	Zero	11/26/24 14:25	200.0	0.0	off	R-A /Span * 100	0.1
	High	11/26/24 14:35	200.0	181.4	off	R-A /Span * 100	0.5

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Offline	Offline	
	Zero	11/26/24 14:25	10.0	0.0	off	R-A /Span * 100	0.0
	High	11/26/24 14:30	10.0	9.6	off	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Offline	Offline	
	High	11/26/24 14:25	21.0	18.0	off	R-A	0.1
	Zero	11/26/24 14:30	21.0	0.0	off	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/27/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/27/24 02:24	200.0	179.7		R-A /Span * 100	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/27/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	11/27/24 02:19	30.0	21.5		R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/27/24 03:14	200.0	0.0		R-A /Span * 100	0.4
	High	11/27/24 03:24	200.0	177.3		R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/27/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/27/24 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/27/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/27/24 03:24	200.0	179.7		R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/27/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/27/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/27/24 03:14	18.0	18.0		R-A	0.0
	Zero	11/27/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/28/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/28/24 02:24	200.0	179.7		R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/28/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	11/28/24 02:19	30.0	21.5		R-A /Span * 100	1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/28/24 03:14	200.0	0.0		R-A /Span * 100	0.5
	High	11/28/24 03:24	200.0	177.3		R-A /Span * 100	0.4

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/28/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	11/28/24 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/28/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/28/24 03:24	200.0	179.7		R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/28/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/28/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/28/24 03:14	18.0	18.0		R-A	0.0
	Zero	11/28/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/29/24 02:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/29/24 02:24	200.0	179.7		R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/29/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	11/29/24 02:19	30.0	21.5		R-A /Span * 100	1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/29/24 03:14	200.0	0.0		R-A /Span * 100	0.5
	High	11/29/24 03:24	200.0	177.3		R-A /Span * 100	0.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/29/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	11/29/24 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/29/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/29/24 03:24	200.0	179.7		R-A /Span * 100	0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/29/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/29/24 03:19	10.0	9.6		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/29/24 03:14	18.0	18.0		R-A	0.0
	Zero	11/29/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/30/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/30/24 02:24	200.0	181.0		R-A /Span * 100	2.2

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/30/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/30/24 02:19	30.0	21.5	21.2	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/30/24 03:14	200.0	0.0	0.9	R-A /Span * 100		0.5
	High	11/30/24 03:24	200.0	178.4	176.4	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/30/24 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/30/24 03:19	10.0	9.1	9.0	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/30/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/30/24 03:24	200.0	181.0	179.0	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/30/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/30/24 03:19	10.0	9.6	9.6	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/30/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	11/30/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/01/24 02:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	12/01/24 02:24	200.0	181.0	179.3	R-A /Span * 100		0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/01/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/01/24 02:19	30.0	21.5	21.0	R-A /Span * 100		1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/01/24 03:14	200.0	0.0	1.0	R-A /Span * 100		0.5
	High	12/01/24 03:24	200.0	178.4	177.0	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/01/24 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/01/24 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/01/24 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/01/24 03:24	200.0	181.0	179.6	R-A /Span * 100		0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/01/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/01/24 03:19	10.0	9.6	9.6	R-A /Span * 100		0.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/01/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	12/01/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/02/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/02/24 02:24	200.0	181.0	179.2	R-A /Span * 100		0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/02/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/02/24 02:19	30.0	21.5	21.0	R-A /Span * 100		1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/02/24 03:14	200.0	0.0	0.9	R-A /Span * 100		0.5
	High	12/02/24 03:24	200.0	178.4	176.4	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/02/24 03:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	12/02/24 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/02/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/02/24 03:24	200.0	181.0	178.9	R-A /Span * 100		1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/02/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/02/24 03:19	10.0	9.6	9.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/02/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	12/02/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/03/24 02:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	12/03/24 02:24	200.0	181.0	179.2	R-A /Span * 100		0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/03/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/03/24 02:19	30.0	21.5	21.0	R-A /Span * 100		1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/03/24 03:14	200.0	0.0	1.0	R-A /Span * 100		0.5
	High	12/03/24 03:24	200.0	178.4	176.9	R-A /Span * 100		0.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/03/24 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/03/24 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/03/24 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	12/03/24 03:24	200.0	181.0	178.9	R-A /Span * 100		1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/03/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/03/24 03:19	10.0	9.6	9.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/03/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	12/03/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/04/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/04/24 02:24	200.0	181.0	179.4	R-A /Span * 100		0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/04/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/04/24 02:19	30.0	21.5	21.2	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/04/24 03:14	200.0	0.0	1.0	R-A /Span * 100		0.5
	High	12/04/24 03:24	200.0	178.4	177.4	R-A /Span * 100		0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/04/24 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/04/24 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/04/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/04/24 03:24	200.0	181.0	179.3	R-A /Span * 100		0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/04/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/04/24 03:19	10.0	9.6	9.5	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/04/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	12/04/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/05/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/05/24 02:24	200.0	181.0	180.0	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/05/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/05/24 02:19	30.0	21.5	21.1	R-A /Span * 100		1.3

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/05/24 03:14	200.0	0.0	1.0	R-A /Span * 100		0.5
	High	12/05/24 03:24	200.0	178.4	178.8	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/05/24 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/05/24 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/05/24 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/05/24 03:24	200.0	181.0	179.8	R-A /Span * 100		0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/05/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/05/24 03:19	10.0	9.6	9.6	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/05/24 03:14	18.0	18.0	18.1	R-A		0.1
	Zero	12/05/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/06/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/06/24 02:24	200.0	181.0	178.9	R-A /Span * 100		1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/06/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/06/24 02:19	30.0	21.5	21.0	R-A /Span * 100		1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/06/24 03:14	200.0	0.0	1.0	R-A /Span * 100		0.5
	High	12/06/24 03:24	200.0	178.4	179.1	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/06/24 03:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	12/06/24 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/06/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/06/24 03:24	200.0	181.0	178.8	R-A /Span * 100		1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/06/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/06/24 03:19	10.0	9.6	9.4	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/06/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	12/06/24 03:19	18.0	0.0	-0.1	R-A		0.1

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/07/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/07/24 02:24	200.0	181.0	179.7	R-A /Span * 100		0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/07/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/07/24 02:19	30.0	21.5	21.2	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/07/24 03:14	200.0	0.0	1.0	R-A /Span * 100		0.5
	High	12/07/24 03:24	200.0	178.4	178.8	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/07/24 03:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	12/07/24 03:19	10.0	9.1	9.3	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/07/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/07/24 03:24	200.0	181.0	189.1	>1x Alert R-A /Span * 100		4.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/07/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/07/24 03:19	10.0	9.6	10.2	R-A		0.6
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/07/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	12/07/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/08/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/08/24 02:24	200.0	181.0	179.4	R-A /Span * 100		0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/08/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/08/24 02:19	30.0	21.5	21.3	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/08/24 03:14	200.0	0.0	0.9	R-A /Span * 100		0.5
	High	12/08/24 03:24	200.0	178.4	179.0	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/08/24 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/08/24 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/08/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/08/24 03:24	200.0	181.0	188.7	>1x Alert R-A /Span * 100		3.9

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/08/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/08/24 03:19	10.0	9.6	10.2	R-A		0.6
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/08/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	12/08/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/09/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/09/24 02:24	200.0	181.0	180.0	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/09/24 02:14	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	12/09/24 02:19	30.0	21.5	21.3	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/09/24 03:14	200.0	0.0	1.1	R-A /Span * 100		0.6
	High	12/09/24 03:24	200.0	178.4	179.2	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/09/24 03:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	12/09/24 03:19	10.0	9.1	9.3	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/09/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/09/24 03:24	200.0	181.0	188.7	>1x Alert R-A /Span * 100		3.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/09/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/09/24 03:19	10.0	9.6	10.2	R-A		0.6
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/09/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	12/09/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/09/24 16:58	200.0	0.0	0.7	R-A /Span * 100		0.4
	High	12/09/24 17:08	200.0	178.4	178.8	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/09/24 16:58	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/09/24 17:03	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/09/24 16:58	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/09/24 17:08	200.0	181.0	181.3	R-A /Span * 100		0.2

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/09/24 16:58	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/09/24 17:03	10.0	9.6	9.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/09/24 16:58	18.0	18.0	18.0	R-A		0.0
	Zero	12/09/24 17:03	18.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/10/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/10/24 02:24	200.0	181.0	179.4	R-A /Span * 100		0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/10/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/10/24 02:19	30.0	21.5	21.1	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/10/24 03:14	200.0	0.0	1.0	R-A /Span * 100		0.5
	High	12/10/24 03:24	200.0	178.4	178.8	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/10/24 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/10/24 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/10/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/10/24 03:24	200.0	181.0	181.1	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/10/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/10/24 03:19	10.0	9.6	9.6	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/10/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	12/10/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/11/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/11/24 02:24	200.0	181.0	179.1	R-A /Span * 100		1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/11/24 02:14	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	12/11/24 02:19	30.0	21.5	21.0	R-A /Span * 100		1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/11/24 03:14	200.0	0.0	1.1	R-A /Span * 100		0.6
	High	12/11/24 03:24	200.0	178.4	179.6	R-A /Span * 100		0.6

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/11/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	12/11/24 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/11/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/11/24 03:24	200.0	181.0		R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/11/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/11/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/11/24 03:14	18.0	18.0		R-A	0.0
	Zero	12/11/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/12/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/12/24 02:24	200.0	181.0		R-A /Span * 100	0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/12/24 02:14	30.0	0.0		R-A /Span * 100	0.3
	High	12/12/24 02:19	30.0	21.5		R-A /Span * 100	1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/12/24 03:14	200.0	0.0		R-A /Span * 100	0.5
	High	12/12/24 03:24	200.0	178.4		R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/12/24 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	12/12/24 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/12/24 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	12/12/24 03:24	200.0	181.0		R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/12/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/12/24 03:19	10.0	9.6		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/12/24 03:14	18.0	18.0		R-A	0.1
	Zero	12/12/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/13/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/13/24 02:24	200.0	181.0		R-A /Span * 100	1.4

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/13/24 02:14	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	12/13/24 02:19	30.0	21.5	20.9	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/13/24 03:14	200.0	0.0	0.9	R-A /Span * 100		0.5
	High	12/13/24 03:24	200.0	178.4	178.0	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/13/24 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/13/24 03:19	10.0	9.1	9.0	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/13/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/13/24 03:24	200.0	181.0	180.6	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/13/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/13/24 03:19	10.0	9.6	9.6	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/13/24 03:14	18.0	18.0	17.9	R-A		0.1
	Zero	12/13/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/14/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/14/24 02:24	200.0	181.0	178.7	R-A /Span * 100		1.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/14/24 02:14	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	12/14/24 02:19	30.0	21.5	21.1	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/14/24 03:14	200.0	0.0	0.9	R-A /Span * 100		0.5
	High	12/14/24 03:24	200.0	178.4	178.0	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/14/24 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/14/24 03:19	10.0	9.1	9.0	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/14/24 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/14/24 03:24	200.0	181.0	181.0	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/14/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/14/24 03:19	10.0	9.6	9.6	R-A /Span * 100		0.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/14/24 03:14	18.0	18.0	17.9	R-A		0.1
	Zero	12/14/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/15/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/15/24 02:24	200.0	181.0	179.2	R-A /Span * 100		0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/15/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/15/24 02:19	30.0	21.5	21.3	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/15/24 03:14	200.0	0.0	1.0	R-A /Span * 100		0.5
	High	12/15/24 03:24	200.0	178.4	177.3	R-A /Span * 100		0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/15/24 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/15/24 03:19	10.0	9.1	9.0	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/15/24 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/15/24 03:24	200.0	181.0	180.9	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/15/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/15/24 03:19	10.0	9.6	9.6	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/15/24 03:14	18.0	18.0	17.9	R-A		0.1
	Zero	12/15/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/16/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/16/24 02:24	200.0	181.0	178.9	R-A /Span * 100		1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/16/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/16/24 02:19	30.0	21.5	21.1	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/16/24 03:14	200.0	0.0	0.9	R-A /Span * 100		0.5
	High	12/16/24 03:24	200.0	178.4	178.3	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/16/24 03:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	12/16/24 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/16/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/16/24 03:24	200.0	181.0		R-A /Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/16/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/16/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/16/24 03:14	18.0	17.9		R-A	0.1
	Zero	12/16/24 03:19	18.0	-0.1		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/17/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/17/24 02:24	200.0	181.0		R-A /Span * 100	1.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/17/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/17/24 02:19	30.0	21.5		R-A /Span * 100	1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/17/24 03:14	200.0	0.0		R-A /Span * 100	0.5
	High	12/17/24 03:24	200.0	178.4		R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/17/24 03:14	10.0	0.0		R-A /Span * 100	2.0
	High	12/17/24 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/17/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/17/24 03:24	200.0	181.0		R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/17/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/17/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/17/24 03:14	18.0	17.9		R-A	0.1
	Zero	12/17/24 03:19	18.0	-0.1		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/18/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/18/24 02:24	200.0	181.0		R-A /Span * 100	1.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/18/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/18/24 02:19	30.0	21.5		R-A /Span * 100	1.7

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/18/24 03:14	200.0	0.0	0.9	R-A /Span * 100	0.5
	High	12/18/24 03:24	200.0	178.4	177.0	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/18/24 03:14	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	12/18/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/18/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	12/18/24 03:24	200.0	181.0	180.5	R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/18/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/18/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/18/24 03:14	18.0	18.0	17.9	R-A	0.1
	Zero	12/18/24 03:19	18.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/19/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/19/24 02:24	200.0	181.0	178.7	R-A /Span * 100	1.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/19/24 02:14	30.0	0.0	0.1	R-A /Span * 100	0.3
	High	12/19/24 02:19	30.0	21.5	21.0	R-A /Span * 100	1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/19/24 03:14	200.0	0.0	1.0	R-A /Span * 100	0.5
	High	12/19/24 03:24	200.0	178.4	179.8	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/19/24 03:14	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	12/19/24 03:19	10.0	9.1	9.2	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/19/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	12/19/24 03:24	200.0	181.0	181.0	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/19/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/19/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/19/24 03:14	18.0	18.0	17.9	R-A	0.1
	Zero	12/19/24 03:19	18.0	0.0	-0.1	R-A	0.1

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Pass
	Zero	12/19/24 13:33	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	12/19/24 13:43	200.0	176.9	176.9	R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Offline	Pass
	Zero	12/19/24 13:33	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	12/19/24 13:38	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Offline
	Zero	12/19/24 13:33	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	12/19/24 13:43	200.0	181.4	181.1	R-A /Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Offline	Offline
	Zero	12/19/24 13:33	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/19/24 13:38	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Offline
	High	12/19/24 13:33	21.0	18.0	17.9	R-A	0.1
	Zero	12/19/24 13:38	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	12/19/24 13:34	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	12/19/24 13:44	200.0	178.4	179.4	R-A /Span * 100	0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	12/19/24 13:34	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/19/24 13:39	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	12/19/24 13:34	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	12/19/24 13:44	200.0	181.0	181.5	R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	12/19/24 13:34	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/19/24 13:39	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	12/19/24 13:34	18.0	18.0	18.0	R-A	0.0
	Zero	12/19/24 13:39	18.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	12/20/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/20/24 02:24	200.0	181.0	181.0	R-A /Span * 100	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	12/20/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/20/24 02:19	30.0	21.5	21.6	R-A /Span * 100	0.3

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/20/24 03:14	200.0	0.0	0.7	R-A /Span * 100	0.4
	High	12/20/24 03:24	200.0	178.4	179.9	R-A /Span * 100	0.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/20/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/20/24 03:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/20/24 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	12/20/24 03:24	200.0	181.0	180.9	R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/20/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/20/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/20/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	12/20/24 03:19	18.0	0.0	-0.1	R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/21/24 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/21/24 02:24	200.0	181.0	181.1	R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/21/24 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/21/24 02:19	30.0	21.5	21.6	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/21/24 03:14	200.0	0.0	0.8	R-A /Span * 100	0.4
	High	12/21/24 03:24	200.0	178.4	180.4	R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/21/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/21/24 03:19	10.0	9.1	9.1	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/21/24 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/21/24 03:24	200.0	181.0	181.0	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/21/24 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/21/24 03:19	10.0	9.6	9.6	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/21/24 03:14	18.0	18.0	18.0	R-A	0.0
	Zero	12/21/24 03:19	18.0	0.0	0.0	R-A	0.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/22/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/22/24 02:24	200.0	181.0	180.5	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/22/24 02:14	30.0	0.0	0.1	R-A /Span * 100		0.3
	High	12/22/24 02:19	30.0	21.5	21.5	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/22/24 03:14	200.0	0.0	0.7	R-A /Span * 100		0.4
	High	12/22/24 03:24	200.0	178.4	180.1	R-A /Span * 100		0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/22/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/22/24 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/22/24 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/22/24 03:24	200.0	181.0	180.7	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/22/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/22/24 03:19	10.0	9.6	9.6	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/22/24 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	12/22/24 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/23/24 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/23/24 02:24	200.0	181.0	180.6	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/23/24 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/23/24 02:19	30.0	21.5	21.5	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/23/24 03:14	200.0	0.0	0.9	R-A /Span * 100		0.5
	High	12/23/24 03:24	200.0	178.4	180.2	R-A /Span * 100		0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/23/24 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/23/24 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/23/24 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/23/24 03:24	200.0	181.0	180.8	R-A /Span * 100		0.1

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/23/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/23/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/23/24 03:14	18.0	18.0		R-A	0.0
	Zero	12/23/24 03:19	18.0	-0.1		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/24/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/24/24 02:24	200.0	181.0		R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/24/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/24/24 02:19	30.0	21.5		R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/24/24 03:14	200.0	0.0		R-A /Span * 100	0.3
	High	12/24/24 03:24	200.0	178.4		R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/24/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/24/24 03:19	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/24/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/24/24 03:24	200.0	181.0		R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/24/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/24/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/24/24 03:14	18.0	18.0		R-A	0.0
	Zero	12/24/24 03:19	18.0	-0.1		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/25/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/25/24 02:24	200.0	181.0		R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/25/24 02:14	30.0	0.0		R-A /Span * 100	0.3
	High	12/25/24 02:19	30.0	21.5		R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/25/24 03:14	200.0	0.0		R-A /Span * 100	0.4
	High	12/25/24 03:24	200.0	178.4		R-A /Span * 100	0.8

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/25/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/25/24 03:19	10.0	9.1	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/25/24 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/25/24 03:24	200.0	181.0	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/25/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/25/24 03:19	10.0	9.6	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/25/24 03:14	18.0	18.0	R-A		0.0
	Zero	12/25/24 03:19	18.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/26/24 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/26/24 02:24	200.0	181.0	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/26/24 02:14	30.0	0.0	R-A /Span * 100		0.3
	High	12/26/24 02:19	30.0	21.5	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/26/24 03:14	200.0	0.0	R-A /Span * 100		0.4
	High	12/26/24 03:24	200.0	178.4	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/26/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/26/24 03:19	10.0	9.1	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/26/24 03:14	200.0	0.0	R-A /Span * 100		0.1
	High	12/26/24 03:24	200.0	181.0	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/26/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/26/24 03:19	10.0	9.6	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/26/24 03:14	18.0	18.0	R-A		0.0
	Zero	12/26/24 03:19	18.0	0.0	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/27/24 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/27/24 02:24	200.0	181.0	R-A /Span * 100		0.3

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/27/24 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/27/24 02:19	30.0	21.5		R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/27/24 03:14	200.0	0.0		R-A /Span * 100	0.3
	High	12/27/24 03:24	200.0	178.4		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/27/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/27/24 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/27/24 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/27/24 03:24	200.0	181.0		R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/27/24 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/27/24 03:19	10.0	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/27/24 03:14	18.0	18.0		R-A	0.0
	Zero	12/27/24 03:19	18.0	0.0		R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Offline	Pass	
	Zero	12/27/24 14:26	200.0	0.0		R-A /Span * 100	0.1
	High	12/27/24 14:36	200.0	176.9		R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Offline	Pass	
	Zero	12/27/24 14:26	10.0	0.0		R-A /Span * 100	2.0
	High	12/27/24 14:31	10.0	9.1		R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Offline	Offline	
	Zero	12/27/24 14:26	200.0	0.0	off	R-A /Span * 100	0.1
	High	12/27/24 14:36	200.0	181.4	off	R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Offline	Offline	
	Zero	12/27/24 14:26	10.0	0.0	off	R-A /Span * 100	0.0
	High	12/27/24 14:31	10.0	9.6	off	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Offline	Offline	
	High	12/27/24 14:26	21.0	18.0	off	R-A	0.0
	Zero	12/27/24 14:31	21.0	0.0	off	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/28/24 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/28/24 02:24	200.0	181.0		R-A /Span * 100	0.1

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	12/28/24 02:14	30.0	0.0	0.1		R-A /Span * 100	0.3
	High	12/28/24 02:19	30.0	21.5	21.6		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	12/28/24 03:14	200.0	0.0	0.7		R-A /Span * 100	0.4
	High	12/28/24 03:24	200.0	178.4	178.0		R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	12/28/24 03:14	10.0	0.0	0.0		R-A /Span * 100	0.0
	High	12/28/24 03:19	10.0	9.1	9.0		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	12/28/24 03:14	200.0	0.0	0.0		R-A /Span * 100	0.0
	High	12/28/24 03:24	200.0	181.0	181.3		R-A /Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	12/28/24 03:14	10.0	0.0	0.0		R-A /Span * 100	0.0
	High	12/28/24 03:19	10.0	9.6	9.6		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	12/28/24 03:14	18.0	18.0	18.0		R-A	0.0
	Zero	12/28/24 03:19	18.0	0.0	-0.1		R-A	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Offline		Pass
	Zero	12/28/24 22:56	10.0	0.0	-0.2		R-A /Span * 100	2.0
	High	12/28/24 23:01	10.0	9.1	9.1		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Offline		Offline
	Zero	12/28/24 22:56	10.0	0.0	0.0	off	R-A /Span * 100	0.0
	High	12/28/24 23:01	10.0	9.6	9.7	off	R-A /Span * 100	1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	12/29/24 02:14	200.0	0.0	0.0		R-A /Span * 100	0.0
	High	12/29/24 02:24	200.0	180.6	179.4		R-A /Span * 100	0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	12/29/24 02:14	30.0	0.0	0.1		R-A /Span * 100	0.3
	High	12/29/24 02:19	30.0	21.5	21.6		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	12/29/24 03:14	200.0	0.0	0.6		R-A /Span * 100	0.3
	High	12/29/24 03:24	200.0	178.3	179.1		R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	12/29/24 03:14	10.0	0.0	0.0		R-A /Span * 100	0.0
	High	12/29/24 03:19	10.0	9.1	9.0		R-A /Span * 100	1.0

Daily Calibration Results

All Units

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 11:15 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/29/24 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/29/24 03:24	200.0	180.6	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/29/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/29/24 03:19	10.0	9.6	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/29/24 03:14	18.0	18.0	R-A		0.0
	Zero	12/29/24 03:19	18.0	-0.1	R-A		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/30/24 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/30/24 02:24	200.0	180.6	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/30/24 02:14	30.0	0.0	R-A /Span * 100		0.3
	High	12/30/24 02:19	30.0	21.5	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/30/24 03:14	200.0	0.0	R-A /Span * 100		0.4
	High	12/30/24 03:24	200.0	178.3	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/30/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/30/24 03:19	10.0	9.1	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/30/24 03:14	200.0	0.0	R-A /Span * 100		0.1
	High	12/30/24 03:24	200.0	180.6	R-A /Span * 100		0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/30/24 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/30/24 03:19	10.0	9.6	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/30/24 03:14	18.0	18.0	R-A		0.0
	Zero	12/30/24 03:19	18.0	0.0	R-A		0.1