

DOCKETED

Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	261240
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q4 2024 - Part 1 - searchable
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	1/22/2025 11:14:01 AM
Docketed Date:	1/22/2025



REP

**Roseville Energy Park
(03-AFC-01C)**

Quarterly Air Quality Report

2024-Q4

**Reporting Period: October 1, 2024 – December 31, 2024
Prepared on: January 1, 2025**

Submitted to:

California Energy Commission

QUARTERLY AIR QUALITY REPORT

Part I. Identification

- a. Quarterly emission report period: **OCTOBER 1, 2024 – DECEMBER 31, 2024**
- b. Reporting date: **JANUARY 1, 2025**
- c. Person completing report: **JULIE MANFREDI**
- d. Plant name: **ROSEVILLE ENERGY PARK**
- e. Plant location:
 - 5120 PHILLIP ROAD**
 - ROSEVILLE, CA 95747**
- f. Person responsible for review and integrity of report: **NATHAN RIBORDY**
- g. Mailing address of report reviewer:
 - 5120 PHILLIP ROAD**
 - ROSEVILLE, CA 95747**
- h. Telephone number of report reviewer: **916-746-1673**

Part II. Measuring Instrumentation Information:

Monitor	Type	Manufacturer	Serial No.	Model No.	Available for Operation
Combustion Turbine Generator #1 (CT1)	Natl Gas Fired, Combined Cycle with Dry Low Nox Combustors	Siemens	B005712	SGT800	2007
CT1 SCR Catalyst	Ammonia Injection System within the Heat Recovery Steam Generator	Peerless	70373		2007
CT1 Oxidation Catalyst			017421-CV		2007
Combustion Turbine Generator #2 (CT2)	Natl Gas Fired, Combined Cycle with Dry Low Nox Combustors	Siemens	B005713	SGT800	2007
CT2 SCR Catalyst	Ammonia Injection System within the Heat Recovery Steam Generator	Peerless	70373		2007
CT2 Oxidation Catalyst			017421-CV		2007
EMERGENCY GENERATOR ENGINE	Diesel Engine	Caterpillar	AFN01451	3412CDITA	2007
FIRE PUMP ENGINE	Diesel Engine	Clarke	CD6068B003958	JU6H-UF60	2007

Part III. Excess Emissions by Pollutant

SEE ATTACHED

Part IV. CEMS Span and Range

Combined-Cycle Turbine CEMS Span and Range

GAS	SPAN VALUE	RANGE
SCR Inlet NOx	30 ppm	0-30 ppm
	200 ppm	0-200 ppm
Stack NOx	10 ppm	0-10 ppm
	200 ppm	0-200 ppm
Oxygen	20.9%	0-25%
CO	10 ppm	0-10 ppm
	200 ppm	0-200 ppm

Part V. Types of Fuels Combusted

NATURAL GAS

Part VI. Continuous Emissions Monitoring System Operation Changes and Failures

SEE ATTACHED

Part VII. Certification of Report Integrity by Reviewer

**THIS IS TO CERTIFY THAT TO THE BEST OF MY
KNOWLEDGE THE INFORMATION PROVIDED IN THE
ABOVE REPORT IS BOTH COMPLETE AND ACCURATE.**

NAME: NATHAN RIBORDY



Nathan Ribordy (Jan 15, 2025 12:37 PST)

TITLE: POWER GENERATION SUPERINTENDENT

DATE: JANUARY 19, 2025

LIST OF ATTACHMENTS

I. PERMIT CONDITIONS (OTHER)

REP CONDITION #	DESCRIPTION
AQ-20	Sulfur content of fuel
AQ-21	Startup and shutdown emission limits
AQ-47, AQ-69, AQ-90 & AQ-103	No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.
AQ-48, AQ-91 & AQ-104	Stack emissions opacity, nuisance complaints for more than 3 minutes
AQ-86	Diesel Fire pump maintenance and testing log, limited to 50 hours per year
AQ-87	Diesel Fire pump operation limited to 24 hours.
AQ-88 & AQ-101	Sulfur content of diesel fuel
AQ-89 & AQ-102	Diesel engine operation and maintenance records
AQ-99	Emergency Generator maintenance and testing log, limited to 50 hours per year. Logs kept for 5 years.
AQ-100	Emergency Generator operation limited to 24 hours.

II. EMISSIONS OVERVIEW

REP CONDITION #	DESCRIPTION
AQ-15	Selective catalytic reduction (SCR) system and an oxidation catalyst on the gas turbine
AQ-32	NOX & CO Hourly/Daily/Quarterly Emissions
AQ-33	SOX - Hourly/Daily/Quarterly Emissions
AQ-51	Ammonia slip exceedances
AQ-54 thru AQ-63 & AQ-71 (AQ-SC6)	Fuel use emission and operational data - Hourly/Daily/Quarterly
AQ-70	PM10 emissions rate from cooling tower shall not exceed lbs per day or quarter limits

III. EMISSIONS DEVIATIONS

REP CONDITION #	DESCRIPTION
AQ-34	Records: occurrence, duration, and type of any startup, shutdown, or malfunction; performance testing, evaluations, calibrations, checks, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any continuous emission monitor; emission measurements, total daily and rolling twelve-month average hours of operation, hourly quantity of fuel used, and gross three-hour average operating load.
AQ-36 thru AQ-38, AQ-41, & AQ-117	PCAPCD notifications/corrective action: breakdowns, excess emissions, CEMS inoperable, or a negative declaration when no excess emissions occurred.
AQ-40	CEMS quality assurance test failures

I. Permit Conditions (Other)

AQ-20

AQ-20 The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas.

Verification: The Project owner shall submit to the CPM the most recent fuel testing analysis performed as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6



Search

INSIDetracc Login

Survey Results

Note: Starting Q4 2022, we began breaking sulfur data down monthly. Data will still be updated on a quarterly basis just with additional granularity.

Jump to:

[2021 - 2024](#)

[2016 - 2020](#)

[2011 - 2015](#)

[2006 - 2010](#)

2021 - 2024

2024

Date	Total Sulfur Maximum		Total Sulfur Average all sites	
	PPMv	gr/100 scf	PPMv	gr/100 scf
2024				
Fourth Quarter	3.9	0.23	2.7	0.16
Fourth Quarter - October	3.7	0.22	2.7	0.16
Fourth Quarter - November	3.7	0.22	2.7	0.16
Fourth Quarter - December	3.9	0.23	2.9	0.17

AQ20 ROSEVILLE ENERGY PARK

4Q24

Fuel Quality Analysis BTU values

<http://www.pge.com/pij>

	OCT	NOV	DEC
1	1075.43	1044.93	1051.63
2	1065.15	1044.24	1053.33
3	1058.93	1046.77	1053.22
4	1056.89	1047.58	1052.40
5	1056.85	1047.13	1052.15
6	1058.35	1044.99	1051.58
7	1055.79	1046.68	1050.88
8	1053.23	1047.77	1051.35
9	1046.61	1049.93	1054.53
10	1043.47	1049.48	1056.47
11	1047.31	1050.08	1052.78
12	1049.20	1052.89	1054.96
13	1053.62	1,050.75	1055.01
14	1056.05	1053.79	1056.55
15	1057.74	1055.13	1054.39
16	1057.14	1056.42	1052.92
17	1053.99	1052.85	1053.04
18	1054.21	1048.89	1053.15
19	1052.39	1048.88	1054.57
20	1050.66	1049.40	1054.60
21	1053.13	1049.37	1015.11
22	1052.20	1048.23	1058.35
23	1052.53	1046.69	1055.75
24	1052.18	1047.52	1054.32
25	1051.50	1049.73	1052.92
26	1051.85	1053.53	1055.17
27	1051.01	1052.90	1054.76
28	1053.21	1053.42	1054.56
29	1052.52	1052.55	1052.48
30	1046.91	1054.71	1055.58
31	1046.65	N/A	1054.72

baseline/operations/gas_quality/p01_2_weeks.shtml

AQ-21

AQ-21 Startup is defined as the period beginning with the turbine light-off until the unit meets the lb/hr and ppmv emission limits in Conditions of Certification AQ-52, -54 and -55. Shutdown is defined as the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Startup and shutdown durations shall not exceed 3.0 hours and one hour, respectively, per occurrence.

Verification: The Project owner shall identify and submit to the CPM as part of the Quarterly Air Quality Report all startups and shutdowns for all units including the maximum hourly emission rate, total emissions and duration.

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
10/01/24 16:02	415591.7		0.5		1.4		0.46		2.29		0	
10/01/24 16:03	415372.2		0.5		1.4		0.46		2.29		0	
10/01/24 16:04	415100.7		0.5		1.4		0.46		2.29		0	
10/01/24 16:05	414413.3		0.5		1.4		0.46		2.29		0	
10/01/24 16:06	415042.9		0.5		1.4		0.46		2.29		0	
10/01/24 16:07	419646.6		0.5		1.4		0.47		2.31		1	
10/01/24 16:08	416590.9		0.5		1.57		0.46		2.56		0	
10/01/24 16:09	414563.5		0.5		1.5		0.46		2.44		0	
10/01/24 16:10	414921.6		0.5		1.4		0.46		2.29		0	
10/01/24 16:11	415100.7		0.5		1.31		0.46		2.14		0	
10/01/24 16:12	415175.8		0.5		1.31		0.46		2.14		0	

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/02/24 11:31	394895.5			0.5			1.33			0.45			2.07			0		
10/02/24 11:32	411363.5			0.4			1.16			0.38			1.87			0		
10/02/24 11:33	415776.5			0.3			1.05			0.28			1.71			0		
10/02/24 11:34	417232.1			0.3			1.22			0.28			1.99			0		
10/02/24 11:35	417445.8			0.4			1.5			0.37			2.46			0		
10/02/24 11:36	424111.5			0.4			1.5			0.38			2.5			1		
10/02/24 11:37	418809			0.4			1.84			0.37			3.03			0		
10/02/24 11:38	417804			0.5			1.5			0.47			2.46			0		
10/02/24 11:39	418993.8			0.5			1.4			0.47			2.31			0		
10/02/24 11:40	419230.7			0.4			1.31			0.37			2.16			0		
10/02/24 11:41	418710.8			0.4			1.31			0.37			2.16			0		

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
10/29/24 9:48	338311.9		0.9		1.43		0.72		1.9		0	
10/29/24 9:49	338542.9		0.9		1.43		0.72		1.9		0	
10/29/24 9:50	338311.9		0.9		1.43		0.72		1.9		0	
10/29/24 9:51	338352.3		0.9		1.52		0.72		2.02		0	
10/29/24 9:52	338467.9		0.9		1.52		0.72		2.02		0	
10/29/24 9:53	335550.9		0.9		1.52		0.72		2		1	
10/29/24 9:54	318499.6		0.9		1.52		0.68		1.9		1	
10/29/24 9:55	294124		0.9		1.59		0.62		1.83		1	
10/29/24 9:56	271712.3		0.9		1.88		0.58		2.01		1	
10/29/24 9:57	248832.8		0.8		3.04		0.49		2.98		1	
10/29/24 9:58	225635.6		0.8		5.61		0.42		4.97		1	
10/29/24 9:59	203853.6		0.5		13.28		0.26		10.63		1	
10/29/24 10:00	178686.7		4.3		16.31		1.83		11.45		1	
10/29/24 10:01	157903.9		128.2		18.88		48.31		11.71		1	
10/29/24 10:02	139385.4		874.7		20.21		290.95		11.06		1	
10/29/24 10:03	62440.7		1758.4		20.73		262.14		5.09		1	
10/29/24 10:04	0		0		22.05		2.56		0.03		0	
10/29/24 10:05	0		0		0.2		0		0		0	
10/29/24 10:06	0		0		0.1		0		0		0	
10/29/24 10:07	0		0		0.1		0		0		0	
10/29/24 10:08	0		0		0		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
11/06/24 9:57	0		0		0		0		0		0	
11/06/24 9:58	0		0		0		0		0		0	
11/06/24 9:59	0		0		0		0		0		0	
11/06/24 10:00	0		0		0		0		0		0	
11/06/24 10:01	0		0		0		0		0		0	
11/06/24 10:02	0		0		0		0		0		1	
11/06/24 10:03	0		-0.1		0		0		0		1	
11/06/24 10:04	9819.5		1958.8		35.4		45.16		1.34		1	
11/06/24 10:05	34351.1		1230.6		14.26		99.72		1.9		1	
11/06/24 10:06	50356.9		779.1		17.7		92.61		3.46		1	
11/06/24 10:07	70879.7		415.4		22.42		69.45		6.17		1	
11/06/24 10:08	116760.1		263.9		27.62		72.66		12.52		1	
11/06/24 10:09	138299.5		175.1		40.59		57.11		21.79		1	
11/06/24 10:10	139425.9		390.7		51.2		128.48		27.71		1	
11/06/24 10:11	144301		1923.4		37.61		654.86		21.08		1	
11/06/24 10:12	148575.4		1865.1		37.55		653.8		21.66		1	
11/06/24 10:13	164893.1		1810.1		38		704.2		24.33		1	
11/06/24 10:14	187114.1		1709.7		49.17		754.7		35.72		1	
11/06/24 10:15	211264.4		472.3		64.47		235.33		52.87		1	
11/06/24 10:16	231966.3		27		69.67		14.77		62.73		1	
11/06/24 10:17	256474.8		3.6		84.19		2.2		83.83		1	
11/06/24 10:18	283414.9		2.4		87.38		1.63		96.12		1	
11/06/24 10:19	303406.4		2.3		41.48		1.65		48.86		1	
11/06/24 10:20	322265.7		2.3		19.44		1.71		24.32		1	
11/06/24 10:21	338716.3		2.2		12.91		1.78		16.98		1	
11/06/24 10:22	346375.5		2.1		10.67		1.7		14.35		1	
11/06/24 10:23	348686		1.8		9.02		1.5		12.21		1	
11/06/24 10:24	351845.5		1.7		8.33		1.44		11.38		1	
11/06/24 10:25	355155.3		1.6		7.13		1.33		9.84		1	
11/06/24 10:26	354185		1.4		6.69		1.18		9.2		1	
11/06/24 10:27	353740.1		1.2		6.08		1.03		8.34		1	
11/06/24 10:28	353647.8		1.1		5.81		0.96		7.98		1	

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/06/24 10:29	356911.3			1.1			5.63			0.9			7.8			1		
11/06/24 10:30	358829			1			5.18			0.83			7.22			1		
11/06/24 10:31	359481.7			1			5.27			0.83			7.36			1		
11/06/24 10:32	359320			0.9			5.27			0.76			7.36			1		
11/06/24 10:33	359429.7			0.9			5.1			0.76			7.11			1		
11/06/24 10:34	364010.2			0.8			5.26			0.7			7.44			1		
11/06/24 10:35	365650.7			0.8			5.17			0.7			7.34			1		
11/06/24 10:36	365431.2			0.8			4.36			0.7			6.18			1		
11/06/24 10:37	365061.5			0.8			4.27			0.7			6.05			1		
11/06/24 10:38	366251.4			0.8			4.08			0.71			5.81			1		
11/06/24 10:39	368232.6			0.7			3.99			0.63			5.71			1		
11/06/24 10:40	367464.4			0.7			4.18			0.63			5.96			1		
11/06/24 10:41	366003			0.7			4.08			0.63			5.8			1		
11/06/24 10:42	367574.1			0.7			4.08			0.63			5.83			1		
11/06/24 10:43	369913.5			0.7			4.08			0.63			5.87			1		
11/06/24 10:44	362416			0.7			4.36			0.62			6.13			1		
11/06/24 10:45	358390			0.7			4.54			0.61			6.31			1		
11/06/24 10:46	353688.2			0.7			4.99			0.61			6.85			1		
11/06/24 10:47	348870.8			0.7			3.22			0.59			4.36			1		
11/06/24 10:48	344787			0.7			2.23			0.58			2.99			1		
11/06/24 10:49	340957.4			0.7			2.15			0.58			2.84			1		
11/06/24 10:50	341165.4			0.7			2.59			0.58			3.43			1		
11/06/24 10:51	340940.1			0.7			2.68			0.58			3.55			1		
11/06/24 10:52	339952.3			0.7			2.86			0.57			3.77			1		
11/06/24 10:53	339796.4			0.7			3.04			0.57			4.01			1		
11/06/24 10:54	340576.2			0.7			3.04			0.57			4.02			1		
11/06/24 10:55	340749.5			0.7			2.77			0.57			3.67			1		
11/06/24 10:56	340784.1			0.7			2.41			0.57			3.19			1		
11/06/24 10:57	339409.3			0.7			2.32			0.57			3.06			1		
11/06/24 10:58	339519.1			0.7			2.15			0.57			2.83			1		
11/06/24 10:59	340021.7			0.7			2.06			0.57			2.71			1		
11/06/24 11:00	340483.8			0.7			2.06			0.57			2.72			1		
11/06/24 11:01	340391.3			0.8			1.97			0.65			2.6			1		
11/06/24 11:02	339305.4			0.7			1.88			0.57			2.47			1		
11/06/24 11:03	339432.5			0.7			1.88			0.57			2.47			1		

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/06/24 11:04	340073.7			0.8			1.88			0.65			2.48			1		
11/06/24 11:05	340697.5			0.8			1.79			0.65			2.36			1		
11/06/24 11:06	340194.9			0.7			1.7			0.57			2.24			1		
11/06/24 11:07	339519.1			0.7			1.7			0.57			2.24			1		
11/06/24 11:08	339062.8			0.7			1.61			0.57			2.12			1		
11/06/24 11:09	339767.5			0.7			1.61			0.57			2.12			1		
11/06/24 11:10	340501.1			0.7			1.61			0.57			2.13			1		
11/06/24 11:11	340085.2			0.7			1.61			0.57			2.12			0		
11/06/24 11:12	339357.4			0.7			1.61			0.57			2.12			0		
11/06/24 11:13	339784.8			0.7			1.52			0.57			2			0		
11/06/24 11:14	344688.8			0.7			1.52			0.58			2.03			0		
11/06/24 11:15	349361.8			0.7			1.54			0.6			2.09			0		

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
11/15/24 15:16	438794.7		1.2		1.5		1.33		2.67		0	
11/15/24 15:17	439170.1		1.2		1.5		1.34		2.67		0	
11/15/24 15:18	439458.9		1.2		1.41		1.34		2.51		0	
11/15/24 15:19	440775.9		1.2		1.41		1.34		2.52		0	
11/15/24 15:20	440631.5		1.2		1.41		1.34		2.52		0	
11/15/24 15:21	440695		1.2		1.41		1.34		2.52		1	
11/15/24 15:22	398783		1.2		1.32		1.2		2.12		1	
11/15/24 15:23	150550.8		1.3		2.43		0.48		1.47		1	
11/15/24 15:24	51489		0		3.88		1.66		0.85		0	
11/15/24 15:25	48445		0		0.1		0		0		0	
11/15/24 15:26	46845		0		0		0		0		0	
11/15/24 15:27	47087.6		0		0		0		0		0	
11/15/24 15:28	46764.1		0		0		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
11/20/24 16:39	86908.7		0		0		0		0		0	
11/20/24 16:40	86972.2		0		0		0		0		0	
11/20/24 16:41	86885.6		0		0		0		0		0	
11/20/24 16:42	86879.8		0		0		0		0		0	
11/20/24 16:43	86458.1		0		0		0		0		0	
11/20/24 16:44	83483.4		0.1		0		0		0		1	
11/20/24 16:45	73577.2		0.1		0		0		0		1	
11/20/24 16:46	60523		48.5		0.5		0		0		1	
11/20/24 16:47	75287		1666.5		13.95		295.82		4.07		1	
11/20/24 16:48	84193.9		980.5		18.07		194.68		5.9		1	
11/20/24 16:49	97398.3		523.2		23.6		120.17		8.92		1	
11/20/24 16:50	132731.3		358.5		28.94		112.27		14.91		1	
11/20/24 16:51	154888.8		234.8		38.6		85.77		23.2		1	
11/20/24 16:52	163356.7		418.5		49.36		161.23		31.3		1	
11/20/24 16:53	179755.3		1928.9		36.14		817.8		25.21		1	
11/20/24 16:54	201144.5		1762.9		43.49		836.6		33.97		1	
11/20/24 16:55	222759.1		690.4		50.8		362.74		43.92		1	
11/20/24 16:56	242184.4		38.9		51.05		22.2		47.99		1	
11/20/24 16:57	264295.7		3.6		62.18		2.26		63.79		1	
11/20/24 16:58	291195.4		2.1		78.67		1.42		88.94		1	
11/20/24 16:59	312555.8		1.9		47.11		1.38		57.16		1	
11/20/24 17:00	330698.9		1.9		26.85		1.47		34.47		1	
11/20/24 17:01	346127.1		2.1		18.13		1.68		24.36		1	
11/20/24 17:02	352440.5		2		13.51		1.64		18.48		1	
11/20/24 17:03	354086.7		1.8		11.28		1.52		15.5		1	
11/20/24 17:04	354543		1.7		9.37		1.45		12.9		1	
11/20/24 17:05	354392.8		1.6		7.98		1.38		10.98		1	
11/20/24 17:06	354427.5		1.6		6.77		1.31		9.31		1	
11/20/24 17:07	354398.6		1.5		6.07		1.23		8.36		1	
11/20/24 17:08	353757.5		1.3		5.47		1.09		7.51		1	
11/20/24 17:09	352856.4		1.2		5.21		1.01		7.13		1	
11/20/24 17:10	352492.5		1.1		5.11		0.95		6.99		1	

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/24 17:11	352342.3			1.1			4.84			0.88			6.62			1		
11/20/24 17:12	351972.6			1.1			4.67			0.88			6.38			1		
11/20/24 17:13	351556.8			1.1			4.58			0.88			6.25			1		
11/20/24 17:14	351285.3			1.1			4.49			0.88			6.13			1		
11/20/24 17:15	350956			1.1			4.4			0.87			6			1		
11/20/24 17:16	350753.8			1.1			4.4			0.87			6			1		
11/20/24 17:17	350210.9			1.1			4.31			0.87			5.87			1		
11/20/24 17:18	350725			1.1			4.31			0.88			5.88			1		
11/20/24 17:19	350418.8			1			4.31			0.8			5.87			1		
11/20/24 17:20	350234			1			4.4			0.8			5.99			1		
11/20/24 17:21	350124.3			0.9			4.47			0.74			6.07			1		
11/20/24 17:22	349754.6			0.9			4.56			0.74			6.2			1		
11/20/24 17:23	349748.8			0.9			4.65			0.74			6.32			1		
11/20/24 17:24	349639			0.9			4.65			0.74			6.31			1		
11/20/24 17:25	349650.6			0.8			4.83			0.66			6.55			1		
11/20/24 17:26	349552.4			0.8			4.92			0.66			6.67			1		
11/20/24 17:27	349217.4			0.8			4.92			0.66			6.67			1		
11/20/24 17:28	348859.3			0.8			4.93			0.65			6.69			1		
11/20/24 17:29	348951.6			0.8			4.56			0.66			6.18			1		
11/20/24 17:30	348905.5			0.8			3.58			0.66			4.84			1		
11/20/24 17:31	346924.2			0.8			3.13			0.66			4.21			1		
11/20/24 17:32	348553.1			0.8			2.59			0.66			3.51			1		
11/20/24 17:33	348576.2			0.8			2.59			0.66			3.51			1		
11/20/24 17:34	348720.7			0.8			2.59			0.66			3.51			1		
11/20/24 17:35	348697.5			0.8			2.59			0.66			3.51			1		
11/20/24 17:36	348691.8			0.8			2.68			0.66			3.63			1		
11/20/24 17:37	348772.6			0.8			2.68			0.66			3.63			1		
11/20/24 17:38	348957.5			0.8			2.77			0.66			3.75			1		
11/20/24 17:39	348893.9			0.8			2.77			0.66			3.76			1		
11/20/24 17:40	348824.6			0.8			2.77			0.66			3.75			1		
11/20/24 17:41	348553.1			0.8			2.68			0.66			3.63			1		
11/20/24 17:42	348853.5			0.8			2.41			0.66			3.27			1		
11/20/24 17:43	348512.7			0.8			2.23			0.66			3.02			1		
11/20/24 17:44	348322.1			0.8			2.06			0.66			2.78			1		
11/20/24 17:45	348154.5			0.8			1.88			0.66			2.54			1		

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/24 17:46	348189.2			0.8			1.88			0.66			2.54			1		
11/20/24 17:47	348183.5			0.8			1.88			0.66			2.54			1		
11/20/24 17:48	348385.6			0.8			1.88			0.66			2.54			1		
11/20/24 17:49	348247			0.8			1.97			0.66			2.66			1		
11/20/24 17:50	348143			0.8			1.97			0.66			2.66			1		
11/20/24 17:51	348091			0.8			1.97			0.66			2.66			1		
11/20/24 17:52	348096.8			0.8			1.88			0.66			2.54			1		
11/20/24 17:53	348102.5			0.8			1.79			0.66			2.42			1		
11/20/24 17:54	347328.6			0.8			1.7			0.66			2.29			1		
11/20/24 17:55	346323.5			0.8			1.61			0.66			2.16			0		
11/20/24 17:56	347484.5			0.8			1.61			0.66			2.17			0		
11/20/24 17:57	347940.8			0.8			1.43			0.66			1.93			0		
11/20/24 17:58	348021.7			0.8			1.25			0.66			1.69			0		
11/20/24 17:59	347842.6			0.8			1.16			0.66			1.57			0		

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/24 18:15	347022.4			3	X		2.98	X		2.44	X		4.01	X		0		
11/20/24 18:16	346814.5			4.2	X		3.99	X		3.46	X		5.37	X		0		
11/20/24 18:17	346508.3			6.2	X		4.44	X		5.06	X		5.97	X		0		
11/20/24 18:18	346404.4			3.3	X		2.11	X		2.73	X		2.84	X		0		
11/20/24 18:19	346941.6			1.4	X		1.76	X		1.15	X		2.37	X		0		
11/20/24 18:20	342996.4			1.3	X		1.67	X		1.07	X		2.23	X		1		
11/20/24 18:21	325419.5			1.2			1.59			0.95			2			1		
11/20/24 18:22	302332			1.1			1.67			0.82			1.96			1		
11/20/24 18:23	280451.8			1.1			1.97			0.71			2.14			1		
11/20/24 18:24	259062.5			0.9			3.78			0.56			3.8			1		
11/20/24 18:25	237124.5			0.8			5.61			0.43			5.17			1		
11/20/24 18:26	215509.9			0.6			13.38			0.32			11.19			1		
11/20/24 18:27	192636.2			6			16.66			2.73			12.46			1		
11/20/24 18:28	173661.4			144.1			19.4			59.15			13.11			1		
11/20/24 18:29	157505.4			988.8			22.84			368.3			14			1		
11/20/24 18:30	110365.8			1757			23.6			457.41			10.11			1		
11/20/24 18:31	75778			0			26.71			511.34			7.9			0		
11/20/24 18:32	75333.2			0			0.3			0			0			0		
11/20/24 18:33	75419.8			0			0.3			0			0			0		
11/20/24 18:34	75662.4			0			0.2			0			0			0		
11/20/24 18:35	75951.2			0			0.2			0			0			0		

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/21/24 23:39	74432.1			0			0			0			0			0		
11/21/24 23:40	74819.1			0			0			0			0			0		
11/21/24 23:41	75027			0			0			0			0			0		
11/21/24 23:42	75356.3			0			0			0			0			0		
11/21/24 23:43	75223.4			0			0			0			0			0		
11/21/24 23:44	70365.6			0			0			0			0			1		
11/21/24 23:45	56704.9			2.6			0.1			0			0			1		
11/21/24 23:46	62897			1508.7			18.54			223.91			4.53			1		
11/21/24 23:47	76800.3			1174.1			13.77			212.62			4.1			1		
11/21/24 23:48	85580.1			633.3			19.67			127.86			6.54			1		
11/21/24 23:49	108465.4			383.2			25.67			98.05			10.81			1		
11/21/24 23:50	151041.8			218.6			36.47			77.89			21.39			1		
11/21/24 23:51	104936.2			47.9			63.37			11.85			25.82			1		
11/21/24 23:52	70781.5			0			65.74			99.65			18.07			0		
11/21/24 23:53	70279			0			2.4			0			0			0		
11/21/24 23:54	70215.5			0			2.7			0			0			0		
11/21/24 23:55	70469.6			0			3.5			0			0			0		
11/21/24 23:56	70585.1			0			4			0			0			0		

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
11/21/24 23:39	74432.1		0		0		0		0		0	
11/21/24 23:40	74819.1		0		0		0		0		0	
11/21/24 23:41	75027		0		0		0		0		0	
11/21/24 23:42	75356.3		0		0		0		0		0	
11/21/24 23:43	75223.4		0		0		0		0		0	
11/21/24 23:44	70365.6		0		0		0		0		1	
11/21/24 23:45	56704.9		2.6		0.1		0		0		1	
11/21/24 23:46	62897		1508.7		18.54		223.91		4.53		1	
11/21/24 23:47	76800.3		1174.1		13.77		212.62		4.1		1	
11/21/24 23:48	85580.1		633.3		19.67		127.86		6.54		1	
11/21/24 23:49	108465.4		383.2		25.67		98.05		10.81		1	
11/21/24 23:50	151041.8		218.6		36.47		77.89		21.39		1	
11/21/24 23:51	104936.2		47.9		63.37		11.85		25.82		1	
11/21/24 23:52	70781.5		0		65.74		99.65		18.07		0	
11/21/24 23:53	70279		0		2.4		0		0		0	
11/21/24 23:54	70215.5		0		2.7		0		0		0	
11/21/24 23:55	70469.6		0		3.5		0		0		0	
11/21/24 23:56	70585.1		0		4		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
11/22/24 0:01	72081.2		0		1		0		0		0	
11/22/24 0:02	72450.8		0		1.1		0		0		0	
11/22/24 0:03	72791.6		0		1.4		0		0		0	
11/22/24 0:04	73005.4		0		1.6		0		0		0	
11/22/24 0:05	73028.5		0		1.7		0		0		0	
11/22/24 0:06	73317.3		0.3		1.8		0		0		1	
11/22/24 0:07	64837.8		0.3		1.7		0		0		1	
11/22/24 0:08	52921.5		16.5		4		0		0		1	
11/22/24 0:09	69857.3		1093.5		37.86		180.15		10.26		1	
11/22/24 0:10	77909.4		892.7		32.82		164.07		9.93		1	
11/22/24 0:11	89144.1		493.1		33.85		103.65		11.71		1	
11/22/24 0:12	120376		336.9		39.83		95.7		18.62		1	
11/22/24 0:13	150712.5		215.2		51.3		76.5		30.01		1	
11/22/24 0:14	156044		197.8		68.16		72.77		41.28		1	
11/22/24 0:15	173753.8		1883.8		59		772.1		39.8		1	
11/22/24 0:16	194444.1		1764.6		60.35		809.36		45.55		1	
11/22/24 0:17	215879.6		731.3		59.44		372.42		49.82		1	
11/22/24 0:18	235692		45.9		57.85		25.53		52.93		1	
11/22/24 0:19	258011.2		4.2		66.29		2.53		66.4		1	
11/22/24 0:20	283975.2		2		79.65		1.34		87.79		1	
11/22/24 0:21	307022.3		1.9		42.44		1.38		50.58		1	
11/22/24 0:22	325922		1.8		19.96		1.4		25.25		1	
11/22/24 0:23	342921.3		2		11.63		1.61		15.48		1	
11/22/24 0:24	359464.4		2		9.98		1.69		13.92		1	
11/22/24 0:25	378121.4		1.9		8.31		1.67		12.2		1	
11/22/24 0:26	398771.4		1.6		6.99		1.54		10.82		1	
11/22/24 0:27	420709.4		1.4		5.53		1.37		9.03		1	
11/22/24 0:28	442329.7		1.1		5.24		1.17		9.01		1	
11/22/24 0:29	448816.3		1		5.71		1.09		9.95		1	
11/22/24 0:30	445697.2		0.9		6.18		0.97		10.69		1	
11/22/24 0:31	444622.8		0.9		5.62		0.97		9.71		1	
11/22/24 0:32	443773.8		0.9		5.44		0.96		9.37		1	

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/22/24 0:33	443848.8			0.9			5.44			0.97			9.37			1		
11/22/24 0:34	444022.1			0.8			5.43			0.88			9.36			1		
11/22/24 0:35	444154.9			0.8			5.25			0.87			9.06			1		
11/22/24 0:36	444224.3			0.8			5.16			0.87			8.9			1		
11/22/24 0:37	444131.9			0.7			5.24			0.78			9.04			1		
11/22/24 0:38	444253.1			0.7			5.15			0.79			8.88			1		
11/22/24 0:39	444605.5			0.7			5.24			0.79			9.05			1		
11/22/24 0:40	444807.7			0.7			5.34			0.79			9.22			1		
11/22/24 0:41	444738.3			0.7			5.25			0.77			9.07			1		
11/22/24 0:42	444622.8			0.7			5.43			0.79			9.37			1		
11/22/24 0:43	444530.4			0.7			5.25			0.77			9.07			1		
11/22/24 0:44	444721			0.7			4.03			0.79			6.95			1		
11/22/24 0:45	445009.8			0.7			3.09			0.79			5.34			1		
11/22/24 0:46	445136.9			0.7			3			0.79			5.18			1		
11/22/24 0:47	445408.4			0.7			3.23			0.77			5.58			1		
11/22/24 0:48	445668.4			0.7			3.84			0.79			6.64			1		
11/22/24 0:49	445697.3			0.7			3.87			0.78			6.7			1		
11/22/24 0:50	445362.2			0.7			2.95			0.77			5.1			1		
11/22/24 0:51	445217.8			0.7			2.58			0.77			4.46			1		
11/22/24 0:52	445015.6			0.7			2.49			0.77			4.3			1		
11/22/24 0:53	444940.5			0.7			2.4			0.77			4.14			1		
11/22/24 0:54	444877			0.7			2.34			0.79			4.04			1		
11/22/24 0:55	444749.9			0.7			2.21			0.77			3.82			1		
11/22/24 0:56	444882.8			0.7			1.94			0.77			3.34			1		
11/22/24 0:57	445541.3			0.7			1.87			0.79			3.24			1		
11/22/24 0:58	445754.9			0.7			1.66			0.78			2.87			1		
11/22/24 0:59	445968.7			0.7			1.57			0.78			2.71			1		
11/22/24 1:00	446142			0.7			1.48			0.78			2.55			1		
11/22/24 1:01	446009.1			0.7			1.48			0.78			2.55			1		
11/22/24 1:02	445899.4			0.8			1.57			0.87			2.71			1		
11/22/24 1:03	445708.8			0.7			1.57			0.78			2.71			1		
11/22/24 1:04	445864.8			0.7			1.59			0.79			2.76			1		
11/22/24 1:05	446165.1			0.7			1.57			0.78			2.71			1		
11/22/24 1:06	445859			0.7			1.48			0.78			2.55			1		
11/22/24 1:07	445489.3			0.7			1.48			0.77			2.55			0		

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/22/24 1:08	445437.3			0.7			1.48			0.77			2.55			0		
11/22/24 1:09	445235.1			0.7			1.38			0.77			2.39			0		
11/22/24 1:10	445495.1			0.7			1.29			0.78			2.23			0		
11/22/24 1:11	445275.5			0.7			1.29			0.77			2.23			0		

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
12/30/24 16:52	450630.1		0.6		1.48		0.68		2.57		0	
12/30/24 16:53	450358.6		0.6		1.38		0.68		2.41		0	
12/30/24 16:54	450347		0.6		1.38		0.68		2.41		0	
12/30/24 16:55	450462.6		0.6		1.38		0.68		2.41		0	
12/30/24 16:56	450266.2		0.6		1.38		0.68		2.41		0	
12/30/24 16:57	450572.3		0.6		1.38		0.68		2.41		1	
12/30/24 16:58	450087.1		0.7		1.38		0.78		2.41		1	
12/30/24 16:59	442913.1		0.6		1.38		0.67		2.37		1	
12/30/24 17:00	424539		0.6		1.38		0.64		2.27		1	
12/30/24 17:01	402554.8		0.6		2		0.6		3.11		1	
12/30/24 17:02	379652.2		0.7		2.41		0.64		3.54		1	
12/30/24 17:03	358563.3		0.8		2.55		0.67		3.54		1	
12/30/24 17:04	336503.9		0.8		3.26		0.63		4.24		1	
12/30/24 17:05	312295.9		0.8		3.35		0.58		4.04		1	
12/30/24 17:06	289959.4		0.8		3.08		0.54		3.46		1	
12/30/24 17:07	268633.6		0.7		3.18		0.46		3.3		1	
12/30/24 17:08	245448		0.7		4.57		0.38		4.34		1	
12/30/24 17:09	226346.1		0.4		10.99		0.22		9.62		1	
12/30/24 17:10	203691.9		0.7		16.7		0.32		13.16		1	
12/30/24 17:11	183504		55.1		19.08		23.77		13.55		1	
12/30/24 17:12	167896.8		533.3		21.01		210.46		13.65		1	
12/30/24 17:13	145941.4		1592.5		21.14		546.12		11.93		1	
12/30/24 17:14	84269		0		21.89		390.16		7.14		0	
12/30/24 17:15	83899.3		0		33.43		1153.06		10.85		0	
12/30/24 17:16	83789.5		0		0.2		0		0		0	
12/30/24 17:17	83310.1		0		0.2		0		0		0	
12/30/24 17:18	82524.5		0		0.1		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
10/17/24 10:02	369942.4		0.9		1.45		0.8		2.11		0	
10/17/24 10:03	369913.5		0.9		1.45		0.8		2.11		0	
10/17/24 10:04	367614.5		0.9		1.54		0.8		2.23		0	
10/17/24 10:05	369601.5		0.9		1.54		0.8		2.24		0	
10/17/24 10:06	370381.3		0.9		1.54		0.8		2.24		0	
10/17/24 10:07	368284.6		1		1.63		0.88		2.36		1	
10/17/24 10:08	358996.5		0.9		1.63		0.78		2.3		1	
10/17/24 10:09	338150.2		0.9		1.63		0.73		2.17		1	
10/17/24 10:10	314733.5		1		2.15		0.74		2.65		1	
10/17/24 10:11	290392.6		1		2.54		0.69		2.9		1	
10/17/24 10:12	266063.2		0.9		3.47		0.59		3.62		1	
10/17/24 10:13	240399.6		0.8		6.87		0.44		6.48		1	
10/17/24 10:14	218195.9		0.6		21.24		0.34		18.2		1	
10/17/24 10:15	191631.1		9.6		29.74		4.37		22.38		1	
10/17/24 10:16	170178.3		187.4		33.56		76.08		22.43		1	
10/17/24 10:17	150441.1		793		38.88		284.73		22.97		1	
10/17/24 10:18	102498.6		1423.1		40.29		348.18		16.22		1	
10/17/24 10:19	0		0		44.25		0		0		0	
10/17/24 10:20	0		0		29.5		0		0		0	
10/17/24 10:21	0		0		0.3		0		0		0	
10/17/24 10:22	0		0		0.2		0		0		0	
10/17/24 10:23	0		0		0.1		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 7:46	0			0			0			0			0			0		
10/28/24 7:47	0			0			0			0			0			0		
10/28/24 7:48	0			0			0			0			0			0		
10/28/24 7:49	0			0			0			0			0			0		
10/28/24 7:50	2102.5			0			0			0.07			0			0		
10/28/24 7:51	8340.8			29.5			0			0.59			0			1		
10/28/24 7:52	24727.9			32.5			0			1.92			0			1		
10/28/24 7:53	39532.3			1083.4			14.75			102.1			2.29			1		
10/28/24 7:54	51899.1			1009.6			13.19			124.97			2.69			1		
10/28/24 7:55	64214			677			17.41			103.66			4.39			1		
10/28/24 7:56	83552.7			470.7			20.65			93.87			6.78			1		
10/28/24 7:57	131437.4			385.3			25.4			120.83			13.11			1		
10/28/24 7:58	153941.5			273.8			35.18			100.58			21.27			1		
10/28/24 7:59	160058.4			467.2			40.23			178.4			25.28			1		
10/28/24 8:00	177693.2			1768			35.58			749.58			24.82			1		
10/28/24 8:01	199042			1432.6			37.53			680.47			29.34			1		
10/28/24 8:02	223302			586.5			45.9			312.48			40.25			1		
10/28/24 8:03	246684.1			110			51.3			64.79			49.71			1		
10/28/24 8:04	270880.6			8.4			54.12			5.43			57.56			1		
10/28/24 8:05	298831.6			2.6			52.38			1.84			61.45			1		
10/28/24 8:06	325096			2.2			27.35			1.74			34.91			1		
10/28/24 8:07	346606.5			2.3			19.35			1.87			26.34			1		
10/28/24 8:08	364576.3			2.3			15.22			2.01			21.79			1		
10/28/24 8:09	383793.7			2.3			14.02			2.11			21.13			1		
10/28/24 8:10	389708.5			2.2			9.8			2.02			15			1		
10/28/24 8:11	323322.7			2			10.39			1.56			13.19			1		
10/28/24 8:12	313930.6			1.8			11.71			1.34			14.44			1		
10/28/24 8:13	331640.4			1.8			12.33			1.39			16.06			1		
10/28/24 8:14	350493.9			1.6			10.39			1.33			14.3			1		
10/28/24 8:15	368972			1.5			10.04			1.32			14.55			1		
10/28/24 8:16	375008.1			1.5			8.63			1.34			12.71			1		
10/28/24 8:17	376319.3			1.5			7.93			1.34			11.71			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 8:18	389587.3			1.4			7.49			1.31			11.45			1		
10/28/24 8:19	412258.8			1.5			6.35			1.43			10.29			1		
10/28/24 8:20	434081.3			1.4			6.26			1.41			10.68			1		
10/28/24 8:21	443271.2			1.4			6.36			1.46			11.07			1		
10/28/24 8:22	383106.3			1.4			6.99			1.24			10.52			1		
10/28/24 8:23	352342.3			1.3			9.54			1.09			13.21			1		
10/28/24 8:24	362589.3			1.3			9.2			1.13			13.1			1		
10/28/24 8:25	360989.3			1.3			8.28			1.14			11.73			1		
10/28/24 8:26	313399.2			1.3			8.4			1			10.34			1		
10/28/24 8:27	319054			1.3			9.33			1.01			11.7			1		
10/28/24 8:28	339484.5			1.3			10.01			1.01			13.35			1		
10/28/24 8:29	354502.6			1.3			9.65			1.06			13.44			1		
10/28/24 8:30	345058.5			1.2			8.98			1.02			12.17			1		
10/28/24 8:31	335862.8			1.2			9.86			0.99			13.01			1		
10/28/24 8:32	332229.6			1.3			9.69			1.05			12.64			1		
10/28/24 8:33	333621.6			1.2			9.25			0.98			12.11			1		
10/28/24 8:34	332524.1			1.2			8.58			0.92			11.21			1		
10/28/24 8:35	333217.3			1.1			3.75			0.85			4.91			1		
10/28/24 8:36	330970.4			1.2			2.41			0.92			3.14			1		
10/28/24 8:37	331097.4			1.2			2.41			0.92			3.14			1		
10/28/24 8:38	332737.9			1.2			2.63			0.94			3.44			1		
10/28/24 8:39	333269.3			1.2			2.86			0.92			3.74			1		
10/28/24 8:40	332980.5			1.2			3.04			0.92			3.97			1		
10/28/24 8:41	332027.4			1.1			3.22			0.85			4.2			1		
10/28/24 8:42	333454.2			1.1			3.4			0.85			4.45			1		
10/28/24 8:43	332899.6			1.1			3.49			0.85			4.56			1		
10/28/24 8:44	332004.3			1.2			3.72			0.93			4.85			1		
10/28/24 8:45	331871.5			1.2			3.13			0.92			4.08			1		
10/28/24 8:46	333286.6			1.2			2.5			0.92			3.28			1		
10/28/24 8:47	332350.9			1.1			1.79			0.85			2.33			1		
10/28/24 8:48	331039.7			1.1			1.67			0.83			2.18			1		
10/28/24 8:49	331033.9			1.2			1.61			0.92			2.09			1		
10/28/24 8:50	331380.5			1.2			1.61			0.92			2.09			1		
10/28/24 8:51	333442.5			1.2			1.52			0.92			1.99			1		
10/28/24 8:52	331900.3			1.1			1.41			0.91			1.84			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 8:53	332258.5			1.1			1.45			0.86			1.9			1		
10/28/24 8:54	331802.2			1.1			1.34			0.85			1.75			1		
10/28/24 8:55	333373.3			1.1			1.34			0.85			1.76			1		
10/28/24 8:56	331998.5			1.1			1.34			0.85			1.75			1		
10/28/24 8:57	332547.3			1.1			1.25			0.85			1.63			1		
10/28/24 8:58	332194.9			1.1			1.25			0.85			1.63			0		
10/28/24 8:59	331403.6			1.1			1.16			0.85			1.51			0		
10/28/24 9:00	332166.1			1.1			1.16			0.85			1.52			0		
10/28/24 9:01	332033.2			1.2			1.16			0.92			1.52			0		
10/28/24 9:02	332633.9			1.2			1.07			0.92			1.4			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 7:46	0			0			0			0			0			0		
10/28/24 7:47	0			0			0			0			0			0		
10/28/24 7:48	0			0			0			0			0			0		
10/28/24 7:49	0			0			0			0			0			0		
10/28/24 7:50	2102.5			0			0			0.07			0			0		
10/28/24 7:51	8340.8			29.5			0			0.59			0			1		
10/28/24 7:52	24727.9			32.5			0			1.92			0			1		
10/28/24 7:53	39532.3			1083.4			14.75			102.1			2.29			1		
10/28/24 7:54	51899.1			1009.6			13.19			124.97			2.69			1		
10/28/24 7:55	64214			677			17.41			103.66			4.39			1		
10/28/24 7:56	83552.7			470.7			20.65			93.87			6.78			1		
10/28/24 7:57	131437.4			385.3			25.4			120.83			13.11			1		
10/28/24 7:58	153941.5			273.8			35.18			100.58			21.27			1		
10/28/24 7:59	160058.4			467.2			40.23			178.4			25.28			1		
10/28/24 8:00	177693.2			1768			35.58			749.58			24.82			1		
10/28/24 8:01	199042			1432.6			37.53			680.47			29.34			1		
10/28/24 8:02	223302			586.5			45.9			312.48			40.25			1		
10/28/24 8:03	246684.1			110			51.3			64.79			49.71			1		
10/28/24 8:04	270880.6			8.4			54.12			5.43			57.56			1		
10/28/24 8:05	298831.6			2.6			52.38			1.84			61.45			1		
10/28/24 8:06	325096			2.2			27.35			1.74			34.91			1		
10/28/24 8:07	346606.5			2.3			19.35			1.87			26.34			1		
10/28/24 8:08	364576.3			2.3			15.22			2.01			21.79			1		
10/28/24 8:09	383793.7			2.3			14.02			2.11			21.13			1		
10/28/24 8:10	389708.5			2.2			9.8			2.02			15			1		
10/28/24 8:11	323322.7			2			10.39			1.56			13.19			1		
10/28/24 8:12	313930.6			1.8			11.71			1.34			14.44			1		
10/28/24 8:13	331640.4			1.8			12.33			1.39			16.06			1		
10/28/24 8:14	350493.9			1.6			10.39			1.33			14.3			1		
10/28/24 8:15	368972			1.5			10.04			1.32			14.55			1		
10/28/24 8:16	375008.1			1.5			8.63			1.34			12.71			1		
10/28/24 8:17	376319.3			1.5			7.93			1.34			11.71			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 8:18	389587.3			1.4			7.49			1.31			11.45			1		
10/28/24 8:19	412258.8			1.5			6.35			1.43			10.29			1		
10/28/24 8:20	434081.3			1.4			6.26			1.41			10.68			1		
10/28/24 8:21	443271.2			1.4			6.36			1.46			11.07			1		
10/28/24 8:22	383106.3			1.4			6.99			1.24			10.52			1		
10/28/24 8:23	352342.3			1.3			9.54			1.09			13.21			1		
10/28/24 8:24	362589.3			1.3			9.2			1.13			13.1			1		
10/28/24 8:25	360989.3			1.3			8.28			1.14			11.73			1		
10/28/24 8:26	313399.2			1.3			8.4			1			10.34			1		
10/28/24 8:27	319054			1.3			9.33			1.01			11.7			1		
10/28/24 8:28	339484.5			1.3			10.01			1.01			13.35			1		
10/28/24 8:29	354502.6			1.3			9.65			1.06			13.44			1		
10/28/24 8:30	345058.5			1.2			8.98			1.02			12.17			1		
10/28/24 8:31	335862.8			1.2			9.86			0.99			13.01			1		
10/28/24 8:32	332229.6			1.3			9.69			1.05			12.64			1		
10/28/24 8:33	333621.6			1.2			9.25			0.98			12.11			1		
10/28/24 8:34	332524.1			1.2			8.58			0.92			11.21			1		
10/28/24 8:35	333217.3			1.1			3.75			0.85			4.91			1		
10/28/24 8:36	330970.4			1.2			2.41			0.92			3.14			1		
10/28/24 8:37	331097.4			1.2			2.41			0.92			3.14			1		
10/28/24 8:38	332737.9			1.2			2.63			0.94			3.44			1		
10/28/24 8:39	333269.3			1.2			2.86			0.92			3.74			1		
10/28/24 8:40	332980.5			1.2			3.04			0.92			3.97			1		
10/28/24 8:41	332027.4			1.1			3.22			0.85			4.2			1		
10/28/24 8:42	333454.2			1.1			3.4			0.85			4.45			1		
10/28/24 8:43	332899.6			1.1			3.49			0.85			4.56			1		
10/28/24 8:44	332004.3			1.2			3.72			0.93			4.85			1		
10/28/24 8:45	331871.5			1.2			3.13			0.92			4.08			1		
10/28/24 8:46	333286.6			1.2			2.5			0.92			3.28			1		
10/28/24 8:47	332350.9			1.1			1.79			0.85			2.33			1		
10/28/24 8:48	331039.7			1.1			1.67			0.83			2.18			1		
10/28/24 8:49	331033.9			1.2			1.61			0.92			2.09			1		
10/28/24 8:50	331380.5			1.2			1.61			0.92			2.09			1		
10/28/24 8:51	333442.5			1.2			1.52			0.92			1.99			1		
10/28/24 8:52	331900.3			1.1			1.41			0.91			1.84			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 8:53	332258.5			1.1			1.45			0.86			1.9			1		
10/28/24 8:54	331802.2			1.1			1.34			0.85			1.75			1		
10/28/24 8:55	333373.3			1.1			1.34			0.85			1.76			1		
10/28/24 8:56	331998.5			1.1			1.34			0.85			1.75			1		
10/28/24 8:57	332547.3			1.1			1.25			0.85			1.63			1		
10/28/24 8:58	332194.9			1.1			1.25			0.85			1.63			0		
10/28/24 8:59	331403.6			1.1			1.16			0.85			1.51			0		
10/28/24 9:00	332166.1			1.1			1.16			0.85			1.52			0		
10/28/24 9:01	332033.2			1.2			1.16			0.92			1.52			0		
10/28/24 9:02	332633.9			1.2			1.07			0.92			1.4			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 7:46	0			0			0			0			0			0		
10/28/24 7:47	0			0			0			0			0			0		
10/28/24 7:48	0			0			0			0			0			0		
10/28/24 7:49	0			0			0			0			0			0		
10/28/24 7:50	2102.5			0			0			0.07			0			0		
10/28/24 7:51	8340.8			29.5			0			0.59			0			1		
10/28/24 7:52	24727.9			32.5			0			1.92			0			1		
10/28/24 7:53	39532.3			1083.4			14.75			102.1			2.29			1		
10/28/24 7:54	51899.1			1009.6			13.19			124.97			2.69			1		
10/28/24 7:55	64214			677			17.41			103.66			4.39			1		
10/28/24 7:56	83552.7			470.7			20.65			93.87			6.78			1		
10/28/24 7:57	131437.4			385.3			25.4			120.83			13.11			1		
10/28/24 7:58	153941.5			273.8			35.18			100.58			21.27			1		
10/28/24 7:59	160058.4			467.2			40.23			178.4			25.28			1		
10/28/24 8:00	177693.2			1768			35.58			749.58			24.82			1		
10/28/24 8:01	199042			1432.6			37.53			680.47			29.34			1		
10/28/24 8:02	223302			586.5			45.9			312.48			40.25			1		
10/28/24 8:03	246684.1			110			51.3			64.79			49.71			1		
10/28/24 8:04	270880.6			8.4			54.12			5.43			57.56			1		
10/28/24 8:05	298831.6			2.6			52.38			1.84			61.45			1		
10/28/24 8:06	325096			2.2			27.35			1.74			34.91			1		
10/28/24 8:07	346606.5			2.3			19.35			1.87			26.34			1		
10/28/24 8:08	364576.3			2.3			15.22			2.01			21.79			1		
10/28/24 8:09	383793.7			2.3			14.02			2.11			21.13			1		
10/28/24 8:10	389708.5			2.2			9.8			2.02			15			1		
10/28/24 8:11	323322.7			2			10.39			1.56			13.19			1		
10/28/24 8:12	313930.6			1.8			11.71			1.34			14.44			1		
10/28/24 8:13	331640.4			1.8			12.33			1.39			16.06			1		
10/28/24 8:14	350493.9			1.6			10.39			1.33			14.3			1		
10/28/24 8:15	368972			1.5			10.04			1.32			14.55			1		
10/28/24 8:16	375008.1			1.5			8.63			1.34			12.71			1		
10/28/24 8:17	376319.3			1.5			7.93			1.34			11.71			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 8:18	389587.3			1.4			7.49			1.31			11.45			1		
10/28/24 8:19	412258.8			1.5			6.35			1.43			10.29			1		
10/28/24 8:20	434081.3			1.4			6.26			1.41			10.68			1		
10/28/24 8:21	443271.2			1.4			6.36			1.46			11.07			1		
10/28/24 8:22	383106.3			1.4			6.99			1.24			10.52			1		
10/28/24 8:23	352342.3			1.3			9.54			1.09			13.21			1		
10/28/24 8:24	362589.3			1.3			9.2			1.13			13.1			1		
10/28/24 8:25	360989.3			1.3			8.28			1.14			11.73			1		
10/28/24 8:26	313399.2			1.3			8.4			1			10.34			1		
10/28/24 8:27	319054			1.3			9.33			1.01			11.7			1		
10/28/24 8:28	339484.5			1.3			10.01			1.01			13.35			1		
10/28/24 8:29	354502.6			1.3			9.65			1.06			13.44			1		
10/28/24 8:30	345058.5			1.2			8.98			1.02			12.17			1		
10/28/24 8:31	335862.8			1.2			9.86			0.99			13.01			1		
10/28/24 8:32	332229.6			1.3			9.69			1.05			12.64			1		
10/28/24 8:33	333621.6			1.2			9.25			0.98			12.11			1		
10/28/24 8:34	332524.1			1.2			8.58			0.92			11.21			1		
10/28/24 8:35	333217.3			1.1			3.75			0.85			4.91			1		
10/28/24 8:36	330970.4			1.2			2.41			0.92			3.14			1		
10/28/24 8:37	331097.4			1.2			2.41			0.92			3.14			1		
10/28/24 8:38	332737.9			1.2			2.63			0.94			3.44			1		
10/28/24 8:39	333269.3			1.2			2.86			0.92			3.74			1		
10/28/24 8:40	332980.5			1.2			3.04			0.92			3.97			1		
10/28/24 8:41	332027.4			1.1			3.22			0.85			4.2			1		
10/28/24 8:42	333454.2			1.1			3.4			0.85			4.45			1		
10/28/24 8:43	332899.6			1.1			3.49			0.85			4.56			1		
10/28/24 8:44	332004.3			1.2			3.72			0.93			4.85			1		
10/28/24 8:45	331871.5			1.2			3.13			0.92			4.08			1		
10/28/24 8:46	333286.6			1.2			2.5			0.92			3.28			1		
10/28/24 8:47	332350.9			1.1			1.79			0.85			2.33			1		
10/28/24 8:48	331039.7			1.1			1.67			0.83			2.18			1		
10/28/24 8:49	331033.9			1.2			1.61			0.92			2.09			1		
10/28/24 8:50	331380.5			1.2			1.61			0.92			2.09			1		
10/28/24 8:51	333442.5			1.2			1.52			0.92			1.99			1		
10/28/24 8:52	331900.3			1.1			1.41			0.91			1.84			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 8:53	332258.5			1.1			1.45			0.86			1.9			1		
10/28/24 8:54	331802.2			1.1			1.34			0.85			1.75			1		
10/28/24 8:55	333373.3			1.1			1.34			0.85			1.76			1		
10/28/24 8:56	331998.5			1.1			1.34			0.85			1.75			1		
10/28/24 8:57	332547.3			1.1			1.25			0.85			1.63			1		
10/28/24 8:58	332194.9			1.1			1.25			0.85			1.63			0		
10/28/24 8:59	331403.6			1.1			1.16			0.85			1.51			0		
10/28/24 9:00	332166.1			1.1			1.16			0.85			1.52			0		
10/28/24 9:01	332033.2			1.2			1.16			0.92			1.52			0		
10/28/24 9:02	332633.9			1.2			1.07			0.92			1.4			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 7:46	0			0			0			0			0			0		
10/28/24 7:47	0			0			0			0			0			0		
10/28/24 7:48	0			0			0			0			0			0		
10/28/24 7:49	0			0			0			0			0			0		
10/28/24 7:50	2102.5			0			0			0.07			0			0		
10/28/24 7:51	8340.8			29.5			0			0.59			0			1		
10/28/24 7:52	24727.9			32.5			0			1.92			0			1		
10/28/24 7:53	39532.3			1083.4			14.75			102.1			2.29			1		
10/28/24 7:54	51899.1			1009.6			13.19			124.97			2.69			1		
10/28/24 7:55	64214			677			17.41			103.66			4.39			1		
10/28/24 7:56	83552.7			470.7			20.65			93.87			6.78			1		
10/28/24 7:57	131437.4			385.3			25.4			120.83			13.11			1		
10/28/24 7:58	153941.5			273.8			35.18			100.58			21.27			1		
10/28/24 7:59	160058.4			467.2			40.23			178.4			25.28			1		
10/28/24 8:00	177693.2			1768			35.58			749.58			24.82			1		
10/28/24 8:01	199042			1432.6			37.53			680.47			29.34			1		
10/28/24 8:02	223302			586.5			45.9			312.48			40.25			1		
10/28/24 8:03	246684.1			110			51.3			64.79			49.71			1		
10/28/24 8:04	270880.6			8.4			54.12			5.43			57.56			1		
10/28/24 8:05	298831.6			2.6			52.38			1.84			61.45			1		
10/28/24 8:06	325096			2.2			27.35			1.74			34.91			1		
10/28/24 8:07	346606.5			2.3			19.35			1.87			26.34			1		
10/28/24 8:08	364576.3			2.3			15.22			2.01			21.79			1		
10/28/24 8:09	383793.7			2.3			14.02			2.11			21.13			1		
10/28/24 8:10	389708.5			2.2			9.8			2.02			15			1		
10/28/24 8:11	323322.7			2			10.39			1.56			13.19			1		
10/28/24 8:12	313930.6			1.8			11.71			1.34			14.44			1		
10/28/24 8:13	331640.4			1.8			12.33			1.39			16.06			1		
10/28/24 8:14	350493.9			1.6			10.39			1.33			14.3			1		
10/28/24 8:15	368972			1.5			10.04			1.32			14.55			1		
10/28/24 8:16	375008.1			1.5			8.63			1.34			12.71			1		
10/28/24 8:17	376319.3			1.5			7.93			1.34			11.71			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 8:18	389587.3			1.4			7.49			1.31			11.45			1		
10/28/24 8:19	412258.8			1.5			6.35			1.43			10.29			1		
10/28/24 8:20	434081.3			1.4			6.26			1.41			10.68			1		
10/28/24 8:21	443271.2			1.4			6.36			1.46			11.07			1		
10/28/24 8:22	383106.3			1.4			6.99			1.24			10.52			1		
10/28/24 8:23	352342.3			1.3			9.54			1.09			13.21			1		
10/28/24 8:24	362589.3			1.3			9.2			1.13			13.1			1		
10/28/24 8:25	360989.3			1.3			8.28			1.14			11.73			1		
10/28/24 8:26	313399.2			1.3			8.4			1			10.34			1		
10/28/24 8:27	319054			1.3			9.33			1.01			11.7			1		
10/28/24 8:28	339484.5			1.3			10.01			1.01			13.35			1		
10/28/24 8:29	354502.6			1.3			9.65			1.06			13.44			1		
10/28/24 8:30	345058.5			1.2			8.98			1.02			12.17			1		
10/28/24 8:31	335862.8			1.2			9.86			0.99			13.01			1		
10/28/24 8:32	332229.6			1.3			9.69			1.05			12.64			1		
10/28/24 8:33	333621.6			1.2			9.25			0.98			12.11			1		
10/28/24 8:34	332524.1			1.2			8.58			0.92			11.21			1		
10/28/24 8:35	333217.3			1.1			3.75			0.85			4.91			1		
10/28/24 8:36	330970.4			1.2			2.41			0.92			3.14			1		
10/28/24 8:37	331097.4			1.2			2.41			0.92			3.14			1		
10/28/24 8:38	332737.9			1.2			2.63			0.94			3.44			1		
10/28/24 8:39	333269.3			1.2			2.86			0.92			3.74			1		
10/28/24 8:40	332980.5			1.2			3.04			0.92			3.97			1		
10/28/24 8:41	332027.4			1.1			3.22			0.85			4.2			1		
10/28/24 8:42	333454.2			1.1			3.4			0.85			4.45			1		
10/28/24 8:43	332899.6			1.1			3.49			0.85			4.56			1		
10/28/24 8:44	332004.3			1.2			3.72			0.93			4.85			1		
10/28/24 8:45	331871.5			1.2			3.13			0.92			4.08			1		
10/28/24 8:46	333286.6			1.2			2.5			0.92			3.28			1		
10/28/24 8:47	332350.9			1.1			1.79			0.85			2.33			1		
10/28/24 8:48	331039.7			1.1			1.67			0.83			2.18			1		
10/28/24 8:49	331033.9			1.2			1.61			0.92			2.09			1		
10/28/24 8:50	331380.5			1.2			1.61			0.92			2.09			1		
10/28/24 8:51	333442.5			1.2			1.52			0.92			1.99			1		
10/28/24 8:52	331900.3			1.1			1.41			0.91			1.84			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/28/24 8:53	332258.5			1.1			1.45			0.86			1.9			1		
10/28/24 8:54	331802.2			1.1			1.34			0.85			1.75			1		
10/28/24 8:55	333373.3			1.1			1.34			0.85			1.76			1		
10/28/24 8:56	331998.5			1.1			1.34			0.85			1.75			1		
10/28/24 8:57	332547.3			1.1			1.25			0.85			1.63			1		
10/28/24 8:58	332194.9			1.1			1.25			0.85			1.63			0		
10/28/24 8:59	331403.6			1.1			1.16			0.85			1.51			0		
10/28/24 9:00	332166.1			1.1			1.16			0.85			1.52			0		
10/28/24 9:01	332033.2			1.2			1.16			0.92			1.52			0		
10/28/24 9:02	332633.9			1.2			1.07			0.92			1.4			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
10/28/24 8:59	331403.6		1.1		1.16		0.85		1.51		0	
10/28/24 9:00	332166.1		1.1		1.16		0.85		1.52		0	
10/28/24 9:01	332033.2		1.2		1.16		0.92		1.52		0	
10/28/24 9:02	332633.9		1.2		1.07		0.92		1.4		0	
10/28/24 9:03	330600.7		1.2		1.09		0.93		1.41		0	
10/28/24 9:04	330814.4		1.2		1.07		0.92		1.39		1	
10/28/24 9:05	316166		1.2		1.07		0.88		1.33		1	
10/28/24 9:06	292882.1		1.2		1.18		0.82		1.36		1	
10/28/24 9:07	268610.5		1.2		1.75		0.77		1.85		1	
10/28/24 9:08	244876.1		1.1		4.74		0.62		4.56		1	
10/28/24 9:09	220258		0.9		12.52		0.49		10.83		1	
10/28/24 9:10	193889.6		14.3		19.55		6.64		14.89		1	
10/28/24 9:11	172939.4		199.6		25.7		82.32		17.45		1	
10/28/24 9:12	152751.6		722.6		30.68		263.33		18.4		1	
10/28/24 9:13	93060.3		1313.3		36.75		291.63		13.43		1	
10/28/24 9:14	0		0		40.02		0		0		0	
10/28/24 9:15	0		0		11.8		0		0		0	
10/28/24 9:16	0		0		5.9		0		0		0	
10/28/24 9:17	0		0		5.9		0		0		0	
10/28/24 9:18	0		0		5.9		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/24 8:40	0			0	X		0	X		0	X		0	X		0		
10/29/24 8:41	0			0	X		0	X		0	X		0	X		0		
10/29/24 8:42	0			0	X		0	X		0	X		0	X		0		
10/29/24 8:43	0			0	X		0	X		0	X		0	X		0		
10/29/24 8:44	0			0	X		0	X		0	X		0	X		0		
10/29/24 8:45	3737.2			29.5	X		0	X		0.26	X		0	X		1		
10/29/24 8:46	20494			29.5	X		0	X		1.44	X		0	X		1		
10/29/24 8:47	36176.3			1331.9	X		19.18	X		115.08	X		2.73	X		1		
10/29/24 8:48	48144.6			1215	X		12.98	X		139.52	X		2.45	X		1		
10/29/24 8:49	60118.7			800.5	X		16.15	X		114.87	X		3.81	X		1		
10/29/24 8:50	74339.7			543.9	X		20.23	X		96.43	X		5.9	X		1		
10/29/24 8:51	111469.1			417.1	X		24.11	X		110.92	X		10.55	X		1		
10/29/24 8:52	154103.2			320	X		25.02	X		117.7	X		15.14	X		1		
10/29/24 8:53	163206.5			227.7	X		20.85	X		88.7	X		13.36	X		1		
10/29/24 8:54	173984.9			1378.5	X		18.39	X		572.41	X		12.57	X		1		
10/29/24 8:55	193288.9			1521.9	X		17.37	X		701.77	X		13.18	X		1		
10/29/24 8:56	217017.5			766.3	X		15.64	X		396.74	X		13.32	X		1		
10/29/24 8:57	240890.6			187.5	X		14.21	X		107.76	X		13.45	X		1		
10/29/24 8:58	263856.7			16	X		12.51	X		10.11	X		12.96	X		1		
10/29/24 8:59	290461.9			2.7	X		11.37	X		1.86	X		12.97	X		1		
10/29/24 9:00	317841.1			2	X		10.25	X		1.54	X		12.8	X		1		
10/29/24 9:01	338537.2			2.1	X		9.48	X		1.66	X		12.6	X		1		
10/29/24 9:02	337636.1			2.2	X		8.93	X		1.77	X		11.85	X		1		
10/29/24 9:03	335608.6			2.4	X		8.93	X		1.89	X		11.77	X		1		
10/29/24 9:04	334395.7			2.2	X		9.06	X		1.77	X		11.9	X		1		
10/29/24 9:05	332391.3			2.1	X		9.06	X		1.63	X		11.83	X		1		
10/29/24 9:06	333771.8			1.9	X		9.06	X		1.5	X		11.88	X		1		
10/29/24 9:07	332703.2			1.7	X		9.2	X		1.38	X		12.01	X		1		
10/29/24 9:08	333119.1			1.6	X		9.2	X		1.24	X		12.03	X		1		
10/29/24 9:09	330271.5			1.5	X		9.33	X		1.18	X		12.11	X		1		
10/29/24 9:10	331790.6			1.4	X		9.33	X		1.12	X		12.16	X		1		
10/29/24 9:11	332044.7			1.3	X		9.33	X		1.05	X		12.17	X		1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/24 9:12	337208.7			1.4	X		9.33	X		1.13	X		12.36	X		1		
10/29/24 9:13	355611.6			1.4	X		9.33	X		1.2	X		13.04	X		1		
10/29/24 9:14	371969.8			1.3	X		9.33	X		1.17	X		13.63	X		1		
10/29/24 9:15	375227.6			1.3	X		8.54	X		1.18	X		12.59	X		1		
10/29/24 9:16	373182.8			1.3	X		8.01	X		1.18	X		11.74	X		1		
10/29/24 9:17	374326.5			1.3	X		8.1	X		1.18	X		11.91	X		1		
10/29/24 9:18	374586.5			1.2	X		8.1	X		1.1	X		11.92	X		1		
10/29/24 9:19	373702.7			1.2	X		8.01	X		1.1	X		11.76	X		1		
10/29/24 9:20	372189.3			1.2	X		7.93	X		1.09	X		11.58	X		1		
10/29/24 9:21	371663.7			1.3	X		7.75	X		1.17	X		11.31	X		1		
10/29/24 9:22	371686.8			1.2	X		7.75	X		1.09	X		11.31	X		1		
10/29/24 9:23	372507			1.1	X		7.66	X		1.02	X		11.21	X		1		
10/29/24 9:24	371964			1.2	X		7.66	X		1.09	X		11.19	X		1		
10/29/24 9:25	379744.6			1.2	X		7.46	X		1.1	X		11.13	X		1		
10/29/24 9:26	399204.6			1.2	X		6.52	X		1.17	X		10.21	X		1		
10/29/24 9:27	405350.5			1.2	X		6.17	X		1.12	X		9.82	X		1		
10/29/24 9:28	407695.6			1.2	X		5.27	X		1.13	X		8.44	X		1		
10/29/24 9:29	407181.5			1.2	X		3.49	X		1.13	X		5.57	X		1		
10/29/24 9:30	411386.6			1.2	X		2.59	X		1.14	X		4.19	X		1		
10/29/24 9:31	427744.8			1.1	X		2.06	X		1.09	X		3.45	X		1		
10/29/24 9:32	443092.1			1.1	X		1.54	X		1.15	X		2.68	X		1		
10/29/24 9:33	445564.4			1.1	X		1.48	X		1.18	X		2.58	X		1		
10/29/24 9:34	448192.5			1.1	X		1.45	X		1.16	X		2.56	X		1		
10/29/24 9:35	446113.1			1.1	X		1.45	X		1.16	X		2.54	X		1		
10/29/24 9:36	446552.1			1.1	X		1.27	X		1.16	X		2.23	X		1		
10/29/24 9:37	445477.7			1.1	X		1.18	X		1.16	X		2.06	X		1		
10/29/24 9:38	445945.6			1.2	X		1.09	X		1.26	X		1.91	X		1		
10/29/24 9:39	445206.2			1.1	X		1.09	X		1.16	X		1.9	X		1		
10/29/24 9:40	443652.4			1.1	X		1	X		1.15	X		1.74	X		1		
10/29/24 9:41	444796.1			1	X		0.91	X		1.06	X		1.59	X		1		
10/29/24 9:42	445206.3			1	X		0.91	X		1.06	X		1.59	X		0		
10/29/24 9:43	451710.3			0.9	X		0.82	X		0.98	X		1.45	X		0		
10/29/24 9:44	468264.8			1	X		0.82	X		1.12	X		1.5	X		0		
10/29/24 9:45	475987.6			1	X		0.73	X		1.13	X		1.36	X		0		
10/29/24 9:46	479568.9			1	X		0.73	X		1.14	X		1.37	X		0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
11/05/24 9:54	370260		0.9		1.16		0.78		1.67		0	
11/05/24 9:55	373275.2		1		1.16		0.87		1.68		0	
11/05/24 9:56	375164		1.1		1.16		0.95		1.69		0	
11/05/24 9:57	377370.5		1.1		1.16		0.95		1.7		0	
11/05/24 9:58	375747.5		1.1		1.16		0.95		1.7		0	
11/05/24 9:59	106703.7		25.4		1.25		6.39		0.52		1	
11/05/24 10:00	0		0		0.98		0		0		0	
11/05/24 10:01	0		0		0		0		0		0	
11/05/24 10:02	0		0		0		0		0		0	
11/05/24 10:03	0		0		0		0		0		0	
11/05/24 10:04	0		0		0		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
11/05/24 10:14	0		0		0		0		0		0	
11/05/24 10:15	0		0		0		0		0		0	
11/05/24 10:16	0		0		0		0		0		0	
11/05/24 10:17	0		0		0		0		0		0	
11/05/24 10:18	3771.9		0		0		0		0		0	
11/05/24 10:19	7745.9		0.2		0		0		0		1	
11/05/24 10:20	22694.7		0.9		0		0		0		1	
11/05/24 10:21	38232.7		775.1		0.74		69.92		0.11		1	
11/05/24 10:22	50836.3		755.6		4.33		90.66		0.85		1	
11/05/24 10:23	62729.5		480.5		6.56		71.1		1.6		1	
11/05/24 10:24	86019.1		305.2		9.01		61.91		3.01		1	
11/05/24 10:25	132841		223.4		13.2		70		6.81		1	
11/05/24 10:26	156176.8		166.3		20.2		61.29		12.25		1	
11/05/24 10:27	189037.6		693.9		24.36		309.42		17.88		1	
11/05/24 10:28	214943.9		774.3		27.11		392.6		22.62		1	
11/05/24 10:29	239435		110		30.44		62.1		28.29		1	
11/05/24 10:30	264653.8		5.8		32.33		3.61		33.22		1	
11/05/24 10:31	291732.7		1.3		29.93		0.89		33.89		1	
11/05/24 10:32	317685.1		1.1		13.25		0.8		16.34		1	
11/05/24 10:33	339911.9		1		9.65		0.79		12.74		1	
11/05/24 10:34	359250.7		1.1		7.49		0.97		10.44		1	
11/05/24 10:35	372986.5		1.1		7.2		0.99		10.43		1	
11/05/24 10:36	372911.3		1.2		6.25		1.07		9.04		1	
11/05/24 10:37	373009.5		1.1		6.16		0.99		8.92		1	
11/05/24 10:38	373055.8		1.1		6.25		1.01		9.05		1	
11/05/24 10:39	371496.2		1.1		6.08		0.93		8.76		1	
11/05/24 10:40	375348.9		1		5.99		0.86		8.72		1	
11/05/24 10:41	372518.6		0.9		5.99		0.77		8.66		1	
11/05/24 10:42	370733.7		0.9		5.01		0.78		7.21		1	
11/05/24 10:43	372293.3		1		2.91		0.85		4.2		1	
11/05/24 10:44	372102.7		1		2.38		0.85		3.43		1	
11/05/24 10:45	372616.8		1		2.41		0.86		3.49		1	

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/05/24 10:46	371698.3			1			2.41			0.86			3.48			1		
11/05/24 10:47	371276.7			1			2.41			0.86			3.48			1		
11/05/24 10:48	371230.5			0.9			2.41			0.78			3.48			1		
11/05/24 10:49	372021.8			0.9			2.32			0.78			3.36			1		
11/05/24 10:50	369364.7			0.8			2.32			0.7			3.33			1		
11/05/24 10:51	372131.6			0.9			2.23			0.78			3.23			1		
11/05/24 10:52	370629.8			0.9			2.15			0.78			3.09			1		
11/05/24 10:53	370618.2			1			2.15			0.86			3.09			1		
11/05/24 10:54	371605.9			0.9			2.06			0.78			2.97			1		
11/05/24 10:55	369722.9			0.9			2.06			0.78			2.95			1		
11/05/24 10:56	370606.6			1			2.06			0.86			2.96			1		
11/05/24 10:57	370358.3			1			1.97			0.86			2.83			1		
11/05/24 10:58	371057.2			1			1.97			0.86			2.83			1		
11/05/24 10:59	370745.3			1			1.97			0.86			2.83			1		
11/05/24 11:00	370572			0.9			1.88			0.78			2.7			1		
11/05/24 11:01	370433.3			0.9			1.88			0.78			2.7			1		
11/05/24 11:02	371704.1			0.8			1.88			0.71			2.71			1		
11/05/24 11:03	369087.5			0.8			1.91			0.71			2.73			1		
11/05/24 11:04	369613.2			0.9			1.88			0.78			2.69			1		
11/05/24 11:05	368504.1			0.9			1.82			0.79			2.6			1		
11/05/24 11:06	369809.5			1			1.79			0.86			2.57			0		
11/05/24 11:07	370208.1			1			1.7			0.86			2.44			0		
11/05/24 11:08	369249.2			1			1.7			0.86			2.43			0		
11/05/24 11:09	370837.7			1			1.61			0.86			2.32			0		
11/05/24 11:10	369243.4			1			1.52			0.86			2.18			0		
11/05/24 11:11	369445.6			0.9			1.52			0.78			2.18			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/06/24 11:40	377803.8			1			1.45			0.89			2.13			0		
11/06/24 11:41	377953.9			1			1.48			0.9			2.16			0		
11/06/24 11:42	378133			1			1.38			0.9			2.03			0		
11/06/24 11:43	378167.7			1			1.36			0.89			2			0		
11/06/24 11:44	378768.4			1			1.36			0.89			2			0		
11/06/24 11:45	375424			1			1.36			0.88			1.98			1		
11/06/24 11:46	356397.2			0.9			1.36			0.76			1.88			1		
11/06/24 11:47	332119.8			1			1.45			0.78			1.87			1		
11/06/24 11:48	308616.5			1			2			0.73			2.39			1		
11/06/24 11:49	285246			1			2.3			0.68			2.55			1		
11/06/24 11:50	261009.1			0.9			3.56			0.58			3.61			1		
11/06/24 11:51	236506.4			0.9			7.77			0.49			7.13			1		
11/06/24 11:52	211830.5			0.7			21.96			0.33			18.06			1		
11/06/24 11:53	185826			17.2			29.26			7.55			21.11			1		
11/06/24 11:54	165782.7			231			33.25			90.35			21.4			1		
11/06/24 11:55	145797			864.5			38.35			297.24			21.7			1		
11/06/24 11:56	68245.8			1464.8			40.23			235.75			10.66			1		
11/06/24 11:57	0			0			41.3			0			0			0		
11/06/24 11:58	0			0			17.7			0			0			0		
11/06/24 11:59	0			0			0.2			0			0			0		
11/06/24 12:00	0			0			0.2			0			0			0		
11/06/24 12:01	0			0			0.1			0			0			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/24 14:17	0			0			0			0			0			0		
11/07/24 14:18	0			0			0			0			0			0		
11/07/24 14:19	0			0			0			0			0			0		
11/07/24 14:20	0			0			0			0			0			0		
11/07/24 14:21	0			0			0			0			0			0		
11/07/24 14:22	5117.7			0.2			0			0			0			1		
11/07/24 14:23	14683.1			0.3			0			0			0			1		
11/07/24 14:24	30787.1			24.9			0.6			0			0			1		
11/07/24 14:25	44297.7			1323.2			17.16			138.32			2.95			1		
11/07/24 14:26	56329.5			916			19.18			121.79			4.2			1		
11/07/24 14:27	68546.1			549.9			23.91			88.88			6.36			1		
11/07/24 14:28	98894.3			388.6			27.81			90.63			10.68			1		
11/07/24 14:29	145346.5			251.9			36.94			86.39			20.85			1		
11/07/24 14:30	154594.2			166			53.1			60.55			31.87			1		
11/07/24 14:31	168878.7			1004.7			55.5			400.3			36.39			1		
11/07/24 14:32	191232.6			1373.3			56.57			619.43			41.99			1		
11/07/24 14:33	215013.2			604.4			63.35			306.59			52.88			1		
11/07/24 14:34	239336.8			99.8			64.63			56.32			60.05			1		
11/07/24 14:35	263238.7			6.5			59.94			4.03			61.26			1		
11/07/24 14:36	291461.2			2			59			1.4			66.75			1		
11/07/24 14:37	316223.8			1.8			32.16			1.32			39.47			1		
11/07/24 14:38	339143.7			1.7			18.42			1.36			24.25			1		
11/07/24 14:39	360556			1.8			14.09			1.57			19.72			1		
11/07/24 14:40	375920.8			1.9			13.19			1.69			19.24			1		
11/07/24 14:41	378052.2			1.9			10.41			1.7			15.28			1		
11/07/24 14:42	378404.5			1.8			10.04			1.57			14.75			1		
11/07/24 14:43	378496.9			1.7			9.69			1.49			14.23			1		
11/07/24 14:44	375915			1.6			8.81			1.41			12.85			1		
11/07/24 14:45	377815.3			1.5			8.72			1.33			12.79			1		
11/07/24 14:46	376434.8			1.3			8.58			1.19			12.54			1		
11/07/24 14:47	375666.6			1.3			8.13			1.19			11.86			1		
11/07/24 14:48	374759.7			1.3			7.78			1.11			11.31			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/24 14:49	373298.3			1.3			7.51			1.1			10.88			1		
11/07/24 14:50	375568.4			1.2			7.33			1.03			10.69			1		
11/07/24 14:51	374274.5			1.2			7.24			1.03			10.52			1		
11/07/24 14:52	372293.3			1.1			7.15			0.94			10.34			1		
11/07/24 14:53	373743.1			1.2			7.17			1.04			10.4			1		
11/07/24 14:54	372541.6			1.1			7.17			0.96			10.37			1		
11/07/24 14:55	371611.7			1			7.08			0.88			10.21			1		
11/07/24 14:56	372229.8			1			7.08			0.88			10.23			1		
11/07/24 14:57	371756.1			1			7.08			0.88			10.22			1		
11/07/24 14:58	370808.8			1			7.08			0.87			10.19			1		
11/07/24 14:59	370444.9			1			7.08			0.87			10.18			1		
11/07/24 15:00	371247.8			1			7.08			0.87			10.2			1		
11/07/24 15:01	369324.3			1			7.17			0.87			10.28			1		
11/07/24 15:02	371438.4			1			7.08			0.87			10.21			1		
11/07/24 15:03	369751.8			1			4.72			0.87			6.77			1		
11/07/24 15:04	369387.8			1.2			2.54			1.03			3.64			1		
11/07/24 15:05	370676			1.2			2.36			1.03			3.4			1		
11/07/24 15:06	367995.8			1.1			2.36			0.95			3.37			1		
11/07/24 15:07	369110.6			1			2.45			0.87			3.51			1		
11/07/24 15:08	369821.1			1.1			2.54			0.95			3.65			1		
11/07/24 15:09	370410.3			1.1			2.63			0.95			3.78			1		
11/07/24 15:10	369203			1.1			2.63			0.95			3.77			1		
11/07/24 15:11	369676.7			1.1			2.72			0.95			3.91			1		
11/07/24 15:12	369636.3			1			2.63			0.87			3.78			1		
11/07/24 15:13	369174.2			1			2.09			0.87			2.99			1		
11/07/24 15:14	369624.7			1			1.82			0.87			2.6			1		
11/07/24 15:15	369093.3			1			1.63			0.87			2.34			1		
11/07/24 15:16	368498.3			1			1.45			0.87			2.08			1		
11/07/24 15:17	368977.8			1			1.18			0.87			1.69			1		
11/07/24 15:18	368198			1.1			1			0.95			1.43			1		
11/07/24 15:19	368608.1			1.1			0.91			0.95			1.3			1		
11/07/24 15:20	367574.1			1.1			0.73			0.94			1.04			1		
11/07/24 15:21	367949.6			1.1			0.73			0.95			1.04			1		
11/07/24 15:22	368354			1			0.64			0.87			0.91			1		
11/07/24 15:23	369595.8			1			0.54			0.87			0.78			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/24 15:24	368590.8			1			0.54			0.87			0.78			0		
11/07/24 15:25	369457.2			1.1			0.54			0.95			0.78			0		
11/07/24 15:26	369018.2			1.1			0.54			0.95			0.78			0		
11/07/24 15:27	367972.7			1.1			0.54			0.95			0.78			0		
11/07/24 15:28	368977.8			1			0.54			0.87			0.78			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/08/24 8:45	370762.6			1.1			0.79			1			1.14			0		
11/08/24 8:46	371455.8			1.1			0.79			1			1.14			0		
11/08/24 8:47	371559.8			1.2			0.8			1.02			1.16			0		
11/08/24 8:48	370855			1.1			0.8			0.94			1.16			0		
11/08/24 8:49	370733.7			1.1			0.8			0.94			1.16			0		
11/08/24 8:50	369116.4			1.2			0.8			1.01			1.15			1		
11/08/24 8:51	354693.2			1.2			0.8			0.97			1.11			1		
11/08/24 8:52	333020.9			1.1			0.88			0.9			1.14			1		
11/08/24 8:53	310072.1			1.1			1.07			0.78			1.29			1		
11/08/24 8:54	285113.1			1.1			1.45			0.73			1.61			1		
11/08/24 8:55	259669			1			3			0.63			3.02			1		
11/08/24 8:56	235755.5			0.8			9.56			0.45			8.75			1		
11/08/24 8:57	211281.8			2.1			16.03			1.05			13.15			1		
11/08/24 8:58	186652.1			67.1			19.67			29.55			14.25			1		
11/08/24 8:59	167059.2			437.2			23.6			172.23			15.3			1		
11/08/24 9:00	147079.3			1067.7			26.95			370.47			15.39			1		
11/08/24 9:01	34004.5			1424			30.04			114.12			3.96			1		
11/08/24 9:02	0			0			29.5			0			0			0		
11/08/24 9:03	0			0			11.8			0			0			0		
11/08/24 9:04	0			0			0.1			0			0			0		
11/08/24 9:05	0			0			0.1			0			0			0		
11/08/24 9:06	0			0			5.9			0			0			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/08/24 18:16	0			0			0			0			0			0		
11/08/24 18:17	0			0			0			0			0			0		
11/08/24 18:18	0			0			0			0			0			0		
11/08/24 18:19	0			0			0			0			0			0		
11/08/24 18:20	0			0			0			0			0			0		
11/08/24 18:21	8647			17.7			0			0.36			0			1		
11/08/24 18:22	25236.2			2.2			0.1			0			0			1		
11/08/24 18:23	39948.2			1212.1			13.11			114.23			2.03			1		
11/08/24 18:24	52320.8			1081.7			12.98			133.41			2.63			1		
11/08/24 18:25	64167.8			644.1			17.04			97.46			4.24			1		
11/08/24 18:26	83564.3			418.6			20.65			82.55			6.7			1		
11/08/24 18:27	131015.7			277			25.21			85.64			12.83			1		
11/08/24 18:28	156101.7			192			38.12			70.69			23.1			1		
11/08/24 18:29	179472.3			516.6			42.96			218.68			29.93			1		
11/08/24 18:30	201635.5			1127.1			46.19			536.12			36.16			1		
11/08/24 18:31	226964.1			334			46.19			178.84			40.71			1		
11/08/24 18:32	250975.8			32.3			46.7			19.1			45.5			1		
11/08/24 18:33	274710.2			2.6			48.79			1.69			52.03			1		
11/08/24 18:34	302672.8			1.9			39.33			1.33			46.21			1		
11/08/24 18:35	328013			1.5			18.25			1.14			23.24			1		
11/08/24 18:36	348737.9			1.4			12.75			1.14			17.27			1		
11/08/24 18:37	370774.2			1.6			11.02			1.37			15.86			1		
11/08/24 18:38	378485.4			1.6			10.09			1.45			14.82			1		
11/08/24 18:39	379340.3			1.6			8.85			1.47			13.03			1		
11/08/24 18:40	380079.6			1.6			8.42			1.4			12.42			1		
11/08/24 18:41	378202.3			1.5			8.33			1.32			12.23			1		
11/08/24 18:42	375995.8			1.5			8.16			1.31			11.9			1		
11/08/24 18:43	376330.8			1.4			7.98			1.23			11.66			1		
11/08/24 18:44	377041.3			1.4			7.93			1.25			11.6			1		
11/08/24 18:45	376717.8			1.4			7.84			1.25			11.46			1		
11/08/24 18:46	375239.2			1.3			7.84			1.17			11.42			1		
11/08/24 18:47	374742.4			1.2			7.75			1.09			11.27			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/08/24 18:48	374904.1			1.2			7.66			1.09			11.15			1		
11/08/24 18:49	374286.1			1.3			7.6			1.1			11.04			1		
11/08/24 18:50	372726.5			1.3			5.27			1.1			7.63			1		
11/08/24 18:51	373390.8			1.3			2.59			1.1			3.76			1		
11/08/24 18:52	371981.4			1.3			2.5			1.1			3.61			1		
11/08/24 18:53	371854.3			1.3			2.41			1.1			3.48			1		
11/08/24 18:54	371681			1.3			2.41			1.1			3.48			1		
11/08/24 18:55	371530.8			1.3			2.41			1.18			3.48			1		
11/08/24 18:56	371831.2			1.3			2.41			1.1			3.48			1		
11/08/24 18:57	372264.4			1.2			2.41			1.02			3.49			1		
11/08/24 18:58	371958.3			1.2			2.32			1.02			3.36			1		
11/08/24 18:59	369850			1.2			2.32			1.01			3.34			1		
11/08/24 19:00	370872.3			1.2			2.23			1.02			3.22			1		
11/08/24 19:01	371461.5			1.3			2.23			1.1			3.22			1		
11/08/24 19:02	370641.3			1.3			2.23			1.17			3.22			1		
11/08/24 19:03	369087.5			1.3			2.23			1.17			3.2			1		
11/08/24 19:04	370791.5			1.3			2.15			1.09			3.09			1		
11/08/24 19:05	368359.7			1.2			2.15			1.01			3.07			1		
11/08/24 19:06	371455.7			1.1			2.06			0.94			2.96			1		
11/08/24 19:07	384845			1.2			2.09			1.07			3.12			1		
11/08/24 19:08	410329.5			1.1			2			1.05			3.18			1		
11/08/24 19:09	430679.1			1.1			1.75			1.12			2.93			1		
11/08/24 19:10	456204.1			1.1			1.69			1.21			2.99			1		
11/08/24 19:11	464856.9			1.2			1.69			1.34			3.04			1		
11/08/24 19:12	468963.8			1.2			1.81			1.37			3.29			1		
11/08/24 19:13	463516.8			1.1			1.87			1.23			3.37			1		
11/08/24 19:14	442283.5			1.1			1.97			1.17			3.38			1		
11/08/24 19:15	426196.8			1.1			2.03			1.11			3.36			1		
11/08/24 19:16	427363.6			1.2			2			1.19			3.31			1		
11/08/24 19:17	427109.5			1.3			1.75			1.3			2.9			1		
11/08/24 19:18	436455.3			1.2			1.48			1.23			2.5			0		
11/08/24 19:19	456562.3			1.2			1.48			1.29			2.61			0		
11/08/24 19:20	467496.5			1.2			1.48			1.32			2.68			0		
11/08/24 19:21	467785.4			1.3			1.5			1.45			2.72			0		
11/08/24 19:22	471066.3			1.3			1.5			1.46			2.74			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
11/09/24 6:43	399551.2		1		1.07		0.93		1.66		0	
11/09/24 6:44	383834.1		1		0.98		0.89		1.47		0	
11/09/24 6:45	377907.8		1		0.95		0.93		1.4		0	
11/09/24 6:46	375891.9		1.1		0.97		1.02		1.41		0	
11/09/24 6:47	376278.8		1.1		0.88		1.02		1.29		0	
11/09/24 6:48	374823.3		1.2		0.88		1.09		1.28		1	
11/09/24 6:49	364195		1.3		0.89		1.08		1.26		1	
11/09/24 6:50	343978.4		1.3		0.89		1.02		1.19		1	
11/09/24 6:51	319857		1.1		0.95		0.85		1.19		1	
11/09/24 6:52	295920.4		1.2		1.18		0.82		1.36		1	
11/09/24 6:53	271591.1		1.1		2.12		0.71		2.24		1	
11/09/24 6:54	247931.8		1		5.71		0.57		5.49		1	
11/09/24 6:55	223175		0.9		14.01		0.5		12.14		1	
11/09/24 6:56	197857.9		16.8		19.47		7.82		14.96		1	
11/09/24 6:57	176491.7		218.8		22.29		91.11		15.27		1	
11/09/24 6:58	155333.5		793		25.81		290.57		15.57		1	
11/09/24 6:59	94221.3		1362.9		30.01		302.94		10.98		1	
11/09/24 7:00	0		0		31.04		0		0		0	
11/09/24 7:01	0		0		17.7		0		0		0	
11/09/24 7:02	0		0		11.8		0		0		0	
11/09/24 7:03	0		0		0.1		0		0		0	
11/09/24 7:04	0		0		5.9		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
11/15/24 12:44	0		0		0		0		0		0	
11/15/24 12:45	0		0		0		0		0		0	
11/15/24 12:46	0		0		0		0		0		0	
11/15/24 12:47	0		0		0		0		0		0	
11/15/24 12:48	0		0		0		0		0		0	
11/15/24 12:49	17732.9		0.3		0		0		0		1	
11/15/24 12:50	23555.3		0.2		0		0		0		1	
11/15/24 12:51	38042		1271.5		17.7		114.13		2.61		1	
11/15/24 12:52	50755.4		434.5		8.68		52.04		1.71		1	
11/15/24 12:53	19777.7		118		9.24		5.49		0.71		1	
11/15/24 12:54	0		0		9.12		0		0		0	
11/15/24 12:55	0		0		7.94		0		0		0	
11/15/24 12:56	0		0		9.69		0		0		0	
11/15/24 12:57	0		0		13.77		0		0		0	
11/15/24 12:58	0		0		18.44		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
11/15/24 12:44	0		0		0		0		0		0	
11/15/24 12:45	0		0		0		0		0		0	
11/15/24 12:46	0		0		0		0		0		0	
11/15/24 12:47	0		0		0		0		0		0	
11/15/24 12:48	0		0		0		0		0		0	
11/15/24 12:49	17732.9		0.3		0		0		0		1	
11/15/24 12:50	23555.3		0.2		0		0		0		1	
11/15/24 12:51	38042		1271.5		17.7		114.13		2.61		1	
11/15/24 12:52	50755.4		434.5		8.68		52.04		1.71		1	
11/15/24 12:53	19777.7		118		9.24		5.49		0.71		1	
11/15/24 12:54	0		0		9.12		0		0		0	
11/15/24 12:55	0		0		7.94		0		0		0	
11/15/24 12:56	0		0		9.69		0		0		0	
11/15/24 12:57	0		0		13.77		0		0		0	
11/15/24 12:58	0		0		18.44		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
11/15/24 13:18	0		0		0.1		0		0		0	
11/15/24 13:19	0		0		0.1		0		0		0	
11/15/24 13:20	0		0		0		0		0		0	
11/15/24 13:21	0		0		0		0		0		0	
11/15/24 13:22	0		0		0		0		0		0	
11/15/24 13:23	1530.7		0.4		0		0		0		1	
11/15/24 13:24	19795		0.4		0		0		0		1	
11/15/24 13:25	34691.8		1174.1		17.7		96.19		2.39		1	
11/15/24 13:26	47676.7		527.8		11.8		59.31		2.18		1	
11/15/24 13:27	28470.9		165.9		12.89		11.14		1.42		1	
11/15/24 13:28	0		0		13.91		0		0		0	
11/15/24 13:29	0		0		12.63		0		0		0	
11/15/24 13:30	0		0		17.25		0		0		0	
11/15/24 13:31	0		0		19.97		0		0		0	
11/15/24 13:32	0		0		21.63		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
11/15/24 13:18	0		0		0.1		0		0		0	
11/15/24 13:19	0		0		0.1		0		0		0	
11/15/24 13:20	0		0		0		0		0		0	
11/15/24 13:21	0		0		0		0		0		0	
11/15/24 13:22	0		0		0		0		0		0	
11/15/24 13:23	1530.7		0.4		0		0		0		1	
11/15/24 13:24	19795		0.4		0		0		0		1	
11/15/24 13:25	34691.8		1174.1		17.7		96.19		2.39		1	
11/15/24 13:26	47676.7		527.8		11.8		59.31		2.18		1	
11/15/24 13:27	28470.9		165.9		12.89		11.14		1.42		1	
11/15/24 13:28	0		0		13.91		0		0		0	
11/15/24 13:29	0		0		12.63		0		0		0	
11/15/24 13:30	0		0		17.25		0		0		0	
11/15/24 13:31	0		0		19.97		0		0		0	
11/15/24 13:32	0		0		21.63		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
11/15/24 13:42	0		0		0.4		0		0		0	
11/15/24 13:43	0		0		0.3		0		0		0	
11/15/24 13:44	0		0		0.2		0		0		0	
11/15/24 13:45	0		0		0.1		0		0		0	
11/15/24 13:46	0		0		0.1		0		0		0	
11/15/24 13:47	8612.3		0.3		0.1		0		0		1	
11/15/24 13:48	22238.4		0.5		0.1		0		0		1	
11/15/24 13:49	36800.2		1476.5		28.03		128.24		4.01		1	
11/15/24 13:50	49946.8		1087.2		18.09		128.01		3.51		1	
11/15/24 13:51	61834.2		629.7		22.36		91.91		5.37		1	
11/15/24 13:52	74045.1		284		27.89		49.59		8.01		1	
11/15/24 13:53	87717.3		94.2		31.32		19.48		10.66		1	
11/15/24 13:54	104012		33.5		37.72		8.22		15.23		1	
11/15/24 13:55	147131.3		15.9		43.46		5.53		24.82		1	
11/15/24 13:56	211091.2		5.9		58.82		2.94		48.19		1	
11/15/24 13:57	260564.3		2.2		86.49		1.33		87.49		1	
11/15/24 13:58	241075.4		15.9		96.12		9.02		89.94		1	
11/15/24 13:59	234548.3		1.9		91.12		1.03		82.98		1	
11/15/24 14:00	254106.5		2.9		92.78		1.73		91.53		1	
11/15/24 14:01	279435.1		2.4		101.97		1.61		110.63		1	
11/15/24 14:02	306571.7		1.6		95.38		1.19		113.53		1	
11/15/24 14:03	334257		1.1		85.11		0.86		110.43		1	
11/15/24 14:04	368434.8		1		69.27		0.85		99.06		1	
11/15/24 14:05	0		5.9		41.75		0		0		1	
11/15/24 14:06	0		0		63.72		0		0		0	
11/15/24 14:07	0		0		153.4		0		0		0	
11/15/24 14:08	0		0		129.8		0		0		0	
11/15/24 14:09	0		0		106.2		0		0		0	
11/15/24 14:10	0		0		1.7		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
11/15/24 13:42	0		0		0.4		0		0		0	
11/15/24 13:43	0		0		0.3		0		0		0	
11/15/24 13:44	0		0		0.2		0		0		0	
11/15/24 13:45	0		0		0.1		0		0		0	
11/15/24 13:46	0		0		0.1		0		0		0	
11/15/24 13:47	8612.3		0.3		0.1		0		0		1	
11/15/24 13:48	22238.4		0.5		0.1		0		0		1	
11/15/24 13:49	36800.2		1476.5		28.03		128.24		4.01		1	
11/15/24 13:50	49946.8		1087.2		18.09		128.01		3.51		1	
11/15/24 13:51	61834.2		629.7		22.36		91.91		5.37		1	
11/15/24 13:52	74045.1		284		27.89		49.59		8.01		1	
11/15/24 13:53	87717.3		94.2		31.32		19.48		10.66		1	
11/15/24 13:54	104012		33.5		37.72		8.22		15.23		1	
11/15/24 13:55	147131.3		15.9		43.46		5.53		24.82		1	
11/15/24 13:56	211091.2		5.9		58.82		2.94		48.19		1	
11/15/24 13:57	260564.3		2.2		86.49		1.33		87.49		1	
11/15/24 13:58	241075.4		15.9		96.12		9.02		89.94		1	
11/15/24 13:59	234548.3		1.9		91.12		1.03		82.98		1	
11/15/24 14:00	254106.5		2.9		92.78		1.73		91.53		1	
11/15/24 14:01	279435.1		2.4		101.97		1.61		110.63		1	
11/15/24 14:02	306571.7		1.6		95.38		1.19		113.53		1	
11/15/24 14:03	334257		1.1		85.11		0.86		110.43		1	
11/15/24 14:04	368434.8		1		69.27		0.85		99.06		1	
11/15/24 14:05	0		5.9		41.75		0		0		1	
11/15/24 14:06	0		0		63.72		0		0		0	
11/15/24 14:07	0		0		153.4		0		0		0	
11/15/24 14:08	0		0		129.8		0		0		0	
11/15/24 14:09	0		0		106.2		0		0		0	
11/15/24 14:10	0		0		1.7		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
11/15/24 13:42	0		0		0.4		0		0		0	
11/15/24 13:43	0		0		0.3		0		0		0	
11/15/24 13:44	0		0		0.2		0		0		0	
11/15/24 13:45	0		0		0.1		0		0		0	
11/15/24 13:46	0		0		0.1		0		0		0	
11/15/24 13:47	8612.3		0.3		0.1		0		0		1	
11/15/24 13:48	22238.4		0.5		0.1		0		0		1	
11/15/24 13:49	36800.2		1476.5		28.03		128.24		4.01		1	
11/15/24 13:50	49946.8		1087.2		18.09		128.01		3.51		1	
11/15/24 13:51	61834.2		629.7		22.36		91.91		5.37		1	
11/15/24 13:52	74045.1		284		27.89		49.59		8.01		1	
11/15/24 13:53	87717.3		94.2		31.32		19.48		10.66		1	
11/15/24 13:54	104012		33.5		37.72		8.22		15.23		1	
11/15/24 13:55	147131.3		15.9		43.46		5.53		24.82		1	
11/15/24 13:56	211091.2		5.9		58.82		2.94		48.19		1	
11/15/24 13:57	260564.3		2.2		86.49		1.33		87.49		1	
11/15/24 13:58	241075.4		15.9		96.12		9.02		89.94		1	
11/15/24 13:59	234548.3		1.9		91.12		1.03		82.98		1	
11/15/24 14:00	254106.5		2.9		92.78		1.73		91.53		1	
11/15/24 14:01	279435.1		2.4		101.97		1.61		110.63		1	
11/15/24 14:02	306571.7		1.6		95.38		1.19		113.53		1	
11/15/24 14:03	334257		1.1		85.11		0.86		110.43		1	
11/15/24 14:04	368434.8		1		69.27		0.85		99.06		1	
11/15/24 14:05	0		5.9		41.75		0		0		1	
11/15/24 14:06	0		0		63.72		0		0		0	
11/15/24 14:07	0		0		153.4		0		0		0	
11/15/24 14:08	0		0		129.8		0		0		0	
11/15/24 14:09	0		0		106.2		0		0		0	
11/15/24 14:10	0		0		1.7		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
11/15/24 14:51	0		0		0.5		0		0		0	
11/15/24 14:52	0		0		0.2		0		0		0	
11/15/24 14:53	0		0		0.2		0		0		0	
11/15/24 14:54	0		0		0.2		0		0		0	
11/15/24 14:55	0		0		0.2		0		0		0	
11/15/24 14:56	1126.4		0.2		0.2		0		0		1	
11/15/24 14:57	13556.7		0.2		0.1		0		0		1	
11/15/24 14:58	31318.5		1398.3		64.9		103.29		7.89		1	
11/15/24 14:59	44915.7		1005.3		17.7		106.44		3.08		1	
11/15/24 15:00	56982.2		654.2		20.98		87.87		4.64		1	
11/15/24 15:01	69210.4		265.8		26.69		43.37		7.17		1	
11/15/24 15:02	82195.3		77.9		30.24		15.11		9.65		1	
11/15/24 15:03	96595.4		28		33.65		6.37		12.62		1	
11/15/24 15:04	130778.9		16.1		37.23		4.96		18.9		1	
11/15/24 15:05	199082.4		7		49.29		3.31		38.1		1	
11/15/24 15:06	206296.9		2.1		72.77		1.03		58.28		1	
11/15/24 15:07	230031.3		37.3		71.6		20.23		63.94		1	
11/15/24 15:08	260541.2		14.9		77.2		9.18		78.07		1	
11/15/24 15:09	285211.3		1.1		85.38		0.75		94.52		1	
11/15/24 15:10	314115.4		0.8		78.42		0.56		95.62		1	
11/15/24 15:11	341078.7		0.8		71.23		0.6		94.31		1	
11/15/24 15:12	249595.3		0.7		59.66		0.39		57.8		1	
11/15/24 15:13	0		0		32.61		0		0		0	
11/15/24 15:14	0		0		76.7		0		0		0	
11/15/24 15:15	0		0		1.1		0		0		0	
11/15/24 15:16	0		0		1		0		0		0	
11/15/24 15:17	0		0		0.8		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
11/15/24 14:51	0		0		0.5		0		0		0	
11/15/24 14:52	0		0		0.2		0		0		0	
11/15/24 14:53	0		0		0.2		0		0		0	
11/15/24 14:54	0		0		0.2		0		0		0	
11/15/24 14:55	0		0		0.2		0		0		0	
11/15/24 14:56	1126.4		0.2		0.2		0		0		1	
11/15/24 14:57	13556.7		0.2		0.1		0		0		1	
11/15/24 14:58	31318.5		1398.3		64.9		103.29		7.89		1	
11/15/24 14:59	44915.7		1005.3		17.7		106.44		3.08		1	
11/15/24 15:00	56982.2		654.2		20.98		87.87		4.64		1	
11/15/24 15:01	69210.4		265.8		26.69		43.37		7.17		1	
11/15/24 15:02	82195.3		77.9		30.24		15.11		9.65		1	
11/15/24 15:03	96595.4		28		33.65		6.37		12.62		1	
11/15/24 15:04	130778.9		16.1		37.23		4.96		18.9		1	
11/15/24 15:05	199082.4		7		49.29		3.31		38.1		1	
11/15/24 15:06	206296.9		2.1		72.77		1.03		58.28		1	
11/15/24 15:07	230031.3		37.3		71.6		20.23		63.94		1	
11/15/24 15:08	260541.2		14.9		77.2		9.18		78.07		1	
11/15/24 15:09	285211.3		1.1		85.38		0.75		94.52		1	
11/15/24 15:10	314115.4		0.8		78.42		0.56		95.62		1	
11/15/24 15:11	341078.7		0.8		71.23		0.6		94.31		1	
11/15/24 15:12	249595.3		0.7		59.66		0.39		57.8		1	
11/15/24 15:13	0		0		32.61		0		0		0	
11/15/24 15:14	0		0		76.7		0		0		0	
11/15/24 15:15	0		0		1.1		0		0		0	
11/15/24 15:16	0		0		1		0		0		0	
11/15/24 15:17	0		0		0.8		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 15:29	0			0			0.2			0			0			0		
11/15/24 15:30	0			0			0.2			0			0			0		
11/15/24 15:31	0			0			0.2			0			0			0		
11/15/24 15:32	0			0			0.2			0			0			0		
11/15/24 15:33	2899.7			0			0.1			0			0			0		
11/15/24 15:34	5868.6			0.2			0.1			0			0			1		
11/15/24 15:35	23122.1			0.5			0.2			0			0			1		
11/15/24 15:36	38556.1			355.3			24.91			32.29			3.73			1		
11/15/24 15:37	51818.3			355.1			20.65			43.4			4.15			1		
11/15/24 15:38	63561.3			126			26.26			18.89			6.48			1		
11/15/24 15:39	76049.4			50.5			30.27			9.06			8.93			1		
11/15/24 15:40	89259.6			25.5			35.64			5.37			12.35			1		
11/15/24 15:41	109684.2			11.2			38.98			2.89			16.6			1		
11/15/24 15:42	170796.4			6.1			46.61			2.46			30.91			1		
11/15/24 15:43	206707			4.2			67.26			2.05			53.97			1		
11/15/24 15:44	247902.9			12.1			83.42			7.06			80.27			1		
11/15/24 15:45	293309.5			21.7			93.4			15.03			106.35			1		
11/15/24 15:46	323218.7			1			91.45			0.75			114.75			1		
11/15/24 15:47	353070.1			0.8			80.78			0.63			110.73			1		
11/15/24 15:48	225254.4			0.8			63.01			0.41			55.1			1		
11/15/24 15:49	0			0			31.76			0			0			0		
11/15/24 15:50	0			0			76.7			0			0			0		
11/15/24 15:51	0			0			1			0			0			0		
11/15/24 15:52	0			0			0.9			0			0			0		
11/15/24 15:53	0			0			0.8			0			0			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 15:29	0			0			0.2			0			0			0		
11/15/24 15:30	0			0			0.2			0			0			0		
11/15/24 15:31	0			0			0.2			0			0			0		
11/15/24 15:32	0			0			0.2			0			0			0		
11/15/24 15:33	2899.7			0			0.1			0			0			0		
11/15/24 15:34	5868.6			0.2			0.1			0			0			1		
11/15/24 15:35	23122.1			0.5			0.2			0			0			1		
11/15/24 15:36	38556.1			355.3			24.91			32.29			3.73			1		
11/15/24 15:37	51818.3			355.1			20.65			43.4			4.15			1		
11/15/24 15:38	63561.3			126			26.26			18.89			6.48			1		
11/15/24 15:39	76049.4			50.5			30.27			9.06			8.93			1		
11/15/24 15:40	89259.6			25.5			35.64			5.37			12.35			1		
11/15/24 15:41	109684.2			11.2			38.98			2.89			16.6			1		
11/15/24 15:42	170796.4			6.1			46.61			2.46			30.91			1		
11/15/24 15:43	206707			4.2			67.26			2.05			53.97			1		
11/15/24 15:44	247902.9			12.1			83.42			7.06			80.27			1		
11/15/24 15:45	293309.5			21.7			93.4			15.03			106.35			1		
11/15/24 15:46	323218.7			1			91.45			0.75			114.75			1		
11/15/24 15:47	353070.1			0.8			80.78			0.63			110.73			1		
11/15/24 15:48	225254.4			0.8			63.01			0.41			55.1			1		
11/15/24 15:49	0			0			31.76			0			0			0		
11/15/24 15:50	0			0			76.7			0			0			0		
11/15/24 15:51	0			0			1			0			0			0		
11/15/24 15:52	0			0			0.9			0			0			0		
11/15/24 15:53	0			0			0.8			0			0			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 20:49	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:50	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:51	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:52	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:53	9444.1			0	X		0	X		0	X		0	X		0		
11/15/24 20:54	10784.2			0.2	X		0	X		0	X		0	X		0		1
11/15/24 20:55	28187.8			7.4	X		0.4	X		0	X		0	X		0		1
11/15/24 20:56	42368.4			1306.3	X		27.14	X		130.41	X		4.46	X		0		1
11/15/24 20:57	54094.1			928.7	X		23.95	X		118.5	X		5.03	X		0		1
11/15/24 20:58	65877.5			488.2	X		30.68	X		75.85	X		7.84	X		0		1
11/15/24 20:59	78914.4			190.8	X		26.06	X		35.53	X		7.99	X		0		1
11/15/24 21:00	92448.1			66.9	X		24.05	X		14.6	X		8.63	X		0		1
11/15/24 21:01	114755.7			29.5	X		22.34	X		7.98	X		9.95	X		0		1
11/15/24 21:02	178421			16.5	X		20.85	X		6.95	X		14.44	X		0		1
11/15/24 21:03	210028.4			5.6	X		17.87	X		2.76	X		14.57	X		0		1
11/15/24 21:04	217323.7			26.2	X		14.54	X		13.43	X		12.27	X		0		1
11/15/24 21:05	223723.7			56.4	X		13.9	X		29.75	X		12.07	X		0		1
11/15/24 21:06	220107.8			15.9	X		13.31	X		8.28	X		11.37	X		0		1
11/15/24 21:07	219432			21.2	X		13.31	X		10.98	X		11.33	X		0		1
11/15/24 21:08	219073.9			19.8	X		13.31	X		10.25	X		11.31	X		0		1
11/15/24 21:09	217733.8			19.1	X		13.31	X		9.8	X		11.25	X		0		1
11/15/24 21:10	218091.9			18.5	X		13.31	X		9.49	X		11.26	X		0		1
11/15/24 21:11	216769.2			18.3	X		13.31	X		9.37	X		11.2	X		0		1
11/15/24 21:12	217294.8			18.3	X		13.31	X		9.39	X		11.23	X		0		1
11/15/24 21:13	216185.8			18.9	X		13.6	X		9.61	X		11.41	X		0		1
11/15/24 21:14	220766.3			19.1	X		13.6	X		9.95	X		11.65	X		0		1
11/15/24 21:15	227137.4			13.7	X		13.31	X		7.33	X		11.74	X		0		1
11/15/24 21:16	233629.9			7.4	X		13.03	X		4.06	X		11.82	X		0		1
11/15/24 21:17	242871.8			4.8	X		12.51	X		2.77	X		11.79	X		0		1
11/15/24 21:18	246089.1			3.2	X		12.26	X		1.88	X		11.71	X		0		1
11/15/24 21:19	253852.4			1.9	X		12.03	X		1.15	X		11.85	X		0		1
11/15/24 21:20	260604.7			1.4	X		12.03	X		0.84	X		12.17	X		0		1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 21:21	265953.5			1.4	X		12.03	X		0.85	X		12.41	X		1		
11/15/24 21:22	273624.3			1.2	X		12.03	X		0.81	X		12.77	X		1		
11/15/24 21:23	280815.6			1	X		11.8	X		0.66	X		12.86	X		1		
11/15/24 21:24	284391.1			0.9	X		11.8	X		0.6	X		13.03	X		1		
11/15/24 21:25	290381			0.8	X		11.8	X		0.53	X		13.3	X		1		
11/15/24 21:26	293615.7			0.7	X		11.8	X		0.46	X		13.45	X		1		
11/15/24 21:27	300957.2			0.6	X		11.8	X		0.4	X		13.78	X		1		
11/15/24 21:28	302632.4			0.5	X		11.58	X		0.39	X		13.61	X		1		
11/15/24 21:29	310511			0.5	X		11.58	X		0.4	X		13.96	X		1		
11/15/24 21:30	315374.6			0.6	X		11.8	X		0.41	X		14.45	X		1		
11/15/24 21:31	322150.1			0.6	X		11.8	X		0.42	X		14.76	X		1		
11/15/24 21:32	321953.8			0.6	X		11.8	X		0.42	X		14.75	X		1		
11/15/24 21:33	327244.7			0.6	X		11.8	X		0.43	X		14.99	X		1		
11/15/24 21:34	329584.1			0.4	X		11.8	X		0.35	X		15.1	X		1		
11/15/24 21:35	336382.7			0.6	X		12.03	X		0.45	X		15.71	X		1		
11/15/24 21:36	350372.6			0.6	X		12.03	X		0.47	X		16.36	X		1		
11/15/24 21:37	335140.8			0.6	X		12.03	X		0.45	X		15.65	X		1		
11/15/24 21:38	0			5.5	X		29.38	X		0	X		0	X		1		
11/15/24 21:39	0			0	X		45.23	X		0	X		0	X		0		
11/15/24 21:40	0			0	X		1	X		0	X		0	X		0		
11/15/24 21:41	0			0	X		0.9	X		0	X		0	X		0		
11/15/24 21:42	0			0	X		0.8	X		0	X		0	X		0		
11/15/24 21:43	0			0	X		0.6	X		0	X		0	X		0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 20:49	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:50	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:51	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:52	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:53	9444.1			0	X		0	X		0	X		0	X		0		
11/15/24 20:54	10784.2			0.2	X		0	X		0	X		0	X		0		1
11/15/24 20:55	28187.8			7.4	X		0.4	X		0	X		0	X		0		1
11/15/24 20:56	42368.4			1306.3	X		27.14	X		130.41	X		4.46	X		0		1
11/15/24 20:57	54094.1			928.7	X		23.95	X		118.5	X		5.03	X		0		1
11/15/24 20:58	65877.5			488.2	X		30.68	X		75.85	X		7.84	X		0		1
11/15/24 20:59	78914.4			190.8	X		26.06	X		35.53	X		7.99	X		0		1
11/15/24 21:00	92448.1			66.9	X		24.05	X		14.6	X		8.63	X		0		1
11/15/24 21:01	114755.7			29.5	X		22.34	X		7.98	X		9.95	X		0		1
11/15/24 21:02	178421			16.5	X		20.85	X		6.95	X		14.44	X		0		1
11/15/24 21:03	210028.4			5.6	X		17.87	X		2.76	X		14.57	X		0		1
11/15/24 21:04	217323.7			26.2	X		14.54	X		13.43	X		12.27	X		0		1
11/15/24 21:05	223723.7			56.4	X		13.9	X		29.75	X		12.07	X		0		1
11/15/24 21:06	220107.8			15.9	X		13.31	X		8.28	X		11.37	X		0		1
11/15/24 21:07	219432			21.2	X		13.31	X		10.98	X		11.33	X		0		1
11/15/24 21:08	219073.9			19.8	X		13.31	X		10.25	X		11.31	X		0		1
11/15/24 21:09	217733.8			19.1	X		13.31	X		9.8	X		11.25	X		0		1
11/15/24 21:10	218091.9			18.5	X		13.31	X		9.49	X		11.26	X		0		1
11/15/24 21:11	216769.2			18.3	X		13.31	X		9.37	X		11.2	X		0		1
11/15/24 21:12	217294.8			18.3	X		13.31	X		9.39	X		11.23	X		0		1
11/15/24 21:13	216185.8			18.9	X		13.6	X		9.61	X		11.41	X		0		1
11/15/24 21:14	220766.3			19.1	X		13.6	X		9.95	X		11.65	X		0		1
11/15/24 21:15	227137.4			13.7	X		13.31	X		7.33	X		11.74	X		0		1
11/15/24 21:16	233629.9			7.4	X		13.03	X		4.06	X		11.82	X		0		1
11/15/24 21:17	242871.8			4.8	X		12.51	X		2.77	X		11.79	X		0		1
11/15/24 21:18	246089.1			3.2	X		12.26	X		1.88	X		11.71	X		0		1
11/15/24 21:19	253852.4			1.9	X		12.03	X		1.15	X		11.85	X		0		1
11/15/24 21:20	260604.7			1.4	X		12.03	X		0.84	X		12.17	X		0		1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 21:21	265953.5			1.4	X		12.03	X		0.85	X		12.41	X		1		
11/15/24 21:22	273624.3			1.2	X		12.03	X		0.81	X		12.77	X		1		
11/15/24 21:23	280815.6			1	X		11.8	X		0.66	X		12.86	X		1		
11/15/24 21:24	284391.1			0.9	X		11.8	X		0.6	X		13.03	X		1		
11/15/24 21:25	290381			0.8	X		11.8	X		0.53	X		13.3	X		1		
11/15/24 21:26	293615.7			0.7	X		11.8	X		0.46	X		13.45	X		1		
11/15/24 21:27	300957.2			0.6	X		11.8	X		0.4	X		13.78	X		1		
11/15/24 21:28	302632.4			0.5	X		11.58	X		0.39	X		13.61	X		1		
11/15/24 21:29	310511			0.5	X		11.58	X		0.4	X		13.96	X		1		
11/15/24 21:30	315374.6			0.6	X		11.8	X		0.41	X		14.45	X		1		
11/15/24 21:31	322150.1			0.6	X		11.8	X		0.42	X		14.76	X		1		
11/15/24 21:32	321953.8			0.6	X		11.8	X		0.42	X		14.75	X		1		
11/15/24 21:33	327244.7			0.6	X		11.8	X		0.43	X		14.99	X		1		
11/15/24 21:34	329584.1			0.4	X		11.8	X		0.35	X		15.1	X		1		
11/15/24 21:35	336382.7			0.6	X		12.03	X		0.45	X		15.71	X		1		
11/15/24 21:36	350372.6			0.6	X		12.03	X		0.47	X		16.36	X		1		
11/15/24 21:37	335140.8			0.6	X		12.03	X		0.45	X		15.65	X		1		
11/15/24 21:38	0			5.5	X		29.38	X		0	X		0	X		1		
11/15/24 21:39	0			0	X		45.23	X		0	X		0	X		0		
11/15/24 21:40	0			0	X		1	X		0	X		0	X		0		
11/15/24 21:41	0			0	X		0.9	X		0	X		0	X		0		
11/15/24 21:42	0			0	X		0.8	X		0	X		0	X		0		
11/15/24 21:43	0			0	X		0.6	X		0	X		0	X		0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 20:49	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:50	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:51	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:52	0			0	X		0	X		0	X		0	X		0		
11/15/24 20:53	9444.1			0	X		0	X		0	X		0	X		0		
11/15/24 20:54	10784.2			0.2	X		0	X		0	X		0	X		0		1
11/15/24 20:55	28187.8			7.4	X		0.4	X		0	X		0	X		0		1
11/15/24 20:56	42368.4			1306.3	X		27.14	X		130.41	X		4.46	X		0		1
11/15/24 20:57	54094.1			928.7	X		23.95	X		118.5	X		5.03	X		0		1
11/15/24 20:58	65877.5			488.2	X		30.68	X		75.85	X		7.84	X		0		1
11/15/24 20:59	78914.4			190.8	X		26.06	X		35.53	X		7.99	X		0		1
11/15/24 21:00	92448.1			66.9	X		24.05	X		14.6	X		8.63	X		0		1
11/15/24 21:01	114755.7			29.5	X		22.34	X		7.98	X		9.95	X		0		1
11/15/24 21:02	178421			16.5	X		20.85	X		6.95	X		14.44	X		0		1
11/15/24 21:03	210028.4			5.6	X		17.87	X		2.76	X		14.57	X		0		1
11/15/24 21:04	217323.7			26.2	X		14.54	X		13.43	X		12.27	X		0		1
11/15/24 21:05	223723.7			56.4	X		13.9	X		29.75	X		12.07	X		0		1
11/15/24 21:06	220107.8			15.9	X		13.31	X		8.28	X		11.37	X		0		1
11/15/24 21:07	219432			21.2	X		13.31	X		10.98	X		11.33	X		0		1
11/15/24 21:08	219073.9			19.8	X		13.31	X		10.25	X		11.31	X		0		1
11/15/24 21:09	217733.8			19.1	X		13.31	X		9.8	X		11.25	X		0		1
11/15/24 21:10	218091.9			18.5	X		13.31	X		9.49	X		11.26	X		0		1
11/15/24 21:11	216769.2			18.3	X		13.31	X		9.37	X		11.2	X		0		1
11/15/24 21:12	217294.8			18.3	X		13.31	X		9.39	X		11.23	X		0		1
11/15/24 21:13	216185.8			18.9	X		13.6	X		9.61	X		11.41	X		0		1
11/15/24 21:14	220766.3			19.1	X		13.6	X		9.95	X		11.65	X		0		1
11/15/24 21:15	227137.4			13.7	X		13.31	X		7.33	X		11.74	X		0		1
11/15/24 21:16	233629.9			7.4	X		13.03	X		4.06	X		11.82	X		0		1
11/15/24 21:17	242871.8			4.8	X		12.51	X		2.77	X		11.79	X		0		1
11/15/24 21:18	246089.1			3.2	X		12.26	X		1.88	X		11.71	X		0		1
11/15/24 21:19	253852.4			1.9	X		12.03	X		1.15	X		11.85	X		0		1
11/15/24 21:20	260604.7			1.4	X		12.03	X		0.84	X		12.17	X		0		1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/24 21:21	265953.5			1.4	X		12.03	X		0.85	X		12.41	X		1		
11/15/24 21:22	273624.3			1.2	X		12.03	X		0.81	X		12.77	X		1		
11/15/24 21:23	280815.6			1	X		11.8	X		0.66	X		12.86	X		1		
11/15/24 21:24	284391.1			0.9	X		11.8	X		0.6	X		13.03	X		1		
11/15/24 21:25	290381			0.8	X		11.8	X		0.53	X		13.3	X		1		
11/15/24 21:26	293615.7			0.7	X		11.8	X		0.46	X		13.45	X		1		
11/15/24 21:27	300957.2			0.6	X		11.8	X		0.4	X		13.78	X		1		
11/15/24 21:28	302632.4			0.5	X		11.58	X		0.39	X		13.61	X		1		
11/15/24 21:29	310511			0.5	X		11.58	X		0.4	X		13.96	X		1		
11/15/24 21:30	315374.6			0.6	X		11.8	X		0.41	X		14.45	X		1		
11/15/24 21:31	322150.1			0.6	X		11.8	X		0.42	X		14.76	X		1		
11/15/24 21:32	321953.8			0.6	X		11.8	X		0.42	X		14.75	X		1		
11/15/24 21:33	327244.7			0.6	X		11.8	X		0.43	X		14.99	X		1		
11/15/24 21:34	329584.1			0.4	X		11.8	X		0.35	X		15.1	X		1		
11/15/24 21:35	336382.7			0.6	X		12.03	X		0.45	X		15.71	X		1		
11/15/24 21:36	350372.6			0.6	X		12.03	X		0.47	X		16.36	X		1		
11/15/24 21:37	335140.8			0.6	X		12.03	X		0.45	X		15.65	X		1		
11/15/24 21:38	0			5.5	X		29.38	X		0	X		0	X		1		
11/15/24 21:39	0			0	X		45.23	X		0	X		0	X		0		
11/15/24 21:40	0			0	X		1	X		0	X		0	X		0		
11/15/24 21:41	0			0	X		0.9	X		0	X		0	X		0		
11/15/24 21:42	0			0	X		0.8	X		0	X		0	X		0		
11/15/24 21:43	0			0	X		0.6	X		0	X		0	X		0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/16/24 8:28	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:29	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:30	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:31	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:32	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:33	1259.2			0.2	X		0	X		0	X		0	X		0		1
11/16/24 8:34	13360.3			0.2	X		0	X		0	X		0	X		0		1
11/16/24 8:35	31330.1			36	X		0.7	X		0	X		0	X		0		1
11/16/24 8:36	45216.1			1358	X		19.18	X		145	X		3.37	X		0		1
11/16/24 8:37	58703.5			879.4	X		21.86	X		121.86	X		4.99	X		0		1
11/16/24 8:38	70065.3			450.9	X		26.69	X		74.49	X		7.26	X		0		1
11/16/24 8:39	81271.1			213.2	X		27.19	X		40.85	X		8.57	X		0		1
11/16/24 8:40	96520.3			89	X		24.05	X		20.25	X		9.01	X		0		1
11/16/24 8:41	122166.6			42.2	X		23.16	X		12.15	X		10.98	X		0		1
11/16/24 8:42	190233.3			19.7	X		20.85	X		8.83	X		15.4	X		0		1
11/16/24 8:43	215752.5			6.6	X		17.37	X		3.34	X		14.55	X		0		1
11/16/24 8:44	222585.8			25.7	X		14.21	X		13.52	X		12.28	X		0		1
11/16/24 8:45	226236.3			36.3	X		13.9	X		19.38	X		12.21	X		0		1
11/16/24 8:46	222949.7			18.1	X		13.31	X		9.5	X		11.51	X		0		1
11/16/24 8:47	221112.8			21.2	X		13.31	X		11.06	X		11.42	X		0		1
11/16/24 8:48	220419.7			22.1	X		13.31	X		11.49	X		11.39	X		0		1
11/16/24 8:49	219033.4			25.1	X		13.6	X		12.99	X		11.56	X		0		1
11/16/24 8:50	221534.5			24.9	X		13.6	X		13	X		11.69	X		0		1
11/16/24 8:51	219547.5			21.4	X		13.6	X		11.09	X		11.59	X		0		1
11/16/24 8:52	218623.3			17.2	X		13.31	X		8.87	X		11.29	X		0		1
11/16/24 8:53	217889.8			21	X		13.6	X		10.81	X		11.5	X		0		1
11/16/24 8:54	232896.3			22.6	X		13.6	X		12.4	X		12.29	X		0		1
11/16/24 8:55	243628.5			9.3	X		13.31	X		5.34	X		12.58	X		0		1
11/16/24 8:56	246707.2			1.9	X		12.26	X		1.08	X		11.75	X		0		1
11/16/24 8:57	247539			1.7	X		12.03	X		0.99	X		11.56	X		0		1
11/16/24 8:58	245944.8			1.4	X		12.03	X		0.79	X		11.48	X		0		1
11/16/24 8:59	247510.1			1.3	X		12.26	X		0.74	X		11.78	X		0		1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/16/24 9:00	247631.4			1.4	X		12.26	X		0.81	X		11.79	X		1		
11/16/24 9:01	246285.5			1.5	X		12.26	X		0.87	X		11.72	X		1		
11/16/24 9:02	258721.7			1.5	X		12.26	X		0.92	X		12.31	X		1		
11/16/24 9:03	282277			1.5	X		12.26	X		1	X		13.44	X		1		
11/16/24 9:04	290704.5			1.4	X		12.03	X		0.93	X		13.57	X		1		
11/16/24 9:05	295406.3			1	X		11.8	X		0.7	X		13.53	X		1		
11/16/24 9:06	312324.8			0.8	X		11.8	X		0.57	X		14.31	X		1		
11/16/24 9:07	327354.5			0.7	X		11.8	X		0.52	X		14.99	X		1		
11/16/24 9:08	333176.9			0.7	X		12.03	X		0.54	X		15.56	X		1		
11/16/24 9:09	333881.5			0.7	X		12.03	X		0.54	X		15.59	X		1		
11/16/24 9:10	335868.6			0.6	X		12.03	X		0.45	X		15.68	X		1		
11/16/24 9:11	335152.3			0.6	X		11.8	X		0.44	X		15.35	X		1		
11/16/24 9:12	335522			0.6	X		11.8	X		0.44	X		15.37	X		1		
11/16/24 9:13	333558.1			0.6	X		11.8	X		0.44	X		15.28	X		1		
11/16/24 9:14	334955.9			0.4	X		11.8	X		0.35	X		15.35	X		1		
11/16/24 9:15	335706.8			0.4	X		11.8	X		0.35	X		15.38	X		1		
11/16/24 9:16	339680.9			0.5	X		12.03	X		0.36	X		15.86	X		1		
11/16/24 9:17	342771.1			0.4	X		11.8	X		0.36	X		15.7	X		1		
11/16/24 9:18	342245.5			0.5	X		12.03	X		0.37	X		15.98	X		1		
11/16/24 9:19	344729.3			0.6	X		12.03	X		0.46	X		16.1	X		1		
11/16/24 9:20	344781.3			0.6	X		12.03	X		0.46	X		16.1	X		1		
11/16/24 9:21	345526.4			0.6	X		11.8	X		0.45	X		15.83	X		1		
11/16/24 9:22	356039			0.5	X		12.03	X		0.38	X		16.62	X		1		
11/16/24 9:23	379675.3			0.5	X		12.26	X		0.41	X		18.07	X		1		
11/16/24 9:24	386346.8			0.5	X		12.51	X		0.43	X		18.76	X		1		
11/16/24 9:25	317823.8			0.5	X		12.51	X		0.35	X		15.43	X		1		
11/16/24 9:26	0			0	X		30.84	X		0	X		0	X		0		
11/16/24 9:27	0			0	X		76.7	X		0	X		0	X		0		
11/16/24 9:28	0			0	X		0.5	X		0	X		0	X		0		
11/16/24 9:29	0			0	X		0.5	X		0	X		0	X		0		
11/16/24 9:30	0			0	X		0.4	X		0	X		0	X		0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/16/24 8:28	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:29	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:30	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:31	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:32	0			0	X		0	X		0	X		0	X		0		
11/16/24 8:33	1259.2			0.2	X		0	X		0	X		0	X		1		
11/16/24 8:34	13360.3			0.2	X		0	X		0	X		0	X		1		
11/16/24 8:35	31330.1			36	X		0.7	X		0	X		0	X		1		
11/16/24 8:36	45216.1			1358	X		19.18	X		145	X		3.37	X		1		
11/16/24 8:37	58703.5			879.4	X		21.86	X		121.86	X		4.99	X		1		
11/16/24 8:38	70065.3			450.9	X		26.69	X		74.49	X		7.26	X		1		
11/16/24 8:39	81271.1			213.2	X		27.19	X		40.85	X		8.57	X		1		
11/16/24 8:40	96520.3			89	X		24.05	X		20.25	X		9.01	X		1		
11/16/24 8:41	122166.6			42.2	X		23.16	X		12.15	X		10.98	X		1		
11/16/24 8:42	190233.3			19.7	X		20.85	X		8.83	X		15.4	X		1		
11/16/24 8:43	215752.5			6.6	X		17.37	X		3.34	X		14.55	X		1		
11/16/24 8:44	222585.8			25.7	X		14.21	X		13.52	X		12.28	X		1		
11/16/24 8:45	226236.3			36.3	X		13.9	X		19.38	X		12.21	X		1		
11/16/24 8:46	222949.7			18.1	X		13.31	X		9.5	X		11.51	X		1		
11/16/24 8:47	221112.8			21.2	X		13.31	X		11.06	X		11.42	X		1		
11/16/24 8:48	220419.7			22.1	X		13.31	X		11.49	X		11.39	X		1		
11/16/24 8:49	219033.4			25.1	X		13.6	X		12.99	X		11.56	X		1		
11/16/24 8:50	221534.5			24.9	X		13.6	X		13	X		11.69	X		1		
11/16/24 8:51	219547.5			21.4	X		13.6	X		11.09	X		11.59	X		1		
11/16/24 8:52	218623.3			17.2	X		13.31	X		8.87	X		11.29	X		1		
11/16/24 8:53	217889.8			21	X		13.6	X		10.81	X		11.5	X		1		
11/16/24 8:54	232896.3			22.6	X		13.6	X		12.4	X		12.29	X		1		
11/16/24 8:55	243628.5			9.3	X		13.31	X		5.34	X		12.58	X		1		
11/16/24 8:56	246707.2			1.9	X		12.26	X		1.08	X		11.75	X		1		
11/16/24 8:57	247539			1.7	X		12.03	X		0.99	X		11.56	X		1		
11/16/24 8:58	245944.8			1.4	X		12.03	X		0.79	X		11.48	X		1		
11/16/24 8:59	247510.1			1.3	X		12.26	X		0.74	X		11.78	X		1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/16/24 9:00	247631.4			1.4	X		12.26	X		0.81	X		11.79	X		1		
11/16/24 9:01	246285.5			1.5	X		12.26	X		0.87	X		11.72	X		1		
11/16/24 9:02	258721.7			1.5	X		12.26	X		0.92	X		12.31	X		1		
11/16/24 9:03	282277			1.5	X		12.26	X		1	X		13.44	X		1		
11/16/24 9:04	290704.5			1.4	X		12.03	X		0.93	X		13.57	X		1		
11/16/24 9:05	295406.3			1	X		11.8	X		0.7	X		13.53	X		1		
11/16/24 9:06	312324.8			0.8	X		11.8	X		0.57	X		14.31	X		1		
11/16/24 9:07	327354.5			0.7	X		11.8	X		0.52	X		14.99	X		1		
11/16/24 9:08	333176.9			0.7	X		12.03	X		0.54	X		15.56	X		1		
11/16/24 9:09	333881.5			0.7	X		12.03	X		0.54	X		15.59	X		1		
11/16/24 9:10	335868.6			0.6	X		12.03	X		0.45	X		15.68	X		1		
11/16/24 9:11	335152.3			0.6	X		11.8	X		0.44	X		15.35	X		1		
11/16/24 9:12	335522			0.6	X		11.8	X		0.44	X		15.37	X		1		
11/16/24 9:13	333558.1			0.6	X		11.8	X		0.44	X		15.28	X		1		
11/16/24 9:14	334955.9			0.4	X		11.8	X		0.35	X		15.35	X		1		
11/16/24 9:15	335706.8			0.4	X		11.8	X		0.35	X		15.38	X		1		
11/16/24 9:16	339680.9			0.5	X		12.03	X		0.36	X		15.86	X		1		
11/16/24 9:17	342771.1			0.4	X		11.8	X		0.36	X		15.7	X		1		
11/16/24 9:18	342245.5			0.5	X		12.03	X		0.37	X		15.98	X		1		
11/16/24 9:19	344729.3			0.6	X		12.03	X		0.46	X		16.1	X		1		
11/16/24 9:20	344781.3			0.6	X		12.03	X		0.46	X		16.1	X		1		
11/16/24 9:21	345526.4			0.6	X		11.8	X		0.45	X		15.83	X		1		
11/16/24 9:22	356039			0.5	X		12.03	X		0.38	X		16.62	X		1		
11/16/24 9:23	379675.3			0.5	X		12.26	X		0.41	X		18.07	X		1		
11/16/24 9:24	386346.8			0.5	X		12.51	X		0.43	X		18.76	X		1		
11/16/24 9:25	317823.8			0.5	X		12.51	X		0.35	X		15.43	X		1		
11/16/24 9:26	0			0	X		30.84	X		0	X		0	X		0		
11/16/24 9:27	0			0	X		76.7	X		0	X		0	X		0		
11/16/24 9:28	0			0	X		0.5	X		0	X		0	X		0		
11/16/24 9:29	0			0	X		0.5	X		0	X		0	X		0		
11/16/24 9:30	0			0	X		0.4	X		0	X		0	X		0		

Monthly Summary By Day Report

Units CT1 and CT2

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 09:57 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2024	33.68	105.65	12.15	24.27	40.45
10/02/2024	27.69	119.29	13.50	26.98	44.96
10/03/2024	28.93	130.97	14.82	29.64	49.34
10/04/2024	28.99	105.22	12.20	24.43	40.69
10/05/2024	22.96	121.72	13.90	27.81	46.40
10/06/2024	23.03	157.18	17.41	34.81	58.01
10/07/2024	17.82	162.72	18.01	36.02	60.00
10/08/2024	32.29	124.50	14.14	28.27	47.13
10/09/2024	30.38	95.38	10.89	21.86	36.45
10/10/2024	32.57	96.56	11.23	22.52	37.58
10/11/2024	35.00	117.28	13.28	26.62	44.39
10/12/2024	32.14	98.01	11.22	22.50	37.56
10/13/2024	32.83	99.89	11.64	23.31	38.83
10/14/2024	33.67	103.96	12.07	24.16	40.26
10/15/2024	31.58	94.78	10.95	21.92	36.52
10/16/2024	31.59	95.94	10.95	21.92	36.52
10/17/2024	40.19	66.76	7.73	15.47	25.78
10/18/2024	15.33	45.02	5.45	10.89	18.12
10/19/2024	15.92	43.87	5.28	10.54	17.52
10/20/2024	16.34	44.17	5.29	10.52	17.49
10/21/2024	18.67	54.71	6.54	13.06	21.70
10/22/2024	25.25	65.94	7.74	15.41	25.68
10/23/2024	25.57	66.94	7.74	15.43	25.77
10/24/2024	25.95	63.25	7.35	14.67	24.48
10/25/2024	26.52	56.60	6.71	13.38	22.28
10/26/2024	17.59	44.06	5.28	10.56	17.52
10/27/2024	15.48	42.75	5.29	10.57	17.56
10/28/2024	82.18	69.10	6.63	13.33	22.20
10/29/2024	50.95	62.15	7.38	14.76	24.60
10/30/2024	31.31	67.39	7.47	14.90	24.89
10/31/2024	25.95	57.96	6.44	12.82	21.29
Monthly Avg/Sum:	908.35 sum	2,679.72 sum	306.68 sum	613.35 sum	1,021.97 sum
Daily Min:	15.33	42.75	5.28	10.52	17.49
Daily Max:	82.18	162.72	18.01	36.02	60.00
Oct 2024 - Oct 2024	908.35 sum	2,679.72 sum	306.68 sum	613.35 sum	1,021.97 sum
QTD:	908.35 sum	2,679.72 sum	306.68 sum	613.35 sum	1,021.97 sum
YTD 2024:	8,236.49 sum	21,342.81 sum	2,387.34 sum	4,776.83 sum	7,959.36 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 09:57 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2024	21.02	50.66	5.57	11.26	18.75
11/02/2024	20.43	51.73	5.52	11.28	18.72
11/03/2024	21.34	51.73	5.72	11.59	19.24
11/04/2024	22.19	54.41	6.03	12.14	20.20
11/05/2024	42.52	51.43	5.72	11.49	19.10
11/06/2024	106.31	67.55	6.31	12.57	21.01
11/07/2024	62.03	85.03	8.62	17.34	28.85
11/08/2024	74.98	96.10	10.26	20.58	34.30
11/09/2024	47.68	62.69	7.75	15.54	25.88
11/10/2024	27.90	60.26	7.02	13.97	23.35
11/11/2024	27.88	66.51	7.69	15.30	25.50
11/12/2024	28.43	61.56	7.09	14.24	23.80
11/13/2024	26.04	66.46	7.58	15.19	25.31
11/14/2024	22.13	63.33	7.28	14.55	24.31
11/15/2024	40.90	76.83	5.00	10.04	16.70
11/16/2024	2.13	0.00	0.14	0.28	0.45
11/17/2024	0.00	0.00	0.00	0.00	0.00
11/18/2024	0.00	0.00	0.00	0.00	0.00
11/19/2024	0.00	0.00	0.00	0.00	0.00
11/20/2024	119.95	19.76	0.35	0.70	1.17
11/21/2024	14.16	1.63	0.01	0.01	0.02
11/22/2024	82.30	74.80	7.07	14.18	23.59
11/23/2024	26.64	56.03	6.64	13.29	22.17
11/24/2024	30.20	58.76	6.85	13.79	22.98
11/25/2024	32.26	64.45	7.45	14.94	24.96
11/26/2024	31.19	65.12	7.44	14.91	24.85
11/27/2024	31.16	65.74	7.50	15.06	25.10
11/28/2024	33.38	65.56	7.47	14.95	24.88
11/29/2024	34.28	67.04	7.62	15.27	25.48
11/30/2024	33.88	66.92	7.64	15.26	25.45
Monthly Avg/Sum:	1,063.31 sum	1,572.09 sum	169.34 sum	339.72 sum	566.12 sum
Daily Min:	0.00	0.00	0.00	0.00	0.00
Daily Max:	119.95	96.10	10.26	20.58	34.30
Oct 2024 - Nov 2024	1,971.66 sum	4,251.81 sum	476.02 sum	953.07 sum	1,588.09 sum
QTD:	1,971.66 sum	4,251.81 sum	476.02 sum	953.07 sum	1,588.09 sum
YTD 2024:	9,299.80 sum	22,914.90 sum	2,556.68 sum	5,116.55 sum	8,525.48 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 09:57 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2024	32.72	60.85	7.10	14.23	23.71
12/02/2024	34.02	65.19	7.47	15.01	25.03
12/03/2024	34.05	59.77	7.10	14.20	23.69
12/04/2024	30.13	62.56	7.34	14.70	24.47
12/05/2024	32.60	62.47	7.54	15.09	25.12
12/06/2024	31.37	59.53	7.32	14.60	24.32
12/07/2024	26.72	53.99	6.53	13.01	21.68
12/08/2024	18.60	45.40	5.44	10.77	17.98
12/09/2024	22.14	57.49	6.75	13.48	22.49
12/10/2024	32.59	65.48	7.58	15.20	25.33
12/11/2024	31.30	67.65	7.67	15.34	25.58
12/12/2024	26.63	69.04	7.82	15.58	25.99
12/13/2024	29.55	66.24	7.53	15.03	25.01
12/14/2024	22.72	53.19	6.31	12.58	20.98
12/15/2024	21.34	49.12	5.95	11.97	19.90
12/16/2024	33.58	64.91	7.44	14.85	24.73
12/17/2024	32.65	65.58	7.48	14.98	24.96
12/18/2024	28.90	64.74	7.37	14.71	24.49
12/19/2024	29.34	62.07	7.06	14.15	23.50
12/20/2024	32.10	65.74	7.44	14.81	24.65
12/21/2024	31.04	64.40	7.33	14.64	24.43
12/22/2024	30.87	65.29	7.45	14.98	24.93
12/23/2024	27.77	60.09	6.96	13.94	23.28
12/24/2024	29.64	65.08	7.41	14.73	24.58
12/25/2024	17.84	47.41	5.70	11.50	19.11
12/26/2024	27.10	63.00	7.17	14.35	23.88
12/27/2024	23.56	58.54	6.79	13.56	22.60
12/28/2024	24.28	59.47	6.84	13.72	22.87
12/29/2024	23.39	57.96	6.70	13.42	22.43
12/30/2024	30.87	40.64	4.52	9.08	15.10
12/31/2024	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum:	849.41 sum	1,802.89 sum	209.11 sum	418.21 sum	696.82 sum
Daily Min:	0.00	0.00	0.00	0.00	0.00
Daily Max:	34.05	69.04	7.82	15.58	25.99
Oct 2024 - Dec 2024	2,821.07 sum	6,054.70 sum	685.13 sum	1,371.28 sum	2,284.91 sum
QTD:	2,821.07 sum	6,054.70 sum	685.13 sum	1,371.28 sum	2,284.91 sum
YTD 2024:	10,149.21 sum	24,717.79 sum	2,765.79 sum	5,534.76 sum	9,222.30 sum

Monthly Summary By Day Report



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/02/2025 09:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2024	0.0	0.0	0.0	0.0
10/02/2024	0.0	0.0	0.0	0.0
10/03/2024	0.0	0.0	0.0	0.0
10/04/2024	0.0	0.0	0.0	0.0
10/05/2024	0.0	0.0	0.0	0.0
10/06/2024	0.0	0.0	0.0	0.0
10/07/2024	0.0	0.0	0.0	0.0
10/08/2024	0.0	0.0	0.0	0.0
10/09/2024	0.0	0.0	0.0	0.0
10/10/2024	0.0	0.0	0.0	0.0
10/11/2024	0.0	0.0	0.0	0.0
10/12/2024	0.0	0.0	0.0	0.0
10/13/2024	0.0	0.0	0.0	0.0
10/14/2024	0.0	0.0	0.0	0.0
10/15/2024	0.0	0.0	0.0	0.0
10/16/2024	0.0	0.0	0.0	0.0
10/17/2024	0.0	0.0	12.0	2.0
10/18/2024	0.0	0.0	0.0	0.0
10/19/2024	0.0	0.0	0.0	0.0
10/20/2024	0.0	0.0	0.0	0.0
10/21/2024	0.0	0.0	0.0	0.0
10/22/2024	0.0	0.0	0.0	0.0
10/23/2024	0.0	0.0	0.0	0.0
10/24/2024	0.0	0.0	0.0	0.0
10/25/2024	0.0	0.0	0.0	0.0
10/26/2024	0.0	0.0	0.0	0.0
10/27/2024	0.0	0.0	0.0	0.0
10/28/2024	0.0	0.0	55.8	15.2
10/29/2024	10.2	1.1	0.0	0.0
10/30/2024	0.0	0.0	0.0	0.0
10/31/2024	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	10.2 sum	1.1 sum	67.8 sum	17.2 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	10.2	1.1	55.8	15.2
Oct 2024 - Oct 2024	10.2 sum	1.1 sum	67.8 sum	17.2 sum
QTD:	10.2 sum	1.1 sum	67.8 sum	17.2 sum
YTD 2024:	1,026.4 sum	137.6 sum	728.8 sum	240.9 sum

Monthly Summary By Day Report



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/02/2025 09:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2024	0.0	0.0	0.0	0.0
11/02/2024	0.0	0.0	0.0	0.0
11/03/2024	0.0	0.0	0.0	0.0
11/04/2024	0.0	0.0	0.0	0.0
11/05/2024	0.0	0.0	20.4	5.6
11/06/2024	60.5	13.7	10.6	1.9
11/07/2024	0.0	0.0	33.8	13.5
11/08/2024	0.0	0.0	38.1	11.2
11/09/2024	0.0	0.0	11.6	1.4
11/10/2024	0.0	0.0	0.0	0.0
11/11/2024	0.0	0.0	0.0	0.0
11/12/2024	0.0	0.0	0.0	0.0
11/13/2024	0.0	0.0	0.0	0.0
11/14/2024	0.0	0.0	0.0	0.0
11/15/2024	0.1	0.1	22.3	36.0
11/16/2024	0.0	0.0	0.0	0.0
11/17/2024	0.0	0.0	0.0	0.0
11/18/2024	0.0	0.0	0.0	0.0
11/19/2024	0.0	0.0	0.0	0.0
11/20/2024	74.4	14.8	0.0	0.0
11/21/2024	14.2	1.5	0.0	0.0
11/22/2024	45.3	14.0	0.0	0.0
11/23/2024	0.0	0.0	0.0	0.0
11/24/2024	0.0	0.0	0.0	0.0
11/25/2024	0.0	0.0	0.0	0.0
11/26/2024	0.0	0.0	0.0	0.0
11/27/2024	0.0	0.0	0.0	0.0
11/28/2024	0.0	0.0	0.0	0.0
11/29/2024	0.0	0.0	0.0	0.0
11/30/2024	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	194.5 sum	44.1 sum	136.8 sum	69.6 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	74.4	14.8	38.1	36.0
Oct 2024 - Nov 2024	204.7 sum	45.2 sum	204.6 sum	86.8 sum
QTD:	204.7 sum	45.2 sum	204.6 sum	86.8 sum
YTD 2024:	1,220.9 sum	181.7 sum	865.6 sum	310.5 sum

Monthly Summary By Day Report



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/02/2025 09:56 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2024	0.0	0.0	0.0	0.0
12/02/2024	0.0	0.0	0.0	0.0
12/03/2024	0.0	0.0	0.0	0.0
12/04/2024	0.0	0.0	0.0	0.0
12/05/2024	0.0	0.0	0.0	0.0
12/06/2024	0.0	0.0	0.0	0.0
12/07/2024	0.0	0.0	0.0	0.0
12/08/2024	0.0	0.0	0.0	0.0
12/09/2024	0.0	0.0	0.0	0.0
12/10/2024	0.0	0.0	0.0	0.0
12/11/2024	0.0	0.0	0.0	0.0
12/12/2024	0.0	0.0	0.0	0.0
12/13/2024	0.0	0.0	0.0	0.0
12/14/2024	0.0	0.0	0.0	0.0
12/15/2024	0.0	0.0	0.0	0.0
12/16/2024	0.0	0.0	0.0	0.0
12/17/2024	0.0	0.0	0.0	0.0
12/18/2024	0.0	0.0	0.0	0.0
12/19/2024	0.0	0.0	0.0	0.0
12/20/2024	0.0	0.0	0.0	0.0
12/21/2024	0.0	0.0	0.0	0.0
12/22/2024	0.0	0.0	0.0	0.0
12/23/2024	0.0	0.0	0.0	0.0
12/24/2024	0.0	0.0	0.0	0.0
12/25/2024	0.0	0.0	0.0	0.0
12/26/2024	0.0	0.0	0.0	0.0
12/27/2024	0.0	0.0	0.0	0.0
12/28/2024	0.0	0.0	0.0	0.0
12/29/2024	0.0	0.0	0.0	0.0
12/30/2024	38.8	2.0	0.0	0.0
12/31/2024	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	38.8 sum	2.0 sum	-	-
Daily Min:	0.0	0.0	-	-
Daily Max:	38.8	2.0	-	-
Oct 2024 - Dec 2024	243.5 sum	47.2 sum	204.6 sum	86.8 sum
QTD:	243.5 sum	47.2 sum	204.6 sum	86.8 sum
YTD 2024:	1,259.7 sum	183.7 sum	865.6 sum	310.5 sum

Startup / Shutdown Events

CT1



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 08:32 **Location:** Roseville, CA

Unit offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/29/2024 11:00	11/06/2024 09:00	191
11/15/2024 16:00	11/20/2024 15:00	120
11/20/2024 19:00	11/21/2024 22:00	28
12/30/2024 18:00	12/31/2024 23:00	30

Startup / Shutdown Events

CT1



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 08:32 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	369.00 Hour(s)
Offline Percentage:	16.71 %
Total Online:	1,839.00 Hour(s)
Online Percentage:	83.29 %

Startup / Shutdown Events

CT1



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 08:32 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/01/2024 16:07	10/01/2024 16:07	Shutdown	1
2	10/02/2024 11:36	10/02/2024 11:36	Shutdown	1
3	10/29/2024 09:53	10/29/2024 10:03	Shutdown	11
4	11/06/2024 10:02	11/06/2024 11:10	cold Startup	69
5	11/15/2024 15:21	11/15/2024 15:23	Shutdown	3
6	11/20/2024 16:44	11/20/2024 17:54	cold Startup	71
7	11/20/2024 18:20	11/20/2024 18:30	Shutdown	11
8	11/21/2024 23:44	11/21/2024 23:51	cold Startup	8
9	11/21/2024 23:51	11/21/2024 23:51	Shutdown	1
10	11/22/2024 00:06	11/22/2024 01:06	cold Startup	61
11	12/30/2024 16:57	12/30/2024 17:13	Shutdown	17

Startup / Shutdown Events

CT1



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/02/2025 08:32 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	4	209	0.19
Warm Startup	0		0.00
Shutdown	7	45	0.04
Total Process Events:	11	254	0.23

Total Report Time: 2,207.98 Hour(s)
Total Operating Time: 1,834.48 Hour(s)
Total Startup Time: 209 Minute(s)
Total Shutdown Time: 45 Minute(s)
Total Startup/Shutdown Time: 254 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time: 0.23 %

Startup / Shutdown Events

CT2



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 08:34 **Location:** Roseville, CA

Unit Offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/17/2024 11:00	10/28/2024 06:00	260
10/28/2024 10:00	10/29/2024 07:00	22
11/06/2024 12:00	11/07/2024 13:00	26
11/08/2024 10:00	11/08/2024 17:00	8
11/09/2024 07:00	11/15/2024 11:00	149
11/15/2024 16:00	11/15/2024 19:00	4
11/15/2024 22:00	11/16/2024 07:00	10
11/16/2024 10:00	12/31/2024 23:00	1094

Startup / Shutdown Events

CT2



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 08:34 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	1,573.00 Hour(s)
Offline Percentage:	71.24 %
Total Online:	635.00 Hour(s)
Online Percentage:	28.76 %

Startup / Shutdown Events

CT2



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/02/2025 08:34 Location: Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/17/2024 10:07	10/17/2024 10:18	Shutdown	12
2	10/28/2024 07:51	10/28/2024 08:57	Cold Startup	67
3	10/28/2024 08:10	10/28/2024 08:10	Shutdown	1
4	10/28/2024 08:21	10/28/2024 08:22	Shutdown	2
5	10/28/2024 08:25	10/28/2024 08:25	Shutdown	1
6	10/28/2024 09:04	10/28/2024 09:13	Shutdown	10
7	10/29/2024 08:45	10/29/2024 09:41	Cold Startup	57
8	11/05/2024 09:59	11/05/2024 09:59	Shutdown	1
9	11/05/2024 10:19	11/05/2024 11:05	Cold Startup	47
10	11/06/2024 11:45	11/06/2024 11:56	Shutdown	12
11	11/07/2024 14:22	11/07/2024 15:23	Cold Startup	62
12	11/08/2024 08:50	11/08/2024 09:01	Shutdown	12
13	11/08/2024 18:21	11/08/2024 19:17	Cold Startup	57
14	11/09/2024 06:48	11/09/2024 06:59	Shutdown	12
15	11/15/2024 12:49	11/15/2024 12:53	Cold Startup	5
16	11/15/2024 12:53	11/15/2024 12:53	Shutdown	1
17	11/15/2024 13:23	11/15/2024 13:27	Cold Startup	5
18	11/15/2024 13:27	11/15/2024 13:27	Shutdown	1
19	11/15/2024 13:47	11/15/2024 14:05	Cold Startup	19
20	11/15/2024 13:57	11/15/2024 13:58	Shutdown	2
21	11/15/2024 14:04	11/15/2024 14:05	Shutdown	2
22	11/15/2024 14:56	11/15/2024 15:12	Cold Startup	17

Startup / Shutdown Events

CT2



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 08:34 **Location:** Roseville, CA

Number	Start Time	End Time	Event Type	Duration
23	11/15/2024 15:12	11/15/2024 15:12	Shutdown	1
24	11/15/2024 15:34	11/15/2024 15:48	Warm Startup	15
25	11/15/2024 15:48	11/15/2024 15:48	Shutdown	1
26	11/15/2024 20:54	11/15/2024 21:38	Cold Startup	45
27	11/15/2024 21:05	11/15/2024 21:05	Shutdown	1
28	11/15/2024 21:37	11/15/2024 21:38	Shutdown	2
29	11/16/2024 08:33	11/16/2024 09:25	Cold Startup	53
30	11/16/2024 09:24	11/16/2024 09:25	Shutdown	2

Startup / Shutdown Events

CT2



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 08:34 **Location:** Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	11	434	1.16
Warm Startup	1	15	0.04
Shutdown	18	76	0.20
Total Process Events:	30	525	1.4

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	624.55 Hour(s)
Total Startup Time:	449 Minute(s)
Total Shutdown Time:	76 Minute(s)
Total Startup/Shutdown Time:	525 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	1.40 %

AQ-47/69/90/103

AQ-47/69/90/103: No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-47/69/90/103 of Roseville Energy Park's 4Q24 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-48/91/104

AQ-48/91/104: Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-48/91/104 of Roseville Energy Park's 4Q24 QAQR, there were no violations of PCAPCD's Rule 202 for opacity.

AQ-86

AQ-86 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD	DATE	Initial	START	END	Reason	Hours Total	mins YTD
7/10/22	DE	1120	1150	Bi-WEEKLY TEST RUN	125	395	9-22-23	LH	1139	1149	CD Power Pm's Test Run	140	557
7/20/22	DWN	1455	1525	Bi-Weekly Test Run	125	425	10-1-2023	LAB	1444	1514	BI-WEEKLY TEST RUN	140	587
8/7/22	DE	1212	1242	Bi-WEEKLY TEST RUN	126	455	10-12-23	DWN	1410	1440	Bi-Weekly Test Run	141	617
8-21-22	CycC	1655	1755	Bi-weekly Test Run	126	485	10-29-23	LAB	1235	1305	BI-WEEKLY TEST RUN	141	647
8/31/22	DE	0952	1012	CD POWER POST MAINTENANCE RUN	127	505	11-12-23	JAC	1150	1220	BI-WEEKLY TEST RUN	142	677
9-17-22	JM	1410	1440	Bi-weekly test Run	127	535	11-25-2023	LAB	1538	1608	BI-WEEKLY TEST RUN	142	707
9-24-22	CycC	1520	1534	Aborted. Redundant Test Run	127	550	12-7-23	DWN	1055	1125	Bi-Weekly Test Run	143	737
10/2/22	DE	1230	1300	Bi-WEEKLY TEST RUN	128	580	12-21-23	KPS	0900	0905	Diesel Delivery 40gallons		
10-15-22	JM	1314	1344	Bi weekly test Run	128	010	12-23-23	KPS	1216	1246	Bi-Weekly Test Run.	143	767
10/30/2022	LAB	1449	1519	BI-WEEKLY TEST RUN	129	640	2024					143	8
11-12-22	JM	1238	1308	Bi weekly test Run	129	070	1-6-24	JR	1123	1153	BI-WEEKLY TEST RUN	144	5
11-27-22	CycC	1011	1041	Bi-weekly Test Run	130	700	1-20-2024	LAB	1507	1537	BI-WEEKLY TEST RUN	144	60
12-10-22	JM	1200	1230	Bi-weekly test Run	130	730	2-1-24	DWN	1205	1235	Bi-Weekly Test Run	145	90
2023					130	0	2-18-24	LAB	0922	0952	BI-WEEKLY TEST RUN	145	120
2024							2/21/24	DE	0806	0808	EDG BLACK PLANT FUNCTION TEST	146	122
1-8-23	LH	13:13	13:43	Biweekly Test Run	131	30	2/21/24	DE	0823	0844	EDG BLACK PLANT FUNCTION TEST	146	143
1-22-23	LAB	1453	1523	BIWEEKLY TEST RUN	131	60	2/21/24	DE	0959	1301	RUNNING TO POWER ESS	149	205
2-3-23	DE	1110	1144	BIWEEKLY TEST RUN	132	94	3/17/24	LAB	1214	1244	BI-WEEKLY TEST RUN	149	235
2-19-23	LAB	1459	1529	BIWEEKLY TEST RUN	132	124	3-31-24	DWN	1120	1150	Bi-Weekly Test Run	150	265
3-5-23	LH	13:00	13:30	Bi Weekly Test Run	133	154	4-14-24	LAB	1021	1051	BI-WEEKLY TEST RUN	150	295
3-18-23	LAB	1114	1144	BIWEEKLY TEST RUN	133	184	5-5-24	JAC	1638	1708	BI-WEEKLY TEST RUN	151	325
5-2-23	CycC	1344	1405	Transfer from Alt to Norm feed	134	205	5-11-24	LAB	1532	1602	BI-WEEKLY TEST RUN	151	355
5-7-23	CycC	1040	1110	Bi-Weekly Test Run	134	235	5-25-24	JR	1624	1634	BI-WEEKLY TEST RUN	152	385
5-13-23	LH	21:22	21:52	Bi-weekly Test Run	135	265	6/4/24	DIESEL FUEL DELIVERY - 130 GALS					
5-28-23	DWN	0810	0840	Bi-Weekly Test Run	135	295	6-9-24	LAB	1104	1134	BI-WEEKLY TEST RUN	152	415
6-8-23	LAB	0831	0901	BI-WEEKLY TEST RUN	136	325	6-19-24	JR	1202	1217	ANNUAL TEST (CD POWER)	153	430
6-15-23	EO	14:25	14:57	REPAIR COOLANT HOSE TEST RUN	136	337	6-21-24	JR	1547	1617	BI-WEEKLY TEST RUN	153	460
6-25-23	DWN	1230	1300	Bi-Weekly Test Run	137	367	7-7-24	LAB	1150	1220	BI-WEEKLY TEST RUN	153	490
7-6-23	KPS			Diesel Delivery x 21 Gallons			7-18-24	DWN	1255	1325	Bi-Weekly Test Run	154	520
7-9-23	LAB	1336	1406	BI-WEEKLY TEST RUN	137	397	7-24-24	DWN	1052	1102	PCAPOD TEST RUN	154	530
7-23-23	JR	1113	1143	BI-WEEKLY TEST RUN	138	427	8-3-24	LAB	1228	1258	BI-WEEKLY TEST RUN	155	560
8-6-2023	LAB	1635	1705	BI-WEEKLY TEST RUN	138	457	8-17-24	JR	1500	1530	BI-WEEKLY TEST RUN	155	590
8-20-2023	JR	1251	1321	BI-WEEKLY TEST RUN	139	487	8-31-24	LAB	1343	1413	BI-WEEKLY TEST RUN	156	620
9-3-2023	LAB	1625	1655	BI-WEEKLY TEST RUN	139	517	9-14-24	JR	1348	1418	BI-WEEKLY TEST RUN	156	650
9-16-2023	LH	0830	0900	Bi-weekly Test Run	140	547	9-28-24	LAB	1336	1406	BI-WEEKLY TEST RUN	157	680
							10-12-24	JR	1210	1240	BI-WEEKLY TEST RUN	157	710

AQ-87

AQ-87 Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	Start Time	Reason	Stop Time	Total Hrs.	VTD Hrs.	Initials
4-14-24	1414	WEEKLY TEST RUN	1444	281.9	8.3	HAB
4-22-24	0207	Weekly Test Run	0237	282.4	8.8	JAB
4-28-24	1450	Weekly Test Run	1520	282.9	9.3	ZAR
5-5-24	1445	Weekly Test Run	1515	283.4	9.8	ZAR
5-12-24	1428	WEEKLY TEST RUN	1458	283.9	10.3	HAB
5-16-24	0802	Annual test	0807	284.0	10.4	JAB
5-25-24	1521	WEEKLY TEST RUN	1551	284.5	10.9	JAB
6-2-24	11:44	Weekly Test Run	1214	285.0	11.4	ZAR
6/4/24	1200	DIESEL FUEL DELIVERY - 70 GALLONS				
6-9-24	1323	WEEKLY TEST RUN	1353	285.5	11.9	HAB
6-16-24		Weekly test Run		286.0	12.4	JAB
6-19-24	1000	ANNUAL TEST (CD POWER)		286.3	12.7	JAB
6-22-24	1510	WEEKLY PM		286.8	13.2	JAB
6-30-24	1446	Weekly Test Run	1516	287.3	13.7	ZAR
7-7-24	1349	WEEKLY TEST RUN	1419	287.8	14.2	HAB
7-14-24	1632	Weekly Test Run	1643	288.0	14.4	CYC
7-17-24		Changed coolant, Hoses + Battery CND Power				
7-17-24	1100	Test Run After Service	1106	288.1	14.5	DWN
7-20-24	1347	WEEKLY PM	1617	288.6	15	JAB
7-24-24	1100	PCAPCD Test Run	1106	288.7	15.1	DWN
7/27/24	1135	Weekly Test Run	1205	289.2	15.6	DE
8-4-24	1312	WEEKLY TEST RUN	1342	289.7	16.1	HAB
8-7-24	1020	Weekly test Run	1050	290.2	16.6	JAB
8-13-24	1105	Weekly Test Run	1135	290.7	17.1	DWN
8-24-24	1340	Weekly Test Run	1420	291.2	17.6	JAB
9-1-24	1510	WEEKLY TEST RUN	1540	291.7	18.1	HAB
9-8-24	1134	Weekly test Run	1204	292.2	18.6	JAB
9-14-24	1428	WEEKLY TEST RUN	1555	292.7	19.1	JAB
9-22-24	0917	WEEKLY TEST RUN	0947	293.2	19.6	JAB
9-29-24	1443	WEEKLY TEST RUN	1513	293.7	20.1	HAB
10-12-24	1135	WEEKLY TEST RUN	1205	294.2	20.6	JAB
10-20-24	1133	WEEKLY TEST RUN	1123	294.7	21.1	JAB
10-24-24	10:15	Filled Diesel tank 57 gallons				
10-27-24	1515	WEEKLY TEST RUN	1545	295.2	21.6	HAB
11-2-24	1056	Weekly test Run	1126	295.7	22.1	JAB
11-9-24	1455	WEEKLY TEST RUN	1525	296.2	22.6	JAB

DATE	Start Time	Reason	Stop Time	TOTAL hrs.	VTD Hrs.	Initials
11-16-24	15:00	Weekly test Run	1530	296.7	23.1	KCS
11-24-24	1555	WEEKLY TEST RUN	1625	297.2	23.6	HAB
12-1-24	1304	Weekly test Run	1334	297.7	24.1	JAB
12-7-24	1450	WEEKLY TEST RUN	1520	298.2	24.6	JAB
12/13/24	1601	WEEKLY TEST RUN	1631	298.7	25.1	JAB
12/22/24	1505	WEEKLY TEST RUN	1535	299.2	25.6	JAB
12-28-24	1502	Weekly test Run	1532	299.7	26.1	JAB

AQ-88/101

AQ-88 The Sulfur content of the Diesel fuel used shall not exceed 15 ppm by weight.

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report as required in Condition of Certification AQ-SC6.



Fuel Dispatch Ticket

Ramos Oil Company
PO Box 401
West Sacramento, CA95691
(916) 371-2570

Ticket No: OD-0257029
Scheduled Delivery: Thu 10/24/24 12:00a
Carrier: Ramos Oil - Bobtail/Lube carrie
Vehicle: Truck # 29180
Driver: Ron Hampton
Reference Number:
Purchase Order No: 9007936

Ship To:	Location 2 City Of Roseville - MAIN 5120 Phillip Rd Roseville, CA 95747	Bill To:	Account 23464 Roseville Energy Park City Of Roseville 5120 Phillip Rd Roseville, CA 95747
Contact:	BEN STANLEY (916) 746-1691		

Delivery Notes:
5190 phillips rd, fill grade-all, Richard 1-916-746-1689, push the buzzer at the gate and they will escort you to the equipment, this week

Order	Product	Units	Load	Product	Units	Origin
	NA1993, Diesel Fuel, Combustible Liquid, PG III					
	#2D 15ppm sulfur (maximum). Dyed diesel fuel, non-taxable use only, penalty for taxable use.					
	Red Dyed R99 Renewable C	50.0		Red Dyed R99 Renev	50.0	Marysville
						418 13th Street , Marysville, CA 95901

Percent Full: _____

76 gal TOTAL
19 gal to

57 gal Diesel fire pump.

Actual Delivery Date/Time: _____	Received By: _____
---	---------------------------

AQ-89/102

AQ-89/102: Records of operation and maintenance shall be kept by the owner or operator for a period of five years and shall be made available to the PCAPCD by request. Information required for reporting to the PCAPCD includes, but is not limited to:

- A. Hours of operation the engine was run for maintenance and testing
- B. Hours of operation the engine was run during interruption of electrical power
- C. Records of sulfur content of the diesel fuel used

Verification: The Project shall include all necessary operational data to demonstrate compliance with the limits provided as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD	DATE	Initial	START	END	Reason	Hours Total	mins YTD	
7/10/22	DE	1120	1150	Bi-WEEKLY TEST RUN	125	395	9-22-23	LH	1139	1149	CD Power Pm's Test Run	140	557	
7/20/22	DWN	1455	1525	Bi-Weekly Test Run	125	425	10-1-2023	LAB	1444	1514	BI-WEEKLY TEST RUN	140	587	
8/7/22	DE	1212	1242	Bi-WEEKLY TEST RUN	126	455	10-12-23	DWN	1410	1440	Bi-Weekly Test Run	141	617	
8-21-22	CycC	1655	1755	Bi-weekly Test Run	126	485	10-29-23	LAB	1235	1305	BI-WEEKLY TEST RUN	141	647	
8/31/22	DE	0952	1012	CD POWER POST MAINTENANCE RUN	127	505	11-12-23	JAC	1150	1220	BI-WEEKLY TEST RUN	142	677	
9-17-22	JM	1410	1440	Bi-weekly test Run	127	535	11-25-2023	LAB	1538	1608	BI-WEEKLY TEST RUN	142	707	
9-24-22	CycC	1520	1534	Aborted. Redundant Test Run	127	550	12-7-23	DWN	1055	1125	Bi-Weekly Test Run	143	737	
10/2/22	DE	1230	1300	Bi-WEEKLY TEST RUN	128	580	12-21-23	KPS	0900	0905	Diesel Delivery 40gallons			
10-15-22	JM	1314	1344	Bi weekly test Run	128	010	12-23-23	KPS	1216	1246	Bi-Weekly Test Run.	143	767	
10/30/2022	LAB	1449	1519	BI-WEEKLY TEST RUN	129	640	2024					143	8	
11-12-22	JM	1238	1308	Bi weekly test Run	129	710	1-6-24	JR	1123	1153	BI-WEEKLY TEST RUN	144	5	
11-27-22	CycC	1011	1041	Bi-weekly Test Run	130	740	1-20-2024	LAB	1507	1537	BI-WEEKLY TEST RUN	144	60	
12-10-22	JM	1200	1230	Bi-weekly test Run	130	730	2-1-24	DWN	1205	1235	Bi-Weekly Test Run	145	90	
							2-18-24	LAB	0922	0952	BI-WEEKLY TEST RUN	145	120	
							2/21/24	DE	0806	0808	EDG BLACK PLANT FUNCTION TEST	146	122	
					2023	130	0	2/21/24	DE	0823	0844	EDG BLACK PLANT FUNCTION TEST	146	143
1-8-23	LH	13:13	13:43	Biweekly Test Run	131	30	2/21/24	DE	0959	1301	RUNNING TO POWER ESS	149	205	
1-22-23	LAB	1453	1523	BIWEEKLY TEST RUN	131	60	3/17/24	LAB	1214	1244	BI-WEEKLY TEST RUN	149	235	
2-3-23	DE	1110	1144	BIWEEKLY TEST RUN	132	94	3-31-24	DWN	1120	1150	Bi-Weekly Test Run	150	265	
2-19-23	LAB	1459	1529	BIWEEKLY TEST RUN	132	124	4-14-24	LAB	1021	1051	BI-WEEKLY TEST RUN	150	295	
3-5-23	LH	13:00	13:30	Bi Weekly Test Run	133	154	5-5-24	JAC	1638	1708	BI-WEEKLY TEST RUN	151	325	
3-18-23	LAB	1114	1144	BIWEEKLY TEST RUN	133	184	5-11-24	LAB	1532	1602	BI-WEEKLY TEST RUN	151	355	
5-2-23	CycC	1344	1405	Transfer from Alt to Norm feed	134	205	5-25-24	JR	1624	1634	BI-WEEKLY TEST RUN	152	385	
5-7-23	CycC	1040	1110	Bi-Weekly Test Run	134	235	6/4/24	DIESEL FUEL DELIVERY - 130 GALS						
5-13-23	LH	21:22	21:52	Bi-weekly Test Run	135	265	6-9-24	LAB	1104	1134	BI-WEEKLY TEST RUN	152	415	
5-28-23	DWN	0810	0840	Bi-Weekly Test Run	135	295	6-19-24	JR	1202	1217	ANNUAL TEST (CD POWER)	153	430	
6-8-23	LAB	0831	0901	BI-WEEKLY TEST RUN	136	325	6-21-24	JR	1547	1617	BI-WEEKLY TEST RUN	153	460	
6-15-23	EO	14:25	14:57	REPAIR COOLANT HOSE TEST RUN	136	337	7-7-24	LAB	1150	1220	BI-WEEKLY TEST RUN	153	490	
6-25-23	DWN	1230	1300	Bi-Weekly Test Run	137	367	7-18-24	DWN	1255	1325	Bi-Weekly Test Run	154	520	
7-6-23	KPS			Diesel Delivery 21 Gallons			7-24-24	DWN	1052	1102	PCAPOD TEST RUN	154	530	
7-9-23	LAB	1336	1406	BI-WEEKLY TEST RUN	137	397	8-3-24	LAB	1228	1258	BI-WEEKLY TEST RUN	155	560	
7-23-23	JR	1113	1143	BI-WEEKLY TEST RUN	138	427	8-17-24	JR	1500	1530	BI-WEEKLY TEST RUN	155	590	
8-6-2023	LAB	1635	1705	BI-WEEKLY TEST RUN	138	457	8-31-24	LAB	1343	1413	BI-WEEKLY TEST RUN	156	620	
8-20-2023	JR	1251	1321	BI-WEEKLY TEST RUN	139	487	9-14-24	JR	1348	1418	BI-WEEKLY TEST RUN	156	650	
9-3-2023	LAB	1625	1655	BI-WEEKLY TEST RUN	139	517	9-28-24	LAB	1336	1406	BI-WEEKLY TEST RUN	157	680	
9-16-2023	LH	0830	0900	Bi-weekly Test Run	140	547	10-12-24	JR	1210	1240	BI-WEEKLY TEST RUN	157	710	

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD
10/26/2024	KAB	1258	1328	BI-WEEKLY TEST RUN	158	740
11-9-24	KAB	1420	1450	BI WEEKLY TEST RUN	158	770
11-23-24	KAB	1617	1647	BI-WEEKLY TEST RUN	159	800
12-7-24	KAB	1415	1445	BI-WEEKLY TEST RUN	159	830
12-22-24	KAB	0903	0933	BI-WEEKLY TEST RUN	160	860



Fuel Dispatch Ticket

Ramos Oil Company
PO Box 401
West Sacramento, CA95691
(916) 371-2570

Ticket No: OD-0257029
Scheduled Delivery: Thu 10/24/24 12:00a
Carrier: Ramos Oil - Bobtail/Lube carrie
Vehicle: Truck # 29180
Driver: Ron Hampton
Reference Number:
Purchase Order No: 9007936

Ship To:	Location 2 City Of Roseville - MAIN 5120 Phillip Rd Roseville, CA 95747	Bill To:	Account 23464 Roseville Energy Park City Of Roseville 5120 Phillip Rd Roseville, CA 95747
Contact:	BEN STANLEY (916) 746-1691		

Delivery Notes:
5190 phillips rd, fill grade-all, Richard 1-916-746-1689, push the buzzer at the gate and they will escort you to the equipment, this week

Order	Product	Units	Load	Product	Units	Origin
	NA1993, Diesel Fuel, Combustible Liquid, PG III					
	#2D 15ppm sulfur (maximum). Dyed diesel fuel, non-taxable use only, penalty for taxable use.					
	Red Dyed R99 Renewable C	50.0		Red Dyed R99 Renev	50.0	Marysville 418 13th Street , Marysville, CA 95901

Percent Full: _____

76 gal TOTAL
19 gal to

57 gal Diesel fire pump.

Actual Delivery Date/Time: _____	Received By: _____
---	---------------------------

AQ-99

AQ-99 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project shall include all necessary operational data to demonstrate compliance with the limits provided as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD	DATE	Initial	START	END	Reason	Hours Total	mins YTD	
7/10/22	DE	1120	1150	Bi-WEEKLY TEST RUN	125	395	9-22-23	LH	1139	1149	CD Power Pm's Test Run	140	557	
7/20/22	DWN	1455	1525	Bi-Weekly Test Run	125	425	10-1-2023	LAB	1444	1514	BI-WEEKLY TEST RUN	140	587	
8/7/22	DE	1212	1242	Bi-WEEKLY TEST RUN	126	455	10-12-23	DWN	1410	1440	Bi-Weekly Test Run	141	617	
8-21-22	CycC	1655	1755	Bi-weekly Test Run	126	485	10-29-23	LAB	1235	1305	BI-WEEKLY TEST RUN	141	647	
8/31/22	DE	0952	1012	CD POWER POST MAINTENANCE RUN	127	505	11-12-23	JAC	1150	1220	BI-WEEKLY TEST RUN	142	677	
9-17-22	JM	1410	1440	Bi-weekly test Run	127	535	11-25-2023	LAB	1538	1608	BI-WEEKLY TEST RUN	142	707	
9-24-22	CycC	1520	1534	Aborted. Redundant Test Run	127	550	12-7-23	DWN	1055	1125	Bi-Weekly Test Run	143	737	
10/2/22	DE	1230	1300	Bi-WEEKLY TEST RUN	128	580	12-21-23	KPS	0900	0905	Diesel Delivery 400 gallons			
10-15-22	JM	1314	1344	Bi weekly test Run	128	010	12-23-23	KPS	1216	1246	Bi-Weekly Test Run.	143	767	
10/30/2022	LAB	1449	1519	BI-WEEKLY TEST RUN	129	640	2024					143	8	
11-12-22	JM	1238	1308	Bi weekly test Run	129	710	1-6-24	JR	1123	1153	BI-WEEKLY TEST RUN	144	5	
11-27-22	CycC	1011	1041	Bi-weekly Test Run	130	740	1-20-2024	LAB	1507	1537	BI-WEEKLY TEST RUN	144	60	
12-10-22	JM	1200	1230	Bi-weekly test Run	130	730	2-1-24	DWN	1205	1235	Bi-Weekly Test Run	145	90	
							2-18-24	LAB	0922	0952	BI-WEEKLY TEST RUN	145	120	
							2/21/24	DE	0806	0808	EDG BLACK PLANT FUNCTION TEST	146	122	
					2023	130	0	2/21/24	DE	0823	0844	EDG BLACK PLANT FUNCTION TEST	146	143
1-8-23	LH	13:13	13:43	Biweekly Test Run	131	30	2/21/24	DE	0959	1301	RUNNING TO POWER ESS	149	205	
1-22-23	LAB	1453	1523	BIWEEKLY TEST RUN	131	60	3/17/24	LAB	1214	1244	BI-WEEKLY TEST RUN	149	235	
2-3-23	DE	1110	1144	BIWEEKLY TEST RUN	132	94	3-31-24	DWN	1120	1150	Bi-Weekly Test Run	150	265	
2-19-23	LAB	1459	1529	BIWEEKLY TEST RUN	132	124	4-14-24	LAB	1021	1051	BI-WEEKLY TEST RUN	150	295	
3-5-23	LH	13:00	13:30	Bi Weekly Test Run	133	154	5-5-24	JAC	1638	1708	BI-WEEKLY TEST RUN	151	325	
3-18-23	LAB	1114	1144	BIWEEKLY TEST RUN	133	184	5-11-24	LAB	1532	1602	BI-WEEKLY TEST RUN	151	355	
5-2-23	CycC	1344	1405	Transfer from Alt to Norm feed	134	205	5-25-24	JR	1624	1634	BI-WEEKLY TEST RUN	152	385	
5-7-23	CycC	1040	1110	Bi-Weekly Test Run	134	235	6/4/24	DIESEL FUEL DELIVERY - 130 GALS						
5-13-23	LH	21:22	21:52	Bi-weekly Test Run	135	265	6-9-24	LAB	1104	1134	BI-WEEKLY TEST RUN	152	415	
5-28-23	DWN	0810	0840	Bi-Weekly Test Run	135	295	6-19-24	JR	1202	1217	ANNUAL TEST (CD POWER)	153	430	
6-8-23	LAB	0831	0901	BI-WEEKLY TEST RUN	136	325	6-21-24	JR	1547	1617	BI-WEEKLY TEST RUN	153	460	
6-15-23	EO	14:25	14:57	REPAIR COOLANT HOSE TEST RUN	136	337	7-7-24	LAB	1150	1220	BI-WEEKLY TEST RUN	153	490	
6-25-23	DWN	1230	1300	Bi-Weekly Test Run	137	367	7-18-24	DWN	1255	1325	Bi-Weekly Test Run	154	520	
7-6-23	KPS			Diesel Delivery x 21 Gallons			7-24-24	DWN	1052	1102	PCAPOD TEST RUN	154	530	
7-9-23	LAB	1336	1406	BI-WEEKLY TEST RUN	137	397	8-3-24	LAB	1228	1258	BI-WEEKLY TEST RUN	155	560	
7-23-23	JR	1113	1143	BI-WEEKLY TEST RUN	138	427	8-17-24	JR	1500	1530	BI-WEEKLY TEST RUN	155	590	
8-6-2023	LAB	1635	1705	BI-WEEKLY TEST RUN	138	457	8-31-24	LAB	1343	1413	BI-WEEKLY TEST RUN	156	620	
8-20-2023	JR	1251	1321	BI-WEEKLY TEST RUN	139	487	9-14-24	JR	1348	1418	BI-WEEKLY TEST RUN	156	650	
9-3-2023	LAB	1625	1655	BI-WEEKLY TEST RUN	139	517	9-28-24	LAB	1336	1406	BI-WEEKLY TEST RUN	157	680	
9-16-2023	LH	0830	0900	Bi-weekly Test Run	140	547	10-12-24	JR	1210	1240	BI-WEEKLY TEST RUN	157	710	

AQ-100

AQ-100 In regards to the Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD	DATE	Initial	START	END	Reason	Hours Total	mins YTD
7/10/22	DE	1120	1150	BI-WEEKLY TEST RUN	125	395	9-22-23	LH	1139	1149	CD Power Pm's Test Run	140	557
7/20/22	DWN	1455	1525	Bi-Weekly Test Run	125	425	10-1-2023	LAB	1444	1514	BI-WEEKLY TEST RUN	140	587
8/7/22	DE	1212	1242	BI-WEEKLY TEST RUN	126	455	10-12-23	DWN	1410	1440	Bi-Weekly Test Run	141	617
8-21-22	CycC	1655	1755	Bi-weekly Test Run	126	485	10-29-23	LAB	1235	1305	BI-WEEKLY TEST RUN	141	647
8/31/22	DE	0952	1012	CD POWER POST MAINTENANCE RUN	127	505	11-12-23	JAC	1150	1220	BI-WEEKLY TEST RUN	142	677
9-17-22	JM	1410	1440	Bi-weekly test Run	127	535	11-25-2023	LAB	1538	1608	BI-WEEKLY TEST RUN	142	707
9-24-22	CycC	1520	1534	Aborted. Redundant Test Run	127	550	12-7-23	DWN	1055	1125	Bi-Weekly Test Run	143	737
10/2/22	DE	1230	1300	BI-WEEKLY TEST RUN	128	580	12-21-23	KPS	0900	0905	Diesel Delivery 40gallons		
10-15-22	JM	1314	1344	Bi weekly test Run	128	010	12-23-23	KPS	1216	1246	Bi-Weekly Test Run.	143	767
10/30/2022	LAB	1449	1519	BI-WEEKLY TEST RUN	129	640	2024					143	8
11-12-22	JM	1238	1308	Bi weekly test Run	129	070	1-6-24	JR	1123	1153	BI-WEEKLY TEST RUN	144	5
11-27-22	CycC	1011	1041	Bi-weekly Test Run	130	700	1-20-2024	LAB	1507	1537	BI-WEEKLY TEST RUN	144	60
12-10-22	JM	1200	1230	Bi-weekly test Run	130	730	2-1-24	DWN	1205	1235	Bi-Weekly Test Run	145	90
2023							2-18-24	LAB	0922	0952	BI-WEEKLY TEST RUN	145	120
2023							2/21/24	DE	0806	0808	EDG BLACK PLANT FUNCTION TEST	146	122
2023							2/21/24	DE	0823	0844	EDG BLACK PLANT FUNCTION TEST	146	143
2023							2/21/24	DE	0959	1301	RUNNING TO POWER ESS	149	205
1-8-23	LH	13:13	13:43	Biweekly Test Run	131	30	3/17/24	LAB	1214	1244	BI-WEEKLY TEST RUN	149	235
1-22-23	LAB	1453	1523	BIWEEKLY TEST RUN	131	60	3-31-24	DWN	1120	1150	Bi-Weekly Test Run	150	265
2-3-23	DE	1110	1144	BIWEEKLY TEST RUN	132	94	4-14-24	LAB	1021	1051	BI-WEEKLY TEST RUN	150	295
2-19-23	LAB	1459	1529	BIWEEKLY TEST RUN	132	124	5-5-24	JAC	1638	1708	BI-WEEKLY TEST RUN	151	325
3-5-23	LH	13:00	13:30	Bi Weekly Test Run	133	154	5-11-24	LAB	1532	1602	BI-WEEKLY TEST RUN	151	355
3-18-23	LAB	1114	1144	BIWEEKLY TEST RUN	133	184	5-25-24	JR	1624	1634	BI-WEEKLY TEST RUN	152	385
5-2-23	CycC	1344	1405	Transfer from Alt to Norm feed	134	205	6/4/24	DIESEL FUEL DELIVERY - 130 GALS					
5-7-23	CycC	1040	1110	Bi-Weekly Test Run	134	235	6-9-24	LAB	1104	1134	BI-WEEKLY TEST RUN	152	415
5-13-23	LH	21:22	21:52	Bi-weekly Test Run	135	265	6-19-24	JR	1202	1217	ANNUAL TEST (CD POWER)	153	430
5-28-23	DWN	0810	0840	Bi-Weekly Test Run	135	295	6-21-24	JR	1547	1617	BI-WEEKLY TEST RUN	153	460
6-8-23	LAB	0831	0901	BI-WEEKLY TEST RUN	136	325	7-7-24	LAB	1150	1220	BI-WEEKLY TEST RUN	153	490
6-15-23	EO	14:25	14:57	REPAIR COOLANT HOSE TEST RUN	136	337	7-18-24	DWN	1255	1325	Bi-Weekly Test Run	154	520
6-25-23	DWN	1230	1300	Bi-Weekly Test Run	137	367	7-24-24	DWN	1052	1102	PCAPOD TEST RUN	154	530
7-6-23	KPS			Diesel Delivery 21 Gallons			8-3-24	LAB	1228	1258	BI-WEEKLY TEST RUN	155	560
7-9-23	LAB	1336	1406	BI-WEEKLY TEST RUN	137	397	8-17-24	JR	1500	1530	BI-WEEKLY TEST RUN	155	590
7-23-23	JR	1113	1143	BI-WEEKLY TEST RUN	138	427	8-31-24	LAB	1343	1413	BI-WEEKLY TEST RUN	156	620
8-6-2023	LAB	1635	1705	BI-WEEKLY TEST RUN	138	457	9-14-24	JR	1348	1418	BI-WEEKLY TEST RUN	156	650
8-20-2023	JR	1251	1321	BI-WEEKLY TEST RUN	139	487	9-28-24	LAB	1336	1406	BI-WEEKLY TEST RUN	157	680
9-3-2023	LAB	1625	1655	BI-WEEKLY TEST RUN	139	517	10-12-24	JR	1210	1240	BI-WEEKLY TEST RUN	157	710
9-16-2023	LH	0830	0900	Bi-weekly Test Run	140	547							

II. Emissions Overview

AQ-15

AQ-15 The Project owner shall install a selective catalytic reduction (SCR) system and an oxidation catalyst on the gas turbine. The SCR and oxidation catalyst equipment shall be operated whenever the gas turbine is operated.

Verification: The Project owner shall submit to the CPM a written statement by a California registered Professional Engineer stating that said engineer has reviewed the as built designs or inspected the identified equipment and certifies that it is operational and air tight. The Project owner shall include the operational status of the SCR and oxidation catalyst during all hours of operation as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

This document is on file from the 2007 4Q QAQR.

AQ-32

AQ-32 The Project owner shall maintain hourly records of NO_x and CO emission concentrations (ppmv @ 15% O₂), and hourly, daily, and quarterly records of NO_x and CO emissions. Ongoing compliance with the CO emission limits during normal operation shall be deemed compliance with the VOC emission limits during normal operation.

Verification: The project owner shall submit to the CPM all concentration, hourly, daily, and quarter NO_x and CO emissions as part of the Quarterly Air Quality Report required by Condition of Certification AQ-SC6

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/02/2025 10:19 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2024	0.4543	4.1404	1.3401	10.6951	0.3068	2.3923	0.1533	1.1956	0.5110	3.9847
Nov 2024	0.5318	4.6383	0.7862	11.4528	0.1699	2.5575	0.0846	1.2779	0.2833	4.2602
Dec 2024	0.4250	5.0633	0.9013	12.3541	0.2093	2.7668	0.1049	1.3828	0.3485	4.6087
Sum/Avg	5.0633		12.3541		2.7668		1.3828		4.6087	
Limit Value										

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
10/01/2024 00:00	13.31	47.98	20.37	57.67
Average/Sum#:	13.31 #	47.98 #	20.37 #	57.67 #
Minimum:	13.31	47.98	20.37	57.67
Maximum:	13.31	47.98	20.37	57.67
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
10/02/2024 00:00	10.67	54.79	17.02	64.50
Average/Sum#:	10.67 #	54.79 #	17.02 #	64.50 #
Minimum:	10.67	54.79	17.02	64.50
Maximum:	10.67	54.79	17.02	64.50
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
10/03/2024 00:00	11.08	60.58	17.85	70.39
Average/Sum#:	11.08 #	60.58 #	17.85 #	70.39 #
Minimum:	11.08	60.58	17.85	70.39
Maximum:	11.08	60.58	17.85	70.39
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
10/04/2024 00:00	11.05	47.27	17.94	57.95

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	11.05 #	47.27 #	17.94 #	57.95 #
Minimum:	11.05	47.27	17.94	57.95
Maximum:	11.05	47.27	17.94	57.95
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
10/05/2024 00:00	8.36	56.31	14.60	65.41

Average/Sum#:	8.36 #	56.31 #	14.60 #	65.41 #
Minimum:	8.36	56.31	14.60	65.41
Maximum:	8.36	56.31	14.60	65.41
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
10/06/2024 00:00	7.89	74.54	15.14	82.64

Average/Sum#:	7.89 #	74.54 #	15.14 #	82.64 #
Minimum:	7.89	74.54	15.14	82.64
Maximum:	7.89	74.54	15.14	82.64
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
10/07/2024 00:00	4.15	77.41	13.67	85.31

Average/Sum#:	4.15 #	77.41 #	13.67 #	85.31 #
Minimum:	4.15	77.41	13.67	85.31
Maximum:	4.15	77.41	13.67	85.31
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
10/08/2024 00:00	11.20	57.08	21.09	67.42
Average/Sum#:	11.20 #	57.08 #	21.09 #	67.42 #
Minimum:	11.20	57.08	21.09	67.42
Maximum:	11.20	57.08	21.09	67.42
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
10/09/2024 00:00	10.71	42.81	19.67	52.57
Average/Sum#:	10.71 #	42.81 #	19.67 #	52.57 #
Minimum:	10.71	42.81	19.67	52.57
Maximum:	10.71	42.81	19.67	52.57
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
10/10/2024 00:00	11.48	42.47	21.09	54.09
Average/Sum#:	11.48 #	42.47 #	21.09 #	54.09 #
Minimum:	11.48	42.47	21.09	54.09
Maximum:	11.48	42.47	21.09	54.09
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
10/11/2024 00:00	12.46	53.09	22.54	64.19

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	12.46 #	53.09 #	22.54 #	64.19 #
Minimum:	12.46	53.09	22.54	64.19
Maximum:	12.46	53.09	22.54	64.19
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
10/12/2024 00:00	11.68	43.79	20.46	54.22

Average/Sum#:	11.68 #	43.79 #	20.46 #	54.22 #
Minimum:	11.68	43.79	20.46	54.22
Maximum:	11.68	43.79	20.46	54.22
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
10/13/2024 00:00	11.82	44.47	21.01	55.42

Average/Sum#:	11.82 #	44.47 #	21.01 #	55.42 #
Minimum:	11.82	44.47	21.01	55.42
Maximum:	11.82	44.47	21.01	55.42
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
10/14/2024 00:00	12.20	46.07	21.47	57.89

Average/Sum#:	12.20 #	46.07 #	21.47 #	57.89 #
Minimum:	12.20	46.07	21.47	57.89
Maximum:	12.20	46.07	21.47	57.89
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
10/15/2024 00:00	11.44	41.89	20.14	52.89
Average/Sum#:	11.44 #	41.89 #	20.14 #	52.89 #
Minimum:	11.44	41.89	20.14	52.89
Maximum:	11.44	41.89	20.14	52.89
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
10/16/2024 00:00	11.86	42.68	19.73	53.26
Average/Sum#:	11.86 #	42.68 #	19.73 #	53.26 #
Minimum:	11.86	42.68	19.73	53.26
Maximum:	11.86	42.68	19.73	53.26
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
10/17/2024 00:00	13.68	41.73	26.51	25.03
Average/Sum#:	13.68 #	41.73 #	26.51 #	25.03 #
Minimum:	13.68	41.73	26.51	25.03
Maximum:	13.68	41.73	26.51	25.03
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
10/18/2024 00:00	15.33	45.02	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	15.33 #	45.02 #	0.00 #	0.00 #
Minimum:	15.33	45.02	0.00	0.00
Maximum:	15.33	45.02	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
10/19/2024 00:00	15.92	43.87	0.00	0.00

Average/Sum#:	15.92 #	43.87 #	0.00 #	0.00 #
Minimum:	15.92	43.87	0.00	0.00
Maximum:	15.92	43.87	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
10/20/2024 00:00	16.34	44.17	0.00	0.00

Average/Sum#:	16.34 #	44.17 #	0.00 #	0.00 #
Minimum:	16.34	44.17	0.00	0.00
Maximum:	16.34	44.17	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
10/21/2024 00:00	18.67	54.71	0.00	0.00

Average/Sum#:	18.67 #	54.71 #	0.00 #	0.00 #
Minimum:	18.67	54.71	0.00	0.00
Maximum:	18.67	54.71	0.00	0.00
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
10/22/2024 00:00	25.25	65.94	0.00	0.00
Average/Sum#:	25.25 #	65.94 #	0.00 #	0.00 #
Minimum:	25.25	65.94	0.00	0.00
Maximum:	25.25	65.94	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
10/23/2024 00:00	25.57	66.94	0.00	0.00
Average/Sum#:	25.57 #	66.94 #	0.00 #	0.00 #
Minimum:	25.57	66.94	0.00	0.00
Maximum:	25.57	66.94	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
10/24/2024 00:00	25.95	63.25	0.00	0.00
Average/Sum#:	25.95 #	63.25 #	0.00 #	0.00 #
Minimum:	25.95	63.25	0.00	0.00
Maximum:	25.95	63.25	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
10/25/2024 00:00	26.52	56.60	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/02/2025 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	26.52 #	56.60 #	0.00 #	0.00 #
Minimum:	26.52	56.60	0.00	0.00
Maximum:	26.52	56.60	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
--	--------------------------------	---------------------------------	--------------------------------	---------------------------------

10/26/2024 00:00	17.59	44.06	0.00	0.00
------------------	-------	-------	------	------

Average/Sum#:	17.59 #	44.06 #	0.00 #	0.00 #
Minimum:	17.59	44.06	0.00	0.00
Maximum:	17.59	44.06	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
--	--------------------------------	---------------------------------	--------------------------------	---------------------------------

10/27/2024 00:00	15.48	42.75	0.00	0.00
------------------	-------	-------	------	------

Average/Sum#:	15.48 #	42.75 #	0.00 #	0.00 #
Minimum:	15.48	42.75	0.00	0.00
Maximum:	15.48	42.75	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
--	--------------------------------	---------------------------------	--------------------------------	---------------------------------

10/28/2024 00:00	22.00	53.58	60.18	15.52
------------------	-------	-------	-------	-------

Average/Sum#:	22.00 #	53.58 #	60.18 #	15.52 #
Minimum:	22.00	53.58	60.18	15.52
Maximum:	22.00	53.58	60.18	15.52
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
10/29/2024 00:00	27.58	27.35	17.35	34.80
Average/Sum#:	27.58 #	27.35 #	17.35 #	34.80 #
Minimum:	27.58	27.35	17.35	34.80
Maximum:	27.58	27.35	17.35	34.80
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
10/30/2024 00:00	0.00	0.00	31.31	67.39
Average/Sum#:	0.00 #	0.00 #	31.31 #	67.39 #
Minimum:	0.00	0.00	31.31	67.39
Maximum:	0.00	0.00	31.31	67.39
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
10/31/2024 00:00	0.00	0.00	25.95	57.96
Average/Sum#:	0.00 #	0.00 #	25.95 #	57.96 #
Minimum:	0.00	0.00	25.95	57.96
Maximum:	0.00	0.00	25.95	57.96
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
11/01/2024 00:00	0.00	0.00	21.02	50.66

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/02/2025 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	0.00 #	0.00 #	21.02 #	50.66 #
Minimum:	0.00	0.00	21.02	50.66
Maximum:	0.00	0.00	21.02	50.66
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)

11/02/2024 00:00	0.00	0.00	20.43	51.73
------------------	------	------	-------	-------

Average/Sum#:	0.00 #	0.00 #	20.43 #	51.73 #
Minimum:	0.00	0.00	20.43	51.73
Maximum:	0.00	0.00	20.43	51.73
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)

11/03/2024 00:00	0.00	0.00	21.34	51.73
------------------	------	------	-------	-------

Average/Sum#:	0.00 #	0.00 #	21.34 #	51.73 #
Minimum:	0.00	0.00	21.34	51.73
Maximum:	0.00	0.00	21.34	51.73
%SI	0.00	0.00	0.00	0.00

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)

11/04/2024 00:00	0.00	0.00	22.19	54.41
------------------	------	------	-------	-------

Average/Sum#:	0.00 #	0.00 #	22.19 #	54.41 #
Minimum:	0.00	0.00	22.19	54.41
Maximum:	0.00	0.00	22.19	54.41
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/02/2025 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
11/05/2024 00:00	0.00	0.00	42.52	51.43
Average/Sum#:	0.00 #	0.00 #	42.52 #	51.43 #
Minimum:	0.00	0.00	42.52	51.43
Maximum:	0.00	0.00	42.52	51.43
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
11/06/2024 00:00	75.29	39.02	31.02	28.53
Average/Sum#:	75.29 #	39.02 #	31.02 #	28.53 #
Minimum:	75.29	39.02	31.02	28.53
Maximum:	75.29	39.02	31.02	28.53
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
11/07/2024 00:00	15.82	48.50	46.21	36.53
Average/Sum#:	15.82 #	48.50 #	46.21 #	36.53 #
Minimum:	15.82	48.50	46.21	36.53
Maximum:	15.82	48.50	46.21	36.53
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
11/08/2024 00:00	17.43	49.67	57.55	46.43

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/02/2025 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	17.43 #	49.67 #	57.55 #	46.43 #
Minimum:	17.43	49.67	57.55	46.43
Maximum:	17.43	49.67	57.55	46.43
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
--	--------------------------------	---------------------------------	--------------------------------	---------------------------------

11/09/2024 00:00	17.64	49.31	30.04	13.38
------------------	-------	-------	-------	-------

Average/Sum#:	17.64 #	49.31 #	30.04 #	13.38 #
Minimum:	17.64	49.31	30.04	13.38
Maximum:	17.64	49.31	30.04	13.38
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
--	--------------------------------	---------------------------------	--------------------------------	---------------------------------

11/10/2024 00:00	27.90	60.26	0.00	0.00
------------------	-------	-------	------	------

Average/Sum#:	27.90 #	60.26 #	0.00 #	0.00 #
Minimum:	27.90	60.26	0.00	0.00
Maximum:	27.90	60.26	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
--	--------------------------------	---------------------------------	--------------------------------	---------------------------------

11/11/2024 00:00	27.88	66.51	0.00	0.00
------------------	-------	-------	------	------

Average/Sum#:	27.88 #	66.51 #	0.00 #	0.00 #
Minimum:	27.88	66.51	0.00	0.00
Maximum:	27.88	66.51	0.00	0.00
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
11/12/2024 00:00	28.43	61.56	0.00	0.00
Average/Sum#:	28.43 #	61.56 #	0.00 #	0.00 #
Minimum:	28.43	61.56	0.00	0.00
Maximum:	28.43	61.56	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
11/13/2024 00:00	26.04	66.46	0.00	0.00
Average/Sum#:	26.04 #	66.46 #	0.00 #	0.00 #
Minimum:	26.04	66.46	0.00	0.00
Maximum:	26.04	66.46	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
11/14/2024 00:00	22.13	63.33	0.00	0.00
Average/Sum#:	22.13 #	63.33 #	0.00 #	0.00 #
Minimum:	22.13	63.33	0.00	0.00
Maximum:	22.13	63.33	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
11/15/2024 00:00	16.55	42.16	23.16	34.67

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/02/2025 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	16.55 #	42.16 #	23.16 #	34.67 #
Minimum:	16.55	42.16	23.16	34.67
Maximum:	16.55	42.16	23.16	34.67
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
--	--------------------------------	---------------------------------	--------------------------------	---------------------------------

11/16/2024 00:00	0.00	0.00	0.00	0.00
------------------	------	------	------	------

Average/Sum#:	0.00 #	0.00 #	0.00 #	0.00 #
Minimum:	0.00	0.00	0.00	0.00
Maximum:	0.00	0.00	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
--	--------------------------------	---------------------------------	--------------------------------	---------------------------------

11/17/2024 00:00	0.00	0.00	0.00	0.00
------------------	------	------	------	------

Average/Sum#:	0.00 #	0.00 #	0.00 #	0.00 #
Minimum:	0.00	0.00	0.00	0.00
Maximum:	0.00	0.00	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
--	--------------------------------	---------------------------------	--------------------------------	---------------------------------

11/18/2024 00:00	0.00	0.00	0.00	0.00
------------------	------	------	------	------

Average/Sum#:	0.00 #	0.00 #	0.00 #	0.00 #
Minimum:	0.00	0.00	0.00	0.00
Maximum:	0.00	0.00	0.00	0.00
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/02/2025 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
11/19/2024 00:00	0.00	0.00	0.00	0.00
Average/Sum#:	0.00 #	0.00 #	0.00 #	0.00 #
Minimum:	0.00	0.00	0.00	0.00
Maximum:	0.00	0.00	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
11/20/2024 00:00	119.95	19.76	0.00	0.00
Average/Sum#:	119.95 #	19.76 #	0.00 #	0.00 #
Minimum:	119.95	19.76	0.00	0.00
Maximum:	119.95	19.76	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
11/21/2024 00:00	14.16	1.63	0.00	0.00
Average/Sum#:	14.16 #	1.63 #	0.00 #	0.00 #
Minimum:	14.16	1.63	0.00	0.00
Maximum:	14.16	1.63	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
11/22/2024 00:00	82.30	74.80	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	82.30 #	74.80 #	0.00 #	0.00 #
Minimum:	82.30	74.80	0.00	0.00
Maximum:	82.30	74.80	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
11/23/2024 00:00	26.64	56.03	0.00	0.00

Average/Sum#:	26.64 #	56.03 #	0.00 #	0.00 #
Minimum:	26.64	56.03	0.00	0.00
Maximum:	26.64	56.03	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
11/24/2024 00:00	30.20	58.76	0.00	0.00

Average/Sum#:	30.20 #	58.76 #	0.00 #	0.00 #
Minimum:	30.20	58.76	0.00	0.00
Maximum:	30.20	58.76	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
11/25/2024 00:00	32.26	64.45	0.00	0.00

Average/Sum#:	32.26 #	64.45 #	0.00 #	0.00 #
Minimum:	32.26	64.45	0.00	0.00
Maximum:	32.26	64.45	0.00	0.00
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
11/26/2024 00:00	31.19	65.12	0.00	0.00
Average/Sum#:	31.19 #	65.12 #	0.00 #	0.00 #
Minimum:	31.19	65.12	0.00	0.00
Maximum:	31.19	65.12	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
11/27/2024 00:00	31.16	65.74	0.00	0.00
Average/Sum#:	31.16 #	65.74 #	0.00 #	0.00 #
Minimum:	31.16	65.74	0.00	0.00
Maximum:	31.16	65.74	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
11/28/2024 00:00	33.38	65.56	0.00	0.00
Average/Sum#:	33.38 #	65.56 #	0.00 #	0.00 #
Minimum:	33.38	65.56	0.00	0.00
Maximum:	33.38	65.56	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
11/29/2024 00:00	34.28	67.04	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/02/2025 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	34.28 #	67.04 #	0.00 #	0.00 #
Minimum:	34.28	67.04	0.00	0.00
Maximum:	34.28	67.04	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
11/30/2024 00:00	33.88	66.92	0.00	0.00

Average/Sum#:	33.88 #	66.92 #	0.00 #	0.00 #
Minimum:	33.88	66.92	0.00	0.00
Maximum:	33.88	66.92	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
12/01/2024 00:00	32.72	60.85	0.00	0.00

Average/Sum#:	32.72 #	60.85 #	0.00 #	0.00 #
Minimum:	32.72	60.85	0.00	0.00
Maximum:	32.72	60.85	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
12/02/2024 00:00	34.02	65.19	0.00	0.00

Average/Sum#:	34.02 #	65.19 #	0.00 #	0.00 #
Minimum:	34.02	65.19	0.00	0.00
Maximum:	34.02	65.19	0.00	0.00
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
12/03/2024 00:00	34.05	59.77	0.00	0.00
Average/Sum#:	34.05 #	59.77 #	0.00 #	0.00 #
Minimum:	34.05	59.77	0.00	0.00
Maximum:	34.05	59.77	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
12/04/2024 00:00	30.13	62.56	0.00	0.00
Average/Sum#:	30.13 #	62.56 #	0.00 #	0.00 #
Minimum:	30.13	62.56	0.00	0.00
Maximum:	30.13	62.56	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
12/05/2024 00:00	32.60	62.47	0.00	0.00
Average/Sum#:	32.60 #	62.47 #	0.00 #	0.00 #
Minimum:	32.60	62.47	0.00	0.00
Maximum:	32.60	62.47	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
12/06/2024 00:00	31.37	59.53	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/02/2025 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	31.37 #	59.53 #	0.00 #	0.00 #
Minimum:	31.37	59.53	0.00	0.00
Maximum:	31.37	59.53	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
12/07/2024 00:00	26.72	53.99	0.00	0.00

Average/Sum#:	26.72 #	53.99 #	0.00 #	0.00 #
Minimum:	26.72	53.99	0.00	0.00
Maximum:	26.72	53.99	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
12/08/2024 00:00	18.60	45.40	0.00	0.00

Average/Sum#:	18.60 #	45.40 #	0.00 #	0.00 #
Minimum:	18.60	45.40	0.00	0.00
Maximum:	18.60	45.40	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
12/09/2024 00:00	22.14	57.49	0.00	0.00

Average/Sum#:	22.14 #	57.49 #	0.00 #	0.00 #
Minimum:	22.14	57.49	0.00	0.00
Maximum:	22.14	57.49	0.00	0.00
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
12/10/2024 00:00	32.59	65.48	0.00	0.00
Average/Sum#:	32.59 #	65.48 #	0.00 #	0.00 #
Minimum:	32.59	65.48	0.00	0.00
Maximum:	32.59	65.48	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
12/11/2024 00:00	31.30	67.65	0.00	0.00
Average/Sum#:	31.30 #	67.65 #	0.00 #	0.00 #
Minimum:	31.30	67.65	0.00	0.00
Maximum:	31.30	67.65	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
12/12/2024 00:00	26.63	69.04	0.00	0.00
Average/Sum#:	26.63 #	69.04 #	0.00 #	0.00 #
Minimum:	26.63	69.04	0.00	0.00
Maximum:	26.63	69.04	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
12/13/2024 00:00	29.55	66.24	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/02/2025 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	29.55 #	66.24 #	0.00 #	0.00 #
Minimum:	29.55	66.24	0.00	0.00
Maximum:	29.55	66.24	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
12/14/2024 00:00	22.72	53.19	0.00	0.00

Average/Sum#:	22.72 #	53.19 #	0.00 #	0.00 #
Minimum:	22.72	53.19	0.00	0.00
Maximum:	22.72	53.19	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
12/15/2024 00:00	21.34	49.12	0.00	0.00

Average/Sum#:	21.34 #	49.12 #	0.00 #	0.00 #
Minimum:	21.34	49.12	0.00	0.00
Maximum:	21.34	49.12	0.00	0.00
%SI	0.00	0.00	0.00	0.00

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOx, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOx, Lb 1 Day(s)
12/16/2024 00:00	33.58	64.91	0.00	0.00

Average/Sum#:	33.58 #	64.91 #	0.00 #	0.00 #
Minimum:	33.58	64.91	0.00	0.00
Maximum:	33.58	64.91	0.00	0.00
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
12/17/2024 00:00	32.65	65.58	0.00	0.00
Average/Sum#:	32.65 #	65.58 #	0.00 #	0.00 #
Minimum:	32.65	65.58	0.00	0.00
Maximum:	32.65	65.58	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
12/18/2024 00:00	28.90	64.74	0.00	0.00
Average/Sum#:	28.90 #	64.74 #	0.00 #	0.00 #
Minimum:	28.90	64.74	0.00	0.00
Maximum:	28.90	64.74	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
12/19/2024 00:00	29.34	62.07	0.00	0.00
Average/Sum#:	29.34 #	62.07 #	0.00 #	0.00 #
Minimum:	29.34	62.07	0.00	0.00
Maximum:	29.34	62.07	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
12/20/2024 00:00	32.10	65.74	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/02/2025 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	32.10 #	65.74 #	0.00 #	0.00 #
Minimum:	32.10	65.74	0.00	0.00
Maximum:	32.10	65.74	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
12/21/2024 00:00	31.04	64.40	0.00	0.00
Average/Sum#:	31.04 #	64.40 #	0.00 #	0.00 #
Minimum:	31.04	64.40	0.00	0.00
Maximum:	31.04	64.40	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
12/22/2024 00:00	30.87	65.29	0.00	0.00
Average/Sum#:	30.87 #	65.29 #	0.00 #	0.00 #
Minimum:	30.87	65.29	0.00	0.00
Maximum:	30.87	65.29	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
12/23/2024 00:00	27.77	60.09	0.00	0.00
Average/Sum#:	27.77 #	60.09 #	0.00 #	0.00 #
Minimum:	27.77	60.09	0.00	0.00
Maximum:	27.77	60.09	0.00	0.00
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
12/24/2024 00:00	29.64	65.08	0.00	0.00
Average/Sum#:	29.64 #	65.08 #	0.00 #	0.00 #
Minimum:	29.64	65.08	0.00	0.00
Maximum:	29.64	65.08	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
12/25/2024 00:00	17.84	47.41	0.00	0.00
Average/Sum#:	17.84 #	47.41 #	0.00 #	0.00 #
Minimum:	17.84	47.41	0.00	0.00
Maximum:	17.84	47.41	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
12/26/2024 00:00	27.10	63.00	0.00	0.00
Average/Sum#:	27.10 #	63.00 #	0.00 #	0.00 #
Minimum:	27.10	63.00	0.00	0.00
Maximum:	27.10	63.00	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
12/27/2024 00:00	23.56	58.54	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/02/2025 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	23.56 #	58.54 #	0.00 #	0.00 #
Minimum:	23.56	58.54	0.00	0.00
Maximum:	23.56	58.54	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
12/28/2024 00:00	24.28	59.47	0.00	0.00
Average/Sum#:	24.28 #	59.47 #	0.00 #	0.00 #
Minimum:	24.28	59.47	0.00	0.00
Maximum:	24.28	59.47	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
12/29/2024 00:00	23.39	57.96	0.00	0.00
Average/Sum#:	23.39 #	57.96 #	0.00 #	0.00 #
Minimum:	23.39	57.96	0.00	0.00
Maximum:	23.39	57.96	0.00	0.00
%SI	0.00	0.00	0.00	0.00
	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO, Lb	NOx, Lb	CO, Lb	NOx, Lb
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
12/30/2024 00:00	30.87	40.64	0.00	0.00
Average/Sum#:	30.87 #	40.64 #	0.00 #	0.00 #
Minimum:	30.87	40.64	0.00	0.00
Maximum:	30.87	40.64	0.00	0.00
%SI	0.00	0.00	0.00	0.00

AQ32 DAILY NOX CO



From: 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/02/2025 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Lb 1 Day(s)	Unit CT1 NOX, Lb 1 Day(s)	Unit CT2 CO, Lb 1 Day(s)	Unit CT2 NOX, Lb 1 Day(s)
12/31/2024 00:00	0.00	0.00	0.00	0.00
Average/Sum#:	0.00 #	0.00 #	0.00 #	0.00 #
Minimum:	0.00	0.00	0.00	0.00
Maximum:	0.00	0.00	0.00	0.00
%SI	0.00	0.00	0.00	0.00