

**DOCKETED**

<b>Docket Number:</b>	01-AFC-06C
<b>Project Title:</b>	Magnolia Power Project-Compliance
<b>TN #:</b>	261256
<b>Document Title:</b>	Magnolia Power Project
<b>Description:</b>	Air Quality Data Request
<b>Filer:</b>	susan fleming
<b>Organization:</b>	California Energy Commission
<b>Submitter Role:</b>	Commission Staff
<b>Submission Date:</b>	1/23/2025 11:47:17 AM
<b>Docketed Date:</b>	1/23/2025



**CALIFORNIA  
ENERGY COMMISSION**



January 23, 2025

Claudia Reyes, Senior Environmental Engineer  
Burbank Water and Power  
320 N. Lake St.  
Burbank, CA 91502

### **Data Requests for Magnolia Power Project (01-AFC-06C)**


Dear Claudia Reyes:

The California Energy Commission (CEC) staff is asking for the information specified in the enclosed Data Requests which is necessary for the staff analysis of the Magnolia Power Project (MPP) petition to amend ([TN#259131](#)). The proposed project changes include an improvement to the on-site stormwater system consisting of installation of an on-site stormwater capture, retention, reuse, and infiltration system near MPP.

These Data Requests seek further information in the area of Air Quality, based on the contents of the petition to amend.

To assist CEC staff in timely completing its environmental review and to meet the requirements of CEQA (see Cal. Code Regs., tit. 14, §§ 15108, 15109), CEC staff is requesting responses to the data requests within 30 days. If you are unable to provide the information requested or need to revise the timeline, please let me know within 10 days of receipt of this letter.

If you have any questions, please email me at [Joseph.Douglas@energy.ca.gov](mailto:Joseph.Douglas@energy.ca.gov).

A handwritten signature in black ink that reads "Joseph Douglas". The script is cursive and fluid.

**Joseph Douglas | Compliance Project Manager**  
California Energy Commission  
Siting, Transmission, and Environmental Protection Division  
Safety and Reliability Branch  
Compliance Monitoring and Enforcement Unit  
715 P Street, MS-2000, Sacramento, CA 95814  
Work/Cell: (916) 956-9527  
Email: [joseph.douglas@energy.ca.gov](mailto:joseph.douglas@energy.ca.gov)

Enclosure: Data Requests

# **MAGNOLIA POWER PROJECT (01-AFC-06C)**

## **AIR QUALITY DATA REQUESTS**

### **TECHNICAL AREA**

**Authors: Jacquelyn Record, Wenjun Qian**

### **BACKGROUND**

The Petition proposes to make on-site drainage improvements to the project site which would allow for a small percentage of the treated stormwater “to be used for cooling tower make-up water at Magnolia Power Project (MPP) or infiltrated into the ground, or a combination of the two” ([TN#259131](#)). Staff needs confirmation no conditions of certification (COCs) for Air Quality would need to be modified and emissions of the cooling tower would not exceed the permitted limits.

### **DATA REQUESTS**

**AQ-1.** Please estimate the PM emissions associated with this proposed project modification.

**AQ-2.** Confirm the project would remain in compliance with the 30.25 lbs/day of condition of certification **AQ-36**.