

| <b>DOCKETED</b>         |                                                                                             |
|-------------------------|---------------------------------------------------------------------------------------------|
| <b>Docket Number:</b>   | 21-TPG-01                                                                                   |
| <b>Project Title:</b>   | Roseville Energy Park Temporary Power Generators                                            |
| <b>TN #:</b>            | 261345                                                                                      |
| <b>Document Title:</b>  | Roseville Energy Park Temporary Generators Quarterly Operational Report - Q4 2024 - Part 3s |
| <b>Description:</b>     | N/A                                                                                         |
| <b>Filer:</b>           | Roseville Electric Compliance                                                               |
| <b>Organization:</b>    | Roseville Electric                                                                          |
| <b>Submitter Role:</b>  | Public Agency                                                                               |
| <b>Submission Date:</b> | 1/28/2025 1:48:01 PM                                                                        |
| <b>Docketed Date:</b>   | 1/28/2025                                                                                   |

### **III. Emissions Deviations**

# CO LbPerHr 1-Hour Block Excess Emissions



CT5

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:54 Location: Roseville, CA

Tag Name: CT5\_CO\_Norm\_LbPerHr\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# CO Ppmvdc 1-Hour Block Excess Emissions



CT5

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:55 Location: Roseville, CA

Tag Name: CT5\_CO\_Norm\_Ppmvdc\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# CO Lbs SUSd 1-Hour Block Excess Emissions



CT5

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:55 Location: Roseville, CA

Tag Name: CT5\_CO\_SUSd\_Lbs\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# Startup/Shutdown Event Report

## CT5 - CO Lbs Per Startup/Shutdown



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 11:57 Location: Roseville, CA

Tag Name: CT5\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 0.00 Hours  
Non-Operating Time: 2,208.00 Hours Report Time: 2,208.00 Hours

### Unit Operation and Excess Events

No Startup or Shutdown Events were found in the reporting period.

# Startup/Shutdown Event Report

CT5 - CO Lbs Per Startup/Shutdown



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 11:57 Location: Roseville, CA

Tag Name: CT5\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 0.00 Hours  
Non-Operating Time: 2,208.00 Hours Report Time: 2,208.00 Hours

## Event Invalid Information

# Startup/Shutdown Event Report

CT5 - CO Lbs Per Startup/Shutdown



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 11:57 Location: Roseville, CA

Tag Name: CT5\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 0.00 Hours  
Non-Operating Time: 2,208.00 Hours Report Time: 2,208.00 Hours

## Periodic Excess and Invalid Summary

# NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT5

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:57 Location: Roseville, CA

Tag Name: CT5\_NH3Slip\_Ppmvdc\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# NOx LbPerHr 1-Hour Block Excess Emissions



CT5

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:58 Location: Roseville, CA

Tag Name: CT5\_NOx\_Norm\_LbPerHr\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# NOx Ppmvdc 1-Hour Block Excess Emissions



CT5

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:58 Location: Roseville, CA

Tag Name: CT5\_NOx\_Norm\_Ppmvdc\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# NOx Lbs SUSd 1-Hour Block Excess Emissions

CT5

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:59 Location: Roseville, CA



Tag Name: CT5\_NOx\_SUSd\_Lbs\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# Startup/Shutdown Event Report

## CT5 - NOx Lbs Per Startup/Shutdown



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 11:59 Location: Roseville, CA

Tag Name: CT5\_NOx\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 0.00 Hours  
Non-Operating Time: 2,208.00 Hours Report Time: 2,208.00 Hours

### Unit Operation and Excess Events

No Startup or Shutdown Events were found in the reporting period.

# Startup/Shutdown Event Report

## CT5 - NOx Lbs Per Startup/Shutdown



**From:** 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY  
**Generated:** 01/02/2025 11:59 **Location:** Roseville, CA  
**Tag Name:** CT5\_NOx\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission  
**Total Operating Time:** 0.00 Hours  
Non-Operating Time: 2,208.00 Hours Report Time: 2,208.00 Hours

Event Invalid Information

# Startup/Shutdown Event Report

## CT5 - NOx Lbs Per Startup/Shutdown



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 11:59 Location: Roseville, CA

Tag Name: CT5\_NOx\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 0.00 Hours  
Non-Operating Time: 2,208.00 Hours Report Time: 2,208.00 Hours

### Periodic Excess and Invalid Summary

# PM10 LbPerHr 1-Hour Block Excess Emissions

CT5



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 12:00 Location: Roseville, CA

Tag Name: CT5\_PM10\_LbPerHr\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# S02 LbPerHr 1-Hour Block Excess Emissions



CT5

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 12:00 Location: Roseville, CA

Tag Name: CT5\_S02\_P60\_LbPerHr\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# VOC LbPerHr 1-Hour Block Excess Emissions



CT5

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 12:01 Location: Roseville, CA

Tag Name: CT5\_VOC\_Norm\_LbPerHr\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# VOC SUSd Lb 1-Hour Block Excess Emissions



CT5

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 12:01 Location: Roseville, CA

Tag Name: CT5\_VOC\_SUSd\_Lbs\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# Startup/Shutdown Event Report

## CT5 - VOC Lbs Per Startup/Shutdown



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 12:02 Location: Roseville, CA

Tag Name: CT5\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 0.00 Hours  
Non-Operating Time: 2,208.00 Hours Report Time: 2,208.00 Hours

### Unit Operation and Excess Events

No Startup or Shutdown Events were found in the reporting period.

# Startup/Shutdown Event Report

## CT5 - VOC Lbs Per Startup/Shutdown



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 12:02 Location: Roseville, CA

Tag Name: CT5\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 0.00 Hours  
Non-Operating Time: 2,208.00 Hours Report Time: 2,208.00 Hours

Event Invalid Information

# Startup/Shutdown Event Report

## CT5 - VOC Lbs Per Startup/Shutdown



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 12:02 Location: Roseville, CA

Tag Name: CT5\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 0.00 Hours  
Non-Operating Time: 2,208.00 Hours Report Time: 2,208.00 Hours

### Periodic Excess and Invalid Summary

# CO LbPerHr 1-Hour Block Excess Emissions



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 12:04 Location: Roseville, CA

Tag Name: CT6\_CO\_Norm\_LbPerHr\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# CO Ppmvdc 1-Hour Block Excess Emissions



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 12:04 Location: Roseville, CA

Tag Name: CT6\_CO\_Norm\_Ppmvdc\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# CO Lbs SUSd 1-Hour Block Excess Emissions



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 12:05 Location: Roseville, CA

Tag Name: CT6\_CO\_SUSd\_Lbs\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# Startup/Shutdown Event Report

## CT6 - CO Lbs Per Startup/Shutdown



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 12:06 Location: Roseville, CA

Tag Name: CT6\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 0.00 Hours  
Non-Operating Time: 2,208.00 Hours Report Time: 2,208.00 Hours

### Unit Operation and Excess Events

No Startup or Shutdown Events were found in the reporting period.

# Startup/Shutdown Event Report

## CT6 - CO Lbs Per Startup/Shutdown



**From:** 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY  
**Generated:** 01/02/2025 12:06 **Location:** Roseville, CA  
**Tag Name:** CT6\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission  
**Total Operating Time:** 0.00 Hours  
Non-Operating Time: 2,208.00 Hours Report Time: 2,208.00 Hours

Event Invalid Information

# Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 12:06 Location: Roseville, CA

Tag Name: CT6\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 0.00 Hours  
Non-Operating Time: 2,208.00 Hours Report Time: 2,208.00 Hours

## Periodic Excess and Invalid Summary

# NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 12:06 Location: Roseville, CA

Tag Name: CT6\_NH3Slip\_Ppmvdc\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# NOx LbPerHr 1-Hour Block Excess Emissions



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 12:07 Location: Roseville, CA

Tag Name: CT6\_NOx\_Norm\_LbPerHr\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# NOx Ppmvdc 1-Hour Block Excess Emissions



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 12:07 Location: Roseville, CA

Tag Name: CT6\_NOx\_Norm\_Ppmvdc\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# NOx Lbs SUSd 1-Hour Block Excess Emissions



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 12:08 Location: Roseville, CA

Tag Name: CT6\_NOx\_SUSd\_Lbs\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# Startup/Shutdown Event Report

## CT6 - NOx Lbs Per Startup/Shutdown



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 12:08 Location: Roseville, CA

Tag Name: CT6\_NOx\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 0.00 Hours  
Non-Operating Time: 2,208.00 Hours Report Time: 2,208.00 Hours

### Unit Operation and Excess Events

No Startup or Shutdown Events were found in the reporting period.

# Startup/Shutdown Event Report

## CT6 - NOx Lbs Per Startup/Shutdown



**From:** 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY  
**Generated:** 01/02/2025 12:08 **Location:** Roseville, CA  
**Tag Name:** CT6\_NOx\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission  
**Total Operating Time:** 0.00 Hours  
Non-Operating Time: 2,208.00 Hours Report Time: 2,208.00 Hours

Event Invalid Information

# Startup/Shutdown Event Report

## CT6 - NOx Lbs Per Startup/Shutdown



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 12:08 Location: Roseville, CA

Tag Name: CT6\_NOx\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 0.00 Hours  
Non-Operating Time: 2,208.00 Hours Report Time: 2,208.00 Hours

### Periodic Excess and Invalid Summary

# PM10 LbPerHr 1-Hour Block Excess Emissions



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 12:09 Location: Roseville, CA

Tag Name: CT6\_PM10\_LbPerHr\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# S02 LbPerHr 1-Hour Block Excess Emissions



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 12:09 Location: Roseville, CA

Tag Name: CT6\_S02\_P60\_LbPerHr\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# VOC LbPerHr 1-Hour Block Excess Emissions



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 12:10 Location: Roseville, CA

Tag Name: CT6\_VOC\_Norm\_LbPerHr\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# VOC SUSd Lb 1-Hour Block Excess Emissions



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 12:10 Location: Roseville, CA

Tag Name: CT6\_VOC\_SUSd\_Lbs\_1H  
Total Operating Time: 0.00 Hour(s) No Exclusions Allowed  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

|                                                       |              |
|-------------------------------------------------------|--------------|
| Total Operating Time:                                 | 0.00 Hour(s) |
| Total Duration (Online only):                         | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 %       |
| Time in compliance as a percentage of operating time: | 100.00 %     |

# Startup/Shutdown Event Report

## CT6 - VOC Lbs Per Startup/Shutdown



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 12:10 Location: Roseville, CA

Tag Name: CT6\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 0.00 Hours  
Non-Operating Time: 2,208.00 Hours Report Time: 2,208.00 Hours

### Unit Operation and Excess Events

No Startup or Shutdown Events were found in the reporting period.

# Startup/Shutdown Event Report

## CT6 - VOC Lbs Per Startup/Shutdown



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 12:10 Location: Roseville, CA

Tag Name: CT6\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 0.00 Hours  
Non-Operating Time: 2,208.00 Hours Report Time: 2,208.00 Hours

Event Invalid Information

# Startup/Shutdown Event Report

## CT6 - VOC Lbs Per Startup/Shutdown



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/02/2025 12:10 Location: Roseville, CA

Tag Name: CT6\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 0.00 Hours  
Non-Operating Time: 2,208.00 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

# Startup / Shutdown Events

CT5



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/08/2025 10:01 Location: Roseville, CA

## Unit Offline

Tag Name: CT5\_UnitOn\_TF\_1H

| Offline Periods  |                  |                     |
|------------------|------------------|---------------------|
| Start Time       | End Time         | Duration in Hour(s) |
| 10/01/2024 00:00 | 12/31/2024 23:00 | 2208                |

# Startup / Shutdown Events

CT5



**From:** 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY  
**Generated:** 01/08/2025 10:01 **Location:** Roseville, CA

---

**Operating Time Summary**

|                                                    |                  |
|----------------------------------------------------|------------------|
| Available Data for Report (excludes missing data): | 2,208.00 Hour(s) |
| Total Offline:                                     | 2,208.00 Hour(s) |
| Offline Percentage:                                | 100.00 %         |
| Total Online:                                      | 0.00 Hour(s)     |
| Online Percentage:                                 | 0.00 %           |

# Startup / Shutdown Events

CT5



**From:** 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY  
**Generated:** 01/08/2025 10:01 **Location:** Roseville, CA

---

No startup/shutdown events found.

# Startup / Shutdown Events

## CT6



**From:** 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY  
**Generated:** 01/08/2025 09:59 **Location:** Roseville, CA

---

### Unit offline

**Tag Name:** CT6\_UnitOn\_TF\_1H

| Offline Periods  |                  |                     |
|------------------|------------------|---------------------|
| Start Time       | End Time         | Duration in Hour(s) |
| 10/01/2024 00:00 | 12/31/2024 23:00 | 2208                |

# Startup / Shutdown Events

CT6



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/08/2025 09:59 Location: Roseville, CA

## Operating Time Summary

|                                                    |                  |
|----------------------------------------------------|------------------|
| Available Data for Report (excludes missing data): | 2,208.00 Hour(s) |
| Total Offline:                                     | 2,208.00 Hour(s) |
| Offline Percentage:                                | 100.00 %         |
| Total Online:                                      | 0.00 Hour(s)     |
| Online Percentage:                                 | 0.00 %           |

# Startup / Shutdown Events

CT6



**From:** 10/01/2024 00:00 **To:** 12/31/2024 23:59 **Facility Name:** ROSEVILLE ENERGY  
**Generated:** 01/08/2025 09:59 **Location:** Roseville, CA

---

No startup/shutdown events found.

# CO Invalid Data

CT5

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:48 Location: Roseville, CA



Tag Name: CT5\_CO\_Ppm\_1H  
Total Operating Time: 0.00 Hour(s)  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

|                                       |              |
|---------------------------------------|--------------|
| Total Operating Time:                 | 0.00 Hour(s) |
| Total Monitor Downtime (Online only): | 0.00 Hour(s) |
| Percent Monitor Availability:         | 100.00 %     |
| Percent Monitor Downtime:             | 0.00 %       |

# NOx Invalid Data



CT5

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:49 Location: Roseville, CA

Tag Name: CT5\_NOx\_Ppm\_1H  
Total Operating Time: 0.00 Hour(s)  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

|                                       |              |
|---------------------------------------|--------------|
| Total Operating Time:                 | 0.00 Hour(s) |
| Total Monitor Downtime (Online only): | 0.00 Hour(s) |
| Percent Monitor Availability:         | 100.00 %     |
| Percent Monitor Downtime:             | 0.00 %       |

# NOx SCR Invalid Data



CT5

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:50 Location: Roseville, CA

Tag Name: CT5\_NOx\_SCR\_Ppm\_1H  
Total Operating Time: 0.00 Hour(s)  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

|                                       |              |
|---------------------------------------|--------------|
| Total Operating Time:                 | 0.00 Hour(s) |
| Total Monitor Downtime (Online only): | 0.00 Hour(s) |
| Percent Monitor Availability:         | 100.00 %     |
| Percent Monitor Downtime:             | 0.00 %       |

# O2 Invalid Data

CT5



From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:50 Location: Roseville, CA

Tag Name: CT5\_O2Dry\_Pct\_1H  
Total Operating Time: 0.00 Hour(s)  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

|                                       |              |
|---------------------------------------|--------------|
| Total Operating Time:                 | 0.00 Hour(s) |
| Total Monitor Downtime (Online only): | 0.00 Hour(s) |
| Percent Monitor Availability:         | 100.00 %     |
| Percent Monitor Downtime:             | 0.00 %       |

# CO Invalid Data



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:51 Location: Roseville, CA

Tag Name: CT6\_CO\_Ppm\_1H  
Total Operating Time: 0.00 Hour(s)  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

|                                       |              |
|---------------------------------------|--------------|
| Total Operating Time:                 | 0.00 Hour(s) |
| Total Monitor Downtime (Online only): | 0.00 Hour(s) |
| Percent Monitor Availability:         | 100.00 %     |
| Percent Monitor Downtime:             | 0.00 %       |

# NOx Invalid Data



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:51 Location: Roseville, CA

Tag Name: CT6\_NOx\_Ppm\_1H  
Total Operating Time: 0.00 Hour(s)  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

|                                       |              |
|---------------------------------------|--------------|
| Total Operating Time:                 | 0.00 Hour(s) |
| Total Monitor Downtime (Online only): | 0.00 Hour(s) |
| Percent Monitor Availability:         | 100.00 %     |
| Percent Monitor Downtime:             | 0.00 %       |

# NOx SCR Invalid Data



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:52 Location: Roseville, CA

Tag Name: CT6\_NOx\_SCR\_Ppm\_1H  
Total Operating Time: 0.00 Hour(s)  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

|                                       |              |
|---------------------------------------|--------------|
| Total Operating Time:                 | 0.00 Hour(s) |
| Total Monitor Downtime (Online only): | 0.00 Hour(s) |
| Percent Monitor Availability:         | 100.00 %     |
| Percent Monitor Downtime:             | 0.00 %       |

# O2 Invalid Data



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:52 Location: Roseville, CA

Tag Name: CT6\_O2Dry\_Pct\_1H  
Total Operating Time: 0.00 Hour(s)  
Non-Operating Time: 2,208.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

|                                       |              |
|---------------------------------------|--------------|
| Total Operating Time:                 | 0.00 Hour(s) |
| Total Monitor Downtime (Online only): | 0.00 Hour(s) |
| Percent Monitor Availability:         | 100.00 %     |
| Percent Monitor Downtime:             | 0.00 %       |

# CO Ppmvdc EDS/CMS Summary Report



CT5

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:42 Location: Roseville, CA  
Description: Electric Utility

CMS Data from: CT5\_CO\_Norm\_Ppmvdc\_1H, CT5\_UnitOn\_TF\_1H  
EDS Data from: CT5\_CO\_Norm\_Ppmvdc\_1H, CT5\_UnitOn\_TF\_1H  
Emission Limitation: 4.0  
No Value Exclusions Allowed  
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T300  
Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
Process Unit(s) Description:  
Operating time for EDS: 0.00 Hour(s)  
Operating time for CMS: 0.00 Hour(s)

## Emission Data Summary

|                                                               |        |
|---------------------------------------------------------------|--------|
| 1. Duration of excess emission in reporting period due to:    |        |
| a. Startup/shutdown                                           | 0      |
| b. Control equipment problems                                 | 0      |
| c. Process Problems                                           | 0      |
| d. Other known causes                                         | 0      |
| e. Unknown causes                                             | 0      |
| 2. Upset Conditions                                           | 0      |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0      |
| 4. Time of Excess Emission as a percentage of operating time  | 0.00   |
| 5. Time in compliance as percentage of operating time         | 100.00 |

## CMS Performance Summary

|                                                         |        |
|---------------------------------------------------------|--------|
| 1. CMS downtime in reporting period due to:             |        |
| a. Monitor equipment malfunctions                       | 0      |
| b. Non-Monitor equipment malfunctions                   | 0      |
| c. Quality assurance calibration                        | 0      |
| d. Other known causes                                   | 0      |
| e. Unknown causes                                       | 0      |
| 2. Total CMS Downtime                                   | 0      |
| 3. Total Downtime as a percentage of operating time     | 0.00   |
| 4. Total Availability as a percentage of operating time | 100.00 |

*Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.*

# CO Lb/Hr EDS/CMS Summary Report

CT5

From: 10/01/2024 00:00 To: 12/31/2024 23:59  
Generated: 01/02/2025 11:43

Facility Name: ROSEVILLE ENERGY  
Location: Roseville, CA  
Description: Electric Utility



CMS Data from: CT5\_CO\_Norm\_LbPerHr\_1H, CT5\_UnitOn\_TF\_1H  
EDS Data from: CT5\_CO\_Norm\_LbPerHr\_1H, CT5\_UnitOn\_TF\_1H  
Emission Limitation: 2.64  
No Value Exclusions Allowed  
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T300  
Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
Process Unit(s) Description:  
Operating time for EDS: 0.00 Hour(s)  
Operating time for CMS: 0.00 Hour(s)

## Emission Data Summary

|                                                               |        |
|---------------------------------------------------------------|--------|
| 1. Duration of excess emission in reporting period due to:    |        |
| a. Startup/shutdown                                           | 0      |
| b. Control equipment problems                                 | 0      |
| c. Process Problems                                           | 0      |
| d. Other known causes                                         | 0      |
| e. Unknown causes                                             | 0      |
| 2. Upset Conditions                                           | 0      |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0      |
| 4. Time of Excess Emission as a percentage of operating time  | 0.00   |
| 5. Time in compliance as percentage of operating time         | 100.00 |

## CMS Performance Summary

|                                                         |        |
|---------------------------------------------------------|--------|
| 1. CMS downtime in reporting period due to:             |        |
| a. Monitor equipment malfunctions                       | 0      |
| b. Non-Monitor equipment malfunctions                   | 0      |
| c. Quality assurance calibration                        | 0      |
| d. Other known causes                                   | 0      |
| e. Unknown causes                                       | 0      |
| 2. Total CMS Downtime                                   | 0      |
| 3. Total Downtime as a percentage of operating time     | 0.00   |
| 4. Total Availability as a percentage of operating time | 100.00 |

*Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.*

# CO SUSD Lb/Hr EDS/CMS Summary Report



CT5

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:43 Location: Roseville, CA  
Description: Electric Utility

CMS Data from: CT5\_CO\_SUSD\_Lbs\_1H, CT5\_UnitOn\_TF\_1H  
EDS Data from: CT5\_CO\_SUSD\_Lbs\_1H, CT5\_UnitOn\_TF\_1H  
Emission Limitation: 41.00  
No Value Exclusions Allowed  
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T300  
Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
Process Unit(s) Description:  
Operating time for EDS: 0.00 Hour(s)  
Operating time for CMS: 0.00 Hour(s)

## Emission Data Summary

|                                                               |        |
|---------------------------------------------------------------|--------|
| 1. Duration of excess emission in reporting period due to:    |        |
| a. Startup/shutdown                                           | 0      |
| b. Control equipment problems                                 | 0      |
| c. Process Problems                                           | 0      |
| d. Other known causes                                         | 0      |
| e. Unknown causes                                             | 0      |
| 2. Upset Conditions                                           | 0      |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0      |
| 4. Time of Excess Emission as a percentage of operating time  | 0.00   |
| 5. Time in compliance as percentage of operating time         | 100.00 |

## CMS Performance Summary

|                                                         |        |
|---------------------------------------------------------|--------|
| 1. CMS downtime in reporting period due to:             |        |
| a. Monitor equipment malfunctions                       | 0      |
| b. Non-Monitor equipment malfunctions                   | 0      |
| c. Quality assurance calibration                        | 0      |
| d. Other known causes                                   | 0      |
| e. Unknown causes                                       | 0      |
| 2. Total CMS Downtime                                   | 0      |
| 3. Total Downtime as a percentage of operating time     | 0.00   |
| 4. Total Availability as a percentage of operating time | 100.00 |

*Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.*

# NOx Ppmvdc EDS/CMS Summary Report



CT5

From: 10/01/2024 00:00 To: 12/31/2024 23:59

Generated: 01/02/2025 11:43

Facility Name: ROSEVILLE ENERGY

Location: Roseville, CA

Description: Electric Utility

CMS Data from:

EDS Data from:

Emission Limitation:

No Value Exclusions Allowed

Monitor Manufacturer and Model No.:

Date of Latest CMS Certification or Audit:

Process Unit(s) Description:

Operating time for EDS:

Operating time for CMS:

CT5\_NOx\_Norm\_Ppmvdc\_1H, CT5\_UnitOn\_TF\_1H

CT5\_NOx\_Norm\_Ppmvdc\_1H, CT5\_UnitOn\_TF\_1H

2.5

TELEDYNE MONITOR LABS INC, T200H

04/01/2024 00:00

0.00 Hour(s)

0.00 Hour(s)

## Emission Data Summary

|                                                               |        |
|---------------------------------------------------------------|--------|
| 1. Duration of excess emission in reporting period due to:    |        |
| a. Startup/shutdown                                           | 0      |
| b. Control equipment problems                                 | 0      |
| c. Process Problems                                           | 0      |
| d. Other known causes                                         | 0      |
| e. Unknown causes                                             | 0      |
| 2. Upset Conditions                                           | 0      |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0      |
| 4. Time of Excess Emission as a percentage of operating time  | 0.00   |
| 5. Time in compliance as percentage of operating time         | 100.00 |

## CMS Performance Summary

|                                                         |        |
|---------------------------------------------------------|--------|
| 1. CMS downtime in reporting period due to:             |        |
| a. Monitor equipment malfunctions                       | 0      |
| b. Non-Monitor equipment malfunctions                   | 0      |
| c. Quality assurance calibration                        | 0      |
| d. Other known causes                                   | 0      |
| e. Unknown causes                                       | 0      |
| 2. Total CMS Downtime                                   | 0      |
| 3. Total Downtime as a percentage of operating time     | 0.00   |
| 4. Total Availability as a percentage of operating time | 100.00 |

*Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.*

# NOx Lb/Hr EDS/CMS Summary Report



CT5

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:44 Location: Roseville, CA  
Description: Electric Utility

CMS Data from: CT5\_NOx\_Norm\_LbPerHr\_1H, CT5\_UnitOn\_TF\_1H  
EDS Data from: CT5\_NOx\_Norm\_LbPerHr\_1H, CT5\_UnitOn\_TF\_1H  
Emission Limitation: 2.71  
No Value Exclusions Allowed  
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H  
Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
Process Unit(s) Description:  
Operating time for EDS: 0.00 Hour(s)  
Operating time for CMS: 0.00 Hour(s)

## Emission Data Summary

|                                                               |        |
|---------------------------------------------------------------|--------|
| 1. Duration of excess emission in reporting period due to:    |        |
| a. Startup/shutdown                                           | 0      |
| b. Control equipment problems                                 | 0      |
| c. Process Problems                                           | 0      |
| d. Other known causes                                         | 0      |
| e. Unknown causes                                             | 0      |
| 2. Upset Conditions                                           | 0      |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0      |
| 4. Time of Excess Emission as a percentage of operating time  | 0.00   |
| 5. Time in compliance as percentage of operating time         | 100.00 |

## CMS Performance Summary

|                                                         |        |
|---------------------------------------------------------|--------|
| 1. CMS downtime in reporting period due to:             |        |
| a. Monitor equipment malfunctions                       | 0      |
| b. Non-Monitor equipment malfunctions                   | 0      |
| c. Quality assurance calibration                        | 0      |
| d. Other known causes                                   | 0      |
| e. Unknown causes                                       | 0      |
| 2. Total CMS Downtime                                   | 0      |
| 3. Total Downtime as a percentage of operating time     | 0.00   |
| 4. Total Availability as a percentage of operating time | 100.00 |

*Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.*

# NOx SUSD Lb/Hr EDS/CMS Summary Report



CT5

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:44 Location: Roseville, CA  
Description: Electric Utility

CMS Data from: CT5\_NOx\_SUSD\_Lbs\_1H, CT5\_UnitOn\_TF\_1H  
EDS Data from: CT5\_NOx\_SUSD\_Lbs\_1H, CT5\_UnitOn\_TF\_1H  
Emission Limitation: 6.50  
No Value Exclusions Allowed  
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H  
Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
Process Unit(s) Description:  
Operating time for EDS: 0.00 Hour(s)  
Operating time for CMS: 0.00 Hour(s)

## Emission Data Summary

|                                                               |        |
|---------------------------------------------------------------|--------|
| 1. Duration of excess emission in reporting period due to:    |        |
| a. Startup/shutdown                                           | 0      |
| b. Control equipment problems                                 | 0      |
| c. Process Problems                                           | 0      |
| d. Other known causes                                         | 0      |
| e. Unknown causes                                             | 0      |
| 2. Upset Conditions                                           | 0      |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0      |
| 4. Time of Excess Emission as a percentage of operating time  | 0.00   |
| 5. Time in compliance as percentage of operating time         | 100.00 |

## CMS Performance Summary

|                                                         |        |
|---------------------------------------------------------|--------|
| 1. CMS downtime in reporting period due to:             |        |
| a. Monitor equipment malfunctions                       | 0      |
| b. Non-Monitor equipment malfunctions                   | 0      |
| c. Quality assurance calibration                        | 0      |
| d. Other known causes                                   | 0      |
| e. Unknown causes                                       | 0      |
| 2. Total CMS Downtime                                   | 0      |
| 3. Total Downtime as a percentage of operating time     | 0.00   |
| 4. Total Availability as a percentage of operating time | 100.00 |

*Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.*

# CO Ppmvdc EDS/CMS Summary Report



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:45 Location: Roseville, CA  
Description: Electric Utility

CMS Data from: CT6\_CO\_Norm\_Ppmvdc\_1H, CT6\_UnitOn\_TF\_1H  
EDS Data from: CT6\_CO\_Norm\_Ppmvdc\_1H, CT6\_UnitOn\_TF\_1H  
Emission Limitation: 4.0  
No Value Exclusions Allowed  
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T300  
Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
Process Unit(s) Description:  
Operating time for EDS: 0.00 Hour(s)  
Operating time for CMS: 0.00 Hour(s)

## Emission Data Summary

|                                                               |        |
|---------------------------------------------------------------|--------|
| 1. Duration of excess emission in reporting period due to:    |        |
| a. Startup/shutdown                                           | 0      |
| b. Control equipment problems                                 | 0      |
| c. Process Problems                                           | 0      |
| d. Other known causes                                         | 0      |
| e. Unknown causes                                             | 0      |
| 2. Upset Conditions                                           | 0      |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0      |
| 4. Time of Excess Emission as a percentage of operating time  | 0.00   |
| 5. Time in compliance as percentage of operating time         | 100.00 |

## CMS Performance Summary

|                                                         |        |
|---------------------------------------------------------|--------|
| 1. CMS downtime in reporting period due to:             |        |
| a. Monitor equipment malfunctions                       | 0      |
| b. Non-Monitor equipment malfunctions                   | 0      |
| c. Quality assurance calibration                        | 0      |
| d. Other known causes                                   | 0      |
| e. Unknown causes                                       | 0      |
| 2. Total CMS Downtime                                   | 0      |
| 3. Total Downtime as a percentage of operating time     | 0.00   |
| 4. Total Availability as a percentage of operating time | 100.00 |

*Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.*

# CO Lb/Hr EDS/CMS Summary Report

CT6



From: 10/01/2024 00:00 To: 12/31/2024 23:59

Generated: 01/02/2025 11:45

Facility Name: ROSEVILLE ENERGY

Location: Roseville, CA

Description: Electric Utility

CMS Data from:

EDS Data from:

Emission Limitation:

No Value Exclusions Allowed

Monitor Manufacturer and Model No.:

Date of Latest CMS Certification or Audit:

Process Unit(s) Description:

Operating time for EDS:

Operating time for CMS:

CT6\_CO\_Norm\_LbPerHr\_1H, CT6\_UnitOn\_TF\_1H

CT6\_CO\_Norm\_LbPerHr\_1H, CT6\_UnitOn\_TF\_1H

2.64

TELEDYNE MONITOR LABS INC, T300

04/01/2024 00:00

0.00 Hour(s)

0.00 Hour(s)

## Emission Data Summary

|                                                               |        |
|---------------------------------------------------------------|--------|
| 1. Duration of excess emission in reporting period due to:    |        |
| a. Startup/shutdown                                           | 0      |
| b. Control equipment problems                                 | 0      |
| c. Process Problems                                           | 0      |
| d. Other known causes                                         | 0      |
| e. Unknown causes                                             | 0      |
| 2. Upset Conditions                                           | 0      |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0      |
| 4. Time of Excess Emission as a percentage of operating time  | 0.00   |
| 5. Time in compliance as percentage of operating time         | 100.00 |

## CMS Performance Summary

|                                                         |        |
|---------------------------------------------------------|--------|
| 1. CMS downtime in reporting period due to:             |        |
| a. Monitor equipment malfunctions                       | 0      |
| b. Non-Monitor equipment malfunctions                   | 0      |
| c. Quality assurance calibration                        | 0      |
| d. Other known causes                                   | 0      |
| e. Unknown causes                                       | 0      |
| 2. Total CMS Downtime                                   | 0      |
| 3. Total Downtime as a percentage of operating time     | 0.00   |
| 4. Total Availability as a percentage of operating time | 100.00 |

*Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.*

# CO SUSL Lb/Hr EDS/CMS Summary Report



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:46 Location: Roseville, CA  
Description: Electric Utility

CMS Data from: CT6\_CO\_SUSL\_Lbs\_1H, CT6\_UnitOn\_TF\_1H  
EDS Data from: CT6\_CO\_SUSL\_Lbs\_1H, CT6\_UnitOn\_TF\_1H  
Emission Limitation: 41.00  
No Value Exclusions Allowed  
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T300  
Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
Process Unit(s) Description:  
Operating time for EDS: 0.00 Hour(s)  
Operating time for CMS: 0.00 Hour(s)

## Emission Data Summary

|                                                               |        |
|---------------------------------------------------------------|--------|
| 1. Duration of excess emission in reporting period due to:    |        |
| a. Startup/shutdown                                           | 0      |
| b. Control equipment problems                                 | 0      |
| c. Process Problems                                           | 0      |
| d. Other known causes                                         | 0      |
| e. Unknown causes                                             | 0      |
| 2. Upset Conditions                                           | 0      |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0      |
| 4. Time of Excess Emission as a percentage of operating time  | 0.00   |
| 5. Time in compliance as percentage of operating time         | 100.00 |

## CMS Performance Summary

|                                                         |        |
|---------------------------------------------------------|--------|
| 1. CMS downtime in reporting period due to:             |        |
| a. Monitor equipment malfunctions                       | 0      |
| b. Non-Monitor equipment malfunctions                   | 0      |
| c. Quality assurance calibration                        | 0      |
| d. Other known causes                                   | 0      |
| e. Unknown causes                                       | 0      |
| 2. Total CMS Downtime                                   | 0      |
| 3. Total Downtime as a percentage of operating time     | 0.00   |
| 4. Total Availability as a percentage of operating time | 100.00 |

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

# NOx Ppmvdc EDS/CMS Summary Report



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:46 Location: Roseville, CA  
Description: Electric Utility

CMS Data from: CT6\_NOx\_Norm\_Ppmvdc\_1H, CT6\_UnitOn\_TF\_1H  
EDS Data from: CT6\_NOx\_Norm\_Ppmvdc\_1H, CT6\_UnitOn\_TF\_1H  
Emission Limitation: 2.5  
No Value Exclusions Allowed  
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H  
Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
Process Unit(s) Description:  
Operating time for EDS: 0.00 Hour(s)  
Operating time for CMS: 0.00 Hour(s)

## Emission Data Summary

|                                                               |        |
|---------------------------------------------------------------|--------|
| 1. Duration of excess emission in reporting period due to:    |        |
| a. Startup/shutdown                                           | 0      |
| b. Control equipment problems                                 | 0      |
| c. Process Problems                                           | 0      |
| d. Other known causes                                         | 0      |
| e. Unknown causes                                             | 0      |
| 2. Upset Conditions                                           | 0      |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0      |
| 4. Time of Excess Emission as a percentage of operating time  | 0.00   |
| 5. Time in compliance as percentage of operating time         | 100.00 |

## CMS Performance Summary

|                                                         |        |
|---------------------------------------------------------|--------|
| 1. CMS downtime in reporting period due to:             |        |
| a. Monitor equipment malfunctions                       | 0      |
| b. Non-Monitor equipment malfunctions                   | 0      |
| c. Quality assurance calibration                        | 0      |
| d. Other known causes                                   | 0      |
| e. Unknown causes                                       | 0      |
| 2. Total CMS Downtime                                   | 0      |
| 3. Total Downtime as a percentage of operating time     | 0.00   |
| 4. Total Availability as a percentage of operating time | 100.00 |

*Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.*

# NOx Lb/Hr EDS/CMS Summary Report



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:47 Location: Roseville, CA  
Description: Electric Utility

CMS Data from: CT6\_NOx\_Norm\_LbPerHr\_1H, CT6\_UnitOn\_TF\_1H  
EDS Data from: CT6\_NOx\_Norm\_LbPerHr\_1H, CT6\_UnitOn\_TF\_1H  
Emission Limitation: 2.71  
No Value Exclusions Allowed  
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H  
Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
Process Unit(s) Description:  
Operating time for EDS: 0.00 Hour(s)  
Operating time for CMS: 0.00 Hour(s)

## Emission Data Summary

|                                                               |        |
|---------------------------------------------------------------|--------|
| 1. Duration of excess emission in reporting period due to:    |        |
| a. Startup/shutdown                                           | 0      |
| b. Control equipment problems                                 | 0      |
| c. Process Problems                                           | 0      |
| d. Other known causes                                         | 0      |
| e. Unknown causes                                             | 0      |
| 2. Upset Conditions                                           | 0      |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0      |
| 4. Time of Excess Emission as a percentage of operating time  | 0.00   |
| 5. Time in compliance as percentage of operating time         | 100.00 |

## CMS Performance Summary

|                                                         |        |
|---------------------------------------------------------|--------|
| 1. CMS downtime in reporting period due to:             |        |
| a. Monitor equipment malfunctions                       | 0      |
| b. Non-Monitor equipment malfunctions                   | 0      |
| c. Quality assurance calibration                        | 0      |
| d. Other known causes                                   | 0      |
| e. Unknown causes                                       | 0      |
| 2. Total CMS Downtime                                   | 0      |
| 3. Total Downtime as a percentage of operating time     | 0.00   |
| 4. Total Availability as a percentage of operating time | 100.00 |

*Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.*

# NOx SUSD Lb/Hr EDS/CMS Summary Report



CT6

From: 10/01/2024 00:00 To: 12/31/2024 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 01/02/2025 11:47 Location: Roseville, CA  
Description: Electric Utility

CMS Data from: CT6\_NOx\_SUSD\_Lbs\_1H, CT6\_UnitOn\_TF\_1H  
EDS Data from: CT6\_NOx\_SUSD\_Lbs\_1H, CT6\_UnitOn\_TF\_1H  
Emission Limitation: 6.50  
No Value Exclusions Allowed  
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H  
Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
Process Unit(s) Description:  
Operating time for EDS: 0.00 Hour(s)  
Operating time for CMS: 0.00 Hour(s)

## Emission Data Summary

|                                                               |        |
|---------------------------------------------------------------|--------|
| 1. Duration of excess emission in reporting period due to:    |        |
| a. Startup/shutdown                                           | 0      |
| b. Control equipment problems                                 | 0      |
| c. Process Problems                                           | 0      |
| d. Other known causes                                         | 0      |
| e. Unknown causes                                             | 0      |
| 2. Upset Conditions                                           | 0      |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0      |
| 4. Time of Excess Emission as a percentage of operating time  | 0.00   |
| 5. Time in compliance as percentage of operating time         | 100.00 |

## CMS Performance Summary

|                                                         |        |
|---------------------------------------------------------|--------|
| 1. CMS downtime in reporting period due to:             |        |
| a. Monitor equipment malfunctions                       | 0      |
| b. Non-Monitor equipment malfunctions                   | 0      |
| c. Quality assurance calibration                        | 0      |
| d. Other known causes                                   | 0      |
| e. Unknown causes                                       | 0      |
| 2. Total CMS Downtime                                   | 0      |
| 3. Total Downtime as a percentage of operating time     | 0.00   |
| 4. Total Availability as a percentage of operating time | 100.00 |

*Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.*

# Cylinder Gas Audit

01/02/2025

Page 1

Facility: ROSEVILLE ENERGY

Unit/Stack: CT5

Parameter/Scale: CO / High

Test Date: 12/17/2024

Test Result: **Pass**

Instrument Name: CT5\_CODualRg\_P\_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

| Date       | Time  | Test Level | Span Value | Reference Value | Measured Value | Ref Value As Pct Span |
|------------|-------|------------|------------|-----------------|----------------|-----------------------|
| 12/17/2024 | 10:54 | L          | 1000       | 245.400         | 258.800        | 24.5 %                |
| 12/17/2024 | 10:59 | M          | 1000       | 559.500         | 561.400        | 56.0 %                |
| 12/17/2024 | 11:06 | L          | 1000       | 245.400         | 258.500        | 24.5 %                |
| 12/17/2024 | 11:11 | M          | 1000       | 559.500         | 562.300        | 56.0 %                |
| 12/17/2024 | 11:18 | L          | 1000       | 245.400         | 258.200        | 24.5 %                |
| 12/17/2024 | 11:23 | M          | 1000       | 559.500         | 562.500        | 56.0 %                |

## Summary Statistics:

| Cal Gas Level | Reference Mean | CEMS Mean | Specification Used | Results    |
|---------------|----------------|-----------|--------------------|------------|
| L             | 245.400        | 258.500   | Std                | <b>5.3</b> |
| M             | 559.500        | 562.067   | Std                | <b>0.5</b> |

# Cylinder Gas Audit

01/02/2025

Page 2

Facility: ROSEVILLE ENERGY

Unit/Stack: CT5

Parameter/Scale: CO / Low

Test Date: 12/17/2024

Test Result: **Pass**

Instrument Name: CT5\_CODualRg\_P\_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

| Date       | Time  | Test Level | Span Value | Reference Value | Measured Value | Ref Value As Pct Span |
|------------|-------|------------|------------|-----------------|----------------|-----------------------|
| 12/17/2024 | 10:00 | L          | 20         | 5.100           | 5.100          | 25.5 %                |
| 12/17/2024 | 10:05 | M          | 20         | 11.100          | 11.100         | 55.5 %                |
| 12/17/2024 | 10:17 | L          | 20         | 5.100           | 5.000          | 25.5 %                |
| 12/17/2024 | 10:22 | M          | 20         | 11.100          | 11.100         | 55.5 %                |
| 12/17/2024 | 10:34 | L          | 20         | 5.100           | 5.000          | 25.5 %                |
| 12/17/2024 | 10:39 | M          | 20         | 11.100          | 11.100         | 55.5 %                |

## Summary Statistics:

| Cal Gas Level | Reference | Mean | CEMS Mean | Specification Used | Results    |
|---------------|-----------|------|-----------|--------------------|------------|
| L             | 5.100     |      | 5.033     | Std                | <b>1.3</b> |
| M             | 11.100    |      | 11.100    | Std                | <b>0.0</b> |

# Cylinder Gas Audit

01/02/2025

Page 3

Facility: ROSEVILLE ENERGY

Unit/Stack: CT6

Parameter/Scale: CO / High

Test Date: 12/17/2024

Test Result: **Pass**

Instrument Name: CT6\_CODualRg\_P\_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

| Date       | Time  | Test Level | Span Value | Reference Value | Measured Value | Ref Value As Pct Span |
|------------|-------|------------|------------|-----------------|----------------|-----------------------|
| 12/17/2024 | 14:40 | L          | 1000       | 250.000         | 251.900        | 25.0 %                |
| 12/17/2024 | 14:45 | M          | 1000       | 571.000         | 571.200        | 57.1 %                |
| 12/17/2024 | 14:52 | L          | 1000       | 250.000         | 253.100        | 25.0 %                |
| 12/17/2024 | 14:57 | M          | 1000       | 571.000         | 573.300        | 57.1 %                |
| 12/17/2024 | 15:04 | L          | 1000       | 250.000         | 251.800        | 25.0 %                |
| 12/17/2024 | 15:09 | M          | 1000       | 571.000         | 570.400        | 57.1 %                |

## Summary Statistics:

| Cal Gas Level | Reference Mean | CEMS Mean | Specification Used | Results    |
|---------------|----------------|-----------|--------------------|------------|
| L             | 250.000        | 252.267   | Std                | <b>0.9</b> |
| M             | 571.000        | 571.633   | Std                | <b>0.1</b> |

# Cylinder Gas Audit

01/02/2025

Page 4

Facility: ROSEVILLE ENERGY

Unit/Stack: CT6

Parameter/Scale: CO / Low

Test Date: 12/17/2024

Test Result: **Pass**

Instrument Name: CT6\_CODualRg\_P\_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

| Date       | Time  | Test Level | Span Value | Reference Value | Measured Value | Ref Value As Pct Span |
|------------|-------|------------|------------|-----------------|----------------|-----------------------|
| 12/17/2024 | 13:48 | L          | 20         | 5.000           | 5.000          | 25.0 %                |
| 12/17/2024 | 13:53 | M          | 20         | 11.200          | 11.200         | 56.0 %                |
| 12/17/2024 | 14:05 | L          | 20         | 5.000           | 5.000          | 25.0 %                |
| 12/17/2024 | 14:10 | M          | 20         | 11.200          | 11.200         | 56.0 %                |
| 12/17/2024 | 14:22 | L          | 20         | 5.000           | 5.000          | 25.0 %                |
| 12/17/2024 | 14:27 | M          | 20         | 11.200          | 11.200         | 56.0 %                |

## Summary Statistics:

| Cal Gas Level | Reference | Mean | CEMS Mean | Specification Used | Results |
|---------------|-----------|------|-----------|--------------------|---------|
| L             | 5.000     |      | 5.000     | Std                | 0.0     |
| M             | 11.200    |      | 11.200    | Std                | 0.0     |

For the Fourth Quarter at RPeak, a Linearity Test was not completed for CT5 or CT6 as there were no operation hours for the quarter.