

## DOCKETED

<b>Docket Number:</b>	01-AFC-17C
<b>Project Title:</b>	Inland Empire Energy Center Project Compliance
<b>TN #:</b>	205293
<b>Document Title:</b>	South County Fire Authority E-mail Response
<b>Description:</b>	N/A
<b>Filer:</b>	BrettFooks
<b>Organization:</b>	California Energy Commission
<b>Submitter Role:</b>	Commission Staff
<b>Submission Date:</b>	7/9/2015 2:07:03 PM
<b>Docketed Date:</b>	7/9/2015

## Fooks, Brett@Energy

---

**From:** Kevin Jorgensen <Kevin.Jorgensen@ci.tracy.ca.us>  
**Sent:** Wednesday, July 08, 2015 6:07 PM  
**To:** Fooks, Brett@Energy  
**Cc:** Lesh, Geoff@Energy; Layton, Matthew@Energy; Scott Owen; Bryan Just; Steve Moncur; Christopher Landreth  
**Subject:** RE: GWF Tracy Power Plant Possible Recycled Water Usage...

Brett,

The South County Fire Authority will accept recycled water in the static water supply at GWF Tracy Power Plant.

*Kevin Jorgensen*  
Chief Building Official  
Fire Code Official  
City of Tracy  
South County Fire Authority  
333 Civic Center Plaza  
Tracy, California 95376  
(209)831-6400-office  
(209)831-6415-direct  
[kevin.jorgensen@ci.tracy.ca.us](mailto:kevin.jorgensen@ci.tracy.ca.us)



---

**From:** Fooks, Brett@Energy [<mailto:Brett.Fooks@energy.ca.gov>]  
**Sent:** Tuesday, July 07, 2015 8:43 AM  
**To:** Kevin Jorgensen  
**Cc:** Lesh, Geoff@Energy; Layton, Matthew@Energy  
**Subject:** GWF Tracy Power Plant Possible Recycled Water Usage...  
**Importance:** High

Kevin,

I spoke with you yesterday afternoon about the possibility of the GWF Tracy Power Plant using recycled water for their fire suppression. The power plant uses a fire water storage tank to supply the fire loop and fire suppression systems on site. The power plant submitted an emergency petition to the California Energy Commission seeking alternative supplies of water in case the power plant can't get water from their current source. One of the alternatives was to purchase

recycled water from the City of Tracy. Recycled water is seen as the preferable alternative due to the tight supply of potable water during the current drought.

Per our conversation yesterday, I have attached some information that defines the quality of and how tertiary recycled water is made. Please let me know if the Tracy Fire Department has any concerns/issues that would prevent the use of recycled water for the fire suppression system at the GWF Tracy power plant.

If you need any additional information or clarification, don't hesitate to call or email me.

Regards,

**Brett Fooks** | Mechanical Engineer

**Direct:** 916.654.5593 | **Fax:** 916.654.3882

[Brett.Fooks@energy.ca.gov](mailto:Brett.Fooks@energy.ca.gov)



CALIFORNIA ENERGY COMMISSION

1516 Ninth Street, Sacramento, CA

[www.energy.ca.gov](http://www.energy.ca.gov)