DOCKETED	
Docket Number:	06-AFC-10C
Project Title:	Midway Peaking Project - Starwood Power-Midway LLC
TN #:	262160
Document Title:	Quarterly Operation Report – 4th Qtr 2024
Description:	Quarterly Operation Report – Fourth Quarter 2024
Filer:	Anwar Ali
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	3/12/2025 9:21:34 AM
Docketed Date:	3/12/2025



Midway Peaking, LLC

4350 Executive Drive, Ste. 320 San Diego, CA 92122 619-756-5795

January 28, 2025

Anwar Ali Compliance Project Manager California Energy Commission 1516 Ninth Street Sacramento, CA 95814-5512 (916) 654-4611

Subject: CEC Quarterly Operation Report – 4th Qtr. 2024 06-AFC-10 Midway Peaking, LLC

Dear Mr. Ali.

Pursuant to Condition of Certification AQ-SC10 of Commission Decision, Docket No. 06-AFC-10, Midway Peaking, LLC hereby submits the *Quarterly Operation Report* for the fourth quarter 2024 reporting period.

The conditions referenced herein have been updated to coincide with the CEC Final order approved on March 14, 2012, Docket No.06-AFC-10C.

Midway Peaking, LLC is committed to the safe and environmentally responsible operation of this facility. Should you have any questions please contact Tony Gilmore, Compliance Manager, at (619) 756-5795.

Sincerely,

Claude Couvillion — Senior Vice President of Operations and Development Middle River Power, LLC

Enclosure

DISTRIBUTION LIST

- Keith Winstead, Planner III/Compliance Project Manager, CEC (e copy)
 Kathy Hurst, Director of EHS, Middle River Power (e copy)
- Ramiro Gonzalez, Plant Manager, Midway Peaking, LLC. (e copy)
- Taylor Leach, Environmental Specialist, NAES (e copy)

Midway Peaking, LLC CEC Quarterly Operation Report Summary Quarter 4 - 2024

Condition	Description of Action	Status / Comments
AQ-7	Submit proof that necessary Title IV SO2 emission allotments have been acquired as necessary for compliance with Title IV requirements annually in the first Quarterly Compliance Report (AQ-SC10) that is due after the annual SO2 allotment due date.	The project was in compliance with the holding/surrendering of Title IV SO2 allotments. The Acid Rain (Title IV) SO2 Annual Reconciliation/Allowance Transfer is due by Mar 1st each year. This information is included in Attachment 7 .
AQ-25	All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere.	The project was in compliance with this requirement,
AQ-26	No air contaminant shall be released into the atmosphere which causes a public nuisance. The project owner will document any complaints that it has received from the public in the Quarterly Operation Report (AQ-SC10).	The project was in compliance with this requirement. No complaints were received from the public during this reporting period.
AQ-27	No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. The project owner shall document any known opacity violations in the Quarterly Operation Report (AQ-SC10).	The project was in compliance with this requirement. No known opacity violations occurred during the reporting period.
AQ-30	The CTGs shall be fired exclusively on PUC-regulated natural gas with a sulfur content of no greater than 1.0 grain of sulfur compounds (as S) per 100 dry scf of natural gas. The project owner shall compile the required data on the sulfur content of the natural gas and submit the information to the CPM and the APCO in the Quarterly Operation Report (AQ-SC10).	The project was in compliance with this requirement. The CTGs are supplied with PUC- regulated natural gas with less than 1.0 gr/100 dscf in accordance with PG&E Gas Rule No. 21. Included in Attachment 1 is data published by PG&E to demonstrate the natural gas sulfur content is consistently less than the standard.
AQ-31	Emission rates from each CTG, except during startup and shutdown periods, shall not exceed any of the following limits: NOx (as NO2) – 2.8 lb/hr and 2.5 ppmvd @ 15% O2; CO – 4.19 lb/hr and 6.0 ppmvd @ 15% O2; VOC (as methane) – 0.82 lb/hr and 2.0 ppmvd @ 15% O2; PM10 – 1.85 lb/hr; or SOx (as SO2) – 0.89 lb/hr. The project owner shall submit to the CPM and APCO CTG emissions data demonstrating compliance with this condition as part of the Quarterly Operation Report (AQ-SC10).	CEMS are used to demonstrate compliance with NOx and CO; all emissions were within permitted emission limits unless specifically noted in Attachment 2 , which includes a copy of the Quarterly CEMS Excess Emission and Downtime Summary report submitted to the APCO for the reporting period. Source tests are conducted every 12 or 24 months to demonstrate compliance with PM10 and VOC and the source test reports are submitted to the CMP and APCO within 60-days of completing the test; refer to AQ-50 for more information. Ongoing monitoring for SOx is not required by the permit.
AQ-32	Combined emission rates except during startup and shutdown periods, shall not exceed any of the following Swift Pac two turbine limits: NOx (as NO2) – 5.6 lb/hr and 2.5 ppmvd @ 15% O2; CO – 8.38 lb/hr and 6.0 ppmvd @ 15% O2; VOC (as methane) – 1.64 lb/hr and 2.0 ppmvd @ 15% O2; PM10 – 3.70 lb/hr; or SOx (as SO2) – 1.78 lb/hr. The project owner shall submit to the CPM and APCO CTG emissions data demonstrating compliance with this condition as part of the Quarterly Operation Report (AQ-SC10).	CEMS are used to demonstrate compliance with NOx and CO; all emissions were within permitted emission limits unless specifically noted in Attachment 2 , which includes a copy of the Quarterly CEMS Excess Emission and Downtime Summary report submitted to the APCO for the reporting period. Source tests are conducted every 12 or 24 months to demonstrate compliance with PM10 and VOC and the source test reports are submitted to the CMP and APCO within 60-days of completing the test; refer to AQ-50 for more information. Ongoing monitoring for SOx is not required by the permit.
AQ-33	The ammonia (NH3) emissions shall not exceed either of the following limits: 4.24 lb/hr or 10 ppmvd @ 15% O2 over a 24 hour rolling average. The project owner shall submit to the CPM and APCO CTG emissions data demonstrating compliance with this condition, using approved calculation methods (AQ-47), as part of the Quarterly Operation Report (AQ-SC10).	Ammonia emissions are estimated hourly using a calculation involving inlet and outlet NOx and O2 CEMS measurements. Included in Attachment 3 is an excess emission report from the CEMS data acquisition and monitoring system (DAHS) to demonstrate that the emission limits were not exceeded during the compliance period.
AQ-34	During start-up, CTG exhaust emission rates shall not exceed any of the following limits: NOx (as NO2) – 30 lb/hr; CO – 12.5 lb/hr; VOC (as methane) – 0.83 lb/hr; PM10 – 1.85 lb/hr; or SOx (as SO2) – 0.89 lb/hr. All averages on a per event basis. The project owner shall submit to the CPM and APCO CEM-derived emissions data for NOx and CO (except when source testing is required for startups) and shall provide calculated PM10 and VOC emission from fuel consumption data and source test results to demonstrate compliance with this condition as part of the Quarterly Operation Report (AQ-SC10)	Included in Attachment 3 are excess emission reports from the CEMS DAHS to demonstrate that the emission limits were not exceeded during the compliance period.

Condition	Description of Action	Status / Comments
AQ-35	During shutdown, CTG exhaust emission rates shall not exceed any of the following limits: NOx (as NO2) – 1.50 lb/hr; CO – 21.33 lb/hr; VOC (as methane) – 0.83 lb/hr; PM10 – 1.85 lb/hr; or SOx (as SO2) – 0.89 lb/hr. All averages on a per event basis. The project owner shall submit to the CPM and APCO CEM-derived emissions data for NOx and CO (except when source testing is required for shutdowns) and shall provide calculated PM10 and VOC emission from fuel consumption data and source test results to demonstrate compliance with this condition as part of the Quarterly Operation Report (AQ-SC10).	Included in Attachment 3 are excess emission reports from the CEMS DAHS to demonstrate that the emission limits were not exceeded during the compliance period. 10/3/2024 NOx shutdown exceedance occurred due to equipment breakdown. Detailed in breakdown report included in Attachment 2
AQ-36	Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its SCR operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. The project owner shall submit to the CPM and APCO the CTG startup and shutdown event duration data demonstrating compliance with this condition as part of the Quarterly Operation Report (AQ-SC10).	The CEMS DAHS monitors unit parameters and is programmed to recognize and record the duration of offline, startup, shutdown and normal operating conditions. The CEMS DAHS is programmed to prevent more than 120 minutes of data being flagged as startup or shutdown.
AQ-37	The duration of each startup or shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. The project owner shall submit to the CPM and APCO the CTG startup and shutdown event duration data demonstrating compliance with this condition as part of the Quarterly Operation Report (AQ-SC10).	The CEMS DAHS monitors unit parameters and is programmed to recognize and record the duration of offline, startup, shutdown and normal operating conditions. The CEMS DAHS is programmed to prevent more than 120 minutes of data being flagged as startup or shutdown. Included inn Attachment 6
AQ-38	The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. The project owner shall submit to the CPM and APCO the CTG startup and shutdown emissions data demonstrating compliance with this condition as part of the Quarterly Operation Report (AQ-SC10).	Included in Attachment 3 are excess emission reports from the CEMS DAHS to demonstrate that the startup and shutdown emission limits were not exceeded during the compliance period. 10/3/2024 NOx shutdown exceedance occurred due to equipment breakdown. Detailed in breakdown report included in Attachment 2
AQ-39	Daily emissions from the CTG shall not exceed any of the following limits: NOx (as NO2) – 79.8 lb/day; CO – 117.6 lb/day; VOC – 19.7 lb/day; PM10 – 44.4 lb/day; or SOx (as SO2) – 21.4 lb/day. The project owner shall submit to the CPM and APCO CTG emissions data demonstrating compliance with this condition as part of the Quarterly Operation Report (AQ-SC10).	Included in Attachment 3 are excess emission reports from the CEMS DAHS to demonstrate that the daily emission limits were not exceeded during the compliance period.
AQ-40	Combined daily emissions from the two Swift Pac unit CTG's operating under permit units C-7286-1 and C-7286-2, and the two Swift Pac unit CTG's operating under permit units C-7286-3 and C-7286 shall not exceed any of the following Swift Pac two turbine limits: NOx (as NO2) – 159.6 lb/day; CO – 235.2 lb/day; VOC – 39.4 lb/day; PM10 – 88.8 lb/day; or SOx (as SO2) – 42.8 lb/day. The project owner shall submit to the CPM and APCO CTG emissions data demonstrating compliance with this condition as part of the Querterly Operation Report (AQ-SC10)	Included in Attachment 3 are excess emission reports from the CEMS DAHS to demonstrate that the daily emission limits were not exceeded during the compliance period.
AQ-41	Quarterly hours of operation of each CTG shall not exceed any of the following limits: 1st Quarter—800 hours, 2nd Quarter—800 hours, 3rd Quarter—1,400 hours, or 4th Quarter—1,000 hours. The project owner shall submit to the CPM and APCO CTG operations data demonstrating compliance with this condition as part of the Quarterly Operation Report (AQ-SC10).	Included in Attachment 4 is a summary of operating time for each unit that demonstrates all CTGs operated less than the allowable limit during the reporting period.
AQ-42	Annual emissions from each CTG, calculated on a twelve month rolling basis, shall not exceed any of the following limits: NOx (as NO2) – 12,736 lb/year; CO – 18,826 lb/year; VOC – 3,281 lb/year; PM10 – 7,400 lb/year; or SOx (as SO2) – 3,560 lb/year. The project owner shall submit to the CPM and APCO CTG emissions data demonstrating compliance with this condition as part of the Quarterly Operation Report (AQ-SC10).	Included in Attachment 5 is a summary of monthly emissions from each turbine over the latest twelve months.
AQ-43	Combined annual emissions from the two Swift Pac unit CTG's operating under permit units C-7286-1 and C-7286-2, and the two Swift Pac unit CTG's operating under permit units C-7286-3 and C-7286 calculated on a twelve consecutive month rolling basis, shall not exceed any of the following Swift Pac two turbine limits: NOx (as NO2) – 25,742 lb/year; CO – 37,652 lb/year; VOC – 6,562 lb/year; PM10 – 14,800 lb/year; or SOx (as SO2) – 7,120 lb/year. The project owner shall submit to the CPM and APCO CTG emissions data demonstrating compliance with this condition as part of the Quarterly Operation Report (AQ-SC10).	Included in Attachment 5 is a summary of monthly emissions from each turbine over the latest twelve months.
AQ-44	Combined annual NOX from CTG's operating under permits C-7286-1, -2, -3, and -4 shall not exceed 50,000 lb/year. The project owner shall compile required emission compliance data using these standards and shall submit the information to the CPM and the APCO as part of the Quarterly Operation Report (AQ-SC10).	Included in Attachment 5 is a summary of monthly emissions from each turbine over the latest twelve months.

Condition	Description of Action	Status / Comments
AQ-45	Each one hour period shall commence on the hour. Each one hour period in a three hour rolling average will commence on the hour. The three hour average will be compiled from the three most recent one hour periods. Each one hour period in a twenty-four hour average for ammonia slip will commence on the hour.	The CEMS DAHS is programmed to record and report emissions data in accordance with these averaging periods.
AQ-46	Daily emissions will be compiled for a twenty-four hour period starting and ending at twelve-midnight. Each month in the twelve consecutive month rolling average emissions shall commence at the beginning of the first day of the month. The twelve consecutive month rolling average emissions to determine compliance with annual emissions limitations shall be compiled from the twelve most recent calendar months.	The CEMS DAHS is programmed to record and report emissions data in accordance with these averaging periods.
AQ-52	The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contractThe result of the natural gas fuel sulfur monitoring data and other fuel sulfur content source data shall be submitted to the CPM and the APCO in the Quarterly Operation Report (AQ-SC10).	The CTGs are supplied with PUC-regulated natural gas with less than 1.0 gr/100 dscf in accordance with PG&E Gas Rule No. 21 (tariff sheet). Included in Attachment 1 is data published by PG&E to meet this requirement.
AQ-54	Fuel sulfur content shall be monitored using one of the following methods: ASTM Methods D1072, D3246, D4084, D4468, D4810, D6228, D6667 or Gas Processors Association Standard 2377. The fuel sulfur content data shall be submitted to the CPM and the APCO in the Quarterly Operation Report (AQ-SC10).	The CTGs are supplied with PUC-regulated natural gas with less than 1.0 gr/100 dscf in accordance with PG&E Gas Rule No. 21 (tariff sheet). Included in Attachment 1 is data published by PG&E to meet this requirement.
AQ-59	The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15- minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. The project owner shall submit to the CPM and APCO CEMS audits demonstrating compliance with this condition as part of the Quarterly Operation Report (AQ-SC10).	The CEMS is designed and programmed to sample, analyze and record emissions data in accordance with these requirements. Any period of downtime from meeting this requirement is reported in the Quarterly CEMS Excess Emission and Downtime Summary report submitted to the APCO. A copy of the report for this reporting period is included in Attachment 2 .
AQ-60	The NOx, CO and O2 CEMS shall meet the requirements in 40 CFR 60, Attachment F Procedure 1 and Part 60, Attachment B Performance Specification 2 (PS 2), or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. The project owner shall submit to the CPM and APCO CEMS audits demonstrating compliance with this condition as part of the Quarterly Operation Report (AQ-SC10).	CEMS are used to demonstrate compliance with NOx and CO; all emissions were within permitted emission limits unless specifically noted in Attachment 2 , which includes a copy of the Quarterly CEMS Excess Emission and Downtime Summary report submitted to the APCO for the reporting period. Source tests are conducted every 12 or 24 months to demonstrate compliance with PM10 and VOC and the source test reports are submitted to the CMP and APCO within 60-days of completing the test; refer to AQ-50 for more information. Ongoing monitoring for SOx is not required by the permit.
AQ-61	Audits of continuous emission monitors shall be conducted as specified by 40 CFR Parts 60 (CO analyzer) and 75 (NOx and O2 analyzers) at least once every QA operating quarter. The project owner shall submit to the CPM and APCO the CEMS audits demonstrating compliance with this condition as part of the Quarterly Operation Report (AQ-SC10).	Copies of audits performed on the CEMS during this compliance period are included in the Quarterly CEMS Excess Emission and Downtime Summary report included in Attachment 2.
AQ-62	The owner/operator shall perform a relative accuracy test audit (RATA) for the NOx, CO and O2 CEMS at least once every two Quality Assurance (QA) operating quarters, this frequency may be reduced to once every four QA quarters if the incentive criteria of 40 CFR 75 are met. A calendar quarter that does not qualify as a QA operating quarter shall be excluded in determining the deadline for the next RATA. No more than eight successive calendar quarters shall elapse after the quarter in which a RATA was last performed without a subsequent RATA having been conducted. The project owner shall submit to the CPM and APCO CEMS audits demonstrating compliance with this condition as part of the Quarterly Operation Report (AQ-SC10).	The most recent RATA test was performed in April 2023 ; a copy of the RATA report is submitted to the CPM and APCO in accordance with AQ-58. The CEMS performance met the incentive criteria of 40 CFR 75, and the units have not operated four QA operating quarters since the latest test (Q2 2023).
AQ-64	Results of the CEM system shall be averaged over a one hour period for NOx emissions and a three hour period for CO emissions using consecutive 15-minute sampling periods in accordance with all applicable requirements of CFR 60.13.	The CEMS DAHS is programmed to record and report emissions data in accordance with these averaging periods.
AQ-65	Excess emissions shall be defined as any operating hour in which the 1-hour NOx concentration exceeds applicable emissions limit and a period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NOx or O2 (or both). The project owner shall submit to the CPM and APCO emission data and monitor downtime data in the Quarterly Operation Reports (AQ-SC10) that follows the definitions of this condition.	CEMS is used to demonstrate compliance; all emissions were within the permitted emission limits unless specifically noted in Attachment 2 , which includes a copy of the Quarterly CEMS Excess Emission and Downtime Summary report submitted to the APCO for the reporting period.
AQ-66	Results of continuous emissions monitoring shall be reduced according to the procedures established in 40 CFR, Part 51, Attachment P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA.	The CEMS DAHS is programmed to record and report emissions data in accordance with these averaging periods.

Condition	Description of Action	Status / Comments
AQ-70	The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter. The project owner shall submit to the CPM and APCO the CEMS audits demonstrating compliance with this condition as part of the Quarterly Operation Report required by this condition and condition AQ-SC10.	A copy of the Quarterly CEMS Excess Emission and Downtime Summary report submitted to the APCO for the reporting period is included in Attachment 2 .
AQ-72	Notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. Submit written copies of these notification reports to the CPM and the APCO as part of the Quarterly Operation Report.	Breakdown notifications, if applicable during this reporting period are contained in Attachment 2.
AQ-73	The District shall be notified in writing within ten days following the correction of any breakdown condition. Submit written copies of these notification reports to as part of the Quarterly Operation Report.	Breakdown notifications, if applicable during this reporting period are contained in Attachment 2.
AQ-77	Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021. Document compliance with Rule 8021 in the Quarterly Operation Report.	There were no activities conducted during the quarter that would have triggered the requirements of this Rule.
AQ-79	Prevent or cleanup any carryout or track out in accordance with the requirements of District Rule 8041. Document compliance with Rule 8041 in the Quarterly Operation Report.	There were no activities conducted during the quarter that would have triggered the requirements of this Rule.
AQ-80	Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051. Document compliance with Rule 8051 in the Quarterly Operation Report.	There were no activities conducted during the quarter that would have triggered the requirements of this Rule.
AQ-81	Any paved road or unpaved road shall comply with the requirements of District Rule 8061 or Rule 8011. Document compliance with Rule 8061 in the Quarterly Operation Report.	There were no activities conducted during the quarter that would have triggered the requirements of this Rule.
AQ-82	Water, gravel, road mix, or chemical/organic dust stabilizers/suppressants, vegetative materials, or other District-approved control measure shall be applied to unpaved vehicle travel areas as required to limit Visible Dust Emissions to 20% opacity and comply with the requirements for a stabilized unpaved road (District Rule 8071). Document compliance with Rule 8071 in the Quarterly Oparation Report	There were no activities conducted during the quarter that would have triggered the requirements of this Rule.
AQ-83	Where dusting materials are allowed to accumulate on paved surfaces, the accumulation shall be removed daily or water and/or chemical/organic dust stabilizers/suppressants shall be applied to the paved surface as required to maintain continuous compliance with the requirements for a stabilized unpaved road as defined in Section 3.59 of District Rule 8011 and limit Visible Dust Emissions (VDE) to 20% opacity. Document compliance with Rule 8071 in the Quarterly Operation Report.	There were no activities conducted during the quarter that would have triggered the requirements of this Rule.
AQ-84	On each day that 50 or more Vehicle Daily Trips or 25 or more Vehicle Daily Trips with 3 axles or more will occur on an unpaved vehicle/equipment traffic area, the project owner shall apply water, gravel, road mix, or chemical/organic dust stabilizers/suppressants, vegetative materials, or other District-approved control measure as required to limit Visible Dust Emissions to 20% opacity. Document compliance with Rule 8071 in the Quarterly Operation Report.	There were no activities conducted during the quarter that would have triggered the requirements of this Rule.
AQ-85	Whenever any portion of the site becomes inactive, the project owner shall restrict access and periodically stabilize any disturbed surface to comply with the conditions for a stabilized surface as defined in Section 3.58 of District Rule 8011. Document compliance with Rule 8011 in the Quarterly Operation Report.	There were no activities conducted during the quarter that would have triggered the requirements of this Rule.
AQ-86	Records and other supporting documentation shall be maintained as required to demonstrate compliance with the requirements of the rules under Regulation VIII only for those days that a control measure was implemented. Document compliance with Regulation VIII in the Quarterly Operation Report.	There were no activities conducted during the quarter that would have triggered the requirements of this Rule.
AQ-SC8	Demonstrate that the actual annual SO2 emissions remain below the 2.28 tons of emissions that have been offset by complying with this condition.	Included in Attachment 5 is a summary of monthly and annual emissions from each turbine over the latest twelve months.
AQ-SC10	The project owner shall submit the Quarterly Operation Reports to the CPM and APCO no later than 30 days following the end of each calendar quarter that include operational and emissions information as necessary to demonstrate compliance with the Conditions of Certification.	This report demonstrates compliance with this requirement.

Attachment 1

Natural Gas Sulfur Content



Gas Quality / Heating Values > Gas System Sulfur Survey Results

Gas System Sulfur Survey Results

Sulfur Information

Gas Quality Information

Therm Factor Heating Values

Gas System Sulfur Survey Results

Note: Starting Q4 2022, we began breaking sulfur data down monthly. Data will still be updated on a quarterly basis just with additional granularity.

∠ 2021 - 2024 2016 - 2020 2011 - 2015 2006 - 2010

2021 - 2024

2024

Feedback

>

1/28/25, 7:56 AM

Gas System Sulfur Survey Results | Pipe Ranger

Date	Total Sulfur Maximum		Total Sulfur Average all sites	
	PPMv	gr/100 scf	PPMv	gr/100 scf
2024				
Fourth Quarter	3.9	0.23	2.7	0.16
Fourth Quarter - October	3.7	0.22	2.7	0.16
Fourth Quarter - November	3.7	0.22	2.7	0.16
Fourth Quarter - December	3.9	0.23	2.9	0.17
Third Quarter	4.3	0.25	2.8	0.17
Third Quarter - July	4.2	0.25	2.8	0.17
Third Quarter - August	4.3	0.25	2.9	0.17
Third Quarter - September	4.1	0.24	3.0	0.18
Second Quarter	4.1	0.24	2.7	0.16
Second Quarter - April	3.6	0.21	2.7	0.16
Second Quarter - May	4.0	0.24	2.8	0.16
Second Quarter - June	4.1	0.24	3.0	0.17
First Quarter	3.8	0.23	2.9	0.17
				0.10

https://www.pge.com/pipeline/en/operating-data/therm/sulfur-info-values.html

1/28/25, 7:56 AM

Gas System Sulfur Survey Results | Pipe Ranger

	,				
First Quarter - January	3.8	0.23	3.0	0.18	
First Quarter - February	3.8	0.23	3.0	0.18	
First Quarter - March	3.5	0.21	2.6	0.15	

2023

Attachment 2

Quarterly CEMS Excess Emissions & Downtime Report



4350 Executive Drive Suite320 San Diego, CA 92121 6197565795

January 23, 2025

San Joaquin Valley Air Pollution Control District Central Region Attn.: Preet Bath 1990 East Gettysburg Ave. Fresno, CA 93726

Subject: Quarterly CEMS Report - 4th Quarter 2024

Dear Ms. Bath:

Pursuant to Condition 45 of Permit to Operate (PTO) Nos. C-7286-1-4, C-7286-2-4, C-7286-3-4, and C-7286-4-4, Midway Peaking, LLC hereby submits the Quarterly CEMS Excess Emission and Downtime Summary Report for the fourth quarter of 2024.

If you have any questions regarding any of the information provided in this submittal, or require additional information, please contact Tony Gilmore, Compliance Manager at 619-756-5795.

Sincerely,

Claude Couvillion Senior Vice President of Operations and Development Midway Peaking, LLC

cc

- ➤ Kathy Hurstr, Director of EHS, Middle River Power (e copy)
- Ramiro Gonzalez, Plant Manager, CalPeak Power, LLC (e copy)
- Taylor Leach, Environmental Specialist, NAES (e copy)

San Joaquin Valley Unified Air Pollution Control District

Certification of Truth and Accuracy

Company Name:	Midway Peaking,LLC	Facility ID:	C - 7286
		•	

I declare, under penalty of perjury under the laws of the state of California that based on information and belief formed after reasonable inquiry, the statements and information provided in the document are true, accurate, and complete:

Signature of Responsible Official

1/23/2025

Date

Claude Couvillion

Name of Responsible Official (please print)

Senior Vice President of Operations and Development Title of Responsible Official (please print)



Northern Region	Central Region	Southern Region						
QUARTERLY CEMS EXCESS EMISSION AND DOWNTIME SUMMARY								
1st 🗌 JAN	- MAR 20 3rd 🗍 JUL -	SEPT 20						
2nd 🗌 APR	- JUN 20 4th 🛛 OCT	- DEC 20 <u>24</u>						
Facility Name: <u>Midway Peaking, LL</u>	Facility Name:Midway Peaking, LLC Permit #:C-7286-1-4 & 2-4 (Midway 1)							
Location: 43627 West Panoche Ro	Location: _43627 West Panoche Rd City: _Firebaugh							
AIRS #: NSPS Source?: 🛛 Yes 🗌 No								
Process Equipment Description:60 MW, simple cycle gas turbine, peaking unit, 611 MMBtu/hr								
Pollutants Monitored: XO _X	\Box SO _X \boxtimes CO \Box Opacity	$\bigcirc O_2 $ $\square CO_2 $ $\square NH_3$						

Total Hours Process Equipment Operated During Quarter: <u>57</u>

CEM Unit Information								
Pollutant Manufacturer / Model Serial # Date Installed Operated								
NOx	TAPI 200EM	374	Q2 2009	75				
SOx								
со	TAPI 300E	1892	Q2 2009	75				
Opacity								
O ₂	TAPI 300E	1892	Q2 2009	75				
CO ₂								
NH ₃								
Other								

Date of Last Performance Specification Test									
Pollutant	Pollutant NO _X SO _X CO Opacity O ₂ CO ₂ NH ₃ Other								
Date	10/17/24		10/17/24		10/17/24				
	🗌 RATA	🗌 RATA	🗌 RATA	🗌 RATA	🗌 RATA	🗌 RATA	🗌 RATA	🗌 RATA	
Туре	🖾 CGA	CGA	🖾 CGA	CGA	🖾 CGA	CGA	CGA	CGA	
	Linearity	Linearity	Linearity	Linearity	Linearity	Linearity	Linearity	Linearity	

Emission Limits (From Operating Permits)									
Pollutant	ollutant ppm @ O ₂ % Ib/MMBtu Ib/hr ¹ Ib/day ¹ Ibs/yr ¹ NSPS (Subpart КККК								
NOx	2.5	N/A	2.8/5.6	79.8 / 159.6	12,736 / 25,742	25			
SOx									
CO	6.0	N/A	4.19/8.38	117.6 / 235.2	18,826 / 37,652	N/A			
Opacity									
O ₂									
CO ₂									
NH ₃									
Other									

Note 1: Midway Unit 1 has a mass emission limit that applies to a single engine, and a mass emission limit that applies when two engines are in operation, presented above as "one engine / two engines".

	Excess Emissions Information (Report in Hours)									
Pollutant	Start-Up / Shutdown	Process Problems	Breakdown	Other Known	Other Unknown	Total Hrs Excess	Total Op Hrs for Qtr	% Excess		
NO _X	0	0	1	0	0	1	75	1.3		
SOx										
CO	0	0	0	0	0	0	75	0		
Opacity										
O ₂										
CO ₂										
NH ₃										
Other										

Include a summary of all dates, times, and excess emissions that occurred during the reporting period or submit copies of all related breakdown reports and Title V deviations.

Excess emissions caused by a startup after shutdown due to a malfunction should be reported as an excess emission due to an equipment breakdown. The source is not however, exempt from emission limits. All exceedances are to be reported in whole hour increments.

	CEM Downtime Information (Report in Hours)									
Pollutant	Monitor Malfunction	Non-Monitor Malfunction	Q/A - Cal	Other	Unknown	Total Hrs Downtime	Total Hrs	% Downtime		
NO _X	0	0	0	0	0	0	75	0		
SOx										
CO	0	0	0	0	0	0	75	0		
Opacity										
O ₂	0	0	0	0	0	0	75	0		
CO ₂										
NH₃										
Other										

Include a summary of all downtime dates, times, duration, and activities that occurred during the reporting period or submit copies of all related breakdown reports and Title V deviations.

Non-CEM malfunctions are incidents that result in the CEM system being down but are not associated with a malfunction of the CEM system, i.e. plant power failure.

1 Midway NOx/H Linearity

Calpeak

Test Information

_

Test Date	10/17/2024
Test Reason	
Grace Period	No
Aborted	No
Result	Passed
Linit offling during a OA	test Netwolid for ACCED

Analyzer and Monitor Information

Range	High
Instrument Span	250 ppm
Component ID	110
Manufacturer	TELEDYNE
Model	M200EM
Serial Number	374

Unit offline during QA test -- Not valid for 40CFR75

Run Time		Gas	Response		Cylinder Information
Low Gas	S				
1	11:06 AM	57.00	55.66		Allowable Reference Values:
2	11:18 AM	57.00	59.84		Allowable Reference values. $50.75 \text{ ppm} (20.30\% \text{ of span})$
3	11:31 AM	57.00	59.93		Cylinder ID: CC755708
N	Mean (ppm)	57.00	58.48	_	Expiration Date: 11/29/2030
[(Difference of means(R-A) ppm)	1.5	Limit 5	Passed	EPA Vendor ID: W12022 Cylinder contains:
Ĺ	inearity Error (%)	2.6	Limit 5.0	Passed	CO,NO,NOX,BALN
Mid Gas	5				
1	11:10 AM	141.30	139.65		Allowable Reference Values:
2	11:23 AM	141.30	141.38		Allowable Reference values. 125-150 ppm (50-60% of span)
3	11:35 AM	141.30	140.14		Cylinder ID: CC755707
Ν	Mean (ppm) 141.30		140.39	_	Expiration Date: 11/29/2030
Γ	Difference of means (R-A)	0.9	Limit 5	Passed	EPA Vendor ID: W12022
(ppm)				Cylinder contains:
L	inearity Error (%)	0.6	Limit 5.0	Passed	CO,NO,NOX,BALN
High Ga	S				
1	11:14 AM	227.00	227.09		Allowable Reference values:
2	11:27 AM	227.00	228.63		200-250 ppm (80-100% of span)
3	11:40 AM	227.00	229.48	_	Cylinder ID: EB0149214
Ν	<i>l</i> lean (ppm)	227.00	228.40		Expiration Date: 6/12/2032
[(Difference of means (R-A) (ppm)		Limit 5	Passed	EPA Vendor ID: W12024 Cvlinder contains:
L	inearity Error (%)	0.6	Limit 5.0	Passed	CO,NO,NOX,BALN

Linearity Error (LE) Determination

LE (%) = (|R-A| / R) * 100

R = Reference gas value

A = Mean of actual CEMS responses

1 Midway NOx/L CGA

Calpeak

Test Information				Analyzer and Monitor Information				
st Date sult	10/17/2024 Passed		Range Instrument Span Manufacturer Model Serial Number		Low 10 ppm TELEDYNE M200EM 374			
Run	Time	Reference Gas	CEMS Response	9	Cylinder Information			
Low Gas	i							
1	9:23 AM	2.560	2.415					
2	9:32 AM	2.560	2.471		Allowable Reference values:			
3	9:40 AM	2.560	2.494		2-3 ppm (20-30% of span) Cylinder ID: CC760992			
М	lean (ppm)	2.560	2.460		Expiration Date: 12/3/2025			
Di (p	ifference of means (Cm-Ca)	-0.1	Limit 2	Passed	EPA Vendor ID: W12022 Cvlinder contains:			
C	EMS Accuracy (%)	-3.9	Limit 15	Passed	BALN,CO,NO,NOX			
Mid Gas								
1	9:28 AM	5.420	3.985		Allowable Reference Values:			
2	9:36 AM	5.420	4.027		5-6 npm (50-60% of span)			
3	9:45 AM	5.420	4.046		Cvlinder ID: CC754803			
Μ	lean (ppm)	5.420	4.019		Expiration Date: 1/17/2026			
Di (p	ifference of means (Cm-Ca) opm)	-1.4	Limit 2	Passed	EPA Vendor ID: W12023 Cylinder contains:			
C	EMS Accuracy (%)	-25.8	Limit 15		BĂLN,CO,NO,NOX			

Accuracy (%) = ((Cm - Ca) / Ca) * 100

Ca = Reference gas value

Cm = Mean of actual CEMS responses

1 Midway CO/H CGA

Calpeak

Test Information				Analyzer and Monitor Information					
est Date esult	10/17/2024 Passed		Range Instrument Span Manufacturer Model Serial Number		High 1000 ppm TELEDYNE M300E 1892				
Run	Time	Reference Gas	CEMS Response		Cylinder Information				
Low Gas									
	11·06 AM	276 600	293 292						
2	11:18 AM	276.600	293.137		Allowable Reference Values:				
3	11:31 AM	276.600	293.007		200-300 ppm (20-30% of span) Cylinder ID: CC755708				
M	Mean (ppm) 276.600		293.145		Expiration Date: 11/29/2030				
Di (p	fference of means (Cm-Ca) pm)	16.5	6.5 <i>Limit</i> 5		EPA Vendor ID: W12022 Cylinder contains:				
CI	EMS Accuracy (%)	6.0	Limit 15	Passed	CO,NO,NOX,BALN				
Mid Gas									
1	11:10 AM	548.000	560.685		Allowable Reference Values:				
2	11:23 AM	548.000	559.158		500-600 ppm (50-60% of span)				
3	11:35 AM	548.000	557.316		Cylinder ID: CC755707				
M	ean (ppm)	548.000	559.053	_	Expiration Date: 11/29/2030				
Di (p	fference of means (Cm-Ca) pm)	11.1	Limit 5		EPA Vendor ID: W12022 Cylinder contains:				
CE	EMS Accuracy (%)	2.0	Limit 15	Passed	CO,NO,NOX,BALN				

CEMS Accuracy Determination (%)

Accuracy (%) = ((Cm - Ca) / Ca) * 100

Ca = Reference gas value

Cm = Mean of actual CEMS responses

1 Midway CO/L CGA

Calpeak

Test Information				Analyzer and Monitor Information				
st Date sult	10/17/2024 Passed		Range Instrument Span Manufacturer Model Serial Number		Low 20 ppm TELEDYNE M300E 1892			
	_	Reference	CEMS					
Run	Time	Gas	Response	•	Cylinder Information			
Low Ga	S							
1	9:23 AM	4.920	5.056					
2	9:32 AM	4.920	4.981		Allowable Reference values:			
3	9:40 AM	4.920	4.988		Cvlinder ID: CC760992			
	Vean (ppm)	4.920	5.008	_	Expiration Date: 12/3/2025			
[(Difference of means (Cm-Ca) (ppm)	0.1	Limit 2	Passed	EPA Vendor ID: W12022 Cylinder contains:			
(CEMS Accuracy (%)	1.8	Limit 15	Passed	CO,NO,NOX,BALN			
Mid Gas	6							
1	9:28 AM	10.600	10.588		Allowable Reference Values:			
2	9:36 AM	10.600	10.559		10_{12} npm (50_60% of span			
3	9:45 AM	10.600	10.529		Cvlinder ID: CC754803			
	Mean (ppm)	10.600	10.559		Expiration Date: 1/17/2026			
[(Difference of means (Cm-Ca) (ppm)		Limit 2	Passed	EPA Vendor ID: W12023 Cylinder contains:			
(CEMS Accuracy (%)	-0.4	Limit 15	Passed	CÓ,NO,NOX,BALN			

CEMS Accuracy Determination (%)

Accuracy (%) = ((Cm - Ca) / Ca) * 100

Ca = Reference gas value

Cm = Mean of actual CEMS responses

1 Midway O2 Linearity

Calpeak

Test Information Analyzer and Monitor Information Single Scale **Test Date** 10/17/2024 Range Instrument Span 21 %02 **Test Reason** Component ID 120 Grace Period No Manufacturer TELEDYNE Aborted No Model M300E Result Passed Serial Number 1892 Unit offline during QA test -- Not valid for 40CFR75

Run	Time	Reference Gas	CEMS Response		Cylinder Information	
	e					
	5 11·58 ΔΜ	5 450	5 4 5 4			
2	12:07 PM	5.450	5 470			
3	12:16 PM	5 450	5 475		Allowable Reference Values:	
	(loop (9/ 02)	E 4E0	E 466	_	4.2-0.3 %O2 (20-30% of spari)	
וי	\mathcal{O}	5.450	5.400	Deserd	Expiration Date: 11/19/2030	
Ĺ	Sillerence of means (R-A)	0.0	Limit 0.5	Passed	EPA Vendor ID: W12022	
L	inearity Error (%)	0.3	Limit 5.0	Passed	Cylinder contains: O2,BALN	
Mid Gas	5					
1	12:01 PM	11.600	11.612		Allowable Reference Values:	
2	12:10 PM	11.600	11.636		10 5-12 6 %O2 (50-60% of	
3	12:19 PM	11.600	11.623		span)	
Ν	Vlean (%O2)	11.600	11.624		Cylinder ID: CC755982	
[(Difference of means(R-A) %O2)	0.0	Limit 0.5	Passed	Expiration Date: 11/19/2030 EPA Vendor ID: W12022	
L	inearity Error (%)	0.2	Limit 5.0	Passed	Cylinder contains: O2,BALN	
High Ga	IS					
1	12:04 PM	19.060	19.115		Allowable Reference Values:	
2	12:13 PM	19.060	19.137		16.8-21 %O2 (80-100% of	
3	12:22 PM	19.060	19.128		span)	
Ν	Mean (%O2)	19.060	19.127	_	Cylinder ID: EB0166973	
Difference of means (R-A) (%O2)		0.1	Limit 0.5	Passed	Expiration Date: 6/4/2032 EPA Vendor ID: 12024	
Ĺ	inearity Error (%)	0.3	Limit 5.0	Passed	Cylinder contains: O2 BALN	

Linearity Error (LE) Determination

*LE (%) = (|R-A| / R) * 100*

R = Reference gas value

A = Mean of actual CEMS responses

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx ppm @15% O2 1-Hr

		_
Reason	Duration	
Other Known Causes (excess)	1 hour	
Source operating time	75 hours	
Duration of NOx ppm @15% O2 1-Hr excess emissions	1 hour	
Source operating time with excess emissions	1.3%	

CALPEAK: ({optional DAHS description}): Cedar Reports 8.04.06 1/9/2025 8:16 AM, 1 Midway Excess Emissions Summary Page 1 of 22

Calpeak Excess Emissions for 10/1/2024 thru 12/31/2024: NOx ppm @15% O2 1-Hr

Parameter	Start	End	Duration	Value	Min	Max	Limit	Reason	Action
NOx ppm @15% O2 1-Hr	10/3/2024 4:00 PM	4:59 PM	1 hour	6.1	6.1	6.1	2.50	Other Known Causes (excess)	Troubleshoot & Repair

Total duration

1 hour

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx ppm @15% O2 4-Hr (Subpart KKKK)

Reason	Duration	
There are no excess emissions for this report.		
Source operating time	75 hours	
Duration of NOx ppm @15% O2 4-Hr (Subpart KKKK) excess emissions	0	
Source operating time with excess emissions	0.0%	

Calpeak Excess Emissions for 10/1/2024 thru 12/31/2024: NOx ppm @15% O2 4-Hr (Subpart KKKK)

	Parameter	Start	End	Duration	Value	Min	Max	Limit	Reason	Action
--	-----------	-------	-----	----------	-------	-----	-----	-------	--------	--------

There are no excess emissions for this report.

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx Lb/hr Per S/U

_

Reason	Duration
There are no excess emissions for this report.	
Source operating time	11 hours, 12 minutes
Duration of NOx Lb/hr Per S/U excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak Excess Emissions for 10/1/2024 thru 12/31/2024: NOx Lb/hr Per S/U

	Parameter Start	End	Duration	Value	Min	Max	Limit	Reason	Action	
--	-----------------	-----	----------	-------	-----	-----	-------	--------	--------	--

There are no excess emissions for this report.

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx Lb/hr Per S/D

Reason	Duration
Other Known Causes (excess)	2 minutes
Source operating time	3 hours, 43 minutes
Duration of NOx Lb/hr Per S/D excess emissions	2 minutes
Source operating time with excess emissions	0.9%

Calpeak Excess Emissions for 10/1/2024 thru 12/31/2024: NOx Lb/hr Per S/D

Parameter	Start	End	Duration	Value	Min	Max	Limit	Reason	Action
NOx Lb/hr Per S/D	10/3/2024 4:09 PM	4:09 PM	1 minute	3.61	3.61	3.61	3.00	Other Known Causes (excess)	Troubleshoot & Repair
NOx Lb/hr Per S/D	10/3/2024 4:34 PM	4:34 PM	1 minute	2.40	2.40	2.40	1.50	Other Known Causes (excess)	Troubleshoot & Repair
			a : ,						

Total duration

2 minutes

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: Normal Ops NOx lbs 1-Hr

Reason	Duration	
Other Known Causes (excess)	1 hour	
Source operating time	75 hours	
Duration of Normal Ops NOx lbs 1-Hr excess emissions	1 hour	
Source operating time with excess emissions	1.3%	

CALPEAK: ({optional DAHS description}): Cedar Reports 8.04.06 1/9/2025 8:16 AM, 1 Midway Excess Emissions Summary Page 9 of 22

Calpeak Excess Emissions for 10/1/2024 thru 12/31/2024: Normal Ops NOx lbs 1-Hr

Normal Ops NOx lbs 1-Hr 10/3/2024 4:00 PM 4:59 PM 1 hour 7.34 7.34 7.34 5.60 Other Known Causes Troubleshoot & Repair	Parameter	Start	End	Duration	Value	Min	Max	Limit	Reason	Action
	Normal Ops NOx lbs 1-Hr	10/3/2024 4:00 PM	4:59 PM	1 hour	7.34	7.34	7.34	5.60	Other Known Causes (excess)	Troubleshoot & Repair

Total duration

1 hour

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx lbs/Day

Reason	Duration
There are no excess emissions for this report.	
Source operating time	75 hours
Duration of NOx lbs/Day excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): Cedar Reports 8.04.06 1/9/2025 8:16 AM, 1 Midway Excess Emissions Summary Page 11 of 22

Calpeak Excess Emissions for 10/1/2024 thru 12/31/2024: NOx lbs/Day

	Parameter Start End	Duration \	Value Min I	Max Limit	Reason	Action
--	---------------------	------------	-------------	-----------	--------	--------

There are no excess emissions for this report.

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: CO ppm @15% O2 3-Hr Rolling

Reason	Duration
There are no excess emissions for this report.	
Source operating time	75 hours
Duration of CO ppm @15% O2 3-Hr Rolling excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak Excess Emissions for 10/1/2024 thru 12/31/2024: CO ppm @15% O2 3-Hr Rolling

	Parameter	Start	End	Duration	Value	Min	Max	Limit	Reason	Action
--	-----------	-------	-----	----------	-------	-----	-----	-------	--------	--------

There are no excess emissions for this report.

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: CO Lb/hr Per S/U

Reason	Duration
There are no excess emissions for this report.	
Source operating time	11 hours, 12 minutes
Duration of CO Lb/hr Per S/U excess emissions	0
Source operating time with excess emissions	0.0%
Calpeak Excess Emissions for 10/1/2024 thru 12/31/2024: CO Lb/hr Per S/U

Parameter Start End Duration value Min Max Limit Reason Action	Parameter	Start	End	Duration	Value	Min	Max	Limit	Reason	Action	
--	-----------	-------	-----	----------	-------	-----	-----	-------	--------	--------	--

There are no excess emissions for this report.

1 Midway Excess Emissions Summary

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: CO Lb/hr Per S/D

Reason	Duration
There are no excess emissions for this report.	
Source operating time	3 hours, 43 minutes
Duration of CO Lb/hr Per S/D excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak Excess Emissions for 10/1/2024 thru 12/31/2024: CO Lb/hr Per S/D

Parameter Start End Duration value Min Max Limit Reason Action	Parameter	Start	End	Duration	Value	Min	Max	Limit	Reason	Action	
--	-----------	-------	-----	----------	-------	-----	-----	-------	--------	--------	--

There are no excess emissions for this report.

1 Midway Excess Emissions Summary

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: Normal Ops CO lbs 3-Hr Rolling

Reason	Duration
There are no excess emissions for this report.	
Source operating time	75 hours
Duration of Normal Ops CO lbs 3-Hr Rolling excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak Excess Emissions for 10/1/2024 thru 12/31/2024: Normal Ops CO lbs 3-Hr Rolling

Parameter	Start	End	Duration	Value	Min	Max	Limit	Reason	Action

There are no excess emissions for this report.

1 Midway Excess Emissions Summary

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: CO lbs/Day

Reason	Duration
There are no excess emissions for this report.	
Source operating time	75 hours
Duration of CO lbs/Day excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak Excess Emissions for 10/1/2024 thru 12/31/2024: CO lbs/Day

	Parameter	Start	End	Duration	Value	Min	Max	Limit	Reason	Action
--	-----------	-------	-----	----------	-------	-----	-----	-------	--------	--------

There are no excess emissions for this report.

Calpeak

CEMS Downtime for 10/1/2024 thru 12/31/2024: NOx ppm @15% O2

Reason	Duration
There are no CEMS downtimes for this report.	
Source operating time	75 hours
Duration of NOx ppm @15% O2 monitor downtime	0
Percent monitor downtime	0.0%
Source operating time with valid data	75 hours
Percent monitor availability	100.0%

CALPEAK: ({optional DAHS description}): Cedar Reports 8.04.06 1/9/2025 8:04 AM, 1 Midway CEMS Downtime Summary Page 1 of 4

Calpeak CEMS Downtime for 10/1/2024 thru 12/31/2024: NOx lbs

Reason	Duration
There are no CEMS downtimes for this report.	
Source operating time	75 hours
Duration of NOx lbs monitor downtime	0
Percent monitor downtime	0.0%
Source operating time with valid data	75 hours
Percent monitor availability	100.0%
,	

Calpeak

CEMS Downtime for 10/1/2024 thru 12/31/2024: CO ppm @15% O2

Reason	Duration
There are no CEMS downtimes for this report.	
Source operating time	75 hours
Duration of CO ppm @15% O2 monitor downtime	0
Percent monitor downtime	0.0%
Source operating time with valid data	75 hours
Percent monitor availability	100.0%

CALPEAK: ({optional DAHS description}): Cedar Reports 8.04.06 1/9/2025 8:04 AM, 1 Midway CEMS Downtime Summary Page 3 of 4

Calpeak CEMS Downtime for 10/1/2024 thru 12/31/2024: CO lbs

Duration	
75 hours	
0	
0.0%	
75 hours	
100.0%	
	Duration 75 hours 0 0.0% 75 hours 100.0%

CALPEAK: ({optional DAHS description}): Cedar Reports 8.04.06 1/9/2025 8:04 AM, 1 Midway CEMS Downtime Summary Page 4 of 4



4350 Executive Drive Suite 320 San Diego, CA 92121 619-756-5795

October 11, 2024

Preet Bath Air Quality Inspector San Joaquin Valley APCD 1990 East Gettysburg Avenue Fresno, CA 93726-0244

RE: Title V – Deviation/Breakdown Report C-2024-10-2 Date of Occurrence: 10/3/2024 Date of Discovery: 10/3/2024 Midway Peaking, LLC

Dear Ms. Bath:

Pursuant to condition 11 of Permit to Operate (PTO) C-7286-0-3, Midway Peaking, LLC hereby submits the attached Title V Deviation Report, including the associated Certification of Truth and Accuracy.

Midway Peaking is aware that the breakdown notification to the district appears to be three minutes after the allotted one hour notification period. Midway received the initial excess emissions alarm on 10/3/24 at 16:10 CEMS time and due to the ongoing intermittent issue and the remote operations of the plant, the facility was in the process of diagnosing and restoring the unit to prevent additional excess emissions. Throughout this breakdown, the facility made a good faith effort to limit excess emissions and restore the facility to safe and stable operations as quickly as possible. Midway believes this time discrepancy falls within COM Policy 2035 IV.A.1 and should be excused.

Midway Peaking, LLC is committed to safe and environmentally responsible operations. Should you require additional information please contact Tony Gilmore, Compliance Manager at 619-756-5795.

Sincerely,

Claude Couvillion SVP of Operations and Development Middle River Power, LLC



4350 Executive Drive Suite 320 San Diego, CA 92121 619-756-5795

DISTRIBUTION LIST

- Preet Bath, Air Quality Inspector, San Joaquin Valley Air Pollution Control District (e copy)
- Ramiro Gonzalez, Plant Manager, Midway Peaking (e copy)
- > Kathy Hurst, Director of EHS, Middle River Power (e copy)
- > Taylor Leach, Environmental Specialist, NAES (e copy)





BREAKDOWN / TITLE V - DEVIATION REPORTING FORM

Check	Check the appropriate box if using this form to submit/report a:							
	Breakdown Notification (must be reported within 1 hour)	Title V Deviation						
	Breakdown Follow-up Report	Title V Deviation/Breakdown Follow-up Report						
 This form can be used to file the initial report of an equipment breakdown, and as the follow-up report for both a breakdown and/or deviation from a Federal Title V permit condition. The required reports must be submitted to the nearest District regional office as follows: Breakdown follow-up reports no later than 10 days <u>after returning to compliance</u> Deviation reports no later than 10 days <u>after discovery</u> 								
Company Name:Midway Peaking, LLCFacility ID:C-7286								
Brea	Breakdown - Initial Notification:							
	Reported by: <u>R. Gonzalez</u>	Date: 10/03/2024						
	Reported to:	Email Time: <u>5:13 PM (CEMS)</u>						
	BREAKDOWN / DEVIATI	ON INFORMATION						
1.	Permit unit and condition number(s):							
	C-7286-0-3, Condition 5							
	C-7286-1-4, C-7286-2-4, Conditions 8 & 11							
2.	Equipment involved:							
	Midway Unit 1 GTB (C-7286-2) engine exhaust air te	empering controls system.						
3.	Location of operation:							

43627 W Panoche Rd, Firebaugh, CA 93622

Central Region Office (Fresno, Kings, & Madera Counties) 1990 E Gettysburg Ave Fresno, CA 93726-0244 Tel: (559) 230-5950 ♦ FAX: (559) 230-6062 Southern Region Office (*Tulare County & Valley portion of Kern County*) 34946 Flyover Court Bakersfield, CA 93308-9725 Tel: (661) 392-5500 ♦ FAX: (661) 392-5585





4. Description of permit condition:

<u>C-7286-0-3</u>, <u>Condition 5</u>: The permittee must comply with all conditions of the permit including permit revisions originated by the District.

<u>C-7286-1-4, -2-4 Condition 8</u>: Combined emission rates from the CTG's operating under permit units C-7286-1 and C-7286-2, except during startup and shutdown periods, shall not exceed any of the following limits: **NOx (as NO2)- 5.6 lb/hr** and **2.5 ppmvd@ 15% 02**; CO - 8.38 lb/hr and 6.0 ppmvd @ 15% O2; VOC (as methane) - 1.64 lb/hr and 2.0 ppmvd @ 15% O2; PM10 - 3.70 lb/hr; or SOx (as SO2) - 1.78 lb/hr. NOx (as NO2) emission rates are one hour rolling averages. All other emission rates are three hour rolling averages.

<u>C-7286-1-4, -2-4 Condition 11</u>: During **shutdown**, CTG exhaust emission rates shall not exceed any of the following limits: **NOx (as NO2) - 1.50 lb/hr;** CO- 21.33 lb/hr; VOC (as methane)- 0.83 lb/hr; PM10- 1.85 lb/hr; or SOx (as SO2)- 0.89 lb/hr, based on a per event average.

5. Date, time, and duration of breakdown/deviation:

Deviation Periods:

- 10/03/2024 1600 1659 (1hr)
- 10/03/2024 1605 1609 (4-minute shutdown period)
- 10/03/2024 1628 1633 (6-minute shutdown period)

Breakdown Period: Based on a review of CEMS minute data, symptoms of the issue began on 10/03/2024 at 16:05. The breakdown condition was resolved on 10/03/2024 at 16:45.

[Note: All time periods in this report are in CEMS time]

6. Description of breakdown/deviation (include excess and visible emissions, if applicable):

Gas turbine B experienced a failure in the bleed air control system causing excess emissions.

Normal operation excess emissions:

- NOx ppm @15% O2 1-Hr:
 - 10/03/2024 4:00 PM 4:59 PM (CEMS): 6.1 ppm @ 15% O2 (Permit limit is 2.5 ppm @ 15% O2, 1 hour rolling average)
- NOx lb/hr:
 - 10/03/2024 4:00 PM 4:59 PM (CEMS): 7.34 lb/hr (Permit limit is 5.6 lb/hr, 1 hour rolling average)

Shutdown excess emissions:

- NOx lb/hr:
 - 10/03/2024 4:05 4:08 PM (CEMS): 3.61 lb/hr (Permit limit 3.0 lb/hr, event average two engine operation)
 - o 10/03/2024 4:28 4:33 PM (CEMS): 2.4 lb/hr (Permit limit 1.5 lb/hr, event average)

7. Date and time when breakdown/deviation was discovered:

10/03/2024 at 16:10 hours (CEMS time)

Northern Region Office (Merced, San Joaquin, & Stanislaus Counties) 4800 Enterprise Way Modesto, CA 95356-8718 Tel: (209) 557-6400 ♦ FAX: (209) 557-6475 Central Region Office (Fresno, Kings, & Madera Counties) 1990 E Gettysburg Ave Fresno, CA 93726-0244 Tel: (559) 230-5950 ♦ FAX: (559) 230-6062

Southern Region Office (Tulare County & Valley portion of Kern County) 34946 Flyover Court Bakersfield, CA 93308-9725 Tel: (661) 392-5500 ♦ FAX: (661) 392-5585



Date and time compliance was achieved:

8.



Probable cause of breakdown/deviation: 9. During the initial stages of the dispatch of Midway 1 on 10/3/2024, the turbine 'B' (GTB) damper failed causing two load reduction (driveback) events during the start process. These drivebacks are flagged as shutdown events based on fuel flow and MW load. Event investigation determined that Gas Turbine B (GTB) pantleg damper drive actuator positioner was the failed component (see attached photos). This piece of equipment controls a large damper that allows cooling air supplied from (tempering) air fans to be introduced into the hot exhaust stream. This process controls the turbine exhaust to a design temperature acceptable to the Selective Catalyst Reduction (SCR) NOx emission control component. The SCR NOx catalyst is rated up to an 850 degrees temperature. Temperatures higher than the 850 deg rating can potentially have negative effects on the NOx catalyst and SCR life. The SCR system has protection designed and employed in the Gas Turbine operating software to prevent SCR overtemperature conditions. The Gas Turbine controls will reduce turbine load (driveback) by reducing fuel to the turbine and shedding generator load to compensate for the high temperature. The control system will react to the (driveback) and attempt to return to a loaded condition when the temperature parameter allows. This resulted in the cycling of the protection system allowing the turbine and generator to resume load and subsequent rise in temperature and driveback again. The Midway operators noted this trend and the associated alarms and took appropriate action. After confirmation with an onsite technician and with no option to make repairs on the operating unit, the unit was shut down to prevent further potential exceedance. Once the engine was shut down, the site technician manually opened the damper and locked it in a stationary position. GTB restarted and completed operation with no further emission issues. Measures taken to correct this occurrence and prevent recurrence: 10. To following steps were implemented to investigate the cause and to prevent a recurrence: Conducted an inspection and determined the source temp and driveback alarm, which was a pantleg damper drive actuator positioner assembly.

10/03/2024 at 17:00, after shutting down and interim repairs completed and GTB restarted.

- The failed positioner was replaced and function checked. Operation was restored.

The damper assembly also inspected and found functionally operational.

- Attach photographs of defective equipment.
- Provide any additional information necessary to establish that this occurrence was the result of an unavoidable failure or malfunction; Rule 1100 *Equipment Breakdown* assigns the burden of proof to the source owner/operator seeking relief.

See attached CEMS Emissions and Operating Data

Northern Region Office (Merced, San Joaquin, & Stanislaus Counties) 4800 Enterprise Way Modesto, CA 95356-8718 Tel: (209) 557-6400 ♦ FAX: (209) 557-6475 Central Region Office (Fresno, Kings, & Madera Counties) 1990 E Gettysburg Ave Fresno, CA 93726-0244 Tel: (559) 230-5950 ♦ FAX: (559) 230-6062 Southern Region Office (*Tulare County & Valley portion of Kern County*) 34946 Flyover Court Bakersfield, CA 93308-9725 Tel: (661) 392-5500 ♦ FAX: (661) 392-5585

CERTIFICATION:

I declare, under penalty of perjury under the laws of the state of California, that based on information and belief formed after reasonable inquiry, all information provided in this report is true, accurate, and addresses all deviations that resulted from this event:

Signature of Responsible Official (Responsible Official only required for Title V Permit Holders)

Claude Couvillion Name of Responsible Official

SVP of Operations and Development

Title of Responsible Official

10/11/2024 Date

760-912-3007

Telephone

jcouvillion@mrpgenco.com Email

1 Midway Excess Emissions Summary

Calpeak Excess Emissions for 10/3/2024: NOx ppm @15% O2 1-Hr

Reason	Duration	-
Other Known Causes (excess)	1 hour	
Source operating time	5 hours	
Duration of NOx ppm @15% O2 1-Hr excess emissions	1 hour	
Source operating time with excess emissions	20.0%	
Duration of NOx ppm @15% O2 1-Hr excess emissions Source operating time with excess emissions	1 hour 20.0%	

Calpeak Excess Emissions for 10/3/2024: NOx ppm @15% O2 1-Hr

NOx ppm @15% O2 1-Hr 10/3/2024 4:00 PM 4:59 PM 1 hour 6.1 6.1 6.1 2.50 Other Known Causes (excess) Troubleshoot & Repair	Parameter	Start	End	Duration	Value	Min	Max	Limit	Reason	Action
	NOx ppm @15% O2 1-Hr	10/3/2024 4:00 PM	4:59 PM	1 hour	6.1	6.1	6.1	2.50	Other Known Causes (excess)	Troubleshoot & Repair

Total duration

1 hour

1 Midway Excess Emissions Summary

Calpeak Excess Emissions for 10/3/2024: NOx Lb/hr Per S/D

Reason	Duration
Other Known Causes (excess)	2 minutes
Source operating time	24 minutes
Duration of NOx Lb/hr Per S/D excess emissions	2 minutes
Source operating time with excess emissions	8.3%

Calpeak Excess Emissions for 10/3/2024: NOx Lb/hr Per S/D

NOv Lb/br Der C/D 40/2/2024 4:00 DM 4:00 DM 1 mir						
NOX LD/nr Per 5/D 10/3/2024 4:09 PM 4:09 PM 1 mir	nute 3.61	3.61	3.61	3.00	Other Known Causes (excess)	Troubleshoot & Repair
NOx Lb/hr Per S/D 10/3/2024 4:34 PM 4:34 PM 1 mir	nute 2.40	2.40	2.40	1.50	Other Known Causes (excess)	Troubleshoot & Repair

Total duration

2 minutes

1 Midway Excess Emissions Summary

Calpeak Excess Emissions for 10/3/2024: Normal Ops NOx lbs 1-Hr

Reason	Duration	
Other Known Causes (excess)	1 hour	
Source operating time	5 hours	
Duration of Normal Ops NOx lbs 1-Hr excess emissions	1 hour	
Source operating time with excess emissions	20.0%	

Calpeak Excess Emissions for 10/3/2024: Normal Ops NOx lbs 1-Hr

Parameter St	Start	End	Duration	Value	Min	Max	Limit	Reason	Action
Normal Ops NOx lbs 1-Hr 10	0/3/2024 4:00 PM	4:59 PM	1 hour	7.34	7.34	7.34	5.60	Other Known Causes (excess)	Troubleshoot & Repair

Total duration

1 hour

Calpeak California

Midway 1- Hourly Emissions Report October 3, 2024 - Hour 15

			NOx ppm (NOx	1-Hr @15% O2 - 2.5 lbs - 2.8	CC	Emission Lim 3-Hr Rolling O ppm @15% (CO lbs - 4.1	lits 7 D2 - 6 9	24-Hr NH3 Slip ppm NH3 Slip	Rolling @15% O2 - 10 lbs - ERR	_		
Minute	O2%	NOx ppm	NOx ppm @15% O2	NOx Ib/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO Ib/mmBtu	CO lb/hr	NH3 Slip ppm @15% O2	NH3 Slip Ib/hr	Process Status
00	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
01	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
02	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
03	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
04	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
05	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
06	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
07	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
08	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
09	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
10	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
11	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
12	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
20	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
21	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
24	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
25	20.86	0.00	0.00	0.0000	0.00	0.16	0.50	0.0011	0.04	Down	Down	Startup
26	19.36	0.33	1.02	0.0037	0.27	23.70	73.59	0.1636	12.04	Down	Down	Startup
27	18.23	9.86	21.79	0.0795	5.10	15.05	33.26	0.0739	4.74	Down	Down	Startup
28	18.47	7.28	17.68	0.0645	6.71	1.86	4.52	0.0100	1.04	Down	Down	Startup
29	17.21	4.44	7.10	0.0259	5.97	1.17	1.87	0.0042	0.96	Down	Down	Startup

CALPEAK: ({optional DAHS description}): Cedar Reports 8.04.06 10/10/2024 8:59 AM, Midway 1- Hourly Emissions Report

Minute	O2%	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lb/hr	NH3 Slip ppm @15% O2	NH3 Slip lb/hr	Process Status
30	16.42	6.26	8.24	0.0301	9.72	1.41	1.86	0.0041	1.32	Down	Down	Startup
31	15.89	12.32	14.51	0.0530	22.09	1.33	1.57	0.0035	1.46	Down	Down	Startup
32	15.16	21.96	22.57	0.0824	41.66	1.22	1.25	0.0028	1.42	Down	Down	Startup
33	14.67	57.38	54.34	0.1984	111.06	1.83	1.73	0.0039	2.18	Down	Down	Startup
34	14.54	35.79	33.20	0.1212	68.38	3.16	2.93	0.0065	3.66	Down	Down	Startup
35	14.50	21.20	19.54	0.0714	40.20	4.68	4.31	0.0096	5.41	Down	Down	Startup
36	14.51	19.39	17.90	0.0654	36.91	5.99	5.53	0.0123	6.94	Down	Down	Startup
37	14.52	19.39	17.93	0.0655	36.94	6.88	6.36	0.0141	7.95	Down	Down	Startup
38	14.69	19.29	18.33	0.0669	37.77	6.91	6.57	0.0146	8.24	Down	Down	Startup
39	14.99	18.89	18.86	0.0689	38.94	6.79	6.78	0.0151	8.53	Down	Down	Startup
40	14.94	18.50	18.31	0.0669	37.73	6.65	6.58	0.0146	8.23	Down	Down	Startup
41	15.23	19.05	19.82	0.0724	40.70	6.11	6.36	0.0141	7.93	Down	Down	Startup
42	15.27	21.09	22.10	0.0807	45.42	5.12	5.37	0.0119	6.70	9.3	7.88	Startup
43	15.47	20.00	21.73	0.0793	44.59	4.27	4.64	0.0103	5.79	20.3	18.00	Startup
44	15.33	5.68	6.02	0.0220	12.35	3.94	4.17	0.0093	5.22	9.7	8.42	Startup
45	15.07	2.76	2.79	0.0102	5.71	3.45	3.49	0.0078	4.36	7.7	6.16	Startup
46	15.24	3.09	3.22	0.0118	6.61	2.69	2.80	0.0062	3.48	9.3	7.84	Startup
47	15.30	3.18	3.35	0.0122	6.83	2.17	2.29	0.0051	2.86	9.3	7.85	Startup
48	15.33	2.97	3.15	0.0115	6.46	2.14	2.27	0.0050	2.81	10.6	8.98	Startup
49	15.29	2.65	2.79	0.0102	5.72	2.25	2.37	0.0053	2.97	10.3	8.41	Startup
50	15.33	2.43	2.57	0.0094	5.05	2.38	2.52	0.0056	3.01	11.2	9.14	Startup
51	15.53	2.39	2.63	0.0096	4.92	2.43	2.67	0.0059	3.03	11.5	9.75	Startup
52	15.57	2.24	2.48	0.0091	4.67	2.43	2.69	0.0060	3.07	11.1	9.23	Startup
53	15.49	1.97	2.15	0.0078	4.00	2.44	2.66	0.0059	3.03	11.3	9.23	Startup
54	15.41	1.90	2.04	0.0075	3.84	2.45	2.63	0.0059	3.03	11.5	9.22	Startup
55	15.46	1.93	2.09	0.0076	3.90	2.49	2.70	0.0060	3.08	10.9	8.72	Startup
56	15.44	1.84	1.99	0.0073	3.74	2.61	2.82	0.0063	3.23	10.4	8.21	Startup
57	15.43	1.78	1.92	0.0070	3.59	2.73	2.94	0.0065	3.34	9.9	8.21	Startup
58	15.44	1.84	1.99	0.0073	3.74	2.75	2.97	0.0066	3.38	9.5	7.69	Startup
59	15.47	1.83	1.99	0.0073	3.74	2.74	2.98	0.0066	3.38	7.7	6.15	Normal
Average Total 3-Hr RIng 24-Hr RIng	15.7	10.7		0.0415		4.2	6.3 NSD *	0.0140	4.47 2.47 NSD *	3.2 0.5	8.84 5.13 0.59	Startup

* - Excluding Startup & Shutdown Emissions

Calpeak California

Midway 1- Hourly Emissions Report October 3, 2024 - Hour 16

			NOx ppm (NOx	Emission Limits 1-Hr 3-Hr Rolling om @15% O2 - 2.5 CO ppm @15% O2 - 6 NOx lbs - 2.8 CO lbs - 4.19			24-Hr NH3 Slip ppm NH3 Slip	Rolling @15% O2 - 10 blbs - ERR	_			
Minute	O2%	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lb/hr	NH3 Slip ppm @15% O2	NH3 Slip lb/hr	Process Status
00	15.43	1.84	1.98	0.0072	3.69	2.74	2.96	0.0066	3.38	8.0	6.66	Normal
01	15.46	1.93	2.09	0.0076	3.90	2.73	2.96	0.0066	3.38	7.9	6.16	Normal
02	15.45	1.96	2.12	0.0077	3.94	2.72	2.94	0.0065	3.32	8.2	6.65	Normal
03	15.46	1.95	2.11	0.0077	3.94	2.71	2.94	0.0065	3.33	8.1	6.65	Normal
04	15.47	1.94	2.11	0.0077	3.94	2.71	2.94	0.0065	3.33	8.0	6.66	Normal
05	15.54	1.92	2.11	0.0077	3.31	2.69	2.96	0.0066	2.83	13.6	9.46	Shutdown
06	16.89	1.70	2.50	0.0091	2.03	2.59	3.81	0.0085	1.90	30.7	20.11	Shutdown
07	16.92	1.10	1.63	0.0060	2.06	1.95	2.89	0.0064	2.20	10.4	10.67	Shutdown
08	15.84	3.72	4.34	0.0158	7.02	1.10	1.28	0.0029	1.29	12.6	10.23	Shutdown
09	15.51	17.06	18.67	0.0682	34.27	0.81	0.89	0.0020	1.00	24.9	20.10	Normal
10	15.59	43.69	48.54	0.1772	89.83	1.20	1.33	0.0030	1.52	54.1	45.62	Normal
11	15.57	19.22	21.28	0.0777	39.78	1.66	1.84	0.0041	2.10	26.6	22.53	Normal
12	15.55	2.77	3.05	0.0112	5.73	2.07	2.28	0.0051	2.61	8.5	7.16	Normal
13	15.49	2.28	2.49	0.0091	4.66	2.44	2.66	0.0059	3.02	8.3	6.66	Normal
14	15.45	2.25	2.44	0.0089	4.55	2.67	2.89	0.0064	3.28	8.5	6.65	Normal
15	15.49	2.21	2.41	0.0088	4.51	2.69	2.93	0.0065	3.34	8.3	6.66	Normal
16	15.51	2.08	2.28	0.0083	4.25	2.70	2.96	0.0066	3.38	8.0	6.65	Normal
17	15.50	1.95	2.13	0.0078	4.00	2.70	2.95	0.0066	3.38	7.9	6.65	Normal
18	15.48	1.92	2.09	0.0076	3.83	2.69	2.93	0.0065	3.28	8.4	7.06	Normal
19	15.92	1.88	2.23	0.0081	2.57	2.69	3.19	0.0071	2.25	23.8	14.26	Shutdown
20	17.72	1.34	2.49	0.0091	1.74	2.43	4.51	0.0100	1.92	26.8	23.93	Shutdown
21	17.58	0.87	1.55	0.0056	1.61	1.65	2.93	0.0065	1.87	10.6	12.88	Shutdown
22	16.71	0.85	1.20	0.0044	1.67	0.86	1.21	0.0027	1.03	8.6	8.73	Shutdown
23	16.35	2.59	3.36	0.0123	5.54	0.78	1.01	0.0022	0.99	7.9	8.10	Shutdown
24	15.93	15.52	18.42	0.0673	33.88	1.20	1.42	0.0032	1.61	22.1	21.14	Normal
25	15.50	38.96	42.57	0.1554	70.33	1.63	1.78	0.0040	1.81	52.5	38.01	Normal
26	15.75	11.83	13.55	0.0495	24.53	1.69	1.94	0.0043	2.13	18.8	16.35	Normal
27	15.57	3.24	3.59	0.0131	6.70	1.58	1.75	0.0039	2.00	8.9	7.67	Normal
28	15.80	2.05	2.37	0.0087	4.03	1.86	2.15	0.0048	2.23	9.6	7.88	Shutdown
29	16.60	1.79	2.46	0.0090	2.83	2.17	2.98	0.0066	2.08	17.8	14.17	Shutdown
30	17.19	1.46	2.32	0.0085	2.64	1.96	3.12	0.0069	2.14	12.5	13.35	Shutdown

Minute	O2%	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lb/hr	NH3 Slip ppm @15% O2	NH3 Slip lb/hr	Process Status
31	17.24	1.04	1.68	0.0061	1.90	1.44	2.32	0.0052	1.62	11.2	12.15	Shutdown
32	17.24	0.84	1.35	0.0049	1.53	1.22	1.97	0.0044	1.37	9.1	9.97	Shutdown
33	17.27	0.80	1.30	0.0047	1.47	1.24	2.02	0.0045	1.41	7.8	8.74	Shutdown
34	17.21	0.79	1.26	0.0046	1.29	1.28	2.05	0.0045	1.26	8.9	8.67	Normal
35	17.00	0.78	1.18	0.0043	1.20	1.27	1.92	0.0043	1.20	10.0	8.64	Normal
36	17.00	0.77	1.16	0.0043	1.19	1.12	1.69	0.0038	1.05	10.1	8.60	Normal
37	16.99	0.75	1.13	0.0041	1.14	0.96	1.45	0.0032	0.89	10.0	8.65	Normal
38	17.00	0.74	1.12	0.0041	1.14	0.89	1.35	0.0030	0.84	10.0	8.64	Normal
39	16.99	0.75	1.13	0.0041	1.15	0.91	1.37	0.0031	0.87	9.7	8.40	Normal
40	16.98	0.76	1.14	0.0042	1.18	0.93	1.40	0.0031	0.87	9.9	8.42	Normal
41	17.00	0.76	1.15	0.0042	1.18	0.96	1.45	0.0032	0.90	9.8	8.39	Normal
42	17.02	0.76	1.16	0.0042	1.18	1.00	1.52	0.0034	0.95	9.5	8.39	Normal
43	17.02	0.77	1.17	0.0043	1.20	1.03	1.57	0.0035	0.98	9.5	8.40	Normal
44	17.02	0.78	1.19	0.0043	1.20	1.07	1.63	0.0036	1.01	9.5	8.40	Normal
45	17.06	0.78	1.20	0.0044	1.37	1.13	1.74	0.0039	1.21	5.8	5.58	Startup
46	17.16	0.80	1.26	0.0046	1.50	1.61	2.54	0.0056	1.82	3.7	3.92	Startup
47	17.17	0.89	1.41	0.0051	1.74	1.89	2.99	0.0066	2.25	2.5	3.06	Startup
48	17.05	1.45	2.22	0.0081	3.09	1.82	2.79	0.0062	2.37	3.3	3.82	Startup
49	16.64	4.13	5.72	0.0209	9.54	1.52	2.11	0.0047	2.15	8.7	10.04	Startup
50	16.14	11.83	14.66	0.0535	27.90	1.55	1.92	0.0043	2.24	18.7	20.34	Normal
51	15.87	11.85	13.90	0.0507	28.26	1.78	2.09	0.0046	2.56	18.5	18.95	Normal
52	15.76	2.27	2.61	0.0095	5.33	2.37	2.72	0.0060	3.36	7.6	7.29	Normal
53	15.76	1.05	1.21	0.0044	2.47	3.73	4.28	0.0095	5.33	6.2	6.17	Normal
54	15.76	0.99	1.14	0.0041	2.29	5.22	5.99	0.0133	7.46	6.1	6.17	Normal
55	15.77	0.94	1.08	0.0039	2.18	5.89	6.77	0.0151	8.46	6.0	6.16	Normal
56	15.78	0.91	1.05	0.0038	2.13	5.96	6.87	0.0153	8.58	5.9	6.17	Normal
57	15.79	0.89	1.03	0.0038	2.13	5.80	6.70	0.0149	8.34	5.9	6.16	Normal
58	15.78	0.88	1.01	0.0037	2.07	5.60	6.45	0.0143	8.01	5.9	6.17	Normal
59	15.81	0.88	1.02	0.0037	2.07	5.58	6.47	0.0144	8.07	5.6	5.60	Normal
Average Total 3-Hr Rlng 24-Hr Rlng	16.3	4.1		0.0176		2.2	2.7 NSD *	0.0061	2.95 2.70 NSD *	12.3 1.0	10.76 10.76 0.99	Startup

* - Excluding Startup & Shutdown Emissions

Calpeak California

Midway 1- Hourly Emissions Report October 3, 2024 - Hour 17

			Emission Limits 1-Hr 3-Hr Rolling NOx ppm @15% O2 - 2.5 CO ppm @15% O2 - 6 NH3 5 NOx lbs - 2.8 CO lbs - 4.19 N				24-Hr NH3 Slip ppm NH3 Slip	Rolling @15% O2 - 10 lbs - ERR	_			
Minute	O2%	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lb/hr	NH3 Slip ppm @15% O2	NH3 Slip Ib/hr	Process Status
00	15.81	0.86	1.00	0.0036	2.02	5.63	6.53	0.0145	8.12	5.5	5.60	Normal
01	15.81	0.87	1.01	0.0037	2.07	5.32	6.17	0.0137	7.65	5.6	5.58	Normal
02	15.80	0.92	1.06	0.0039	2.18	4.40	5.09	0.0113	6.32	5.7	5.59	Normal
03	15.81	1.00	1.16	0.0042	2.35	3.56	4.13	0.0092	5.14	5.7	5.59	Normal
04	15.81	1.04	1.21	0.0044	2.46	3.28	3.80	0.0084	4.69	5.9	6.15	Normal
05	15.81	1.05	1.22	0.0044	2.46	3.30	3.83	0.0085	4.75	5.8	5.59	Normal
06	15.81	1.04	1.21	0.0044	2.46	3.34	3.87	0.0086	4.80	5.9	6.14	Normal
07	15.81	1.04	1.21	0.0044	2.46	3.38	3.92	0.0087	4.86	5.8	5.59	Normal
08	15.81	1.02	1.18	0.0043	2.40	3.38	3.92	0.0087	4.86	5.8	5.59	Normal
09	15.81	1.02	1.18	0.0043	2.40	3.37	3.91	0.0087	4.85	5.9	6.14	Normal
10	15.81	1.03	1.19	0.0044	2.46	3.35	3.88	0.0086	4.81	5.5	5.59	Normal
11	15.82	1.03	1.20	0.0044	2.46	3.33	3.87	0.0086	4.81	5.4	5.59	Normal
12	15.81	1.02	1.18	0.0043	2.40	3.31	3.84	0.0085	4.74	5.1	5.02	Normal
13	15.82	1.01	1.17	0.0043	2.40	3.31	3.84	0.0085	4.74	5.0	5.02	Normal
14	15.82	1.03	1.20	0.0044	2.46	3.33	3.87	0.0086	4.79	5.1	5.02	Normal
15	15.82	1.02	1.18	0.0043	2.40	3.35	3.89	0.0086	4.81	5.0	5.03	Normal
16	15.83	1.01	1.18	0.0043	2.40	3.33	3.88	0.0086	4.80	4.5	4.46	Normal
17	15.83	1.03	1.20	0.0044	2.46	3.32	3.86	0.0086	4.79	4.2	4.46	Normal
18	15.83	1.05	1.22	0.0045	2.51	3.34	3.89	0.0086	4.80	4.1	4.46	Normal
19	15.83	1.07	1.25	0.0045	2.51	3.36	3.91	0.0087	4.86	3.3	3.35	Normal
20	15.83	1.07	1.25	0.0045	2.51	3.36	3.91	0.0087	4.85	3.3	3.35	Normal
21	15.83	1.05	1.22	0.0045	2.50	3.36	3.91	0.0087	4.85	2.4	2.23	Normal
22	15.83	1.08	1.26	0.0046	2.57	3.36	3.91	0.0087	4.86	2.3	2.24	Normal
23	15.84	1.12	1.31	0.0048	2.68	3.37	3.93	0.0087	4.85	1.5	1.67	Normal
24	15.83	1.11	1.29	0.0047	2.62	3.38	3.93	0.0087	4.85	1.6	1.67	Normal
25	15.83	1.13	1.31	0.0048	2.68	3.40	3.96	0.0088	4.92	1.5	1.68	Normal
26	15.83	1.17	1.36	0.0050	2.79	3.37	3.92	0.0087	4.85	1.6	1.67	Normal
27	15.83	1.19	1.38	0.0051	2.85	3.31	3.85	0.0086	4.79	1.5	1.67	Normal
28	15.83	1.25	1.45	0.0053	2.96	3.15	3.67	0.0081	4.52	1.6	1.67	Normal
29	15.83	1.32	1.54	0.0056	3.13	3.00	3.49	0.0078	4.35	1.7	1.67	Normal
30	15.83	1.29	1.50	0.0055	3.06	2.97	3.46	0.0077	4.29	1.7	1.67	Normal

Minute	02%	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lb/hr	NH3 Slip ppm @15% O2	NH3 Slip Ib/hr	Process Status
31	15.83	1.31	1.52	0.0056	3.12	2.99	3.48	0.0077	4.29	1.8	1.67	Normal
32	15.83	1.34	1.56	0.0057	3.17	2.99	3.48	0.0077	4.30	1.8	1.67	Normal
33	15.85	1.35	1.58	0.0058	3.23	2.94	3.43	0.0076	4.23	1.7	1.67	Normal
34	15.85	1.45	1.69	0.0062	3.45	2.79	3.26	0.0072	4.01	1.8	1.67	Normal
35	15.85	1.56	1.82	0.0067	3.72	2.61	3.05	0.0068	3.78	2.0	2.22	Normal
36	15.84	1.57	1.83	0.0067	3.72	2.54	2.96	0.0066	3.67	1.5	1.67	Normal
37	15.85	1.58	1.85	0.0067	3.73	2.54	2.97	0.0066	3.67	1.1	1.11	Normal
38	15.84	1.62	1.89	0.0069	3.84	2.54	2.96	0.0066	3.67	1.2	1.11	Normal
39	15.85	1.65	1.93	0.0070	3.89	2.54	2.97	0.0066	3.67	1.2	1.11	Normal
40	15.85	1.67	1.95	0.0071	3.94	2.57	3.00	0.0067	3.73	1.2	1.11	Normal
41	15.85	1.66	1.94	0.0071	3.94	2.61	3.05	0.0068	3.77	1.1	1.11	Normal
42	15.86	1.60	1.87	0.0068	3.78	2.67	3.13	0.0069	3.83	1.1	1.11	Normal
43	15.87	1.61	1.89	0.0069	3.83	2.72	3.19	0.0071	3.94	1.0	1.11	Normal
44	15.86	1.64	1.92	0.0070	3.88	2.76	3.23	0.0072	4.00	1.0	1.11	Normal
45	15.86	1.64	1.92	0.0070	3.89	2.76	3.23	0.0072	4.00	1.0	1.11	Normal
46	15.85	1.64	1.92	0.0070	3.89	2.74	3.20	0.0071	3.95	1.2	1.11	Normal
47	15.85	1.64	1.92	0.0070	3.89	2.74	3.20	0.0071	3.95	1.0	1.11	Normal
48	15.85	1.63	1.90	0.0070	3.89	2.75	3.21	0.0071	3.95	1.0	1.11	Normal
49	15.86	1.62	1.90	0.0069	3.83	2.75	3.22	0.0072	4.00	1.1	1.11	Normal
50	15.86	1.56	1.83	0.0067	3.72	2.71	3.17	0.0071	3.94	1.0	1.11	Normal
51	15.87	1.54	1.81	0.0066	3.67	2.66	3.12	0.0069	3.83	1.0	1.11	Normal
52	15.87	1.58	1.85	0.0068	3.77	2.64	3.10	0.0069	3.83	1.0	1.11	Normal
53	15.87	1.56	1.83	0.0067	3.72	2.64	3.10	0.0069	3.83	1.0	1.11	Normal
54	15.87	1.59	1.87	0.0068	3.77	2.64	3.10	0.0069	3.83	0.9	1.11	Normal
55	15.87	1.63	1.91	0.0070	3.88	2.64	3.10	0.0069	3.83	1.0	1.11	Normal
56	15.87	1.57	1.84	0.0067	3.72	2.64	3.10	0.0069	3.83	1.0	1.11	Normal
57	15.87	1.58	1.85	0.0068	3.77	2.64	3.10	0.0069	3.83	1.0	1.11	Normal
58	15.87	1.64	1.92	0.0070	3.89	2.66	3.12	0.0069	3.83	1.1	1.11	Normal
59	15.87	1.66	1.95	0.0071	3.93	2.68	3.14	0.0070	3.89	1.0	1.11	Normal
Average Total 3-Hr RIng	15.8	1.3		0.0056		3.1	3.6 3.1 *	0.0080	4.48 4.48 2.2 *	2.7	2.71 2.71	Normal
24-Hr Ring										1.1	1.10	

* - Excluding Startup & Shutdown Emissions

Calpeak California

Midway 1- Hourly Emissions Report October 3, 2024 - Hour 18

			1-Hr NOx ppm @15% O2 - 2.5 NOx lbs - 2.8		3-Hr Rolling CO ppm @15% O2 - 6 CO lbs - 4.19			24-Hr Rolling NH3 Slip ppm @15% O2 - 10 NH3 Slip lbs - ERR		0		
Minute	O2%	NOx ppm	NOx ppm @15% O2	NOx Ib/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO Ib/mmBtu	CO lb/hr	NH3 Slip ppm @15% O2	NH3 Slip lb/hr	Process Status
00	15.88	1.62	1.90	0.0070	3.88	2.69	3.16	0.0070	3.88	0.9	1.11	Normal
01	15.88	1.64	1.93	0.0070	3.88	2.68	3.15	0.0070	3.88	0.9	1.11	Normal
02	15.87	1.65	1.94	0.0071	3.94	2.70	3.17	0.0070	3.89	1.1	1.11	Normal
03	15.87	1.64	1.92	0.0070	3.88	2.71	3.18	0.0071	3.93	1.0	1.11	Normal
04	15.87	1.63	1.91	0.0070	3.88	2.70	3.17	0.0070	3.88	1.0	1.11	Normal
05	15.88	1.64	1.93	0.0070	3.88	2.70	3.17	0.0071	3.94	1.1	1.11	Normal
06	15.88	1.63	1.92	0.0070	3.88	2.71	3.19	0.0071	3.94	1.1	1.11	Normal
07	15.88	1.58	1.86	0.0068	3.77	2.71	3.19	0.0071	3.94	0.9	1.11	Normal
08	15.88	1.55	1.82	0.0067	3.72	2.72	3.20	0.0071	3.94	1.0	1.11	Normal
09	15.88	1.57	1.85	0.0067	3.71	2.73	3.21	0.0071	3.94	1.0	1.11	Normal
10	15.88	1.58	1.86	0.0068	3.77	2.73	3.21	0.0071	3.94	0.9	1.11	Normal
11	15.89	1.56	1.84	0.0067	3.73	2.74	3.23	0.0072	4.00	0.8	0.56	Normal
12	15.88	1.54	1.81	0.0066	3.66	2.75	3.23	0.0072	3.99	0.9	1.11	Normal
13	15.87	1.57	1.84	0.0067	3.72	2.77	3.25	0.0072	4.00	1.0	1.11	Normal
14	15.88	1.59	1.87	0.0068	3.77	2.78	3.27	0.0073	4.04	1.1	1.11	Normal
15	15.88	1.59	1.87	0.0068	3.77	2.78	3.27	0.0073	4.05	0.9	1.11	Normal
16	15.87	1.59	1.87	0.0068	3.77	2.80	3.28	0.0073	4.05	0.9	1.11	Normal
17	15.88	1.59	1.87	0.0068	3.77	2.81	3.30	0.0073	4.05	1.0	1.11	Normal
18	15.88	1.60	1.88	0.0069	3.83	2.81	3.30	0.0073	4.05	0.9	1.11	Normal
19	15.86	1.59	1.86	0.0068	3.77	2.81	3.29	0.0073	4.05	1.0	1.11	Normal
20	15.87	1.57	1.84	0.0067	3.71	2.82	3.31	0.0074	4.10	1.0	1.11	Normal
21	15.86	1.57	1.84	0.0067	3.72	2.83	3.31	0.0074	4.10	1.0	1.11	Normal
22	15.86	1.56	1.83	0.0067	3.72	2.82	3.30	0.0073	4.05	1.0	1.11	Normal
23	15.87	1.52	1.78	0.0065	3.61	2.78	3.26	0.0072	4.00	0.9	1.11	Normal
24	15.88	1.55	1.82	0.0067	3.72	2.77	3.26	0.0072	4.00	0.8	0.56	Normal
25	15.87	1.57	1.84	0.0067	3.71	2.78	3.26	0.0072	4.00	0.9	1.11	Normal
26	15.88	1.53	1.80	0.0066	3.66	2.79	3.28	0.0073	4.04	0.8	0.55	Normal
27	15.87	1.54	1.81	0.0066	3.66	2.78	3.26	0.0072	4.00	0.9	1.11	Normal
28	15.88	1.57	1.85	0.0067	3.71	2.78	3.27	0.0073	4.04	0.9	1.11	Normal
29	15.88	1.57	1.85	0.0067	3.71	2.78	3.27	0.0073	4.04	0.9	1.11	Normal
30	15.86	1.58	1.85	0.0068	3.77	2.79	3.27	0.0073	4.05	1.0	1.11	Normal

Minute	02%	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lb/hr	NH3 Slip ppm @15% O2	NH3 Slip Ib/hr	Process Status
31	15.86	1.56	1.83	0.0067	3.71	2.80	3.28	0.0073	4.05	1.0	1.11	Normal
32	15.87	1.55	1.82	0.0066	3.67	2.84	3.33	0.0074	4.11	0.2	0.00	Normal
33	15.86	1.60	1.87	0.0068	3.77	2.84	3.32	0.0074	4.10	0.1	0.00	Normal
34	15.87	1.69	1.98	0.0072	4.00	2.84	3.33	0.0074	4.11	0.2	0.00	Normal
35	15.87	1.72	2.02	0.0074	4.10	2.84	3.33	0.0074	4.10	0.2	0.00	Normal
36	15.87	1.70	1.99	0.0073	4.05	2.86	3.35	0.0075	4.16	0.2	0.00	Normal
37	15.87	1.68	1.97	0.0072	4.00	2.87	3.37	0.0075	4.16	0.1	0.00	Normal
38	15.87	1.65	1.94	0.0071	3.94	2.84	3.33	0.0074	4.11	0.1	0.00	Normal
39	15.85	1.70	1.99	0.0073	4.05	2.78	3.25	0.0072	4.00	0.3	0.56	Normal
40	15.85	1.77	2.07	0.0076	4.22	2.73	3.19	0.0071	3.94	0.3	0.56	Normal
41	15.85	1.76	2.06	0.0075	4.16	2.71	3.17	0.0070	3.88	0.3	0.55	Normal
42	15.86	1.80	2.11	0.0077	4.28	2.73	3.20	0.0071	3.94	0.2	0.00	Normal
43	15.86	1.81	2.12	0.0077	4.27	2.73	3.20	0.0071	3.94	0.4	0.55	Normal
44	15.86	1.77	2.07	0.0076	4.21	2.71	3.17	0.0071	3.94	0.3	0.55	Normal
45	15.86	1.69	1.98	0.0072	3.99	2.67	3.13	0.0069	3.83	0.2	0.00	Normal
46	15.86	1.71	2.00	0.0073	4.05	2.66	3.11	0.0069	3.83	0.2	0.00	Normal
47	15.86	1.79	2.10	0.0077	4.27	2.70	3.16	0.0070	3.88	0.2	0.00	Normal
48	15.87	1.81	2.12	0.0078	4.33	2.73	3.20	0.0071	3.94	0.3	0.55	Normal
49	15.87	1.82	2.13	0.0078	4.32	2.73	3.20	0.0071	3.94	0.2	0.00	Normal
50	15.86	1.82	2.13	0.0078	4.32	2.74	3.21	0.0071	3.94	0.3	0.55	Normal
51	15.87	1.80	2.11	0.0077	4.27	2.77	3.25	0.0072	4.00	0.2	0.00	Normal
52	15.87	1.71	2.01	0.0073	4.05	2.78	3.26	0.0072	4.00	0.1	0.00	Normal
53	15.86	1.73	2.03	0.0074	4.11	2.80	3.28	0.0073	4.05	0.3	0.55	Normal
54	15.86	1.76	2.06	0.0075	4.15	2.84	3.32	0.0074	4.11	0.2	0.00	Normal
55	15.87	1.77	2.08	0.0076	4.22	2.86	3.35	0.0075	4.16	0.1	0.00	Normal
56	15.86	1.82	2.13	0.0078	4.32	2.86	3.35	0.0074	4.11	0.2	0.00	Normal
57	15.86	1.83	2.14	0.0078	4.33	2.84	3.32	0.0074	4.10	0.3	0.55	Normal
58	15.86	1.83	2.14	0.0078	4.32	2.83	3.31	0.0074	4.10	0.3	0.55	Normal
59	15.86	1.82	2.13	0.0078	4.32	2.82	3.30	0.0073	4.04	0.3	0.55	Normal
Average Total	15.9	1.7		0.0071		2.8	3.3	0.0072	4.00 4.00	0.6	0.67 0.67	Normal
24-Hr Ring							3.2 "		3.5	1.1	1.10	

* - Excluding Startup & Shutdown Emissions

Calpeak California

Midway 1- Hourly Emissions Report October 3, 2024 - Hour 19

			%NOx ppm NOx	1-Hr ⊉15% O2 - 2.5 lbs - 2.8	Emission Limits 3-Hr Rolling 2.5 CO ppm @15% O2 - 6 CO lbs - 4.19			24-Hr NH3 Slip ppm NH3 Slip	Rolling @15% O2 - 10 lbs - ERR	_		
Minute	O2%	NOx ppm	NOx ppm @15% O2	NOx Ib/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lb/hr	NH3 Slip ppm @15% O2	NH3 Slip Ib/hr	Process Status
00	15.87	1.83	2.15	0.0078	4.32	2.81	3.30	0.0073	4.04	0.2	0.00	Normal
01	15.86	1.85	2.17	0.0079	4.38	2.82	3.30	0.0073	4.04	0.3	0.55	Normal
02	15.87	1.85	2.17	0.0079	4.38	2.83	3.32	0.0074	4.11	0.2	0.00	Normal
03	15.88	1.82	2.14	0.0078	4.33	2.82	3.31	0.0074	4.10	0.1	0.00	Normal
04	15.88	1.82	2.14	0.0078	4.32	2.80	3.29	0.0073	4.04	0.2	0.00	Normal
05	15.88	1.85	2.17	0.0079	4.38	2.80	3.29	0.0073	4.05	0.2	0.00	Normal
06	15.87	1.87	2.19	0.0080	4.43	2.80	3.28	0.0073	4.05	0.3	0.55	Normal
07	15.89	1.86	2.19	0.0080	4.44	2.80	3.30	0.0073	4.05	0.3	0.55	Normal
08	15.88	1.85	2.17	0.0079	4.37	2.81	3.30	0.0073	4.04	0.2	0.00	Normal
09	15.88	1.85	2.17	0.0079	4.38	2.83	3.33	0.0074	4.10	0.2	0.00	Normal
10	15.89	1.87	2.20	0.0080	4.43	2.83	3.33	0.0074	4.09	0.2	0.00	Normal
11	15.89	1.88	2.21	0.0081	4.48	2.84	3.34	0.0074	4.10	0.2	0.00	Normal
12	15.88	1.86	2.19	0.0080	4.43	2.87	3.37	0.0075	4.15	0.2	0.00	Normal
13	15.87	1.86	2.18	0.0080	4.44	2.90	3.40	0.0076	4.21	0.3	0.55	Normal
14	15.88	1.88	2.21	0.0081	4.50	2.89	3.40	0.0075	4.16	0.2	0.00	Normal
15	15.87	1.88	2.21	0.0081	4.50	2.88	3.38	0.0075	4.16	0.3	0.56	Normal
16	15.88	1.86	2.19	0.0080	4.43	2.86	3.36	0.0075	4.15	0.2	0.00	Normal
17	15.87	1.85	2.17	0.0079	4.38	2.85	3.34	0.0074	4.10	0.3	0.55	Normal
18	15.86	1.79	2.10	0.0077	4.27	2.84	3.32	0.0074	4.11	0.2	0.00	Normal
19	15.88	1.72	2.02	0.0074	4.11	2.84	3.34	0.0074	4.11	0.0	0.00	Normal
20	15.88	1.74	2.05	0.0075	4.15	2.84	3.34	0.0074	4.11	0.1	0.00	Normal
21	15.89	1.81	2.13	0.0078	4.33	2.85	3.36	0.0075	4.17	0.1	0.00	Normal
22	15.89	1.83	2.16	0.0079	4.38	2.84	3.34	0.0074	4.11	0.1	0.00	Normal
23	15.88	1.83	2.15	0.0079	4.38	2.84	3.34	0.0074	4.10	0.2	0.00	Normal
24	15.89	1.84	2.17	0.0079	4.38	2.83	3.33	0.0074	4.10	0.2	0.00	Normal
25	15.89	1.85	2.18	0.0080	4.44	2.81	3.31	0.0074	4.10	0.2	0.00	Normal
26	15.88	1.85	2.17	0.0079	4.39	2.81	3.30	0.0073	4.06	0.2	0.00	Normal
27	15.88	1.84	2.16	0.0079	4.39	2.83	3.33	0.0074	4.11	0.1	0.00	Normal
28	15.88	1.83	2.15	0.0079	4.38	2.84	3.34	0.0074	4.10	0.2	0.00	Normal
29	15.87	1.85	2.17	0.0079	4.38	2.86	3.35	0.0075	4.15	0.3	0.55	Normal
30	15.89	1.86	2.19	0.0080	4.30	2.88	3.39	0.0075	4.03	0.9	1.07	Normal

Minute	O2%	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lb/hr	NH3 Slip ppm @15% O2	NH3 Slip lb/hr	Process Status
31	16.28	1.87	2.39	0.0087	3.73	2.83	3.61	0.0080	3.43	5.0	4.71	Normal
32	16.93	1.85	2.75	0.0100	3.41	2.43	3.61	0.0080	2.72	7.7	7.84	Shutdown
33	17.54	1.22	2.14	0.0078	2.06	1.88	3.30	0.0073	1.93	9.9	10.86	Shutdown
34	17.98	0.76	1.54	0.0056	1.11	1.59	3.21	0.0071	1.41	14.9	16.30	Shutdown
35	18.59	0.69	1.76	0.0064	0.71	1.83	4.67	0.0104	1.15	31.7	30.62	Shutdown
36	19.31	0.71	2.20	0.0080	0.57	1.76	5.47	0.0121	0.86	48.3	53.15	Shutdown
37	19.52	0.70	2.17	0.0079	0.52	1.19	3.70	0.0082	0.54	53.7	63.40	Shutdown
38	19.50	0.51	1.58	0.0058	0.39	0.57	1.77	0.0039	0.26	51.9	61.27	Shutdown
39	19.51	0.44	1.37	0.0050	0.34	0.53	1.65	0.0037	0.25	50.9	61.03	Shutdown
40	19.49	0.43	1.34	0.0049	0.33	0.60	1.86	0.0041	0.28	50.9	60.22	Shutdown
41	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
42	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
43	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
44	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
45	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
46	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
47	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
48	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
49	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
50	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
51	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
52	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
53	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
54	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
55	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
56	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
57	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
58	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
59	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
Average Total	16.5	1.6		0.0077		2.5	3.3	0.0074	3.41 2.32	5.5	9.13 6.21	Shutdown
3-Hr RIng 24-Hr RIng							3.4 *		3.5 *	1.0	1.06	

* - Excluding Startup & Shutdown Emissions

Calpeak California Midway 1- Hourly Operations Report October 3, 2024 - Hour 15

Minute	CT-A Nat Gas Flow lb/hr	CT-B Nat Gas Flow lb/hr	Heat Input Rate mmBtu/hr	NH3 Flow lb/hr	Megawatts	SCR Inlet Temp °F	Stack HSL Temp °F	Shelter Temp °F	Process Status
00	Down	Down	Down	Down	Down	111.3	149.9	71.2	Down
01	Down	Down	Down	Down	Down	111.4	149.9	71.1	Down
02	Down	Down	Down	Down	Down	111.4	150.0	71.1	Down
03	Down	Down	Down	Down	Down	111.4	150.0	71.3	Down
04	Down	Down	Down	Down	Down	111.4	150.0	71.6	Down
05	Down	Down	Down	Down	Down	111.4	150.0	71.9	Down
06	Down	Down	Down	Down	Down	111.4	150.0	72.2	Down
07	Down	Down	Down	Down	Down	111.4	150.0	72.5	Down
08	Down	Down	Down	Down	Down	111.5	150.1	72.9	Down
09	Down	Down	Down	Down	Down	111.5	150.0	73.3	Down
10	Down	Down	Down	Down	Down	111.5	149.9	73.8	Down
11	Down	Down	Down	Down	Down	111.6	150.0	74.5	Down
12	Down	Down	Down	Down	Down	111.5	150.1	75.0	Down
13	Down	Down	Down	Down	Down	111.6	150.0	74.9	Down
14	Down	Down	Down	Down	Down	111.6	150.1	74.3	Down
15	Down	Down	Down	Down	Down	111.6	150.0	73.6	Down
16	Down	Down	Down	Down	Down	111.6	150.0	72.8	Down
17	Down	Down	Down	Down	Down	111.6	150.0	71.8	Down
18	Down	Down	Down	Down	Down	111.6	150.0	70.9	Down
19	Down	Down	Down	Down	Down	111.6	149.9	70.7	Down
20	Down	Down	Down	Down	Down	111.6	150.0	71.2	Down
21	Down	Down	Down	Down	Down	111.7	149.9	72.0	Down
22	Down	Down	Down	Down	Down	111.6	150.0	72.7	Down
23	Down	Down	Down	Down	Down	111.5	150.0	73.5	Down
24	Down	Down	Down	Down	Down	111.4	150.0	74.2	Down
25	1432.1	Down	33.5	Down	0.0	111.3	163.8	74.8	Startup
26	3149.0	Down	73.6	Down	0.0	116.9	207.8	75.5	Startup
27	2743.8	Down	64.2	Down	0.0	141.7	253.6	76.1	Startup
28	4449.3	Down	104.1	Down	4.1	171.4	297.0	76.7	Startup
29	7871.7	1982.3	230.4	Down	14.8	211.0	338.9	77.1	Startup
30	8866.1	4939.3	322.8	Down	24.8	263.0	365.7	76.8	Startup
31	9662.2	8155.1	416.7	Down	35.0	340.2	360.8	76.1	Startup
32	10526.1	11097.2	505.6	Down	44.9	429.8	359.0	75.2	Startup
33	11493.6	12441.2	559.8	Down	50.0	515.1	358.8	74.3	Startup

Minute	CT-A Nat Gas Flow lb/hr	CT-B Nat Gas Flow lb/hr	Heat Input Rate mmBtu/hr	NH3 Flow lb/hr	Megawatts	SCR Inlet Temp °F	Stack HSL Temp °F	Shelter Temp °F	Process Status
34	11611.4	12514.1	564.1	Down	50.1	585.4	359.0	73.3	Startup
35	11560.7	12519.4	563.1	Down	50.1	640.7	359.0	72.3	Startup
36	11615.0	12522.8	564.4	Down	50.1	684.2	359.0	71.6	Startup
37	11599.2	12521.9	564.0	Down	50.1	719.2	358.9	71.7	Startup
38	11637.7	12507.7	564.6	Down	50.1	747.2	359.0	72.3	Startup
39	11623.8	12539.3	565.1	Down	50.1	767.3	359.0	73.0	Startup
40	11605.1	12515.4	563.9	Down	50.1	785.2	359.0	73.7	Startup
41	11554.8	12487.9	562.2	Down	50.1	797.3	359.1	74.5	Startup
42	11596.7	12471.8	562.8	56.56	50.1	807.4	359.0	75.2	Startup
43	11555.5	12495.6	562.4	108.09	50.1	813.8	359.0	75.8	Startup
44	11573.3	12438.0	561.5	126.88	50.1	820.6	359.0	76.4	Startup
45	11532.3	12402.7	559.6	126.02	50.1	830.3	359.0	77.0	Startup
46	11567.4	12387.5	560.2	134.24	50.1	837.2	359.0	77.5	Startup
47	11578.9	12390.9	560.5	135.36	50.0	842.1	359.0	77.6	Startup
48	11600.3	12404.0	561.2	142.68	50.0	846.0	359.0	76.9	Startup
49	11564.0	12403.9	560.4	141.76	50.1	849.5	359.1	76.0	Startup
50	11075.0	11922.8	537.7	141.41	47.7	852.2	359.0	75.2	Startup
51	10567.8	11379.4	513.2	141.21	45.1	852.3	358.9	74.2	Startup
52	10574.1	11351.2	512.7	141.25	45.1	850.8	359.0	73.1	Startup
53	10578.4	11357.0	512.9	141.25	45.1	850.8	358.8	72.1	Startup
54	10550.9	11360.0	512.5	140.01	45.1	852.0	358.9	71.6	Startup
55	10557.2	11371.9	512.9	138.94	45.1	853.1	358.9	71.9	Startup
56	10571.9	11371.4	513.1	136.83	45.1	853.4	358.9	72.6	Startup
57	10564.7	11377.1	513.2	134.69	45.1	853.6	358.9	73.3	Startup
58	10571.7	11363.2	513.0	133.40	45.1	853.7	358.9	74.1	Startup
59	10570.7	11358.9	512.9	126.82	45.1	854.1	359.0	74.9	Normal
Average Total	10050.1 5.8 klb	11366.2 5.9 klb	500.8 290.5	130.41 0.0 klbs	40.8	433.1	263.1	73.8	Startup

Calpeak California Midway 1- Hourly Operations Report October 3, 2024 - Hour 16

Minute	CT-A Nat Gas Flow lb/hr	CT-B Nat Gas Flow lb/hr	Heat Input Rate mmBtu/hr	NH3 Flow lb/hr	Megawatts	SCR Inlet Temp °F	Stack HSL Temp °F	Shelter Temp °F	Process Status
00	10557.0	11355.6	512.4	126.87	45.1	854.8	358.9	75.6	Normal
01	10576.2	11360.0	513.0	127.06	45.1	855.2	358.9	76.2	Normal
02	10550.0	11343.9	511.8	127.17	45.1	855.4	358.9	76.8	Normal
03	10539.6	11350.4	511.8	127.23	45.1	855.5	358.9	77.3	Normal
04	10569.6	11349.1	512.5	127.19	45.1	856.0	359.1	77.2	Normal
05	8772.7	9616.7	430.1	127.29	35.8	856.2	358.9	76.4	Shutdown
06	6911.5	2643.2	223.4	127.43	13.4	850.4	358.9	75.5	Shutdown
07	10698.4	4017.5	344.2	127.53	27.1	838.6	359.0	74.5	Shutdown
08	11987.1	7024.3	444.6	127.50	38.0	833.1	358.9	73.5	Shutdown
09	11336.0	10154.2	502.5	127.50	44.9	839.6	359.0	72.8	Normal
10	10677.2	11002.1	507.0	127.51	45.1	848.6	359.0	72.0	Normal
11	10671.5	11220.1	512.0	127.49	45.1	851.5	358.8	71.7	Normal
12	10659.3	11223.5	511.7	127.38	45.1	852.8	358.8	71.6	Normal
13	10673.5	11234.4	512.3	127.53	45.1	854.3	358.9	71.8	Normal
14	10672.2	11209.3	511.7	127.55	45.1	855.8	358.9	72.0	Normal
15	10695.5	11219.5	512.5	127.65	45.1	856.9	358.8	72.3	Normal
16	10693.2	11199.9	511.9	127.59	45.1	857.7	358.8	72.7	Normal
17	10670.6	11213.4	511.7	127.57	45.1	857.9	358.8	73.0	Normal
18	10497.9	11055.8	504.0	127.62	44.1	858.1	358.9	73.4	Normal
19	7067.7	6484.8	316.9	127.67	23.4	856.8	358.9	73.8	Shutdown
20	6483.0	1700.4	191.4	127.74	10.6	847.1	358.8	74.1	Shutdown
21	10364.2	1878.1	286.2	127.71	21.0	827.7	358.9	74.5	Shutdown
22	11972.0	4262.0	379.5	127.81	30.8	811.6	358.9	74.8	Shutdown
23	11896.6	7356.8	450.1	127.73	38.8	805.6	358.9	74.5	Shutdown
24	11212.7	10312.5	503.4	127.54	45.1	810.8	358.9	74.0	Normal
25	9515.7	9837.2	452.6	127.63	38.3	824.4	358.9	73.7	Normal
26	10576.8	10619.7	495.6	127.57	43.4	834.6	358.9	72.9	Normal
27	10748.7	11132.6	511.7	127.63	45.0	842.3	358.9	72.1	Normal
28	11983.5	7824.9	463.2	127.79	39.1	842.9	358.8	71.1	Shutdown
29	11972.6	1492.7	314.8	127.93	24.7	827.6	358.8	70.8	Shutdown
30	11973.3	1304.5	310.5	128.03	24.3	776.2	358.9	70.8	Shutdown
31	11995.2	1332.2	311.7	128.14	24.3	725.9	358.9	71.0	Shutdown
32	11953.2	1363.8	311.4	121.71	24.4	684.7	358.8	71.2	Shutdown
33	11971.0	1379.3	312.1	118.32	24.4	650.7	358.9	71.6	Shutdown
34	11967.9	Down	279.8	107.85	24.1	622.6	358.9	71.9	Normal
Minute	CT-A Nat Gas Flow lb/hr	CT-B Nat Gas Flow lb/hr	Heat Input Rate mmBtu/hr	NH3 Flow lb/hr	Megawatts	SCR Inlet Temp °F	Stack HSL Temp °F	Shelter Temp °F	Process Status
------------------	----------------------------	----------------------------	-----------------------------	--------------------	-----------	----------------------	----------------------	--------------------	----------------
35	11913.3	Down	278.6	105.30	24.0	590.3	358.8	72.3	Normal
36	11870.0	Down	277.5	105.15	23.7	568.9	358.8	72.7	Normal
37	11929.5	Down	279.0	105.04	23.9	553.2	358.9	73.2	Normal
38	11913.7	Down	278.6	105.00	23.9	540.2	358.9	73.6	Normal
39	11976.0	Down	280.0	104.94	24.0	531.4	358.9	74.1	Normal
40	11997.0	Down	280.6	105.04	24.0	522.3	358.9	74.4	Normal
41	11967.0	Down	279.8	105.01	23.9	514.2	359.0	74.4	Normal
42	11966.7	Down	279.8	104.99	23.9	506.5	358.9	74.1	Normal
43	11972.0	Down	279.9	104.89	24.0	500.4	358.8	73.6	Normal
44	11981.0	Down	280.1	104.88	24.0	494.9	359.0	72.9	Normal
45	11935.9	1334.2	310.3	104.95	24.3	483.9	358.8	72.2	Startup
46	11633.9	2323.9	326.5	105.03	25.1	472.6	358.9	71.3	Startup
47	10658.4	3903.7	340.5	104.84	26.5	481.1	358.8	71.0	Startup
48	10758.8	5568.2	381.8	113.64	30.9	507.7	358.8	71.0	Startup
49	11441.6	8072.3	456.3	131.37	39.5	551.4	358.9	71.1	Startup
50	10781.1	11516.7	521.4	139.34	46.7	603.8	358.8	71.4	Normal
51	10970.7	12862.8	557.3	143.55	49.9	653.6	358.8	71.7	Normal
52	11201.0	12789.3	560.9	143.34	50.0	692.3	358.8	72.0	Normal
53	11255.5	12728.0	560.9	143.24	50.0	720.4	358.8	72.4	Normal
54	11307.9	12664.7	560.5	143.35	50.1	742.0	358.9	72.8	Normal
55	11346.4	12607.8	560.1	143.18	50.0	758.0	358.9	73.1	Normal
56	11364.5	12602.2	560.5	143.13	50.0	770.3	358.9	73.5	Normal
57	11362.2	12581.7	559.9	143.11	50.1	779.9	358.9	73.9	Normal
58	11371.4	12599.7	560.5	143.10	50.0	787.5	358.9	74.3	Normal
59	11359.2	12587.1	560.0	142.46	50.1	793.3	359.0	74.1	Normal
Average Total	11005.0 11.0 klb	8486.1 7.0 klb	455.9 455.9	124.46 0.1 klbs	35.9	731.7	358.9	73.2	Startup

Calpeak California Midway 1- Hourly Operations Report October 3, 2024 - Hour 17

Minute	CT-A Nat Gas Flow lb/hr	CT-B Nat Gas Flow lb/hr	Heat Input Rate mmBtu/hr	NH3 Flow lb/hr	Megawatts	SCR Inlet Temp °F	Stack HSL Temp °F	Shelter Temp °F	Process Status
00	11397.4	12566.3	560.4	142.14	50.1	797.7	358.8	73.7	Normal
01	11399.2	12473.4	558.3	142.12	50.1	801.5	358.9	73.1	Normal
02	11464.4	12431.7	558.8	142.05	50.1	805.1	358.8	72.4	Normal
03	11491.6	12431.9	559.4	142.13	50.1	808.7	358.9	71.7	Normal
04	11464.6	12429.7	558.7	142.37	50.1	811.4	358.9	70.9	Normal
05	11463.4	12425.4	558.6	142.31	50.0	813.0	358.8	70.6	Normal
06	11449.2	12425.4	558.3	142.40	50.1	814.4	358.9	71.0	Normal
07	11480.1	12408.0	558.6	142.23	50.1	815.5	358.9	71.7	Normal
08	11487.4	12407.1	558.7	142.35	50.0	816.5	358.9	72.5	Normal
09	11463.2	12401.5	558.1	142.48	50.1	817.3	358.8	73.3	Normal
10	11471.8	12424.3	558.8	140.89	50.1	818.0	358.9	74.1	Normal
11	11467.5	12423.1	558.7	140.52	50.1	818.7	358.9	74.8	Normal
12	11442.7	12415.5	557.8	138.84	50.0	819.1	358.8	75.5	Normal
13	11442.3	12428.6	558.1	138.81	50.1	819.5	358.9	76.1	Normal
14	11443.2	12392.7	557.3	138.81	50.1	819.8	358.9	76.6	Normal
15	11478.8	12422.1	558.8	138.78	50.1	819.9	358.9	77.2	Normal
16	11456.9	12411.2	558.1	137.04	50.1	820.1	358.9	77.3	Normal
17	11456.3	12404.9	558.0	135.52	50.1	820.4	358.9	76.7	Normal
18	11440.2	12418.9	557.9	134.60	50.0	820.7	358.8	75.9	Normal
19	11492.3	12398.1	558.6	131.30	50.1	821.0	359.0	74.8	Normal
20	11435.7	12407.1	557.5	130.67	50.1	821.3	358.8	73.9	Normal
21	11447.9	12396.3	557.5	126.67	50.1	821.4	358.8	72.9	Normal
22	11477.5	12418.9	558.8	126.38	50.1	821.4	358.8	72.1	Normal
23	11453.5	12403.3	557.9	122.58	50.1	821.4	358.9	71.7	Normal
24	11464.2	12404.4	558.1	122.51	50.1	821.5	358.8	72.0	Normal
25	11460.5	12421.1	558.4	122.30	50.1	821.9	358.8	72.7	Normal
26	11453.8	12405.6	558.0	122.48	50.1	822.4	358.8	73.4	Normal
27	11452.0	12406.9	557.9	122.28	50.1	822.7	358.8	74.1	Normal
28	11451.5	12396.1	557.7	122.32	50.1	823.2	358.8	74.8	Normal
29	11434.1	12409.2	557.5	122.23	50.1	823.4	358.8	75.6	Normal
30	11441.6	12397.4	557.4	122.24	50.1	823.6	358.9	76.2	Normal
31	11425.3	12377.6	556.5	122.31	50.0	823.7	358.8	76.8	Normal
32	11413.9	12413.7	557.2	122.21	50.1	823.9	358.9	77.3	Normal
33	11424.2	12359.5	556.1	122.22	50.0	824.2	358.9	77.7	Normal
34	11434.8	12363.2	556.5	122.31	50.1	824.6	358.9	77.4	Normal

CALPEAK: ({optional DAHS description}): Cedar Reports 8.04.06 10/10/2024 9:01 AM, Midway 1- Hourly Operations Report

Minute	CT-A Nat Gas Flow lb/hr	CT-B Nat Gas Flow lb/hr	Heat Input Rate mmBtu/hr	NH3 Flow lb/hr	Megawatts	SCR Inlet Temp °F	Stack HSL Temp °F	Shelter Temp °F	Process Status
35	11391.1	12372.1	555.7	122.34	50.1	824.8	358.9	76.5	Normal
36	11393.6	12374.2	555.8	119.59	50.1	824.8	358.9	75.5	Normal
37	11433.3	12364.1	556.4	117.80	50.1	824.8	358.9	74.5	Normal
38	11401.2	12377.1	556.0	117.72	50.1	824.9	358.9	73.6	Normal
39	11417.5	12355.1	555.9	117.69	50.0	825.0	358.8	72.6	Normal
40	11401.7	12351.9	555.5	117.68	50.1	824.9	358.8	71.8	Normal
41	11410.0	12349.7	555.6	117.59	50.1	824.7	358.8	71.9	Normal
42	11391.3	12361.8	555.5	117.70	50.1	824.3	358.9	72.4	Normal
43	11392.0	12340.2	554.9	117.57	50.1	823.7	358.8	73.2	Normal
44	11391.3	12354.2	555.3	117.57	50.1	823.4	358.9	73.9	Normal
45	11420.4	12341.9	555.6	117.57	50.1	823.3	358.8	74.6	Normal
46	11422.9	12358.9	556.1	117.65	50.1	823.3	358.8	75.3	Normal
47	11428.0	12348.3	556.0	117.61	50.1	823.0	358.8	76.0	Normal
48	11422.7	12348.8	555.9	117.51	50.1	822.8	358.9	76.6	Normal
49	11390.9	12361.2	555.5	117.67	50.1	822.7	358.8	77.1	Normal
50	11393.1	12366.4	555.6	117.64	50.1	823.0	358.9	77.6	Normal
51	11390.9	12346.7	555.2	117.64	50.0	823.2	358.9	77.5	Normal
52	11373.5	12358.9	555.0	117.64	50.1	823.2	358.9	76.8	Normal
53	11408.4	12345.4	555.4	117.64	50.1	822.9	358.9	75.9	Normal
54	11379.1	12356.0	555.1	117.61	50.1	822.8	358.9	74.9	Normal
55	11393.5	12362.5	555.5	117.54	50.1	822.6	358.8	73.8	Normal
56	11375.1	12357.8	555.0	117.72	50.1	822.3	358.8	72.9	Normal
57	11374.0	12332.1	554.3	117.58	50.1	822.2	358.8	72.1	Normal
58	11415.0	12336.6	555.3	117.64	50.1	822.0	358.8	72.0	Normal
59	11397.2	12317.8	554.5	117.53	50.1	821.9	358.9	72.0	Normal
Average Total	11430.5 11.4 klb	12389.3 12.4 klb	557.0 557.0	126.61 0.1 klbs	50.1	820.4	358.9	74.3	Normal

Calpeak California Midway 1- Hourly Operations Report October 3, 2024 - Hour 18

Minute	CT-A Nat Gas Flow lb/hr	CT-B Nat Gas Flow lb/hr	Heat Input Rate mmBtu/hr	NH3 Flow lb/hr	Megawatts	SCR Inlet Temp °F	Stack HSL Temp °F	Shelter Temp °F	Process Status
00	11378.4	12338.6	554.6	117.63	50.1	821.9	358.8	72.3	Normal
01	11387.9	12366.1	555.5	117.62	50.1	821.9	358.8	72.6	Normal
02	11394.3	12337.5	555.0	117.65	50.1	821.8	358.8	73.0	Normal
03	11346.2	12344.2	553.9	117.61	50.1	821.5	358.8	73.3	Normal
04	11375.1	12345.3	554.6	117.57	50.1	821.1	358.8	73.6	Normal
05	11385.4	12325.9	554.5	117.66	50.1	821.2	358.9	73.9	Normal
06	11374.8	12348.7	554.8	117.64	50.1	821.1	358.9	74.3	Normal
07	11374.6	12341.8	554.6	117.58	50.1	820.8	358.9	74.6	Normal
08	11406.6	12327.5	554.9	117.67	50.1	820.7	358.8	75.0	Normal
09	11383.0	12341.1	554.7	117.68	50.1	820.6	359.0	75.1	Normal
10	11388.8	12322.5	554.4	117.53	50.1	820.2	358.9	74.9	Normal
11	11413.6	12351.0	555.8	117.51	50.1	819.7	358.8	74.4	Normal
12	11355.6	12350.7	554.4	117.58	50.1	819.5	358.9	73.9	Normal
13	11405.9	12342.2	555.3	117.71	50.1	819.4	358.9	73.2	Normal
14	11374.6	12315.8	554.0	117.71	50.1	819.3	358.8	72.4	Normal
15	11377.1	12340.8	554.6	117.55	50.1	819.3	358.8	71.9	Normal
16	11394.0	12342.0	555.0	117.60	50.1	819.1	358.8	71.7	Normal
17	11355.3	12338.6	554.0	117.64	50.1	819.2	358.8	71.7	Normal
18	11379.8	12345.1	554.7	117.51	50.1	819.3	358.8	71.9	Normal
19	11369.9	12351.7	554.8	117.61	50.1	819.2	358.8	72.2	Normal
20	11358.8	12332.0	554.0	117.56	50.1	818.8	358.8	72.5	Normal
21	11398.5	12323.1	554.6	117.56	50.1	818.5	358.8	72.8	Normal
22	11395.6	12323.4	554.6	117.57	50.1	818.3	358.8	73.1	Normal
23	11381.6	12343.1	554.8	117.61	50.1	818.3	358.8	73.4	Normal
24	11392.6	12359.1	555.4	117.53	50.1	818.2	358.8	73.8	Normal
25	11383.2	12348.5	555.0	117.49	50.1	817.9	358.8	74.2	Normal
26	11393.6	12319.4	554.5	117.53	50.1	817.9	358.8	74.5	Normal
27	11384.3	12335.7	554.6	117.57	50.0	817.8	358.9	74.8	Normal
28	11348.2	12326.9	553.5	117.60	50.1	817.8	358.9	74.9	Normal
29	11364.0	12325.5	554.0	117.62	50.1	817.8	358.8	74.3	Normal
30	11363.3	12339.9	554.3	117.53	50.1	817.6	358.8	73.6	Normal
31	11382.0	12337.5	554.7	117.41	50.1	817.6	358.9	73.1	Normal
32	11395.2	12365.9	555.7	114.25	50.1	817.7	358.8	72.5	Normal
33	11383.2	12326.6	554.4	113.00	50.1	818.1	358.7	71.7	Normal
34	11382.3	12338.4	554.7	112.91	50.1	818.0	358.8	71.5	Normal

Minute	CT-A Nat Gas Flow lb/hr	CT-B Nat Gas Flow lb/hr	Heat Input Rate mmBtu/hr	NH3 Flow lb/hr	Megawatts	SCR Inlet Temp °F	Stack HSL Temp °F	Shelter Temp °F	Process Status
35	11393.1	12332.9	554.8	113.00	50.1	817.7	358.8	71.5	Normal
36	11383.2	12335.2	554.6	113.09	50.0	817.6	358.8	71.6	Normal
37	11413.0	12337.4	555.4	112.99	50.0	817.1	358.8	71.8	Normal
38	11370.8	12342.9	554.5	113.07	50.1	816.9	358.8	72.1	Normal
39	11390.8	12342.9	555.0	112.95	50.1	817.2	358.8	72.4	Normal
40	11392.2	12358.6	555.4	113.01	50.1	817.5	358.8	72.7	Normal
41	11376.9	12333.2	554.5	112.91	50.1	817.8	358.8	73.0	Normal
42	11391.9	12362.0	555.5	112.88	50.1	817.8	358.8	73.3	Normal
43	11358.4	12327.5	553.9	113.05	50.1	817.9	358.8	73.7	Normal
44	11368.3	12343.6	554.5	112.94	50.1	818.0	358.8	74.0	Normal
45	11373.0	12361.6	555.1	112.92	50.1	817.9	358.8	74.3	Normal
46	11381.9	12351.7	555.1	112.93	50.0	818.0	358.8	74.7	Normal
47	11379.8	12349.4	554.9	112.86	50.1	818.2	358.8	74.9	Normal
48	11390.6	12340.8	554.9	112.95	50.1	818.2	358.8	74.5	Normal
49	11361.7	12328.6	554.0	112.82	50.0	818.0	358.8	73.9	Normal
50	11373.0	12334.3	554.4	112.77	50.0	817.9	358.8	73.0	Normal
51	11402.1	12325.5	554.8	112.79	50.1	817.6	358.8	72.0	Normal
52	11393.7	12337.5	554.9	112.87	50.1	817.3	358.8	71.3	Normal
53	11377.1	12339.7	554.6	112.94	50.1	817.2	358.8	71.3	Normal
54	11361.3	12339.0	554.2	112.85	50.1	817.2	358.8	71.9	Normal
55	11395.2	12345.4	555.1	112.78	50.1	817.0	358.8	72.5	Normal
56	11373.0	12347.0	554.8	112.70	50.1	816.8	358.8	73.2	Normal
57	11391.7	12324.8	554.6	112.78	50.1	816.8	358.8	73.9	Normal
58	11372.1	12322.4	554.1	112.72	50.1	816.8	358.8	74.6	Normal
59	11350.2	12330.3	553.7	112.75	50.0	817.0	358.8	75.2	Normal
Average Total	11380.7 11.4 klb	12339.3 12.3 klb	554.6 554.6	115.42 0.1 klbs	50.1	818.6	358.8	73.2	Normal

Calpeak California Midway 1- Hourly Operations Report October 3, 2024 - Hour 19

Minute	CT-A Nat Gas Flow lb/hr	CT-B Nat Gas Flow lb/hr	Heat Input Rate mmBtu/hr	NH3 Flow lb/hr	Megawatts	SCR Inlet Temp °F	Stack HSL Temp °F	Shelter Temp °F	Process Status
00	11369.6	12324.2	554.1	112.73	50.0	817.0	358.8	75.8	Normal
01	11374.4	12326.2	554.2	112.78	50.1	816.8	358.8	76.3	Normal
02	11387.4	12340.3	554.8	112.78	50.1	816.6	358.8	76.8	Normal
03	11405.7	12329.1	555.0	112.82	50.0	816.4	358.8	77.3	Normal
04	11364.7	12317.6	553.8	112.51	50.1	816.3	358.9	77.6	Normal
05	11342.8	12347.8	554.0	112.73	50.0	816.3	358.8	77.1	Normal
06	11399.7	12313.6	554.5	112.77	50.1	816.4	358.8	76.1	Normal
07	11377.3	12335.7	554.5	112.93	50.1	816.2	358.8	75.1	Normal
08	11375.1	12311.7	553.9	112.67	50.1	816.2	358.9	74.2	Normal
09	11378.3	12322.4	554.2	112.78	50.1	816.1	358.8	73.2	Normal
10	11351.2	12328.9	553.7	112.79	50.0	815.8	358.9	72.5	Normal
11	11368.8	12319.2	553.9	112.83	50.1	815.8	358.7	72.3	Normal
12	11373.3	12313.6	553.9	112.70	50.1	815.7	358.8	72.7	Normal
13	11380.9	12328.2	554.4	112.80	50.1	815.6	358.8	73.2	Normal
14	11380.0	12341.5	554.6	112.79	50.1	815.6	358.8	73.9	Normal
15	11401.5	12337.9	555.1	112.75	50.1	815.7	358.8	74.5	Normal
16	11351.8	12334.7	553.8	112.76	50.0	815.8	358.8	75.1	Normal
17	11354.7	12336.3	553.9	112.76	50.1	815.8	358.9	75.7	Normal
18	11392.9	12343.5	555.0	112.82	50.1	815.6	358.7	76.2	Normal
19	11371.9	12341.3	554.5	112.69	50.1	815.6	358.8	76.7	Normal
20	11360.6	12344.9	554.3	112.70	50.1	815.4	358.8	77.2	Normal
21	11406.0	12358.4	555.7	112.73	50.1	815.4	358.8	77.6	Normal
22	11372.2	12337.4	554.5	112.82	50.1	815.6	358.9	78.0	Normal
23	11367.8	12328.0	554.1	112.66	50.0	815.6	358.8	77.3	Normal
24	11381.4	12327.3	554.4	112.75	50.1	815.8	358.8	76.3	Normal
25	11386.8	12331.6	554.6	112.71	50.1	815.9	358.8	75.1	Normal
26	11395.5	12340.0	555.0	112.78	50.1	815.7	358.8	74.0	Normal
27	11399.0	12358.0	555.6	112.83	50.1	815.8	358.8	72.8	Normal
28	11372.1	12330.7	554.3	112.75	50.1	816.1	358.8	72.0	Normal
29	11350.5	12336.8	553.8	112.84	50.1	816.5	358.8	71.9	Normal
30	10955.2	12031.3	537.5	112.70	47.9	816.5	358.7	72.4	Normal
31	8744.2	9580.8	428.5	112.74	36.0	815.7	358.8	73.0	Normal
32	6959.8	7615.5	340.9	112.80	26.4	809.6	358.8	73.6	Shutdown
33	5438.4	5885.1	264.9	112.85	17.7	796.0	358.8	74.3	Shutdown
34	4080.5	4417.8	198.7	112.90	10.8	774.8	358.8	75.0	Shutdown

Minute	CT-A Nat Gas Flow lb/hr	CT-B Nat Gas Flow lb/hr	Heat Input Rate mmBtu/hr	NH3 Flow lb/hr	Megawatts	SCR Inlet Temp °F	Stack HSL Temp °F	Shelter Temp °F	Process Status
35	2265.1	2447.5	110.1	112.88	2.3	747.4	358.9	75.5	Shutdown
36	1472.2	1555.2	70.7	113.16	0.0	718.4	358.9	76.1	Shutdown
37	1373.2	1439.5	65.8	113.21	0.0	690.0	358.8	76.6	Shutdown
38	1401.4	1458.7	66.9	113.13	0.0	663.6	358.8	77.1	Shutdown
39	1418.3	1469.5	67.5	113.29	0.0	640.8	358.8	77.5	Shutdown
40	1411.5	1476.0	67.5	113.20	0.0	619.8	358.8	77.9	Shutdown
41	Down	Down	Down	Down	Down	601.2	358.9	77.8	Down
42	Down	Down	Down	Down	Down	584.0	354.6	77.0	Down
43	Down	Down	Down	Down	Down	560.5	344.7	76.0	Down
44	Down	Down	Down	Down	Down	538.5	334.5	74.9	Down
45	Down	Down	Down	Down	Down	514.6	325.0	73.9	Down
46	Down	Down	Down	Down	Down	490.7	315.9	73.0	Down
47	Down	Down	Down	Down	Down	474.9	306.5	72.6	Down
48	Down	Down	Down	Down	Down	465.4	297.4	72.5	Down
49	Down	Down	Down	Down	Down	457.5	288.8	72.5	Down
50	Down	Down	Down	Down	Down	452.1	280.7	72.6	Down
51	Down	Down	Down	Down	Down	448.7	272.9	72.8	Down
52	Down	Down	Down	Down	Down	446.8	265.4	73.0	Down
53	Down	Down	Down	Down	Down	446.1	258.3	73.2	Down
54	Down	Down	Down	Down	Down	446.3	251.5	73.5	Down
55	Down	Down	Down	Down	Down	447.0	245.0	73.8	Down
56	Down	Down	Down	Down	Down	448.0	238.8	74.1	Down
57	Down	Down	Down	Down	Down	449.3	232.8	74.4	Down
58	Down	Down	Down	Down	Down	450.6	227.0	74.7	Down
59	Down	Down	Down	Down	Down	451.9	221.5	75.0	Down
Average Total	9434.5 6.4 klb	10228.4 7.0 klb	459.8 312.7	112.82 0.1 klbs	40.1	695.8	335.5	74.8	Shutdown

Calpeak California Midway 1- Daily Emissions Report October 3, 2024

Emission Limits														
		N0	1-Hr 0x ppm @159 NOx lbs -	% O2 - 2.5 2.8	СС	3-Hr Rollin D ppm @15% CO lbs - 4.1	g O2 - 6 19	24-F NH3 Slip pp NH3 S	fr Rolling om @15% O2 lip lbs - ERR	- 10	Daily NOx lbs - 134 CO lbs - 252	.6 2		
Hour	O2%	NOx ppm	NOx ppm @15% O2	NOx lbs	CO ppm	CO ppm @15% O2	3-Hr RIng CO ppm @15% O2 *	CO lbs	3-Hr Ring CO lbs *	NH3 Slip ppm @15% O2	24-Hr RIng NH3 Slip ppm @15% O2	NH3 Slip lbs	24-Hr Ring NH3 lbs	Process Status
00	Down	Down	Down	Down	Down	Down	Down	Down	1.6	0.0	0.4	Down	0.38	Down
01	Down	Down	Down	Down	Down	Down	Down	Down	1.6	0.0	0.4	Down	0.38	Down
02	Down	Down	Down	Down	Down	Down	Down	Down	1.6	0.0	0.4	Down	0.38	Down
03	Down	Down	Down	Down	Down	Down	Down	Down	1.6	0.0	0.4	Down	0.38	Down
04	Down	Down	Down	Down	Down	Down	Down	Down	1.6	0.0	0.4	Down	0.38	Down
05	DCal	DCal	DCal	DCal	DCal	DCal	Down	DCal	1.6	0.0	0.4	DCal	0.38	Down
06	Down	Down	Down	Down	Down	Down	Down	Down	1.6	0.0	0.4	Down	0.38	Down
07	Down	Down	Down	Down	Down	Down	Down	Down	1.6	0.0	0.4	Down	0.38	Down
08	Down	Down	Down	Down	Down	Down	Down	Down	1.6	0.0	0.4	Down	0.38	Down
09	Down	Down	Down	Down	Down	Down	Down	Down	1.6	0.0	0.4	Down	0.38	Down
10	Down	Down	Down	Down	Down	Down	Down	Down	1.6	0.0	0.4	Down	0.38	Down
11	Down	Down	Down	Down	Down	Down	Down	Down	1.6	0.0	0.4	Down	0.38	Down
12	Down	Down	Down	Down	Down	Down	Down	Down	1.6	0.0	0.4	Down	0.38	Down
13	Down	Down	Down	Down	Down	Down	Down	Down	1.6	0.0	0.4	Down	0.38	Down
14	Down	Down	Down	Down	Down	Down	Down	Down	1.6	0.0	0.4	Down	0.38	Down
15	15.7	10.7	11.4	11.92	4.2	6.3	NSD	2.47	1.6	3.2	0.5	5.13	0.59	Startup
16	16.3	4.1	4.8	8.35	2.2	2.7	NSD	2.70	1.6	12.3	1.0	10.76	0.99	Startup
17	15.8	1.3	1.5	3.11	3.1	3.6	3.1	4.48	1.6	2.7	1.1	2.71	1.10	Normal
18	15.9	1.7	1.9	3.94	2.8	3.3	3.2	4.00	1.6	0.6	1.1	0.67	1.10	Normal
19	16.5	1.6	2.1	2.47	2.5	3.3	3.4	2.32	1.6	5.5	1.0	6.21	1.06	Shutdown
20	Down	Down	Down	Down	Down	Down	NSD	Down	1.6	0.0	1.0	Down	1.06	Down
21	Down	Down	Down	Down	Down	Down	NSD	Down	1.6	0.0	1.0	Down	1.06	Down
22	Down	Down	Down	Down	Down	Down	Down	Down	1.6	0.0	1.0	Down	1.06	Down
23	Down	Down	Down	Down	Down	Down	Down	Down	1.6	0.0	1.0	Down	1.06	Down
Average Total	16.0	3.9	4	29.8	3.0	3.8		16.0		1.0		5.1 25.5		

* - Excluding Startup & Shutdown Emissions







PHONE: 559 230-6000

DATE: 10/03/2024

PHONE:

SUBJECT: BREAKDOWN MIDWAY PEAKING

COMMENTS

Midway Peaking at 43627 W. Panoche Rd, Firebaugh, CA 93622

760 530-2323

Phone: (559) 230- 6000 Fax: (559) 230- 6061



San Joaquin Valley AIR POLLUTION CONTROL DISTRICT

Breakdown # _

Report of Equipment Breakdown

Company Name: Starwood Power- Midway, LLC Phone #: (619) 726- 2410
Permit Number(s): C-7286-1(2) [Midway Unit 1]
Equipment involved:
Location of Property (Address, Lease, Field, Section, Township, Range):
Firebaugh CA 93622
Date and Time of Occurrence: 1700 (0/2 0021
Date and Time of Discovery (200 10/5/2009
Time Corrective Action Commenced: 1000 1013/10074
Date and Time Corrective Action Successful: 1800 40/7/2014
Estimated Emissions:
Pollutant Estimated Emission Rate: Visible (Yes or No)
NOX DOM 4.8 PPM NO
Cause of the Occurrence:
Expand Custon Namber failed in the closed position
10 south 1
comprim; zing NUX control.
Management Taken to Correct this Conversion and Drovent its Degumentas
At P. t. 6

At first Engine was shutdown, until Damper could be openend, Engine restanted. NOX is Now in control

Attach Photographs of Defective Equipment.

Provide any additional information necessary to establish that this occurrence was the result of an unavoidable failure or malfunction. Rule 1100 – Equipment Breakdown assigns the burden of proof to the source operator seeking exemption from legal action. An exception cannot be granted for an occurrence, which was the result of negligence.

Reported By: Reported To: Time: 10/3 Time: 10/3 Initial Notification: Phone Call made 1813 Rule 1100 Notification (rev. 10.02.06) Left Message



Northern Region	Central Region	Southern Region
QUARTERLY CEM	IS EXCESS EMISSION AND DOW	NTIME SUMMARY
1st 🗌 JAN -	MAR 20 3rd 🗌 JUL -	- SEPT 20
2nd 🗌 APR	- JUN 20 4th 🛛 OCT	- DEC 20 <u>24</u>
Facility Name: _Midway Peaking, LLC	Cermit	#: C-7286-3-4 & -4-4 (Midway 2)
Location: 43627 West Panoche Rd.	City: _I	Firebaugh
AIRS #:	NSPS Source?:	Yes 🗌 No
Process Equipment Description: <u>60 I</u>	<u>WW, simple cycle gas turbine, peak</u>	king unit, 611 MMBtu/hr
Pollutants Monitored: XO _x	□ SO _X	$\square O_2$ $\square CO_2$ $\square NH_3$

Total Hours Process Equipment Operated During Quarter: 45

	CEM U	CEM Unit Information										
Pollutant	Manufacturer / Model	Serial #	Date Installed	Total Hours CEMS Operated During Qtr								
NOx	TAPI 200EM	375	Q2 2009	61								
SOx												
со	TAPI 300E	1893	Q2 2009	61								
Opacity												
O ₂	TAPI 300E	1893	Q2 2009	61								
CO ₂												
NH ₃												
Other												

	Date of Last Performance Specification Test											
Pollutant	NOx	SOx	СО	Opacity	O ₂	CO ₂	NH₃	Other				
Date	10/17/24		10/17/24		10/17/24							
	🗌 RATA	🗌 RATA	🗌 RATA	🗌 RATA	🗌 RATA	🗌 RATA	🗌 RATA	🗌 RATA				
Туре	🖾 CGA	CGA	🖾 CGA	CGA	🖾 CGA	CGA	CGA	CGA				
	Linearity	Linearity	Linearity	Linearity	Linearity	Linearity	Linearity	Linearity				

	Emission Limits (From Operating Permits)							
Pollutant	ppm @ O ₂ %	lb/MMBtu	lb/hr ¹	lb/day ¹	lbs/yr ¹)	NSPS (Subpart KKKK)		
NOx	2.5	N/A	2.8/5.6	79.8 / 159.6	12,736 / 25,742	25		
SO _X								
CO	6.0	N/A	4.19/8.38	117.6 / 235.2	18,826 / 37,652	N/A		
Opacity								
O ₂								
CO ₂								
NH ₃								
Other								

Note 1: Midway Unit 2 has a mass emission limit that applies to a single engine, and a mass emission limit that applies when two engines are in operation, presented above as "one engine / two engines".

	Excess Emissions Information (Report in Hours)									
Pollutant	Start-Up / Shutdown	Process Problems	Breakdown	Other Known	Other Unknown	Total Hrs Excess	Total Op Hrs for Qtr	% Excess		
NO _X	0	0	0	0	0	0	61	0		
SOx										
CO	0	0	0	0	0	0	61	0		
Opacity										
O ₂										
CO ₂										
NH ₃										
Other										

Include a summary of all dates, times, and excess emissions that occurred during the reporting period or submit copies of all related breakdown reports and Title V deviations.

Excess emissions caused by a startup after shutdown due to a malfunction should be reported as an excess emission due to an equipment breakdown. The source is not however, exempt from emission limits. All exceedances are to be reported in whole hour increments.

	CEM Downtime Information (Report in Hours)								
Pollutant	Monitor Malfunction	Non-Monitor Malfunction	Q/A - Cal	Other	Unknown	Total Hrs Downtime	Total Hrs	% Downtime	
NOx	0	0	0	0	0	0	61	0	
SO _X									
CO	0	0	0	0	0	0	61	0	
Opacity									
O ₂	0	0	0	0	0	0	61	0	
CO ₂									
NH ₃									
Other									

Include a summary of all downtime dates, times, duration, and activities that occurred during the reporting period or submit copies of all related breakdown reports and Title V deviations.

Non-CEM malfunctions are incidents that result in the CEM system being down but are not associated with a malfunction of the CEM system, i.e. plant power failure.

2 Midway NOx/H Linearity

Calpeak

Test Information

Test Date	10/17/2024
Test Reason	
Grace Period	No
Aborted	No
Result	Passed
Unit offline during QA	test Not valid for 40CFR75

Analyzer and Monitor Information

Range	High
Instrument Span	250 ppm
Component ID	210
Manufacturer	TELEDYNE
Model	M200EM
Serial Number	375

Run	Time	Reference Gas	CEMS Response		Cylinder Information
Low Gas					
1	11:06 AM	56.50	55.17		Allowable Reference Values:
2	11:18 AM	56.50	59.70		50-75 ppm (20-30% of span)
3	11:31 AM	56.50	59.86		Cylinder ID: CC751838
M	ean (ppm)	56.50	58.24	_	Expiration Date: 11/29/2030
Di (p	fference of means (R-A) pm)	1.7	Limit 5	Passed	EPA Vendor ID: W12022 Cylinder contains:
Lir	nearity Error (%)	3.1	Limit 5.0	Passed	BALN,CO,NO,NOX
Mid Gas					
1	11:10 AM	139.20	137.06		Allowable Reference Values:
2	11:23 AM	139.20	137.83		125-150 ppm (50-60% of span)
3	11:35 AM	139.20	138.10		Cylinder ID: EB0144811
M	ean (ppm)	139.20	137.66	_	Expiration Date: 11/29/2030
Di	fference of means (R-A)	1.5	Limit 5	Passed	EPA Vendor ID: W12022
(p	pm)				Cylinder contains:
Lir	nearity Error (%)	1.1	Limit 5.0	Passed	BALN,CO,NO,NOX
High Gas	5				Allowable Deference Values
1	11:14 AM	228.00	228.78		Allowable Reference values:
2	11:27 AM	228.00	228.95		200-250 ppm (80-100% of span)
3	11:40 AM	228.00	228.90		Cvlinder ID: EB0166772
M	ean (ppm)	228.00	228.88		Expiration Date: 1/12/2032
Di (p	fference of means(R-A) pm)	0.9	Limit 5	Passed	EPA Vendor ID: W12024 Cylinder contains:
Lir	nearity Error (%)	0.4	Limit 5.0	Passed	BALN,CO,NO,NOX

Linearity Error (LE) Determination

LE (%) = (|R-A| / R) * 100

R = Reference gas value

A = Mean of actual CEMS responses

2 Midway NOx/L CGA

Calpeak

st Inform	ation		Analyzer and Monitor Information			
sult	10/17/2024 Passed		Range Instrument Span Manufacturer Model Serial Number		Low 10 ppm TELEDYNE M200EM 375	
		Reference	CEMS			
Run	Time	Gas	Response	9	Cylinder Information	
Low Ga	S					
1	9:23 AM	2.550	2.315			
2	9:32 AM	2.550	2.407		Allowable Reference Values:	
3	9:40 AM	2.550	2.413		2-3 ppm (20-30% of span) Cvlinder ID: CC761028	
	Mean (ppm)	2.550	2.378		Expiration Date: 12/3/2025	
 (Difference of means (Cm-Ca) (ppm)	-0.2	Limit 2	Passed	EPA Vendor ID: W12022 Cvlinder contains:	
(CEMS Accuracy (%)	-6.7	Limit 15	Passed	BALN,CO,NO,NOX	
Mid Gas	6					
1	9:28 AM	5.530	5.373		Allowable Reference Values:	
2	9:36 AM	5.530	5.400		5-6 ppm (50-60% of span)	
3	9:45 AM	5.530	5.381		Cvlinder ID: CC761027	
	Mean (ppm)	5.530	5.385		Expiration Date: 12/3/2025	
 (Difference of means (Cm-Ca) (ppm)	-0.1	Limit 2	Passed	EPA Vendor ID: W12022 Cylinder contains:	
(CEMS Accuracy (%)	-2.6	Limit 15	Passed	BÁLN,CO,NO,NOX	

CEMS Accuracy Determination (%)

Accuracy (%) = ((Cm - Ca) / Ca) * 100

Ca = Reference gas value

Cm = Mean of actual CEMS responses

2 Midway CO/H CGA

Calpeak

est Informa		Analyzer and Monitor Information				
est Date esult	10/17/2024 Passed		Range Instrument Span Manufacturer Model Serial Number		High 1000 ppm TELEDYNE M300E 1893	
Run	Time	Reference Gas	CEMS Response		Cylinder Information	
Low Gas						
1	11·06 AM	276 700	276 640			
2	11:18 AM	276.700	276.816		Allowable Reference Values:	
3	11:31 AM	276.700	279.259		200-300 ppm (20-30% of span) Cylinder ID: CC751838	
Me	ean (ppm)	276.700	277.572		Expiration Date: 11/29/2030	
Di (pi	fference of means (Cm-Ca)	0.9	Limit 5	Passed	EPA Vendor ID: W12022	
ĊE	EMS Accuracy (%)	0.3	Limit 15	Passed	BALN,CO,NO,NOX	
Mid Gas						
1	11:10 AM	551.000	544.897		Allowable Reference Values:	
2	11:23 AM	551.000	542.749		500-600 ppm (50-60% of span)	
3	11:35 AM	551.000	546.446		Cvlinder ID: EB0144811	
Me	ean (ppm)	551.000	544.697		Expiration Date: 11/29/2030	
Difference of means (Cm-Ca) (ppm)		-6.3	Limit 5		EPA Vendor ID: W12022 Cylinder contains:	
CE	EMS Accuracy (%)	-1.1	Limit 15	Passed	BÁLN,CO,NO,NOX	

CEMS Accuracy Determination (%)

Accuracy (%) = ((Cm - Ca) / Ca) * 100

Ca = Reference gas value

Cm = Mean of actual CEMS responses

2 Midway CO/L CGA

Calpeak

est Informat		Analyzer and Monitor Information				
est Date esult	10/17/2024 Passed		Range Instrument Span Manufacturer Model Serial Number		Low 20 ppm TELEDYNE M300E 1893	
Run Time		Reference CEMS Gas Response		Cylinder Information		
l ow Gas						
1	9:23 AM	4.880	4,890			
2	9:32 AM	4.880	4.904		Allowable Reference Values:	
3	9:40 AM	4.880	4.940		4-6 ppm (20-30% of span) Cylinder ID: CC761028	
Me	an (ppm)	4.880	4.911	_	Expiration Date: 12/3/2025	
Diff (qq	erence of means (Cm-Ca) m)	0.0	Limit 2	Passed	EPA Vendor ID: W12022 Cylinder contains:	
ĊE	MS Accuracy (%)	0.6	Limit 15	Passed	BALN,CO,NO,NOX	
Mid Gas						
1	9:28 AM	10.900	10.925		Allowable Reference Values:	
2	9:36 AM	10.900	11.028		10-12 ppm (50-60% of span)	
3	9:45 AM	10.900	10.891		Cylinder ID: CC761027	
Ме	an (ppm)	10.900	10.948		Expiration Date: 12/3/2025	
Diff (pp	erence of means (Cm-Ca) m)	0.0	Limit 2	Passed	EPA Vendor ID: W12022 Cvlinder contains:	
ČE	MS Accuracy (%)	0.4	Limit 15	Passed	BALN,CO,NO,NOX	

CEMS Accuracy Determination (%)

Accuracy (%) = ((Cm - Ca) / Ca) * 100

Ca = Reference gas value

Cm = Mean of actual CEMS responses

2 Midway O2 Linearity

Calpeak

Test Information Analyzer and Monitor Information Single Scale Test Date 10/17/2024 Range Instrument Span 21 %02 **Test Reason** Component ID 220 Grace Period No Manufacturer TELEDYNE Aborted No Model M300E Result Passed Serial Number 1893 Unit offline during QA test -- Not valid for 40CFR75

Run	n Time	Reference Gas	CEMS Response		Cylinder Information
l ow G	25				
1	11:58 AM	5.470	5.484		
2	12:07 PM	5.470	5.493		Allowable Reference Values:
3	12:16 PM	5.470	5.507		4.2-6.3 %O2 (20-30% of span)
	Mean $(\%\Omega^2)$	5 470	5 495	_	Cvlinder ID: CC181315
	Difference of means (R-A) (%O2)	0.0	Limit 0.5	Passed	Expiration Date: 11/19/2030 EPA Vendor ID: W12022
	Linearity Error (%)	0.5	Limit 5.0	Passed	Cylinder contains: O2, BALN
Mid Ga	IS				
1	12:01 PM	11.640	11.665		Allowable Reference Values:
2	12:10 PM	11.640	11.670		10 5-12 6 %O2 (50-60% of
3	12:19 PM	11.640	11.667		span)
	Mean (%O2)	11.640	11.667	_	Cylinder ID: CC462060
	Difference of means (R-A) (%O2)	0.0	Limit 0.5	Passed	Expiration Date: 11/19/2030 EPA Vendor ID: W12022
	Linearity Error (%)	0.2	Limit 5.0	Passed	Cylinder contains: O2,BALN
High G	as				
1	12:04 PM	19.020	19.117		Allowable Reference Values:
2	12:13 PM	19.020	19.131		16 8-21 %O2 (80-100% of
3	12:22 PM	19.020	19.122		span)
	Mean (%O2)	19.020	19.123	_	Cylinder ID: CC755990
	Difference of means (R-A) (%O2)	0.1	Limit 0.5	Passed	Expiration Date: 6/18/2032 EPA Vendor ID: W12024
	Linearity Error (%)	0.5	Limit 5.0	Passed	Cylinder contains: O2,BALN

Linearity Error (LE) Determination

*LE (%) = (|R-A| / R) * 100*

R = Reference gas value

A = Mean of actual CEMS responses

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx ppm @15% O2 1-Hr

Reason	Duration
There are no excess emissions for this report.	
Source operating time	61 hours
Duration of NOx ppm @15% O2 1-Hr excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx ppm @15% O2 4-Hr (Subpart KKKK)

Reaso	on	Duration	_
Ther	e are no excess emissions for this report.		
	Source operating time	61 hours	
	Duration of NOx ppm @15% O2 4-Hr (Subpart KKKK) excess emissions	0	
	Source operating time with excess emissions	0.0%	

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx Lb/hr Per S/U

Reason	Duration
There are no excess emissions for this report.	
Source operating time	8 hours, 12 minutes
Duration of NOx Lb/hr Per S/U excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx Lb/hr Per S/D

Reason	Duration
There are no excess emissions for this report.	
Source operating time	2 hours, 35 minutes
Duration of NOx Lb/hr Per S/D excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: Normal Ops NOx lbs 1-Hr

Reason	Duration	
There are no excess emissions for this report.		
Source operating time	61 hours	
Duration of Normal Ops NOx lbs 1-Hr excess emissions	0	
Source operating time with excess emissions	0.0%	

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx lbs/Day

Reason	Duration
There are no excess emissions for this report.	
Source operating time	61 hours
Duration of NOx lbs/Day excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: CO ppm @15% O2 3-Hr Rolling

Reason	Duration	
There are no excess emissions for this report.		
Source operating time	61 hours	
Duration of CO ppm @15% O2 3-Hr Rolling excess emissions	0	
Source operating time with excess emissions	0.0%	

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: CO Lb/hr Per S/U

_

Reason	Duration
There are no excess emissions for this report.	
Source operating time	8 hours, 12 minutes
Duration of CO Lb/hr Per S/U excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: CO Lb/hr Per S/D

Reason	Duration
There are no excess emissions for this report.	
Source operating time	2 hours, 35 minutes
Duration of CO Lb/hr Per S/D excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: Normal Ops CO lbs 3-Hr Rolling

Reason	Duration
There are no excess emissions for this report.	
Source operating time	61 hours
Duration of Normal Ops CO lbs 3-Hr Rolling excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: CO lbs/Day

Reason	Duration
There are no excess emissions for this report.	
Source operating time	61 hours
Duration of CO lbs/Day excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

CEMS Downtime for 10/1/2024 thru 12/31/2024: NOx ppm @15% O2

Reason	Duration
There are no CEMS downtimes for this report.	
Source operating time	61 hours
Duration of NOx ppm @15% O2 monitor downtime	0
Percent monitor downtime	0.0%
Source operating time with valid data	61 hours
Percent monitor availability	100.0%

CALPEAK: ({optional DAHS description}): Cedar Reports 8.04.06 1/9/2025 8:04 AM, 2 Midway CEMS Downtime Summary Page 1 of 4

Calpeak CEMS Downtime for 10/1/2024 thru 12/31/2024: NOx lbs

	Reason	Duration
	There are no CEMS downtimes for this report.	
•	Source operating time	61 hours
	Duration of NOx lbs monitor downtime	0
	Percent monitor downtime	0.0%
	Source operating time with valid data	61 hours
	Percent monitor availability	100.0%

Calpeak

CEMS Downtime for 10/1/2024 thru 12/31/2024: CO ppm @15% O2

Reason	Duration
There are no CEMS downtimes for this report.	
Source operating time	61 hours
Duration of CO ppm @15% O2 monitor downtime	0
Percent monitor downtime	0.0%
Source operating time with valid data	61 hours
Percent monitor availability	100.0%

CALPEAK: ({optional DAHS description}): Cedar Reports 8.04.06 1/9/2025 8:04 AM, 2 Midway CEMS Downtime Summary Page 3 of 4

Calpeak CEMS Downtime for 10/1/2024 thru 12/31/2024: CO lbs

Reason	Duration
There are no CEMS downtimes for this report.	
Source operating time	61 hours
Duration of CO lbs monitor downtime	0
Percent monitor downtime	0.0%
Source operating time with valid data	61 hours
Percent monitor availability	100.0%

Attachment 3

CEMS DAHS Excess Emission Reports

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx ppm @15% O2 1-Hr

Reason	Duration
Other Known Causes (excess)	1 hour
Source operating time	75 hours
Duration of NOx ppm @15% O2 1-Hr excess emissions	1 hour
Source operating time with excess emissions	1.3%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:34 AM, 1 Midway Excess Emissions Summary Page 1 of 27
1 Midway Excess Emissions

Calpeak Excess Emissions for 10/1/2024 thru 12/31/2024: NOx ppm @15% O2 1-Hr

Parameter	Start	End	Duration	Value	Min	Max	Limit	Reason	Action
NOx ppm @15% O2 1-Hr	10/3/2024 4:00 PM	4:59 PM	1 hour	6.1	6.1	6.1	2.50	Other Known Causes (excess)	Troubleshoot & Repair

Total duration

1 hour

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx ppm @15% O2 4-Hr (Subpart KKKK)

Reason	Duration	
There are no excess emissions for this report.		
Source operating time	75 hours	
Duration of NOx ppm @15% O2 4-Hr (Subpart KKKK) excess emissions	0	
Source operating time with excess emissions	0.0%	

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:34 AM, 1 Midway Excess Emissions Summary Page 3 of 27

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx Lb/hr Per S/U

Reason	Duration
There are no excess emissions for this report.	
Source operating time	11 hours, 12 minutes
Duration of NOx Lb/hr Per S/U excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:34 AM, 1 Midway Excess Emissions Summary Page 4 of 27

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx Lb/hr Per S/D

Reason	Duration
Other Known Causes (excess)	2 minutes
Source operating time	3 hours, 43 minutes
Duration of NOx Lb/hr Per S/D excess emissions	2 minutes
Source operating time with excess emissions	0.9%

1 Midway Excess Emissions

Calpeak Excess Emissions for 10/1/2024 thru 12/31/2024: NOx Lb/hr Per S/D

Parameter	Start	End	Duration	Value	Min	Max	Limit	Reason	Action
NOx Lb/hr Per S/D	10/3/2024 4:09 PM	4:09 PM	1 minute	3.61	3.61	3.61	3.00	Other Known Causes (excess)	Troubleshoot & Repair
NOx Lb/hr Per S/D	10/3/2024 4:34 PM	4:34 PM	1 minute	2.40	2.40	2.40	1.50	Other Known Causes (excess)	Troubleshoot & Repair
	l dunation		0 minutes						

Total duration

2 minutes

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: Normal Ops NOx lbs 1-Hr

		_
Reason	Duration	
Other Known Causes (excess)	1 hour	
Source operating time	75 hours	
Duration of Normal Ops NOx lbs 1-Hr excess emissions	1 hour	
Source operating time with excess emissions	1.3%	

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:34 AM, 1 Midway Excess Emissions Summary Page 7 of 27

1 Midway Excess Emissions

	Calpeak	
Excess Emissions for	10/1/2024 thru 12/31/2024	: Normal Ops NOx lbs 1-Hr

Parameter	Start	End	Duration	Value	Min	Max	Limit	Reason	Action
Normal Ops NOx lbs 1-Hr	10/3/2024 4:00 PM	4:59 PM	1 hour	7.34	7.34	7.34	5.60	Other Known Causes (excess)	Troubleshoot & Repair

Total duration

1 hour

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx lbs/Day

Reason	Duration
There are no excess emissions for this report.	
Source operating time	75 hours
Duration of NOx lbs/Day excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: SOx Lb/hr Per S/U

Reason		Duration		
There are no excess	emissions for this report.			
Source operating	time	11 hours, 12 minutes		
Duration of SOx I	b/hr Per S/U excess emissions	0		
Source operating	time with excess emissions	0.0%		

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: SOx Lb/hr Per S/D

Duration		
3 hours, 43 minutes		
0		
0.0%		

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: Normal Ops SOx lbs 3-Hr Rolling

Reason	Duration
There are no excess emissions for this report.	
Source operating time	75 hours
Duration of Normal Ops SOx lbs 3-Hr Rolling excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: SOx lbs/Day

Reason	Duration
There are no excess emissions for this report.	
Source operating time	75 hours
Duration of SOx lbs/Day excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:34 AM, 1 Midway Excess Emissions SummaryPage 13 of 27

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: CO ppm @15% O2 3-Hr Rolling

Reason	Duration
There are no excess emissions for this report.	
Source operating time	75 hours
Duration of CO ppm @15% O2 3-Hr Rolling excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:34 AM, 1 Midway Excess Emissions SummaryPage 14 of 27

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: CO Lb/hr Per S/U

Reason	Duration
There are no excess emissions for this report	t.
Source operating time	11 hours, 12 minutes
Duration of CO Lb/hr Per S/U excess emissions	s 0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:34 AM, 1 Midway Excess Emissions SummaryPage 15 of 27

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: CO Lb/hr Per S/D

Reason	Duration
There are no excess emissions for this report.	
Source operating time	3 hours, 43 minutes
Duration of CO Lb/hr Per S/D excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:34 AM, 1 Midway Excess Emissions SummaryPage 16 of 27

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: Normal Ops CO lbs 3-Hr Rolling

Reason	Duration
There are no excess emissions for this report.	
Source operating time	75 hours
Duration of Normal Ops CO lbs 3-Hr Rolling excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: CO lbs/Day

Reason	Duration
There are no excess emissions for this report.	
Source operating time	75 hours
Duration of CO lbs/Day excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:34 AM, 1 Midway Excess Emissions SummaryPage 18 of 27

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: PM Lb/hr Per S/U

Reason	Duration
There are no excess emissions for this report.	
Source operating time	11 hours, 12 minutes
Duration of PM Lb/hr Per S/U excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:34 AM, 1 Midway Excess Emissions SummaryPage 19 of 27

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: PM Lb/hr Per S/D

Reason	Duration
There are no excess emissions for this report.	
Source operating time	3 hours, 43 minutes
Duration of PM Lb/hr Per S/D excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:34 AM, 1 Midway Excess Emissions SummaryPage 20 of 27

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: Normal Ops PM lbs 3-Hr Rolling

Reason	Duration
There are no excess emissions for this report.	
Source operating time	75 hours
Duration of Normal Ops PM lbs 3-Hr Rolling excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: PM lbs/Day

Reason	Duration
There are no excess emissions for this report.	
Source operating time	75 hours
Duration of PM lbs/Day excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:34 AM, 1 Midway Excess Emissions SummaryPage 22 of 27

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NH3 Slip ppm @ 15% O2 24-Hr Rolling Avg

Reason	Duration
There are no excess emissions for this report.	
Source operating time	75 hours
Duration of NH3 Slip ppm @ 15% O2 24-Hr Rolling Avg excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:34 AM, 1 Midway Excess Emissions SummaryPage 23 of 27

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: VOC Lb/hr Per S/U

Reason	Duration
There are no excess emissions for this report.	
Source operating time	11 hours, 12 minutes
Duration of VOC Lb/hr Per S/U excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:34 AM, 1 Midway Excess Emissions SummaryPage 24 of 27

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: VOC Lb/hr Per S/D

Reason	Duration
There are no excess emissions for this report.	
Source operating time	3 hours, 43 minutes
Duration of VOC Lb/hr Per S/D excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: Normal Ops VOC lbs 3-Hr Rolling

Reason	Duration
There are no excess emissions for this report.	
Source operating time	75 hours
Duration of Normal Ops VOC lbs 3-Hr Rolling excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:34 AM, 1 Midway Excess Emissions SummaryPage 26 of 27

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: VOC lbs/Day

Reason	Duration
There are no excess emissions for this report.	
Source operating time	75 hours
Duration of VOC lbs/Day excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx ppm @15% O2 1-Hr

Reason	Duration
There are no excess emissions for this report.	
Source operating time	61 hours
Duration of NOx ppm @15% O2 1-Hr excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx ppm @15% O2 4-Hr (Subpart KKKK)

Reason	Duration	
There are no excess emissions for this report.		
Source operating time	61 hours	
Duration of NOx ppm @15% O2 4-Hr (Subpart KKKK) excess emissions	0	
Source operating time with excess emissions	0.0%	

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:36 AM, 2 Midway Excess Emissions Summary Page 2 of 24

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx Lb/hr Per S/U

Reason	Duration
There are no excess emissions for this report.	
Source operating time	8 hours, 12 minutes
Duration of NOx Lb/hr Per S/U excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx Lb/hr Per S/D

Reason	Duration
There are no excess emissions for this report.	
Source operating time	2 hours, 35 minutes
Duration of NOx Lb/hr Per S/D excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: Normal Ops NOx lbs 1-Hr

Reason	Duration
There are no excess emissions for this report.	
Source operating time	61 hours
Duration of Normal Ops NOx lbs 1-Hr excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:36 AM, 2 Midway Excess Emissions Summary Page 5 of 24

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NOx lbs/Day

Reason	Duration
There are no excess emissions for this report.	
Source operating time	61 hours
Duration of NOx lbs/Day excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:36 AM, 2 Midway Excess Emissions Summary Page 6 of 24

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: SOx Lb/hr Per S/U

Reason	Duration
There are no excess emissions for this report.	
Source operating time	8 hours, 12 minutes
Duration of SOx Lb/hr Per S/U excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: SOx Lb/hr Per S/D

Reason	Duration
There are no excess emissions for this report.	
Source operating time	2 hours, 35 minutes
Duration of SOx Lb/hr Per S/D excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: Normal Ops SOx lbs 3-Hr Rolling

Reason	Duration
There are no excess emissions for this	report.
Source operating time	61 hours
Duration of Normal Ops SOx lbs 3-Hr Ro emissions	olling excess 0
Source operating time with excess emiss	sions 0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: SOx lbs/Day

Reason	Duration
There are no excess emissions for this report.	
Source operating time	61 hours
Duration of SOx lbs/Day excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:36 AM, 2 Midway Excess Emissions SummaryPage 10 of 24
Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: CO ppm @15% O2 3-Hr Rolling

Reason	Duration	
There are no excess emissions for this report.		
Source operating time	61 hours	
Duration of CO ppm @15% O2 3-Hr Rolling excess emissions	0	
Source operating time with excess emissions	0.0%	

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:36 AM, 2 Midway Excess Emissions SummaryPage 11 of 24

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: CO Lb/hr Per S/U

Reason	Duration
There are no excess emissions for this report.	
Source operating time	8 hours, 12 minutes
Duration of CO Lb/hr Per S/U excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:36 AM, 2 Midway Excess Emissions SummaryPage 12 of 24

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: CO Lb/hr Per S/D

Reason		Duration
There	are no excess emissions for this report.	
	Source operating time	2 hours, 35 minutes
	Duration of CO Lb/hr Per S/D excess emissions	0
	Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:36 AM, 2 Midway Excess Emissions SummaryPage 13 of 24

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: Normal Ops CO lbs 3-Hr Rolling

Reason	Duration
There are no excess emissions for this report.	
Source operating time	61 hours
Duration of Normal Ops CO lbs 3-Hr Rolling excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:36 AM, 2 Midway Excess Emissions SummaryPage 14 of 24

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: CO lbs/Day

Reason	Duration
There are no excess emissions for this report.	
Source operating time	61 hours
Duration of CO lbs/Day excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: PM Lb/hr Per S/U

Reason	Duration
There are no excess emissions for this report.	
Source operating time	8 hours, 12 minutes
Duration of PM Lb/hr Per S/U excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:36 AM, 2 Midway Excess Emissions SummaryPage 16 of 24

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: PM Lb/hr Per S/D

Reason	Duration
There are no excess emissions for this report.	
Source operating time	2 hours, 35 minutes
Duration of PM Lb/hr Per S/D excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: Normal Ops PM lbs 3-Hr Rolling

Reason	Duration
There are no excess emissions for this report.	
Source operating time	61 hours
Duration of Normal Ops PM lbs 3-Hr Rolling excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:36 AM, 2 Midway Excess Emissions SummaryPage 18 of 24

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: PM lbs/Day

Reason	Duration
There are no excess emissions for this report.	
Source operating time	61 hours
Duration of PM lbs/Day excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:36 AM, 2 Midway Excess Emissions SummaryPage 19 of 24

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: NH3 Slip ppm @ 15% O2 24-Hr Rolling Avg

Reason	Duration
There are no excess emissions for this report.	
Source operating time	61 hours
Duration of NH3 Slip ppm @ 15% O2 24-Hr Rolling Avg excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: VOC Lb/hr Per S/U

Reason	Duration
There are no excess emissions for this report.	
Source operating time	8 hours, 12 minutes
Duration of VOC Lb/hr Per S/U excess emissions	0
Source operating time with excess emissions	0.0%

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: VOC Lb/hr Per S/D

Reason	Duration
There are no excess emissions for this report.	
Source operating time	2 hours, 35 minutes
Duration of VOC Lb/hr Per S/D excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:36 AM, 2 Midway Excess Emissions SummaryPage 22 of 24

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: Normal Ops VOC lbs 3-Hr Rolling

Reason	Duration
There are no excess emissions for this report.	
Source operating time	61 hours
Duration of Normal Ops VOC lbs 3-Hr Rolling excess emissions	0
Source operating time with excess emissions	0.0%

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/14/2025 11:36 AM, 2 Midway Excess Emissions SummaryPage 23 of 24

Calpeak

Excess Emissions for 10/1/2024 thru 12/31/2024: VOC lbs/Day

Reason	Duration
There are no excess emissions for this report.	
Source operating time	61 hours
Duration of VOC lbs/Day excess emissions	0
Source operating time with excess emissions	0.0%

Attachment 4

Unit Operating Hours

Midway Peaking, LLC Firebaugh, CA Midway Condition 17 2024

Quarter	Limit
1	800
2	800
3	1400
4	1000
Limit is per Turbine	;

Month	Unit 1A CT-A Nat Gas On-Time Monthly Total	Unit 1B CT-B Nat Gas On-Time Monthly Total	Unit 2A CT-A Nat Gas On-Time Monthly Total	Unit 2B CT-B Nat Gas On-Time Monthly Total
01 2024	18.6	18.4	18.5	18.4
02 2024	8.3	6.3	6.6	6.5
03 2024	0.0	0.0	0.0	0.0
04 2024	1.5	1.3	6.3	3.6
05 2024	17.1	4.9	3.4	1.4
06 2024	11.6	10.5	9.5	8.3
07 2024	48.3	47.0	46.9	46.1
08 2024	13.1	12.9	13.7	13.2
09 2024	10.8	10.5	10.9	10.5
10 2024	33.3	32.6	29.1	29.4
11 2024	17.5	16.9	11.4	11.1
12 2024	5.7	5.5	3.1	3.0
Total	186	167	159	152

Attachment 5

Annual Emissions Summary

Midway Peaking, LLC Firebaugh, CA

Midway Condition 18 and 19 U1 December 2024 12-Month Rolling

	Paran NOx CO VOC PM10 SOx	neter	Limit Ib/yr	per Turbine 12,736 18,826 3,281 7,400 3,560	I	Limit Ib/yr perl 25, 37, 6, 14, 7,	Unit 742 652 562 800 120	Limit Ib/yr fo	r Facility 50,000	
Month	CT-A NOx lbs 12-Month Rolling Total	CT-B NOx lbs 12-Month Rolling Total	CT-A CO Ibs 12-Month Rolling Total	CT-B CO Ibs 12-Month Rolling Total	CT-A VOC lbs 12-Month Rolling Total	CT-B VOC lbs 12-Month Rolling Total	CT-A PM lbs 12-Month Rolling Total	CT-B PM Ibs 12-Month Rolling Total	CT-A SOx lbs 12-Month Rolling Total	CT-B SOx lbs 12-Month Rolling Total
01 2024	551	625	488	536	37	44	180	207	48	54
02 2024	578	601	455	491	35	40	171	191	46	50
03 2024	519	504	390	412	30	32	149	154	40	41
04 2024	347	328	251	263	19	20	94	97	25	26
05 2024	392	343	260	264	23	20	110	100	29	26
06 2024	424	371	271	273	24	21	118	107	31	28
07 2024	560	500	371	370	32	29	156	146	40	38
08 2024	580	521	381	380	33	30	159	149	40	38
09 2024	622	562	404	402	35	32	170	160	43	41
10 2024	704	647	455	455	40	37	196	187	50	48
11 2024	688	625	420	413	38	34	182	171	46	44
12 2024	715	652	437	430	39	35	188	177	48	46

Midway Peaking, LLC Firebaugh, CA

Midway Condition 18 and 19 U2 December 2024 12-Month Rolling

Parameter NOx CO VOC PM10 SOx		Limit Ib/yr	per turbine 12,736 18,826 3,281 7,400 3,560	Lir	nit lb/yr per U 25,7 37,6 6,5 14,8 7,1	nit 42 52 62 00 20	t Limit Ib/yr for Facility 2 50,000 2 2 0			
Month	CT-A NOx lbs 12-Month Rolling Total	CT-B NOx lbs 12-Month Rolling Total	CT-A CO Ibs 12-Month Rolling Total	CT-B CO lbs 12-Month Rolling Total	CT-A VOC lbs 12-Month Rolling Total	CT-B VOC lbs 12-Month Rolling Total	CT-A PM lbs 12-Month Rolling Total	CT-B PM Ibs 12-Month Rolling Total	CT-A SOx lbs 12-Month Rolling Total	CT-B SOx lbs 12-Month Rolling Total
01 2024	533	515	607	577	21	22	163	160	55	54
02 2024	497	501	555	546	20	21	151	153	52	52
03 2024	377	387	410	413	15	16	112	115	39	39
04 2024	260	254	283	275	11	10	76	75	27	26
05 2024	266	250	277	267	11	10	77	74	27	25
06 2024	300	284	296	282	12	11	82	79	28	26
07 2024	438	441	402	388	16	15	112	111	38	36
08 2024	480	478	425	409	16	15	118	117	40	38
09 2024	511	510	449	431	17	16	127	126	43	41
10 2024	579	583	505	490	20	19	146	146	50	48
11 2024	536	539	453	435	17	16	129	128	44	42
12 2024	545	548	463	445	17	16	131	130	45	43

Attachment 6

Startup/Shutdown Duration

1 Midway Events

Calpeak for 10/1/2024 thru 12/31/2024

Parameter	Start	End	Duration	Value
Startup	10/1/2024 3:24 PM	3:52 PM	0.48	
Shutdown	10/1/2024 7:02 PM	7:11 PM	0.17	
Startup	10/2/2024 3:55 PM	4:30 PM	0.60	
Shutdown	10/2/2024 7:31 PM	7:40 PM	0.17	
Startup	10/3/2024 3:25 PM	3:58 PM	0.57	
Shutdown	10/3/2024 4:05 PM	4:08 PM	0.07	
Shutdown	10/3/2024 4:19 PM	4:23 PM	0.08	
Shutdown	10/3/2024 4:28 PM	4:33 PM	0.10	
Startup	10/3/2024 4:45 PM	4:49 PM	0.08	
Shutdown	10/3/2024 7:32 PM	7:40 PM	0.15	
Startup	10/5/2024 4:26 PM	4:53 PM	0.47	
Shutdown	10/5/2024 6:16 PM	6:25 PM	0.17	
Startup	10/5/2024 8:09 PM	8:27 PM	0.32	
Shutdown	10/5/2024 10:31 PM	10:40 PM	0.17	
Startup	10/6/2024 4:16 PM	4:46 PM	0.52	
Shutdown	10/6/2024 11:31 PM	11:40 PM	0.17	
Startup	10/7/2024 3:26 PM	3:49 PM	0.40	
Shutdown	10/7/2024 9:31 PM	9:40 PM	0.17	
Startup	10/8/2024 4:24 PM	4:48 PM	0.42	
Shutdown	10/8/2024 6:16 PM	6:25 PM	0.17	
Startup	10/15/2024 1:55 PM	2:28 PM	0.57	
Shutdown	10/15/2024 2:42 PM	2:51 PM	0.17	
Startup	10/30/2024 7:40 AM	8:14 AM	0.58	
Shutdown	10/30/2024 8:46 AM	8:54 AM	0.15	
Startup	11/1/2024 3:53 PM	4:22 PM	0.50	

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/28/2025 7:33 AM, 1 Midway Events

Parameter	Start	End	Duration	Value
Shutdown	11/1/2024 6:02 PM	6:10 PM	0.15	
Startup	11/9/2024 8:06 AM	8:39 AM	0.57	
Shutdown	11/9/2024 9:17 AM	9:25 AM	0.15	
Startup	11/9/2024 12:22 PM	12:44 PM	0.38	
Shutdown	11/9/2024 1:31 PM	1:40 PM	0.17	
Startup	11/10/2024 8:37 AM	9:10 AM	0.57	
Shutdown	11/10/2024 9:46 AM	9:55 AM	0.17	
Startup	11/11/2024 9:07 AM	9:37 AM	0.52	
Shutdown	11/11/2024 2:02 PM	2:10 PM	0.15	
Startup	11/19/2024 1:27 PM	2:06 PM	0.67	
Shutdown	11/19/2024 3:03 PM	3:11 PM	0.15	
Startup	11/19/2024 4:24 PM	4:42 PM	0.32	
Shutdown	11/19/2024 5:31 PM	5:39 PM	0.15	
Startup	11/21/2024 7:38 AM	8:13 AM	0.60	
Shutdown	11/21/2024 8:46 AM	8:54 AM	0.15	
Startup	11/22/2024 7:05 AM	7:34 AM	0.50	
Shutdown	11/22/2024 8:47 AM	8:55 AM	0.15	
Startup	12/10/2024 9:37 AM	10:19 AM	0.72	
Shutdown	12/10/2024 12:05 PM	12:13 PM	0.15	
Startup	12/18/2024 6:23 AM	6:55 AM	0.55	
Shutdown	12/18/2024 8:02 AM	8:10 AM	0.15	
Startup	12/18/2024 9:23 AM	9:41 AM	0.32	
Shutdown	12/18/2024 10:31 AM	10:39 AM	0.15	

2 Midway Events

Calpeak for 10/1/2024 thru 12/31/2024

Parameter	Start	End	Duration	Value
Startup	10/1/2024 3:24 PM	3:44 PM	0.35	
Shutdown	10/1/2024 7:03 PM	7:11 PM	0.15	
Startup	10/2/2024 3:55 PM	4:32 PM	0.63	
Shutdown	10/2/2024 7:32 PM	7:40 PM	0.15	
Startup	10/3/2024 3:25 PM	3:45 PM	0.35	
Shutdown	10/3/2024 7:32 PM	7:41 PM	0.17	
Startup	10/5/2024 4:26 PM	4:54 PM	0.48	
Startup	10/6/2024 4:16 PM	4:42 PM	0.45	
Shutdown	10/6/2024 11:32 PM	11:40 PM	0.15	
Startup	10/7/2024 3:26 PM	3:44 PM	0.32	
Shutdown	10/7/2024 9:32 PM	9:40 PM	0.15	
Startup	10/8/2024 4:24 PM	4:53 PM	0.50	
Startup	10/8/2024 5:04 PM	5:22 PM	0.32	
Shutdown	10/8/2024 6:16 PM	6:25 PM	0.17	
Startup	10/9/2024 11:42 AM	12:02 PM	0.35	
Shutdown	10/9/2024 12:21 PM	12:29 PM	0.15	
Startup	10/30/2024 7:40 AM	8:03 AM	0.40	
Shutdown	10/30/2024 8:46 AM	8:54 AM	0.15	
Startup	11/1/2024 3:53 PM	4:13 PM	0.35	
Shutdown	11/1/2024 6:02 PM	6:10 PM	0.15	
Startup	11/9/2024 8:06 AM	8:28 AM	0.38	
Shutdown	11/9/2024 9:17 AM	9:25 AM	0.15	
Startup	11/9/2024 12:22 PM	12:49 PM	0.47	
Startup	11/10/2024 8:37 AM	9:03 AM	0.45	
Shutdown	11/10/2024 9:46 AM	9:54 AM	0.15	

CALPEAK: ({optional DAHS description}): CeDAR Reports 8.06.04 1/28/2025 7:34 AM, 2 Midway Events

Parameter	Start	End	Duration	Value
Startup	11/19/2024 1:30 PM	1:59 PM	0.50	
Shutdown	11/19/2024 3:02 PM	3:10 PM	0.15	
Startup	11/19/2024 4:24 PM	4:42 PM	0.32	
Shutdown	11/19/2024 5:31 PM	5:39 PM	0.15	
Startup	11/21/2024 7:38 AM	8:02 AM	0.42	
Shutdown	11/21/2024 8:46 AM	8:54 AM	0.15	
Startup	11/22/2024 7:05 AM	7:25 AM	0.35	
Shutdown	11/22/2024 8:48 AM	8:56 AM	0.15	
Startup	12/18/2024 6:23 AM	6:46 AM	0.40	
Shutdown	12/18/2024 8:02 AM	8:10 AM	0.15	
Startup	12/18/2024 9:23 AM	9:47 AM	0.42	
Shutdown	12/18/2024 10:31 AM	10:39 AM	0.15	

Attachment 7

Acid Rain Program Final Compliance Summary



? <u>Help</u> 🖉 <u>Definitions</u> 🔽 <u>Contact Us</u>







Detailed Compliance Report

Allowance Deductions for Compliance Year 2023 Acid Rain Program

Primary Representative

Claude Couvillion

Alternate Representative

Jon Boyer

Account Name

Midway Peaking

Account Number

056639FACLTY

Program

Acid Rain Program

Beginning Balance

0

SO2 Emissions (tons)

0

Excess Emissions (tons)

0

Ending Balance

0