

DOCKETED	
Docket Number:	24-OPT-02
Project Title:	Compass Energy Storage Project
TN #:	262347
Document Title:	Shannon Yerkovich Comments - combustible materials nearby - not safe!
Description:	N/A
Filer:	System
Organization:	Shannon Yerkovich
Submitter Role:	Public
Submission Date:	3/25/2025 1:21:05 PM
Docketed Date:	3/25/2025

Comment Received From: Shannon Yerkovich
Submitted On: 3/25/2025
Docket Number: 24-OPT-02

combustible materials nearby - not safe!

Please do not approve this, its a HUGE risk - there is a hydrogen gas station directly across the street! A lithium battery storage facility should never be placed near a hydrogen gas station due to the high risk of fire, explosion, and chain reactions. They should be stored far apart with strict safety measures in place, including fire-resistant barriers, ventilation, and gas leak detection systems. Having a lithium battery storage location next to a hydrogen gas station would be a major safety hazard for several reasons:

1. Fire & Explosion Risk

Lithium batteries can overheat (thermal runaway) and catch fire if damaged, overcharged, or exposed to high temperatures.

Hydrogen is highly flammable and ignites easily, even from a small spark.

If a lithium battery fire occurs, the intense heat could ignite leaking hydrogen gas, leading to a massive explosion.

2. Difficult to Extinguish Fires

Lithium battery fires burn at very high temperatures and can be difficult to put out with conventional fire extinguishers.

Hydrogen flames are nearly invisible, making it harder to detect a fire before it spreads.

3. Chain Reaction Risk

If a lithium battery fire starts, the heat could cause a hydrogen leak or explosion.

If a hydrogen explosion occurs, it could damage nearby lithium battery storage, potentially igniting more fires.

Please do not approve this, there are way too many risks associated with this project