

DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	262751-2
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q1 2025 - Part 4s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	4/23/2025 7:58:04 AM
Docketed Date:	4/23/2025

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2025 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

AQ-54 thru 63 & 71

AQ54-63 & 71: Fuel use emission and operational data -
Hourly/Daily/Quarterly

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSDTF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/07/25 5:39	93990.3			0			0			0			0			0		
01/07/25 5:40	94463.9			0			0			0			0			0		
01/07/25 5:41	94452.4			0			0			0			0			0		
01/07/25 5:42	94845.2			0			0			0			0			0		
01/07/25 5:43	88855.3			0			0			0			0			0		
01/07/25 5:44	90143.3			-0.2			0			0			0			1		
01/07/25 5:45	79128.1			-0.2			0			0			0			1		
01/07/25 5:46	78146.2			1907.7			23.6			351.44			7.16			1		
01/07/25 5:47	92482.7			1132.8			14.75			246.98			5.29			1		
01/07/25 5:48	98010.5			682			19.44			157.54			7.39			1		
01/07/25 5:49	113046			436.3			23.91			116.22			10.48			1		
01/07/25 5:50	148968.2			310.9			29.5			109.2			17.05			1		
01/07/25 5:51	163235.4			192.8			41.3			74.19			26.15			1		
01/07/25 5:52	173505.4			805			47.59			329.2			32.03			1		
01/07/25 5:53	190562.5			1900.7			37.43			853.92			27.67			1		
01/07/25 5:54	211039.2			1689.2			44.25			840.19			36.22			1		
01/07/25 5:55	232180			482.1			52.81			263.84			47.57			1		
01/07/25 5:56	251137.5			28.2			53.6			16.72			52.23			1		
01/07/25 5:57	273046.7			2.8			70.57			1.83			74.75			1		
01/07/25 5:58	299842.4			1.9			87.98			1.32			102.33			1		
01/07/25 5:59	321653.4			1.7			51.99			1.26			64.88			1		
01/07/25 6:00	339958.1			1.7			28.73			1.37			37.89			1		
01/07/25 6:01	354081			1.9			17.53			1.55			24.08			1		
01/07/25 6:02	289335.5			1.8			14.19			1.22			15.93			1		
01/07/25 6:03	183157.5			2			19.84			0.85			14.1			1		
01/07/25 6:04	175636.9			688.7			34.44			285.06			23.46			1		
01/07/25 6:05	188003.7			1737.6			36.24			770.15			26.44			1		
01/07/25 6:06	196772			1643.2			33.33			762.15			25.44			1		
01/07/25 6:07	206805.2			880.3			30.98			429.17			24.85			1		
01/07/25 6:08	227784.4			232.6			33.71			124.92			29.8			1		
01/07/25 6:09	247550.5			25.4			35.78			14.82			34.37			1		
01/07/25 6:10	268015.6			2.5			35.63			1.58			37.04			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/07/25 6:11	294776.7			1.3			52.38			0.93			59.89			1		
01/07/25 6:12	307842.5			1.2			30.06			0.88			35.9			1		
01/07/25 6:13	308887.9			1.2			17.35			0.9			20.79			1		
01/07/25 6:14	308749.3			1.2			14.53			0.9			17.4			1		
01/07/25 6:15	308293			1.1			13.3			0.83			15.9			1		
01/07/25 6:16	318303.2			1			12.94			0.73			15.99			1		
01/07/25 6:17	336140.1			0.9			10.28			0.71			13.41			1		
01/07/25 6:18	349621.7			0.9			8.45			0.73			11.46			1		
01/07/25 6:19	353439.8			0.8			7.49			0.66			10.26			1		
01/07/25 6:20	353665			0.8			7.13			0.66			9.79			1		
01/07/25 6:21	353867.2			0.8			7.13			0.66			9.79			1		
01/07/25 6:22	353832.5			0.8			7.04			0.66			9.67			1		
01/07/25 6:23	353514.8			0.7			6.96			0.59			9.54			1		
01/07/25 6:24	353705.5			0.7			6.87			0.59			9.43			1		
01/07/25 6:25	352966.1			0.7			6.87			0.59			9.41			1		
01/07/25 6:26	352567.5			0.7			6.96			0.59			9.52			1		
01/07/25 6:27	352007.3			0.7			6.96			0.58			9.5			1		
01/07/25 6:28	352255.6			0.6			7.04			0.51			9.63			1		
01/07/25 6:29	351643.4			0.6			7.04			0.51			9.61			1		
01/07/25 6:30	354797.2			0.7			7.04			0.59			9.7			1		
01/07/25 6:31	360550.3			0.7			5.72			0.61			8			1		
01/07/25 6:32	361110.5			0.6			4.92			0.53			6.89			1		
01/07/25 6:33	360850.7			0.6			5.27			0.53			7.38			1		
01/07/25 6:34	362681.7			0.6			4.2			0.53			5.91			1		
01/07/25 6:35	363132.3			0.6			3.75			0.54			5.29			1		
01/07/25 6:36	363426.8			0.6			3.75			0.54			5.29			1		
01/07/25 6:37	363634.8			0.6			3.93			0.54			5.55			1		
01/07/25 6:38	364229.8			0.6			4.02			0.54			5.68			1		
01/07/25 6:39	362202.3			0.6			3.49			0.53			4.9			1		
01/07/25 6:40	360891.1			0.6			2.91			0.52			4.07			1		
01/07/25 6:41	360758.2			0.6			2.41			0.53			3.38			1		
01/07/25 6:42	359169.8			0.6			2.32			0.53			3.24			1		
01/07/25 6:43	358020.3			0.6			2.32			0.53			3.23			1		
01/07/25 6:44	357321.4			0.6			2.32			0.53			3.22			1		
01/07/25 6:45	359499			0.5			2.32			0.45			3.24			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/07/25 6:46	361520.7			0.5			2.23			0.46			3.13			1		
01/07/25 6:47	362265.8			0.6			2.06			0.53			2.89			1		
01/07/25 6:48	364559			0.6			1.88			0.54			2.65			1		
01/07/25 6:49	365038.4			0.6			1.7			0.54			2.41			1		
01/07/25 6:50	362034.8			0.6			1.52			0.53			2.13			1		
01/07/25 6:51	361387.8			0.6			1.43			0.53			2			1		
01/07/25 6:52	360931.5			0.6			1.34			0.53			1.88			1		
01/07/25 6:53	360140.2			0.6			1.25			0.53			1.75			1		
01/07/25 6:54	358829			0.6			1.16			0.53			1.62			1		
01/07/25 6:55	357211.6			0.6			1.16			0.53			1.61			1		
01/07/25 6:56	359140.9			0.6			1.16			0.53			1.62			1		
01/07/25 6:57	360631.1			0.6			1.07			0.53			1.5			1		
01/07/25 6:58	359943.8			0.5			1.07			0.46			1.5			0		
01/07/25 6:59	361110.6			0.6			1.16			0.53			1.63			0		
01/07/25 7:00	362069.5			0.6			1.25			0.53			1.76			0		
01/07/25 7:01	363351.7			0.6			1.25			0.54			1.76			0		
01/07/25 7:02	364316.4			0.6			1.34			0.54			1.89			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/07/25 5:56	251137.5			28.2			53.6			16.72			52.23			1		
01/07/25 5:57	273046.7			2.8			70.57			1.83			74.75			1		
01/07/25 5:58	299842.4			1.9			87.98			1.32			102.33			1		
01/07/25 5:59	321653.4			1.7			51.99			1.26			64.88			1		
01/07/25 6:00	339958.1			1.7			28.73			1.37			37.89			1		
01/07/25 6:01	354081			1.9			17.53			1.55			24.08			1		
01/07/25 6:02	289335.5			1.8			14.19			1.22			15.93			1		
01/07/25 6:03	183157.5			2			19.84			0.85			14.1			1		
01/07/25 6:04	175636.9			688.7			34.44			285.06			23.46			1		
01/07/25 6:05	188003.7			1737.6			36.24			770.15			26.44			1		
01/07/25 6:06	196772			1643.2			33.33			762.15			25.44			1		
01/07/25 6:07	206805.2			880.3			30.98			429.17			24.85			1		
01/07/25 6:08	227784.4			232.6			33.71			124.92			29.8			1		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/06/25 23:53	448972.3			0.7			1.37			0.87			2.7			0		
02/06/25 23:54	448983.9			0.7			1.37			0.78			2.43			0		
02/06/25 23:55	444045.2			1.1			1.39			1.18			2.4			0		
02/06/25 23:56	426849.5			1.5			1.36			1.56			2.26			0		
02/06/25 23:57	405223.4			1.5			1.27			1.39			2			0		
02/06/25 23:58	382407.4			1			1.32			0.87			1.96			1		
02/06/25 23:59	361630.4			0.7			1.3			0.59			1.83			1		
02/07/25 0:00	339051.3			0.7			1.3			0.56			1.72			1		
02/07/25 0:01	315409.3			0.8			1.39			0.58			1.7			1		
02/07/25 0:02	293020.7			0.7			1.48			0.48			1.68			1		
02/07/25 0:03	272012.7			0.6			1.52			0.4			1.61			1		
02/07/25 0:04	249069.6			0.6			2.4			0.33			2.32			1		
02/07/25 0:05	229534.6			0.3			7.1			0.16			6.34			1		
02/07/25 0:06	206539.5			0.1			12.13			0.05			9.74			1		
02/07/25 0:07	186132.2			37.2			14.26			16.37			10.32			1		
02/07/25 0:08	170184.1			408.3			16.05			164.07			10.62			1		
02/07/25 0:09	153508.3			1485.2			17.7			538.58			10.56			1		
02/07/25 0:10	90183.8			1899.6			17.52			404.39			6.14			1		
02/07/25 0:11	84777.3			0			27.53			1035.08			9.07			0		
02/07/25 0:12	84933.2			0			0.1			0			0			0		
02/07/25 0:13	85539.7			0			0.1			0			0			0		
02/07/25 0:14	85996			0			0.1			0			0			0		
02/07/25 0:15	86157.8			0			0.1			0			0			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/18/25 23:39	0			0			0			0			0			0		
02/18/25 23:40	0			0			0			0			0			0		
02/18/25 23:41	0			0			0			0			0			0		
02/18/25 23:42	0			0			0			0			0			0		
02/18/25 23:43	10899.7			0			0			0			0			0		
02/18/25 23:44	26120			0			0			0			0			1		
02/18/25 23:45	32612.4			0			0			0			0			1		
02/18/25 23:46	43616.1			1282.3			11.8			132.03			2			1		
02/18/25 23:47	54625.5			982.2			8.65			126.63			1.84			1		
02/18/25 23:48	66524.5			634.3			14.75			99.67			3.81			1		
02/18/25 23:49	88861			375.2			21.83			78.7			7.54			1		
02/18/25 23:50	131639.5			244.9			28.7			76.13			14.68			1		
02/18/25 23:51	147044.7			161.1			40.17			55.94			22.95			1		
02/18/25 23:52	159469.3			841.2			45.11			316.73			27.95			1		
02/18/25 23:53	178057.1			1849.4			37.01			777.86			25.62			1		
02/18/25 23:54	199792.9			1602.5			45.65			756.15			35.45			1		
02/18/25 23:55	222476			209.4			52			110			44.96			1		
02/18/25 23:56	242097.8			16.3			52.49			9.35			49.38			1		
02/18/25 23:57	266675.5			2.4			73.2			1.51			75.86			1		
02/18/25 23:58	292928.3			2			76.3			1.38			86.86			1		
02/18/25 23:59	314369.6			1.8			39.78			1.33			48.61			1		
02/19/25 0:00	332177.6			1.9			22.49			1.48			29.03			1		
02/19/25 0:01	346236.8			1.9			14.83			1.59			19.96			1		
02/19/25 0:02	350632.5			1.8			12.57			1.49			17.13			1		
02/19/25 0:03	350938.7			1.6			11.12			1.35			15.16			1		
02/19/25 0:04	355363.3			1.5			9.32			1.22			12.87			1		
02/19/25 0:05	359042.7			1.3			7.64			1.1			10.65			1		
02/19/25 0:06	359949.5			1.1			6.59			0.96			9.22			1		
02/19/25 0:07	360400.1			1.1			6.16			0.9			8.63			1		
02/19/25 0:08	360301.9			1			5.64			0.82			7.89			1		
02/19/25 0:09	360371.2			0.9			5.46			0.75			7.65			1		
02/19/25 0:10	359418.1			0.9			5.37			0.75			7.5			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/19/25 0:11	359741.6			0.8			5.02			0.67			7.02			1		
02/19/25 0:12	360821.8			0.8			4.83			0.69			6.77			1		
02/19/25 0:13	361422.5			0.7			4.83			0.61			6.78			1		
02/19/25 0:14	361370.5			0.7			4.83			0.61			6.78			1		
02/19/25 0:15	361520.7			0.7			4.76			0.6			6.68			1		
02/19/25 0:16	359216			0.7			4.76			0.6			6.64			1		
02/19/25 0:17	356564.7			0.7			4.84			0.59			6.71			1		
02/19/25 0:18	355536.5			0.7			4.58			0.59			6.33			1		
02/19/25 0:19	354953.1			0.7			4.11			0.6			5.67			1		
02/19/25 0:20	352908.3			0.7			4.23			0.59			5.8			1		
02/19/25 0:21	352377			0.7			4.14			0.59			5.67			1		
02/19/25 0:22	354907			0.7			4.11			0.6			5.67			1		
02/19/25 0:23	355802.3			0.6			4.02			0.53			5.56			1		
02/19/25 0:24	356304.8			0.6			4.02			0.53			5.57			1		
02/19/25 0:25	357610.2			0.6			4.11			0.53			5.72			1		
02/19/25 0:26	358349.5			0.6			4.2			0.53			5.85			1		
02/19/25 0:27	358499.8			0.6			4.11			0.53			5.73			1		
02/19/25 0:28	358875.2			0.6			3.4			0.53			4.74			1		
02/19/25 0:29	357257.9			0.6			2.59			0.53			3.6			1		
02/19/25 0:30	355906.2			0.6			2.5			0.53			3.46			1		
02/19/25 0:31	354878			0.6			2.41			0.52			3.33			1		
02/19/25 0:32	353318.5			0.6			2.41			0.52			3.31			1		
02/19/25 0:33	352642.7			0.6			2.5			0.52			3.43			1		
02/19/25 0:34	352948.8			0.6			2.5			0.52			3.43			1		
02/19/25 0:35	351088.8			0.6			2.5			0.52			3.42			1		
02/19/25 0:36	350314.8			0.6			1.85			0.51			2.52			1		
02/19/25 0:37	353324.2			0.6			1.52			0.52			2.09			1		
02/19/25 0:38	354456.4			0.6			1.43			0.52			1.97			1		
02/19/25 0:39	355871.5			0.6			1.34			0.53			1.85			1		
02/19/25 0:40	357130.8			0.6			1.16			0.53			1.61			1		
02/19/25 0:41	358459.3			0.6			1.07			0.53			1.49			1		
02/19/25 0:42	359631.9			0.6			0.98			0.53			1.37			1		
02/19/25 0:43	357979.9			0.6			0.89			0.53			1.24			1		
02/19/25 0:44	355455.7			0.6			0.88			0.52			1.22			1		
02/19/25 0:45	353549.5			0.6			0.8			0.52			1.11			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/19/25 0:46	352151.7			0.6			0.8			0.52			1.1			1		
02/19/25 0:47	350465.1			0.6			0.8			0.52			1.1			0		
02/19/25 0:48	349436.9			0.6			0.72			0.52			0.97			0		
02/19/25 0:49	352775.5			0.6			0.72			0.52			0.98			0		
02/19/25 0:50	353844.1			0.6			0.72			0.52			0.98			0		
02/19/25 0:51	354623.9			0.6			0.72			0.52			0.99			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/26/25 9:00	351256.3			0.7			1.07			0.59			1.47			0		
03/26/25 9:01	350442			0.7			1.16			0.59			1.58			0		
03/26/25 9:02	349176.9			0.7			1.16			0.59			1.58			0		
03/26/25 9:03	348420.2			0.7			1.16			0.59			1.58			0		
03/26/25 9:04	347883			0.7			1.16			0.59			1.57			0		
03/26/25 9:05	337543.7			0.7			1.16			0.57			1.53			1		
03/26/25 9:06	297745.7			0.7			1.18			0.51			1.37			0		
03/26/25 9:07	290317.5			0.7			1.41			0.48			1.59			0		
03/26/25 9:08	301765.9			0.7			1.2			0.53			1.41			0		
03/26/25 9:09	320509.7			0.6			1.09			0.48			1.36			0		
03/26/25 9:10	329249.1			0.6			1.07			0.49			1.37			0		

Monthly Summary By Day Report

Units CT1 and CT2

From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission



Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
01/01/2025	0.00	0.00	0.00	0.00	0.00
01/02/2025	0.00	0.00	0.00	0.00	0.00
01/03/2025	0.00	0.00	0.00	0.00	0.00
01/04/2025	0.00	0.00	0.00	0.00	0.00
01/05/2025	0.00	0.00	0.00	0.00	0.00
01/06/2025	0.00	0.00	0.00	0.00	0.00
01/07/2025	113.52	70.21	5.28	10.55	17.65
01/08/2025	31.63	78.99	8.30	16.35	27.69
01/09/2025	24.90	60.31	6.88	13.77	22.94
01/10/2025	27.97	60.22	6.91	13.80	22.97
01/11/2025	23.50	59.16	6.73	13.49	22.48
01/12/2025	23.59	64.29	7.18	14.35	23.90
01/13/2025	26.19	68.68	7.57	15.19	25.30
01/14/2025	29.90	67.27	7.54	15.03	25.07
01/15/2025	29.59	60.53	6.88	13.77	22.96
01/16/2025	31.43	61.27	6.92	13.86	23.08
01/17/2025	31.30	62.97	7.11	14.27	23.75
01/18/2025	30.63	60.98	6.84	13.70	22.83
01/19/2025	31.12	62.03	6.98	13.99	23.29
01/20/2025	27.22	67.02	7.49	14.94	24.88
01/21/2025	26.76	65.29	7.28	14.59	24.29
01/22/2025	29.40	66.96	7.49	14.98	24.99
01/23/2025	39.25	105.01	8.62	16.95	28.82
01/24/2025	40.05	86.82	8.93	17.60	29.94
01/25/2025	28.17	70.56	7.82	15.63	26.08
01/26/2025	28.60	70.00	7.71	15.46	25.74
01/27/2025	26.10	71.51	7.82	15.64	26.02
01/28/2025	42.56	93.80	8.84	17.50	29.58
01/29/2025	38.55	84.15	8.42	16.67	28.04
01/30/2025	31.66	67.01	7.54	15.10	25.12
01/31/2025	25.21	69.47	7.70	15.43	25.76
Monthly Avg/Sum:	838.80 sum	1,754.51 sum	186.78 sum	372.61 sum	623.17 sum
Daily Min:	0.00	0.00	0.00	0.00	0.00
Daily Max:	113.52	105.01	8.93	17.60	29.94
Jan 2025 - Jan 2025	838.80 sum	1,754.51 sum	186.78 sum	372.61 sum	623.17 sum
QTD:	838.80 sum	1,754.51 sum	186.78 sum	372.61 sum	623.17 sum
YTD 2025:	838.80 sum	1,754.51 sum	186.78 sum	372.61 sum	623.17 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2025 08:03 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
02/01/2025	25.88	65.36	7.48	15.00	24.96
02/02/2025	22.33	62.30	7.33	14.56	24.29
02/03/2025	15.51	68.93	7.80	15.59	26.02
02/04/2025	16.28	66.63	7.57	15.13	25.22
02/05/2025	23.12	59.81	6.83	13.76	22.84
02/06/2025	25.58	69.81	7.84	15.67	26.12
02/07/2025	21.96	1.11	0.03	0.05	0.09
02/08/2025	0.00	0.00	0.00	0.00	0.00
02/09/2025	0.00	0.00	0.00	0.00	0.00
02/10/2025	0.00	0.00	0.00	0.00	0.00
02/11/2025	0.00	0.00	0.00	0.00	0.00
02/12/2025	0.00	0.00	0.00	0.00	0.00
02/13/2025	0.00	0.00	0.00	0.00	0.00
02/14/2025	0.00	0.00	0.00	0.00	0.00
02/15/2025	0.00	0.00	0.00	0.00	0.00
02/16/2025	0.00	0.00	0.00	0.00	0.00
02/17/2025	0.00	0.00	0.00	0.00	0.00
02/18/2025	42.04	7.67	0.03	0.05	0.09
02/19/2025	22.14	60.62	6.59	13.13	21.92
02/20/2025	22.88	57.25	6.79	13.50	22.50
02/21/2025	24.31	56.69	6.71	13.35	22.29
02/22/2025	19.71	48.39	5.96	11.87	19.76
02/23/2025	13.08	40.59	5.28	10.47	17.43
02/24/2025	17.02	45.10	5.87	11.62	19.36
02/25/2025	24.46	66.30	7.50	14.71	24.86
02/26/2025	27.10	65.94	8.11	15.93	26.91
02/27/2025	24.69	55.54	6.62	13.22	22.01
02/28/2025	24.48	56.76	6.73	13.44	22.40
Monthly Avg/Sum:	412.57 sum	954.80 sum	111.07 sum	221.05 sum	369.07 sum
Daily Min:	0.00	0.00	0.00	0.00	0.00
Daily Max:	42.04	69.81	8.11	15.93	26.91
Jan 2025 - Feb 2025	1,251.37 sum	2,709.31 sum	297.85 sum	593.66 sum	992.24 sum
QTD:	1,251.37 sum	2,709.31 sum	297.85 sum	593.66 sum	992.24 sum
YTD 2025:	1,251.37 sum	2,709.31 sum	297.85 sum	593.66 sum	992.24 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission



Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
03/01/2025	19.04	48.47	6.02	12.03	20.01
03/02/2025	12.35	40.75	5.28	10.56	17.55
03/03/2025	14.75	54.20	6.43	12.88	21.46
03/04/2025	20.19	62.33	7.22	14.39	24.01
03/05/2025	15.73	73.70	8.23	16.45	27.44
03/06/2025	22.94	58.49	6.78	13.56	22.60
03/07/2025	23.66	60.05	6.86	13.84	23.07
03/08/2025	22.24	58.71	6.73	13.54	22.55
03/09/2025	20.06	59.11	6.79	13.67	22.75
03/10/2025	21.29	59.60	6.90	13.82	22.98
03/11/2025	20.02	60.99	7.07	14.16	23.61
03/12/2025	22.79	66.85	7.69	15.32	25.58
03/13/2025	21.14	61.55	7.14	14.19	23.72
03/14/2025	25.20	67.50	7.74	15.49	25.79
03/15/2025	24.24	58.28	6.76	13.60	22.65
03/16/2025	21.09	56.50	6.65	13.28	22.15
03/17/2025	23.00	60.54	6.96	13.94	23.29
03/18/2025	18.37	49.57	5.84	11.76	19.61
03/19/2025	22.07	59.33	6.87	13.70	22.84
03/20/2025	23.65	53.75	6.30	12.73	21.20
03/21/2025	24.47	50.61	6.01	12.12	20.22
03/22/2025	15.32	43.88	5.28	10.58	17.68
03/23/2025	18.26	49.23	5.89	11.90	19.77
03/24/2025	22.06	55.86	6.60	13.18	22.00
03/25/2025	21.02	48.92	5.93	11.85	19.74
03/26/2025	14.52	43.51	5.30	10.71	17.82
03/27/2025	14.11	43.70	5.28	10.76	17.86
03/28/2025	13.84	44.00	5.32	10.78	17.90
03/29/2025	14.57	45.16	5.40	10.87	18.07
03/30/2025	14.45	45.15	5.45	11.02	18.29
03/31/2025	14.61	45.66	5.39	10.92	18.14
Monthly Avg/Sum:	601.05 sum	1,685.95 sum	198.11 sum	397.60 sum	662.35 sum
Daily Min:	12.35	40.75	5.28	10.56	17.55
Daily Max:	25.20	73.70	8.23	16.45	27.44
Jan 2025 - Mar 2025	1,852.42 sum	4,395.26 sum	495.96 sum	991.26 sum	1,654.59 sum
QTD:	1,852.42 sum	4,395.26 sum	495.96 sum	991.26 sum	1,654.59 sum
YTD 2025:	1,852.42 sum	4,395.26 sum	495.96 sum	991.26 sum	1,654.59 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission



Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
01/01/2025	0.00	0.00	0.00	0.00	0.00
01/02/2025	0.00	0.00	0.00	0.00	0.00
01/03/2025	0.00	0.00	0.00	0.00	0.00
01/04/2025	0.00	0.00	0.00	0.00	0.00
01/05/2025	0.00	0.00	0.00	0.00	0.00
01/06/2025	0.00	0.00	0.00	0.00	0.00
01/07/2025	113.52	70.21	5.28	10.55	17.65
01/08/2025	31.63	78.99	8.30	16.35	27.69
01/09/2025	24.90	60.31	6.88	13.77	22.94
01/10/2025	27.97	60.22	6.91	13.80	22.97
01/11/2025	23.50	59.16	6.73	13.49	22.48
01/12/2025	23.59	64.29	7.18	14.35	23.90
01/13/2025	26.19	68.68	7.57	15.19	25.30
01/14/2025	29.90	67.27	7.54	15.03	25.07
01/15/2025	29.59	60.53	6.88	13.77	22.96
01/16/2025	31.43	61.27	6.92	13.86	23.08
01/17/2025	31.30	62.97	7.11	14.27	23.75
01/18/2025	30.63	60.98	6.84	13.70	22.83
01/19/2025	31.12	62.03	6.98	13.99	23.29
01/20/2025	27.22	67.02	7.49	14.94	24.88
01/21/2025	26.76	65.29	7.28	14.59	24.29
01/22/2025	29.40	66.96	7.49	14.98	24.99
01/23/2025	39.25	105.01	8.62	16.95	28.82
01/24/2025	40.05	86.82	8.93	17.60	29.94
01/25/2025	28.17	70.56	7.82	15.63	26.08
01/26/2025	28.60	70.00	7.71	15.46	25.74
01/27/2025	26.10	71.51	7.82	15.64	26.02
01/28/2025	42.56	93.80	8.84	17.50	29.58
01/29/2025	38.55	84.15	8.42	16.67	28.04
01/30/2025	31.66	67.01	7.54	15.10	25.12
01/31/2025	25.21	69.47	7.70	15.43	25.76
Monthly Avg/Sum:	838.80 sum	1,754.51 sum	186.78 sum	372.61 sum	623.17 sum
Daily Min:	0.00	0.00	0.00	0.00	0.00
Daily Max:	113.52	105.01	8.93	17.60	29.94
Jan 2025 - Jan 2025	838.80 sum	1,754.51 sum	186.78 sum	372.61 sum	623.17 sum
QTD:	838.80 sum	1,754.51 sum	186.78 sum	372.61 sum	623.17 sum
YTD 2025:	838.80 sum	1,754.51 sum	186.78 sum	372.61 sum	623.17 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2025 08:20 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
02/01/2025	25.88	65.36	7.48	15.00	24.96
02/02/2025	22.33	62.30	7.33	14.56	24.29
02/03/2025	15.51	68.93	7.80	15.59	26.02
02/04/2025	16.28	66.63	7.57	15.13	25.22
02/05/2025	23.12	59.81	6.83	13.76	22.84
02/06/2025	25.58	69.81	7.84	15.67	26.12
02/07/2025	21.96	1.11	0.03	0.05	0.09
02/08/2025	0.00	0.00	0.00	0.00	0.00
02/09/2025	0.00	0.00	0.00	0.00	0.00
02/10/2025	0.00	0.00	0.00	0.00	0.00
02/11/2025	0.00	0.00	0.00	0.00	0.00
02/12/2025	0.00	0.00	0.00	0.00	0.00
02/13/2025	0.00	0.00	0.00	0.00	0.00
02/14/2025	0.00	0.00	0.00	0.00	0.00
02/15/2025	0.00	0.00	0.00	0.00	0.00
02/16/2025	0.00	0.00	0.00	0.00	0.00
02/17/2025	0.00	0.00	0.00	0.00	0.00
02/18/2025	42.04	7.67	0.03	0.05	0.09
02/19/2025	22.14	60.62	6.59	13.13	21.92
02/20/2025	22.88	57.25	6.79	13.50	22.50
02/21/2025	24.31	56.69	6.71	13.35	22.29
02/22/2025	19.71	48.39	5.96	11.87	19.76
02/23/2025	13.08	40.59	5.28	10.47	17.43
02/24/2025	17.02	45.10	5.87	11.62	19.36
02/25/2025	24.46	66.30	7.50	14.71	24.86
02/26/2025	27.10	65.94	8.11	15.93	26.91
02/27/2025	24.69	55.54	6.62	13.22	22.01
02/28/2025	24.48	56.76	6.73	13.44	22.40
Monthly Avg/Sum:	412.57 sum	954.80 sum	111.07 sum	221.05 sum	369.07 sum
Daily Min:	0.00	0.00	0.00	0.00	0.00
Daily Max:	42.04	69.81	8.11	15.93	26.91
Jan 2025 - Feb 2025	1,251.37 sum	2,709.31 sum	297.85 sum	593.66 sum	992.24 sum
QTD:	1,251.37 sum	2,709.31 sum	297.85 sum	593.66 sum	992.24 sum
YTD 2025:	1,251.37 sum	2,709.31 sum	297.85 sum	593.66 sum	992.24 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission



Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
03/01/2025	19.04	48.47	6.02	12.03	20.01
03/02/2025	12.35	40.75	5.28	10.56	17.55
03/03/2025	14.75	54.20	6.43	12.88	21.46
03/04/2025	20.19	62.33	7.22	14.39	24.01
03/05/2025	15.73	73.70	8.23	16.45	27.44
03/06/2025	22.94	58.49	6.78	13.56	22.60
03/07/2025	23.66	60.05	6.86	13.84	23.07
03/08/2025	22.24	58.71	6.73	13.54	22.55
03/09/2025	20.06	59.11	6.79	13.67	22.75
03/10/2025	21.29	59.60	6.90	13.82	22.98
03/11/2025	20.02	60.99	7.07	14.16	23.61
03/12/2025	22.79	66.85	7.69	15.32	25.58
03/13/2025	21.14	61.55	7.14	14.19	23.72
03/14/2025	25.20	67.50	7.74	15.49	25.79
03/15/2025	24.24	58.28	6.76	13.60	22.65
03/16/2025	21.09	56.50	6.65	13.28	22.15
03/17/2025	23.00	60.54	6.96	13.94	23.29
03/18/2025	18.37	49.57	5.84	11.76	19.61
03/19/2025	22.07	59.33	6.87	13.70	22.84
03/20/2025	23.65	53.75	6.30	12.73	21.20
03/21/2025	24.47	50.61	6.01	12.12	20.22
03/22/2025	15.32	43.88	5.28	10.58	17.68
03/23/2025	18.26	49.23	5.89	11.90	19.77
03/24/2025	22.06	55.86	6.60	13.18	22.00
03/25/2025	21.02	48.92	5.93	11.85	19.74
03/26/2025	14.52	43.51	5.30	10.71	17.82
03/27/2025	14.11	43.70	5.28	10.76	17.86
03/28/2025	13.84	44.00	5.32	10.78	17.90
03/29/2025	14.57	45.16	5.40	10.87	18.07
03/30/2025	14.45	45.15	5.45	11.02	18.29
03/31/2025	14.61	45.66	5.39	10.92	18.14
Monthly Avg/Sum:	601.05 sum	1,685.95 sum	198.11 sum	397.60 sum	662.35 sum
Daily Min:	12.35	40.75	5.28	10.56	17.55
Daily Max:	25.20	73.70	8.23	16.45	27.44
Jan 2025 - Mar 2025	1,852.42 sum	4,395.26 sum	495.96 sum	991.26 sum	1,654.59 sum
QTD:	1,852.42 sum	4,395.26 sum	495.96 sum	991.26 sum	1,654.59 sum
YTD 2025:	1,852.42 sum	4,395.26 sum	495.96 sum	991.26 sum	1,654.59 sum

Monthly Summary By Day Report



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT1		Unit CT2	
	CO_SUSD, LbPerHr		NOX_SUSD, LbPerHr	
	1 Hour(s)		1 Hour(s)	
01/01/2025	0.0	0.0	0.0	0.0
01/02/2025	0.0	0.0	0.0	0.0
01/03/2025	0.0	0.0	0.0	0.0
01/04/2025	0.0	0.0	0.0	0.0
01/05/2025	0.0	0.0	0.0	0.0
01/06/2025	0.0	0.0	0.0	0.0
01/07/2025	96.4	20.1	0.0	0.0
01/08/2025	0.0	0.0	0.0	0.0
01/09/2025	0.0	0.0	0.0	0.0
01/10/2025	0.0	0.0	0.0	0.0
01/11/2025	0.0	0.0	0.0	0.0
01/12/2025	0.0	0.0	0.0	0.0
01/13/2025	0.0	0.0	0.0	0.0
01/14/2025	0.0	0.0	0.0	0.0
01/15/2025	0.0	0.0	0.0	0.0
01/16/2025	0.0	0.0	0.0	0.0
01/17/2025	0.0	0.0	0.0	0.0
01/18/2025	0.0	0.0	0.0	0.0
01/19/2025	0.0	0.0	0.0	0.0
01/20/2025	0.0	0.0	0.0	0.0
01/21/2025	0.0	0.0	0.0	0.0
01/22/2025	0.0	0.0	0.0	0.0
01/23/2025	0.0	0.0	0.0	0.0
01/24/2025	0.0	0.0	0.0	0.0
01/25/2025	0.0	0.0	0.0	0.0
01/26/2025	0.0	0.0	0.0	0.0
01/27/2025	0.0	0.0	0.0	0.0
01/28/2025	0.0	0.0	0.0	0.0
01/29/2025	0.0	0.0	0.0	0.0
01/30/2025	0.0	0.0	0.0	0.0
01/31/2025	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	96.4 sum	20.1 sum	-	-
Daily Min:	0.0	0.0	-	-
Daily Max:	96.4	20.1	-	-
Jan 2025 - Jan 2025	96.4 sum	20.1 sum	-	-
QTD:	96.4 sum	20.1 sum	0.0 sum	0.0 sum
YTD 2025:	96.4 sum	20.1 sum	0.0 sum	0.0 sum

Monthly Summary By Day Report



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1		Unit CT2	
	CO_SUSD, LbPerHr		NOX_SUSD, LbPerHr	
	1 Hour(s)		1 Hour(s)	
02/01/2025	0.0	0.0	0.0	0.0
02/02/2025	0.0	0.0	0.0	0.0
02/03/2025	0.0	0.0	0.0	0.0
02/04/2025	0.0	0.0	0.0	0.0
02/05/2025	0.0	0.0	0.0	0.0
02/06/2025	0.0	0.0	0.0	0.0
02/07/2025	36.0	1.2	0.0	0.0
02/08/2025	0.0	0.0	0.0	0.0
02/09/2025	0.0	0.0	0.0	0.0
02/10/2025	0.0	0.0	0.0	0.0
02/11/2025	0.0	0.0	0.0	0.0
02/12/2025	0.0	0.0	0.0	0.0
02/13/2025	0.0	0.0	0.0	0.0
02/14/2025	0.0	0.0	0.0	0.0
02/15/2025	0.0	0.0	0.0	0.0
02/16/2025	0.0	0.0	0.0	0.0
02/17/2025	0.0	0.0	0.0	0.0
02/18/2025	42.4	7.5	0.0	0.0
02/19/2025	0.5	4.9	0.0	0.0
02/20/2025	0.0	0.0	0.0	0.0
02/21/2025	0.0	0.0	0.0	0.0
02/22/2025	0.0	0.0	0.0	0.0
02/23/2025	0.0	0.0	0.0	0.0
02/24/2025	0.0	0.0	0.0	0.0
02/25/2025	0.0	0.0	0.0	0.0
02/26/2025	0.0	0.0	0.0	0.0
02/27/2025	0.0	0.0	0.0	0.0
02/28/2025	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	78.9 sum	13.6 sum	-	-
Daily Min:	0.0	0.0	-	-
Daily Max:	42.4	7.5	-	-
Jan 2025 - Feb 2025	175.3 sum	33.7 sum	-	-
QTD:	175.3 sum	33.7 sum	0.0 sum	0.0 sum
YTD 2025:	175.3 sum	33.7 sum	0.0 sum	0.0 sum

Monthly Summary By Day Report



From: 01/01/2025 00:00 To: 03/31/2025 23:59

Generated: 04/01/2025 08:03

Facility Name: ROSEVILLE ENERGY

Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1		Unit CT2	
	CO_SUSD, LbPerHr		NOX_SUSD, LbPerHr	
	1 Hour(s)		1 Hour(s)	
03/01/2025	0.0	0.0	0.0	0.0
03/02/2025	0.0	0.0	0.0	0.0
03/03/2025	0.0	0.0	0.0	0.0
03/04/2025	0.0	0.0	0.0	0.0
03/05/2025	0.0	0.0	0.0	0.0
03/06/2025	0.0	0.0	0.0	0.0
03/07/2025	0.0	0.0	0.0	0.0
03/08/2025	0.0	0.0	0.0	0.0
03/09/2025	0.0	0.0	0.0	0.0
03/10/2025	0.0	0.0	0.0	0.0
03/11/2025	0.0	0.0	0.0	0.0
03/12/2025	0.0	0.0	0.0	0.0
03/13/2025	0.0	0.0	0.0	0.0
03/14/2025	0.0	0.0	0.0	0.0
03/15/2025	0.0	0.0	0.0	0.0
03/16/2025	0.0	0.0	0.0	0.0
03/17/2025	0.0	0.0	0.0	0.0
03/18/2025	0.0	0.0	0.0	0.0
03/19/2025	0.0	0.0	0.0	0.0
03/20/2025	0.0	0.0	0.0	0.0
03/21/2025	0.0	0.0	0.0	0.0
03/22/2025	0.0	0.0	0.0	0.0
03/23/2025	0.0	0.0	0.0	0.0
03/24/2025	0.0	0.0	0.0	0.0
03/25/2025	0.0	0.0	0.0	0.0
03/26/2025	0.0	0.0	0.0	0.0
03/27/2025	0.0	0.0	0.0	0.0
03/28/2025	0.0	0.0	0.0	0.0
03/29/2025	0.0	0.0	0.0	0.0
03/30/2025	0.0	0.0	0.0	0.0
03/31/2025	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	0.0 sum	0.0 sum	-	-
Daily Min:	0.0	0.0	-	-
Daily Max:	0.0	0.0	-	-
Jan 2025 - Mar 2025	175.3 sum	33.7 sum	-	-
QTD:	175.3 sum	33.7 sum	0.0 sum	0.0 sum
YTD 2025:	175.3 sum	33.7 sum	0.0 sum	0.0 sum

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 01/01/2025 00:00 To: 03/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Jan 2025	0.4197	4.8549	0.8772	11.6422	0.1864	2.6133	0.0935	1.3065	0.3115	4.3536
Feb 2025	0.2063	4.8897	0.4776	11.7162	0.1106	2.6380	0.0556	1.3190	0.1845	4.3950
Mar 2025	0.3004	5.1901	0.8433	12.5595	0.1990	2.8370	0.0990	1.4180	0.3311	4.7261
Sum/Avg	5.1901		12.5595		2.8370		1.4180		4.7261	
Limit Value										

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/01/2025 00:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 01:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 02:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 03:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 04:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 05:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 06:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 07:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 08:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 09:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 10:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 11:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 12:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 13:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 14:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 15:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 16:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 17:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 18:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 19:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 20:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 21:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 22:00	0.0	0.0	0	0.00	0.00000	0.00
01/01/2025 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/02/2025 00:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 01:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 02:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 03:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 04:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 05:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 06:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 07:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 08:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 09:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 10:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 11:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 12:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 13:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 14:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 15:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 16:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 17:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 18:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 19:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 20:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 21:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 22:00	0.0	0.0	0	0.00	0.00000	0.00
01/02/2025 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/03/2025 00:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 01:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 02:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 03:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 04:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 05:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 06:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 07:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 08:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 09:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 10:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 11:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 12:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 13:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 14:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 15:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 16:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 17:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 18:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 19:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 20:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 21:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 22:00	0.0	0.0	0	0.00	0.00000	0.00
01/03/2025 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/04/2025 00:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 01:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 02:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 03:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 04:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 05:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 06:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 07:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 08:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 09:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 10:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 11:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 12:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 13:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 14:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 15:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 16:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 17:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 18:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 19:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 20:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 21:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 22:00	0.0	0.0	0	0.00	0.00000	0.00
01/04/2025 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/05/2025 00:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 01:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 02:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 03:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 04:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 05:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 06:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 07:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 08:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 09:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 10:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 11:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 12:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 13:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 14:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 15:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 16:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 17:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 18:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 19:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 20:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 21:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 22:00	0.0	0.0	0	0.00	0.00000	0.00
01/05/2025 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/06/2025 00:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 01:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 02:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 03:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 04:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 05:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 06:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 07:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 08:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 09:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 10:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 11:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 12:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 13:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 14:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 15:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 16:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 17:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 18:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 19:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 20:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 21:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 22:00	0.0	0.0	0	0.00	0.00000	0.00
01/06/2025 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/07/2025 00:00	0.0	0.0	0	0.00	0.00000	0.00
01/07/2025 01:00	0.0	0.0	0	0.00	0.00000	0.00
01/07/2025 02:00	0.0	0.0	0	0.00	0.00000	0.00
01/07/2025 03:00	0.0	0.0	0	0.00	0.00000	0.00
01/07/2025 04:00	0.0	0.0	0	0.00	0.00000	0.00
01/07/2025 05:00	0.0	0.0	0	0.22	0.11118	0.37
01/07/2025 06:00	0.6	1.1	1	0.42	0.20976	0.70
01/07/2025 07:00	0.6	1.4	2	0.48	0.24114	0.80
01/07/2025 08:00	0.6	1.4	1	0.56	0.27948	0.93
01/07/2025 09:00	0.6	1.4	1	0.57	0.28710	0.96
01/07/2025 10:00	0.6	1.4	1	0.57	0.28344	0.94
01/07/2025 11:00	0.6	1.3	1	0.47	0.23310	0.78
01/07/2025 12:00	0.6	1.4	1	0.45	0.22362	0.75
01/07/2025 13:00	0.6	1.4	1	0.44	0.22128	0.74
01/07/2025 14:00	0.6	1.4	1	0.44	0.21990	0.73
01/07/2025 15:00	0.8	1.4	1	0.55	0.27336	0.91
01/07/2025 16:00	0.8	1.4	1	0.63	0.31416	1.05
01/07/2025 17:00	0.9	1.4	1	0.62	0.30936	1.03
01/07/2025 18:00	0.9	1.4	1	0.62	0.30906	1.03
01/07/2025 19:00	0.9	1.4	1	0.62	0.31122	1.04
01/07/2025 20:00	0.9	1.4	1	0.62	0.31176	1.04
01/07/2025 21:00	0.9	1.5	1	0.62	0.31236	1.04
01/07/2025 22:00	0.9	1.5	1	0.63	0.31302	1.04
01/07/2025 23:00	0.9	1.5	1	0.62	0.31212	1.04
Average/Sum#:	0.7	1.3	1	0.53	0.26718	0.89
Minimum:	0.0	0.0	1	0.22	0.11118	0.37
Maximum:	0.9	1.5	2	0.63	0.31416	1.05
%SI	20.83	20.83	25.00	20.83	20.83	20.83

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/08/2025 00:00	0.9	1.5	1	0.62	0.31152	1.04
01/08/2025 01:00	1.0	1.5	1	0.62	0.31122	1.04
01/08/2025 02:00	0.9	1.5	1	0.62	0.31152	1.04
01/08/2025 03:00	1.0	1.5	1	0.62	0.31110	1.04
01/08/2025 04:00	1.0	1.4	1	0.62	0.31164	1.04
01/08/2025 05:00	1.0	1.4	1	0.62	0.31056	1.04
01/08/2025 06:00	1.0	1.5	1	0.62	0.30972	1.03
01/08/2025 07:00	0.9	1.5	2	0.65	0.32460	1.08
01/08/2025 08:00	1.0	1.5	1	0.63	0.31518	1.05
01/08/2025 09:00	1.0	1.5	1	0.62	0.30858	1.03
01/08/2025 10:00	1.0	1.4	1	0.62	0.30954	1.03
01/08/2025 11:00	0.8	1.3	1	0.50	0.24930	0.83
01/08/2025 12:00	0.7	1.3	1	0.44	0.21972	0.73
01/08/2025 13:00	0.7	1.3	1	0.44	0.21948	0.73
01/08/2025 14:00	0.6	1.4	1	0.44	0.21924	0.73
01/08/2025 15:00	0.8	1.3	1	0.54	0.27234	0.91
01/08/2025 16:00	0.8	1.4	1	0.63	0.31602	1.05
01/08/2025 17:00	0.9	1.4	1	0.63	0.31368	1.05
01/08/2025 18:00	1.0	1.4	1	0.63	0.31326	1.04
01/08/2025 19:00	1.1	1.4	1	0.63	0.31278	1.04
01/08/2025 20:00	1.1	1.4	1	0.62	0.31242	1.04
01/08/2025 21:00	1.2	1.4	1	0.62	0.31158	1.04
01/08/2025 22:00	1.2	1.4	1	0.62	0.31092	1.04
01/08/2025 23:00	1.2	1.4	1	0.62	0.31038	1.03
Average/Sum#:	1.0	1.4	1	0.59	0.29651	0.99
Minimum:	0.6	1.3	1	0.44	0.21924	0.73
Maximum:	1.2	1.5	2	0.65	0.32460	1.08
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/09/2025 00:00	1.3	1.4	1	0.62	0.30918	1.03
01/09/2025 01:00	1.2	1.5	1	0.62	0.30894	1.03
01/09/2025 02:00	1.3	1.5	1	0.62	0.30900	1.03
01/09/2025 03:00	1.2	1.4	2	0.62	0.31194	1.04
01/09/2025 04:00	1.2	1.4	1	0.62	0.31248	1.04
01/09/2025 05:00	1.1	1.4	1	0.63	0.31326	1.04
01/09/2025 06:00	1.1	1.5	1	0.63	0.31338	1.04
01/09/2025 07:00	1.1	1.5	1	0.62	0.30930	1.03
01/09/2025 08:00	1.1	1.4	1	0.61	0.30576	1.02
01/09/2025 09:00	0.7	1.3	2	0.45	0.22686	0.76
01/09/2025 10:00	0.7	1.4	2	0.44	0.22086	0.74
01/09/2025 11:00	0.6	1.3	2	0.44	0.22032	0.73
01/09/2025 12:00	0.6	1.3	1	0.44	0.22014	0.73
01/09/2025 13:00	0.6	1.4	1	0.44	0.21984	0.73
01/09/2025 14:00	0.6	1.3	1	0.44	0.21990	0.73
01/09/2025 15:00	0.7	1.4	1	0.50	0.25194	0.84
01/09/2025 16:00	0.6	1.4	1	0.64	0.31962	1.07
01/09/2025 17:00	0.7	1.4	1	0.64	0.31764	1.06
01/09/2025 18:00	0.8	1.4	1	0.63	0.31500	1.05
01/09/2025 19:00	1.0	1.5	1	0.63	0.31308	1.04
01/09/2025 20:00	1.0	1.4	1	0.63	0.31254	1.04
01/09/2025 21:00	1.0	1.4	1	0.62	0.31134	1.04
01/09/2025 22:00	1.1	1.4	1	0.62	0.31128	1.04
01/09/2025 23:00	1.1	1.5	1	0.62	0.31068	1.04
Average/Sum#:	0.9	1.4	1	0.57	0.28685	0.96
Minimum:	0.6	1.3	1	0.44	0.21984	0.73
Maximum:	1.3	1.5	2	0.64	0.31962	1.07
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/10/2025 00:00	1.1	1.4	1	0.62	0.30912	1.03
01/10/2025 01:00	1.1	1.4	1	0.62	0.31128	1.04
01/10/2025 02:00	1.1	1.4	1	0.62	0.30858	1.03
01/10/2025 03:00	1.2	1.5	2	0.62	0.30798	1.03
01/10/2025 04:00	1.1	1.4	1	0.61	0.30708	1.02
01/10/2025 05:00	1.2	1.5	1	0.61	0.30696	1.02
01/10/2025 06:00	1.3	1.5	1	0.61	0.30654	1.02
01/10/2025 07:00	1.3	1.4	1	0.62	0.30816	1.03
01/10/2025 08:00	1.3	1.5	1	0.61	0.30726	1.02
01/10/2025 09:00	1.1	1.4	1	0.61	0.30744	1.02
01/10/2025 10:00	0.9	1.3	1	0.54	0.27030	0.90
01/10/2025 11:00	0.7	1.4	1	0.44	0.21996	0.73
01/10/2025 12:00	0.7	1.3	1	0.44	0.21954	0.73
01/10/2025 13:00	0.6	1.4	1	0.44	0.21924	0.73
01/10/2025 14:00	0.6	1.3	1	0.44	0.21918	0.73
01/10/2025 15:00	0.6	1.3	1	0.44	0.21948	0.73
01/10/2025 16:00	0.8	1.4	1	0.55	0.27258	0.91
01/10/2025 17:00	0.9	1.4	1	0.63	0.31320	1.04
01/10/2025 18:00	1.0	1.4	1	0.63	0.31314	1.04
01/10/2025 19:00	1.1	1.4	1	0.62	0.31206	1.04
01/10/2025 20:00	1.2	1.5	1	0.62	0.31164	1.04
01/10/2025 21:00	1.3	1.4	1	0.62	0.31044	1.03
01/10/2025 22:00	1.2	1.4	1	0.62	0.30906	1.03
01/10/2025 23:00	1.4	1.4	1	0.62	0.30804	1.03
Average/Sum#:	1.0	1.4	1	0.58	0.28743	0.96
Minimum:	0.6	1.3	1	0.44	0.21918	0.73
Maximum:	1.4	1.5	2	0.63	0.31320	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/11/2025 00:00	1.3	1.4	1	0.62	0.30858	1.03
01/11/2025 01:00	1.3	1.4	1	0.62	0.30846	1.03
01/11/2025 02:00	1.3	1.4	1	0.62	0.30852	1.03
01/11/2025 03:00	1.3	1.5	1	0.62	0.30864	1.03
01/11/2025 04:00	1.1	1.5	1	0.62	0.30906	1.03
01/11/2025 05:00	1.0	1.5	1	0.62	0.30960	1.03
01/11/2025 06:00	0.8	1.5	2	0.66	0.32958	1.10
01/11/2025 07:00	0.7	1.5	2	0.67	0.33480	1.12
01/11/2025 08:00	0.8	1.4	2	0.51	0.25416	0.85
01/11/2025 09:00	0.6	1.4	2	0.44	0.22128	0.74
01/11/2025 10:00	0.6	1.4	2	0.44	0.22098	0.74
01/11/2025 11:00	0.6	1.4	2	0.44	0.22056	0.74
01/11/2025 12:00	0.6	1.4	1	0.44	0.22026	0.73
01/11/2025 13:00	0.6	1.4	1	0.44	0.21996	0.73
01/11/2025 14:00	0.6	1.4	2	0.44	0.21984	0.73
01/11/2025 15:00	0.6	1.4	1	0.44	0.21978	0.73
01/11/2025 16:00	0.8	1.4	1	0.51	0.25272	0.84
01/11/2025 17:00	0.9	1.4	1	0.62	0.30852	1.03
01/11/2025 18:00	0.9	1.4	1	0.62	0.30870	1.03
01/11/2025 19:00	0.9	1.5	1	0.62	0.31056	1.04
01/11/2025 20:00	1.0	1.4	1	0.62	0.31098	1.04
01/11/2025 21:00	1.0	1.4	1	0.62	0.31224	1.04
01/11/2025 22:00	1.0	1.5	1	0.62	0.31122	1.04
01/11/2025 23:00	1.0	1.5	1	0.62	0.30792	1.03
Average/Sum#:	0.9	1.4	1	0.56	0.28071	0.94
Minimum:	0.6	1.4	1	0.44	0.21978	0.73
Maximum:	1.3	1.5	2	0.67	0.33480	1.12
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/12/2025 00:00	1.1	1.5	1	0.62	0.30798	1.03
01/12/2025 01:00	1.1	1.5	1	0.62	0.30894	1.03
01/12/2025 02:00	1.2	1.5	1	0.61	0.30720	1.02
01/12/2025 03:00	1.2	1.5	2	0.62	0.31062	1.04
01/12/2025 04:00	1.0	1.5	1	0.63	0.31344	1.04
01/12/2025 05:00	1.1	1.5	1	0.63	0.31566	1.05
01/12/2025 06:00	1.0	1.5	2	0.64	0.32172	1.07
01/12/2025 07:00	0.7	1.5	2	0.67	0.33396	1.11
01/12/2025 08:00	1.2	1.5	1	0.61	0.30744	1.02
01/12/2025 09:00	1.1	1.5	2	0.61	0.30732	1.02
01/12/2025 10:00	0.8	1.3	2	0.50	0.25038	0.83
01/12/2025 11:00	0.6	1.4	2	0.44	0.22056	0.74
01/12/2025 12:00	0.6	1.4	2	0.44	0.22080	0.74
01/12/2025 13:00	0.6	1.4	2	0.44	0.22128	0.74
01/12/2025 14:00	0.6	1.4	1	0.44	0.22134	0.74
01/12/2025 15:00	0.8	1.5	1	0.55	0.27432	0.91
01/12/2025 16:00	0.4	1.5	2	0.69	0.34572	1.15
01/12/2025 17:00	0.5	1.5	2	0.68	0.34038	1.13
01/12/2025 18:00	0.8	1.5	1	0.64	0.31992	1.07
01/12/2025 19:00	0.7	1.5	2	0.66	0.32802	1.09
01/12/2025 20:00	0.7	1.5	2	0.66	0.33072	1.10
01/12/2025 21:00	0.7	1.5	2	0.67	0.33384	1.11
01/12/2025 22:00	0.9	1.5	2	0.65	0.32544	1.08
01/12/2025 23:00	1.1	1.5	1	0.63	0.31290	1.04
Average/Sum#:	0.9	1.5	2	0.60	0.29916	1.00
Minimum:	0.4	1.3	1	0.44	0.22056	0.74
Maximum:	1.2	1.5	2	0.69	0.34572	1.15
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/13/2025 00:00	1.1	1.5	2	0.63	0.31326	1.04
01/13/2025 01:00	1.2	1.5	1	0.62	0.30906	1.03
01/13/2025 02:00	1.3	1.5	1	0.62	0.30798	1.03
01/13/2025 03:00	1.3	1.5	2	0.61	0.30732	1.02
01/13/2025 04:00	1.2	1.5	1	0.62	0.30774	1.03
01/13/2025 05:00	1.1	1.5	2	0.62	0.31044	1.03
01/13/2025 06:00	1.1	1.5	2	0.62	0.31128	1.04
01/13/2025 07:00	1.1	1.5	1	0.63	0.31416	1.05
01/13/2025 08:00	1.0	1.5	2	0.60	0.29940	1.00
01/13/2025 09:00	0.7	1.4	1	0.48	0.23958	0.80
01/13/2025 10:00	1.3	1.4	2	0.62	0.30966	1.03
01/13/2025 11:00	0.9	1.5	1	0.63	0.31332	1.04
01/13/2025 12:00	0.9	1.4	1	0.62	0.31092	1.04
01/13/2025 13:00	0.9	1.4	1	0.62	0.31068	1.04
01/13/2025 14:00	0.9	1.5	1	0.62	0.31062	1.04
01/13/2025 15:00	0.9	1.5	1	0.62	0.30912	1.03
01/13/2025 16:00	0.8	1.5	2	0.65	0.32472	1.08
01/13/2025 17:00	0.6	1.5	2	0.66	0.32922	1.10
01/13/2025 18:00	0.8	1.5	1	0.65	0.32334	1.08
01/13/2025 19:00	0.7	1.5	2	0.66	0.33060	1.10
01/13/2025 20:00	0.6	1.5	2	0.69	0.34320	1.14
01/13/2025 21:00	0.5	1.5	2	0.70	0.35160	1.17
01/13/2025 22:00	0.5	1.5	2	0.70	0.35244	1.17
01/13/2025 23:00	0.5	1.5	2	0.70	0.35058	1.17
Average/Sum#:	0.9	1.5	2	0.63	0.31626	1.05
Minimum:	0.5	1.4	1	0.48	0.23958	0.80
Maximum:	1.3	1.5	2	0.70	0.35244	1.17
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/14/2025 00:00	0.9	1.5	2	0.66	0.32754	1.09
01/14/2025 01:00	1.0	1.5	2	0.65	0.32604	1.09
01/14/2025 02:00	1.1	1.5	2	0.65	0.32700	1.09
01/14/2025 03:00	1.2	1.5	2	0.65	0.32568	1.09
01/14/2025 04:00	1.1	1.5	2	0.65	0.32586	1.09
01/14/2025 05:00	1.0	1.5	2	0.67	0.33558	1.12
01/14/2025 06:00	0.7	1.5	2	0.73	0.36306	1.21
01/14/2025 07:00	1.0	1.5	2	0.69	0.34320	1.14
01/14/2025 08:00	1.6	1.5	1	0.62	0.30954	1.03
01/14/2025 09:00	1.2	1.5	2	0.62	0.31104	1.04
01/14/2025 10:00	0.9	1.4	2	0.50	0.24966	0.83
01/14/2025 11:00	0.9	1.4	1	0.55	0.27558	0.92
01/14/2025 12:00	0.9	1.4	1	0.62	0.31158	1.04
01/14/2025 13:00	0.9	1.5	1	0.62	0.31170	1.04
01/14/2025 14:00	0.9	1.4	1	0.62	0.30906	1.03
01/14/2025 15:00	0.9	1.4	1	0.62	0.30768	1.03
01/14/2025 16:00	1.0	1.5	1	0.62	0.30960	1.03
01/14/2025 17:00	1.0	1.5	1	0.61	0.30720	1.02
01/14/2025 18:00	1.0	1.5	1	0.62	0.30804	1.03
01/14/2025 19:00	1.1	1.5	1	0.61	0.30624	1.02
01/14/2025 20:00	1.3	1.5	1	0.61	0.30516	1.02
01/14/2025 21:00	1.4	1.4	1	0.61	0.30456	1.02
01/14/2025 22:00	1.4	1.4	1	0.61	0.30474	1.02
01/14/2025 23:00	1.3	1.5	1	0.62	0.30858	1.03
Average/Sum#:	1.1	1.5	1	0.63	0.31308	1.04
Minimum:	0.7	1.4	1	0.50	0.24966	0.83
Maximum:	1.6	1.5	2	0.73	0.36306	1.21
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/15/2025 00:00	1.2	1.5	2	0.62	0.30828	1.03
01/15/2025 01:00	1.2	1.5	1	0.62	0.30852	1.03
01/15/2025 02:00	1.3	1.4	1	0.62	0.30804	1.03
01/15/2025 03:00	1.3	1.5	2	0.62	0.30750	1.03
01/15/2025 04:00	1.3	1.5	1	0.61	0.30720	1.02
01/15/2025 05:00	1.3	1.5	1	0.62	0.30768	1.03
01/15/2025 06:00	1.4	1.4	1	0.62	0.30786	1.03
01/15/2025 07:00	1.4	1.4	1	0.62	0.30798	1.03
01/15/2025 08:00	1.5	1.5	1	0.61	0.30636	1.02
01/15/2025 09:00	1.0	1.4	2	0.47	0.23742	0.79
01/15/2025 10:00	0.8	1.4	2	0.44	0.22098	0.74
01/15/2025 11:00	0.7	1.4	2	0.45	0.22350	0.75
01/15/2025 12:00	0.7	1.4	2	0.45	0.22416	0.75
01/15/2025 13:00	0.7	1.3	2	0.45	0.22428	0.75
01/15/2025 14:00	0.7	1.4	2	0.45	0.22308	0.74
01/15/2025 15:00	1.1	1.4	1	0.52	0.25956	0.87
01/15/2025 16:00	0.9	1.5	1	0.63	0.31554	1.05
01/15/2025 17:00	1.0	1.4	1	0.62	0.31056	1.04
01/15/2025 18:00	1.1	1.5	1	0.62	0.30918	1.03
01/15/2025 19:00	1.2	1.4	1	0.62	0.30822	1.03
01/15/2025 20:00	1.2	1.4	1	0.63	0.31428	1.05
01/15/2025 21:00	1.3	1.5	1	0.62	0.31224	1.04
01/15/2025 22:00	1.3	1.5	1	0.62	0.31134	1.04
01/15/2025 23:00	1.3	1.4	1	0.62	0.31086	1.04
Average/Sum#:	1.1	1.4	1	0.57	0.28644	0.96
Minimum:	0.7	1.3	1	0.44	0.22098	0.74
Maximum:	1.5	1.5	2	0.63	0.31554	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/16/2025 00:00	1.5	1.5	1	0.62	0.30990	1.03
01/16/2025 01:00	1.4	1.5	1	0.62	0.30834	1.03
01/16/2025 02:00	1.6	1.5	1	0.62	0.30804	1.03
01/16/2025 03:00	1.7	1.5	1	0.62	0.30756	1.03
01/16/2025 04:00	1.3	1.5	2	0.62	0.31020	1.03
01/16/2025 05:00	1.3	1.5	2	0.62	0.31206	1.04
01/16/2025 06:00	1.3	1.5	2	0.63	0.31506	1.05
01/16/2025 07:00	1.5	1.5	1	0.62	0.31176	1.04
01/16/2025 08:00	1.5	1.5	1	0.62	0.31038	1.03
01/16/2025 09:00	1.1	1.3	2	0.51	0.25548	0.85
01/16/2025 10:00	0.9	1.5	2	0.45	0.22344	0.74
01/16/2025 11:00	0.8	1.4	2	0.45	0.22302	0.74
01/16/2025 12:00	0.7	1.4	1	0.45	0.22302	0.74
01/16/2025 13:00	0.7	1.4	1	0.45	0.22254	0.74
01/16/2025 14:00	0.7	1.5	1	0.44	0.22242	0.74
01/16/2025 15:00	1.3	1.4	1	0.56	0.28122	0.94
01/16/2025 16:00	1.0	1.4	1	0.62	0.31014	1.03
01/16/2025 17:00	1.0	1.4	1	0.62	0.31026	1.03
01/16/2025 18:00	1.1	1.4	1	0.62	0.30918	1.03
01/16/2025 19:00	1.2	1.4	1	0.62	0.30870	1.03
01/16/2025 20:00	1.3	1.4	1	0.62	0.31098	1.04
01/16/2025 21:00	1.3	1.5	1	0.62	0.31236	1.04
01/16/2025 22:00	1.3	1.5	1	0.62	0.31236	1.04
01/16/2025 23:00	1.2	1.5	1	0.62	0.31188	1.04
Average/Sum#:	1.2	1.5	1	0.58	0.28876	0.96
Minimum:	0.7	1.3	1	0.44	0.22242	0.74
Maximum:	1.7	1.5	2	0.63	0.31506	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/17/2025 00:00	1.2	1.5	1	0.62	0.31140	1.04
01/17/2025 01:00	1.2	1.5	2	0.62	0.31110	1.04
01/17/2025 02:00	1.2	1.4	1	0.62	0.31128	1.04
01/17/2025 03:00	1.2	1.5	2	0.62	0.31098	1.04
01/17/2025 04:00	1.2	1.5	1	0.62	0.31056	1.04
01/17/2025 05:00	1.2	1.5	2	0.62	0.31056	1.04
01/17/2025 06:00	1.3	1.5	2	0.62	0.30996	1.03
01/17/2025 07:00	1.4	1.5	1	0.62	0.30840	1.03
01/17/2025 08:00	1.3	1.5	2	0.62	0.31134	1.04
01/17/2025 09:00	1.2	1.4	2	0.63	0.31338	1.04
01/17/2025 10:00	1.1	1.5	2	0.63	0.31602	1.05
01/17/2025 11:00	1.1	1.5	1	0.63	0.31572	1.05
01/17/2025 12:00	1.0	1.4	1	0.51	0.25314	0.84
01/17/2025 13:00	0.8	1.4	2	0.45	0.22332	0.74
01/17/2025 14:00	0.8	1.4	1	0.45	0.22338	0.74
01/17/2025 15:00	0.8	1.4	1	0.45	0.22290	0.74
01/17/2025 16:00	1.1	1.4	1	0.58	0.28878	0.96
01/17/2025 17:00	1.0	1.4	1	0.63	0.31482	1.05
01/17/2025 18:00	1.1	1.4	1	0.63	0.31254	1.04
01/17/2025 19:00	1.2	1.4	1	0.62	0.31098	1.04
01/17/2025 20:00	1.3	1.4	1	0.62	0.31002	1.03
01/17/2025 21:00	1.4	1.4	1	0.62	0.31020	1.03
01/17/2025 22:00	1.4	1.4	1	0.62	0.30978	1.03
01/17/2025 23:00	1.6	1.4	1	0.62	0.30828	1.03
Average/Sum#:	1.2	1.4	1	0.59	0.29704	0.99
Minimum:	0.8	1.4	1	0.45	0.22290	0.74
Maximum:	1.6	1.5	2	0.63	0.31602	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/18/2025 00:00	1.5	1.5	1	0.62	0.30762	1.03
01/18/2025 01:00	1.4	1.5	1	0.62	0.31026	1.03
01/18/2025 02:00	1.3	1.6	1	0.62	0.31074	1.04
01/18/2025 03:00	1.4	1.5	2	0.62	0.31044	1.03
01/18/2025 04:00	1.4	1.5	2	0.62	0.30948	1.03
01/18/2025 05:00	1.3	1.5	1	0.62	0.31014	1.03
01/18/2025 06:00	1.4	1.5	1	0.62	0.31062	1.04
01/18/2025 07:00	1.4	1.5	1	0.62	0.30972	1.03
01/18/2025 08:00	1.2	1.4	2	0.60	0.30012	1.00
01/18/2025 09:00	0.8	1.3	2	0.45	0.22386	0.75
01/18/2025 10:00	0.8	1.4	2	0.44	0.22236	0.74
01/18/2025 11:00	0.8	1.4	2	0.44	0.22224	0.74
01/18/2025 12:00	0.8	1.4	2	0.44	0.22224	0.74
01/18/2025 13:00	0.8	1.4	2	0.44	0.22236	0.74
01/18/2025 14:00	0.7	1.4	2	0.44	0.22236	0.74
01/18/2025 15:00	1.3	1.4	1	0.52	0.25968	0.87
01/18/2025 16:00	1.1	1.5	1	0.62	0.30930	1.03
01/18/2025 17:00	1.1	1.5	1	0.62	0.30846	1.03
01/18/2025 18:00	1.1	1.5	1	0.63	0.31278	1.04
01/18/2025 19:00	1.2	1.5	1	0.62	0.31038	1.03
01/18/2025 20:00	1.3	1.4	2	0.62	0.30942	1.03
01/18/2025 21:00	1.3	1.4	1	0.62	0.30894	1.03
01/18/2025 22:00	1.3	1.5	2	0.62	0.30858	1.03
01/18/2025 23:00	1.4	1.4	1	0.62	0.30804	1.03
Average/Sum#:	1.2	1.5	1	0.57	0.28542	0.95
Minimum:	0.7	1.3	1	0.44	0.22224	0.74
Maximum:	1.5	1.6	2	0.63	0.31278	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/19/2025 00:00	1.4	1.4	1	0.62	0.30804	1.03
01/19/2025 01:00	1.4	1.4	1	0.62	0.30774	1.03
01/19/2025 02:00	1.3	1.5	1	0.62	0.30774	1.03
01/19/2025 03:00	1.5	1.5	2	0.62	0.30846	1.03
01/19/2025 04:00	1.4	1.4	1	0.62	0.30858	1.03
01/19/2025 05:00	1.3	1.5	2	0.63	0.31446	1.05
01/19/2025 06:00	1.2	1.5	2	0.65	0.32508	1.08
01/19/2025 07:00	1.1	1.5	2	0.66	0.32814	1.09
01/19/2025 08:00	1.4	1.5	1	0.62	0.31134	1.04
01/19/2025 09:00	1.1	1.4	2	0.56	0.27810	0.93
01/19/2025 10:00	0.8	1.4	2	0.45	0.22416	0.75
01/19/2025 11:00	0.8	1.4	2	0.45	0.22422	0.75
01/19/2025 12:00	0.8	1.4	2	0.45	0.22422	0.75
01/19/2025 13:00	0.8	1.3	2	0.45	0.22434	0.75
01/19/2025 14:00	0.8	1.4	1	0.45	0.22446	0.75
01/19/2025 15:00	0.9	1.4	1	0.51	0.25692	0.86
01/19/2025 16:00	0.8	1.4	1	0.65	0.32364	1.08
01/19/2025 17:00	1.0	1.4	1	0.63	0.31560	1.05
01/19/2025 18:00	1.2	1.4	1	0.62	0.31164	1.04
01/19/2025 19:00	1.2	1.5	1	0.62	0.31026	1.03
01/19/2025 20:00	1.3	1.4	1	0.62	0.30942	1.03
01/19/2025 21:00	1.4	1.4	1	0.62	0.31032	1.03
01/19/2025 22:00	1.9	1.5	1	0.63	0.31566	1.05
01/19/2025 23:00	1.6	1.5	1	0.62	0.30780	1.03
Average/Sum#:	1.2	1.4	1	0.58	0.29085	0.97
Minimum:	0.8	1.3	1	0.45	0.22416	0.75
Maximum:	1.9	1.5	2	0.66	0.32814	1.09
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/20/2025 00:00	1.3	1.5	2	0.64	0.31794	1.06
01/20/2025 01:00	1.3	1.5	2	0.64	0.31890	1.06
01/20/2025 02:00	1.2	1.5	2	0.65	0.32748	1.09
01/20/2025 03:00	1.2	1.5	2	0.65	0.32574	1.09
01/20/2025 04:00	1.2	1.5	2	0.63	0.31722	1.06
01/20/2025 05:00	1.1	1.5	2	0.64	0.31890	1.06
01/20/2025 06:00	1.1	1.5	2	0.65	0.32352	1.08
01/20/2025 07:00	1.0	1.5	2	0.65	0.32508	1.08
01/20/2025 08:00	1.2	1.5	2	0.62	0.31020	1.03
01/20/2025 09:00	1.1	1.5	2	0.63	0.31326	1.04
01/20/2025 10:00	1.1	1.5	2	0.62	0.31116	1.04
01/20/2025 11:00	1.0	1.4	2	0.62	0.30984	1.03
01/20/2025 12:00	1.0	1.5	1	0.59	0.29412	0.98
01/20/2025 13:00	0.7	1.3	1	0.44	0.22140	0.74
01/20/2025 14:00	0.7	1.3	1	0.44	0.22140	0.74
01/20/2025 15:00	0.9	1.4	1	0.51	0.25560	0.85
01/20/2025 16:00	0.7	1.5	2	0.66	0.32844	1.09
01/20/2025 17:00	0.5	1.5	2	0.68	0.33996	1.13
01/20/2025 18:00	0.7	1.5	2	0.67	0.33300	1.11
01/20/2025 19:00	0.7	1.5	2	0.67	0.33678	1.12
01/20/2025 20:00	0.6	1.5	2	0.69	0.34278	1.14
01/20/2025 21:00	0.8	1.5	2	0.67	0.33582	1.12
01/20/2025 22:00	1.0	1.5	2	0.65	0.32610	1.09
01/20/2025 23:00	1.1	1.4	2	0.63	0.31572	1.05
Average/Sum#:	1.0	1.5	2	0.62	0.31127	1.04
Minimum:	0.5	1.3	1	0.44	0.22140	0.74
Maximum:	1.3	1.5	2	0.69	0.34278	1.14
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/21/2025 00:00	1.0	1.5	2	0.66	0.32820	1.09
01/21/2025 01:00	1.1	1.5	2	0.64	0.32076	1.07
01/21/2025 02:00	0.7	1.5	2	0.70	0.34758	1.16
01/21/2025 03:00	1.1	1.5	2	0.64	0.32094	1.07
01/21/2025 04:00	1.2	1.5	2	0.63	0.31590	1.05
01/21/2025 05:00	1.1	1.5	2	0.65	0.32346	1.08
01/21/2025 06:00	1.0	1.5	2	0.67	0.33336	1.11
01/21/2025 07:00	0.9	1.5	2	0.66	0.33018	1.10
01/21/2025 08:00	1.4	1.5	1	0.62	0.30918	1.03
01/21/2025 09:00	1.3	1.5	2	0.62	0.30996	1.03
01/21/2025 10:00	1.0	1.4	2	0.60	0.30030	1.00
01/21/2025 11:00	0.7	1.3	2	0.45	0.22506	0.75
01/21/2025 12:00	0.7	1.4	2	0.45	0.22434	0.75
01/21/2025 13:00	0.7	1.4	2	0.45	0.22374	0.75
01/21/2025 14:00	0.7	1.4	2	0.44	0.22218	0.74
01/21/2025 15:00	0.9	1.4	1	0.51	0.25524	0.85
01/21/2025 16:00	0.9	1.4	1	0.64	0.32142	1.07
01/21/2025 17:00	0.7	1.5	2	0.67	0.33336	1.11
01/21/2025 18:00	0.7	1.5	2	0.67	0.33408	1.11
01/21/2025 19:00	1.0	1.5	2	0.65	0.32364	1.08
01/21/2025 20:00	1.0	1.5	2	0.65	0.32736	1.09
01/21/2025 21:00	1.1	1.5	2	0.65	0.32418	1.08
01/21/2025 22:00	1.1	1.5	2	0.64	0.32064	1.07
01/21/2025 23:00	1.2	1.5	2	0.63	0.31560	1.05
Average/Sum#:	1.0	1.5	2	0.61	0.30378	1.01
Minimum:	0.7	1.3	1	0.44	0.22218	0.74
Maximum:	1.4	1.5	2	0.70	0.34758	1.16
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/22/2025 00:00	1.3	1.5	1	0.62	0.31164	1.04
01/22/2025 01:00	1.4	1.5	1	0.62	0.30906	1.03
01/22/2025 02:00	1.4	1.4	1	0.62	0.30960	1.03
01/22/2025 03:00	1.3	1.5	2	0.62	0.31128	1.04
01/22/2025 04:00	1.2	1.5	1	0.63	0.31254	1.04
01/22/2025 05:00	1.0	1.5	2	0.66	0.33222	1.11
01/22/2025 06:00	0.4	1.6	2	0.77	0.38604	1.29
01/22/2025 07:00	0.3	1.5	3	0.81	0.40470	1.35
01/22/2025 08:00	1.2	1.4	1	0.63	0.31710	1.06
01/22/2025 09:00	1.4	1.5	2	0.62	0.30750	1.03
01/22/2025 10:00	1.1	1.5	2	0.62	0.31194	1.04
01/22/2025 11:00	1.1	1.5	2	0.63	0.31542	1.05
01/22/2025 12:00	1.0	1.3	1	0.55	0.27420	0.91
01/22/2025 13:00	0.8	1.4	2	0.44	0.22242	0.74
01/22/2025 14:00	0.8	1.4	1	0.45	0.22344	0.74
01/22/2025 15:00	1.2	1.4	1	0.57	0.28326	0.94
01/22/2025 16:00	0.9	1.5	1	0.64	0.31758	1.06
01/22/2025 17:00	1.0	1.5	1	0.63	0.31536	1.05
01/22/2025 18:00	1.1	1.5	1	0.62	0.31188	1.04
01/22/2025 19:00	1.0	1.5	2	0.64	0.32112	1.07
01/22/2025 20:00	1.2	1.5	2	0.64	0.32028	1.07
01/22/2025 21:00	1.2	1.5	2	0.64	0.32094	1.07
01/22/2025 22:00	1.1	1.5	2	0.66	0.33024	1.10
01/22/2025 23:00	1.1	1.5	2	0.65	0.32550	1.09
Average/Sum#:	1.1	1.5	2	0.62	0.31230	1.04
Minimum:	0.3	1.3	1	0.44	0.22242	0.74
Maximum:	1.4	1.6	3	0.81	0.40470	1.35
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/23/2025 00:00	1.3	1.5	2	0.62	0.31176	1.04
01/23/2025 01:00	1.3	1.5	2	0.62	0.30972	1.03
01/23/2025 02:00	1.3	1.4	1	0.63	0.31260	1.04
01/23/2025 03:00	1.4	1.5	2	0.63	0.31374	1.05
01/23/2025 04:00	1.3	1.5	2	0.64	0.32208	1.07
01/23/2025 05:00	1.1	1.5	2	0.66	0.32754	1.09
01/23/2025 06:00	1.2	1.5	2	0.65	0.32616	1.09
01/23/2025 07:00	1.2	1.5	2	0.65	0.32298	1.08
01/23/2025 08:00	1.3	1.5	2	0.62	0.31212	1.04
01/23/2025 09:00	1.2	1.5	2	0.62	0.31182	1.04
01/23/2025 10:00	1.1	1.5	2	0.63	0.31374	1.05
01/23/2025 11:00	1.1	1.5	2	0.63	0.31512	1.05
01/23/2025 12:00	0.9	1.4	2	0.60	0.29994	1.00
01/23/2025 13:00	0.8	1.3	1	0.45	0.22398	0.75
01/23/2025 14:00	0.8	1.3	1	0.45	0.22344	0.74
01/23/2025 15:00	1.0	1.4	1	0.51	0.25560	0.85
01/23/2025 16:00	0.9	1.4	1	0.64	0.31800	1.06
01/23/2025 17:00	1.1	1.4	1	0.63	0.31464	1.05
01/23/2025 18:00	1.2	1.4	1	0.63	0.31308	1.04
01/23/2025 19:00	1.3	1.5	1	0.62	0.31242	1.04
01/23/2025 20:00	1.4	1.4	1	0.62	0.31152	1.04
01/23/2025 21:00	1.3	1.4	1	0.62	0.31176	1.04
01/23/2025 22:00	1.4	1.5	1	0.62	0.31122	1.04
01/23/2025 23:00	1.4	1.4	2	0.62	0.31050	1.04
Average/Sum#:	1.2	1.4	2	0.61	0.30440	1.02
Minimum:	0.8	1.3	1	0.45	0.22344	0.74
Maximum:	1.4	1.5	2	0.66	0.32754	1.09
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/24/2025 00:00	1.4	1.5	1	0.63	0.31266	1.04
01/24/2025 01:00	1.3	1.5	2	0.63	0.31560	1.05
01/24/2025 02:00	1.3	1.5	2	0.63	0.31548	1.05
01/24/2025 03:00	1.3	1.5	2	0.63	0.31488	1.05
01/24/2025 04:00	1.3	1.5	2	0.63	0.31434	1.05
01/24/2025 05:00	1.3	1.5	2	0.63	0.31398	1.05
01/24/2025 06:00	1.3	1.5	2	0.63	0.31428	1.05
01/24/2025 07:00	1.2	1.5	2	0.64	0.31974	1.07
01/24/2025 08:00	1.3	1.5	2	0.63	0.31416	1.05
01/24/2025 09:00	1.3	1.5	2	0.63	0.31446	1.05
01/24/2025 10:00	1.2	1.5	2	0.63	0.31656	1.06
01/24/2025 11:00	1.1	1.5	2	0.64	0.31866	1.06
01/24/2025 12:00	1.0	1.5	2	0.64	0.31944	1.06
01/24/2025 13:00	1.0	1.5	2	0.64	0.31782	1.06
01/24/2025 14:00	0.9	1.5	2	0.63	0.31716	1.06
01/24/2025 15:00	0.9	1.5	2	0.64	0.31764	1.06
01/24/2025 16:00	0.9	1.4	2	0.64	0.31842	1.06
01/24/2025 17:00	1.0	1.4	2	0.63	0.31590	1.05
01/24/2025 18:00	1.1	1.4	2	0.63	0.31518	1.05
01/24/2025 19:00	1.3	1.5	2	0.63	0.31464	1.05
01/24/2025 20:00	1.2	1.5	2	0.63	0.31542	1.05
01/24/2025 21:00	1.3	1.5	2	0.63	0.31446	1.05
01/24/2025 22:00	1.3	1.4	2	0.63	0.31410	1.05
01/24/2025 23:00	1.3	1.4	2	0.63	0.31446	1.05
Average/Sum#:	1.2	1.5	2	0.63	0.31581	1.05
Minimum:	0.9	1.4	1	0.63	0.31266	1.04
Maximum:	1.4	1.5	2	0.64	0.31974	1.07
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/25/2025 00:00	1.3	1.4	2	0.63	0.31428	1.05
01/25/2025 01:00	1.3	1.5	2	0.63	0.31530	1.05
01/25/2025 02:00	1.3	1.4	2	0.62	0.31206	1.04
01/25/2025 03:00	1.3	1.5	2	0.63	0.31494	1.05
01/25/2025 04:00	1.2	1.5	2	0.64	0.31776	1.06
01/25/2025 05:00	1.2	1.5	2	0.64	0.31878	1.06
01/25/2025 06:00	1.2	1.5	2	0.64	0.31860	1.06
01/25/2025 07:00	0.7	1.5	2	0.70	0.34950	1.17
01/25/2025 08:00	0.5	1.5	2	0.75	0.37494	1.25
01/25/2025 09:00	1.3	1.4	2	0.62	0.31092	1.04
01/25/2025 10:00	1.2	1.5	2	0.62	0.31140	1.04
01/25/2025 11:00	1.1	1.4	2	0.62	0.31212	1.04
01/25/2025 12:00	1.0	1.5	2	0.62	0.31212	1.04
01/25/2025 13:00	1.0	1.5	2	0.63	0.31296	1.04
01/25/2025 14:00	1.0	1.4	2	0.63	0.31524	1.05
01/25/2025 15:00	0.9	1.5	2	0.64	0.32130	1.07
01/25/2025 16:00	0.8	1.5	2	0.66	0.32898	1.10
01/25/2025 17:00	0.7	1.5	2	0.67	0.33552	1.12
01/25/2025 18:00	0.9	1.5	2	0.65	0.32586	1.09
01/25/2025 19:00	0.9	1.5	2	0.65	0.32514	1.08
01/25/2025 20:00	0.8	1.5	2	0.67	0.33492	1.12
01/25/2025 21:00	0.6	1.5	2	0.69	0.34674	1.16
01/25/2025 22:00	0.6	1.5	2	0.69	0.34602	1.15
01/25/2025 23:00	0.6	1.5	2	0.69	0.34368	1.15
Average/Sum#:	1.0	1.5	2	0.65	0.32580	1.09
Minimum:	0.5	1.4	2	0.62	0.31092	1.04
Maximum:	1.3	1.5	2	0.75	0.37494	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/26/2025 00:00	0.9	1.5	2	0.66	0.33204	1.11
01/26/2025 01:00	1.1	1.5	2	0.65	0.32328	1.08
01/26/2025 02:00	1.2	1.5	1	0.63	0.31344	1.04
01/26/2025 03:00	1.3	1.5	2	0.63	0.31404	1.05
01/26/2025 04:00	1.3	1.4	2	0.63	0.31602	1.05
01/26/2025 05:00	1.2	1.5	2	0.63	0.31566	1.05
01/26/2025 06:00	1.1	1.5	2	0.65	0.32334	1.08
01/26/2025 07:00	0.6	1.5	2	0.69	0.34686	1.16
01/26/2025 08:00	1.1	1.5	2	0.65	0.32292	1.08
01/26/2025 09:00	1.2	1.5	2	0.63	0.31362	1.05
01/26/2025 10:00	1.1	1.5	2	0.63	0.31416	1.05
01/26/2025 11:00	1.1	1.5	2	0.63	0.31638	1.05
01/26/2025 12:00	0.9	1.5	2	0.64	0.31812	1.06
01/26/2025 13:00	0.9	1.5	2	0.64	0.31836	1.06
01/26/2025 14:00	0.9	1.5	2	0.64	0.31752	1.06
01/26/2025 15:00	0.9	1.5	2	0.63	0.31398	1.05
01/26/2025 16:00	0.9	1.5	2	0.64	0.31836	1.06
01/26/2025 17:00	0.9	1.5	2	0.64	0.32244	1.07
01/26/2025 18:00	0.7	1.5	2	0.67	0.33552	1.12
01/26/2025 19:00	0.7	1.5	2	0.67	0.33552	1.12
01/26/2025 20:00	0.8	1.5	2	0.67	0.33390	1.11
01/26/2025 21:00	0.9	1.5	2	0.65	0.32586	1.09
01/26/2025 22:00	1.1	1.5	2	0.63	0.31344	1.04
01/26/2025 23:00	1.1	1.5	2	0.63	0.31452	1.05
Average/Sum#:	1.0	1.5	2	0.64	0.32164	1.07
Minimum:	0.6	1.4	1	0.63	0.31344	1.04
Maximum:	1.3	1.5	2	0.69	0.34686	1.16
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/27/2025 00:00	1.1	1.5	2	0.63	0.31638	1.05
01/27/2025 01:00	1.2	1.5	2	0.63	0.31578	1.05
01/27/2025 02:00	1.1	1.5	2	0.63	0.31416	1.05
01/27/2025 03:00	1.2	1.5	2	0.63	0.31518	1.05
01/27/2025 04:00	1.1	1.5	2	0.63	0.31398	1.05
01/27/2025 05:00	0.9	1.5	2	0.67	0.33270	1.11
01/27/2025 06:00	0.7	1.5	2	0.70	0.35016	1.17
01/27/2025 07:00	0.5	1.5	2	0.72	0.35940	1.20
01/27/2025 08:00	0.9	1.5	2	0.67	0.33552	1.12
01/27/2025 09:00	1.1	1.5	2	0.63	0.31506	1.05
01/27/2025 10:00	1.1	1.5	2	0.63	0.31596	1.05
01/27/2025 11:00	0.9	1.5	2	0.64	0.31878	1.06
01/27/2025 12:00	0.9	1.5	2	0.64	0.31752	1.06
01/27/2025 13:00	0.8	1.5	2	0.64	0.31842	1.06
01/27/2025 14:00	0.8	1.5	2	0.64	0.31788	1.06
01/27/2025 15:00	0.8	1.5	2	0.64	0.31800	1.06
01/27/2025 16:00	0.8	1.5	2	0.65	0.32292	1.08
01/27/2025 17:00	0.6	1.5	2	0.66	0.32892	1.10
01/27/2025 18:00	1.0	1.5	2	0.64	0.31884	1.06
01/27/2025 19:00	0.8	1.5	2	0.66	0.33042	1.10
01/27/2025 20:00	0.8	1.5	2	0.67	0.33300	1.11
01/27/2025 21:00	0.8	1.5	2	0.66	0.33246	1.11
01/27/2025 22:00	0.8	1.5	2	0.67	0.33270	1.11
01/27/2025 23:00	0.9	1.5	2	0.66	0.32916	1.10
Average/Sum#:	0.9	1.5	2	0.65	0.32514	1.08
Minimum:	0.5	1.5	2	0.63	0.31398	1.05
Maximum:	1.2	1.5	2	0.72	0.35940	1.20
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/28/2025 00:00	1.2	1.5	2	0.62	0.31116	1.04
01/28/2025 01:00	1.3	1.5	2	0.62	0.30972	1.03
01/28/2025 02:00	1.3	1.5	2	0.63	0.31254	1.04
01/28/2025 03:00	1.3	1.5	2	0.63	0.31410	1.05
01/28/2025 04:00	1.2	1.5	2	0.63	0.31308	1.04
01/28/2025 05:00	1.2	1.5	2	0.64	0.32052	1.07
01/28/2025 06:00	1.1	1.5	2	0.66	0.33126	1.10
01/28/2025 07:00	1.3	1.5	2	0.63	0.31476	1.05
01/28/2025 08:00	1.3	1.5	2	0.63	0.31260	1.04
01/28/2025 09:00	1.3	1.5	2	0.62	0.31134	1.04
01/28/2025 10:00	1.2	1.5	2	0.62	0.30888	1.03
01/28/2025 11:00	1.1	1.4	2	0.62	0.30876	1.03
01/28/2025 12:00	1.1	1.5	2	0.62	0.31032	1.03
01/28/2025 13:00	1.1	1.4	2	0.62	0.31158	1.04
01/28/2025 14:00	1.2	1.4	1	0.62	0.30948	1.03
01/28/2025 15:00	1.1	1.4	1	0.62	0.30930	1.03
01/28/2025 16:00	1.1	1.5	1	0.62	0.31098	1.04
01/28/2025 17:00	1.1	1.5	1	0.62	0.31074	1.04
01/28/2025 18:00	1.2	1.5	2	0.63	0.31398	1.05
01/28/2025 19:00	1.3	1.5	2	0.62	0.31068	1.04
01/28/2025 20:00	1.3	1.5	2	0.62	0.31212	1.04
01/28/2025 21:00	1.4	1.5	2	0.62	0.31206	1.04
01/28/2025 22:00	1.4	1.5	2	0.62	0.31158	1.04
01/28/2025 23:00	1.3	1.5	2	0.62	0.31068	1.04
Average/Sum#:	1.2	1.5	2	0.63	0.31259	1.04
Minimum:	1.1	1.4	1	0.62	0.30876	1.03
Maximum:	1.4	1.5	2	0.66	0.33126	1.10
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/29/2025 00:00	1.3	1.5	2	0.62	0.31104	1.04
01/29/2025 01:00	1.3	1.5	2	0.62	0.31170	1.04
01/29/2025 02:00	1.2	1.5	2	0.62	0.31224	1.04
01/29/2025 03:00	1.3	1.5	2	0.63	0.31266	1.04
01/29/2025 04:00	1.3	1.5	2	0.63	0.31290	1.04
01/29/2025 05:00	1.3	1.5	2	0.63	0.31602	1.05
01/29/2025 06:00	1.2	1.5	2	0.64	0.31878	1.06
01/29/2025 07:00	1.1	1.5	2	0.65	0.32460	1.08
01/29/2025 08:00	1.2	1.5	2	0.64	0.31932	1.06
01/29/2025 09:00	1.2	1.5	2	0.63	0.31452	1.05
01/29/2025 10:00	1.1	1.5	2	0.63	0.31734	1.06
01/29/2025 11:00	1.1	1.5	2	0.63	0.31584	1.05
01/29/2025 12:00	1.1	1.4	2	0.63	0.31308	1.04
01/29/2025 13:00	1.0	1.5	2	0.63	0.31368	1.05
01/29/2025 14:00	1.0	1.5	2	0.63	0.31380	1.05
01/29/2025 15:00	1.0	1.4	2	0.63	0.31410	1.05
01/29/2025 16:00	1.0	1.5	2	0.64	0.31794	1.06
01/29/2025 17:00	0.9	1.5	2	0.64	0.32154	1.07
01/29/2025 18:00	1.1	1.5	2	0.63	0.31722	1.06
01/29/2025 19:00	1.2	1.4	2	0.62	0.31212	1.04
01/29/2025 20:00	1.2	1.5	2	0.62	0.31224	1.04
01/29/2025 21:00	1.2	1.4	2	0.62	0.31140	1.04
01/29/2025 22:00	1.4	1.4	2	0.62	0.30924	1.03
01/29/2025 23:00	1.4	1.5	2	0.62	0.30990	1.03
Average/Sum#:	1.2	1.5	2	0.63	0.31472	1.05
Minimum:	0.9	1.4	2	0.62	0.30924	1.03
Maximum:	1.4	1.5	2	0.65	0.32460	1.08
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/30/2025 00:00	1.4	1.4	2	0.62	0.31002	1.03
01/30/2025 01:00	1.4	1.5	2	0.62	0.30960	1.03
01/30/2025 02:00	1.4	1.4	1	0.62	0.30930	1.03
01/30/2025 03:00	1.5	1.5	2	0.62	0.30888	1.03
01/30/2025 04:00	1.4	1.5	2	0.62	0.30900	1.03
01/30/2025 05:00	1.4	1.5	2	0.62	0.30930	1.03
01/30/2025 06:00	1.3	1.5	2	0.64	0.31776	1.06
01/30/2025 07:00	1.4	1.5	2	0.63	0.31542	1.05
01/30/2025 08:00	1.3	1.5	2	0.63	0.31284	1.04
01/30/2025 09:00	1.2	1.5	2	0.65	0.32550	1.09
01/30/2025 10:00	0.7	1.5	2	0.68	0.34152	1.14
01/30/2025 11:00	0.6	1.5	2	0.68	0.34224	1.14
01/30/2025 12:00	0.8	1.5	2	0.61	0.30468	1.02
01/30/2025 13:00	1.5	1.2	1	0.57	0.28362	0.95
01/30/2025 14:00	1.0	1.4	1	0.62	0.30870	1.03
01/30/2025 15:00	1.0	1.4	1	0.62	0.31014	1.03
01/30/2025 16:00	0.9	1.4	1	0.62	0.30834	1.03
01/30/2025 17:00	1.0	1.4	1	0.62	0.31026	1.03
01/30/2025 18:00	0.9	1.5	1	0.63	0.31344	1.04
01/30/2025 19:00	0.9	1.4	2	0.64	0.31764	1.06
01/30/2025 20:00	0.9	1.4	2	0.64	0.32130	1.07
01/30/2025 21:00	1.0	1.4	2	0.64	0.31920	1.06
01/30/2025 22:00	1.0	1.5	2	0.64	0.31866	1.06
01/30/2025 23:00	1.1	1.4	1	0.62	0.31080	1.04
Average/Sum#:	1.1	1.4	2	0.63	0.31409	1.05
Minimum:	0.6	1.2	1	0.57	0.28362	0.95
Maximum:	1.5	1.5	2	0.68	0.34224	1.14
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
01/31/2025 00:00	1.1	1.5	1	0.62	0.30870	1.03
01/31/2025 01:00	1.1	1.5	1	0.62	0.30876	1.03
01/31/2025 02:00	1.1	1.4	1	0.62	0.30882	1.03
01/31/2025 03:00	1.1	1.5	2	0.62	0.30924	1.03
01/31/2025 04:00	1.1	1.4	1	0.62	0.31080	1.04
01/31/2025 05:00	0.9	1.5	2	0.65	0.32262	1.08
01/31/2025 06:00	0.5	1.5	2	0.70	0.35106	1.17
01/31/2025 07:00	0.7	1.5	2	0.66	0.33240	1.11
01/31/2025 08:00	0.7	1.5	2	0.67	0.33684	1.12
01/31/2025 09:00	0.3	1.5	2	0.75	0.37380	1.25
01/31/2025 10:00	0.1	1.5	2	0.76	0.37884	1.26
01/31/2025 11:00	0.8	1.4	1	0.65	0.32670	1.09
01/31/2025 12:00	1.0	1.4	1	0.62	0.31014	1.03
01/31/2025 13:00	0.9	1.5	1	0.63	0.31332	1.04
01/31/2025 14:00	1.0	1.5	2	0.63	0.31464	1.05
01/31/2025 15:00	1.0	1.5	2	0.63	0.31350	1.05
01/31/2025 16:00	0.9	1.4	2	0.64	0.32052	1.07
01/31/2025 17:00	1.0	1.4	1	0.62	0.31134	1.04
01/31/2025 18:00	0.9	1.5	1	0.62	0.31086	1.04
01/31/2025 19:00	0.9	1.5	1	0.62	0.31146	1.04
01/31/2025 20:00	1.0	1.5	1	0.62	0.31146	1.04
01/31/2025 21:00	1.0	1.4	1	0.62	0.31152	1.04
01/31/2025 22:00	0.9	1.5	1	0.62	0.31164	1.04
01/31/2025 23:00	0.9	1.4	1	0.62	0.31194	1.04
Average/Sum#:	0.9	1.5	1	0.64	0.32171	1.07
Minimum:	0.1	1.4	1	0.62	0.30870	1.03
Maximum:	1.1	1.5	2	0.76	0.37884	1.26
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/01/2025 00:00	0.9	1.4	1	0.62	0.31212	1.04
02/01/2025 01:00	0.9	1.4	1	0.62	0.31200	1.04
02/01/2025 02:00	1.0	1.4	1	0.62	0.31242	1.04
02/01/2025 03:00	1.0	1.5	2	0.63	0.31266	1.04
02/01/2025 04:00	0.9	1.5	1	0.63	0.31308	1.04
02/01/2025 05:00	0.9	1.4	2	0.63	0.31308	1.04
02/01/2025 06:00	0.9	1.4	2	0.63	0.31314	1.04
02/01/2025 07:00	1.0	1.5	2	0.63	0.31530	1.05
02/01/2025 08:00	1.0	1.4	2	0.63	0.31284	1.04
02/01/2025 09:00	0.8	1.4	1	0.57	0.28566	0.95
02/01/2025 10:00	1.0	1.4	1	0.63	0.31350	1.05
02/01/2025 11:00	1.0	1.4	1	0.63	0.31590	1.05
02/01/2025 12:00	1.1	1.4	1	0.62	0.31188	1.04
02/01/2025 13:00	0.9	1.4	1	0.57	0.28530	0.95
02/01/2025 14:00	0.8	1.4	2	0.64	0.32196	1.07
02/01/2025 15:00	0.8	1.4	1	0.64	0.32160	1.07
02/01/2025 16:00	0.8	1.4	1	0.64	0.31950	1.07
02/01/2025 17:00	1.0	1.4	1	0.63	0.31290	1.04
02/01/2025 18:00	1.0	1.4	1	0.63	0.31332	1.04
02/01/2025 19:00	0.9	1.4	1	0.63	0.31416	1.05
02/01/2025 20:00	0.9	1.4	1	0.63	0.31482	1.05
02/01/2025 21:00	0.8	1.4	1	0.64	0.31752	1.06
02/01/2025 22:00	0.8	1.4	1	0.63	0.31620	1.05
02/01/2025 23:00	0.8	1.4	1	0.63	0.31638	1.05
Average/Sum#:	0.9	1.4	1	0.63	0.31239	1.04
Minimum:	0.8	1.4	1	0.57	0.28530	0.95
Maximum:	1.1	1.5	2	0.64	0.32196	1.07
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/02/2025 00:00	0.8	1.4	1	0.63	0.31608	1.05
02/02/2025 01:00	0.8	1.4	1	0.63	0.31620	1.05
02/02/2025 02:00	0.8	1.4	1	0.63	0.31644	1.05
02/02/2025 03:00	0.9	1.4	1	0.63	0.31644	1.05
02/02/2025 04:00	0.8	1.4	1	0.63	0.31662	1.06
02/02/2025 05:00	0.8	1.4	1	0.63	0.31638	1.05
02/02/2025 06:00	0.8	1.4	1	0.63	0.31614	1.05
02/02/2025 07:00	0.8	1.4	1	0.63	0.31542	1.05
02/02/2025 08:00	0.8	1.4	1	0.57	0.28494	0.95
02/02/2025 09:00	0.9	1.4	1	0.63	0.31422	1.05
02/02/2025 10:00	0.8	1.4	1	0.63	0.31518	1.05
02/02/2025 11:00	0.9	1.4	1	0.63	0.31350	1.05
02/02/2025 12:00	0.9	1.4	1	0.63	0.31284	1.04
02/02/2025 13:00	0.9	1.4	1	0.59	0.29586	0.99
02/02/2025 14:00	0.6	1.3	1	0.44	0.22146	0.74
02/02/2025 15:00	0.6	1.3	1	0.44	0.22248	0.74
02/02/2025 16:00	0.7	1.3	1	0.51	0.25608	0.85
02/02/2025 17:00	0.8	1.4	1	0.64	0.31782	1.06
02/02/2025 18:00	0.8	1.4	1	0.63	0.31716	1.06
02/02/2025 19:00	0.8	1.4	1	0.63	0.31710	1.06
02/02/2025 20:00	0.8	1.4	1	0.63	0.31662	1.06
02/02/2025 21:00	0.8	1.4	1	0.64	0.31770	1.06
02/02/2025 22:00	0.7	1.4	1	0.64	0.31764	1.06
02/02/2025 23:00	0.8	1.4	1	0.64	0.31842	1.06
Average/Sum#:	0.8	1.4	1	0.61	0.30370	1.01
Minimum:	0.6	1.3	1	0.44	0.22146	0.74
Maximum:	0.9	1.4	1	0.64	0.31842	1.06
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/03/2025 00:00	0.8	1.4	1	0.63	0.31668	1.06
02/03/2025 01:00	0.8	1.4	1	0.63	0.31578	1.05
02/03/2025 02:00	0.8	1.4	0	0.63	0.31674	1.06
02/03/2025 03:00	0.9	1.4	0	0.63	0.31608	1.05
02/03/2025 04:00	0.8	1.4	0	0.64	0.31764	1.06
02/03/2025 05:00	0.8	1.4	0	0.63	0.31716	1.06
02/03/2025 06:00	0.3	1.5	0	0.70	0.34992	1.17
02/03/2025 07:00	0.4	1.5	0	0.69	0.34572	1.15
02/03/2025 08:00	0.7	1.4	0	0.65	0.32256	1.08
02/03/2025 09:00	0.9	1.4	0	0.62	0.31200	1.04
02/03/2025 10:00	0.9	1.4	0	0.62	0.31122	1.04
02/03/2025 11:00	0.8	1.3	0	0.54	0.27036	0.90
02/03/2025 12:00	0.6	1.3	0	0.45	0.22344	0.74
02/03/2025 13:00	0.6	1.4	0	0.44	0.22206	0.74
02/03/2025 14:00	0.9	1.3	0	0.48	0.23952	0.80
02/03/2025 15:00	0.7	1.4	0	0.65	0.32370	1.08
02/03/2025 16:00	0.2	1.5	0	0.75	0.37488	1.25
02/03/2025 17:00	0.1	1.5	0	0.77	0.38694	1.29
02/03/2025 18:00	0.1	1.5	0	0.81	0.40398	1.35
02/03/2025 19:00	0.1	1.5	0	0.77	0.38664	1.29
02/03/2025 20:00	0.1	1.5	0	0.76	0.37824	1.26
02/03/2025 21:00	0.1	1.5	0	0.77	0.38316	1.28
02/03/2025 22:00	0.4	1.5	0	0.68	0.34146	1.14
02/03/2025 23:00	0.7	1.4	0	0.65	0.32388	1.08
Average/Sum#:	0.6	1.4	1	0.65	0.32499	1.08
Minimum:	0.1	1.3	1	0.44	0.22206	0.74
Maximum:	0.9	1.5	1	0.81	0.40398	1.35
%SI	0.00	0.00	91.67	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/04/2025 00:00	0.7	1.4	0	0.65	0.32310	1.08
02/04/2025 01:00	0.8	1.4	0	0.64	0.31788	1.06
02/04/2025 02:00	0.8	1.4	0	0.63	0.31740	1.06
02/04/2025 03:00	0.9	1.5	2	0.64	0.31764	1.06
02/04/2025 04:00	0.8	1.4	2	0.64	0.31968	1.07
02/04/2025 05:00	0.7	1.4	2	0.65	0.32550	1.09
02/04/2025 06:00	0.3	1.5	2	0.72	0.35766	1.19
02/04/2025 07:00	0.3	1.5	2	0.69	0.34590	1.15
02/04/2025 08:00	0.7	1.4	1	0.65	0.32712	1.09
02/04/2025 09:00	0.8	1.3	1	0.48	0.24090	0.80
02/04/2025 10:00	0.6	1.4	2	0.45	0.22404	0.75
02/04/2025 11:00	0.6	1.3	1	0.45	0.22380	0.75
02/04/2025 12:00	0.5	1.4	1	0.46	0.22902	0.76
02/04/2025 13:00	0.9	1.2	1	0.56	0.27792	0.93
02/04/2025 14:00	0.2	1.5	2	0.73	0.36666	1.22
02/04/2025 15:00	0.2	1.4	2	0.70	0.34998	1.17
02/04/2025 16:00	0.4	1.5	2	0.68	0.33930	1.13
02/04/2025 17:00	0.3	1.5	2	0.70	0.34854	1.16
02/04/2025 18:00	0.1	1.5	2	0.73	0.36570	1.22
02/04/2025 19:00	0.3	1.5	2	0.71	0.35322	1.18
02/04/2025 20:00	0.4	1.5	2	0.68	0.34152	1.14
02/04/2025 21:00	0.8	1.4	2	0.64	0.32058	1.07
02/04/2025 22:00	1.0	1.4	2	0.62	0.31242	1.04
02/04/2025 23:00	0.9	1.5	2	0.63	0.31368	1.05
Average/Sum#:	0.6	1.4	2	0.63	0.31497	1.05
Minimum:	0.1	1.2	1	0.45	0.22380	0.75
Maximum:	1.0	1.5	2	0.73	0.36666	1.22
%SI	0.00	0.00	12.50	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/05/2025 00:00	0.9	1.5	2	0.62	0.30954	1.03
02/05/2025 01:00	1.0	1.5	2	0.62	0.30810	1.03
02/05/2025 02:00	1.0	1.5	2	0.62	0.30768	1.03
02/05/2025 03:00	1.0	1.5	2	0.62	0.30822	1.03
02/05/2025 04:00	1.0	1.5	2	0.62	0.30882	1.03
02/05/2025 05:00	1.2	1.5	2	0.61	0.30732	1.02
02/05/2025 06:00	0.9	1.5	2	0.65	0.32298	1.08
02/05/2025 07:00	0.6	1.5	2	0.68	0.34002	1.13
02/05/2025 08:00	1.0	1.5	2	0.60	0.29754	0.99
02/05/2025 09:00	0.6	1.3	2	0.45	0.22368	0.75
02/05/2025 10:00	0.6	1.4	2	0.45	0.22302	0.74
02/05/2025 11:00	0.6	1.3	2	0.45	0.22320	0.74
02/05/2025 12:00	0.6	1.2	2	0.45	0.22338	0.74
02/05/2025 13:00	0.6	1.2	2	0.45	0.22320	0.74
02/05/2025 14:00	0.6	1.1	2	0.45	0.22344	0.74
02/05/2025 15:00	0.6	1.3	1	0.45	0.22344	0.74
02/05/2025 16:00	0.7	1.4	1	0.51	0.25656	0.86
02/05/2025 17:00	0.6	1.5	2	0.67	0.33426	1.11
02/05/2025 18:00	0.8	1.5	2	0.64	0.32112	1.07
02/05/2025 19:00	1.0	1.4	2	0.63	0.31296	1.04
02/05/2025 20:00	1.0	1.5	2	0.63	0.31542	1.05
02/05/2025 21:00	1.4	1.5	2	0.63	0.31368	1.05
02/05/2025 22:00	1.3	1.5	2	0.63	0.31374	1.05
02/05/2025 23:00	1.2	1.5	2	0.63	0.31428	1.05
Average/Sum#:	0.9	1.4	2	0.57	0.28565	0.95
Minimum:	0.6	1.1	1	0.45	0.22302	0.74
Maximum:	1.4	1.5	2	0.68	0.34002	1.13
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/06/2025 00:00	1.2	1.5	2	0.63	0.31386	1.05
02/06/2025 01:00	1.2	1.5	2	0.63	0.31254	1.04
02/06/2025 02:00	1.2	1.5	2	0.63	0.31434	1.05
02/06/2025 03:00	1.3	1.5	2	0.63	0.31548	1.05
02/06/2025 04:00	1.3	1.5	2	0.63	0.31506	1.05
02/06/2025 05:00	1.3	1.5	2	0.63	0.31428	1.05
02/06/2025 06:00	1.2	1.5	2	0.63	0.31512	1.05
02/06/2025 07:00	1.2	1.5	2	0.63	0.31512	1.05
02/06/2025 08:00	1.0	1.5	2	0.65	0.32382	1.08
02/06/2025 09:00	0.5	1.5	2	0.70	0.35214	1.17
02/06/2025 10:00	0.1	1.5	3	0.78	0.39162	1.31
02/06/2025 11:00	0.1	1.5	2	0.77	0.38358	1.28
02/06/2025 12:00	0.3	1.5	2	0.72	0.36156	1.21
02/06/2025 13:00	0.7	1.5	2	0.67	0.33522	1.12
02/06/2025 14:00	1.0	1.5	2	0.64	0.32124	1.07
02/06/2025 15:00	0.9	1.5	2	0.65	0.32448	1.08
02/06/2025 16:00	0.8	1.4	2	0.64	0.32112	1.07
02/06/2025 17:00	1.0	1.4	2	0.63	0.31578	1.05
02/06/2025 18:00	1.1	1.4	2	0.63	0.31416	1.05
02/06/2025 19:00	0.8	1.4	2	0.63	0.31560	1.05
02/06/2025 20:00	0.8	1.4	2	0.64	0.31794	1.06
02/06/2025 21:00	0.8	1.4	2	0.63	0.31578	1.05
02/06/2025 22:00	0.8	1.4	2	0.63	0.31638	1.05
02/06/2025 23:00	0.8	1.4	2	0.62	0.31026	1.03
Average/Sum#:	0.9	1.5	2	0.65	0.32652	1.09
Minimum:	0.1	1.4	2	0.62	0.31026	1.03
Maximum:	1.3	1.5	3	0.78	0.39162	1.31
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/07/2025 00:00	0.0	0.0	0	0.29	0.14412	0.48
02/07/2025 01:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 02:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 03:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 04:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 05:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 06:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 07:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 08:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 09:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 10:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 11:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 12:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 13:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 14:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 15:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 16:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 17:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 18:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 19:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 20:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 21:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 22:00	0.0	0.0	0	0.00	0.00000	0.00
02/07/2025 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.29	0.14412	0.48
Minimum:	0.0	0.0	0	0.29	0.14412	0.48
Maximum:	0.0	0.0	0	0.29	0.14412	0.48
%SI	95.83	95.83	100.00	95.83	95.83	95.83

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/08/2025 00:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 01:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 02:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 03:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 04:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 05:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 06:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 07:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 08:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 09:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 10:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 11:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 12:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 13:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 14:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 15:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 16:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 17:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 18:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 19:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 20:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 21:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 22:00	0.0	0.0	0	0.00	0.00000	0.00
02/08/2025 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/09/2025 00:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 01:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 02:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 03:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 04:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 05:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 06:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 07:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 08:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 09:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 10:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 11:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 12:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 13:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 14:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 15:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 16:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 17:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 18:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 19:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 20:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 21:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 22:00	0.0	0.0	0	0.00	0.00000	0.00
02/09/2025 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/10/2025 00:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 01:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 02:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 03:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 04:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 05:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 06:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 07:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 08:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 09:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 10:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 11:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 12:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 13:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 14:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 15:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 16:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 17:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 18:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 19:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 20:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 21:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 22:00	0.0	0.0	0	0.00	0.00000	0.00
02/10/2025 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/11/2025 00:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 01:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 02:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 03:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 04:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 05:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 06:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 07:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 08:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 09:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 10:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 11:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 12:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 13:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 14:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 15:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 16:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 17:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 18:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 19:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 20:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 21:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 22:00	0.0	0.0	0	0.00	0.00000	0.00
02/11/2025 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/12/2025 00:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 01:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 02:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 03:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 04:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 05:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 06:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 07:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 08:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 09:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 10:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 11:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 12:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 13:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 14:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 15:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 16:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 17:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 18:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 19:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 20:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 21:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 22:00	0.0	0.0	0	0.00	0.00000	0.00
02/12/2025 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/13/2025 00:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 01:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 02:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 03:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 04:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 05:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 06:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 07:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 08:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 09:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 10:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 11:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 12:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 13:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 14:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 15:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 16:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 17:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 18:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 19:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 20:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 21:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 22:00	0.0	0.0	0	0.00	0.00000	0.00
02/13/2025 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/14/2025 00:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 01:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 02:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 03:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 04:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 05:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 06:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 07:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 08:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 09:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 10:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 11:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 12:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 13:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 14:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 15:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 16:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 17:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 18:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 19:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 20:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 21:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 22:00	0.0	0.0	0	0.00	0.00000	0.00
02/14/2025 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/15/2025 00:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 01:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 02:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 03:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 04:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 05:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 06:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 07:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 08:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 09:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 10:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 11:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 12:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 13:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 14:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 15:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 16:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 17:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 18:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 19:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 20:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 21:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 22:00	0.0	0.0	0	0.00	0.00000	0.00
02/15/2025 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/16/2025 00:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 01:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 02:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 03:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 04:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 05:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 06:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 07:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 08:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 09:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 10:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 11:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 12:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 13:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 14:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 15:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 16:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 17:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 18:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 19:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 20:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 21:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 22:00	0.0	0.0	0	0.00	0.00000	0.00
02/16/2025 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/17/2025 00:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 01:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 02:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 03:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 04:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 05:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 06:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 07:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 08:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 09:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 10:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 11:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 12:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 13:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 14:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 15:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 16:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 17:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 18:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 19:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 20:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 21:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 22:00	0.0	0.0	0	0.00	0.00000	0.00
02/17/2025 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/18/2025 00:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 01:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 02:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 03:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 04:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 05:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 06:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 07:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 08:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 09:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 10:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 11:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 12:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 13:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 14:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 15:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 16:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 17:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 18:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 19:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 20:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 21:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 22:00	0.0	0.0	0	0.00	0.00000	0.00
02/18/2025 23:00	0.0	0.0	0	0.20	0.09762	0.33
Average/Sum#:	0.0	0.0	0	0.20	0.09762	0.33
Minimum:	0.0	0.0	0	0.20	0.09762	0.33
Maximum:	0.0	0.0	0	0.20	0.09762	0.33
%SI	95.83	95.83	100.00	95.83	95.83	95.83

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/19/2025 00:00	0.6	0.8	1	0.45	0.22500	0.75
02/19/2025 01:00	0.6	1.1	1	0.45	0.22404	0.75
02/19/2025 02:00	0.7	1.3	1	0.45	0.22410	0.75
02/19/2025 03:00	0.6	1.5	1	0.55	0.27438	0.91
02/19/2025 04:00	0.5	1.3	1	0.56	0.28062	0.94
02/19/2025 05:00	0.9	1.4	2	0.62	0.31218	1.04
02/19/2025 06:00	0.3	1.5	2	0.70	0.35046	1.17
02/19/2025 07:00	0.8	1.4	2	0.63	0.31722	1.06
02/19/2025 08:00	0.9	1.4	2	0.62	0.30912	1.03
02/19/2025 09:00	0.6	1.2	1	0.46	0.22908	0.76
02/19/2025 10:00	0.6	1.3	2	0.44	0.21792	0.73
02/19/2025 11:00	0.6	1.4	2	0.44	0.21936	0.73
02/19/2025 12:00	0.6	1.3	1	0.44	0.21810	0.73
02/19/2025 13:00	0.6	1.3	1	0.44	0.21828	0.73
02/19/2025 14:00	0.6	1.2	1	0.44	0.21924	0.73
02/19/2025 15:00	0.6	1.3	1	0.44	0.21948	0.73
02/19/2025 16:00	1.0	1.3	1	0.52	0.25842	0.86
02/19/2025 17:00	0.8	1.4	1	0.63	0.31338	1.04
02/19/2025 18:00	1.0	1.4	1	0.62	0.30750	1.03
02/19/2025 19:00	1.0	1.4	2	0.62	0.30882	1.03
02/19/2025 20:00	1.3	1.4	2	0.61	0.30522	1.02
02/19/2025 21:00	1.0	1.4	2	0.61	0.30702	1.02
02/19/2025 22:00	1.1	1.4	2	0.61	0.30660	1.02
02/19/2025 23:00	1.1	1.4	2	0.61	0.30720	1.02
Average/Sum#:	0.8	1.3	1	0.54	0.26970	0.90
Minimum:	0.3	0.8	1	0.44	0.21792	0.73
Maximum:	1.3	1.5	2	0.70	0.35046	1.17
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/20/2025 00:00	1.1	1.4	2	0.61	0.30726	1.02
02/20/2025 01:00	1.0	1.4	2	0.61	0.30684	1.02
02/20/2025 02:00	1.1	1.3	1	0.61	0.30714	1.02
02/20/2025 03:00	1.1	1.5	2	0.61	0.30696	1.02
02/20/2025 04:00	1.0	1.4	2	0.61	0.30666	1.02
02/20/2025 05:00	1.0	1.4	2	0.62	0.30942	1.03
02/20/2025 06:00	1.1	1.4	2	0.61	0.30576	1.02
02/20/2025 07:00	1.1	1.4	2	0.61	0.30516	1.02
02/20/2025 08:00	1.0	1.4	2	0.61	0.30570	1.02
02/20/2025 09:00	0.8	1.3	2	0.50	0.24900	0.83
02/20/2025 10:00	0.6	1.4	2	0.44	0.21882	0.73
02/20/2025 11:00	0.6	1.3	2	0.44	0.21894	0.73
02/20/2025 12:00	0.6	1.3	1	0.44	0.21888	0.73
02/20/2025 13:00	0.6	1.3	1	0.44	0.21870	0.73
02/20/2025 14:00	0.6	1.3	2	0.44	0.21864	0.73
02/20/2025 15:00	0.6	1.3	2	0.44	0.21924	0.73
02/20/2025 16:00	0.7	1.3	1	0.51	0.25686	0.86
02/20/2025 17:00	0.7	1.4	1	0.63	0.31278	1.04
02/20/2025 18:00	0.8	1.4	1	0.62	0.30948	1.03
02/20/2025 19:00	0.8	1.4	1	0.62	0.31098	1.04
02/20/2025 20:00	0.9	1.4	2	0.62	0.30960	1.03
02/20/2025 21:00	0.9	1.4	1	0.62	0.31008	1.03
02/20/2025 22:00	1.0	1.4	2	0.62	0.31056	1.04
02/20/2025 23:00	1.0	1.4	2	0.62	0.31002	1.03
Average/Sum#:	0.9	1.4	2	0.56	0.28140	0.94
Minimum:	0.6	1.3	1	0.44	0.21864	0.73
Maximum:	1.1	1.5	2	0.63	0.31278	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/21/2025 00:00	1.1	1.4	2	0.62	0.30828	1.03
02/21/2025 01:00	1.2	1.4	2	0.62	0.30858	1.03
02/21/2025 02:00	1.1	1.4	2	0.61	0.30720	1.02
02/21/2025 03:00	1.2	1.5	2	0.61	0.30690	1.02
02/21/2025 04:00	1.2	1.4	2	0.61	0.30636	1.02
02/21/2025 05:00	1.0	1.4	2	0.63	0.31512	1.05
02/21/2025 06:00	0.8	1.4	2	0.65	0.32658	1.09
02/21/2025 07:00	1.3	1.4	2	0.61	0.30666	1.02
02/21/2025 08:00	1.0	1.3	2	0.50	0.24984	0.83
02/21/2025 09:00	0.7	1.3	2	0.44	0.21840	0.73
02/21/2025 10:00	0.6	1.3	2	0.44	0.21996	0.73
02/21/2025 11:00	0.6	1.2	1	0.44	0.22038	0.73
02/21/2025 12:00	0.6	1.4	1	0.44	0.22050	0.74
02/21/2025 13:00	0.6	1.4	1	0.44	0.21918	0.73
02/21/2025 14:00	0.6	1.3	1	0.44	0.21906	0.73
02/21/2025 15:00	0.6	1.3	1	0.44	0.21888	0.73
02/21/2025 16:00	0.9	1.3	1	0.51	0.25656	0.86
02/21/2025 17:00	0.7	1.4	1	0.63	0.31446	1.05
02/21/2025 18:00	0.9	1.4	1	0.62	0.30894	1.03
02/21/2025 19:00	1.0	1.4	1	0.61	0.30672	1.02
02/21/2025 20:00	1.1	1.4	1	0.61	0.30648	1.02
02/21/2025 21:00	1.2	1.4	1	0.61	0.30534	1.02
02/21/2025 22:00	1.2	1.4	1	0.61	0.30414	1.01
02/21/2025 23:00	1.3	1.4	1	0.61	0.30456	1.02
Average/Sum#:	0.9	1.4	1	0.56	0.27830	0.93
Minimum:	0.6	1.2	1	0.44	0.21840	0.73
Maximum:	1.3	1.5	2	0.65	0.32658	1.09
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/22/2025 00:00	1.2	1.4	2	0.62	0.30810	1.03
02/22/2025 01:00	1.2	1.4	1	0.62	0.30798	1.03
02/22/2025 02:00	1.1	1.3	1	0.61	0.30690	1.02
02/22/2025 03:00	1.3	1.5	2	0.61	0.30576	1.02
02/22/2025 04:00	1.4	1.4	2	0.61	0.30510	1.02
02/22/2025 05:00	1.2	1.4	2	0.61	0.30534	1.02
02/22/2025 06:00	1.1	1.4	2	0.61	0.30654	1.02
02/22/2025 07:00	0.9	1.3	2	0.54	0.26976	0.90
02/22/2025 08:00	0.7	1.3	2	0.44	0.21774	0.73
02/22/2025 09:00	0.8	1.2	2	0.44	0.21912	0.73
02/22/2025 10:00	0.7	1.3	2	0.44	0.21912	0.73
02/22/2025 11:00	0.7	1.3	1	0.44	0.22038	0.73
02/22/2025 12:00	0.6	1.3	1	0.44	0.22122	0.74
02/22/2025 13:00	0.6	1.3	1	0.44	0.22086	0.74
02/22/2025 14:00	0.7	1.3	1	0.44	0.21930	0.73
02/22/2025 15:00	0.6	1.4	1	0.44	0.21906	0.73
02/22/2025 16:00	0.6	1.3	1	0.44	0.21870	0.73
02/22/2025 17:00	0.6	1.3	1	0.44	0.21858	0.73
02/22/2025 18:00	0.7	1.2	1	0.44	0.21798	0.73
02/22/2025 19:00	0.7	1.3	2	0.44	0.21870	0.73
02/22/2025 20:00	0.7	1.3	1	0.44	0.21882	0.73
02/22/2025 21:00	0.7	1.3	1	0.44	0.21876	0.73
02/22/2025 22:00	0.8	1.3	1	0.44	0.21834	0.73
02/22/2025 23:00	0.7	1.3	1	0.44	0.21828	0.73
Average/Sum#:	0.8	1.3	1	0.49	0.24669	0.82
Minimum:	0.6	1.2	1	0.44	0.21774	0.73
Maximum:	1.4	1.5	2	0.62	0.30810	1.03
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/23/2025 00:00	0.7	1.3	1	0.44	0.21810	0.73
02/23/2025 01:00	0.7	1.3	1	0.44	0.21780	0.73
02/23/2025 02:00	0.7	1.3	1	0.43	0.21726	0.72
02/23/2025 03:00	0.7	1.2	1	0.43	0.21720	0.72
02/23/2025 04:00	0.7	1.3	1	0.44	0.21822	0.73
02/23/2025 05:00	0.7	1.3	1	0.44	0.21930	0.73
02/23/2025 06:00	0.7	1.2	1	0.44	0.21900	0.73
02/23/2025 07:00	0.6	1.3	1	0.44	0.21924	0.73
02/23/2025 08:00	0.6	1.3	1	0.44	0.21960	0.73
02/23/2025 09:00	0.6	1.3	1	0.44	0.21942	0.73
02/23/2025 10:00	0.6	1.3	1	0.44	0.21960	0.73
02/23/2025 11:00	0.6	1.2	1	0.44	0.21960	0.73
02/23/2025 12:00	0.6	1.3	1	0.44	0.22038	0.73
02/23/2025 13:00	0.6	1.4	1	0.44	0.21990	0.73
02/23/2025 14:00	0.6	1.3	1	0.44	0.21960	0.73
02/23/2025 15:00	0.6	1.2	1	0.44	0.21792	0.73
02/23/2025 16:00	0.6	1.2	1	0.44	0.21762	0.73
02/23/2025 17:00	0.6	1.2	1	0.43	0.21744	0.72
02/23/2025 18:00	0.6	1.3	1	0.43	0.21666	0.72
02/23/2025 19:00	0.6	1.2	1	0.43	0.21630	0.72
02/23/2025 20:00	0.7	1.2	1	0.43	0.21576	0.72
02/23/2025 21:00	0.7	1.1	1	0.43	0.21564	0.72
02/23/2025 22:00	0.7	1.2	1	0.43	0.21612	0.72
02/23/2025 23:00	0.8	1.3	1	0.43	0.21672	0.72
Average/Sum#:	0.7	1.3	1	0.44	0.21810	0.73
Minimum:	0.6	1.1	1	0.43	0.21564	0.72
Maximum:	0.8	1.4	1	0.44	0.22038	0.73
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/24/2025 00:00	0.7	1.2	1	0.43	0.21624	0.72
02/24/2025 01:00	0.8	1.1	1	0.43	0.21564	0.72
02/24/2025 02:00	0.7	1.4	1	0.43	0.21558	0.72
02/24/2025 03:00	0.8	1.2	1	0.43	0.21600	0.72
02/24/2025 04:00	0.7	1.2	1	0.43	0.21678	0.72
02/24/2025 05:00	0.7	1.3	1	0.44	0.21798	0.73
02/24/2025 06:00	0.7	1.2	2	0.44	0.21912	0.73
02/24/2025 07:00	0.7	1.3	1	0.45	0.22278	0.74
02/24/2025 08:00	0.8	1.2	1	0.44	0.21900	0.73
02/24/2025 09:00	0.6	1.3	1	0.44	0.21810	0.73
02/24/2025 10:00	0.6	1.3	1	0.44	0.21816	0.73
02/24/2025 11:00	0.6	1.2	1	0.44	0.21798	0.73
02/24/2025 12:00	0.6	1.2	1	0.44	0.21858	0.73
02/24/2025 13:00	0.6	1.2	1	0.44	0.21870	0.73
02/24/2025 14:00	0.6	1.3	1	0.44	0.21846	0.73
02/24/2025 15:00	0.6	1.2	1	0.44	0.21888	0.73
02/24/2025 16:00	0.6	1.2	1	0.45	0.22554	0.75
02/24/2025 17:00	1.1	1.3	1	0.51	0.25572	0.85
02/24/2025 18:00	0.9	1.4	1	0.61	0.30642	1.02
02/24/2025 19:00	0.9	1.4	1	0.61	0.30738	1.02
02/24/2025 20:00	0.9	1.4	1	0.61	0.30720	1.02
02/24/2025 21:00	0.9	1.4	1	0.61	0.30678	1.02
02/24/2025 22:00	1.0	1.4	1	0.61	0.30726	1.02
02/24/2025 23:00	1.0	1.4	1	0.61	0.30726	1.02
Average/Sum#:	0.8	1.3	1	0.48	0.24215	0.81
Minimum:	0.6	1.1	1	0.43	0.21558	0.72
Maximum:	1.1	1.4	2	0.61	0.30738	1.02
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/25/2025 00:00	0.9	1.3	1	0.53	0.26748	0.89
02/25/2025 01:00	0.7	1.4	1	0.44	0.21864	0.73
02/25/2025 02:00	0.7	1.1	1	0.44	0.22020	0.73
02/25/2025 03:00	0.7	1.4	1	0.44	0.21960	0.73
02/25/2025 04:00	0.7	1.3	1	0.44	0.21972	0.73
02/25/2025 05:00	1.1	1.3	1	0.51	0.25656	0.86
02/25/2025 06:00	1.1	1.4	2	0.61	0.30672	1.02
02/25/2025 07:00	1.2	1.4	1	0.59	0.29274	0.98
02/25/2025 08:00	0.8	1.3	2	0.44	0.22020	0.73
02/25/2025 09:00	0.7	1.2	2	0.44	0.21852	0.73
02/25/2025 10:00	0.7	1.2	1	0.44	0.21810	0.73
02/25/2025 11:00	0.6	1.3	2	0.44	0.21822	0.73
02/25/2025 12:00	0.6	1.3	1	0.44	0.21786	0.73
02/25/2025 13:00	0.6	1.3	1	0.44	0.21966	0.73
02/25/2025 14:00	0.6	1.3	2	0.44	0.21774	0.73
02/25/2025 15:00	0.6	1.3	1	0.43	0.21732	0.72
02/25/2025 16:00	0.6	1.4	1	0.43	0.21738	0.72
02/25/2025 17:00	0.8	1.3	1	0.50	0.25026	0.83
02/25/2025 18:00	0.9	1.4	1	0.62	0.30852	1.03
02/25/2025 19:00	0.9	1.4	1	0.62	0.30792	1.03
02/25/2025 20:00	1.1	1.4	1	0.61	0.30666	1.02
02/25/2025 21:00	1.0	1.4	2	0.61	0.30726	1.02
02/25/2025 22:00	1.2	1.4	1	0.62	0.30912	1.03
02/25/2025 23:00	1.1	1.4	2	0.62	0.30900	1.03
Average/Sum#:	0.8	1.3	1	0.51	0.25273	0.84
Minimum:	0.6	1.1	1	0.43	0.21732	0.72
Maximum:	1.2	1.4	2	0.62	0.30912	1.03
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/26/2025 00:00	1.2	1.4	2	0.62	0.30882	1.03
02/26/2025 01:00	1.2	1.4	2	0.62	0.30900	1.03
02/26/2025 02:00	1.1	1.4	2	0.62	0.30912	1.03
02/26/2025 03:00	1.2	1.5	2	0.62	0.30924	1.03
02/26/2025 04:00	1.1	1.4	2	0.62	0.30942	1.03
02/26/2025 05:00	1.1	1.4	2	0.62	0.30882	1.03
02/26/2025 06:00	1.1	1.4	2	0.62	0.31146	1.04
02/26/2025 07:00	1.1	1.4	2	0.62	0.30984	1.03
02/26/2025 08:00	1.1	1.4	2	0.59	0.29268	0.98
02/26/2025 09:00	0.7	1.1	2	0.44	0.21918	0.73
02/26/2025 10:00	0.7	1.3	1	0.44	0.22086	0.74
02/26/2025 11:00	0.6	1.2	1	0.45	0.22302	0.74
02/26/2025 12:00	0.6	1.3	1	0.44	0.22014	0.73
02/26/2025 13:00	0.6	1.3	1	0.44	0.21966	0.73
02/26/2025 14:00	0.6	1.3	1	0.44	0.21936	0.73
02/26/2025 15:00	0.6	1.2	1	0.44	0.21930	0.73
02/26/2025 16:00	0.7	1.4	1	0.50	0.25110	0.84
02/26/2025 17:00	0.7	1.4	1	0.63	0.31626	1.05
02/26/2025 18:00	0.8	1.4	1	0.63	0.31362	1.05
02/26/2025 19:00	1.0	1.4	1	0.62	0.31218	1.04
02/26/2025 20:00	1.1	1.4	1	0.62	0.31050	1.04
02/26/2025 21:00	1.2	1.4	1	0.62	0.30906	1.03
02/26/2025 22:00	1.4	1.4	1	0.62	0.30828	1.03
02/26/2025 23:00	1.3	1.4	2	0.62	0.30786	1.03
Average/Sum#:	1.0	1.4	1	0.56	0.28078	0.94
Minimum:	0.6	1.1	1	0.44	0.21918	0.73
Maximum:	1.4	1.5	2	0.63	0.31626	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/27/2025 00:00	1.3	1.4	1	0.61	0.30708	1.02
02/27/2025 01:00	1.3	1.4	1	0.61	0.30612	1.02
02/27/2025 02:00	1.3	1.4	1	0.61	0.30630	1.02
02/27/2025 03:00	1.4	1.4	2	0.62	0.30762	1.03
02/27/2025 04:00	1.3	1.4	1	0.62	0.30966	1.03
02/27/2025 05:00	1.3	1.4	2	0.62	0.31002	1.03
02/27/2025 06:00	1.3	1.4	2	0.62	0.30972	1.03
02/27/2025 07:00	1.1	1.3	2	0.54	0.27024	0.90
02/27/2025 08:00	0.8	1.3	2	0.44	0.22002	0.73
02/27/2025 09:00	0.8	1.4	1	0.44	0.21990	0.73
02/27/2025 10:00	0.8	1.3	2	0.44	0.21882	0.73
02/27/2025 11:00	0.7	1.2	1	0.44	0.21876	0.73
02/27/2025 12:00	0.7	1.3	1	0.44	0.21918	0.73
02/27/2025 13:00	0.6	1.4	1	0.44	0.21936	0.73
02/27/2025 14:00	0.6	1.3	1	0.44	0.21810	0.73
02/27/2025 15:00	0.6	1.3	1	0.43	0.21726	0.72
02/27/2025 16:00	0.8	1.4	1	0.50	0.24900	0.83
02/27/2025 17:00	0.7	1.4	1	0.62	0.31122	1.04
02/27/2025 18:00	0.6	1.4	1	0.63	0.31446	1.05
02/27/2025 19:00	0.8	1.4	1	0.63	0.31272	1.04
02/27/2025 20:00	1.0	1.4	1	0.62	0.31098	1.04
02/27/2025 21:00	1.0	1.4	1	0.62	0.31080	1.04
02/27/2025 22:00	1.2	1.4	1	0.62	0.30870	1.03
02/27/2025 23:00	1.2	1.4	1	0.62	0.30894	1.03
Average/Sum#:	1.0	1.4	1	0.55	0.27521	0.92
Minimum:	0.6	1.2	1	0.43	0.21726	0.72
Maximum:	1.4	1.4	2	0.63	0.31446	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
02/28/2025 00:00	1.3	1.4	1	0.62	0.30816	1.03
02/28/2025 01:00	1.5	1.4	2	0.62	0.31068	1.04
02/28/2025 02:00	1.4	1.4	1	0.62	0.31068	1.04
02/28/2025 03:00	1.3	1.4	2	0.62	0.31098	1.04
02/28/2025 04:00	1.4	1.4	1	0.62	0.31044	1.03
02/28/2025 05:00	1.3	1.4	1	0.62	0.30996	1.03
02/28/2025 06:00	1.3	1.4	1	0.62	0.31092	1.04
02/28/2025 07:00	1.3	1.4	1	0.62	0.31122	1.04
02/28/2025 08:00	1.0	1.4	1	0.49	0.24678	0.82
02/28/2025 09:00	0.7	1.2	2	0.44	0.21870	0.73
02/28/2025 10:00	0.7	1.3	1	0.44	0.21948	0.73
02/28/2025 11:00	0.6	1.3	2	0.44	0.21906	0.73
02/28/2025 12:00	0.6	1.4	1	0.44	0.21912	0.73
02/28/2025 13:00	0.6	1.3	1	0.44	0.21882	0.73
02/28/2025 14:00	0.6	1.4	1	0.44	0.21912	0.73
02/28/2025 15:00	0.6	1.4	1	0.44	0.21936	0.73
02/28/2025 16:00	0.7	1.3	1	0.50	0.25008	0.83
02/28/2025 17:00	0.6	1.4	1	0.64	0.31926	1.06
02/28/2025 18:00	0.6	1.4	1	0.63	0.31740	1.06
02/28/2025 19:00	0.7	1.4	1	0.63	0.31560	1.05
02/28/2025 20:00	0.8	1.4	1	0.63	0.31542	1.05
02/28/2025 21:00	0.8	1.4	1	0.63	0.31470	1.05
02/28/2025 22:00	1.0	1.4	1	0.63	0.31278	1.04
02/28/2025 23:00	1.0	1.4	1	0.62	0.31164	1.04
Average/Sum#:	0.9	1.4	1	0.56	0.28002	0.93
Minimum:	0.6	1.2	1	0.44	0.21870	0.73
Maximum:	1.5	1.4	2	0.64	0.31926	1.06
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/01/2025 00:00	1.1	1.4	1	0.62	0.31062	1.04
03/01/2025 01:00	1.2	1.4	2	0.62	0.30918	1.03
03/01/2025 02:00	1.1	1.3	1	0.62	0.30984	1.03
03/01/2025 03:00	1.1	1.4	2	0.62	0.31224	1.04
03/01/2025 04:00	1.1	1.4	1	0.62	0.31062	1.04
03/01/2025 05:00	1.2	1.4	2	0.62	0.30894	1.03
03/01/2025 06:00	1.3	1.4	2	0.62	0.30804	1.03
03/01/2025 07:00	1.2	1.4	2	0.62	0.30906	1.03
03/01/2025 08:00	0.8	1.3	1	0.46	0.22980	0.77
03/01/2025 09:00	0.7	1.3	2	0.44	0.21948	0.73
03/01/2025 10:00	0.7	1.4	1	0.44	0.21804	0.73
03/01/2025 11:00	0.7	1.3	1	0.44	0.21780	0.73
03/01/2025 12:00	0.6	1.2	1	0.44	0.21810	0.73
03/01/2025 13:00	0.6	1.2	1	0.44	0.21816	0.73
03/01/2025 14:00	0.6	1.2	1	0.44	0.21792	0.73
03/01/2025 15:00	0.6	1.3	1	0.43	0.21708	0.72
03/01/2025 16:00	0.5	1.3	1	0.46	0.22890	0.76
03/01/2025 17:00	0.6	1.2	1	0.44	0.21762	0.73
03/01/2025 18:00	0.6	1.3	1	0.44	0.21828	0.73
03/01/2025 19:00	0.6	1.3	1	0.44	0.21852	0.73
03/01/2025 20:00	0.6	1.3	1	0.44	0.21888	0.73
03/01/2025 21:00	0.6	1.1	1	0.44	0.21966	0.73
03/01/2025 22:00	0.6	1.3	1	0.44	0.22008	0.73
03/01/2025 23:00	0.6	1.2	1	0.44	0.21990	0.73
Average/Sum#:	0.8	1.3	1	0.50	0.24987	0.83
Minimum:	0.5	1.1	1	0.43	0.21708	0.72
Maximum:	1.3	1.4	2	0.62	0.31224	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/02/2025 00:00	0.6	1.3	1	0.44	0.22038	0.73
03/02/2025 01:00	0.6	1.4	1	0.44	0.21984	0.73
03/02/2025 02:00	0.6	1.3	1	0.44	0.21966	0.73
03/02/2025 03:00	0.7	1.3	1	0.44	0.21960	0.73
03/02/2025 04:00	0.6	1.2	2	0.44	0.21936	0.73
03/02/2025 05:00	0.6	1.3	1	0.44	0.21912	0.73
03/02/2025 06:00	0.6	1.2	1	0.44	0.21930	0.73
03/02/2025 07:00	0.6	1.3	1	0.44	0.22038	0.73
03/02/2025 08:00	0.6	1.2	1	0.44	0.22008	0.73
03/02/2025 09:00	0.6	1.3	1	0.44	0.22014	0.73
03/02/2025 10:00	0.6	1.2	1	0.44	0.22044	0.73
03/02/2025 11:00	0.6	1.2	1	0.44	0.22086	0.74
03/02/2025 12:00	0.6	1.3	1	0.44	0.22002	0.73
03/02/2025 13:00	0.6	1.3	1	0.44	0.22080	0.74
03/02/2025 14:00	0.6	1.1	1	0.44	0.22050	0.74
03/02/2025 15:00	0.6	1.2	1	0.44	0.21912	0.73
03/02/2025 16:00	0.7	1.2	1	0.44	0.21828	0.73
03/02/2025 17:00	0.6	1.1	1	0.44	0.21900	0.73
03/02/2025 18:00	0.6	1.3	1	0.44	0.21924	0.73
03/02/2025 19:00	0.6	1.3	1	0.44	0.21912	0.73
03/02/2025 20:00	0.6	1.3	2	0.44	0.21954	0.73
03/02/2025 21:00	0.6	1.3	1	0.44	0.21966	0.73
03/02/2025 22:00	0.6	1.3	1	0.44	0.21978	0.73
03/02/2025 23:00	0.6	1.2	2	0.44	0.22002	0.73
Average/Sum#:	0.6	1.3	1	0.44	0.21976	0.73
Minimum:	0.6	1.1	1	0.44	0.21828	0.73
Maximum:	0.7	1.4	2	0.44	0.22086	0.74
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/03/2025 00:00	0.6	1.0	2	0.44	0.22044	0.73
03/03/2025 01:00	0.6	1.2	2	0.44	0.22056	0.74
03/03/2025 02:00	0.7	1.2	2	0.44	0.22038	0.73
03/03/2025 03:00	0.7	1.3	2	0.44	0.22080	0.74
03/03/2025 04:00	0.6	1.2	2	0.44	0.22044	0.73
03/03/2025 05:00	0.9	1.3	1	0.51	0.25446	0.85
03/03/2025 06:00	1.1	1.4	1	0.62	0.30936	1.03
03/03/2025 07:00	1.1	1.4	1	0.61	0.30630	1.02
03/03/2025 08:00	0.7	1.3	2	0.47	0.23352	0.78
03/03/2025 09:00	0.7	1.3	2	0.44	0.22032	0.73
03/03/2025 10:00	0.6	1.4	2	0.44	0.22074	0.74
03/03/2025 11:00	0.6	1.4	1	0.44	0.21984	0.73
03/03/2025 12:00	0.6	1.3	2	0.44	0.21858	0.73
03/03/2025 13:00	0.6	1.3	1	0.44	0.21792	0.73
03/03/2025 14:00	0.6	1.3	2	0.44	0.21774	0.73
03/03/2025 15:00	0.6	1.3	2	0.44	0.21768	0.73
03/03/2025 16:00	0.8	1.4	1	0.50	0.25080	0.84
03/03/2025 17:00	0.7	1.4	2	0.65	0.32292	1.08
03/03/2025 18:00	0.4	1.5	2	0.69	0.34260	1.14
03/03/2025 19:00	0.5	1.5	2	0.67	0.33684	1.12
03/03/2025 20:00	0.4	1.5	2	0.69	0.34668	1.16
03/03/2025 21:00	0.3	1.5	2	0.71	0.35406	1.18
03/03/2025 22:00	0.3	1.5	2	0.74	0.36996	1.23
03/03/2025 23:00	0.2	1.5	2	0.74	0.37170	1.24
Average/Sum#:	0.6	1.4	2	0.54	0.26811	0.89
Minimum:	0.2	1.0	1	0.44	0.21768	0.73
Maximum:	1.1	1.5	2	0.74	0.37170	1.24
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/04/2025 00:00	1.0	1.4	1	0.62	0.30858	1.03
03/04/2025 01:00	1.0	1.4	1	0.61	0.30576	1.02
03/04/2025 02:00	1.0	1.5	1	0.61	0.30732	1.02
03/04/2025 03:00	1.1	1.5	2	0.61	0.30702	1.02
03/04/2025 04:00	0.9	1.4	2	0.64	0.31902	1.06
03/04/2025 05:00	0.9	1.4	2	0.63	0.31728	1.06
03/04/2025 06:00	0.9	1.4	2	0.64	0.32118	1.07
03/04/2025 07:00	1.0	1.4	2	0.58	0.29238	0.97
03/04/2025 08:00	0.6	1.2	1	0.46	0.23106	0.77
03/04/2025 09:00	0.8	1.4	1	0.56	0.28086	0.94
03/04/2025 10:00	0.9	1.4	2	0.63	0.31608	1.05
03/04/2025 11:00	0.9	1.4	1	0.63	0.31536	1.05
03/04/2025 12:00	0.8	1.4	1	0.54	0.27096	0.90
03/04/2025 13:00	0.6	1.4	2	0.45	0.22302	0.74
03/04/2025 14:00	0.6	1.3	2	0.45	0.22392	0.75
03/04/2025 15:00	0.6	1.4	2	0.45	0.22458	0.75
03/04/2025 16:00	0.7	1.3	1	0.51	0.25620	0.85
03/04/2025 17:00	0.5	1.4	2	0.68	0.34152	1.14
03/04/2025 18:00	0.4	1.5	2	0.70	0.35058	1.17
03/04/2025 19:00	0.7	1.4	2	0.65	0.32304	1.08
03/04/2025 20:00	0.6	1.4	2	0.66	0.32958	1.10
03/04/2025 21:00	0.5	1.5	2	0.69	0.34602	1.15
03/04/2025 22:00	0.5	1.5	2	0.70	0.35010	1.17
03/04/2025 23:00	0.5	1.5	2	0.69	0.34632	1.15
Average/Sum#:	0.8	1.4	2	0.60	0.30032	1.00
Minimum:	0.4	1.2	1	0.45	0.22302	0.74
Maximum:	1.1	1.5	2	0.70	0.35058	1.17
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/05/2025 00:00	0.1	1.5	2	0.77	0.38700	1.29
03/05/2025 01:00	0.2	1.5	2	0.76	0.37794	1.26
03/05/2025 02:00	0.5	1.5	2	0.69	0.34608	1.15
03/05/2025 03:00	0.4	1.5	2	0.72	0.36048	1.20
03/05/2025 04:00	0.4	1.5	2	0.70	0.35100	1.17
03/05/2025 05:00	0.5	1.5	2	0.69	0.34260	1.14
03/05/2025 06:00	0.7	1.5	2	0.68	0.34050	1.14
03/05/2025 07:00	0.7	1.4	2	0.67	0.33438	1.11
03/05/2025 08:00	0.6	1.5	2	0.68	0.34206	1.14
03/05/2025 09:00	0.5	1.5	2	0.69	0.34398	1.15
03/05/2025 10:00	0.6	1.4	2	0.66	0.33150	1.11
03/05/2025 11:00	0.7	1.4	2	0.65	0.32538	1.08
03/05/2025 12:00	0.5	1.5	2	0.68	0.34236	1.14
03/05/2025 13:00	0.1	1.5	2	0.76	0.37902	1.26
03/05/2025 14:00	0.3	1.5	2	0.70	0.35184	1.17
03/05/2025 15:00	0.6	1.4	2	0.66	0.32904	1.10
03/05/2025 16:00	0.6	1.4	2	0.66	0.33186	1.11
03/05/2025 17:00	0.5	1.4	2	0.67	0.33654	1.12
03/05/2025 18:00	0.6	1.4	2	0.66	0.32952	1.10
03/05/2025 19:00	0.6	1.5	2	0.67	0.33408	1.11
03/05/2025 20:00	0.4	1.5	2	0.71	0.35334	1.18
03/05/2025 21:00	0.6	1.5	2	0.66	0.33222	1.11
03/05/2025 22:00	0.9	1.4	2	0.63	0.31584	1.05
03/05/2025 23:00	0.9	1.4	2	0.63	0.31542	1.05
Average/Sum#:	0.5	1.5	2	0.69	0.34308	1.14
Minimum:	0.1	1.4	2	0.63	0.31542	1.05
Maximum:	0.9	1.5	2	0.77	0.38700	1.29
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/06/2025 00:00	1.0	1.4	2	0.63	0.31500	1.05
03/06/2025 01:00	1.0	1.4	2	0.63	0.31494	1.05
03/06/2025 02:00	0.9	1.4	2	0.63	0.31560	1.05
03/06/2025 03:00	1.0	1.4	2	0.63	0.31530	1.05
03/06/2025 04:00	1.0	1.4	2	0.63	0.31530	1.05
03/06/2025 05:00	0.9	1.5	2	0.64	0.31866	1.06
03/06/2025 06:00	0.8	1.5	2	0.64	0.32190	1.07
03/06/2025 07:00	1.0	1.4	2	0.63	0.31488	1.05
03/06/2025 08:00	1.0	1.4	2	0.59	0.29598	0.99
03/06/2025 09:00	0.7	1.4	2	0.44	0.22242	0.74
03/06/2025 10:00	0.7	1.3	2	0.45	0.22344	0.74
03/06/2025 11:00	0.7	1.4	2	0.45	0.22350	0.75
03/06/2025 12:00	0.7	1.4	2	0.45	0.22398	0.75
03/06/2025 13:00	0.7	1.4	2	0.45	0.22404	0.75
03/06/2025 14:00	0.7	1.4	2	0.45	0.22404	0.75
03/06/2025 15:00	0.7	1.3	2	0.45	0.22362	0.75
03/06/2025 16:00	0.7	1.4	1	0.46	0.23058	0.77
03/06/2025 17:00	0.8	1.4	1	0.51	0.25542	0.85
03/06/2025 18:00	0.8	1.5	2	0.64	0.31878	1.06
03/06/2025 19:00	0.9	1.4	2	0.64	0.31776	1.06
03/06/2025 20:00	1.0	1.4	2	0.63	0.31686	1.06
03/06/2025 21:00	1.1	1.4	2	0.63	0.31596	1.05
03/06/2025 22:00	1.2	1.4	2	0.63	0.31524	1.05
03/06/2025 23:00	1.3	1.4	2	0.63	0.31488	1.05
Average/Sum#:	0.9	1.4	2	0.57	0.28242	0.94
Minimum:	0.7	1.3	1	0.44	0.22242	0.74
Maximum:	1.3	1.5	2	0.64	0.32190	1.07
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/07/2025 00:00	1.5	1.4	2	0.63	0.31368	1.05
03/07/2025 01:00	1.4	1.4	2	0.62	0.31242	1.04
03/07/2025 02:00	1.3	1.4	2	0.63	0.31356	1.05
03/07/2025 03:00	1.3	1.5	2	0.63	0.31362	1.05
03/07/2025 04:00	1.2	1.4	2	0.63	0.31458	1.05
03/07/2025 05:00	1.1	1.4	2	0.64	0.31980	1.07
03/07/2025 06:00	0.4	1.5	2	0.74	0.36840	1.23
03/07/2025 07:00	0.9	1.4	2	0.65	0.32460	1.08
03/07/2025 08:00	1.0	1.3	2	0.55	0.27330	0.91
03/07/2025 09:00	0.7	1.4	2	0.44	0.22248	0.74
03/07/2025 10:00	0.7	1.4	2	0.45	0.22356	0.75
03/07/2025 11:00	0.7	1.4	2	0.45	0.22362	0.75
03/07/2025 12:00	0.7	1.4	2	0.45	0.22404	0.75
03/07/2025 13:00	0.6	1.4	2	0.45	0.22350	0.75
03/07/2025 14:00	0.6	1.3	1	0.45	0.22368	0.75
03/07/2025 15:00	0.6	1.3	1	0.45	0.22350	0.75
03/07/2025 16:00	0.7	1.4	1	0.51	0.25488	0.85
03/07/2025 17:00	0.6	1.5	2	0.65	0.32652	1.09
03/07/2025 18:00	0.7	1.4	2	0.64	0.32160	1.07
03/07/2025 19:00	0.8	1.4	2	0.64	0.32010	1.07
03/07/2025 20:00	0.9	1.4	2	0.64	0.31794	1.06
03/07/2025 21:00	0.9	1.5	2	0.64	0.31806	1.06
03/07/2025 22:00	1.0	1.4	2	0.63	0.31488	1.05
03/07/2025 23:00	1.0	1.4	2	0.63	0.31524	1.05
Average/Sum#:	0.9	1.4	2	0.58	0.28782	0.96
Minimum:	0.4	1.3	1	0.44	0.22248	0.74
Maximum:	1.5	1.5	2	0.74	0.36840	1.23
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/08/2025 00:00	1.1	1.4	2	0.63	0.31452	1.05
03/08/2025 01:00	1.2	1.4	2	0.63	0.31344	1.04
03/08/2025 02:00	1.2	1.5	2	0.62	0.31236	1.04
03/08/2025 03:00	1.2	1.5	2	0.63	0.31314	1.04
03/08/2025 04:00	1.2	1.4	2	0.63	0.31368	1.05
03/08/2025 05:00	1.1	1.5	2	0.63	0.31260	1.04
03/08/2025 06:00	1.1	1.4	2	0.62	0.31026	1.03
03/08/2025 07:00	1.0	1.4	2	0.55	0.27276	0.91
03/08/2025 08:00	0.8	1.4	2	0.44	0.22236	0.74
03/08/2025 09:00	0.7	1.4	2	0.45	0.22320	0.74
03/08/2025 10:00	0.7	1.3	2	0.45	0.22350	0.75
03/08/2025 11:00	0.7	1.4	1	0.45	0.22416	0.75
03/08/2025 12:00	0.6	1.4	1	0.45	0.22506	0.75
03/08/2025 13:00	0.6	1.3	2	0.45	0.22422	0.75
03/08/2025 14:00	0.6	1.3	1	0.44	0.22188	0.74
03/08/2025 15:00	0.6	1.4	1	0.44	0.22164	0.74
03/08/2025 16:00	0.7	1.4	1	0.51	0.25272	0.84
03/08/2025 17:00	0.4	1.5	2	0.68	0.34026	1.13
03/08/2025 18:00	0.6	1.4	2	0.65	0.32592	1.09
03/08/2025 19:00	0.8	1.4	2	0.63	0.31710	1.06
03/08/2025 20:00	0.7	1.4	2	0.65	0.32604	1.09
03/08/2025 21:00	0.7	1.4	2	0.65	0.32598	1.09
03/08/2025 22:00	1.1	1.4	2	0.63	0.31260	1.04
03/08/2025 23:00	1.1	1.4	2	0.63	0.31434	1.05
Average/Sum#:	0.9	1.4	2	0.56	0.28182	0.94
Minimum:	0.4	1.3	1	0.44	0.22164	0.74
Maximum:	1.2	1.5	2	0.68	0.34026	1.13
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/09/2025 00:00	0.9	1.4	2	0.65	0.32388	1.08
03/09/2025 01:00	0.6	1.5	2	0.68	0.33828	1.13
03/09/2025 02:00	0.6	1.5	2	0.67	0.33618	1.12
03/09/2025 03:00	1.2	1.5	2	0.63	0.31380	1.05
03/09/2025 04:00	1.2	1.4	2	0.63	0.31446	1.05
03/09/2025 05:00	1.1	1.4	2	0.63	0.31488	1.05
03/09/2025 06:00	1.1	1.5	2	0.63	0.31494	1.05
03/09/2025 07:00	0.9	1.4	2	0.50	0.25146	0.84
03/09/2025 08:00	0.8	1.4	2	0.44	0.22200	0.74
03/09/2025 09:00	0.8	1.4	2	0.45	0.22272	0.74
03/09/2025 10:00	0.7	1.4	2	0.45	0.22272	0.74
03/09/2025 11:00	0.7	1.3	1	0.45	0.22284	0.74
03/09/2025 12:00	0.7	1.4	1	0.44	0.22248	0.74
03/09/2025 13:00	0.6	1.4	1	0.45	0.22296	0.74
03/09/2025 14:00	0.6	1.4	1	0.45	0.22308	0.74
03/09/2025 15:00	0.6	1.3	1	0.45	0.22386	0.75
03/09/2025 16:00	0.6	1.3	1	0.48	0.23976	0.80
03/09/2025 17:00	0.6	1.5	2	0.67	0.33648	1.12
03/09/2025 18:00	0.5	1.4	2	0.67	0.33330	1.11
03/09/2025 19:00	0.6	1.4	2	0.66	0.33096	1.10
03/09/2025 20:00	0.6	1.4	2	0.66	0.33054	1.10
03/09/2025 21:00	0.6	1.5	2	0.66	0.33216	1.11
03/09/2025 22:00	0.9	1.4	2	0.63	0.31596	1.05
03/09/2025 23:00	1.0	1.4	2	0.64	0.31836	1.06
Average/Sum#:	0.8	1.4	2	0.57	0.28450	0.95
Minimum:	0.5	1.3	1	0.44	0.22200	0.74
Maximum:	1.2	1.5	2	0.68	0.33828	1.13
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/10/2025 00:00	1.1	1.4	2	0.63	0.31344	1.04
03/10/2025 01:00	1.1	1.4	2	0.63	0.31332	1.04
03/10/2025 02:00	1.1	1.4	2	0.63	0.31326	1.04
03/10/2025 03:00	1.2	1.5	2	0.63	0.31446	1.05
03/10/2025 04:00	1.2	1.4	2	0.63	0.31536	1.05
03/10/2025 05:00	0.9	1.4	2	0.66	0.33102	1.10
03/10/2025 06:00	0.3	1.5	3	0.77	0.38640	1.29
03/10/2025 07:00	1.2	1.4	2	0.63	0.31608	1.05
03/10/2025 08:00	0.9	1.3	2	0.48	0.23832	0.79
03/10/2025 09:00	0.8	1.4	1	0.47	0.23700	0.79
03/10/2025 10:00	0.8	1.4	2	0.45	0.22482	0.75
03/10/2025 11:00	0.7	1.3	2	0.45	0.22476	0.75
03/10/2025 12:00	0.7	1.3	1	0.45	0.22362	0.75
03/10/2025 13:00	0.7	1.4	1	0.45	0.22296	0.74
03/10/2025 14:00	0.7	1.3	1	0.44	0.22230	0.74
03/10/2025 15:00	0.6	1.3	1	0.45	0.22272	0.74
03/10/2025 16:00	0.7	1.3	1	0.48	0.23796	0.79
03/10/2025 17:00	0.6	1.5	2	0.65	0.32592	1.09
03/10/2025 18:00	0.5	1.4	2	0.65	0.32460	1.08
03/10/2025 19:00	0.6	1.4	2	0.64	0.31950	1.07
03/10/2025 20:00	0.7	1.4	2	0.64	0.31866	1.06
03/10/2025 21:00	0.9	1.4	2	0.63	0.31614	1.05
03/10/2025 22:00	1.0	1.4	2	0.63	0.31584	1.05
03/10/2025 23:00	0.8	1.5	2	0.65	0.32514	1.08
Average/Sum#:	0.8	1.4	2	0.58	0.28765	0.96
Minimum:	0.3	1.3	1	0.44	0.22230	0.74
Maximum:	1.2	1.5	3	0.77	0.38640	1.29
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/11/2025 00:00	0.9	1.4	2	0.64	0.31986	1.07
03/11/2025 01:00	0.9	1.4	2	0.64	0.32028	1.07
03/11/2025 02:00	0.9	1.4	2	0.64	0.32034	1.07
03/11/2025 03:00	0.9	1.4	2	0.64	0.31938	1.06
03/11/2025 04:00	0.9	1.4	2	0.64	0.31884	1.06
03/11/2025 05:00	1.0	1.4	2	0.64	0.31848	1.06
03/11/2025 06:00	0.9	1.4	2	0.65	0.32268	1.08
03/11/2025 07:00	0.9	1.4	2	0.64	0.31998	1.07
03/11/2025 08:00	0.8	1.4	2	0.65	0.32262	1.08
03/11/2025 09:00	0.9	1.4	1	0.59	0.29688	0.99
03/11/2025 10:00	0.7	1.4	1	0.47	0.23550	0.79
03/11/2025 11:00	0.7	1.4	1	0.44	0.22206	0.74
03/11/2025 12:00	0.7	1.4	1	0.44	0.22242	0.74
03/11/2025 13:00	0.6	1.3	2	0.44	0.22248	0.74
03/11/2025 14:00	0.6	1.4	1	0.44	0.22248	0.74
03/11/2025 15:00	0.6	1.4	1	0.45	0.22254	0.74
03/11/2025 16:00	0.9	1.3	1	0.48	0.23904	0.80
03/11/2025 17:00	0.6	1.4	1	0.65	0.32466	1.08
03/11/2025 18:00	0.5	1.4	2	0.68	0.33834	1.13
03/11/2025 19:00	0.5	1.4	2	0.67	0.33636	1.12
03/11/2025 20:00	0.6	1.4	2	0.66	0.33108	1.10
03/11/2025 21:00	0.6	1.4	2	0.66	0.33096	1.10
03/11/2025 22:00	0.7	1.4	2	0.65	0.32436	1.08
03/11/2025 23:00	0.6	1.4	2	0.66	0.32904	1.10
Average/Sum#:	0.7	1.4	2	0.59	0.29503	0.98
Minimum:	0.5	1.3	1	0.44	0.22206	0.74
Maximum:	1.0	1.4	2	0.68	0.33834	1.13
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/12/2025 00:00	0.9	1.4	2	0.63	0.31602	1.05
03/12/2025 01:00	0.9	1.4	2	0.63	0.31578	1.05
03/12/2025 02:00	0.9	1.5	2	0.63	0.31590	1.05
03/12/2025 03:00	0.9	1.5	2	0.63	0.31680	1.06
03/12/2025 04:00	0.8	1.4	2	0.64	0.31956	1.07
03/12/2025 05:00	0.6	1.4	2	0.66	0.32904	1.10
03/12/2025 06:00	0.7	1.4	2	0.65	0.32364	1.08
03/12/2025 07:00	0.8	1.4	2	0.63	0.31698	1.06
03/12/2025 08:00	0.8	1.5	2	0.63	0.31740	1.06
03/12/2025 09:00	0.7	1.4	2	0.64	0.31950	1.07
03/12/2025 10:00	0.8	1.4	2	0.63	0.31680	1.06
03/12/2025 11:00	0.7	1.4	2	0.63	0.31650	1.06
03/12/2025 12:00	0.7	1.4	2	0.63	0.31620	1.05
03/12/2025 13:00	0.7	1.4	2	0.63	0.31530	1.05
03/12/2025 14:00	0.8	1.4	2	0.63	0.31518	1.05
03/12/2025 15:00	0.9	1.4	2	0.63	0.31476	1.05
03/12/2025 16:00	0.8	1.5	2	0.66	0.32862	1.10
03/12/2025 17:00	0.7	1.5	2	0.65	0.32478	1.08
03/12/2025 18:00	0.9	1.4	2	0.63	0.31362	1.05
03/12/2025 19:00	0.9	1.4	2	0.63	0.31482	1.05
03/12/2025 20:00	0.9	1.5	2	0.64	0.31770	1.06
03/12/2025 21:00	0.7	1.4	2	0.66	0.32976	1.10
03/12/2025 22:00	0.6	1.4	2	0.66	0.33054	1.10
03/12/2025 23:00	0.8	1.5	2	0.64	0.32184	1.07
Average/Sum#:	0.8	1.4	2	0.64	0.31946	1.07
Minimum:	0.6	1.4	2	0.63	0.31362	1.05
Maximum:	0.9	1.5	2	0.66	0.33054	1.10
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/13/2025 00:00	0.9	1.4	2	0.63	0.31680	1.06
03/13/2025 01:00	0.9	1.4	2	0.63	0.31584	1.05
03/13/2025 02:00	0.9	1.4	2	0.63	0.31566	1.05
03/13/2025 03:00	1.0	1.5	2	0.63	0.31596	1.05
03/13/2025 04:00	0.9	1.4	2	0.63	0.31656	1.06
03/13/2025 05:00	0.9	1.4	2	0.63	0.31740	1.06
03/13/2025 06:00	0.7	1.5	2	0.66	0.33078	1.10
03/13/2025 07:00	0.7	1.4	2	0.66	0.33030	1.10
03/13/2025 08:00	0.6	1.5	2	0.67	0.33720	1.12
03/13/2025 09:00	0.9	1.4	2	0.64	0.31824	1.06
03/13/2025 10:00	0.9	1.4	2	0.63	0.31728	1.06
03/13/2025 11:00	0.8	1.4	2	0.60	0.30216	1.01
03/13/2025 12:00	0.7	1.4	2	0.45	0.22356	0.75
03/13/2025 13:00	0.7	1.4	2	0.45	0.22326	0.74
03/13/2025 14:00	0.7	1.3	2	0.44	0.22218	0.74
03/13/2025 15:00	0.7	1.4	2	0.45	0.22362	0.75
03/13/2025 16:00	0.7	1.4	2	0.45	0.22374	0.75
03/13/2025 17:00	0.6	1.3	1	0.51	0.25572	0.85
03/13/2025 18:00	0.8	1.4	1	0.56	0.27990	0.93
03/13/2025 19:00	0.9	1.4	2	0.63	0.31722	1.06
03/13/2025 20:00	0.7	1.4	2	0.65	0.32598	1.09
03/13/2025 21:00	0.7	1.5	2	0.65	0.32592	1.09
03/13/2025 22:00	0.8	1.5	2	0.64	0.32070	1.07
03/13/2025 23:00	0.6	1.5	2	0.67	0.33720	1.12
Average/Sum#:	0.8	1.4	2	0.59	0.29638	0.99
Minimum:	0.6	1.3	1	0.44	0.22218	0.74
Maximum:	1.0	1.5	2	0.67	0.33720	1.12
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/14/2025 00:00	0.9	1.4	2	0.64	0.31830	1.06
03/14/2025 01:00	1.0	1.4	2	0.63	0.31446	1.05
03/14/2025 02:00	1.0	1.4	2	0.63	0.31386	1.05
03/14/2025 03:00	1.1	1.4	2	0.63	0.31368	1.05
03/14/2025 04:00	1.0	1.4	2	0.63	0.31584	1.05
03/14/2025 05:00	0.8	1.5	2	0.65	0.32742	1.09
03/14/2025 06:00	0.7	1.5	2	0.66	0.33156	1.11
03/14/2025 07:00	0.4	1.6	2	0.74	0.36924	1.23
03/14/2025 08:00	0.3	1.4	3	0.77	0.38532	1.28
03/14/2025 09:00	0.9	1.4	2	0.64	0.31776	1.06
03/14/2025 10:00	1.1	1.4	2	0.62	0.31152	1.04
03/14/2025 11:00	1.1	1.4	2	0.63	0.31260	1.04
03/14/2025 12:00	1.0	1.4	2	0.63	0.31506	1.05
03/14/2025 13:00	0.9	1.4	2	0.63	0.31680	1.06
03/14/2025 14:00	0.8	1.4	2	0.64	0.31830	1.06
03/14/2025 15:00	0.9	1.4	2	0.64	0.31770	1.06
03/14/2025 16:00	0.8	1.4	2	0.64	0.31968	1.07
03/14/2025 17:00	0.7	1.4	2	0.65	0.32580	1.09
03/14/2025 18:00	0.8	1.4	2	0.64	0.31812	1.06
03/14/2025 19:00	1.0	1.4	2	0.63	0.31386	1.05
03/14/2025 20:00	1.0	1.4	2	0.63	0.31326	1.04
03/14/2025 21:00	1.0	1.4	2	0.63	0.31332	1.04
03/14/2025 22:00	1.0	1.4	2	0.63	0.31620	1.05
03/14/2025 23:00	1.0	1.4	2	0.63	0.31410	1.05
Average/Sum#:	0.9	1.4	2	0.65	0.32224	1.07
Minimum:	0.3	1.4	2	0.62	0.31152	1.04
Maximum:	1.1	1.6	3	0.77	0.38532	1.28
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/15/2025 00:00	1.1	1.4	2	0.63	0.31308	1.04
03/15/2025 01:00	1.1	1.4	2	0.63	0.31254	1.04
03/15/2025 02:00	1.1	1.4	2	0.62	0.31236	1.04
03/15/2025 03:00	1.2	1.4	2	0.63	0.31254	1.04
03/15/2025 04:00	1.1	1.4	2	0.63	0.31380	1.05
03/15/2025 05:00	1.1	1.4	2	0.62	0.31230	1.04
03/15/2025 06:00	1.1	1.4	2	0.62	0.31230	1.04
03/15/2025 07:00	1.1	1.4	2	0.63	0.31314	1.04
03/15/2025 08:00	1.0	1.4	2	0.63	0.31398	1.05
03/15/2025 09:00	1.0	1.4	2	0.63	0.31452	1.05
03/15/2025 10:00	0.9	1.4	2	0.63	0.31488	1.05
03/15/2025 11:00	0.9	1.4	2	0.63	0.31524	1.05
03/15/2025 12:00	0.8	1.3	2	0.50	0.24762	0.83
03/15/2025 13:00	0.8	1.3	1	0.44	0.22068	0.74
03/15/2025 14:00	0.7	1.3	1	0.44	0.22020	0.73
03/15/2025 15:00	0.7	1.4	1	0.44	0.22050	0.74
03/15/2025 16:00	0.7	1.4	1	0.44	0.21990	0.73
03/15/2025 17:00	0.7	1.4	1	0.48	0.24096	0.80
03/15/2025 18:00	0.7	1.3	2	0.44	0.22074	0.74
03/15/2025 19:00	0.7	1.4	1	0.45	0.22314	0.74
03/15/2025 20:00	0.8	1.4	1	0.56	0.27948	0.93
03/15/2025 21:00	1.0	1.4	1	0.62	0.31098	1.04
03/15/2025 22:00	1.0	1.4	2	0.63	0.31470	1.05
03/15/2025 23:00	1.0	1.4	2	0.63	0.31614	1.05
Average/Sum#:	0.9	1.4	2	0.57	0.28316	0.94
Minimum:	0.7	1.3	1	0.44	0.21990	0.73
Maximum:	1.2	1.4	2	0.63	0.31614	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/16/2025 00:00	1.0	1.4	2	0.63	0.31626	1.05
03/16/2025 01:00	1.0	1.4	2	0.63	0.31608	1.05
03/16/2025 02:00	1.0	1.4	2	0.63	0.31566	1.05
03/16/2025 03:00	1.1	1.4	2	0.63	0.31572	1.05
03/16/2025 04:00	1.1	1.4	2	0.63	0.31518	1.05
03/16/2025 05:00	1.0	1.4	2	0.64	0.31758	1.06
03/16/2025 06:00	0.9	1.4	2	0.64	0.31872	1.06
03/16/2025 07:00	1.0	1.4	2	0.55	0.27546	0.92
03/16/2025 08:00	0.7	1.3	2	0.44	0.22218	0.74
03/16/2025 09:00	0.7	1.4	2	0.45	0.22302	0.74
03/16/2025 10:00	0.7	1.4	2	0.45	0.22320	0.74
03/16/2025 11:00	0.6	1.4	1	0.45	0.22362	0.75
03/16/2025 12:00	0.6	1.3	2	0.45	0.22290	0.74
03/16/2025 13:00	0.6	1.2	1	0.44	0.22092	0.74
03/16/2025 14:00	0.6	1.4	1	0.44	0.22194	0.74
03/16/2025 15:00	0.6	1.4	1	0.44	0.22200	0.74
03/16/2025 16:00	0.7	1.4	1	0.44	0.22170	0.74
03/16/2025 17:00	0.8	1.3	1	0.51	0.25410	0.85
03/16/2025 18:00	0.6	1.4	1	0.64	0.32094	1.07
03/16/2025 19:00	0.8	1.4	2	0.63	0.31680	1.06
03/16/2025 20:00	0.9	1.4	2	0.63	0.31518	1.05
03/16/2025 21:00	0.9	1.4	2	0.63	0.31650	1.06
03/16/2025 22:00	0.9	1.4	2	0.63	0.31464	1.05
03/16/2025 23:00	0.9	1.4	2	0.63	0.31458	1.05
Average/Sum#:	0.8	1.4	2	0.55	0.27687	0.92
Minimum:	0.6	1.2	1	0.44	0.22092	0.74
Maximum:	1.1	1.4	2	0.64	0.32094	1.07
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/17/2025 00:00	1.0	1.4	2	0.63	0.31338	1.04
03/17/2025 01:00	0.9	1.4	2	0.63	0.31572	1.05
03/17/2025 02:00	0.9	1.5	2	0.63	0.31746	1.06
03/17/2025 03:00	1.0	1.5	2	0.63	0.31668	1.06
03/17/2025 04:00	0.9	1.4	2	0.64	0.31962	1.07
03/17/2025 05:00	0.9	1.4	2	0.63	0.31722	1.06
03/17/2025 06:00	0.8	1.4	2	0.65	0.32412	1.08
03/17/2025 07:00	0.3	1.5	2	0.76	0.38016	1.27
03/17/2025 08:00	1.0	1.4	2	0.62	0.31146	1.04
03/17/2025 09:00	1.0	1.4	2	0.62	0.31104	1.04
03/17/2025 10:00	1.0	1.4	2	0.62	0.31068	1.04
03/17/2025 11:00	0.8	1.3	2	0.52	0.26052	0.87
03/17/2025 12:00	0.7	1.3	1	0.44	0.22050	0.74
03/17/2025 13:00	0.7	1.4	1	0.44	0.22188	0.74
03/17/2025 14:00	0.7	1.3	2	0.44	0.22200	0.74
03/17/2025 15:00	0.7	1.4	1	0.44	0.22248	0.74
03/17/2025 16:00	0.7	1.3	2	0.45	0.22272	0.74
03/17/2025 17:00	0.9	1.3	1	0.51	0.25542	0.85
03/17/2025 18:00	1.1	1.4	2	0.62	0.31164	1.04
03/17/2025 19:00	1.0	1.4	2	0.62	0.31236	1.04
03/17/2025 20:00	1.0	1.4	2	0.63	0.31392	1.05
03/17/2025 21:00	1.1	1.4	2	0.63	0.31272	1.04
03/17/2025 22:00	1.0	1.4	2	0.63	0.31338	1.04
03/17/2025 23:00	0.9	1.4	2	0.51	0.25476	0.85
Average/Sum#:	0.9	1.4	2	0.58	0.29091	0.97
Minimum:	0.3	1.3	1	0.44	0.22050	0.74
Maximum:	1.1	1.5	2	0.76	0.38016	1.27
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/18/2025 00:00	0.7	1.4	2	0.45	0.22326	0.74
03/18/2025 01:00	0.7	1.4	2	0.45	0.22374	0.75
03/18/2025 02:00	0.8	1.4	2	0.45	0.22350	0.75
03/18/2025 03:00	0.8	1.4	2	0.45	0.22362	0.75
03/18/2025 04:00	0.9	1.4	2	0.52	0.25782	0.86
03/18/2025 05:00	1.2	1.5	2	0.63	0.31638	1.05
03/18/2025 06:00	1.2	1.4	2	0.63	0.31554	1.05
03/18/2025 07:00	1.2	1.5	2	0.63	0.31602	1.05
03/18/2025 08:00	1.1	1.4	2	0.63	0.31272	1.04
03/18/2025 09:00	1.0	1.4	2	0.55	0.27606	0.92
03/18/2025 10:00	0.7	1.4	2	0.45	0.22362	0.75
03/18/2025 11:00	0.7	1.4	2	0.45	0.22398	0.75
03/18/2025 12:00	0.7	1.4	2	0.45	0.22386	0.75
03/18/2025 13:00	0.7	1.4	2	0.45	0.22374	0.75
03/18/2025 14:00	0.7	1.4	2	0.44	0.22194	0.74
03/18/2025 15:00	0.6	1.3	2	0.44	0.22194	0.74
03/18/2025 16:00	0.6	1.3	2	0.44	0.22140	0.74
03/18/2025 17:00	0.6	1.3	1	0.49	0.24450	0.82
03/18/2025 18:00	0.6	1.3	2	0.44	0.22206	0.74
03/18/2025 19:00	0.7	1.4	2	0.44	0.22062	0.74
03/18/2025 20:00	0.7	1.4	2	0.44	0.22134	0.74
03/18/2025 21:00	0.8	1.4	2	0.44	0.22242	0.74
03/18/2025 22:00	0.8	1.3	2	0.45	0.22266	0.74
03/18/2025 23:00	0.6	1.4	1	0.55	0.27408	0.91
Average/Sum#:	0.8	1.4	2	0.49	0.24487	0.82
Minimum:	0.6	1.3	1	0.44	0.22062	0.74
Maximum:	1.2	1.5	2	0.63	0.31638	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/19/2025 00:00	0.7	1.4	2	0.51	0.25500	0.85
03/19/2025 01:00	0.8	1.4	1	0.56	0.27978	0.93
03/19/2025 02:00	1.0	1.5	2	0.64	0.31800	1.06
03/19/2025 03:00	1.1	1.5	2	0.63	0.31506	1.05
03/19/2025 04:00	1.1	1.4	2	0.62	0.31002	1.03
03/19/2025 05:00	0.9	1.5	2	0.65	0.32430	1.08
03/19/2025 06:00	0.9	1.5	2	0.64	0.32142	1.07
03/19/2025 07:00	1.1	1.4	2	0.62	0.31002	1.03
03/19/2025 08:00	1.0	1.4	2	0.60	0.29796	0.99
03/19/2025 09:00	0.7	1.3	2	0.44	0.22194	0.74
03/19/2025 10:00	0.7	1.3	2	0.44	0.22098	0.74
03/19/2025 11:00	0.7	1.3	2	0.44	0.22158	0.74
03/19/2025 12:00	0.6	1.4	1	0.52	0.25992	0.87
03/19/2025 13:00	0.7	1.3	2	0.44	0.22074	0.74
03/19/2025 14:00	0.7	1.4	2	0.44	0.22110	0.74
03/19/2025 15:00	0.7	1.3	1	0.50	0.25176	0.84
03/19/2025 16:00	0.9	1.3	1	0.51	0.25524	0.85
03/19/2025 17:00	0.7	1.4	2	0.65	0.32586	1.09
03/19/2025 18:00	0.9	1.4	2	0.63	0.31620	1.05
03/19/2025 19:00	0.8	1.4	2	0.64	0.31758	1.06
03/19/2025 20:00	0.7	1.5	2	0.66	0.32850	1.10
03/19/2025 21:00	0.8	1.4	2	0.65	0.32550	1.09
03/19/2025 22:00	1.0	1.4	2	0.63	0.31326	1.04
03/19/2025 23:00	1.0	1.4	2	0.64	0.31824	1.06
Average/Sum#:	0.8	1.4	2	0.57	0.28542	0.95
Minimum:	0.6	1.3	1	0.44	0.22074	0.74
Maximum:	1.1	1.5	2	0.66	0.32850	1.10
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/20/2025 00:00	1.1	1.4	2	0.63	0.31314	1.04
03/20/2025 01:00	1.1	1.4	2	0.63	0.31344	1.04
03/20/2025 02:00	1.1	1.5	2	0.63	0.31398	1.05
03/20/2025 03:00	1.1	1.4	2	0.63	0.31494	1.05
03/20/2025 04:00	1.1	1.4	2	0.63	0.31254	1.04
03/20/2025 05:00	1.3	1.4	2	0.62	0.31140	1.04
03/20/2025 06:00	1.1	1.4	2	0.62	0.31176	1.04
03/20/2025 07:00	1.1	1.4	2	0.60	0.30132	1.00
03/20/2025 08:00	0.8	1.3	2	0.44	0.22242	0.74
03/20/2025 09:00	0.8	1.4	2	0.45	0.22368	0.75
03/20/2025 10:00	0.8	1.3	2	0.45	0.22416	0.75
03/20/2025 11:00	0.7	1.4	2	0.45	0.22410	0.75
03/20/2025 12:00	0.7	1.4	2	0.45	0.22428	0.75
03/20/2025 13:00	0.7	1.4	2	0.45	0.22368	0.75
03/20/2025 14:00	0.7	1.3	2	0.45	0.22356	0.75
03/20/2025 15:00	0.7	1.4	1	0.45	0.22326	0.74
03/20/2025 16:00	0.7	1.3	2	0.44	0.22152	0.74
03/20/2025 17:00	0.7	1.4	1	0.46	0.23244	0.77
03/20/2025 18:00	0.8	1.3	2	0.44	0.22062	0.74
03/20/2025 19:00	0.7	1.4	2	0.44	0.22056	0.74
03/20/2025 20:00	0.7	1.3	1	0.48	0.23760	0.79
03/20/2025 21:00	1.2	1.4	2	0.63	0.31326	1.04
03/20/2025 22:00	1.3	1.4	2	0.63	0.31548	1.05
03/20/2025 23:00	2.0	1.4	2	0.63	0.31494	1.05
Average/Sum#:	1.0	1.4	2	0.53	0.26492	0.88
Minimum:	0.7	1.3	1	0.44	0.22056	0.74
Maximum:	2.0	1.5	2	0.63	0.31548	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/21/2025 00:00	1.8	1.4	2	0.63	0.31482	1.05
03/21/2025 01:00	2.5	1.4	2	0.63	0.31386	1.05
03/21/2025 02:00	1.4	1.4	2	0.63	0.31380	1.05
03/21/2025 03:00	1.4	1.5	2	0.63	0.31380	1.05
03/21/2025 04:00	1.2	1.4	2	0.63	0.31380	1.05
03/21/2025 05:00	1.2	1.4	2	0.63	0.31326	1.04
03/21/2025 06:00	1.2	1.4	2	0.63	0.31374	1.05
03/21/2025 07:00	1.2	1.4	2	0.63	0.31380	1.05
03/21/2025 08:00	0.9	1.3	2	0.46	0.23160	0.77
03/21/2025 09:00	0.9	1.4	1	0.44	0.22236	0.74
03/21/2025 10:00	0.8	1.4	2	0.45	0.22344	0.74
03/21/2025 11:00	0.8	1.3	2	0.44	0.22224	0.74
03/21/2025 12:00	0.8	1.4	1	0.44	0.22152	0.74
03/21/2025 13:00	0.7	1.3	2	0.44	0.22128	0.74
03/21/2025 14:00	0.7	1.4	1	0.44	0.22128	0.74
03/21/2025 15:00	0.7	1.3	1	0.44	0.22122	0.74
03/21/2025 16:00	0.7	1.3	1	0.44	0.22140	0.74
03/21/2025 17:00	0.7	1.3	1	0.45	0.22488	0.75
03/21/2025 18:00	0.7	1.4	1	0.44	0.22092	0.74
03/21/2025 19:00	0.8	1.4	2	0.44	0.21990	0.73
03/21/2025 20:00	0.7	1.3	2	0.44	0.21942	0.73
03/21/2025 21:00	0.8	1.4	2	0.44	0.21966	0.73
03/21/2025 22:00	0.9	1.4	2	0.44	0.21936	0.73
03/21/2025 23:00	0.9	1.3	2	0.44	0.21942	0.73
Average/Sum#:	1.0	1.4	2	0.51	0.25253	0.84
Minimum:	0.7	1.3	1	0.44	0.21936	0.73
Maximum:	2.5	1.5	2	0.63	0.31482	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/22/2025 00:00	0.8	1.3	2	0.44	0.21954	0.73
03/22/2025 01:00	0.8	1.4	1	0.44	0.21900	0.73
03/22/2025 02:00	0.8	1.6	2	0.44	0.21906	0.73
03/22/2025 03:00	0.9	1.4	2	0.44	0.21900	0.73
03/22/2025 04:00	0.8	1.3	2	0.44	0.22056	0.74
03/22/2025 05:00	0.8	1.4	2	0.44	0.22116	0.74
03/22/2025 06:00	0.8	1.3	2	0.44	0.22110	0.74
03/22/2025 07:00	0.8	1.4	2	0.44	0.22164	0.74
03/22/2025 08:00	0.8	1.3	1	0.44	0.22170	0.74
03/22/2025 09:00	0.7	1.4	2	0.44	0.22230	0.74
03/22/2025 10:00	0.7	1.3	1	0.44	0.22206	0.74
03/22/2025 11:00	0.7	1.3	1	0.45	0.22284	0.74
03/22/2025 12:00	0.7	1.4	1	0.44	0.22116	0.74
03/22/2025 13:00	0.7	1.3	1	0.44	0.22074	0.74
03/22/2025 14:00	0.7	1.3	1	0.44	0.22062	0.74
03/22/2025 15:00	0.7	1.3	1	0.44	0.22056	0.74
03/22/2025 16:00	0.7	1.3	1	0.44	0.22026	0.73
03/22/2025 17:00	0.7	1.3	1	0.45	0.22350	0.75
03/22/2025 18:00	0.7	1.3	1	0.44	0.22050	0.74
03/22/2025 19:00	0.7	1.3	1	0.44	0.22062	0.74
03/22/2025 20:00	0.7	1.3	2	0.44	0.22026	0.73
03/22/2025 21:00	0.8	1.4	1	0.44	0.22020	0.73
03/22/2025 22:00	0.9	1.3	2	0.44	0.21960	0.73
03/22/2025 23:00	1.0	1.3	2	0.44	0.21930	0.73
Average/Sum#:	0.8	1.3	1	0.44	0.22072	0.74
Minimum:	0.7	1.3	1	0.44	0.21900	0.73
Maximum:	1.0	1.6	2	0.45	0.22350	0.75
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/23/2025 00:00	0.9	1.4	2	0.44	0.21990	0.73
03/23/2025 01:00	0.9	1.3	2	0.44	0.22080	0.74
03/23/2025 02:00	0.9	1.3	2	0.45	0.22260	0.74
03/23/2025 03:00	0.9	1.3	2	0.45	0.22302	0.74
03/23/2025 04:00	0.8	1.3	2	0.45	0.22266	0.74
03/23/2025 05:00	0.9	1.4	2	0.45	0.22260	0.74
03/23/2025 06:00	0.9	1.3	2	0.45	0.22698	0.76
03/23/2025 07:00	0.8	1.3	2	0.45	0.22350	0.75
03/23/2025 08:00	0.8	1.3	2	0.45	0.22368	0.75
03/23/2025 09:00	0.8	1.3	1	0.45	0.22392	0.75
03/23/2025 10:00	0.8	1.3	2	0.45	0.22320	0.74
03/23/2025 11:00	0.7	1.3	1	0.45	0.22296	0.74
03/23/2025 12:00	0.7	1.3	1	0.44	0.22230	0.74
03/23/2025 13:00	0.7	1.4	1	0.45	0.22260	0.74
03/23/2025 14:00	0.7	1.3	1	0.45	0.22254	0.74
03/23/2025 15:00	0.7	1.3	1	0.45	0.22260	0.74
03/23/2025 16:00	0.7	1.4	1	0.44	0.22176	0.74
03/23/2025 17:00	0.8	1.3	1	0.50	0.25176	0.84
03/23/2025 18:00	0.6	1.4	1	0.64	0.32226	1.07
03/23/2025 19:00	0.7	1.4	1	0.63	0.31560	1.05
03/23/2025 20:00	1.0	1.4	2	0.63	0.31386	1.05
03/23/2025 21:00	1.0	1.4	2	0.63	0.31374	1.05
03/23/2025 22:00	1.0	1.4	1	0.63	0.31320	1.04
03/23/2025 23:00	1.0	1.5	2	0.63	0.31620	1.05
Average/Sum#:	0.8	1.3	2	0.50	0.24726	0.82
Minimum:	0.6	1.3	1	0.44	0.21990	0.73
Maximum:	1.0	1.5	2	0.64	0.32226	1.07
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/24/2025 00:00	0.9	1.4	2	0.64	0.31824	1.06
03/24/2025 01:00	1.0	1.4	2	0.64	0.31794	1.06
03/24/2025 02:00	0.9	1.4	2	0.63	0.31716	1.06
03/24/2025 03:00	1.1	1.5	2	0.63	0.31602	1.05
03/24/2025 04:00	1.1	1.4	2	0.63	0.31440	1.05
03/24/2025 05:00	1.2	1.4	2	0.63	0.31362	1.05
03/24/2025 06:00	1.3	1.4	2	0.62	0.31224	1.04
03/24/2025 07:00	1.1	1.3	2	0.47	0.23616	0.79
03/24/2025 08:00	0.9	1.4	1	0.44	0.22230	0.74
03/24/2025 09:00	0.9	1.3	1	0.44	0.22206	0.74
03/24/2025 10:00	0.8	1.4	1	0.44	0.22110	0.74
03/24/2025 11:00	0.7	1.4	1	0.44	0.22146	0.74
03/24/2025 12:00	0.7	1.3	1	0.44	0.22152	0.74
03/24/2025 13:00	0.7	1.4	1	0.44	0.22146	0.74
03/24/2025 14:00	0.7	1.4	1	0.44	0.22098	0.74
03/24/2025 15:00	0.7	1.3	1	0.44	0.21990	0.73
03/24/2025 16:00	0.7	1.4	1	0.44	0.21906	0.73
03/24/2025 17:00	0.8	1.3	1	0.50	0.24894	0.83
03/24/2025 18:00	0.6	1.4	1	0.64	0.32094	1.07
03/24/2025 19:00	0.6	1.4	1	0.64	0.31914	1.06
03/24/2025 20:00	0.9	1.4	1	0.64	0.31788	1.06
03/24/2025 21:00	0.8	1.4	1	0.63	0.31722	1.06
03/24/2025 22:00	0.9	1.4	1	0.64	0.31914	1.06
03/24/2025 23:00	1.2	1.4	2	0.64	0.31878	1.06
Average/Sum#:	0.9	1.4	1	0.55	0.27490	0.92
Minimum:	0.6	1.3	1	0.44	0.21906	0.73
Maximum:	1.3	1.5	2	0.64	0.32094	1.07
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/25/2025 00:00	1.1	1.4	1	0.64	0.31806	1.06
03/25/2025 01:00	1.1	1.4	2	0.64	0.31788	1.06
03/25/2025 02:00	1.1	1.4	1	0.64	0.31782	1.06
03/25/2025 03:00	1.1	1.4	2	0.64	0.31752	1.06
03/25/2025 04:00	1.1	1.4	2	0.63	0.31722	1.06
03/25/2025 05:00	1.3	1.4	2	0.63	0.31596	1.05
03/25/2025 06:00	1.3	1.3	2	0.54	0.27066	0.90
03/25/2025 07:00	1.2	1.3	1	0.44	0.22158	0.74
03/25/2025 08:00	0.9	1.3	1	0.44	0.22236	0.74
03/25/2025 09:00	0.8	1.4	1	0.44	0.22248	0.74
03/25/2025 10:00	0.8	1.4	1	0.45	0.22272	0.74
03/25/2025 11:00	0.8	1.2	1	0.44	0.22164	0.74
03/25/2025 12:00	0.7	1.3	1	0.44	0.22062	0.74
03/25/2025 13:00	0.7	1.3	1	0.44	0.22092	0.74
03/25/2025 14:00	0.7	1.3	1	0.44	0.22032	0.73
03/25/2025 15:00	0.7	1.3	1	0.44	0.22050	0.74
03/25/2025 16:00	0.7	1.4	1	0.44	0.21972	0.73
03/25/2025 17:00	0.7	1.3	1	0.44	0.21954	0.73
03/25/2025 18:00	0.8	1.3	1	0.44	0.21864	0.73
03/25/2025 19:00	0.8	1.4	1	0.44	0.21924	0.73
03/25/2025 20:00	1.1	1.3	1	0.44	0.21996	0.73
03/25/2025 21:00	1.1	1.3	1	0.44	0.21984	0.73
03/25/2025 22:00	0.9	1.4	1	0.44	0.21990	0.73
03/25/2025 23:00	0.8	1.4	1	0.44	0.22020	0.73
Average/Sum#:	0.9	1.3	1	0.49	0.24689	0.82
Minimum:	0.7	1.2	1	0.44	0.21864	0.73
Maximum:	1.3	1.4	2	0.64	0.31806	1.06
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/26/2025 00:00	0.9	1.3	1	0.44	0.22056	0.74
03/26/2025 01:00	1.0	1.3	1	0.44	0.22002	0.73
03/26/2025 02:00	0.8	1.4	1	0.44	0.21948	0.73
03/26/2025 03:00	0.8	1.3	1	0.44	0.21990	0.73
03/26/2025 04:00	0.8	1.4	1	0.44	0.21936	0.73
03/26/2025 05:00	0.8	1.4	1	0.44	0.21960	0.73
03/26/2025 06:00	0.8	1.3	1	0.44	0.22032	0.73
03/26/2025 07:00	0.8	1.3	1	0.44	0.22104	0.74
03/26/2025 08:00	0.7	1.3	1	0.44	0.22230	0.74
03/26/2025 09:00	0.7	1.2	1	0.44	0.21954	0.73
03/26/2025 10:00	0.7	1.3	1	0.45	0.22362	0.75
03/26/2025 11:00	0.6	1.4	1	0.45	0.22470	0.75
03/26/2025 12:00	0.6	1.3	1	0.45	0.22296	0.74
03/26/2025 13:00	0.6	1.3	1	0.44	0.22242	0.74
03/26/2025 14:00	0.6	1.3	1	0.45	0.22278	0.74
03/26/2025 15:00	0.6	1.3	1	0.45	0.22308	0.74
03/26/2025 16:00	0.6	1.3	1	0.45	0.22344	0.74
03/26/2025 17:00	0.6	1.3	1	0.47	0.23640	0.79
03/26/2025 18:00	0.6	1.4	2	0.45	0.22386	0.75
03/26/2025 19:00	0.7	1.4	1	0.45	0.22404	0.75
03/26/2025 20:00	0.7	1.3	1	0.45	0.22392	0.75
03/26/2025 21:00	0.7	1.4	1	0.45	0.22416	0.75
03/26/2025 22:00	0.7	1.3	2	0.45	0.22446	0.75
03/26/2025 23:00	0.7	1.3	1	0.45	0.22422	0.75
Average/Sum#:	0.7	1.3	1	0.45	0.22276	0.74
Minimum:	0.6	1.2	1	0.44	0.21936	0.73
Maximum:	1.0	1.4	2	0.47	0.23640	0.79
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/27/2025 00:00	0.7	1.3	2	0.45	0.22404	0.75
03/27/2025 01:00	0.7	1.4	1	0.45	0.22332	0.74
03/27/2025 02:00	0.7	1.4	1	0.45	0.22326	0.74
03/27/2025 03:00	0.8	1.3	1	0.45	0.22308	0.74
03/27/2025 04:00	0.7	1.3	1	0.45	0.22302	0.74
03/27/2025 05:00	0.7	1.3	1	0.45	0.22368	0.75
03/27/2025 06:00	0.7	1.4	1	0.45	0.22452	0.75
03/27/2025 07:00	0.7	1.3	2	0.45	0.22416	0.75
03/27/2025 08:00	0.7	1.3	1	0.45	0.22392	0.75
03/27/2025 09:00	0.7	1.4	1	0.45	0.22362	0.75
03/27/2025 10:00	0.6	1.3	2	0.45	0.22344	0.74
03/27/2025 11:00	0.6	1.4	1	0.45	0.22404	0.75
03/27/2025 12:00	0.6	1.3	1	0.45	0.22326	0.74
03/27/2025 13:00	0.6	1.3	1	0.45	0.22386	0.75
03/27/2025 14:00	0.7	1.3	2	0.45	0.22398	0.75
03/27/2025 15:00	0.7	1.3	1	0.45	0.22338	0.74
03/27/2025 16:00	0.7	1.3	1	0.44	0.22248	0.74
03/27/2025 17:00	0.7	1.3	1	0.44	0.22194	0.74
03/27/2025 18:00	0.7	1.3	1	0.44	0.22236	0.74
03/27/2025 19:00	0.7	1.3	2	0.45	0.22254	0.74
03/27/2025 20:00	0.7	1.3	2	0.44	0.22224	0.74
03/27/2025 21:00	0.7	1.3	2	0.45	0.22254	0.74
03/27/2025 22:00	0.7	1.3	2	0.45	0.22296	0.74
03/27/2025 23:00	0.7	1.3	2	0.45	0.22350	0.75
Average/Sum#:	0.7	1.3	1	0.45	0.22330	0.74
Minimum:	0.6	1.3	1	0.44	0.22194	0.74
Maximum:	0.8	1.4	2	0.45	0.22452	0.75
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/28/2025 00:00	0.7	1.2	2	0.45	0.22254	0.74
03/28/2025 01:00	0.7	1.3	1	0.45	0.22296	0.74
03/28/2025 02:00	0.7	1.5	2	0.45	0.22284	0.74
03/28/2025 03:00	0.8	1.3	2	0.44	0.22230	0.74
03/28/2025 04:00	0.7	1.3	2	0.44	0.22248	0.74
03/28/2025 05:00	0.7	1.3	1	0.45	0.22278	0.74
03/28/2025 06:00	0.7	1.3	2	0.45	0.22392	0.75
03/28/2025 07:00	0.7	1.3	2	0.45	0.22470	0.75
03/28/2025 08:00	0.7	1.3	1	0.45	0.22494	0.75
03/28/2025 09:00	0.7	1.4	1	0.45	0.22476	0.75
03/28/2025 10:00	0.7	1.4	1	0.45	0.22530	0.75
03/28/2025 11:00	0.6	1.4	1	0.45	0.22548	0.75
03/28/2025 12:00	0.6	1.4	1	0.45	0.22530	0.75
03/28/2025 13:00	0.6	1.3	1	0.45	0.22548	0.75
03/28/2025 14:00	0.6	1.3	1	0.45	0.22362	0.75
03/28/2025 15:00	0.6	1.4	1	0.45	0.22326	0.74
03/28/2025 16:00	0.6	1.4	1	0.45	0.22314	0.74
03/28/2025 17:00	0.6	1.4	1	0.45	0.22308	0.74
03/28/2025 18:00	0.6	1.3	2	0.45	0.22326	0.74
03/28/2025 19:00	0.7	1.4	2	0.45	0.22356	0.75
03/28/2025 20:00	0.7	1.4	2	0.45	0.22380	0.75
03/28/2025 21:00	0.7	1.3	2	0.45	0.22350	0.75
03/28/2025 22:00	0.7	1.3	2	0.45	0.22368	0.75
03/28/2025 23:00	0.7	1.4	2	0.45	0.22422	0.75
Average/Sum#:	0.7	1.3	2	0.45	0.22379	0.75
Minimum:	0.6	1.2	1	0.44	0.22230	0.74
Maximum:	0.8	1.5	2	0.45	0.22548	0.75
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/29/2025 00:00	0.7	1.3	2	0.45	0.22566	0.75
03/29/2025 01:00	0.7	1.4	2	0.45	0.22590	0.75
03/29/2025 02:00	0.7	1.3	2	0.45	0.22596	0.75
03/29/2025 03:00	0.8	1.4	2	0.45	0.22608	0.75
03/29/2025 04:00	0.7	1.3	2	0.45	0.22578	0.75
03/29/2025 05:00	0.7	1.3	2	0.47	0.23250	0.78
03/29/2025 06:00	0.7	1.3	2	0.49	0.24270	0.81
03/29/2025 07:00	0.9	1.4	2	0.45	0.22692	0.76
03/29/2025 08:00	0.8	1.4	2	0.45	0.22680	0.76
03/29/2025 09:00	0.7	1.3	2	0.45	0.22620	0.75
03/29/2025 10:00	0.7	1.4	2	0.45	0.22476	0.75
03/29/2025 11:00	0.7	1.4	2	0.45	0.22494	0.75
03/29/2025 12:00	0.7	1.4	2	0.45	0.22476	0.75
03/29/2025 13:00	0.7	1.3	2	0.45	0.22458	0.75
03/29/2025 14:00	0.6	1.4	2	0.45	0.22428	0.75
03/29/2025 15:00	0.6	1.3	2	0.45	0.22464	0.75
03/29/2025 16:00	0.6	1.3	1	0.45	0.22440	0.75
03/29/2025 17:00	0.6	1.4	1	0.46	0.22806	0.76
03/29/2025 18:00	0.7	1.3	2	0.45	0.22278	0.74
03/29/2025 19:00	0.7	1.3	2	0.45	0.22254	0.74
03/29/2025 20:00	0.7	1.4	1	0.45	0.22272	0.74
03/29/2025 21:00	0.7	1.4	2	0.45	0.22272	0.74
03/29/2025 22:00	0.8	1.4	2	0.45	0.22284	0.74
03/29/2025 23:00	0.7	1.3	2	0.45	0.22356	0.75
Average/Sum#:	0.7	1.4	2	0.45	0.22592	0.75
Minimum:	0.6	1.3	1	0.45	0.22254	0.74
Maximum:	0.9	1.4	2	0.49	0.24270	0.81
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/30/2025 00:00	0.7	1.4	2	0.45	0.22398	0.75
03/30/2025 01:00	0.7	1.3	2	0.45	0.22524	0.75
03/30/2025 02:00	0.7	1.3	1	0.45	0.22554	0.75
03/30/2025 03:00	0.8	1.3	2	0.45	0.22512	0.75
03/30/2025 04:00	0.7	1.3	2	0.49	0.24258	0.81
03/30/2025 05:00	0.6	1.4	1	0.56	0.28182	0.94
03/30/2025 06:00	0.9	1.4	2	0.51	0.25626	0.85
03/30/2025 07:00	0.7	1.4	2	0.45	0.22266	0.74
03/30/2025 08:00	0.7	1.3	2	0.45	0.22278	0.74
03/30/2025 09:00	0.7	1.3	2	0.44	0.22200	0.74
03/30/2025 10:00	0.7	1.4	2	0.45	0.22272	0.74
03/30/2025 11:00	0.7	1.4	2	0.45	0.22374	0.75
03/30/2025 12:00	0.6	1.3	2	0.45	0.22332	0.74
03/30/2025 13:00	0.6	1.3	2	0.45	0.22392	0.75
03/30/2025 14:00	0.6	1.3	1	0.45	0.22326	0.74
03/30/2025 15:00	0.7	1.4	1	0.44	0.22242	0.74
03/30/2025 16:00	0.6	1.3	1	0.45	0.22290	0.74
03/30/2025 17:00	0.6	1.4	1	0.48	0.23904	0.80
03/30/2025 18:00	0.7	1.3	2	0.45	0.22350	0.75
03/30/2025 19:00	0.7	1.3	2	0.45	0.22320	0.74
03/30/2025 20:00	0.7	1.3	2	0.45	0.22356	0.75
03/30/2025 21:00	0.7	1.4	2	0.45	0.22266	0.74
03/30/2025 22:00	0.7	1.3	2	0.45	0.22338	0.74
03/30/2025 23:00	0.7	1.3	2	0.45	0.22362	0.75
Average/Sum#:	0.7	1.3	2	0.46	0.22872	0.76
Minimum:	0.6	1.3	1	0.44	0.22200	0.74
Maximum:	0.9	1.4	2	0.56	0.28182	0.94
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 01/01/2025 00:00 **To:** 03/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
03/31/2025 00:00	0.7	1.4	2	0.45	0.22374	0.75
03/31/2025 01:00	0.7	1.4	2	0.45	0.22386	0.75
03/31/2025 02:00	0.7	1.4	2	0.45	0.22362	0.75
03/31/2025 03:00	0.8	1.4	2	0.45	0.22368	0.75
03/31/2025 04:00	0.7	1.4	2	0.45	0.22668	0.76
03/31/2025 05:00	0.7	1.3	2	0.46	0.23226	0.77
03/31/2025 06:00	0.7	1.4	1	0.50	0.25002	0.83
03/31/2025 07:00	0.7	1.4	2	0.49	0.24510	0.82
03/31/2025 08:00	0.8	1.3	2	0.45	0.22326	0.74
03/31/2025 09:00	0.7	1.4	2	0.45	0.22308	0.74
03/31/2025 10:00	0.7	1.4	2	0.45	0.22308	0.74
03/31/2025 11:00	0.7	1.3	2	0.45	0.22362	0.75
03/31/2025 12:00	0.7	1.4	2	0.45	0.22332	0.74
03/31/2025 13:00	0.7	1.3	2	0.45	0.22278	0.74
03/31/2025 14:00	0.7	1.4	1	0.45	0.22260	0.74
03/31/2025 15:00	0.7	1.3	2	0.45	0.22260	0.74
03/31/2025 16:00	0.7	1.3	2	0.44	0.22248	0.74
03/31/2025 17:00	0.7	1.4	2	0.45	0.22296	0.74
03/31/2025 18:00	0.7	1.4	2	0.45	0.22380	0.75
03/31/2025 19:00	0.7	1.3	2	0.45	0.22440	0.75
03/31/2025 20:00	0.7	1.4	2	0.45	0.22440	0.75
03/31/2025 21:00	0.7	1.3	2	0.45	0.22440	0.75
03/31/2025 22:00	0.7	1.4	2	0.45	0.22602	0.75
03/31/2025 23:00	0.7	1.4	2	0.48	0.23976	0.80
Average/Sum#:	0.7	1.4	2	0.46	0.22673	0.76
Minimum:	0.7	1.3	1	0.44	0.22248	0.74
Maximum:	0.8	1.4	2	0.50	0.25002	0.83
%SI	0.00	0.00	0.00	0.00	0.00	0.00