

DOCKETED

Docket Number:	12-AFC-03
Project Title:	Redondo Beach Energy Project
TN #:	201836
Document Title:	Report of Conversation re: Availability of Recycled Water for Project Operation on 02/04/14
Description:	Between CEC/Abdel-Karim Abulaban and WBMWD/Joe Walters, Manager of Business Development
Filer:	Alicia Campos
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	3/6/2014 2:58:33 PM
Docketed Date:	3/6/2014

CALIFORNIA ENERGY COMMISSION
REPORT OF CONVERSATION Page 1 of 1



Siting and Environmental Protection Division

FILE: (2012-AFC-03)

PROJECT TITLE: Redondo Beach Energy Project

<input checked="" type="checkbox"/> Telephone	310-660-6208	<input type="checkbox"/> Meeting Location:	
NAME:	Abdel-Karim Abulaban	DATE:	2/7/2014
WITH:	Joe Walters, Manager of Business Development, WBMWD		
SUBJECT:	Availability of recycled water for project operation		
		TIME:	2:45 p.m.

Background: In the RBEP application for certification the applicant stated that recycled water is not available for project use. The applicant stated that the West Basin Municipal Water District has a recycled water pipeline that is used to supply recycled water to the King Harbor Yacht Club adjacent to the project site, but that the WBMWD does not have the capacity to supply recycled water to the project as it does not produce recycled water in sufficient amounts to meet its current clientele.

Energy Commission staff contacted Mr. Walters of the WBMWD to verify the information supplied by the applicant. Staff learned that the WBMWD pipeline that supplies recycled wastewater to the King Harbor Yacht Club is a 12-inch pipeline and that it does have the extra capacity and availability to supply disinfected tertiary treated recycled water to the RBEP. WBMWD would even pay for the permit application to the department of public health and also for the construction of the additional pipeline that would connect the RBEP to the existing 12-inch pipeline. The WBMWD also expressed willingness to work with the applicant on the engineering of the connections from the RBEP to the existing pipeline. WBMWD also informed staff that the rate charged for recycled water through June 2014 is \$904 per acre-foot.

CC:	Signed:
	Name: Abdel-Karim Abulaban