# DOCKETED

| | |
|---|---|
| **Docket Number:** | 06-AFC-09C |
| **Project Title:** | Colusa Generating Station - Compliance |
| **TN #:** | 202270 |
| **Document Title:** | Quarter Operating Report Quarter Ending March 31, 2014 |
| **Description:** | N/A |
| **Filer:** | Charles Robert Price |
| **Organization:** | Pacific Gas & Electric Co. |
| **Submitter Role:** | Applicant |
| **Submission Date:** | 4/29/2014 3:56:13 PM |
| **Docketed Date:** | 4/29/2014 |

Pacific Gas and Electric Company®

**Ed Warner**
Plant Manager

*Mailing Address*
Pacific Gas and Electric Company
Colusa Generating Station
P.O. Box 398
Maxwell, CA 95955

530.934.9061
Fax: 530.934.9024

CGS14-L-0009
April 29, 2014

Eric Veerkamp
California Energy Commission
1516 Ninth Street, MS-2000
Sacramento, CA 95814

Reference: Colusa Generating Station (06-AFC-9)

Subject: Condition of Certification AQSC-9 – Quarterly Operating Reports

Dear Eric:

The 2014 1st Quarter Operating Report is being submitted in accordance with Condition of Certification AQSC-9. If you have any questions, please contact Charles Price at (530) 934-9007.

Sincerely,

4/29

Ed Warner
Senior Plant Manager

cc: File No. 3.6.3.1

Charles Price, PG&E
Jason Vann, PG&E

Pacific Gas and
Electric Company

# Colusa Generating Station

# (CEC# 06-AFC-9C, PTO# 21006-259)

## Quarterly Operating Report

Quarter Ending March 31, 2014

PACIFIC GAS AND ELECTRIC COMPANY
COLUSA GENERATING STATION

# QUARTERLY OPERATIONS REPORT

## QUARTER ENDING March 2014

This report documents compliance with the California Energy Commission's Conditions of Certification AQSC-9 and Colusa County Air Pollution Control District Permit Condition 17.

Attached are summaries of relevant permit conditions and compliance status as well as corresponding required documentation.

| | |
|---|---|
| Attachment 1: | Air Quality Complaints (AQ-5) |
| Attachment 2: | Fuel Quality Data (AQ-10, 11) |
| Attachment 3: | Compliance Demonstration with KKKK (AQ-13) |
| Attachment 4: | Excess Emissions/Downtime Report (AQ-4, 19) |
| Attachment 5: | Hourly Emissions VOC (AQ-14) |
| Attachment 6: | Hourly Emissions NOx (AQ-15) |
| Attachment 7: | Hourly Emissions CO (AQ-16) |
| Attachment 8: | Hourly Emissions NH3 (AQ-18) |
| Attachment 9: | Quarterly/Annual Emission Report (Fuel Use, NH3 Use, Operating Hours) (AQ-23, 26) |
| Attachment 10: | Maximum Emissions Both Turbines (AQ-25) |
| Attachment 11: | RATA/Certification Testing (AQ-19) |
| Attachment 12: | Startup/Shutdowns (AQ-22) |
| Attachment 13: | Water Bath Heater Operations (AQ-17) |
| Attachment 14: | Toxics (AQ-29) |

# ATTACHMENT 1
Complaints (AQ-5)

During the 1st quarter of 2014, there were no complaints issued from the public for the Colusa Generating Station. The site continues to be available for inspection by representatives of the CCAPCD.

# ATTACHMENT 2
# Fuel Quality Data (AQ-10, 11)

# 2014 Monthly Sulfur Content - Colusa Generating Station

**All Units in Grains of Sulfur per Standard Cubic Foot**

| Jan-14 | Feb-14 | Mar-14 | Apr-14 | May-14 | Jun-14 | Jul-14 | Aug-14 | Sep-14 | Oct-14 | Nov-14 | Dec-14 | Avg |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 0.200 | 0.173 | 0.182 | | | | | | | | | | 0.185 |

**Permit Limits: .75 Grains/SCF per Month (PSD Condition X.I.4); .3 Grains/SCF Annual Average (PTO # 10, AQ-11)**

**Laboratory Test Report**
Applied Technology Services (ATS)
3400 Crow Canyon Road
San Ramon, CA 94583

**Report #:** 562.1-14.8

**Pacific Gas and Electric Company**

**SUBJECT: CHEMICAL ANALYSES OF GAS SAMPLE FROM COLUSA POWER PLANT**
**ATS CHEMISTRY SERVICES UNIT FILE 1402-005**

On January 30, 2014, Steve North collected two samples of natural gas at Colusa Power Plant, in a 1-L Tedlar bag and in a 500-ml steel cylinder.

The Tedlar bag sample was analyzed for sulfur compounds on January 30, 2014, by Air Toxics Ltd. within 24 hours of the time it was collected. The Air Toxics report is attached.

The steel cylinder was received at ATS on January 31, 2014 and the hydrocarbons in the sample were analyzed using an Agilent 3000 GC with thermal conductivity detector. The results are as follows:

**Table 1: Hydrocarbon Content of Natural Gas from Colusa Power Plant on 01-30-14**

| GAS PHASE COMPONENT | VOLUME |
|---|---|
| METHANE, % | 94.846 |
| ETHANE, % | 3.057 |
| PROPANE, % | 0.160 |
| ISO-BUTANE, % | 0.020 |
| N-BUTANE, % | 0.024 |
| ISO-PENTANE, % | 0.005 |
| N-PENTANE, % | 0.004 |
| HEXANES, HEPTANES, OCTANES, % | 0.004 |
| CARBON DIOXIDE, % | 0.803 |
| NITROGEN, % | 1.055 |
| HYDROGEN, % | 0.003 |
| HELIUM, % | 0.011 |
| OXYGEN, % | 0.008 |
| TOTAL, % | 100.0 |
| CALC. BTU/CU.FT: | 1022.58 |
| REAL RELATIVE DENSITY | 0.584 |

As shown in Table 2, the total sulfur content in the gas supply is 0.200 grains per 100 cu. ft. Please contact Surinder Sidhu at 925-866-5510 if there are any questions regarding the chemical analyses.

pc: Charles Price

Date: February 6, 2014

Tested by: S Sidhu
Surinder Sidhu

Approved by: Clement O. Da Silva
Clement O. Da Silva

**Table 2: Sulfur Analysis of Natural Gas Supply to Colusa Power Plant on January 30, 2014**

(All results in ppmv)

| Gas Component | Concentration |
|---|---|
| Hydrogen Sulfide | 1.00 |
| Carbonyl Sulfide | 0.26 |
| Methyl Mercaptan | 0.09 |
| Ethyl Mercaptan | 0.03 |
| Dimethyl Sulfide | <0.02 |
| Isopropyl Mercaptan | <0.02 |
| tert-Butyl Mercaptan | 1.00 |
| sec-Butyl Mercaptan | <0.02 |
| Tetrahydrothiophene | 1.00 |
| Other Sulfur Compounds | <0.02 |
| Total | 3.38 |

Total sulfur in grains/100 cu. ft.= 0.200

eurofins | Air Toxics

2/4/2014
Mr. Clement Dasilva
PG&E
3400 Crow Canyon Road

San Ramon CA 94583

Project Name: Natural Gas Sampling
Project #:
Workorder #: 1401446

Dear Mr. Clement Dasilva

The following report includes the data for the above referenced project for sample(s) received on 1/30/2014 at Air Toxics Ltd.

The data and associated QC analyzed by ASTM D-5504 are compliant with the project requirements or laboratory criteria with the exception of the deviations noted in the attached case narrative.

Thank you for choosing Air Toxics Ltd. for your air analysis needs. Air Toxics Ltd. is committed to providing accurate data of the highest quality. Please feel free to contact the Project Manager: Kelly Buettner at 916-985-1000 if you have any questions regarding the data in this report.

Regards,

Kelly Buettner

Project Manager

eurofins | Air Toxics

# WORK ORDER #: 1401446

Work Order Summary

| | | | |
|---|---|---|---|
| **CLIENT:** | Mr. Clement Dasilva<br>PG&E<br>3400 Crow Canyon Road<br>San Ramon, CA 94583 | **BILL TO:** | Mr. Clement Dasilva<br>PG&E<br>3400 Crow Canyon Road<br>San Ramon, CA 94583 |
| **PHONE:** | 925-866-5421 | **P.O. #** | 3500782251 |
| **FAX:** | 925-866-5681 | **PROJECT #** | Natural Gas Sampling |
| **DATE RECEIVED:** | 01/30/2014 | **CONTACT:** | Kelly Buettner |
| **DATE COMPLETED:** | 02/04/2014 | | |

| FRACTION # | NAME | TEST | RECEIPT VAC./PRES. | FINAL PRESSURE |
|---|---|---|---|---|
| 01A | CPP-GS-JAN-A | ASTM D-5504 | Tedlar Bag | Tedlar Bag |
| 02A | Lab Blank | ASTM D-5504 | NA | NA |
| 03A | LCS | ASTM D-5504 | NA | NA |
| 03AA | LCSD | ASTM D-5504 | NA | NA |

CERTIFIED BY: Heidi Mayo

Technical Director

DATE: 02/04/14

Certification numbers: AZ Licensure AZ0775, CA NELAP - 12282CA, NJ NELAP - CA016, NY NELAP - 11291, TX NELAP - T104704434-13-6, UT NELAP CA009332013-4, VA NELAP - 460197, WA NELAP - C935
Name of Accrediting Agency: NELAP/ORELAP (Oregon Environmental Laboratory Accreditation Program)
Accreditation number: CA300005, Effective date: 10/18/2013, Expiration date: 10/17/2014.
Eurofins Air Toxics Inc.. certifies that the test results contained in this report meet all requirements of the NELAC standards

This report shall not be reproduced, except in full, without the written approval of Eurofins Air Toxics, Inc.

180 BLUE RAVINE ROAD, SUITE B FOLSOM, CA - 9563
(916) 985-1000 . (800) 985-5955 . FAX (916) 985-1020

eurofins | Air Toxics

**LABORATORY NARRATIVE**
**ASTM D-5504**
**PG&E**
**Workorder# 1401446**

One 1 Liter Tedlar Bag sample was received on January 30, 2014. The laboratory performed the analysis of sulfur compounds via ASTM D-5504 using GC/SCD. The method involves direct injection of the air sample into the GC via a fixed 2.0 mL sampling loop. See the data sheets for the reporting limits for each compound.

## Receiving Notes

There were no receiving discrepancies.

## Analytical Notes

There were no analytical discrepancies.

## Definition of Data Qualifying Flags

Seven qualifiers may have been used on the data analysis sheets and indicate as follows:
B - Compound present in laboratory blank greater than reporting limit.
J - Estimated value.
E - Exceeds instrument calibration range.
S - Saturated peak.
Q - Exceeds quality control limits.
U - Compound analyzed for but not detected above the detection limit.
M - Reported value may be biased due to apparent matrix interferences.
File extensions may have been used on the data analysis sheets and indicates as follows:
a-File was requantified
b-File was quantified by a second column and detector
r1-File was requantified for the purpose of reissue

eurofins | Air Toxics

# Summary of Detected Compounds
# SULFUR GASES BY ASTM D-5504 GC/SCD

**Client Sample ID: CPP-GS-JAN-A**

**Lab ID#: 1401446-01A**

| Compound | Rpt. Limit (ppbv) | Amount (ppbv) |
|---|---|---|
| Hydrogen Sulfide | 24 | 1000 |
| Carbonyl Sulfide | 24 | 260 |
| Methyl Mercaptan | 24 | 90 |
| Ethyl Mercaptan | 24 | 30 |
| tert-Butyl Mercaptan | 24 | 1000 |
| Tetrahydrothiophene | 24 | 1000 |

eurofins | Air Toxics

**Client Sample ID: CPP-GS-JAN-A**

**Lab ID#: 1401446-01A**

**SULFUR GASES BY ASTM D-5504 GC/SCD**

| | | | |
|---|---|---|---|
| **File Name:** | **k013020** | **Date of Collection:** | **1/30/14 2:18:00 PM** |
| **Dil. Factor:** | **6.00** | **Date of Analysis:** | **1/30/14 06:16 PM** |

| Compound | Rpt. Limit (ppbv) | Amount (ppbv) |
|---|---|---|
| Hydrogen Sulfide | 24 | 1000 |
| Carbonyl Sulfide | 24 | 260 |
| Methyl Mercaptan | 24 | 90 |
| Ethyl Mercaptan | 24 | 30 |
| Dimethyl Sulfide | 24 | Not Detected |
| Carbon Disulfide | 30 | Not Detected |
| Isopropyl Mercaptan | 24 | Not Detected |
| tert-Butyl Mercaptan | 24 | 1000 |
| n-Propyl Mercaptan | 24 | Not Detected |
| Ethyl Methyl Sulfide | 24 | Not Detected |
| Thiophene | 24 | Not Detected |
| Isobutyl Mercaptan | 24 | Not Detected |
| Diethyl Sulfide | 24 | Not Detected |
| n-Butyl Mercaptan | 24 | Not Detected |
| Dimethyl Disulfide | 24 | Not Detected |
| 3-Methylthiophene | 24 | Not Detected |
| Tetrahydrothiophene | 24 | 1000 |
| 2-Ethylthiophene | 24 | Not Detected |
| 2,5-Dimethylthiophene | 24 | Not Detected |
| Diethyl Disulfide | 24 | Not Detected |

**Container Type: 1 Liter Tedlar Bag**

eurofins | Air Toxics

**Client Sample ID: Lab Blank**

**Lab ID#: 1401446-02A**

**SULFUR GASES BY ASTM D-5504 GC/SCD**

| | | | |
|---|---|---|---|
| **File Name:** | **k013011** | **Date of Collection: NA** | |
| **Dil. Factor:** | **1.00** | **Date of Analysis: 1/30/14 10:30 AM** | |

| **Compound** | **Rpt. Limit (ppbv)** | **Amount (ppbv)** |
|---|---|---|
| Hydrogen Sulfide | 4.0 | Not Detected |
| Carbonyl Sulfide | 4.0 | Not Detected |
| Methyl Mercaptan | 4.0 | Not Detected |
| Ethyl Mercaptan | 4.0 | Not Detected |
| Dimethyl Sulfide | 4.0 | Not Detected |
| Carbon Disulfide | 5.0 | Not Detected |
| Isopropyl Mercaptan | 4.0 | Not Detected |
| tert-Butyl Mercaptan | 4.0 | Not Detected |
| n-Propyl Mercaptan | 4.0 | Not Detected |
| Ethyl Methyl Sulfide | 4.0 | Not Detected |
| Thiophene | 4.0 | Not Detected |
| Isobutyl Mercaptan | 4.0 | Not Detected |
| Diethyl Sulfide | 4.0 | Not Detected |
| n-Butyl Mercaptan | 4.0 | Not Detected |
| Dimethyl Disulfide | 4.0 | Not Detected |
| 3-Methylthiophene | 4.0 | Not Detected |
| Tetrahydrothiophene | 4.0 | Not Detected |
| 2-Ethylthiophene | 4.0 | Not Detected |
| 2,5-Dimethylthiophene | 4.0 | Not Detected |
| Diethyl Disulfide | 4.0 | Not Detected |

**Container Type: NA - Not Applicable**

eurofins | Air Toxics

**Client Sample ID: LCS**

**Lab ID#: 1401446-03A**

**SULFUR GASES BY ASTM D-5504 GC/SCD**

| | | | |
|---|---|---|---|
| **File Name:** | **k013007** | **Date of Collection: NA** | |
| **Dil. Factor:** | **1.00** | **Date of Analysis: 1/30/14 08:44 AM** | |

| **Compound** | **%Recovery** | **Method Limits** |
|---|---|---|
| Hydrogen Sulfide | 102 | 70-130 |
| Carbonyl Sulfide | 100 | 70-130 |
| Methyl Mercaptan | 103 | 70-130 |
| Ethyl Mercaptan | 110 | 70-130 |
| Dimethyl Sulfide | 99 | 70-130 |
| Carbon Disulfide | 111 | 70-130 |
| Isopropyl Mercaptan | 87 | 70-130 |
| tert-Butyl Mercaptan | 90 | 70-130 |
| n-Propyl Mercaptan | 87 | 70-130 |
| Ethyl Methyl Sulfide | 97 | 70-130 |
| Thiophene | 102 | 70-130 |
| Isobutyl Mercaptan | 88 | 70-130 |
| Diethyl Sulfide | 100 | 70-130 |
| n-Butyl Mercaptan | 88 | 70-130 |
| Dimethyl Disulfide | 100 | 70-130 |
| 3-Methylthiophene | 107 | 70-130 |
| Tetrahydrothiophene | 114 | 70-130 |
| 2-Ethylthiophene | 118 | 70-130 |
| 2,5-Dimethylthiophene | 116 | 70-130 |
| Diethyl Disulfide | 123 | 70-130 |

**Container Type: NA - Not Applicable**

eurofins | Air Toxics

**Client Sample ID: LCSD**

**Lab ID#: 1401446-03AA**

**SULFUR GASES BY ASTM D-5504 GC/SCD**

| | | | |
|---|---|---|---|
| **File Name:** | **k013009** | **Date of Collection: NA** | |
| **Dil. Factor:** | **1.00** | **Date of Analysis: 1/30/14 09:33 AM** | |

| **Compound** | **%Recovery** | **Method Limits** |
|---|---|---|
| Hydrogen Sulfide | 97 | 70-130 |
| Carbonyl Sulfide | 103 | 70-130 |
| Methyl Mercaptan | 106 | 70-130 |
| Ethyl Mercaptan | 112 | 70-130 |
| Dimethyl Sulfide | 109 | 70-130 |
| Carbon Disulfide | 112 | 70-130 |
| Isopropyl Mercaptan | 88 | 70-130 |
| tert-Butyl Mercaptan | 95 | 70-130 |
| n-Propyl Mercaptan | 84 | 70-130 |
| Ethyl Methyl Sulfide | 102 | 70-130 |
| Thiophene | 107 | 70-130 |
| Isobutyl Mercaptan | 90 | 70-130 |
| Diethyl Sulfide | 102 | 70-130 |
| n-Butyl Mercaptan | 80 | 70-130 |
| Dimethyl Disulfide | 103 | 70-130 |
| 3-Methylthiophene | 107 | 70-130 |
| Tetrahydrothiophene | 103 | 70-130 |
| 2-Ethylthiophene | 116 | 70-130 |
| 2,5-Dimethylthiophene | 115 | 70-130 |
| Diethyl Disulfide | 111 | 70-130 |

**Container Type: NA - Not Applicable**

# Chain of Custody Record

## Pacific Gas and Electric Company

**SAM #**

| | | | |
|---|---|---|---|
| Client: PG&E Environmental Services | Project Manager: Clem Da Silva | | Date: 1/30/14 |
| Address: 3400 Crow Canyon Road | Telephone Number: 925-866-5421 | Email: codu@pge.com | Laboratory: Air Toxics |
| City: San Ramon / State: CA / Zip: 94583 | Site Contacat: Clem Da Silva 925.866.5421 | | Laboratory Phone: 916-985-1000 |
| Project Number/Name: Natural Gas Sampling | Sampler: Steve North 925-785-3039 | | Laboratory Fax: |
| Contract Number, PO Number: | Laboratory Contact: 180 Blue Ravine Rd. Folsom CA, 95630 | | |

Preparation and Analysis

| PG&E Sample ID | SAM#-ID# | Date | Time | Sample Type | Containers Volume | Containers Type | Containers No. | Preservative | Condition on Receipt/Comments | Sulfur |
|---|---|---|---|---|---|---|---|---|---|---|
| CPP-GS-JAN-A | 01A | 1/30/14 | 14:10 | Gas | 1 liter | bag | 1 | None | | X |
| ~~[illegible]~~ | | | | ~~Gas~~ | ~~1 liter~~ | ~~bag~~ | ~~1~~ | ~~None~~ | ~~[illegible]~~ | ~~X~~ |

**Special Instruction:** Please hold samples for 45 days.
Email results to Clem daSilva CODU@PGE.COM and Lauren Eastman LKE1@PGE.COM

Turn Around Time Required: ☑ Normal ☐ Rush ☐ Other

QC Level: ☑ I. ☐ II. ☐ III.

Project Specific Requirements (Specify):

| | Date | Time | | Date | Time |
|---|---|---|---|---|---|
| 1. Relinquished By: Steve North | 1/30/14 | 16:22 | 1. Received By: ATL | 1/30/14 | 16:22 |
| 2. Relinquished By: | | | 2. Received By: | | |
| 3. Relinquished By: | | | 3. Received By: | | |

Comments

Custody Seal Intact? Y N None Temp N/A HP

1401446

**.Laboratory Test Report**

**Report #:** 562.1-14.15

Applied Technology Services (ATS)
3400 Crow Canyon Road
San Ramon, CA 94583

**Pacific Gas and Electric Company**

**SUBJECT: CHEMICAL ANALYSES OF GAS SAMPLE FROM COLUSA POWER PLANT**
**ATS CHEMISTRY SERVICES UNIT FILE 1402-069**

On February 19, 2014, Steve North collected two samples of natural gas at Colusa Power Plant, in a 1-L Tedlar bag and in a 500-ml steel cylinder.

The Tedlar bag sample was analyzed for sulfur compounds on February 19, 2014, by Air Toxics Ltd. within 24 hours of the time it was collected. The Air Toxics report is attached.

The steel cylinder was received at ATS on February 24, 2014, and the hydrocarbons in the sample were analyzed using an Agilent 3000 GC with thermal conductivity detector. The results are as follows:

**Table 1: Hydrocarbon Content of Natural Gas from Colusa Power Plant on 02/19/2014**

| GAS PHASE COMPONENT | VOLUME |
|---|---|
| METHANE, % | 95.664 |
| ETHANE, % | 2.895 |
| PROPANE, % | 0.077 |
| ISO-BUTANE, % | 0.008 |
| N-BUTANE, % | 0.009 |
| ISO-PENTANE, % | 0.003 |
| N-PENTANE, % | 0.003 |
| HEXANES, HEPTANES, OCTANES, % | 0.000 |
| CARBON DIOXIDE, % | 0.774 |
| NITROGEN, % | 0.542 |
| HYDROGEN, % | 0.003 |
| HELIUM, % | 0.010 |
| OXYGEN, % | 0.000 |
| TOTAL, % | 100.0 |
| CALC. BTU/CU.FT: | 1024.7 |
| REAL RELATIVE DENSITY | 0.580 |

As shown in Table 2, the total sulfur content in the gas supply is 0.173 grains per 100 cu. ft. Please contact Evan Cavalli at 925-866-5510 if there are any questions regarding the chemical analyses.
Attachments

pc: Charles Price

Date: February 27, 2014

Tested by: Evan M. Cavalli

Approved by: Clement O. Da Silva

**Table 2: Sulfur Analysis of Natural Gas Supply to Colusa Power Plant on February 19, 2014**

(All results in ppmv)

| Gas Component | Concentration |
|---|---|
| Hydrogen Sulfide | 0.68 |
| Carbonyl Sulfide | 0.17 |
| Methyl Mercaptan | 0.06 |
| Ethyl Mercaptan | 0.02 |
| Dimethyl Sulfide | 0.03 |
| Isopropyl Mercaptan | <0.02 |
| tert-Butyl Mercaptan | 0.98 |
| sec-Butyl Mercaptan | <0.02 |
| Tetrahydrothiophene | 0.97 |
| Other Sulfur Compounds | <0.02 |
| Total | 2.91 |

Total sulfur in grains/100 cu. ft.= 0.173

eurofins | Air Toxics

2/26/2014
Mr. Clement Dasilva
PG&E
3400 Crow Canyon Road

San Ramon CA 94583

Project Name: Natural Gas Sampling
Project #:
Workorder #: 1402283

Dear Mr. Clement Dasilva

The following report includes the data for the above referenced project for sample(s) received on 2/19/2014 at Air Toxics Ltd.

The data and associated QC analyzed by ASTM D-5504 are compliant with the project requirements or laboratory criteria with the exception of the deviations noted in the attached case narrative.

Thank you for choosing Air Toxics Ltd. for your air analysis needs. Air Toxics Ltd. is committed to providing accurate data of the highest quality. Please feel free to contact the Project Manager: Kelly Buettner at 916-985-1000 if you have any questions regarding the data in this report.

Regards,

Kelly Buettner

Project Manager

eurofins | Air Toxics

# WORK ORDER #: 1402283

Work Order Summary

| | | | |
|---|---|---|---|
| **CLIENT:** | Mr. Clement Dasilva<br>PG&E<br>3400 Crow Canyon Road<br>San Ramon, CA 94583 | **BILL TO:** | Mr. Clement Dasilva<br>PG&E<br>3400 Crow Canyon Road<br>San Ramon, CA 94583 |
| **PHONE:** | 925-866-5421 | **P.O. #** | 3500782251 |
| **FAX:** | 925-866-5681 | **PROJECT #** | Natural Gas Sampling |
| **DATE RECEIVED:** | 02/19/2014 | **CONTACT:** | Kelly Buettner |
| **DATE COMPLETED:** | 02/26/2014 | | |

| FRACTION # | NAME | TEST | RECEIPT VAC./PRES. | FINAL PRESSURE |
|---|---|---|---|---|
| 01A | HBPP-GS-FEB-A | ASTM D-5504 | Tedlar Bag | Tedlar Bag |
| 02A | CPP-GS-FEB-A | ASTM D-5504 | Tedlar Bag | Tedlar Bag |
| 03A | Lab Blank | ASTM D-5504 | NA | NA |
| 04A | LCS | ASTM D-5504 | NA | NA |
| 04AA | LCSD | ASTM D-5504 | NA | NA |

CERTIFIED BY: Heidi Mayo

Technical Director

DATE: 02/26/14

Certification numbers: AZ Licensure AZ0775, CA NELAP - 12282CA, NJ NELAP - CA016, NY NELAP - 11291, TX NELAP - T104704434-13-6, UT NELAP CA009332013-4, VA NELAP - 460197, WA NELAP - C935
Name of Accrediting Agency: NELAP/ORELAP (Oregon Environmental Laboratory Accreditation Program)
Accreditation number: CA300005, Effective date: 10/18/2013, Expiration date: 10/17/2014.
Eurofins Air Toxics Inc.. certifies that the test results contained in this report meet all requirements of the NELAC standards

This report shall not be reproduced, except in full, without the written approval of Eurofins Air Toxics, Inc.

180 BLUE RAVINE ROAD, SUITE B FOLSOM, CA - 9563
(916) 985-1000 . (800) 985-5955 . FAX (916) 985-1020

eurofins | Air Toxics

**LABORATORY NARRATIVE**
**ASTM D-5504**
**PG&E**
**Workorder# 1402283**

Two 1 Liter Tedlar Bag samples were received on February 19, 2014. The laboratory performed the analysis of sulfur compounds via ASTM D-5504 using GC/SCD. The method involves direct injection of the air sample into the GC via a fixed 2.0 mL sampling loop. See the data sheets for the reporting limits for each compound.

## Receiving Notes

There were no receiving discrepancies.

## Analytical Notes

There were no analytical discrepancies.

## Definition of Data Qualifying Flags

Seven qualifiers may have been used on the data analysis sheets and indicate as follows:
B - Compound present in laboratory blank greater than reporting limit.
J - Estimated value.
E - Exceeds instrument calibration range.
S - Saturated peak.
Q - Exceeds quality control limits.
U - Compound analyzed for but not detected above the detection limit.
M - Reported value may be biased due to apparent matrix interferences.
File extensions may have been used on the data analysis sheets and indicates as follows:
a-File was requantified
b-File was quantified by a second column and detector
r1-File was requantified for the purpose of reissue

eurofins | Air Toxics

# Summary of Detected Compounds
# SULFUR GASES BY ASTM D-5504 GC/SCD

**Client Sample ID: HBPP-GS-FEB-A**

**Lab ID#: 1402283-01A**

| Compound | Rpt. Limit (ppbv) | Amount (ppbv) |
|---|---|---|
| Hydrogen Sulfide | 16 | 480 |
| Carbonyl Sulfide | 16 | 290 |
| Methyl Mercaptan | 16 | 75 |
| Ethyl Mercaptan | 16 | 23 |
| Dimethyl Sulfide | 16 | 51 |
| tert-Butyl Mercaptan | 16 | 940 |
| Tetrahydrothiophene | 16 | 810 |

**Client Sample ID: CPP-GS-FEB-A**

**Lab ID#: 1402283-02A**

| Compound | Rpt. Limit (ppbv) | Amount (ppbv) |
|---|---|---|
| Hydrogen Sulfide | 24 | 680 |
| Carbonyl Sulfide | 24 | 170 |
| Methyl Mercaptan | 24 | 64 |
| Ethyl Mercaptan | 24 | 24 |
| Dimethyl Sulfide | 24 | 25 |
| tert-Butyl Mercaptan | 24 | 980 |
| Tetrahydrothiophene | 24 | 970 |

eurofins | Air Toxics

**Client Sample ID: HBPP-GS-FEB-A**

**Lab ID#: 1402283-01A**

**SULFUR GASES BY ASTM D-5504 GC/SCD**

| | | | |
|---|---|---|---|
| **File Name:** | **k021920** | **Date of Collection:** | **2/19/14 9:01:00 AM** |
| **Dil. Factor:** | **4.00** | **Date of Analysis:** | **2/19/14 08:01 PM** |

| Compound | Rpt. Limit (ppbv) | Amount (ppbv) |
|---|---|---|
| Hydrogen Sulfide | 16 | 480 |
| Carbonyl Sulfide | 16 | 290 |
| Methyl Mercaptan | 16 | 75 |
| Ethyl Mercaptan | 16 | 23 |
| Dimethyl Sulfide | 16 | 51 |
| Carbon Disulfide | 20 | Not Detected |
| Isopropyl Mercaptan | 16 | Not Detected |
| tert-Butyl Mercaptan | 16 | 940 |
| n-Propyl Mercaptan | 16 | Not Detected |
| Ethyl Methyl Sulfide | 16 | Not Detected |
| Thiophene | 16 | Not Detected |
| Isobutyl Mercaptan | 16 | Not Detected |
| Diethyl Sulfide | 16 | Not Detected |
| n-Butyl Mercaptan | 16 | Not Detected |
| Dimethyl Disulfide | 16 | Not Detected |
| 3-Methylthiophene | 16 | Not Detected |
| Tetrahydrothiophene | 16 | 810 |
| 2-Ethylthiophene | 16 | Not Detected |
| 2,5-Dimethylthiophene | 16 | Not Detected |
| Diethyl Disulfide | 16 | Not Detected |

**Container Type: 1 Liter Tedlar Bag**

eurofins | Air Toxics

**Client Sample ID: CPP-GS-FEB-A**

**Lab ID#: 1402283-02A**

**SULFUR GASES BY ASTM D-5504 GC/SCD**

| | | | |
|---|---|---|---|
| **File Name:** | **k021921** | **Date of Collection:** | **2/19/14 2:52:00 PM** |
| **Dil. Factor:** | **6.00** | **Date of Analysis:** | **2/19/14 08:24 PM** |

| Compound | Rpt. Limit (ppbv) | Amount (ppbv) |
|---|---|---|
| Hydrogen Sulfide | 24 | 680 |
| Carbonyl Sulfide | 24 | 170 |
| Methyl Mercaptan | 24 | 64 |
| Ethyl Mercaptan | 24 | 24 |
| Dimethyl Sulfide | 24 | 25 |
| Carbon Disulfide | 30 | Not Detected |
| Isopropyl Mercaptan | 24 | Not Detected |
| tert-Butyl Mercaptan | 24 | 980 |
| n-Propyl Mercaptan | 24 | Not Detected |
| Ethyl Methyl Sulfide | 24 | Not Detected |
| Thiophene | 24 | Not Detected |
| Isobutyl Mercaptan | 24 | Not Detected |
| Diethyl Sulfide | 24 | Not Detected |
| n-Butyl Mercaptan | 24 | Not Detected |
| Dimethyl Disulfide | 24 | Not Detected |
| 3-Methylthiophene | 24 | Not Detected |
| Tetrahydrothiophene | 24 | 970 |
| 2-Ethylthiophene | 24 | Not Detected |
| 2,5-Dimethylthiophene | 24 | Not Detected |
| Diethyl Disulfide | 24 | Not Detected |

**Container Type: 1 Liter Tedlar Bag**

eurofins | Air Toxics

**Client Sample ID: Lab Blank**

**Lab ID#: 1402283-03A**

**SULFUR GASES BY ASTM D-5504 GC/SCD**

| | | | |
|---|---|---|---|
| **File Name:** | **k021903** | **Date of Collection: NA** | |
| **Dil. Factor:** | **1.00** | **Date of Analysis: 2/19/14 08:57 AM** | |

| **Compound** | **Rpt. Limit (ppbv)** | **Amount (ppbv)** |
|---|---|---|
| Hydrogen Sulfide | 4.0 | Not Detected |
| Carbonyl Sulfide | 4.0 | Not Detected |
| Methyl Mercaptan | 4.0 | Not Detected |
| Ethyl Mercaptan | 4.0 | Not Detected |
| Dimethyl Sulfide | 4.0 | Not Detected |
| Carbon Disulfide | 5.0 | Not Detected |
| Isopropyl Mercaptan | 4.0 | Not Detected |
| tert-Butyl Mercaptan | 4.0 | Not Detected |
| n-Propyl Mercaptan | 4.0 | Not Detected |
| Ethyl Methyl Sulfide | 4.0 | Not Detected |
| Thiophene | 4.0 | Not Detected |
| Isobutyl Mercaptan | 4.0 | Not Detected |
| Diethyl Sulfide | 4.0 | Not Detected |
| n-Butyl Mercaptan | 4.0 | Not Detected |
| Dimethyl Disulfide | 4.0 | Not Detected |
| 3-Methylthiophene | 4.0 | Not Detected |
| Tetrahydrothiophene | 4.0 | Not Detected |
| 2-Ethylthiophene | 4.0 | Not Detected |
| 2,5-Dimethylthiophene | 4.0 | Not Detected |
| Diethyl Disulfide | 4.0 | Not Detected |

**Container Type: NA - Not Applicable**

eurofins | Air Toxics

**Client Sample ID: LCS**

**Lab ID#: 1402283-04A**

**SULFUR GASES BY ASTM D-5504 GC/SCD**

| | | | |
|---|---|---|---|
| **File Name:** | **k021902** | **Date of Collection: NA** | |
| **Dil. Factor:** | **1.00** | **Date of Analysis: 2/19/14 08:28 AM** | |

| **Compound** | **%Recovery** | **Method Limits** |
|---|---|---|
| Hydrogen Sulfide | 90 | 70-130 |
| Carbonyl Sulfide | 87 | 70-130 |
| Methyl Mercaptan | 88 | 70-130 |
| Ethyl Mercaptan | 95 | 70-130 |
| Dimethyl Sulfide | 86 | 70-130 |
| Carbon Disulfide | 90 | 70-130 |
| Isopropyl Mercaptan | 83 | 70-130 |
| tert-Butyl Mercaptan | 86 | 70-130 |
| n-Propyl Mercaptan | 82 | 70-130 |
| Ethyl Methyl Sulfide | 78 | 70-130 |
| Thiophene | 87 | 70-130 |
| Isobutyl Mercaptan | 89 | 70-130 |
| Diethyl Sulfide | 87 | 70-130 |
| n-Butyl Mercaptan | 78 | 70-130 |
| Dimethyl Disulfide | 78 | 70-130 |
| 3-Methylthiophene | 77 | 70-130 |
| Tetrahydrothiophene | 78 | 70-130 |
| 2-Ethylthiophene | 84 | 70-130 |
| 2,5-Dimethylthiophene | 82 | 70-130 |
| Diethyl Disulfide | 87 | 70-130 |

**Container Type: NA - Not Applicable**

eurofins | Air Toxics

**Client Sample ID: LCSD**

**Lab ID#: 1402283-04AA**

**SULFUR GASES BY ASTM D-5504 GC/SCD**

| | | | |
|---|---|---|---|
| **File Name:** | **k021918** | **Date of Collection: NA** | |
| **Dil. Factor:** | **1.00** | **Date of Analysis: 2/19/14 02:24 PM** | |

| **Compound** | **%Recovery** | **Method Limits** |
|---|---|---|
| Hydrogen Sulfide | 97 | 70-130 |
| Carbonyl Sulfide | 98 | 70-130 |
| Methyl Mercaptan | 102 | 70-130 |
| Ethyl Mercaptan | 105 | 70-130 |
| Dimethyl Sulfide | 98 | 70-130 |
| Carbon Disulfide | 102 | 70-130 |
| Isopropyl Mercaptan | 97 | 70-130 |
| tert-Butyl Mercaptan | 99 | 70-130 |
| n-Propyl Mercaptan | 95 | 70-130 |
| Ethyl Methyl Sulfide | 96 | 70-130 |
| Thiophene | 93 | 70-130 |
| Isobutyl Mercaptan | 101 | 70-130 |
| Diethyl Sulfide | 99 | 70-130 |
| n-Butyl Mercaptan | 90 | 70-130 |
| Dimethyl Disulfide | 87 | 70-130 |
| 3-Methylthiophene | 84 | 70-130 |
| Tetrahydrothiophene | 85 | 70-130 |
| 2-Ethylthiophene | 86 | 70-130 |
| 2,5-Dimethylthiophene | 86 | 70-130 |
| Diethyl Disulfide | 88 | 70-130 |

**Container Type: NA - Not Applicable**

**Laboratory Test Report**
Applied Technology Services (ATS)
3400 Crow Canyon Road
San Ramon, CA 94583

**Report #:** 562.1-14.25

**Pacific Gas and Electric Company**

**SUBJECT: CHEMICAL ANALYSES OF GAS SAMPLE FROM COLUSA POWER PLANT**
**ATS CHEMISTRY SERVICES UNIT FILE 1403-027**

On March 14, 2014, Steve North collected two samples of natural gas at Colusa Power Plant, in a 1-L Tedlar bag and in a 500-ml steel cylinder.

The Tedlar bag sample was analyzed for sulfur compounds on March 14, 2014, by Air Toxics Ltd. within 24 hours of the time it was collected. The Air Toxics report is attached.

The steel cylinder was received at ATS on March 14, 2014 and the hydrocarbons in the sample were analyzed using an Agilent 3000 GC with thermal conductivity detector. The results are as follows:

**Table 1: Hydrocarbon Content of Natural Gas from Colusa Power Plant on 03-14-14**

| GAS PHASE COMPONENT | VOLUME |
|---|---|
| METHANE, % | 95.120 |
| ETHANE, % | 3.427 |
| PROPANE, % | 0.075 |
| ISO-BUTANE, % | 0.007 |
| N-BUTANE, % | 0.008 |
| ISO-PENTANE, % | 0.002 |
| N-PENTANE, % | 0.001 |
| HEXANES, HEPTANES, OCTANES, % | 0.001 |
| CARBON DIOXIDE, % | 0.774 |
| NITROGEN, % | 0.561 |
| HYDROGEN, % | 0.0025 |
| HELIUM, % | 0.009 |
| OXYGEN, % | 0.017 |
| TOTAL, % | 100 |
| CALC. BTU/CU.FT: | 1028.3 |
| REAL RELATIVE DENSITY | 0.582 |
| METHANE NUMBER | 89.6 |

As shown in Table 2, the total sulfur content in the gas supply is 0.182 grains per 100 cu. ft.
Please contact Surinder Sidhu at 925-866-5510 if there are any questions regarding the chemical analyses.

pc: Charles Price

Date: March 27, 2014

Tested by: S Sidhu

Surinder Sidhu

Approved by: Clement O. Da Silva

Clement O. Da Silva

**Table 2: Sulfur Analysis of Natural Gas Supply to Colusa Power Plant on March 14, 2014**

(All results in ppmv)

| Gas Component | Concentration |
|---|---|
| Hydrogen Sulfide | 0.970 |
| Carbonyl Sulfide | 0.120 |
| Methyl Mercaptan | 0.063 |
| Ethyl Mercaptan | <0.024 |
| Dimethyl Sulfide | <0.024 |
| Isopropyl Mercaptan | <0.024 |
| tert-Butyl Mercaptan | 1.000 |
| sec-Butyl Mercaptan | <0.024 |
| Tetrahydrothiophene | 0.910 |
| Other Sulfur Compounds | <0.024 |
| Total | 3.063 |

Total sulfur in grains/100 cu. ft.= 0.182

# Chain of Custody Record

## Pacific Gas and Electric Company

**SAM # ATS**

| | | | |
|---|---|---|---|
| Client: PG&E Applied technical Services | Project Manager: Clem da Silva | | Date: |
| Address: 3400 Crow Canyon Road | Telephone Number: 925-866-5421 | Email: codu@pge.com | Laboratory: ATS |
| City: San Ramon / State: CA / Zip: 94583 | Site Contacat: Clem Da Silva 925-866-5421 | | Laboratory Phone: |
| Project Number/Name: Nat'l Gas Sampling | Sampler: Steve North 925-785-3039 | | Laboratory Fax: |
| Contract Number, PO Number: | Laboratory Contact: | | |

| PG&E Sample ID | SAM#-ID# | Date | Time | Sample Type | Containers Volume | Containers Type | Containers No. | Preservative | Condition on Receipt/Comments | Preparation and Analysis: C1-C10 | Sulfur |
|---|---|---|---|---|---|---|---|---|---|---|---|
| CPP-GS-MAR-1 | | 3/14/14 | 10:58 | Gas | 500cc | cyl | 1 | None | | X | |
| ~~Jm~~ | | | | ~~Gas~~ | ~~500cc~~ | ~~cyl~~ | ~~1~~ | ~~None~~ | | X | |
| ~~Jm~~ | | | | ~~Gas~~ | ~~500cc~~ | ~~cyl~~ | ~~1~~ | ~~None~~ | | X | |
| CPP-GS-MAR-B | | | 1103 | gas | 1l | bag | 1 | None | | | X |

**Special Instruction:**

| Turn Around Time Required | QC Level | Project Specific Requirements (Specify) |
|---|---|---|
| ☑ Normal ☐ Rush ☐ Other | ☑ I. ☐ II. ☐ III. | |

| | Date | Time | | Date | Time |
|---|---|---|---|---|---|
| 1. Relinquished By: Steve North | | | 1. Received By | | |
| 2. Relinquished By | | | 2. Received By | | |
| 3. Relinquished By | | | 3. Received By | | |

Comments

eurofins | Air Toxics

3/21/2014
Mr. Clement Dasilva
PG&E
3400 Crow Canyon Road

San Ramon CA 94583

Project Name: Natural Gas Sampling
Project #:
Workorder #: 1403260

Dear Mr. Clement Dasilva

The following report includes the data for the above referenced project for sample(s) received on 3/14/2014 at Air Toxics Ltd.

The data and associated QC analyzed by ASTM D-5504 are compliant with the project requirements or laboratory criteria with the exception of the deviations noted in the attached case narrative.

Thank you for choosing Air Toxics Ltd. for your air analysis needs. Air Toxics Ltd. is committed to providing accurate data of the highest quality. Please feel free to contact the Project Manager: Kelly Buettner at 916-985-1000 if you have any questions regarding the data in this report.

Regards,

Kelly Buettner

Project Manager

eurofins | Air Toxics

# WORK ORDER #: 1403260

Work Order Summary

| | | | |
|---|---|---|---|
| **CLIENT:** | Mr. Clement Dasilva<br>PG&E<br>3400 Crow Canyon Road<br>San Ramon, CA 94583 | **BILL TO:** | Mr. Clement Dasilva<br>PG&E<br>3400 Crow Canyon Road<br>San Ramon, CA 94583 |
| **PHONE:** | 925-866-5421 | **P.O. #** | 3500782251 |
| **FAX:** | 925-866-5681 | **PROJECT #** | Natural Gas Sampling |
| **DATE RECEIVED:** | 03/14/2014 | **CONTACT:** | Kelly Buettner |
| **DATE COMPLETED:** | 03/21/2014 | | |

| FRACTION # | NAME | TEST | RECEIPT VAC./PRES. | FINAL PRESSURE |
|---|---|---|---|---|
| 01A | CPP-GS-MAR-A | ASTM D-5504 | Tedlar Bag | Tedlar Bag |
| 02A | Lab Blank | ASTM D-5504 | NA | NA |
| 03A | LCS | ASTM D-5504 | NA | NA |
| 03AA | LCSD | ASTM D-5504 | NA | NA |

CERTIFIED BY: Heidi Rayo DATE: 03/21/14

Technical Director

Certification numbers: AZ Licensure AZ0775, CA NELAP - 12282CA, NJ NELAP - CA016, NY NELAP - 11291, TX NELAP - T104704434-13-6, UT NELAP CA009332013-4, VA NELAP - 460197, WA NELAP - C935
Name of Accrediting Agency: NELAP/ORELAP (Oregon Environmental Laboratory Accreditation Program)
Accreditation number: CA300005, Effective date: 10/18/2013, Expiration date: 10/17/2014.
Eurofins Air Toxics Inc.. certifies that the test results contained in this report meet all requirements of the NELAC standards

This report shall not be reproduced, except in full, without the written approval of Eurofins Air Toxics, Inc.

180 BLUE RAVINE ROAD, SUITE B FOLSOM, CA - 9563
(916) 985-1000 . (800) 985-5955 . FAX (916) 985-1020

eurofins | Air Toxics

**LABORATORY NARRATIVE**
**ASTM D-5504**
**PG&E**
**Workorder# 1403260**

One 1 Liter Tedlar Bag sample was received on March 14, 2014. The laboratory performed the analysis of sulfur compounds via ASTM D-5504 using GC/SCD. The method involves direct injection of the air sample into the GC via a fixed 1.0 mL sampling loop. See the data sheets for the reporting limits for each compound.

## Receiving Notes

There were no receiving discrepancies.

## Analytical Notes

There were no analytical discrepancies.

## Definition of Data Qualifying Flags

Seven qualifiers may have been used on the data analysis sheets and indicate as follows:
B - Compound present in laboratory blank greater than reporting limit.
J - Estimated value.
E - Exceeds instrument calibration range.
S - Saturated peak.
Q - Exceeds quality control limits.
U - Compound analyzed for but not detected above the detection limit.
M - Reported value may be biased due to apparent matrix interferences.
File extensions may have been used on the data analysis sheets and indicates as follows:
a-File was requantified
b-File was quantified by a second column and detector
r1-File was requantified for the purpose of reissue

eurofins | Air Toxics

# Summary of Detected Compounds
# SULFUR GASES BY ASTM D-5504 GC/SCD

**Client Sample ID: CPP-GS-MAR-A**

**Lab ID#: 1403260-01A**

| Compound | Rpt. Limit (ppbv) | Amount (ppbv) |
|---|---|---|
| Hydrogen Sulfide | 24 | 970 |
| Carbonyl Sulfide | 24 | 120 |
| Methyl Mercaptan | 24 | 63 |
| tert-Butyl Mercaptan | 24 | 1000 |
| Tetrahydrothiophene | 24 | 910 |

eurofins | Air Toxics

**Client Sample ID: CPP-GS-MAR-A**

**Lab ID#: 1403260-01A**

**SULFUR GASES BY ASTM D-5504 GC/SCD**

| | | | |
|---|---|---|---|
| **File Name:** | **k031412** | **Date of Collection:** | **3/14/14 11:01:00 AM** |
| **Dil. Factor:** | **6.00** | **Date of Analysis:** | **3/14/14 03:19 PM** |

| Compound | Rpt. Limit (ppbv) | Amount (ppbv) |
|---|---|---|
| Hydrogen Sulfide | 24 | 970 |
| Carbonyl Sulfide | 24 | 120 |
| Methyl Mercaptan | 24 | 63 |
| Ethyl Mercaptan | 24 | Not Detected |
| Dimethyl Sulfide | 24 | Not Detected |
| Carbon Disulfide | 30 | Not Detected |
| Isopropyl Mercaptan | 24 | Not Detected |
| tert-Butyl Mercaptan | 24 | 1000 |
| n-Propyl Mercaptan | 24 | Not Detected |
| Ethyl Methyl Sulfide | 24 | Not Detected |
| Thiophene | 24 | Not Detected |
| Isobutyl Mercaptan | 24 | Not Detected |
| Diethyl Sulfide | 24 | Not Detected |
| n-Butyl Mercaptan | 24 | Not Detected |
| Dimethyl Disulfide | 24 | Not Detected |
| 3-Methylthiophene | 24 | Not Detected |
| Tetrahydrothiophene | 24 | 910 |
| 2-Ethylthiophene | 24 | Not Detected |
| 2,5-Dimethylthiophene | 24 | Not Detected |
| Diethyl Disulfide | 24 | Not Detected |

**Container Type: 1 Liter Tedlar Bag**

eurofins | Air Toxics

**Client Sample ID: Lab Blank**

**Lab ID#: 1403260-02A**

**SULFUR GASES BY ASTM D-5504 GC/SCD**

| | | | |
|---|---|---|---|
| **File Name:** | **k031405** | **Date of Collection: NA** | |
| **Dil. Factor:** | **1.00** | **Date of Analysis: 3/13/14 09:56 PM** | |

| **Compound** | **Rpt. Limit (ppbv)** | **Amount (ppbv)** |
|---|---|---|
| Hydrogen Sulfide | 4.0 | Not Detected |
| Carbonyl Sulfide | 4.0 | Not Detected |
| Methyl Mercaptan | 4.0 | Not Detected |
| Ethyl Mercaptan | 4.0 | Not Detected |
| Dimethyl Sulfide | 4.0 | Not Detected |
| Carbon Disulfide | 5.0 | Not Detected |
| Isopropyl Mercaptan | 4.0 | Not Detected |
| tert-Butyl Mercaptan | 4.0 | Not Detected |
| n-Propyl Mercaptan | 4.0 | Not Detected |
| Ethyl Methyl Sulfide | 4.0 | Not Detected |
| Thiophene | 4.0 | Not Detected |
| Isobutyl Mercaptan | 4.0 | Not Detected |
| Diethyl Sulfide | 4.0 | Not Detected |
| n-Butyl Mercaptan | 4.0 | Not Detected |
| Dimethyl Disulfide | 4.0 | Not Detected |
| 3-Methylthiophene | 4.0 | Not Detected |
| Tetrahydrothiophene | 4.0 | Not Detected |
| 2-Ethylthiophene | 4.0 | Not Detected |
| 2,5-Dimethylthiophene | 4.0 | Not Detected |
| Diethyl Disulfide | 4.0 | Not Detected |

**Container Type: NA - Not Applicable**

eurofins | Air Toxics

**Client Sample ID: LCS**

**Lab ID#: 1403260-03A**

**SULFUR GASES BY ASTM D-5504 GC/SCD**

| | | | |
|---|---|---|---|
| **File Name:** | **k031403** | **Date of Collection: NA** | |
| **Dil. Factor:** | **1.00** | **Date of Analysis: 3/13/14 09:04 PM** | |

| **Compound** | **%Recovery** | **Method Limits** |
|---|---|---|
| Hydrogen Sulfide | 83 | 70-130 |
| Carbonyl Sulfide | 87 | 70-130 |
| Methyl Mercaptan | 86 | 70-130 |
| Ethyl Mercaptan | 98 | 70-130 |
| Dimethyl Sulfide | 94 | 70-130 |
| Carbon Disulfide | 100 | 70-130 |
| Isopropyl Mercaptan | 92 | 70-130 |
| tert-Butyl Mercaptan | 93 | 70-130 |
| n-Propyl Mercaptan | 84 | 70-130 |
| Ethyl Methyl Sulfide | 87 | 70-130 |
| Thiophene | 90 | 70-130 |
| Isobutyl Mercaptan | 88 | 70-130 |
| Diethyl Sulfide | 93 | 70-130 |
| n-Butyl Mercaptan | 75 | 70-130 |
| Dimethyl Disulfide | 86 | 70-130 |
| 3-Methylthiophene | 86 | 70-130 |
| Tetrahydrothiophene | 92 | 70-130 |
| 2-Ethylthiophene | 90 | 70-130 |
| 2,5-Dimethylthiophene | 88 | 70-130 |
| Diethyl Disulfide | 98 | 70-130 |

**Container Type: NA - Not Applicable**

eurofins | Air Toxics

**Client Sample ID: LCSD**

**Lab ID#: 1403260-03AA**

**SULFUR GASES BY ASTM D-5504 GC/SCD**

| | | | |
|---|---|---|---|
| **File Name:** | **k031404** | **Date of Collection: NA** | |
| **Dil. Factor:** | **1.00** | **Date of Analysis: 3/13/14 09:33 PM** | |

| **Compound** | **%Recovery** | **Method Limits** |
|---|---|---|
| Hydrogen Sulfide | 82 | 70-130 |
| Carbonyl Sulfide | 87 | 70-130 |
| Methyl Mercaptan | 87 | 70-130 |
| Ethyl Mercaptan | 95 | 70-130 |
| Dimethyl Sulfide | 91 | 70-130 |
| Carbon Disulfide | 97 | 70-130 |
| Isopropyl Mercaptan | 92 | 70-130 |
| tert-Butyl Mercaptan | 94 | 70-130 |
| n-Propyl Mercaptan | 86 | 70-130 |
| Ethyl Methyl Sulfide | 90 | 70-130 |
| Thiophene | 90 | 70-130 |
| Isobutyl Mercaptan | 91 | 70-130 |
| Diethyl Sulfide | 92 | 70-130 |
| n-Butyl Mercaptan | 73 | 70-130 |
| Dimethyl Disulfide | 85 | 70-130 |
| 3-Methylthiophene | 84 | 70-130 |
| Tetrahydrothiophene | 93 | 70-130 |
| 2-Ethylthiophene | 88 | 70-130 |
| 2,5-Dimethylthiophene | 83 | 70-130 |
| Diethyl Disulfide | 98 | 70-130 |

**Container Type: NA - Not Applicable**

1403260

**Chain of Custody Record** | **Pacific Gas and Electric Company** | 

**SAM #**

| | | | | |
|---|---|---|---|---|
| Client: PG&E Environmental Services | | Project Manager: Clem Da Silva | | Date: 3/14/14 |
| Address: 3400 Crow Canyon Road | | Telephone Number: 925-866-5421 | Email: codu@pge.com | Laboratory: Air Toxics |
| City: San Ramon | State: CA | Zip: 94583 | Site Contact: Clem Da Silva 925.866.5421 | Laboratory Phone: 916-985-1000 |
| Project Number/Name: Natural Gas Sampling | | | Sampler: Steve North 925-705-3039 | Laboratory Fax: |
| Contract Number, PO Number: | | Laboratory Contact: 180 Blue Ravine Rd. Folsom CA, 95630 | | |

Preparation and Analysis

| PG&E Sample ID | SAM#-ID# | Date | Time | Sample Type | Containers: Volume | Containers: Type | Containers: No. | Preservative | Condition on Receipt/Comments | Still-F | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| CPP-GS-MAR-A | 01 | 3/14/14 | 1304 | Gas | 1 liter | bag | 1 | None | | X | | | | | | | |
| | | | | Gas | 1 liter | bag | 1 | None | | X | | | | | | | |

**Special Instruction:** Please hold samples for 45 days.
Email results to Clem daSilva CODU@PGE.COM and Laurel Eastman LKE1@PGE.COM

| Turn Around Time Required | QC Level | Project Specific Requirements (Specify) |
|---|---|---|
| ☒ Normal ☐ Rush ☐ Other | ☒ I ☐ II ☐ III | |

| | | | | | |
|---|---|---|---|---|---|
| 1. Relinquished By: Steve North | Date: 3/14/14 | Time: 13:04 | 1. Received By | Date: 3/14/14 | Time: 13:04 |
| 2. Relinquished By: | Date: | Time: | 2. Received By | Date: | Time: |
| 3. Relinquished By: | Date: | Time: | 3. Received By | Date: | Time: |

Comments

Custody Seal Intact? Y N None Temp N/A

Blank CofC.xls

# ATTACHMENT 3
## 40 CFR 60 Section KKKK (AQ-13)

40 CFR 60 KKKK Emission Limits:

Natural Gas Fired Combustion Turbine > 850 MMBtu

15 PPMVDC @ 15% $O_2$; 4 Hour Rolling Average

During Normal Operations

96 PPMVDC @ 15%; 4 Hour Rolling Average

Turbines operating at less than 75% of Peak Load (Startup/Shutdown)

**KKKK Compliance (Colusa Generating Station)**

40 CFR Part 60 Subpart KKKK applies to all stationary gas turbines rated at greater than or equal to 10 MMBtu/hr that commence construction, modification, or reconstruction after February 18, 2005. The gas turbines involved in this project have a rating of 1612 MMBtu/hr and were installed after February 18, 2005. Therefore, this subpart applies to these gas turbines. The KKKK compliance summaries for the stationary natural gas turbines is summarized below and are based on the following applicable sections of the KKKK performance standards. The non-applicable portions of KKKK are not listed in the compliance summary:

| Section | Requirement |
|---|---|
| 60.4305 | CGS Turbines/HRSGs are rated at larger than 10 mmbtu/hr and construction commenced after February 18, 2005. Subpart KKKK applies. |
| 60.4310 | No exemptions apply. |
| 60.4315 | Pollutants regulated under Subpart KKKK: $NO_x$ and $SO_2$. |
| 60.4320 | NOx emissions limit: 15 ppmv @15%$O_2$ |
| 60.4330 | SO2 emissions limit: 0.90 lbs SO2/MWh (gross output), or<br>cannot burn any fuel which contains total potential sulfur emissions in excess of 0.060 lbs SO2/MMBtu (heat input). |
| 60.4333 | Operate turbine/HRSG, APC systems, and monitoring equipment to minimize emissions at all times including during startup, shutdown, and malfunction. |
| 60.4340(b)(1) | For units with SCR, install a $NO_x$ CEMS per 60.4335(b) or 60.4345. If Part 75 applies, $NO_x$ can be monitored per Appendix E of Part 75. (CGS QAP applies here) |
| 60.4345 | Meet all CEMS Performance Specs and develop a QA Plan for the CEMS. . (CGS QAP applies here) |
| 60.4350 | All CEMS data must be reduced to hourly averages per 60.13(h). . (CGS QAP applies here) |
| 60.4355 | If applicable, develop and insure all parametric monitoring and monitoring plans comply with this section. . (CGS QAP applies here) |
| 60.4360 | Monitor fuel sulfur content, or invoke exemption per 60.4365. |
| 60.4365 | Exemption for fuel sulfur monitoring, if fuel is demonstrated not to exceed potential sulfur emissions of 0.060 lbs $SO_2$/MMBtu, Use PG&E gas quality data to show that exemption applies per 60.4365 (a) or (b). |
| 60.4375 | Submit excess emissions reports per 60.7(c). Within 30 days following the end of each 6 month period (see 60.4395). In compliance. |
| 60.4380(b) | Determine excess emissions and monitor downtime per (b) (1-3) |
| 60.4400 | Initial and annual $NO_X$ performance tests not required if CEMS used |

| | |
|---|---|
| | per 60.4340(b)(1) |
| 60.4405 | If $NO_x$ CEMS used, use 60.4405 (a-d) procedures in lieu of performance test. |
| 60.4415 | Perform initial $SO_2$ performance test per 60.4415 (2) or (3). This test must be conducted even if the 60.4365 exemption is invoked. |

Compliance with the applicable provisions of NSPS KKKK are summarized below. Specific data to support the compliance determinations listed below are included as attachments.

| Section | Compliance |
|---|---|
| 60.4305 | KKKK is applicable to the facility. In compliance |
| 60.4310 | No exemptions apply. |
| 60.4315 | $NO_x$ and $SO_2$ are in compliance with the KKKK emission standards and monitoring requirements. |
| 60.4320 | $NO_x$ emissions limit: 9 ppmv @15%$O_2$ (See attached GE data sheet). In compliance. |
| 60.4330 | $SO_2$ emissions limit:<br>CT1 172 MW 1.283 lb/hr ($SO_2$ source test date: 2010)<br>CT2 172 MW 1.649 lb/hr ($SO_2$ source test date: 2010)<br>CT1 - 1.283/172 = 0.0075 lb/MWh<br>CT2 - 1.649/172 = 0.0096 lb/MWh<br>In compliance with SO2 emission limits. The project will only use pipe quality natural gas with sulfur limits less than 0.06 lbs/MMBtu. See attached natural gas fuel analysis. In compliance with limits based on monthly fuel sampling. |
| 60.4333 | The facility will operate turbine/HRSG, APC systems, and monitoring equipment to minimize emissions at all times including during startup, shutdown, and malfunction. In compliance. |
| 60.4340(b)(1) | CT1 and CT2 utilize SCR and $NO_x$ CEMS per 60.4335(b) or 60.4345. In addition, Part 75 applies and $NO_x$ is monitored per Appendix E of Part 75. See attached Quality Assurance Plan (attached). In compliance. |
| 60.4345 | In compliance. . |
| 60.4350 | In compliance |
| 60.4355 | In compliance |
| 60.4360 | In compliance through exemption per 60.4365. |
| 60.4365 | Requesting exemption (a) and (b) for sulfur monitoring. The fuel used is pipeline quality natural gas with an average grain loading less than 0.30 gr/100 SCF which converts to 0.0008 lb/MMBtu of $SO_2$. See fuel |

| | |
|---|---|
| | analysis Attachment 2. Annual compliance based on PG&E supplied fuel analysis data. |
| 60.4375 | No excess emissions during this reporting period. In compliance. |
| 60.4380(b) | No excess emissions or monitor downtime, per (b) (1-3). In compliance. |
| 60.4400 | In compliance. $NO_x$ CEMs used per 60.4340(b)(1). $NO_x$, CO, and VOC will be tested annually. |
| 60.4405 | In compliance. See QAP for CEMs certification. |
| 60.4415 | In compliance. Initial $SO_2$ source test results and QAP are available upon request. Future compliance under this requirement may be determined using one of three methods summarized in 60.4415. |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/01/2014 00:00 | 1 | 1 |
| 01/01/2014 01:00 | 1 | 1 |
| 01/01/2014 02:00 | 1 | 1 |
| 01/01/2014 03:00 | 1 | 2 |
| 01/01/2014 04:00 | 1 | 2 |
| 01/01/2014 05:00 | 1 | 2 |
| 01/01/2014 06:00 | 1 | 2 |
| 01/01/2014 07:00 | 1 | 2 |
| 01/01/2014 08:00 | 1 | 2 |
| 01/01/2014 09:00 | 1 | 2 |
| 01/01/2014 10:00 | 1 | 2 |
| 01/01/2014 11:00 | 1 | 2 |
| 01/01/2014 12:00 | 1 | 2 |
| 01/01/2014 13:00 | 1 | 16 |
| 01/01/2014 14:00 | 1 | 21 |
| 01/01/2014 15:00 | 1 | 21 |
| 01/01/2014 16:00 | 14 | 20 |
| 01/01/2014 17:00 | 18 | 6 |
| 01/01/2014 18:00 | 18 | 1 |
| 01/01/2014 19:00 | 18 | 1 |
| 01/01/2014 20:00 | 5 | 1 |
| 01/01/2014 21:00 | 1 | 1 |
| 01/01/2014 22:00 | 1 | 1 |
| 01/01/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 4 | 5 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 18 | 21 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/02/2014 00:00 | 1 | 1 |
| 01/02/2014 01:00 | 1 | 1 |
| 01/02/2014 02:00 | 1 | 1 |
| 01/02/2014 03:00 | 1 | 1 |
| 01/02/2014 04:00 | 1 | 1 |
| 01/02/2014 05:00 | 1 | 1 |
| 01/02/2014 06:00 | 1 | 1 |
| 01/02/2014 07:00 | 1 | 1 |
| 01/02/2014 08:00 | 1 | 1 |
| 01/02/2014 09:00 | 1 | 1 |
| 01/02/2014 10:00 | 1 | 1 |
| 01/02/2014 11:00 | 1 | 1 |
| 01/02/2014 12:00 | 1 | 1 |
| 01/02/2014 13:00 | 1 | 1 |
| 01/02/2014 14:00 | 1 | 1 |
| 01/02/2014 15:00 | 1 | 1 |
| 01/02/2014 16:00 | 1 | 1 |
| 01/02/2014 17:00 | 1 | 1 |
| 01/02/2014 18:00 | 1 | 1 |
| 01/02/2014 19:00 | 1 | 1 |
| 01/02/2014 20:00 | 1 | 1 |
| 01/02/2014 21:00 | 1 | 1 |
| 01/02/2014 22:00 | 1 | 1 |
| 01/02/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/03/2014 00:00 | 1 | 1 |
| 01/03/2014 01:00 | 1 | 1 |
| 01/03/2014 02:00 | 1 | 1 |
| 01/03/2014 03:00 | 1 | 1 |
| 01/03/2014 04:00 | 1 | 1 |
| 01/03/2014 05:00 | 1 | 1 |
| 01/03/2014 06:00 | 1 | 1 |
| 01/03/2014 07:00 | 1 | 1 |
| 01/03/2014 08:00 | 1 | 1 |
| 01/03/2014 09:00 | 1 | 1 |
| 01/03/2014 10:00 | 1 | 1 |
| 01/03/2014 11:00 | 1 | 1 |
| 01/03/2014 12:00 | 1 | 1 |
| 01/03/2014 13:00 | 1 | 1 |
| 01/03/2014 14:00 | 1 | 1 |
| 01/03/2014 15:00 | 1 | 1 |
| 01/03/2014 16:00 | 1 | 1 |
| 01/03/2014 17:00 | 1 | 1 |
| 01/03/2014 18:00 | 1 | 1 |
| 01/03/2014 19:00 | 1 | 1 |
| 01/03/2014 20:00 | 1 | 1 |
| 01/03/2014 21:00 | 1 | 1 |
| 01/03/2014 22:00 | 1 | 1 |
| 01/03/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/04/2014 00:00 | 1 | 1 |
| 01/04/2014 01:00 | 1 | 1 |
| 01/04/2014 02:00 | 1 | 1 |
| 01/04/2014 03:00 | 1 | 1 |
| 01/04/2014 04:00 | 1 | 1 |
| 01/04/2014 05:00 | 1 | 1 |
| 01/04/2014 06:00 | 1 | 1 |
| 01/04/2014 07:00 | 1 | 1 |
| 01/04/2014 08:00 | 1 | 1 |
| 01/04/2014 09:00 | 1 | 1 |
| 01/04/2014 10:00 | 1 | 1 |
| 01/04/2014 11:00 | 1 | 1 |
| 01/04/2014 12:00 | 1 | 1 |
| 01/04/2014 13:00 | 1 | 1 |
| 01/04/2014 14:00 | 1 | 1 |
| 01/04/2014 15:00 | 1 | 1 |
| 01/04/2014 16:00 | 1 | 1 |
| 01/04/2014 17:00 | 1 | 1 |
| 01/04/2014 18:00 | 1 | 1 |
| 01/04/2014 19:00 | 1 | 1 |
| 01/04/2014 20:00 | 1 | 1 |
| 01/04/2014 21:00 | 1 | 1 |
| 01/04/2014 22:00 | 1 | 1 |
| 01/04/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/05/2014 00:00 | 1 | 1 |
| 01/05/2014 01:00 | 1 | 1 |
| 01/05/2014 02:00 | 1 | 1 |
| 01/05/2014 03:00 | 1 | 1 |
| 01/05/2014 04:00 | 1 | 1 |
| 01/05/2014 05:00 | 1 | 1 |
| 01/05/2014 06:00 | 1 | 1 |
| 01/05/2014 07:00 | 1 | 1 |
| 01/05/2014 08:00 | 1 | 1 |
| 01/05/2014 09:00 | 1 | 1 |
| 01/05/2014 10:00 | 1 | 1 |
| 01/05/2014 11:00 | 1 | 1 |
| 01/05/2014 12:00 | 1 | 1 |
| 01/05/2014 13:00 | 1 | 1 |
| 01/05/2014 14:00 | 1 | 1 |
| 01/05/2014 15:00 | 1 | 1 |
| 01/05/2014 16:00 | 1 | 1 |
| 01/05/2014 17:00 | 1 | 1 |
| 01/05/2014 18:00 | 1 | 1 |
| 01/05/2014 19:00 | 1 | 1 |
| 01/05/2014 20:00 | 1 | 1 |
| 01/05/2014 21:00 | 1 | 1 |
| 01/05/2014 22:00 | 1 | 1 |
| 01/05/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/06/2014 00:00 | 1 | 1 |
| 01/06/2014 01:00 | 1 | 1 |
| 01/06/2014 02:00 | 1 | 1 |
| 01/06/2014 03:00 | 1 | 1 |
| 01/06/2014 04:00 | 1 | 1 |
| 01/06/2014 05:00 | 1 | 1 |
| 01/06/2014 06:00 | 1 | 1 |
| 01/06/2014 07:00 | 1 | 1 |
| 01/06/2014 08:00 | 1 | 1 |
| 01/06/2014 09:00 | 1 | 1 |
| 01/06/2014 10:00 | 1 | 1 |
| 01/06/2014 11:00 | 1 | 1 |
| 01/06/2014 12:00 | 1 | 1 |
| 01/06/2014 13:00 | 1 | 1 |
| 01/06/2014 14:00 | 1 | 1 |
| 01/06/2014 15:00 | 1 | 1 |
| 01/06/2014 16:00 | 1 | 1 |
| 01/06/2014 17:00 | 1 | 1 |
| 01/06/2014 18:00 | 1 | 1 |
| 01/06/2014 19:00 | 1 | 1 |
| 01/06/2014 20:00 | 1 | 1 |
| 01/06/2014 21:00 | 1 | 1 |
| 01/06/2014 22:00 | 1 | 1 |
| 01/06/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/07/2014 00:00 | 1 | 1 |
| 01/07/2014 01:00 | 1 | 1 |
| 01/07/2014 02:00 | 1 | 1 |
| 01/07/2014 03:00 | 1 | 1 |
| 01/07/2014 04:00 | 1 | 1 |
| 01/07/2014 05:00 | 1 | 1 |
| 01/07/2014 06:00 | 1 | 1 |
| 01/07/2014 07:00 | 1 | 1 |
| 01/07/2014 08:00 | 1 | 1 |
| 01/07/2014 09:00 | 1 | 1 |
| 01/07/2014 10:00 | 1 | 1 |
| 01/07/2014 11:00 | 1 | 1 |
| 01/07/2014 12:00 | 1 | 1 |
| 01/07/2014 13:00 | 1 | 1 |
| 01/07/2014 14:00 | 1 | 1 |
| 01/07/2014 15:00 | 1 | 1 |
| 01/07/2014 16:00 | 1 | 1 |
| 01/07/2014 17:00 | 1 | 1 |
| 01/07/2014 18:00 | 1 | 1 |
| 01/07/2014 19:00 | 1 | 1 |
| 01/07/2014 20:00 | 1 | 1 |
| 01/07/2014 21:00 | 1 | 1 |
| 01/07/2014 22:00 | 1 | 1 |
| 01/07/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/08/2014 00:00 | 1 | 1 |
| 01/08/2014 01:00 | 1 | 1 |
| 01/08/2014 02:00 | 1 | 1 |
| 01/08/2014 03:00 | 1 | 1 |
| 01/08/2014 04:00 | 1 | 1 |
| 01/08/2014 05:00 | 1 | 1 |
| 01/08/2014 06:00 | 1 | 1 |
| 01/08/2014 07:00 | 1 | 1 |
| 01/08/2014 08:00 | 1 | 1 |
| 01/08/2014 09:00 | 1 | 1 |
| 01/08/2014 10:00 | 1 | 1 |
| 01/08/2014 11:00 | 1 | 1 |
| 01/08/2014 12:00 | 1 | 1 |
| 01/08/2014 13:00 | 1 | 1 |
| 01/08/2014 14:00 | 1 | 1 |
| 01/08/2014 15:00 | 1 | 1 |
| 01/08/2014 16:00 | 1 | 1 |
| 01/08/2014 17:00 | 1 | 1 |
| 01/08/2014 18:00 | 1 | 1 |
| 01/08/2014 19:00 | 1 | 1 |
| 01/08/2014 20:00 | 1 | 1 |
| 01/08/2014 21:00 | 1 | 1 |
| 01/08/2014 22:00 | 2 | 3 |
| 01/08/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/09/2014 00:00 | 2 | 3 |
| 01/09/2014 01:00 | 2 | 3 |
| 01/09/2014 02:00 | 2 | 3 |
| 01/09/2014 03:00 | 2 | 3 |
| 01/09/2014 04:00 | 2 | 3 |
| 01/09/2014 05:00 | 2 | 3 |
| 01/09/2014 06:00 | 2 | 3 |
| 01/09/2014 07:00 | 2 | 3 |
| 01/09/2014 08:00 | 2 | 3 |
| 01/09/2014 09:00 | 2 | 3 |
| 01/09/2014 10:00 | 2 | 3 |
| 01/09/2014 11:00 | 2 | 3 |
| 01/09/2014 12:00 | 2 | 3 |
| 01/09/2014 13:00 | 2 | 3 |
| 01/09/2014 14:00 | 2 | 3 |
| 01/09/2014 15:00 | 2 | 3 |
| 01/09/2014 16:00 | 2 | 3 |
| 01/09/2014 17:00 | 2 | 3 |
| 01/09/2014 18:00 | 2 | 3 |
| 01/09/2014 19:00 | 2 | 3 |
| 01/09/2014 20:00 | 2 | 3 |
| 01/09/2014 21:00 | 2 | 3 |
| 01/09/2014 22:00 | 2 | 3 |
| 01/09/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/10/2014 00:00 | 2 | 3 |
| 01/10/2014 01:00 | 2 | 3 |
| 01/10/2014 02:00 | 2 | 3 |
| 01/10/2014 03:00 | 2 | 3 |
| 01/10/2014 04:00 | 2 | 3 |
| 01/10/2014 05:00 | 2 | 3 |
| 01/10/2014 06:00 | 2 | 3 |
| 01/10/2014 07:00 | 2 | 3 |
| 01/10/2014 08:00 | 2 | 3 |
| 01/10/2014 09:00 | 2 | 3 |
| 01/10/2014 10:00 | 2 | 3 |
| 01/10/2014 11:00 | 2 | 3 |
| 01/10/2014 12:00 | 2 | 3 |
| 01/10/2014 13:00 | 2 | 3 |
| 01/10/2014 14:00 | 2 | 3 |
| 01/10/2014 15:00 | 2 | 3 |
| 01/10/2014 16:00 | 2 | 3 |
| 01/10/2014 17:00 | 2 | 3 |
| 01/10/2014 18:00 | 2 | 3 |
| 01/10/2014 19:00 | 2 | 3 |
| 01/10/2014 20:00 | 2 | 3 |
| 01/10/2014 21:00 | 2 | 3 |
| 01/10/2014 22:00 | 2 | 3 |
| 01/10/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/11/2014 00:00 | 2 | 3 |
| 01/11/2014 01:00 | 2 | 3 |
| 01/11/2014 02:00 | 2 | 3 |
| 01/11/2014 03:00 | 2 | 3 |
| 01/11/2014 04:00 | 2 | 3 |
| 01/11/2014 05:00 | 2 | 3 |
| 01/11/2014 06:00 | 2 | 3 |
| 01/11/2014 07:00 | 2 | 3 |
| 01/11/2014 08:00 | 2 | 3 |
| 01/11/2014 09:00 | 2 | 3 |
| 01/11/2014 10:00 | 2 | 3 |
| 01/11/2014 11:00 | 2 | 3 |
| 01/11/2014 12:00 | 2 | 3 |
| 01/11/2014 13:00 | 2 | 3 |
| 01/11/2014 14:00 | 2 | 3 |
| 01/11/2014 15:00 | 2 | 3 |
| 01/11/2014 16:00 | 2 | 3 |
| 01/11/2014 17:00 | 2 | 3 |
| 01/11/2014 18:00 | 2 | 3 |
| 01/11/2014 19:00 | 2 | 3 |
| 01/11/2014 20:00 | 2 | 3 |
| 01/11/2014 21:00 | 2 | 3 |
| 01/11/2014 22:00 | 2 | 3 |
| 01/11/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/12/2014 00:00 | 2 | 3 |
| 01/12/2014 01:00 | 2 | 3 |
| 01/12/2014 02:00 | 2 | 3 |
| 01/12/2014 03:00 | 2 | 3 |
| 01/12/2014 04:00 | 2 | 3 |
| 01/12/2014 05:00 | 2 | 3 |
| 01/12/2014 06:00 | 2 | 3 |
| 01/12/2014 07:00 | 2 | 3 |
| 01/12/2014 08:00 | 2 | 3 |
| 01/12/2014 09:00 | 2 | 3 |
| 01/12/2014 10:00 | 2 | 3 |
| 01/12/2014 11:00 | 2 | 3 |
| 01/12/2014 12:00 | 2 | 3 |
| 01/12/2014 13:00 | 2 | 3 |
| 01/12/2014 14:00 | 2 | 3 |
| 01/12/2014 15:00 | 2 | 3 |
| 01/12/2014 16:00 | 2 | 3 |
| 01/12/2014 17:00 | 2 | 3 |
| 01/12/2014 18:00 | 2 | 3 |
| 01/12/2014 19:00 | 2 | 3 |
| 01/12/2014 20:00 | 2 | 3 |
| 01/12/2014 21:00 | 2 | 3 |
| 01/12/2014 22:00 | 2 | 3 |
| 01/12/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/13/2014 00:00 | 2 | 3 |
| 01/13/2014 01:00 | 2 | 3 |
| 01/13/2014 02:00 | 2 | 3 |
| 01/13/2014 03:00 | 2 | 3 |
| 01/13/2014 04:00 | 2 | 3 |
| 01/13/2014 05:00 | 2 | 3 |
| 01/13/2014 06:00 | 2 | 3 |
| 01/13/2014 07:00 | 2 | 3 |
| 01/13/2014 08:00 | 2 | 3 |
| 01/13/2014 09:00 | 2 | 3 |
| 01/13/2014 10:00 | 2 | 3 |
| 01/13/2014 11:00 | 2 | 3 |
| 01/13/2014 12:00 | 2 | 3 |
| 01/13/2014 13:00 | 2 | 3 |
| 01/13/2014 14:00 | 2 | 3 |
| 01/13/2014 15:00 | 2 | 3 |
| 01/13/2014 16:00 | 2 | 3 |
| 01/13/2014 17:00 | 2 | 3 |
| 01/13/2014 18:00 | 2 | 3 |
| 01/13/2014 19:00 | 2 | 3 |
| 01/13/2014 20:00 | 2 | 3 |
| 01/13/2014 21:00 | 2 | 3 |
| 01/13/2014 22:00 | 2 | 3 |
| 01/13/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/14/2014 00:00 | 2 | 3 |
| 01/14/2014 01:00 | 2 | 3 |
| 01/14/2014 02:00 | 2 | 3 |
| 01/14/2014 03:00 | 2 | 3 |
| 01/14/2014 04:00 | 2 | 3 |
| 01/14/2014 05:00 | 2 | 3 |
| 01/14/2014 06:00 | 2 | 3 |
| 01/14/2014 07:00 | 2 | 3 |
| 01/14/2014 08:00 | 2 | 3 |
| 01/14/2014 09:00 | 2 | 3 |
| 01/14/2014 10:00 | 2 | 3 |
| 01/14/2014 11:00 | 2 | 3 |
| 01/14/2014 12:00 | 2 | 3 |
| 01/14/2014 13:00 | 2 | 3 |
| 01/14/2014 14:00 | 2 | 3 |
| 01/14/2014 15:00 | 2 | 3 |
| 01/14/2014 16:00 | 2 | 3 |
| 01/14/2014 17:00 | 2 | 3 |
| 01/14/2014 18:00 | 2 | 3 |
| 01/14/2014 19:00 | 2 | 3 |
| 01/14/2014 20:00 | 2 | 3 |
| 01/14/2014 21:00 | 2 | 3 |
| 01/14/2014 22:00 | 2 | 3 |
| 01/14/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/15/2014 00:00 | 2 | 3 |
| 01/15/2014 01:00 | 2 | 3 |
| 01/15/2014 02:00 | 2 | 3 |
| 01/15/2014 03:00 | 2 | 3 |
| 01/15/2014 04:00 | 2 | 3 |
| 01/15/2014 05:00 | 2 | 3 |
| 01/15/2014 06:00 | 2 | 3 |
| 01/15/2014 07:00 | 2 | 3 |
| 01/15/2014 08:00 | 2 | 3 |
| 01/15/2014 09:00 | 2 | 3 |
| 01/15/2014 10:00 | 2 | 3 |
| 01/15/2014 11:00 | 2 | 3 |
| 01/15/2014 12:00 | 2 | 3 |
| 01/15/2014 13:00 | 2 | 3 |
| 01/15/2014 14:00 | 2 | 3 |
| 01/15/2014 15:00 | 2 | 3 |
| 01/15/2014 16:00 | 2 | 3 |
| 01/15/2014 17:00 | 2 | 3 |
| 01/15/2014 18:00 | 2 | 3 |
| 01/15/2014 19:00 | 2 | 3 |
| 01/15/2014 20:00 | 2 | 3 |
| 01/15/2014 21:00 | 2 | 3 |
| 01/15/2014 22:00 | 2 | 3 |
| 01/15/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/16/2014 00:00 | 2 | 3 |
| 01/16/2014 01:00 | 2 | 3 |
| 01/16/2014 02:00 | 2 | 3 |
| 01/16/2014 03:00 | 2 | 3 |
| 01/16/2014 04:00 | 2 | 3 |
| 01/16/2014 05:00 | 2 | 3 |
| 01/16/2014 06:00 | 2 | 3 |
| 01/16/2014 07:00 | 2 | 3 |
| 01/16/2014 08:00 | 2 | 3 |
| 01/16/2014 09:00 | 2 | 3 |
| 01/16/2014 10:00 | 2 | 3 |
| 01/16/2014 11:00 | 2 | 3 |
| 01/16/2014 12:00 | 2 | 3 |
| 01/16/2014 13:00 | 2 | 3 |
| 01/16/2014 14:00 | 2 | 3 |
| 01/16/2014 15:00 | 2 | 3 |
| 01/16/2014 16:00 | 2 | 3 |
| 01/16/2014 17:00 | 2 | 3 |
| 01/16/2014 18:00 | 2 | 3 |
| 01/16/2014 19:00 | 2 | 3 |
| 01/16/2014 20:00 | 2 | 3 |
| 01/16/2014 21:00 | 2 | 3 |
| 01/16/2014 22:00 | 2 | 3 |
| 01/16/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/17/2014 00:00 | 2 | 3 |
| 01/17/2014 01:00 | 2 | 3 |
| 01/17/2014 02:00 | 2 | 3 |
| 01/17/2014 03:00 | 2 | 3 |
| 01/17/2014 04:00 | 2 | 3 |
| 01/17/2014 05:00 | 2 | 3 |
| 01/17/2014 06:00 | 2 | 3 |
| 01/17/2014 07:00 | 2 | 3 |
| 01/17/2014 08:00 | 2 | 3 |
| 01/17/2014 09:00 | 2 | 3 |
| 01/17/2014 10:00 | 2 | 3 |
| 01/17/2014 11:00 | 2 | 3 |
| 01/17/2014 12:00 | 2 | 3 |
| 01/17/2014 13:00 | 2 | 3 |
| 01/17/2014 14:00 | 2 | 3 |
| 01/17/2014 15:00 | 2 | 3 |
| 01/17/2014 16:00 | 2 | 3 |
| 01/17/2014 17:00 | 2 | 3 |
| 01/17/2014 18:00 | 2 | 3 |
| 01/17/2014 19:00 | 2 | 3 |
| 01/17/2014 20:00 | 2 | 3 |
| 01/17/2014 21:00 | 2 | 3 |
| 01/17/2014 22:00 | 2 | 3 |
| 01/17/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/18/2014 00:00 | 2 | 3 |
| 01/18/2014 01:00 | 2 | 3 |
| 01/18/2014 02:00 | 2 | 3 |
| 01/18/2014 03:00 | 2 | 3 |
| 01/18/2014 04:00 | 2 | 3 |
| 01/18/2014 05:00 | 2 | 3 |
| 01/18/2014 06:00 | 2 | 3 |
| 01/18/2014 07:00 | 2 | 3 |
| 01/18/2014 08:00 | 2 | 3 |
| 01/18/2014 09:00 | 2 | 3 |
| 01/18/2014 10:00 | 2 | 3 |
| 01/18/2014 11:00 | 2 | 3 |
| 01/18/2014 12:00 | 2 | 3 |
| 01/18/2014 13:00 | 2 | 3 |
| 01/18/2014 14:00 | 2 | 3 |
| 01/18/2014 15:00 | 2 | 3 |
| 01/18/2014 16:00 | 2 | 3 |
| 01/18/2014 17:00 | 2 | 3 |
| 01/18/2014 18:00 | 2 | 3 |
| 01/18/2014 19:00 | 2 | 3 |
| 01/18/2014 20:00 | 2 | 3 |
| 01/18/2014 21:00 | 2 | 3 |
| 01/18/2014 22:00 | 2 | 3 |
| 01/18/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/19/2014 00:00 | 2 | 3 |
| 01/19/2014 01:00 | 2 | 3 |
| 01/19/2014 02:00 | 2 | 3 |
| 01/19/2014 03:00 | 2 | 3 |
| 01/19/2014 04:00 | 2 | 3 |
| 01/19/2014 05:00 | 2 | 3 |
| 01/19/2014 06:00 | 2 | 3 |
| 01/19/2014 07:00 | 2 | 3 |
| 01/19/2014 08:00 | 2 | 3 |
| 01/19/2014 09:00 | 2 | 3 |
| 01/19/2014 10:00 | 2 | 3 |
| 01/19/2014 11:00 | 2 | 3 |
| 01/19/2014 12:00 | 2 | 3 |
| 01/19/2014 13:00 | 2 | 3 |
| 01/19/2014 14:00 | 2 | 3 |
| 01/19/2014 15:00 | 2 | 3 |
| 01/19/2014 16:00 | 2 | 3 |
| 01/19/2014 17:00 | 2 | 3 |
| 01/19/2014 18:00 | 2 | 3 |
| 01/19/2014 19:00 | 2 | 3 |
| 01/19/2014 20:00 | 2 | 3 |
| 01/19/2014 21:00 | 2 | 3 |
| 01/19/2014 22:00 | 2 | 3 |
| 01/19/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/20/2014 00:00 | 2 | 3 |
| 01/20/2014 01:00 | 2 | 3 |
| 01/20/2014 02:00 | 2 | 3 |
| 01/20/2014 03:00 | 2 | 3 |
| 01/20/2014 04:00 | 2 | 3 |
| 01/20/2014 05:00 | 2 | 3 |
| 01/20/2014 06:00 | 2 | 3 |
| 01/20/2014 07:00 | 2 | 3 |
| 01/20/2014 08:00 | 2 | 3 |
| 01/20/2014 09:00 | 2 | 3 |
| 01/20/2014 10:00 | 2 | 3 |
| 01/20/2014 11:00 | 2 | 3 |
| 01/20/2014 12:00 | 2 | 3 |
| 01/20/2014 13:00 | 2 | 3 |
| 01/20/2014 14:00 | 2 | 3 |
| 01/20/2014 15:00 | 2 | 3 |
| 01/20/2014 16:00 | 2 | 3 |
| 01/20/2014 17:00 | 2 | 3 |
| 01/20/2014 18:00 | 2 | 3 |
| 01/20/2014 19:00 | 2 | 3 |
| 01/20/2014 20:00 | 2 | 3 |
| 01/20/2014 21:00 | 2 | 3 |
| 01/20/2014 22:00 | 2 | 3 |
| 01/20/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/21/2014 00:00 | 2 | 3 |
| 01/21/2014 01:00 | 2 | 3 |
| 01/21/2014 02:00 | 2 | 3 |
| 01/21/2014 03:00 | 2 | 3 |
| 01/21/2014 04:00 | 2 | 3 |
| 01/21/2014 05:00 | 2 | 3 |
| 01/21/2014 06:00 | 2 | 3 |
| 01/21/2014 07:00 | 2 | 3 |
| 01/21/2014 08:00 | 2 | 3 |
| 01/21/2014 09:00 | 2 | 3 |
| 01/21/2014 10:00 | 2 | 3 |
| 01/21/2014 11:00 | 2 | 3 |
| 01/21/2014 12:00 | 2 | 3 |
| 01/21/2014 13:00 | 2 | 3 |
| 01/21/2014 14:00 | 2 | 3 |
| 01/21/2014 15:00 | 2 | 3 |
| 01/21/2014 16:00 | 2 | 3 |
| 01/21/2014 17:00 | 2 | 3 |
| 01/21/2014 18:00 | 2 | 3 |
| 01/21/2014 19:00 | 2 | 3 |
| 01/21/2014 20:00 | 2 | 3 |
| 01/21/2014 21:00 | 2 | 3 |
| 01/21/2014 22:00 | 2 | 3 |
| 01/21/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/22/2014 00:00 | 2 | 3 |
| 01/22/2014 01:00 | 2 | 3 |
| 01/22/2014 02:00 | 2 | 3 |
| 01/22/2014 03:00 | 2 | 3 |
| 01/22/2014 04:00 | 2 | 3 |
| 01/22/2014 05:00 | 2 | 3 |
| 01/22/2014 06:00 | 2 | 3 |
| 01/22/2014 07:00 | 2 | 3 |
| 01/22/2014 08:00 | 2 | 3 |
| 01/22/2014 09:00 | 2 | 3 |
| 01/22/2014 10:00 | 2 | 3 |
| 01/22/2014 11:00 | 2 | 3 |
| 01/22/2014 12:00 | 2 | 3 |
| 01/22/2014 13:00 | 2 | 3 |
| 01/22/2014 14:00 | 2 | 3 |
| 01/22/2014 15:00 | 2 | 3 |
| 01/22/2014 16:00 | 2 | 3 |
| 01/22/2014 17:00 | 2 | 3 |
| 01/22/2014 18:00 | 2 | 3 |
| 01/22/2014 19:00 | 2 | 3 |
| 01/22/2014 20:00 | 2 | 3 |
| 01/22/2014 21:00 | 2 | 3 |
| 01/22/2014 22:00 | 2 | 3 |
| 01/22/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/23/2014 00:00 | 2 | 3 |
| 01/23/2014 01:00 | 2 | 3 |
| 01/23/2014 02:00 | 2 | 3 |
| 01/23/2014 03:00 | 2 | 3 |
| 01/23/2014 04:00 | 2 | 3 |
| 01/23/2014 05:00 | 2 | 3 |
| 01/23/2014 06:00 | 2 | 3 |
| 01/23/2014 07:00 | 2 | 3 |
| 01/23/2014 08:00 | 2 | 3 |
| 01/23/2014 09:00 | 2 | 3 |
| 01/23/2014 10:00 | 2 | 3 |
| 01/23/2014 11:00 | 2 | 3 |
| 01/23/2014 12:00 | 2 | 3 |
| 01/23/2014 13:00 | 2 | 3 |
| 01/23/2014 14:00 | 2 | 3 |
| 01/23/2014 15:00 | 2 | 3 |
| 01/23/2014 16:00 | 2 | 3 |
| 01/23/2014 17:00 | 2 | 3 |
| 01/23/2014 18:00 | 2 | 3 |
| 01/23/2014 19:00 | 2 | 3 |
| 01/23/2014 20:00 | 2 | 3 |
| 01/23/2014 21:00 | 2 | 3 |
| 01/23/2014 22:00 | 2 | 3 |
| 01/23/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/24/2014 00:00 | 2 | 3 |
| 01/24/2014 01:00 | 2 | 3 |
| 01/24/2014 02:00 | 2 | 3 |
| 01/24/2014 03:00 | 2 | 3 |
| 01/24/2014 04:00 | 2 | 3 |
| 01/24/2014 05:00 | 2 | 3 |
| 01/24/2014 06:00 | 2 | 3 |
| 01/24/2014 07:00 | 2 | 3 |
| 01/24/2014 08:00 | 2 | 3 |
| 01/24/2014 09:00 | 2 | 3 |
| 01/24/2014 10:00 | 2 | 3 |
| 01/24/2014 11:00 | 2 | 3 |
| 01/24/2014 12:00 | 2 | 3 |
| 01/24/2014 13:00 | 2 | 3 |
| 01/24/2014 14:00 | 2 | 3 |
| 01/24/2014 15:00 | 2 | 3 |
| 01/24/2014 16:00 | 2 | 3 |
| 01/24/2014 17:00 | 2 | 3 |
| 01/24/2014 18:00 | 2 | 3 |
| 01/24/2014 19:00 | 2 | 3 |
| 01/24/2014 20:00 | 2 | 3 |
| 01/24/2014 21:00 | 2 | 3 |
| 01/24/2014 22:00 | 2 | 3 |
| 01/24/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/25/2014 00:00 | 2 | 3 |
| 01/25/2014 01:00 | 2 | 3 |
| 01/25/2014 02:00 | 2 | 3 |
| 01/25/2014 03:00 | 2 | 3 |
| 01/25/2014 04:00 | 2 | 3 |
| 01/25/2014 05:00 | 2 | 3 |
| 01/25/2014 06:00 | 2 | 3 |
| 01/25/2014 07:00 | 2 | 3 |
| 01/25/2014 08:00 | 2 | 3 |
| 01/25/2014 09:00 | 2 | 3 |
| 01/25/2014 10:00 | 2 | 3 |
| 01/25/2014 11:00 | 2 | 3 |
| 01/25/2014 12:00 | 2 | 3 |
| 01/25/2014 13:00 | 2 | 3 |
| 01/25/2014 14:00 | 2 | 3 |
| 01/25/2014 15:00 | 2 | 3 |
| 01/25/2014 16:00 | 2 | 3 |
| 01/25/2014 17:00 | 2 | 3 |
| 01/25/2014 18:00 | 2 | 3 |
| 01/25/2014 19:00 | 2 | 3 |
| 01/25/2014 20:00 | 2 | 3 |
| 01/25/2014 21:00 | 2 | 3 |
| 01/25/2014 22:00 | 2 | 3 |
| 01/25/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/26/2014 00:00 | 2 | 3 |
| 01/26/2014 01:00 | 2 | 3 |
| 01/26/2014 02:00 | 2 | 3 |
| 01/26/2014 03:00 | 2 | 3 |
| 01/26/2014 04:00 | 2 | 3 |
| 01/26/2014 05:00 | 2 | 3 |
| 01/26/2014 06:00 | 2 | 3 |
| 01/26/2014 07:00 | 2 | 3 |
| 01/26/2014 08:00 | 2 | 3 |
| 01/26/2014 09:00 | 2 | 3 |
| 01/26/2014 10:00 | 2 | 3 |
| 01/26/2014 11:00 | 2 | 3 |
| 01/26/2014 12:00 | 2 | 3 |
| 01/26/2014 13:00 | 2 | 3 |
| 01/26/2014 14:00 | 2 | 3 |
| 01/26/2014 15:00 | 2 | 3 |
| 01/26/2014 16:00 | 2 | 3 |
| 01/26/2014 17:00 | 2 | 3 |
| 01/26/2014 18:00 | 2 | 3 |
| 01/26/2014 19:00 | 2 | 3 |
| 01/26/2014 20:00 | 2 | 3 |
| 01/26/2014 21:00 | 2 | 3 |
| 01/26/2014 22:00 | 2 | 3 |
| 01/26/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/27/2014 00:00 | 2 | 3 |
| 01/27/2014 01:00 | 2 | 3 |
| 01/27/2014 02:00 | 2 | 3 |
| 01/27/2014 03:00 | 2 | 3 |
| 01/27/2014 04:00 | 2 | 3 |
| 01/27/2014 05:00 | 2 | 3 |
| 01/27/2014 06:00 | 2 | 3 |
| 01/27/2014 07:00 | 2 | 3 |
| 01/27/2014 08:00 | 2 | 3 |
| 01/27/2014 09:00 | 2 | 3 |
| 01/27/2014 10:00 | 2 | 3 |
| 01/27/2014 11:00 | 2 | 3 |
| 01/27/2014 12:00 | 2 | 3 |
| 01/27/2014 13:00 | 2 | 3 |
| 01/27/2014 14:00 | 2 | 3 |
| 01/27/2014 15:00 | 2 | 3 |
| 01/27/2014 16:00 | 2 | 3 |
| 01/27/2014 17:00 | 2 | 3 |
| 01/27/2014 18:00 | 2 | 3 |
| 01/27/2014 19:00 | 2 | 3 |
| 01/27/2014 20:00 | 2 | 3 |
| 01/27/2014 21:00 | 2 | 3 |
| 01/27/2014 22:00 | 2 | 3 |
| 01/27/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/28/2014 00:00 | 2 | 3 |
| 01/28/2014 01:00 | 2 | 3 |
| 01/28/2014 02:00 | 2 | 3 |
| 01/28/2014 03:00 | 2 | 3 |
| 01/28/2014 04:00 | 2 | 3 |
| 01/28/2014 05:00 | 2 | 3 |
| 01/28/2014 06:00 | 2 | 3 |
| 01/28/2014 07:00 | 2 | 3 |
| 01/28/2014 08:00 | 2 | 3 |
| 01/28/2014 09:00 | 2 | 3 |
| 01/28/2014 10:00 | 2 | 3 |
| 01/28/2014 11:00 | 2 | 3 |
| 01/28/2014 12:00 | 2 | 3 |
| 01/28/2014 13:00 | 2 | 3 |
| 01/28/2014 14:00 | 2 | 3 |
| 01/28/2014 15:00 | 2 | 3 |
| 01/28/2014 16:00 | 2 | 3 |
| 01/28/2014 17:00 | 2 | 3 |
| 01/28/2014 18:00 | 2 | 3 |
| 01/28/2014 19:00 | 2 | 3 |
| 01/28/2014 20:00 | 2 | 3 |
| 01/28/2014 21:00 | 2 | 3 |
| 01/28/2014 22:00 | 2 | 3 |
| 01/28/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 2 | 3 |
| **Minimum:** | 2 | 3 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/29/2014 00:00 | 2 | 3 |
| 01/29/2014 01:00 | 2 | 3 |
| 01/29/2014 02:00 | 2 | 3 |
| 01/29/2014 03:00 | 2 | 3 |
| 01/29/2014 04:00 | 2 | 3 |
| 01/29/2014 05:00 | 2 | 3 |
| 01/29/2014 06:00 | 2 | 3 |
| 01/29/2014 07:00 | 2 | 3 |
| 01/29/2014 08:00 | 2 | 18 |
| 01/29/2014 09:00 | 2 | 31 |
| 01/29/2014 10:00 | 2 | 36 |
| 01/29/2014 11:00 | 2 | 39 |
| 01/29/2014 12:00 | 2 | 27 |
| 01/29/2014 13:00 | 2 | 13 |
| 01/29/2014 14:00 | 16 | 9 |
| 01/29/2014 15:00 | 23 | 4 |
| 01/29/2014 16:00 | 23 | 1 |
| 01/29/2014 17:00 | 22 | 1 |
| 01/29/2014 18:00 | 8 | 1 |
| 01/29/2014 19:00 | 1 | 1 |
| 01/29/2014 20:00 | 1 | 1 |
| 01/29/2014 21:00 | 1 | 1 |
| 01/29/2014 22:00 | 1 | 1 |
| 01/29/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 5 | 9 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 23 | 39 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/30/2014 00:00 | 1 | 1 |
| 01/30/2014 01:00 | 1 | 1 |
| 01/30/2014 02:00 | 1 | 1 |
| 01/30/2014 03:00 | 1 | 1 |
| 01/30/2014 04:00 | 1 | 1 |
| 01/30/2014 05:00 | 1 | 1 |
| 01/30/2014 06:00 | 1 | 1 |
| 01/30/2014 07:00 | 1 | 1 |
| 01/30/2014 08:00 | 1 | 1 |
| 01/30/2014 09:00 | 1 | 1 |
| 01/30/2014 10:00 | 1 | 1 |
| 01/30/2014 11:00 | 1 | 1 |
| 01/30/2014 12:00 | 1 | 1 |
| 01/30/2014 13:00 | 1 | 1 |
| 01/30/2014 14:00 | 1 | 1 |
| 01/30/2014 15:00 | 1 | 1 |
| 01/30/2014 16:00 | 1 | 1 |
| 01/30/2014 17:00 | 1 | 1 |
| 01/30/2014 18:00 | 1 | 1 |
| 01/30/2014 19:00 | 1 | 1 |
| 01/30/2014 20:00 | 1 | 1 |
| 01/30/2014 21:00 | 1 | 1 |
| 01/30/2014 22:00 | 1 | 1 |
| 01/30/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 01/31/2014 00:00 | 1 | 1 |
| 01/31/2014 01:00 | 1 | 1 |
| 01/31/2014 02:00 | 1 | 1 |
| 01/31/2014 03:00 | 1 | 1 |
| 01/31/2014 04:00 | 1 | 1 |
| 01/31/2014 05:00 | 1 | 1 |
| 01/31/2014 06:00 | 1 | 1 |
| 01/31/2014 07:00 | 1 | 1 |
| 01/31/2014 08:00 | 1 | 1 |
| 01/31/2014 09:00 | 1 | 1 |
| 01/31/2014 10:00 | 1 | 1 |
| 01/31/2014 11:00 | 1 | 1 |
| 01/31/2014 12:00 | 1 | 1 |
| 01/31/2014 13:00 | 1 | 1 |
| 01/31/2014 14:00 | 1 | 1 |
| 01/31/2014 15:00 | 1 | 1 |
| 01/31/2014 16:00 | 1 | 1 |
| 01/31/2014 17:00 | 1 | 1 |
| 01/31/2014 18:00 | 1 | 1 |
| 01/31/2014 19:00 | 1 | 1 |
| 01/31/2014 20:00 | 1 | 1 |
| 01/31/2014 21:00 | 1 | 1 |
| 01/31/2014 22:00 | 1 | 1 |
| 01/31/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/01/2014 00:00 | 1 | 1 |
| 02/01/2014 01:00 | 1 | 1 |
| 02/01/2014 02:00 | 1 | 1 |
| 02/01/2014 03:00 | 1 | 1 |
| 02/01/2014 04:00 | 1 | 1 |
| 02/01/2014 05:00 | 1 | 1 |
| 02/01/2014 06:00 | 1 | 1 |
| 02/01/2014 07:00 | 1 | 1 |
| 02/01/2014 08:00 | 1 | 1 |
| 02/01/2014 09:00 | 1 | 1 |
| 02/01/2014 10:00 | 1 | 1 |
| 02/01/2014 11:00 | 1 | 1 |
| 02/01/2014 12:00 | 1 | 1 |
| 02/01/2014 13:00 | 1 | 1 |
| 02/01/2014 14:00 | 1 | 1 |
| 02/01/2014 15:00 | 1 | 1 |
| 02/01/2014 16:00 | 1 | 1 |
| 02/01/2014 17:00 | 1 | 1 |
| 02/01/2014 18:00 | 1 | 1 |
| 02/01/2014 19:00 | 1 | 1 |
| 02/01/2014 20:00 | 1 | 1 |
| 02/01/2014 21:00 | 1 | 1 |
| 02/01/2014 22:00 | 1 | 1 |
| 02/01/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/02/2014 00:00 | 1 | 1 |
| 02/02/2014 01:00 | 1 | 1 |
| 02/02/2014 02:00 | 1 | 1 |
| 02/02/2014 03:00 | 1 | 1 |
| 02/02/2014 04:00 | 1 | 1 |
| 02/02/2014 05:00 | 1 | 1 |
| 02/02/2014 06:00 | 1 | 1 |
| 02/02/2014 07:00 | 1 | 1 |
| 02/02/2014 08:00 | 1 | 1 |
| 02/02/2014 09:00 | 1 | 1 |
| 02/02/2014 10:00 | 1 | 1 |
| 02/02/2014 11:00 | 1 | 1 |
| 02/02/2014 12:00 | 1 | 1 |
| 02/02/2014 13:00 | 1 | 1 |
| 02/02/2014 14:00 | 1 | 1 |
| 02/02/2014 15:00 | 1 | 1 |
| 02/02/2014 16:00 | 1 | 1 |
| 02/02/2014 17:00 | 1 | 1 |
| 02/02/2014 18:00 | 1 | 1 |
| 02/02/2014 19:00 | 1 | 1 |
| 02/02/2014 20:00 | 1 | 1 |
| 02/02/2014 21:00 | 1 | 1 |
| 02/02/2014 22:00 | 1 | 1 |
| 02/02/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/03/2014 00:00 | 1 | 1 |
| 02/03/2014 01:00 | 1 | 1 |
| 02/03/2014 02:00 | 1 | 1 |
| 02/03/2014 03:00 | 1 | 1 |
| 02/03/2014 04:00 | 1 | 1 |
| 02/03/2014 05:00 | 1 | 1 |
| 02/03/2014 06:00 | 1 | 1 |
| 02/03/2014 07:00 | 1 | 1 |
| 02/03/2014 08:00 | 1 | 1 |
| 02/03/2014 09:00 | 1 | 1 |
| 02/03/2014 10:00 | 1 | 1 |
| 02/03/2014 11:00 | 1 | 1 |
| 02/03/2014 12:00 | 1 | 1 |
| 02/03/2014 13:00 | 1 | 1 |
| 02/03/2014 14:00 | 1 | 1 |
| 02/03/2014 15:00 | 1 | 1 |
| 02/03/2014 16:00 | 1 | 1 |
| 02/03/2014 17:00 | 1 | 1 |
| 02/03/2014 18:00 | 1 | 1 |
| 02/03/2014 19:00 | 1 | 1 |
| 02/03/2014 20:00 | 1 | 1 |
| 02/03/2014 21:00 | 1 | 1 |
| 02/03/2014 22:00 | 1 | 1 |
| 02/03/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/04/2014 00:00 | 1 | 1 |
| 02/04/2014 01:00 | 1 | 1 |
| 02/04/2014 02:00 | 1 | 1 |
| 02/04/2014 03:00 | 1 | 1 |
| 02/04/2014 04:00 | 1 | 1 |
| 02/04/2014 05:00 | 1 | 1 |
| 02/04/2014 06:00 | 1 | 1 |
| 02/04/2014 07:00 | 1 | 1 |
| 02/04/2014 08:00 | 1 | 1 |
| 02/04/2014 09:00 | 1 | 1 |
| 02/04/2014 10:00 | 1 | 1 |
| 02/04/2014 11:00 | 1 | 1 |
| 02/04/2014 12:00 | 1 | 1 |
| 02/04/2014 13:00 | 1 | 1 |
| 02/04/2014 14:00 | 1 | 1 |
| 02/04/2014 15:00 | 1 | 1 |
| 02/04/2014 16:00 | 1 | 1 |
| 02/04/2014 17:00 | 1 | 1 |
| 02/04/2014 18:00 | 1 | 1 |
| 02/04/2014 19:00 | 1 | 1 |
| 02/04/2014 20:00 | 1 | 1 |
| 02/04/2014 21:00 | 1 | 1 |
| 02/04/2014 22:00 | 1 | 1 |
| 02/04/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/05/2014 00:00 | 1 | 1 |
| 02/05/2014 01:00 | 1 | 1 |
| 02/05/2014 02:00 | 1 | 1 |
| 02/05/2014 03:00 | 1 | 1 |
| 02/05/2014 04:00 | 1 | 1 |
| 02/05/2014 05:00 | 1 | 1 |
| 02/05/2014 06:00 | 1 | 1 |
| 02/05/2014 07:00 | 1 | 1 |
| 02/05/2014 08:00 | 1 | 1 |
| 02/05/2014 09:00 | 1 | 1 |
| 02/05/2014 10:00 | 1 | 1 |
| 02/05/2014 11:00 | 1 | 1 |
| 02/05/2014 12:00 | 1 | 1 |
| 02/05/2014 13:00 | 1 | 1 |
| 02/05/2014 14:00 | 1 | 1 |
| 02/05/2014 15:00 | 1 | 1 |
| 02/05/2014 16:00 | 1 | 1 |
| 02/05/2014 17:00 | 1 | 1 |
| 02/05/2014 18:00 | 1 | 1 |
| 02/05/2014 19:00 | 1 | 1 |
| 02/05/2014 20:00 | 1 | 1 |
| 02/05/2014 21:00 | 1 | 1 |
| 02/05/2014 22:00 | 1 | 1 |
| 02/05/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit<br>Unit CT1<br>NOx_4Hr, Ppmvdc<br>1 Hour(s) | > Limit<br>Unit CT2<br>NOx_4Hr, Ppmvdc<br>1 Hour(s) |
|---|---|---|
| 02/06/2014 00:00 | 1 | 1 |
| 02/06/2014 01:00 | 1 | 1 |
| 02/06/2014 02:00 | 1 | 1 |
| 02/06/2014 03:00 | 1 | 1 |
| 02/06/2014 04:00 | 1 | 1 |
| 02/06/2014 05:00 | 1 | 1 |
| 02/06/2014 06:00 | 1 | 1 |
| 02/06/2014 07:00 | 1 | 1 |
| 02/06/2014 08:00 | 1 | 1 |
| 02/06/2014 09:00 | 1 | 1 |
| 02/06/2014 10:00 | 1 | 1 |
| 02/06/2014 11:00 | 1 | 1 |
| 02/06/2014 12:00 | 1 | 1 |
| 02/06/2014 13:00 | 1 | 1 |
| 02/06/2014 14:00 | 1 | 1 |
| 02/06/2014 15:00 | 1 | 1 |
| 02/06/2014 16:00 | 1 | 1 |
| 02/06/2014 17:00 | 1 | 1 |
| 02/06/2014 18:00 | 1 | 1 |
| 02/06/2014 19:00 | 1 | 1 |
| 02/06/2014 20:00 | 1 | 1 |
| 02/06/2014 21:00 | 1 | 1 |
| 02/06/2014 22:00 | 1 | 1 |
| 02/06/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/07/2014 00:00 | 1 | 1 |
| 02/07/2014 01:00 | 1 | 1 |
| 02/07/2014 02:00 | 1 | 1 |
| 02/07/2014 03:00 | 1 | 1 |
| 02/07/2014 04:00 | 1 | 1 |
| 02/07/2014 05:00 | 1 | 1 |
| 02/07/2014 06:00 | 1 | 1 |
| 02/07/2014 07:00 | 1 | 1 |
| 02/07/2014 08:00 | 1 | 1 |
| 02/07/2014 09:00 | 1 | 1 |
| 02/07/2014 10:00 | 1 | 1 |
| 02/07/2014 11:00 | 1 | 1 |
| 02/07/2014 12:00 | 1 | 1 |
| 02/07/2014 13:00 | 1 | 1 |
| 02/07/2014 14:00 | 1 | 1 |
| 02/07/2014 15:00 | 1 | 1 |
| 02/07/2014 16:00 | 1 | 1 |
| 02/07/2014 17:00 | 1 | 1 |
| 02/07/2014 18:00 | 1 | 1 |
| 02/07/2014 19:00 | 1 | 1 |
| 02/07/2014 20:00 | 1 | 1 |
| 02/07/2014 21:00 | 1 | 1 |
| 02/07/2014 22:00 | 1 | 1 |
| 02/07/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/08/2014 00:00 | 1 | 1 |
| 02/08/2014 01:00 | 1 | 1 |
| 02/08/2014 02:00 | 1 | 1 |
| 02/08/2014 03:00 | 1 | 1 |
| 02/08/2014 04:00 | 1 | 1 |
| 02/08/2014 05:00 | 1 | 1 |
| 02/08/2014 06:00 | 1 | 1 |
| 02/08/2014 07:00 | 1 | 1 |
| 02/08/2014 08:00 | 1 | 1 |
| 02/08/2014 09:00 | 1 | 1 |
| 02/08/2014 10:00 | 1 | 1 |
| 02/08/2014 11:00 | 1 | 1 |
| 02/08/2014 12:00 | 1 | 1 |
| 02/08/2014 13:00 | 1 | 1 |
| 02/08/2014 14:00 | 1 | 1 |
| 02/08/2014 15:00 | 1 | 1 |
| 02/08/2014 16:00 | 1 | 1 |
| 02/08/2014 17:00 | 1 | 1 |
| 02/08/2014 18:00 | 1 | 1 |
| 02/08/2014 19:00 | 1 | 1 |
| 02/08/2014 20:00 | 1 | 1 |
| 02/08/2014 21:00 | 1 | 1 |
| 02/08/2014 22:00 | 1 | 1 |
| 02/08/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/09/2014 00:00 | 1 | 1 |
| 02/09/2014 01:00 | 1 | 1 |
| 02/09/2014 02:00 | 1 | 1 |
| 02/09/2014 03:00 | 1 | 1 |
| 02/09/2014 04:00 | 1 | 1 |
| 02/09/2014 05:00 | 1 | 1 |
| 02/09/2014 06:00 | 1 | 1 |
| 02/09/2014 07:00 | 1 | 1 |
| 02/09/2014 08:00 | 1 | 1 |
| 02/09/2014 09:00 | 1 | 1 |
| 02/09/2014 10:00 | 1 | 1 |
| 02/09/2014 11:00 | 1 | 1 |
| 02/09/2014 12:00 | 1 | 1 |
| 02/09/2014 13:00 | 1 | 1 |
| 02/09/2014 14:00 | 1 | 1 |
| 02/09/2014 15:00 | 1 | 1 |
| 02/09/2014 16:00 | 1 | 1 |
| 02/09/2014 17:00 | 1 | 1 |
| 02/09/2014 18:00 | 1 | 1 |
| 02/09/2014 19:00 | 1 | 1 |
| 02/09/2014 20:00 | 1 | 1 |
| 02/09/2014 21:00 | 1 | 1 |
| 02/09/2014 22:00 | 1 | 1 |
| 02/09/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/10/2014 00:00 | 1 | 1 |
| 02/10/2014 01:00 | 1 | 1 |
| 02/10/2014 02:00 | 1 | 1 |
| 02/10/2014 03:00 | 0 | 1 |
| 02/10/2014 04:00 | 0 | 1 |
| 02/10/2014 05:00 | 0 | 1 |
| 02/10/2014 06:00 | 1 | 1 |
| 02/10/2014 07:00 | 1 | 1 |
| 02/10/2014 08:00 | 1 | 1 |
| 02/10/2014 09:00 | 1 | 1 |
| 02/10/2014 10:00 | 1 | 1 |
| 02/10/2014 11:00 | 1 | 1 |
| 02/10/2014 12:00 | 1 | 1 |
| 02/10/2014 13:00 | 1 | 1 |
| 02/10/2014 14:00 | 1 | 1 |
| 02/10/2014 15:00 | 1 | 1 |
| 02/10/2014 16:00 | 1 | 1 |
| 02/10/2014 17:00 | 1 | 1 |
| 02/10/2014 18:00 | 1 | 1 |
| 02/10/2014 19:00 | 1 | 1 |
| 02/10/2014 20:00 | 1 | 1 |
| 02/10/2014 21:00 | 1 | 1 |
| 02/10/2014 22:00 | 1 | 1 |
| 02/10/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 0 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/11/2014 00:00 | 1 | 1 |
| 02/11/2014 01:00 | 1 | 1 |
| 02/11/2014 02:00 | 1 | 1 |
| 02/11/2014 03:00 | 1 | 1 |
| 02/11/2014 04:00 | 1 | 1 |
| 02/11/2014 05:00 | 1 | 1 |
| 02/11/2014 06:00 | 1 | 1 |
| 02/11/2014 07:00 | 1 | 1 |
| 02/11/2014 08:00 | 1 | 1 |
| 02/11/2014 09:00 | 1 | 1 |
| 02/11/2014 10:00 | 1 | 1 |
| 02/11/2014 11:00 | 1 | 1 |
| 02/11/2014 12:00 | 1 | 1 |
| 02/11/2014 13:00 | 1 | 1 |
| 02/11/2014 14:00 | 1 | 1 |
| 02/11/2014 15:00 | 1 | 1 |
| 02/11/2014 16:00 | 1 | 1 |
| 02/11/2014 17:00 | 1 | 1 |
| 02/11/2014 18:00 | 1 | 1 |
| 02/11/2014 19:00 | 1 | 1 |
| 02/11/2014 20:00 | 1 | 1 |
| 02/11/2014 21:00 | 1 | 1 |
| 02/11/2014 22:00 | 1 | 1 |
| 02/11/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/12/2014 00:00 | 1 | 1 |
| 02/12/2014 01:00 | 1 | 1 |
| 02/12/2014 02:00 | 1 | 1 |
| 02/12/2014 03:00 | 1 | 1 |
| 02/12/2014 04:00 | 1 | 1 |
| 02/12/2014 05:00 | 1 | 1 |
| 02/12/2014 06:00 | 1 | 1 |
| 02/12/2014 07:00 | 1 | 1 |
| 02/12/2014 08:00 | 1 | 1 |
| 02/12/2014 09:00 | 1 | 1 |
| 02/12/2014 10:00 | 1 | 1 |
| 02/12/2014 11:00 | 1 | 1 |
| 02/12/2014 12:00 | 1 | 1 |
| 02/12/2014 13:00 | 1 | 1 |
| 02/12/2014 14:00 | 1 | 1 |
| 02/12/2014 15:00 | 1 | 1 |
| 02/12/2014 16:00 | 1 | 1 |
| 02/12/2014 17:00 | 1 | 1 |
| 02/12/2014 18:00 | 1 | 1 |
| 02/12/2014 19:00 | 1 | 1 |
| 02/12/2014 20:00 | 1 | 1 |
| 02/12/2014 21:00 | 1 | 1 |
| 02/12/2014 22:00 | 1 | 1 |
| 02/12/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/13/2014 00:00 | 1 | 1 |
| 02/13/2014 01:00 | 1 | 1 |
| 02/13/2014 02:00 | 1 | 1 |
| 02/13/2014 03:00 | 1 | 1 |
| 02/13/2014 04:00 | 1 | 1 |
| 02/13/2014 05:00 | 1 | 1 |
| 02/13/2014 06:00 | 1 | 1 |
| 02/13/2014 07:00 | 1 | 1 |
| 02/13/2014 08:00 | 1 | 1 |
| 02/13/2014 09:00 | 1 | 1 |
| 02/13/2014 10:00 | 1 | 1 |
| 02/13/2014 11:00 | 1 | 1 |
| 02/13/2014 12:00 | 1 | 1 |
| 02/13/2014 13:00 | 1 | 1 |
| 02/13/2014 14:00 | 1 | 1 |
| 02/13/2014 15:00 | 1 | 1 |
| 02/13/2014 16:00 | 1 | 1 |
| 02/13/2014 17:00 | 1 | 1 |
| 02/13/2014 18:00 | 1 | 1 |
| 02/13/2014 19:00 | 1 | 1 |
| 02/13/2014 20:00 | 1 | 1 |
| 02/13/2014 21:00 | 1 | 1 |
| 02/13/2014 22:00 | 1 | 1 |
| 02/13/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/14/2014 00:00 | 1 | 1 |
| 02/14/2014 01:00 | 1 | 1 |
| 02/14/2014 02:00 | 1 | 1 |
| 02/14/2014 03:00 | 1 | 1 |
| 02/14/2014 04:00 | 1 | 1 |
| 02/14/2014 05:00 | 1 | 1 |
| 02/14/2014 06:00 | 1 | 1 |
| 02/14/2014 07:00 | 1 | 1 |
| 02/14/2014 08:00 | 1 | 1 |
| 02/14/2014 09:00 | 1 | 1 |
| 02/14/2014 10:00 | 1 | 1 |
| 02/14/2014 11:00 | 1 | 1 |
| 02/14/2014 12:00 | 1 | 1 |
| 02/14/2014 13:00 | 1 | 1 |
| 02/14/2014 14:00 | 1 | 1 |
| 02/14/2014 15:00 | 1 | 1 |
| 02/14/2014 16:00 | 1 | 1 |
| 02/14/2014 17:00 | 1 | 1 |
| 02/14/2014 18:00 | 1 | 1 |
| 02/14/2014 19:00 | 1 | 1 |
| 02/14/2014 20:00 | 1 | 1 |
| 02/14/2014 21:00 | 1 | 1 |
| 02/14/2014 22:00 | 1 | 1 |
| 02/14/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/15/2014 00:00 | 1 | 1 |
| 02/15/2014 01:00 | 1 | 1 |
| 02/15/2014 02:00 | 1 | 1 |
| 02/15/2014 03:00 | 1 | 1 |
| 02/15/2014 04:00 | 1 | 1 |
| 02/15/2014 05:00 | 1 | 1 |
| 02/15/2014 06:00 | 1 | 1 |
| 02/15/2014 07:00 | 1 | 1 |
| 02/15/2014 08:00 | 1 | 1 |
| 02/15/2014 09:00 | 1 | 1 |
| 02/15/2014 10:00 | 1 | 1 |
| 02/15/2014 11:00 | 1 | 1 |
| 02/15/2014 12:00 | 1 | 1 |
| 02/15/2014 13:00 | 1 | 1 |
| 02/15/2014 14:00 | 1 | 1 |
| 02/15/2014 15:00 | 1 | 1 |
| 02/15/2014 16:00 | 1 | 1 |
| 02/15/2014 17:00 | 1 | 1 |
| 02/15/2014 18:00 | 1 | 1 |
| 02/15/2014 19:00 | 1 | 1 |
| 02/15/2014 20:00 | 1 | 1 |
| 02/15/2014 21:00 | 1 | 1 |
| 02/15/2014 22:00 | 1 | 1 |
| 02/15/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/16/2014 00:00 | 1 | 1 |
| 02/16/2014 01:00 | 1 | 1 |
| 02/16/2014 02:00 | 1 | 1 |
| 02/16/2014 03:00 | 1 | 1 |
| 02/16/2014 04:00 | 1 | 1 |
| 02/16/2014 05:00 | 1 | 1 |
| 02/16/2014 06:00 | 1 | 1 |
| 02/16/2014 07:00 | 1 | 1 |
| 02/16/2014 08:00 | 1 | 1 |
| 02/16/2014 09:00 | 1 | 1 |
| 02/16/2014 10:00 | 1 | 1 |
| 02/16/2014 11:00 | 1 | 1 |
| 02/16/2014 12:00 | 1 | 1 |
| 02/16/2014 13:00 | 1 | 1 |
| 02/16/2014 14:00 | 1 | 1 |
| 02/16/2014 15:00 | 1 | 1 |
| 02/16/2014 16:00 | 1 | 1 |
| 02/16/2014 17:00 | 1 | 1 |
| 02/16/2014 18:00 | 1 | 1 |
| 02/16/2014 19:00 | 1 | 1 |
| 02/16/2014 20:00 | 1 | 1 |
| 02/16/2014 21:00 | 1 | 1 |
| 02/16/2014 22:00 | 1 | 1 |
| 02/16/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/17/2014 00:00 | 1 | 1 |
| 02/17/2014 01:00 | 1 | 1 |
| 02/17/2014 02:00 | 1 | 1 |
| 02/17/2014 03:00 | 1 | 1 |
| 02/17/2014 04:00 | 1 | 1 |
| 02/17/2014 05:00 | 1 | 1 |
| 02/17/2014 06:00 | 1 | 1 |
| 02/17/2014 07:00 | 1 | 1 |
| 02/17/2014 08:00 | 1 | 1 |
| 02/17/2014 09:00 | 1 | 1 |
| 02/17/2014 10:00 | 1 | 1 |
| 02/17/2014 11:00 | 1 | 1 |
| 02/17/2014 12:00 | 1 | 1 |
| 02/17/2014 13:00 | 1 | 1 |
| 02/17/2014 14:00 | 1 | 1 |
| 02/17/2014 15:00 | 1 | 1 |
| 02/17/2014 16:00 | 1 | 1 |
| 02/17/2014 17:00 | 1 | 1 |
| 02/17/2014 18:00 | 1 | 1 |
| 02/17/2014 19:00 | 1 | 1 |
| 02/17/2014 20:00 | 1 | 1 |
| 02/17/2014 21:00 | 1 | 1 |
| 02/17/2014 22:00 | 1 | 1 |
| 02/17/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/18/2014 00:00 | 1 | 1 |
| 02/18/2014 01:00 | 1 | 1 |
| 02/18/2014 02:00 | 1 | 1 |
| 02/18/2014 03:00 | 1 | 1 |
| 02/18/2014 04:00 | 1 | 1 |
| 02/18/2014 05:00 | 1 | 1 |
| 02/18/2014 06:00 | 1 | 1 |
| 02/18/2014 07:00 | 1 | 1 |
| 02/18/2014 08:00 | 1 | 1 |
| 02/18/2014 09:00 | 1 | 1 |
| 02/18/2014 10:00 | 1 | 1 |
| 02/18/2014 11:00 | 1 | 1 |
| 02/18/2014 12:00 | 1 | 1 |
| 02/18/2014 13:00 | 1 | 1 |
| 02/18/2014 14:00 | 1 | 1 |
| 02/18/2014 15:00 | 1 | 1 |
| 02/18/2014 16:00 | 1 | 1 |
| 02/18/2014 17:00 | 1 | 1 |
| 02/18/2014 18:00 | 1 | 1 |
| 02/18/2014 19:00 | 1 | 1 |
| 02/18/2014 20:00 | 1 | 1 |
| 02/18/2014 21:00 | 1 | 1 |
| 02/18/2014 22:00 | 1 | 1 |
| 02/18/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/19/2014 00:00 | 1 | 1 |
| 02/19/2014 01:00 | 1 | 1 |
| 02/19/2014 02:00 | 2 | 3 |
| 02/19/2014 03:00 | 2 | 3 |
| 02/19/2014 04:00 | 2 | 3 |
| 02/19/2014 05:00 | 2 | 3 |
| 02/19/2014 06:00 | 2 | 3 |
| 02/19/2014 07:00 | 2 | 3 |
| 02/19/2014 08:00 | 2 | 3 |
| 02/19/2014 09:00 | 2 | 3 |
| 02/19/2014 10:00 | 2 | 3 |
| 02/19/2014 11:00 | 2 | 3 |
| 02/19/2014 12:00 | 16 | 3 |
| 02/19/2014 13:00 | 21 | 3 |
| 02/19/2014 14:00 | 25 | 3 |
| 02/19/2014 15:00 | 24 | 3 |
| 02/19/2014 16:00 | 9 | 3 |
| 02/19/2014 17:00 | 5 | 18 |
| 02/19/2014 18:00 | 1 | 21 |
| 02/19/2014 19:00 | 1 | 21 |
| 02/19/2014 20:00 | 1 | 19 |
| 02/19/2014 21:00 | 1 | 4 |
| 02/19/2014 22:00 | 1 | 1 |
| 02/19/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 5 | 6 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 25 | 21 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/20/2014 00:00 | 1 | 1 |
| 02/20/2014 01:00 | 1 | 1 |
| 02/20/2014 02:00 | 1 | 1 |
| 02/20/2014 03:00 | 1 | 1 |
| 02/20/2014 04:00 | 1 | 1 |
| 02/20/2014 05:00 | 1 | 1 |
| 02/20/2014 06:00 | 1 | 1 |
| 02/20/2014 07:00 | 1 | 1 |
| 02/20/2014 08:00 | 1 | 1 |
| 02/20/2014 09:00 | 1 | 1 |
| 02/20/2014 10:00 | 1 | 1 |
| 02/20/2014 11:00 | 1 | 1 |
| 02/20/2014 12:00 | 1 | 1 |
| 02/20/2014 13:00 | 1 | 1 |
| 02/20/2014 14:00 | 1 | 1 |
| 02/20/2014 15:00 | 1 | 1 |
| 02/20/2014 16:00 | 1 | 1 |
| 02/20/2014 17:00 | 1 | 1 |
| 02/20/2014 18:00 | 1 | 1 |
| 02/20/2014 19:00 | 1 | 1 |
| 02/20/2014 20:00 | 1 | 1 |
| 02/20/2014 21:00 | 1 | 1 |
| 02/20/2014 22:00 | 1 | 1 |
| 02/20/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/21/2014 00:00 | 1 | 1 |
| 02/21/2014 01:00 | 1 | 1 |
| 02/21/2014 02:00 | 1 | 1 |
| 02/21/2014 03:00 | 1 | 1 |
| 02/21/2014 04:00 | 1 | 1 |
| 02/21/2014 05:00 | 1 | 1 |
| 02/21/2014 06:00 | 1 | 1 |
| 02/21/2014 07:00 | 1 | 1 |
| 02/21/2014 08:00 | 1 | 1 |
| 02/21/2014 09:00 | 1 | 1 |
| 02/21/2014 10:00 | 1 | 1 |
| 02/21/2014 11:00 | 1 | 1 |
| 02/21/2014 12:00 | 1 | 1 |
| 02/21/2014 13:00 | 1 | 1 |
| 02/21/2014 14:00 | 1 | 1 |
| 02/21/2014 15:00 | 1 | 1 |
| 02/21/2014 16:00 | 1 | 1 |
| 02/21/2014 17:00 | 1 | 1 |
| 02/21/2014 18:00 | 1 | 1 |
| 02/21/2014 19:00 | 1 | 1 |
| 02/21/2014 20:00 | 1 | 1 |
| 02/21/2014 21:00 | 1 | 1 |
| 02/21/2014 22:00 | 1 | 1 |
| 02/21/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/22/2014 00:00 | 1 | 1 |
| 02/22/2014 01:00 | 1 | 1 |
| 02/22/2014 02:00 | 1 | 1 |
| 02/22/2014 03:00 | 1 | 1 |
| 02/22/2014 04:00 | 1 | 1 |
| 02/22/2014 05:00 | 1 | 1 |
| 02/22/2014 06:00 | 1 | 1 |
| 02/22/2014 07:00 | 1 | 1 |
| 02/22/2014 08:00 | 1 | 1 |
| 02/22/2014 09:00 | 1 | 1 |
| 02/22/2014 10:00 | 1 | 1 |
| 02/22/2014 11:00 | 1 | 1 |
| 02/22/2014 12:00 | 1 | 1 |
| 02/22/2014 13:00 | 1 | 1 |
| 02/22/2014 14:00 | 1 | 1 |
| 02/22/2014 15:00 | 1 | 1 |
| 02/22/2014 16:00 | 1 | 1 |
| 02/22/2014 17:00 | 1 | 1 |
| 02/22/2014 18:00 | 1 | 1 |
| 02/22/2014 19:00 | 1 | 1 |
| 02/22/2014 20:00 | 1 | 1 |
| 02/22/2014 21:00 | 1 | 1 |
| 02/22/2014 22:00 | 1 | 1 |
| 02/22/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/23/2014 00:00 | 1 | 1 |
| 02/23/2014 01:00 | 1 | 1 |
| 02/23/2014 02:00 | 1 | 1 |
| 02/23/2014 03:00 | 1 | 1 |
| 02/23/2014 04:00 | 1 | 1 |
| 02/23/2014 05:00 | 1 | 1 |
| 02/23/2014 06:00 | 1 | 1 |
| 02/23/2014 07:00 | 1 | 1 |
| 02/23/2014 08:00 | 1 | 1 |
| 02/23/2014 09:00 | 1 | 1 |
| 02/23/2014 10:00 | 1 | 1 |
| 02/23/2014 11:00 | 1 | 1 |
| 02/23/2014 12:00 | 1 | 1 |
| 02/23/2014 13:00 | 1 | 1 |
| 02/23/2014 14:00 | 1 | 1 |
| 02/23/2014 15:00 | 1 | 1 |
| 02/23/2014 16:00 | 1 | 1 |
| 02/23/2014 17:00 | 1 | 1 |
| 02/23/2014 18:00 | 1 | 1 |
| 02/23/2014 19:00 | 1 | 1 |
| 02/23/2014 20:00 | 1 | 1 |
| 02/23/2014 21:00 | 1 | 1 |
| 02/23/2014 22:00 | 1 | 1 |
| 02/23/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/24/2014 00:00 | 1 | 1 |
| 02/24/2014 01:00 | 1 | 1 |
| 02/24/2014 02:00 | 1 | 1 |
| 02/24/2014 03:00 | 1 | 1 |
| 02/24/2014 04:00 | 1 | 1 |
| 02/24/2014 05:00 | 1 | 1 |
| 02/24/2014 06:00 | 1 | 1 |
| 02/24/2014 07:00 | 1 | 1 |
| 02/24/2014 08:00 | 1 | 1 |
| 02/24/2014 09:00 | 1 | 1 |
| 02/24/2014 10:00 | 1 | 1 |
| 02/24/2014 11:00 | 1 | 1 |
| 02/24/2014 12:00 | 1 | 1 |
| 02/24/2014 13:00 | 1 | 1 |
| 02/24/2014 14:00 | 1 | 1 |
| 02/24/2014 15:00 | 1 | 1 |
| 02/24/2014 16:00 | 1 | 1 |
| 02/24/2014 17:00 | 1 | 1 |
| 02/24/2014 18:00 | 1 | 1 |
| 02/24/2014 19:00 | 1 | 1 |
| 02/24/2014 20:00 | 1 | 1 |
| 02/24/2014 21:00 | 1 | 1 |
| 02/24/2014 22:00 | 1 | 1 |
| 02/24/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/25/2014 00:00 | 1 | 1 |
| 02/25/2014 01:00 | 1 | 1 |
| 02/25/2014 02:00 | 1 | 1 |
| 02/25/2014 03:00 | 1 | 1 |
| 02/25/2014 04:00 | 1 | 1 |
| 02/25/2014 05:00 | 1 | 1 |
| 02/25/2014 06:00 | 1 | 1 |
| 02/25/2014 07:00 | 1 | 1 |
| 02/25/2014 08:00 | 1 | 1 |
| 02/25/2014 09:00 | 1 | 1 |
| 02/25/2014 10:00 | 1 | 1 |
| 02/25/2014 11:00 | 0 | 1 |
| 02/25/2014 12:00 | 0 | 1 |
| 02/25/2014 13:00 | 0 | 1 |
| 02/25/2014 14:00 | 0 | 1 |
| 02/25/2014 15:00 | 0 | 1 |
| 02/25/2014 16:00 | 1 | 1 |
| 02/25/2014 17:00 | 1 | 1 |
| 02/25/2014 18:00 | 1 | 1 |
| 02/25/2014 19:00 | 1 | 1 |
| 02/25/2014 20:00 | 1 | 1 |
| 02/25/2014 21:00 | 1 | 1 |
| 02/25/2014 22:00 | 1 | 1 |
| 02/25/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 21 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/26/2014 00:00 | 1 | 1 |
| 02/26/2014 01:00 | 1 | 1 |
| 02/26/2014 02:00 | 1 | 1 |
| 02/26/2014 03:00 | 1 | 1 |
| 02/26/2014 04:00 | 1 | 1 |
| 02/26/2014 05:00 | 1 | 1 |
| 02/26/2014 06:00 | 1 | 1 |
| 02/26/2014 07:00 | 1 | 1 |
| 02/26/2014 08:00 | 1 | 1 |
| 02/26/2014 09:00 | 1 | 1 |
| 02/26/2014 10:00 | 1 | 1 |
| 02/26/2014 11:00 | 1 | 0 |
| 02/26/2014 12:00 | 1 | 0 |
| 02/26/2014 13:00 | 1 | 0 |
| 02/26/2014 14:00 | 1 | 0 |
| 02/26/2014 15:00 | 1 | 0 |
| 02/26/2014 16:00 | 1 | 1 |
| 02/26/2014 17:00 | 1 | 1 |
| 02/26/2014 18:00 | 1 | 1 |
| 02/26/2014 19:00 | 1 | 1 |
| 02/26/2014 20:00 | 1 | 1 |
| 02/26/2014 21:00 | 1 | 1 |
| 02/26/2014 22:00 | 1 | 1 |
| 02/26/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 21 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/27/2014 00:00 | 1 | 1 |
| 02/27/2014 01:00 | 1 | 1 |
| 02/27/2014 02:00 | 1 | 1 |
| 02/27/2014 03:00 | 1 | 1 |
| 02/27/2014 04:00 | 1 | 1 |
| 02/27/2014 05:00 | 1 | 1 |
| 02/27/2014 06:00 | 1 | 1 |
| 02/27/2014 07:00 | 1 | 1 |
| 02/27/2014 08:00 | 1 | 1 |
| 02/27/2014 09:00 | 1 | 1 |
| 02/27/2014 10:00 | 1 | 1 |
| 02/27/2014 11:00 | 1 | 1 |
| 02/27/2014 12:00 | 1 | 1 |
| 02/27/2014 13:00 | 1 | 1 |
| 02/27/2014 14:00 | 1 | 1 |
| 02/27/2014 15:00 | 1 | 1 |
| 02/27/2014 16:00 | 1 | 1 |
| 02/27/2014 17:00 | 1 | 1 |
| 02/27/2014 18:00 | 1 | 1 |
| 02/27/2014 19:00 | 1 | 1 |
| 02/27/2014 20:00 | 1 | 1 |
| 02/27/2014 21:00 | 1 | 1 |
| 02/27/2014 22:00 | 1 | 1 |
| 02/27/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 02/28/2014 00:00 | 1 | 1 |
| 02/28/2014 01:00 | 1 | 1 |
| 02/28/2014 02:00 | 1 | 1 |
| 02/28/2014 03:00 | 1 | 1 |
| 02/28/2014 04:00 | 1 | 1 |
| 02/28/2014 05:00 | 1 | 1 |
| 02/28/2014 06:00 | 1 | 1 |
| 02/28/2014 07:00 | 1 | 1 |
| 02/28/2014 08:00 | 1 | 1 |
| 02/28/2014 09:00 | 1 | 1 |
| 02/28/2014 10:00 | 1 | 1 |
| 02/28/2014 11:00 | 1 | 1 |
| 02/28/2014 12:00 | 1 | 1 |
| 02/28/2014 13:00 | 1 | 1 |
| 02/28/2014 14:00 | 1 | 1 |
| 02/28/2014 15:00 | 1 | 1 |
| 02/28/2014 16:00 | 1 | 1 |
| 02/28/2014 17:00 | 1 | 1 |
| 02/28/2014 18:00 | 1 | 1 |
| 02/28/2014 19:00 | 1 | 1 |
| 02/28/2014 20:00 | 1 | 1 |
| 02/28/2014 21:00 | 1 | 1 |
| 02/28/2014 22:00 | 1 | 1 |
| 02/28/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/01/2014 00:00 | 1 | 1 |
| 03/01/2014 01:00 | 1 | 1 |
| 03/01/2014 02:00 | 1 | 1 |
| 03/01/2014 03:00 | 1 | 1 |
| 03/01/2014 04:00 | 1 | 1 |
| 03/01/2014 05:00 | 1 | 1 |
| 03/01/2014 06:00 | 1 | 1 |
| 03/01/2014 07:00 | 1 | 1 |
| 03/01/2014 08:00 | 1 | 1 |
| 03/01/2014 09:00 | 1 | 1 |
| 03/01/2014 10:00 | 1 | 1 |
| 03/01/2014 11:00 | 1 | 1 |
| 03/01/2014 12:00 | 1 | 1 |
| 03/01/2014 13:00 | 1 | 1 |
| 03/01/2014 14:00 | 1 | 1 |
| 03/01/2014 15:00 | 1 | 1 |
| 03/01/2014 16:00 | 1 | 1 |
| 03/01/2014 17:00 | 1 | 1 |
| 03/01/2014 18:00 | 1 | 1 |
| 03/01/2014 19:00 | 1 | 1 |
| 03/01/2014 20:00 | 1 | 1 |
| 03/01/2014 21:00 | 1 | 1 |
| 03/01/2014 22:00 | 1 | 1 |
| 03/01/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/02/2014 00:00 | 1 | 1 |
| 03/02/2014 01:00 | 1 | 1 |
| 03/02/2014 02:00 | 1 | 1 |
| 03/02/2014 03:00 | 1 | 1 |
| 03/02/2014 04:00 | 1 | 1 |
| 03/02/2014 05:00 | 1 | 1 |
| 03/02/2014 06:00 | 1 | 1 |
| 03/02/2014 07:00 | 1 | 1 |
| 03/02/2014 08:00 | 1 | 1 |
| 03/02/2014 09:00 | 1 | 1 |
| 03/02/2014 10:00 | 1 | 1 |
| 03/02/2014 11:00 | 1 | 1 |
| 03/02/2014 12:00 | 1 | 1 |
| 03/02/2014 13:00 | 1 | 1 |
| 03/02/2014 14:00 | 1 | 1 |
| 03/02/2014 15:00 | 1 | 1 |
| 03/02/2014 16:00 | 1 | 1 |
| 03/02/2014 17:00 | 1 | 1 |
| 03/02/2014 18:00 | 1 | 1 |
| 03/02/2014 19:00 | 1 | 1 |
| 03/02/2014 20:00 | 1 | 1 |
| 03/02/2014 21:00 | 1 | 1 |
| 03/02/2014 22:00 | 1 | 1 |
| 03/02/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/03/2014 00:00 | 1 | 1 |
| 03/03/2014 01:00 | 1 | 1 |
| 03/03/2014 02:00 | 1 | 1 |
| 03/03/2014 03:00 | 1 | 1 |
| 03/03/2014 04:00 | 1 | 1 |
| 03/03/2014 05:00 | 1 | 1 |
| 03/03/2014 06:00 | 1 | 1 |
| 03/03/2014 07:00 | 1 | 1 |
| 03/03/2014 08:00 | 1 | 1 |
| 03/03/2014 09:00 | 1 | 1 |
| 03/03/2014 10:00 | 1 | 1 |
| 03/03/2014 11:00 | 1 | 1 |
| 03/03/2014 12:00 | 1 | 1 |
| 03/03/2014 13:00 | 1 | 1 |
| 03/03/2014 14:00 | 1 | 1 |
| 03/03/2014 15:00 | 1 | 1 |
| 03/03/2014 16:00 | 1 | 1 |
| 03/03/2014 17:00 | 1 | 1 |
| 03/03/2014 18:00 | 1 | 1 |
| 03/03/2014 19:00 | 1 | 1 |
| 03/03/2014 20:00 | 1 | 1 |
| 03/03/2014 21:00 | 1 | 1 |
| 03/03/2014 22:00 | 1 | 1 |
| 03/03/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/04/2014 00:00 | 1 | 1 |
| 03/04/2014 01:00 | 1 | 1 |
| 03/04/2014 02:00 | 1 | 1 |
| 03/04/2014 03:00 | 1 | 1 |
| 03/04/2014 04:00 | 1 | 1 |
| 03/04/2014 05:00 | 1 | 1 |
| 03/04/2014 06:00 | 1 | 1 |
| 03/04/2014 07:00 | 1 | 1 |
| 03/04/2014 08:00 | 1 | 1 |
| 03/04/2014 09:00 | 1 | 1 |
| 03/04/2014 10:00 | 1 | 1 |
| 03/04/2014 11:00 | 1 | 1 |
| 03/04/2014 12:00 | 1 | 1 |
| 03/04/2014 13:00 | 1 | 1 |
| 03/04/2014 14:00 | 1 | 1 |
| 03/04/2014 15:00 | 1 | 1 |
| 03/04/2014 16:00 | 1 | 1 |
| 03/04/2014 17:00 | 1 | 1 |
| 03/04/2014 18:00 | 1 | 1 |
| 03/04/2014 19:00 | 1 | 1 |
| 03/04/2014 20:00 | 1 | 1 |
| 03/04/2014 21:00 | 1 | 1 |
| 03/04/2014 22:00 | 1 | 1 |
| 03/04/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/05/2014 00:00 | 1 | 1 |
| 03/05/2014 01:00 | 1 | 1 |
| 03/05/2014 02:00 | 1 | 1 |
| 03/05/2014 03:00 | 1 | 1 |
| 03/05/2014 04:00 | 1 | 1 |
| 03/05/2014 05:00 | 1 | 1 |
| 03/05/2014 06:00 | 1 | 1 |
| 03/05/2014 07:00 | 1 | 1 |
| 03/05/2014 08:00 | 1 | 1 |
| 03/05/2014 09:00 | 1 | 1 |
| 03/05/2014 10:00 | 1 | 1 |
| 03/05/2014 11:00 | 1 | 1 |
| 03/05/2014 12:00 | 1 | 1 |
| 03/05/2014 13:00 | 1 | 1 |
| 03/05/2014 14:00 | 1 | 1 |
| 03/05/2014 15:00 | 1 | 1 |
| 03/05/2014 16:00 | 1 | 1 |
| 03/05/2014 17:00 | 1 | 1 |
| 03/05/2014 18:00 | 1 | 1 |
| 03/05/2014 19:00 | 1 | 1 |
| 03/05/2014 20:00 | 1 | 1 |
| 03/05/2014 21:00 | 1 | 1 |
| 03/05/2014 22:00 | 1 | 1 |
| 03/05/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/06/2014 00:00 | 1 | 1 |
| 03/06/2014 01:00 | 1 | 1 |
| 03/06/2014 02:00 | 1 | 1 |
| 03/06/2014 03:00 | 1 | 3 |
| 03/06/2014 04:00 | 1 | 3 |
| 03/06/2014 05:00 | 1 | 3 |
| 03/06/2014 06:00 | 1 | 3 |
| 03/06/2014 07:00 | 1 | 3 |
| 03/06/2014 08:00 | 1 | 3 |
| 03/06/2014 09:00 | 1 | 3 |
| 03/06/2014 10:00 | 1 | 3 |
| 03/06/2014 11:00 | 1 | 3 |
| 03/06/2014 12:00 | 1 | 3 |
| 03/06/2014 13:00 | 1 | 3 |
| 03/06/2014 14:00 | 1 | 3 |
| 03/06/2014 15:00 | 1 | 3 |
| 03/06/2014 16:00 | 1 | 3 |
| 03/06/2014 17:00 | 1 | 3 |
| 03/06/2014 18:00 | 1 | 3 |
| 03/06/2014 19:00 | 1 | 3 |
| 03/06/2014 20:00 | 1 | 3 |
| 03/06/2014 21:00 | 1 | 3 |
| 03/06/2014 22:00 | 1 | 3 |
| 03/06/2014 23:00 | 1 | 3 |
| **Average/Sum#:** | 1 | 3 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/07/2014 00:00 | 1 | 3 |
| 03/07/2014 01:00 | 1 | 3 |
| 03/07/2014 02:00 | 1 | 3 |
| 03/07/2014 03:00 | 15 | 3 |
| 03/07/2014 04:00 | 21 | 3 |
| 03/07/2014 05:00 | 25 | 3 |
| 03/07/2014 06:00 | 24 | 3 |
| 03/07/2014 07:00 | 10 | 18 |
| 03/07/2014 08:00 | 4 | 23 |
| 03/07/2014 09:00 | 1 | 23 |
| 03/07/2014 10:00 | 1 | 22 |
| 03/07/2014 11:00 | 1 | 6 |
| 03/07/2014 12:00 | 1 | 1 |
| 03/07/2014 13:00 | 1 | 1 |
| 03/07/2014 14:00 | 1 | 1 |
| 03/07/2014 15:00 | 1 | 1 |
| 03/07/2014 16:00 | 1 | 1 |
| 03/07/2014 17:00 | 1 | 1 |
| 03/07/2014 18:00 | 1 | 1 |
| 03/07/2014 19:00 | 1 | 1 |
| 03/07/2014 20:00 | 1 | 1 |
| 03/07/2014 21:00 | 1 | 1 |
| 03/07/2014 22:00 | 1 | 1 |
| 03/07/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 5 | 5 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 25 | 23 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/08/2014 00:00 | 1 | 1 |
| 03/08/2014 01:00 | 1 | 1 |
| 03/08/2014 02:00 | 1 | 1 |
| 03/08/2014 03:00 | 1 | 1 |
| 03/08/2014 04:00 | 1 | 1 |
| 03/08/2014 05:00 | 1 | 1 |
| 03/08/2014 06:00 | 1 | 1 |
| 03/08/2014 07:00 | 1 | 1 |
| 03/08/2014 08:00 | 1 | 1 |
| 03/08/2014 09:00 | 1 | 1 |
| 03/08/2014 10:00 | 1 | 1 |
| 03/08/2014 11:00 | 1 | 1 |
| 03/08/2014 12:00 | 1 | 1 |
| 03/08/2014 13:00 | 1 | 1 |
| 03/08/2014 14:00 | 1 | 1 |
| 03/08/2014 15:00 | 1 | 1 |
| 03/08/2014 16:00 | 1 | 1 |
| 03/08/2014 17:00 | 1 | 1 |
| 03/08/2014 18:00 | 1 | 1 |
| 03/08/2014 19:00 | 1 | 1 |
| 03/08/2014 20:00 | 1 | 1 |
| 03/08/2014 21:00 | 1 | 1 |
| 03/08/2014 22:00 | 1 | 1 |
| 03/08/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/09/2014 00:00 | 1 | 1 |
| 03/09/2014 01:00 | 1 | 1 |
| 03/09/2014 02:00 | 1 | 2 |
| 03/09/2014 03:00 | 1 | 2 |
| 03/09/2014 04:00 | 1 | 2 |
| 03/09/2014 05:00 | 1 | 2 |
| 03/09/2014 06:00 | 1 | 2 |
| 03/09/2014 07:00 | 1 | 2 |
| 03/09/2014 08:00 | 1 | 2 |
| 03/09/2014 09:00 | 1 | 2 |
| 03/09/2014 10:00 | 1 | 2 |
| 03/09/2014 11:00 | 8 | 2 |
| 03/09/2014 12:00 | 11 | 2 |
| 03/09/2014 13:00 | 11 | 2 |
| 03/09/2014 14:00 | 10 | 2 |
| 03/09/2014 15:00 | 3 | 14 |
| 03/09/2014 16:00 | 1 | 16 |
| 03/09/2014 17:00 | 1 | 16 |
| 03/09/2014 18:00 | 1 | 15 |
| 03/09/2014 19:00 | 1 | 3 |
| 03/09/2014 20:00 | 1 | 1 |
| 03/09/2014 21:00 | 1 | 1 |
| 03/09/2014 22:00 | 1 | 1 |
| 03/09/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 3 | 4 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 11 | 16 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/10/2014 00:00 | 1 | 1 |
| 03/10/2014 01:00 | 1 | 1 |
| 03/10/2014 02:00 | 1 | 1 |
| 03/10/2014 03:00 | 1 | 1 |
| 03/10/2014 04:00 | 0 | 1 |
| 03/10/2014 05:00 | 0 | 1 |
| 03/10/2014 06:00 | 1 | 1 |
| 03/10/2014 07:00 | 1 | 1 |
| 03/10/2014 08:00 | 1 | 1 |
| 03/10/2014 09:00 | 1 | 1 |
| 03/10/2014 10:00 | 1 | 1 |
| 03/10/2014 11:00 | 1 | 1 |
| 03/10/2014 12:00 | 1 | 1 |
| 03/10/2014 13:00 | 1 | 1 |
| 03/10/2014 14:00 | 1 | 1 |
| 03/10/2014 15:00 | 1 | 1 |
| 03/10/2014 16:00 | 1 | 1 |
| 03/10/2014 17:00 | 1 | 1 |
| 03/10/2014 18:00 | 1 | 1 |
| 03/10/2014 19:00 | 1 | 1 |
| 03/10/2014 20:00 | 1 | 1 |
| 03/10/2014 21:00 | 1 | 1 |
| 03/10/2014 22:00 | 1 | 1 |
| 03/10/2014 23:00 | 2 | 3 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 0 | 1 |
| **Maximum:** | 2 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/11/2014 00:00 | 2 | 3 |
| 03/11/2014 01:00 | 2 | 3 |
| 03/11/2014 02:00 | 2 | 3 |
| 03/11/2014 03:00 | 5 | 3 |
| 03/11/2014 04:00 | 5 | 3 |
| 03/11/2014 05:00 | 4 | 14 |
| 03/11/2014 06:00 | 3 | 22 |
| 03/11/2014 07:00 | 1 | 22 |
| 03/11/2014 08:00 | 1 | 19 |
| 03/11/2014 09:00 | 1 | 8 |
| 03/11/2014 10:00 | 1 | 1 |
| 03/11/2014 11:00 | 1 | 0 |
| 03/11/2014 12:00 | 1 | 0 |
| 03/11/2014 13:00 | 1 | 0 |
| 03/11/2014 14:00 | 1 | 0 |
| 03/11/2014 15:00 | 1 | 1 |
| 03/11/2014 16:00 | 1 | 1 |
| 03/11/2014 17:00 | 1 | 1 |
| 03/11/2014 18:00 | 1 | 1 |
| 03/11/2014 19:00 | 1 | 1 |
| 03/11/2014 20:00 | 1 | 1 |
| 03/11/2014 21:00 | 1 | 1 |
| 03/11/2014 22:00 | 1 | 1 |
| 03/11/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 2 | 6 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 5 | 22 |
| **%SI** | 0 | 17 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/12/2014 00:00 | 1 | 1 |
| 03/12/2014 01:00 | 1 | 1 |
| 03/12/2014 02:00 | 1 | 1 |
| 03/12/2014 03:00 | 1 | 1 |
| 03/12/2014 04:00 | 1 | 1 |
| 03/12/2014 05:00 | 1 | 1 |
| 03/12/2014 06:00 | 1 | 1 |
| 03/12/2014 07:00 | 1 | 1 |
| 03/12/2014 08:00 | 1 | 1 |
| 03/12/2014 09:00 | 1 | 1 |
| 03/12/2014 10:00 | 1 | 1 |
| 03/12/2014 11:00 | 1 | 1 |
| 03/12/2014 12:00 | 1 | 1 |
| 03/12/2014 13:00 | 1 | 1 |
| 03/12/2014 14:00 | 1 | 1 |
| 03/12/2014 15:00 | 1 | 1 |
| 03/12/2014 16:00 | 1 | 1 |
| 03/12/2014 17:00 | 1 | 1 |
| 03/12/2014 18:00 | 1 | 1 |
| 03/12/2014 19:00 | 1 | 1 |
| 03/12/2014 20:00 | 1 | 1 |
| 03/12/2014 21:00 | 1 | 1 |
| 03/12/2014 22:00 | 1 | 1 |
| 03/12/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/13/2014 00:00 | 1 | 1 |
| 03/13/2014 01:00 | 1 | 1 |
| 03/13/2014 02:00 | 1 | 1 |
| 03/13/2014 03:00 | 1 | 1 |
| 03/13/2014 04:00 | 1 | 1 |
| 03/13/2014 05:00 | 1 | 1 |
| 03/13/2014 06:00 | 1 | 1 |
| 03/13/2014 07:00 | 1 | 1 |
| 03/13/2014 08:00 | 1 | 1 |
| 03/13/2014 09:00 | 1 | 1 |
| 03/13/2014 10:00 | 1 | 1 |
| 03/13/2014 11:00 | 1 | 1 |
| 03/13/2014 12:00 | 1 | 1 |
| 03/13/2014 13:00 | 1 | 1 |
| 03/13/2014 14:00 | 1 | 1 |
| 03/13/2014 15:00 | 1 | 1 |
| 03/13/2014 16:00 | 1 | 1 |
| 03/13/2014 17:00 | 1 | 1 |
| 03/13/2014 18:00 | 1 | 1 |
| 03/13/2014 19:00 | 1 | 1 |
| 03/13/2014 20:00 | 1 | 1 |
| 03/13/2014 21:00 | 1 | 1 |
| 03/13/2014 22:00 | 1 | 1 |
| 03/13/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 1 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 1 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/14/2014 00:00 | 1 | 1 |
| 03/14/2014 01:00 | 1 | 1 |
| 03/14/2014 02:00 | 1 | 1 |
| 03/14/2014 03:00 | 1 | 1 |
| 03/14/2014 04:00 | 1 | 1 |
| 03/14/2014 05:00 | 1 | 1 |
| 03/14/2014 06:00 | 1 | 1 |
| 03/14/2014 07:00 | 1 | 8 |
| 03/14/2014 08:00 | 1 | 8 |
| 03/14/2014 09:00 | 1 | 8 |
| 03/14/2014 10:00 | 1 | 8 |
| 03/14/2014 11:00 | 1 | 1 |
| 03/14/2014 12:00 | 1 | 1 |
| 03/14/2014 13:00 | 1 | 1 |
| 03/14/2014 14:00 | 1 | 1 |
| 03/14/2014 15:00 | 1 | 1 |
| 03/14/2014 16:00 | 1 | 1 |
| 03/14/2014 17:00 | 1 | 1 |
| 03/14/2014 18:00 | 1 | 1 |
| 03/14/2014 19:00 | 1 | 1 |
| 03/14/2014 20:00 | 1 | 1 |
| 03/14/2014 21:00 | 1 | 1 |
| 03/14/2014 22:00 | 1 | 1 |
| 03/14/2014 23:00 | 1 | 1 |
| **Average/Sum#:** | 1 | 2 |
| **Minimum:** | 1 | 1 |
| **Maximum:** | 1 | 8 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/15/2014 00:00 | 1 | 3 |
| 03/15/2014 01:00 | 1 | 3 |
| 03/15/2014 02:00 | 1 | 3 |
| 03/15/2014 03:00 | 1 | 3 |
| 03/15/2014 04:00 | 1 | 3 |
| 03/15/2014 05:00 | 1 | 3 |
| 03/15/2014 06:00 | 1 | 3 |
| 03/15/2014 07:00 | 1 | 3 |
| 03/15/2014 08:00 | 1 | 3 |
| 03/15/2014 09:00 | 1 | 3 |
| 03/15/2014 10:00 | 1 | 3 |
| 03/15/2014 11:00 | 1 | 3 |
| 03/15/2014 12:00 | 1 | 3 |
| 03/15/2014 13:00 | 1 | 3 |
| 03/15/2014 14:00 | 1 | 3 |
| 03/15/2014 15:00 | 1 | 3 |
| 03/15/2014 16:00 | 1 | 3 |
| 03/15/2014 17:00 | 1 | 3 |
| 03/15/2014 18:00 | 1 | 3 |
| 03/15/2014 19:00 | 1 | 3 |
| 03/15/2014 20:00 | 1 | 3 |
| 03/15/2014 21:00 | 1 | 3 |
| 03/15/2014 22:00 | 1 | 3 |
| 03/15/2014 23:00 | 1 | 3 |
| **Average/Sum#:** | 1 | 3 |
| **Minimum:** | 1 | 3 |
| **Maximum:** | 1 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/16/2014 00:00 | 1 | 3 |
| 03/16/2014 01:00 | 1 | 3 |
| 03/16/2014 02:00 | 1 | 3 |
| 03/16/2014 03:00 | 1 | 3 |
| 03/16/2014 04:00 | 1 | 3 |
| 03/16/2014 05:00 | 1 | 3 |
| 03/16/2014 06:00 | 1 | 3 |
| 03/16/2014 07:00 | 1 | 3 |
| 03/16/2014 08:00 | 1 | 3 |
| 03/16/2014 09:00 | 1 | 3 |
| 03/16/2014 10:00 | 1 | 3 |
| 03/16/2014 11:00 | 1 | 3 |
| 03/16/2014 12:00 | 1 | 3 |
| 03/16/2014 13:00 | 1 | 3 |
| 03/16/2014 14:00 | 1 | 3 |
| 03/16/2014 15:00 | 1 | 3 |
| 03/16/2014 16:00 | 1 | 3 |
| 03/16/2014 17:00 | 1 | 3 |
| 03/16/2014 18:00 | 1 | 3 |
| 03/16/2014 19:00 | 1 | 3 |
| 03/16/2014 20:00 | 1 | 3 |
| 03/16/2014 21:00 | 1 | 3 |
| 03/16/2014 22:00 | 1 | 3 |
| 03/16/2014 23:00 | 1 | 3 |
| **Average/Sum#:** | 1 | 3 |
| **Minimum:** | 1 | 3 |
| **Maximum:** | 1 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/17/2014 00:00 | 1 | 3 |
| 03/17/2014 01:00 | 1 | 3 |
| 03/17/2014 02:00 | 1 | 3 |
| 03/17/2014 03:00 | 1 | 3 |
| 03/17/2014 04:00 | 1 | 3 |
| 03/17/2014 05:00 | 1 | 3 |
| 03/17/2014 06:00 | 1 | 3 |
| 03/17/2014 07:00 | 1 | 3 |
| 03/17/2014 08:00 | 1 | 3 |
| 03/17/2014 09:00 | 1 | 3 |
| 03/17/2014 10:00 | 1 | 3 |
| 03/17/2014 11:00 | 1 | 3 |
| 03/17/2014 12:00 | 1 | 3 |
| 03/17/2014 13:00 | 1 | 3 |
| 03/17/2014 14:00 | 1 | 3 |
| 03/17/2014 15:00 | 1 | 3 |
| 03/17/2014 16:00 | 1 | 3 |
| 03/17/2014 17:00 | 1 | 3 |
| 03/17/2014 18:00 | 1 | 3 |
| 03/17/2014 19:00 | 1 | 3 |
| 03/17/2014 20:00 | 1 | 3 |
| 03/17/2014 21:00 | 1 | 3 |
| 03/17/2014 22:00 | 1 | 3 |
| 03/17/2014 23:00 | 1 | 3 |
| **Average/Sum#:** | 1 | 3 |
| **Minimum:** | 1 | 3 |
| **Maximum:** | 1 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/18/2014 00:00 | 1 | 3 |
| 03/18/2014 01:00 | 1 | 3 |
| 03/18/2014 02:00 | 1 | 3 |
| 03/18/2014 03:00 | 1 | 3 |
| 03/18/2014 04:00 | 1 | 3 |
| 03/18/2014 05:00 | 1 | 3 |
| 03/18/2014 06:00 | 1 | 3 |
| 03/18/2014 07:00 | 1 | 3 |
| 03/18/2014 08:00 | 1 | 3 |
| 03/18/2014 09:00 | 1 | 3 |
| 03/18/2014 10:00 | 1 | 3 |
| 03/18/2014 11:00 | 1 | 3 |
| 03/18/2014 12:00 | 1 | 3 |
| 03/18/2014 13:00 | 1 | 3 |
| 03/18/2014 14:00 | 1 | 3 |
| 03/18/2014 15:00 | 1 | 3 |
| 03/18/2014 16:00 | 1 | 3 |
| 03/18/2014 17:00 | 1 | 3 |
| 03/18/2014 18:00 | 1 | 3 |
| 03/18/2014 19:00 | 1 | 3 |
| 03/18/2014 20:00 | 1 | 3 |
| 03/18/2014 21:00 | 1 | 3 |
| 03/18/2014 22:00 | 1 | 3 |
| 03/18/2014 23:00 | 1 | 3 |
| **Average/Sum#:** | 1 | 3 |
| **Minimum:** | 1 | 3 |
| **Maximum:** | 1 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/19/2014 00:00 | 1 | 3 |
| 03/19/2014 01:00 | 1 | 3 |
| 03/19/2014 02:00 | 1 | 3 |
| 03/19/2014 03:00 | 1 | 3 |
| 03/19/2014 04:00 | 1 | 3 |
| 03/19/2014 05:00 | 1 | 3 |
| 03/19/2014 06:00 | 1 | 3 |
| 03/19/2014 07:00 | 1 | 3 |
| 03/19/2014 08:00 | 1 | 3 |
| 03/19/2014 09:00 | 1 | 3 |
| 03/19/2014 10:00 | 1 | 3 |
| 03/19/2014 11:00 | 1 | 3 |
| 03/19/2014 12:00 | 1 | 3 |
| 03/19/2014 13:00 | 1 | 3 |
| 03/19/2014 14:00 | 1 | 3 |
| 03/19/2014 15:00 | 1 | 3 |
| 03/19/2014 16:00 | 1 | 3 |
| 03/19/2014 17:00 | 1 | 3 |
| 03/19/2014 18:00 | 1 | 3 |
| 03/19/2014 19:00 | 1 | 3 |
| 03/19/2014 20:00 | 1 | 3 |
| 03/19/2014 21:00 | 1 | 3 |
| 03/19/2014 22:00 | 1 | 3 |
| 03/19/2014 23:00 | 1 | 3 |
| **Average/Sum#:** | 1 | 3 |
| **Minimum:** | 1 | 3 |
| **Maximum:** | 1 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/20/2014 00:00 | 1 | 3 |
| 03/20/2014 01:00 | 1 | 3 |
| 03/20/2014 02:00 | 1 | 3 |
| 03/20/2014 03:00 | 1 | 3 |
| 03/20/2014 04:00 | 1 | 3 |
| 03/20/2014 05:00 | 1 | 3 |
| 03/20/2014 06:00 | 1 | 3 |
| 03/20/2014 07:00 | 1 | 3 |
| 03/20/2014 08:00 | 1 | 3 |
| 03/20/2014 09:00 | 1 | 3 |
| 03/20/2014 10:00 | 1 | 3 |
| 03/20/2014 11:00 | 1 | 3 |
| 03/20/2014 12:00 | 1 | 3 |
| 03/20/2014 13:00 | 1 | 3 |
| 03/20/2014 14:00 | 1 | 3 |
| 03/20/2014 15:00 | 1 | 3 |
| 03/20/2014 16:00 | 1 | 3 |
| 03/20/2014 17:00 | 1 | 3 |
| 03/20/2014 18:00 | 1 | 3 |
| 03/20/2014 19:00 | 1 | 3 |
| 03/20/2014 20:00 | 1 | 3 |
| 03/20/2014 21:00 | 1 | 3 |
| 03/20/2014 22:00 | 1 | 3 |
| 03/20/2014 23:00 | 1 | 3 |
| **Average/Sum#:** | 1 | 3 |
| **Minimum:** | 1 | 3 |
| **Maximum:** | 1 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/21/2014 00:00 | 1 | 3 |
| 03/21/2014 01:00 | 1 | 3 |
| 03/21/2014 02:00 | 1 | 3 |
| 03/21/2014 03:00 | 1 | 3 |
| 03/21/2014 04:00 | 1 | 3 |
| 03/21/2014 05:00 | 1 | 3 |
| 03/21/2014 06:00 | 1 | 3 |
| 03/21/2014 07:00 | 1 | 3 |
| 03/21/2014 08:00 | 1 | 3 |
| 03/21/2014 09:00 | 1 | 3 |
| 03/21/2014 10:00 | 1 | 3 |
| 03/21/2014 11:00 | 1 | 3 |
| 03/21/2014 12:00 | 1 | 3 |
| 03/21/2014 13:00 | 1 | 3 |
| 03/21/2014 14:00 | 1 | 3 |
| 03/21/2014 15:00 | 1 | 3 |
| 03/21/2014 16:00 | 1 | 3 |
| 03/21/2014 17:00 | 1 | 3 |
| 03/21/2014 18:00 | 1 | 3 |
| 03/21/2014 19:00 | 1 | 3 |
| 03/21/2014 20:00 | 1 | 3 |
| 03/21/2014 21:00 | 1 | 3 |
| 03/21/2014 22:00 | 1 | 3 |
| 03/21/2014 23:00 | 1 | 3 |
| **Average/Sum#:** | 1 | 3 |
| **Minimum:** | 1 | 3 |
| **Maximum:** | 1 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/22/2014 00:00 | 1 | 3 |
| 03/22/2014 01:00 | 1 | 3 |
| 03/22/2014 02:00 | 1 | 3 |
| 03/22/2014 03:00 | 1 | 3 |
| 03/22/2014 04:00 | 1 | 3 |
| 03/22/2014 05:00 | 1 | 3 |
| 03/22/2014 06:00 | 1 | 3 |
| 03/22/2014 07:00 | 1 | 3 |
| 03/22/2014 08:00 | 1 | 3 |
| 03/22/2014 09:00 | 1 | 3 |
| 03/22/2014 10:00 | 1 | 3 |
| 03/22/2014 11:00 | 1 | 3 |
| 03/22/2014 12:00 | 1 | 3 |
| 03/22/2014 13:00 | 1 | 3 |
| 03/22/2014 14:00 | 1 | 3 |
| 03/22/2014 15:00 | 1 | 3 |
| 03/22/2014 16:00 | 1 | 3 |
| 03/22/2014 17:00 | 1 | 3 |
| 03/22/2014 18:00 | 1 | 3 |
| 03/22/2014 19:00 | 1 | 3 |
| 03/22/2014 20:00 | 1 | 3 |
| 03/22/2014 21:00 | 1 | 3 |
| 03/22/2014 22:00 | 1 | 3 |
| 03/22/2014 23:00 | 1 | 3 |
| **Average/Sum#:** | 1 | 3 |
| **Minimum:** | 1 | 3 |
| **Maximum:** | 1 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/23/2014 00:00 | 1 | 3 |
| 03/23/2014 01:00 | 1 | 3 |
| 03/23/2014 02:00 | 1 | 3 |
| 03/23/2014 03:00 | 1 | 3 |
| 03/23/2014 04:00 | 1 | 3 |
| 03/23/2014 05:00 | 1 | 3 |
| 03/23/2014 06:00 | 1 | 3 |
| 03/23/2014 07:00 | 1 | 3 |
| 03/23/2014 08:00 | 1 | 3 |
| 03/23/2014 09:00 | 1 | 3 |
| 03/23/2014 10:00 | 1 | 3 |
| 03/23/2014 11:00 | 1 | 3 |
| 03/23/2014 12:00 | 1 | 3 |
| 03/23/2014 13:00 | 1 | 3 |
| 03/23/2014 14:00 | 1 | 3 |
| 03/23/2014 15:00 | 1 | 3 |
| 03/23/2014 16:00 | 1 | 3 |
| 03/23/2014 17:00 | 1 | 3 |
| 03/23/2014 18:00 | 1 | 3 |
| 03/23/2014 19:00 | 1 | 3 |
| 03/23/2014 20:00 | 1 | 3 |
| 03/23/2014 21:00 | 1 | 3 |
| 03/23/2014 22:00 | 1 | 3 |
| 03/23/2014 23:00 | 1 | 3 |
| **Average/Sum#:** | 1 | 3 |
| **Minimum:** | 1 | 3 |
| **Maximum:** | 1 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/24/2014 00:00 | 1 | 3 |
| 03/24/2014 01:00 | 1 | 3 |
| 03/24/2014 02:00 | 1 | 3 |
| 03/24/2014 03:00 | 1 | 3 |
| 03/24/2014 04:00 | 1 | 3 |
| 03/24/2014 05:00 | 1 | 3 |
| 03/24/2014 06:00 | 1 | 3 |
| 03/24/2014 07:00 | 1 | 3 |
| 03/24/2014 08:00 | 1 | 3 |
| 03/24/2014 09:00 | 1 | 3 |
| 03/24/2014 10:00 | 1 | 3 |
| 03/24/2014 11:00 | 1 | 3 |
| 03/24/2014 12:00 | 1 | 3 |
| 03/24/2014 13:00 | 1 | 3 |
| 03/24/2014 14:00 | 1 | 3 |
| 03/24/2014 15:00 | 1 | 3 |
| 03/24/2014 16:00 | 1 | 3 |
| 03/24/2014 17:00 | 1 | 3 |
| 03/24/2014 18:00 | 1 | 3 |
| 03/24/2014 19:00 | 1 | 3 |
| 03/24/2014 20:00 | 1 | 3 |
| 03/24/2014 21:00 | 1 | 3 |
| 03/24/2014 22:00 | 1 | 3 |
| 03/24/2014 23:00 | 1 | 3 |
| **Average/Sum#:** | 1 | 3 |
| **Minimum:** | 1 | 3 |
| **Maximum:** | 1 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/25/2014 00:00 | 1 | 3 |
| 03/25/2014 01:00 | 1 | 3 |
| 03/25/2014 02:00 | 1 | 3 |
| 03/25/2014 03:00 | 1 | 3 |
| 03/25/2014 04:00 | 1 | 3 |
| 03/25/2014 05:00 | 1 | 3 |
| 03/25/2014 06:00 | 1 | 3 |
| 03/25/2014 07:00 | 1 | 3 |
| 03/25/2014 08:00 | 1 | 3 |
| 03/25/2014 09:00 | 1 | 3 |
| 03/25/2014 10:00 | 1 | 3 |
| 03/25/2014 11:00 | 1 | 3 |
| 03/25/2014 12:00 | 1 | 3 |
| 03/25/2014 13:00 | 1 | 3 |
| 03/25/2014 14:00 | 1 | 3 |
| 03/25/2014 15:00 | 1 | 3 |
| 03/25/2014 16:00 | 1 | 3 |
| 03/25/2014 17:00 | 1 | 3 |
| 03/25/2014 18:00 | 1 | 3 |
| 03/25/2014 19:00 | 1 | 3 |
| 03/25/2014 20:00 | 1 | 3 |
| 03/25/2014 21:00 | 1 | 3 |
| 03/25/2014 22:00 | 1 | 3 |
| 03/25/2014 23:00 | 1 | 3 |
| **Average/Sum#:** | 1 | 3 |
| **Minimum:** | 1 | 3 |
| **Maximum:** | 1 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/26/2014 00:00 | 1 | 3 |
| 03/26/2014 01:00 | 1 | 3 |
| 03/26/2014 02:00 | 1 | 3 |
| 03/26/2014 03:00 | 1 | 3 |
| 03/26/2014 04:00 | 1 | 3 |
| 03/26/2014 05:00 | 1 | 3 |
| 03/26/2014 06:00 | 1 | 3 |
| 03/26/2014 07:00 | 1 | 3 |
| 03/26/2014 08:00 | 1 | 3 |
| 03/26/2014 09:00 | 1 | 3 |
| 03/26/2014 10:00 | 1 | 3 |
| 03/26/2014 11:00 | 1 | 3 |
| 03/26/2014 12:00 | 1 | 3 |
| 03/26/2014 13:00 | 1 | 3 |
| 03/26/2014 14:00 | 1 | 3 |
| 03/26/2014 15:00 | 1 | 3 |
| 03/26/2014 16:00 | 1 | 3 |
| 03/26/2014 17:00 | 1 | 3 |
| 03/26/2014 18:00 | 1 | 3 |
| 03/26/2014 19:00 | 1 | 3 |
| 03/26/2014 20:00 | 1 | 3 |
| 03/26/2014 21:00 | 1 | 3 |
| 03/26/2014 22:00 | 1 | 3 |
| 03/26/2014 23:00 | 1 | 3 |
| **Average/Sum#:** | 1 | 3 |
| **Minimum:** | 1 | 3 |
| **Maximum:** | 1 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/27/2014 00:00 | 1 | 3 |
| 03/27/2014 01:00 | 1 | 3 |
| 03/27/2014 02:00 | 1 | 3 |
| 03/27/2014 03:00 | 1 | 3 |
| 03/27/2014 04:00 | 1 | 3 |
| 03/27/2014 05:00 | 1 | 3 |
| 03/27/2014 06:00 | 1 | 3 |
| 03/27/2014 07:00 | 1 | 3 |
| 03/27/2014 08:00 | 1 | 3 |
| 03/27/2014 09:00 | 1 | 3 |
| 03/27/2014 10:00 | 1 | 3 |
| 03/27/2014 11:00 | 1 | 3 |
| 03/27/2014 12:00 | 1 | 3 |
| 03/27/2014 13:00 | 1 | 3 |
| 03/27/2014 14:00 | 1 | 3 |
| 03/27/2014 15:00 | 1 | 3 |
| 03/27/2014 16:00 | 1 | 3 |
| 03/27/2014 17:00 | 1 | 3 |
| 03/27/2014 18:00 | 1 | 3 |
| 03/27/2014 19:00 | 1 | 3 |
| 03/27/2014 20:00 | 1 | 3 |
| 03/27/2014 21:00 | 1 | 3 |
| 03/27/2014 22:00 | 1 | 3 |
| 03/27/2014 23:00 | 1 | 3 |
| **Average/Sum#:** | 1 | 3 |
| **Minimum:** | 1 | 3 |
| **Maximum:** | 1 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/28/2014 00:00 | 1 | 3 |
| 03/28/2014 01:00 | 1 | 3 |
| 03/28/2014 02:00 | 1 | 3 |
| 03/28/2014 03:00 | 1 | 3 |
| 03/28/2014 04:00 | 1 | 3 |
| 03/28/2014 05:00 | 1 | 3 |
| 03/28/2014 06:00 | 1 | 3 |
| 03/28/2014 07:00 | 1 | 3 |
| 03/28/2014 08:00 | 1 | 3 |
| 03/28/2014 09:00 | 1 | 3 |
| 03/28/2014 10:00 | 1 | 3 |
| 03/28/2014 11:00 | 1 | 3 |
| 03/28/2014 12:00 | 1 | 3 |
| 03/28/2014 13:00 | 1 | 3 |
| 03/28/2014 14:00 | 1 | 3 |
| 03/28/2014 15:00 | 1 | 3 |
| 03/28/2014 16:00 | 1 | 3 |
| 03/28/2014 17:00 | 1 | 3 |
| 03/28/2014 18:00 | 1 | 3 |
| 03/28/2014 19:00 | 1 | 3 |
| 03/28/2014 20:00 | 1 | 3 |
| 03/28/2014 21:00 | 1 | 3 |
| 03/28/2014 22:00 | 1 | 3 |
| 03/28/2014 23:00 | 1 | 3 |
| **Average/Sum#:** | 1 | 3 |
| **Minimum:** | 1 | 3 |
| **Maximum:** | 1 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/29/2014 00:00 | 1 | 3 |
| 03/29/2014 01:00 | 1 | 3 |
| 03/29/2014 02:00 | 1 | 3 |
| 03/29/2014 03:00 | 1 | 3 |
| 03/29/2014 04:00 | 1 | 3 |
| 03/29/2014 05:00 | 1 | 3 |
| 03/29/2014 06:00 | 1 | 3 |
| 03/29/2014 07:00 | 1 | 3 |
| 03/29/2014 08:00 | 1 | 3 |
| 03/29/2014 09:00 | 1 | 3 |
| 03/29/2014 10:00 | 1 | 3 |
| 03/29/2014 11:00 | 1 | 3 |
| 03/29/2014 12:00 | 1 | 3 |
| 03/29/2014 13:00 | 1 | 3 |
| 03/29/2014 14:00 | 1 | 3 |
| 03/29/2014 15:00 | 1 | 3 |
| 03/29/2014 16:00 | 1 | 3 |
| 03/29/2014 17:00 | 1 | 3 |
| 03/29/2014 18:00 | 1 | 3 |
| 03/29/2014 19:00 | 1 | 3 |
| 03/29/2014 20:00 | 1 | 3 |
| 03/29/2014 21:00 | 1 | 3 |
| 03/29/2014 22:00 | 1 | 3 |
| 03/29/2014 23:00 | 1 | 3 |
| **Average/Sum#:** | 1 | 3 |
| **Minimum:** | 1 | 3 |
| **Maximum:** | 1 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/30/2014 00:00 | 1 | 3 |
| 03/30/2014 01:00 | 1 | 3 |
| 03/30/2014 02:00 | 1 | 3 |
| 03/30/2014 03:00 | 1 | 3 |
| 03/30/2014 04:00 | 1 | 3 |
| 03/30/2014 05:00 | 1 | 3 |
| 03/30/2014 06:00 | 1 | 3 |
| 03/30/2014 07:00 | 1 | 3 |
| 03/30/2014 08:00 | 1 | 3 |
| 03/30/2014 09:00 | 1 | 3 |
| 03/30/2014 10:00 | 1 | 3 |
| 03/30/2014 11:00 | 1 | 3 |
| 03/30/2014 12:00 | 1 | 3 |
| 03/30/2014 13:00 | 1 | 3 |
| 03/30/2014 14:00 | 1 | 3 |
| 03/30/2014 15:00 | 1 | 3 |
| 03/30/2014 16:00 | 1 | 3 |
| 03/30/2014 17:00 | 1 | 3 |
| 03/30/2014 18:00 | 1 | 3 |
| 03/30/2014 19:00 | 1 | 3 |
| 03/30/2014 20:00 | 1 | 3 |
| 03/30/2014 21:00 | 1 | 3 |
| 03/30/2014 22:00 | 1 | 3 |
| 03/30/2014 23:00 | 1 | 3 |
| **Average/Sum#:** | 1 | 3 |
| **Minimum:** | 1 | 3 |
| **Maximum:** | 1 | 3 |
| **%SI** | 0 | 0 |

# Daily Summary Report

## KKKK NOx 4HR Rolling Avg

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 08:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | > Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s) | > Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s) |
|---|---|---|
| 03/31/2014 00:00 | 1 | 3 |
| 03/31/2014 01:00 | 1 | 3 |
| 03/31/2014 02:00 | 1 | 3 |
| 03/31/2014 03:00 | 1 | 3 |
| 03/31/2014 04:00 | 1 | 3 |
| 03/31/2014 05:00 | 1 | 3 |
| 03/31/2014 06:00 | 1 | 3 |
| 03/31/2014 07:00 | 1 | 3 |
| 03/31/2014 08:00 | 1 | 3 |
| 03/31/2014 09:00 | 1 | 3 |
| 03/31/2014 10:00 | 1 | 3 |
| 03/31/2014 11:00 | 1 | 3 |
| 03/31/2014 12:00 | 1 | 3 |
| 03/31/2014 13:00 | 1 | 3 |
| 03/31/2014 14:00 | 1 | 3 |
| 03/31/2014 15:00 | 1 | 3 |
| 03/31/2014 16:00 | 1 | 3 |
| 03/31/2014 17:00 | 1 | 3 |
| 03/31/2014 18:00 | 1 | 3 |
| 03/31/2014 19:00 | 1 | 3 |
| 03/31/2014 20:00 | 1 | 3 |
| 03/31/2014 21:00 | 1 | 3 |
| 03/31/2014 22:00 | 1 | 3 |
| 03/31/2014 23:00 | 1 | 3 |
| **Average/Sum#:** | 1 | 3 |
| **Minimum:** | 1 | 3 |
| **Maximum:** | 1 | 3 |
| **%SI** | 0 | 0 |

# Excess Emission Report

## CT1 NOx 30 Day Rolling Average (KKKK)

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT1_NOx_30D_Ppmvdc_1D
**Total Operating Time:** 52.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 38.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 52.00 Day(s) |
| Total Duration (Online only): | 0.00 Day(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT2 NOx 30 Day Rolling Average (KKKK)

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT2_NOx_30D_Ppmvdc_1D
**Total Operating Time:** 54.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 36.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 54.00 Day(s) |
| Total Duration (Online only): | 0.00 Day(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# ATTACHMENT 4

## Excess Emission/Downtime Report (AQ-4, 19)

# EDS-CMS Reports

# EDS/CMS Summary Report

## CT1 - CO LbPerHr

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:15 **Location:** Maxwell, CA
**Description:** Electric Utility

---

**CMS Data from:** CT1_CO_LbPerHr_1H
**EDS Data from:** CT1_CO_LbPerHr_1H
**Emission Limitation:** CT1_COLimit_LbPerHr_1H
**No Value Exclusions Allowed**
**Monitor Manufacturer and Model No.:** TELEDYNE MONITOR LABS INC, TML30
**Date of Latest CMS Certification or Audit:** 12/01/2009 00:00
**Operating time for EDS:** 1,178.00 Hour(s)
**Operating time for CMS:** 1,178.00 Hour(s)

| Emission Data Summary | |
|---|---|
| 1. Duration of excess emission in reporting period due to: | |
| a. Startup/shutdown | 0 |
| b. Control equipment problems | 0 |
| c. Process Problems | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Upset Conditions | 0 |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0 |
| 4. Time of Excess Emission as a percentage of operating time | 0.00 |
| 5. Time in compliance as percentage of operating time | 100.00 |

| CMS Performance Summary | |
|---|---|
| 1. CMS downtime in reporting period due to: | |
| a. Monitor equipment malfunctions | 0 |
| b. Non-Monitor equipment malfunctions | 0 |
| c. Quality assurance calibration | 4 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Total CMS Downtime | 4 |
| 3. Total Downtime as a percentage of operating time | 0.34 |
| 4. Total Availability as a percentage of operating time | 99.66 |

*Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.*

# EDS/CMS Summary Report

## CT1 - CO Ppmvdc

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:15 **Location:** Maxwell, CA
**Description:** Electric Utility

---

**CMS Data from:** CT1_CO_Ppmvdc_1H
**EDS Data from:** CT1_CO_3Hr_Ppmvdc_1H
**Emission Limitation:** CT1_COLimit_3Hr_Ppmvdc_1H
**No Value Exclusions Allowed**
**Monitor Manufacturer and Model No.:** TELEDYNE MONITOR LABS INC, TML30
**Date of Latest CMS Certification or Audit:** 12/01/2009 00:00
**Operating time for EDS:** 1,178.00 Hour(s)
**Operating time for CMS:** 1,178.00 Hour(s)

| Emission Data Summary | |
|---|---|
| 1. Duration of excess emission in reporting period due to: | |
| a. Startup/shutdown | 0 |
| b. Control equipment problems | 0 |
| c. Process Problems | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Upset Conditions | 0 |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0 |
| 4. Time of Excess Emission as a percentage of operating time | 0.00 |
| 5. Time in compliance as percentage of operating time | 100.00 |

| CMS Performance Summary | |
|---|---|
| 1. CMS downtime in reporting period due to: | |
| a. Monitor equipment malfunctions | 0 |
| b. Non-Monitor equipment malfunctions | 0 |
| c. Quality assurance calibration | 4 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Total CMS Downtime | 4 |
| 3. Total Downtime as a percentage of operating time | 0.34 |
| 4. Total Availability as a percentage of operating time | 99.66 |

*Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.*

# EDS/CMS Summary Report

## CT1 - NOx LbPerHr

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:15 **Location:** Maxwell, CA
**Description:** Electric Utility

---

**CMS Data from:** CT1_NOx_LbPerHr_1H
**EDS Data from:** CT1_NOx_LbPerHr_1H
**Emission Limitation:** CT1_NOxLimit_LbPerHr_1H
**No Value Exclusions Allowed**
**Monitor Manufacturer and Model No.:** TELEDYNE MONITOR LABS INC, TML41-O2
**Date of Latest CMS Certification or Audit:** 12/01/2009 00:00
**Operating time for EDS:** 1,178.00 Hour(s)
**Operating time for CMS:** 1,178.00 Hour(s)

| Emission Data Summary | |
|---|---|
| 1. Duration of excess emission in reporting period due to: | |
| a. Startup/shutdown | 0 |
| b. Control equipment problems | 0 |
| c. Process Problems | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Upset Conditions | 0 |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0 |
| 4. Time of Excess Emission as a percentage of operating time | 0.00 |
| 5. Time in compliance as percentage of operating time | 100.00 |

| CMS Performance Summary | |
|---|---|
| 1. CMS downtime in reporting period due to: | |
| a. Monitor equipment malfunctions | 0 |
| b. Non-Monitor equipment malfunctions | 0 |
| c. Quality assurance calibration | 4 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Total CMS Downtime | 4 |
| 3. Total Downtime as a percentage of operating time | 0.34 |
| 4. Total Availability as a percentage of operating time | 99.66 |

*Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.*

# EDS/CMS Summary Report

## CT1 - NOx Ppmvdc

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:15 **Location:** Maxwell, CA
**Description:** Electric Utility

---

**CMS Data from:** CT1_NOx_Ppmvdc_1H
**EDS Data from:** CT1_NOx_Ppmvdc_1H
**Emission Limitation:** CT1_NOxLimit_Ppmvdc_1H
**No Value Exclusions Allowed**
**Monitor Manufacturer and Model No.:** TELEDYNE MONITOR LABS INC, TML41-O2
**Date of Latest CMS Certification or Audit:** 12/01/2009 00:00
**Operating time for EDS:** 1,178.00 Hour(s)
**Operating time for CMS:** 1,178.00 Hour(s)

| Emission Data Summary | |
|---|---|
| 1. Duration of excess emission in reporting period due to: | |
| a. Startup/shutdown | 0 |
| b. Control equipment problems | 0 |
| c. Process Problems | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Upset Conditions | 0 |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0 |
| 4. Time of Excess Emission as a percentage of operating time | 0.00 |
| 5. Time in compliance as percentage of operating time | 100.00 |

| CMS Performance Summary | |
|---|---|
| 1. CMS downtime in reporting period due to: | |
| a. Monitor equipment malfunctions | 0 |
| b. Non-Monitor equipment malfunctions | 0 |
| c. Quality assurance calibration | 4 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Total CMS Downtime | 4 |
| 3. Total Downtime as a percentage of operating time | 0.34 |
| 4. Total Availability as a percentage of operating time | 99.66 |

*Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.*

# EDS/CMS Summary Report

## CT2 - CO LbPerHr

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:15 **Location:** Maxwell, CA
**Description:** Electric Utility

---

**CMS Data from:** CT2_CO_LbPerHr_1H
**EDS Data from:** CT2_CO_LbPerHr_1H
**Emission Limitation:** CT2_COLimit_LbPerHr_1H
**No Value Exclusions Allowed**
**Monitor Manufacturer and Model No.:** TELEDYNE MONITOR LABS INC, TML30
**Date of Latest CMS Certification or Audit:** 12/01/2009 00:00
**Operating time for EDS:** 1,193.00 Hour(s)
**Operating time for CMS:** 1,193.00 Hour(s)

| Emission Data Summary | |
|---|---|
| 1. Duration of excess emission in reporting period due to: | |
| a. Startup/shutdown | 0 |
| b. Control equipment problems | 0 |
| c. Process Problems | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Upset Conditions | 0 |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0 |
| 4. Time of Excess Emission as a percentage of operating time | 0.00 |
| 5. Time in compliance as percentage of operating time | 100.00 |

| CMS Performance Summary | |
|---|---|
| 1. CMS downtime in reporting period due to: | |
| a. Monitor equipment malfunctions | 0 |
| b. Non-Monitor equipment malfunctions | 0 |
| c. Quality assurance calibration | 4 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Total CMS Downtime | 4 |
| 3. Total Downtime as a percentage of operating time | 0.34 |
| 4. Total Availability as a percentage of operating time | 99.66 |

*Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.*

# EDS/CMS Summary Report

## CT2 - CO Ppmvdc

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:15 **Location:** Maxwell, CA
**Description:** Electric Utility

---

| | |
|---|---|
| **CMS Data from:** | CT2_CO_Ppmvdc_1H |
| **EDS Data from:** | CT2_CO_3Hr_Ppmvdc_1H |
| **Emission Limitation:** | CT2_COLimit_3Hr_Ppmvdc_1H |
| **No Value Exclusions Allowed** | |
| **Monitor Manufacturer and Model No.:** | TELEDYNE MONITOR LABS INC, TML30 |
| **Date of Latest CMS Certification or Audit:** | 12/01/2009 00:00 |
| **Operating time for EDS:** | 1,193.00 Hour(s) |
| **Operating time for CMS:** | 1,193.00 Hour(s) |

| Emission Data Summary | |
|---|---|
| 1. Duration of excess emission in reporting period due to: | |
| a. Startup/shutdown | 0 |
| b. Control equipment problems | 0 |
| c. Process Problems | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Upset Conditions | 0 |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0 |
| 4. Time of Excess Emission as a percentage of operating time | 0.00 |
| 5. Time in compliance as percentage of operating time | 100.00 |

| CMS Performance Summary | |
|---|---|
| 1. CMS downtime in reporting period due to: | |
| a. Monitor equipment malfunctions | 0 |
| b. Non-Monitor equipment malfunctions | 0 |
| c. Quality assurance calibration | 4 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Total CMS Downtime | 4 |
| 3. Total Downtime as a percentage of operating time | 0.34 |
| 4. Total Availability as a percentage of operating time | 99.66 |

*Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.*

# EDS/CMS Summary Report

## CT2 - NOx LbPerHr

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:15 **Location:** Maxwell, CA
**Description:** Electric Utility

---

**CMS Data from:** CT2_NOx_LbPerHr_1H
**EDS Data from:** CT2_NOx_LbPerHr_1H
**Emission Limitation:** CT2_NOxLimit_LbPerHr_1H
**No Value Exclusions Allowed**
**Monitor Manufacturer and Model No.:** TELEDYNE MONITOR LABS INC, TML41-O2
**Date of Latest CMS Certification or Audit:** 12/01/2009 00:00
**Operating time for EDS:** 1,193.00 Hour(s)
**Operating time for CMS:** 1,193.00 Hour(s)

| Emission Data Summary | |
|---|---|
| 1. Duration of excess emission in reporting period due to: | |
| a. Startup/shutdown | 0 |
| b. Control equipment problems | 0 |
| c. Process Problems | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Upset Conditions | 0 |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0 |
| 4. Time of Excess Emission as a percentage of operating time | 0.00 |
| 5. Time in compliance as percentage of operating time | 100.00 |

| CMS Performance Summary | |
|---|---|
| 1. CMS downtime in reporting period due to: | |
| a. Monitor equipment malfunctions | 0 |
| b. Non-Monitor equipment malfunctions | 0 |
| c. Quality assurance calibration | 4 |
| d. Other known causes | 3 |
| e. Unknown causes | 0 |
| 2. Total CMS Downtime | 7 |
| 3. Total Downtime as a percentage of operating time | 0.59 |
| 4. Total Availability as a percentage of operating time | 99.41 |

*Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.*

# EDS/CMS Summary Report

## CT2 - NOx Ppmvdc

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:15 **Location:** Maxwell, CA
**Description:** Electric Utility

---

**CMS Data from:** CT2_NOx_Ppmvdc_1H
**EDS Data from:** CT2_NOx_Ppmvdc_1H
**Emission Limitation:** CT2_NOxLimit_Ppmvdc_1H
**No Value Exclusions Allowed**
**Monitor Manufacturer and Model No.:** TELEDYNE MONITOR LABS INC, TML41-O2
**Date of Latest CMS Certification or Audit:** 12/01/2009 00:00
**Operating time for EDS:** 1,193.00 Hour(s)
**Operating time for CMS:** 1,193.00 Hour(s)

| Emission Data Summary | |
|---|---|
| 1. Duration of excess emission in reporting period due to: | |
| a. Startup/shutdown | 0 |
| b. Control equipment problems | 0 |
| c. Process Problems | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Upset Conditions | 0 |
| 3. Total Duration (Subtracts Exclusions and Upset Conditions) | 0 |
| 4. Time of Excess Emission as a percentage of operating time | 0.00 |
| 5. Time in compliance as percentage of operating time | 100.00 |

| CMS Performance Summary | |
|---|---|
| 1. CMS downtime in reporting period due to: | |
| a. Monitor equipment malfunctions | 0 |
| b. Non-Monitor equipment malfunctions | 0 |
| c. Quality assurance calibration | 4 |
| d. Other known causes | 3 |
| e. Unknown causes | 0 |
| 2. Total CMS Downtime | 7 |
| 3. Total Downtime as a percentage of operating time | 0.59 |
| 4. Total Availability as a percentage of operating time | 99.41 |

*Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.*

# Excess Emission Reports

# Excess Emission Report

## CT2 - CO LbPerHr 1-Hour Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT2_CO_Lb_1H
**Total Operating Time:** 1,193.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 967.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,193.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT2 - CO Ppmvdc 3-Hour Rolling Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT2_CO_3Hr_Ppmvdc_1H
**Total Operating Time:** 1,193.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 967.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,193.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT2 - NOx LbPerHr 1-Hour Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT2_NOx_Lb_1H
**Total Operating Time:** 1,193.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 967.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,193.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT2 - NOx Ppmvdc 1-Hour Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT2_NOx_Ppmvdc_1H
**Total Operating Time:** 1,193.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 967.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,193.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT1 - CO LbPerHr 1-Hour Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT1_CO_Lb_1H
**Total Operating Time:** 1,178.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 982.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,178.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT1 - CO Ppmvdc 3-Hour Rolling Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT1_CO_3Hr_Ppmvdc_1H
**Total Operating Time:** 1,178.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 982.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,178.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT1 - NOx LbPerHr 1-Hour Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT1_NOx_Lb_1H
**Total Operating Time:** 1,178.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 982.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,178.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT1 - NOx Ppmvdc 1-Hour Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT1_NOx_Ppmvdc_1H
**Total Operating Time:** 1,178.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 982.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,178.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Downtime Reports

# Invalid Data Report

## CT1 - Stack CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:17 **Location:** Maxwell, CA

**Tag Name:** CT1_CO_LbPerHr_1H

**Total Operating Time:** 1,178.00 Hour(s)
Non-Operating Time: 982.00 Hour(s) Report Time: 2,160.00 Hour(s)

| Inc No | Start Time | End Time | Duration in Hour(s) | Reason Code - Description | Action Code - Description |
|---|---|---|---|---|---|
| 1 | 02/25/2014 10:00 | 02/25/2014 13:59 | 4 | 3 - Quality assurance calibration | 4 - Quarterly linearity/cga |

| | |
|---|---|
| Total Operating Time: | 1,178.00 Hour(s) |
| Total Monitor Downtime (Online only): | 4.00 Hour(s) |
| Percent Monitor Availability: | 99.66 % |
| Percent Monitor Downtime: | 0.34 % |

| Report Code | Type | Text | Duration | Duration Percent |
|---|---|---|---|---|
| 3 | Reason | Quality assurance calibration | 4 | 100.00 |
| 4 | Action | Quarterly linearity/cga | 4 | 100.00 |

# Invalid Data Report

## CT1 - Stack NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:17 **Location:** Maxwell, CA

**Tag Name:** CT1_NOx_LbPerHr_1H

**Total Operating Time:** 1,178.00 Hour(s)
Non-Operating Time: 982.00 Hour(s) Report Time: 2,160.00 Hour(s)

| Inc No | Start Time | End Time | Duration in Hour(s) | Reason Code - Description | Action Code - Description |
|---|---|---|---|---|---|
| 1 | 02/25/2014 10:00 | 02/25/2014 13:59 | 4 | 3 - Quality assurance calibration | 4 - Quarterly linearity/cga |

| | |
|---|---|
| Total Operating Time: | 1,178.00 Hour(s) |
| Total Monitor Downtime (Online only): | 4.00 Hour(s) |
| Percent Monitor Availability: | 99.66 % |
| Percent Monitor Downtime: | 0.34 % |

| Report Code | Type | Text | Duration | Duration Percent |
|---|---|---|---|---|
| 3 | Reason | Quality assurance calibration | 4 | 100.00 |
| 4 | Action | Quarterly linearity/cga | 4 | 100.00 |

# Invalid Data Report

## CT2 - Stack CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:17 **Location:** Maxwell, CA

**Tag Name:** CT2_CO_LbPerHr_1H

**Total Operating Time:** 1,193.00 Hour(s)
Non-Operating Time: 967.00 Hour(s) Report Time: 2,160.00 Hour(s)

| Inc No | Start Time | End Time | Duration in Hour(s) | Reason Code - Description | Action Code - Description |
|---|---|---|---|---|---|
| 1 | 02/26/2014 10:00 | 02/26/2014 13:59 | 4 | 3 - Quality assurance calibration | 4 - Quarterly linearity/cga |

| | |
|---|---|
| Total Operating Time: | 1,193.00 Hour(s) |
| Total Monitor Downtime (Online only): | 4.00 Hour(s) |
| Percent Monitor Availability: | 99.66 % |
| Percent Monitor Downtime: | 0.34 % |

| Report Code | Type | Text | Duration | Duration Percent |
|---|---|---|---|---|
| 3 | Reason | Quality assurance calibration | 4 | 100.00 |
| 4 | Action | Quarterly linearity/cga | 4 | 100.00 |

# Invalid Data Report

## CT2 - Stack NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/23/2014 07:17 **Location:** Maxwell, CA

**Tag Name:** CT2_NOx_LbPerHr_1H

**Total Operating Time:** 1,193.00 Hour(s)

Non-Operating Time: 967.00 Hour(s) Report Time: 2,160.00 Hour(s)

| Inc No | Start Time | End Time | Duration in Hour(s) | Reason Code - Description | Action Code - Description |
|---|---|---|---|---|---|
| 1 | 02/26/2014 10:00 | 02/26/2014 13:59 | 4 | 3 - Quality assurance calibration | 4 - Quarterly linearity/cga |
| 2 | 03/11/2014 10:00 | 03/11/2014 12:59 | 3 | 9 - CEMS failed calibration | 3 - Performed manual calibration |

| | |
|---|---|
| Total Operating Time: | 1,193.00 Hour(s) |
| Total Monitor Downtime (Online only): | 7.00 Hour(s) |
| Percent Monitor Availability: | 99.41 % |
| Percent Monitor Downtime: | 0.59 % |

| Report Code | Type | Text | Duration | Duration Percent |
|---|---|---|---|---|
| 3 | Reason | Quality assurance calibration | 4 | 57.14 |
| 9 | Reason | CEMS failed calibration | 3 | 42.86 |
| 3 | Action | Performed manual calibration | 3 | 42.86 |
| 4 | Action | Quarterly linearity/cga | 4 | 57.14 |

# ATTACHMENT 5
## Hourly Emissions VOC (AQ-14)

Pursuant to the CEC conditions of certification, AQ-14 requires that a correlation be developed between emissions of CO and VOC in order to predict ongoing compliance with the VOC limits.

AQ-14 reads as follows:

**AQ-14** The CTGs shall meet a VOC limit of 2.0 ppmvd with duct burner firing and 1.38 ppmvd without duct burner firing @ 15% O2 averaged over one hour. Maximum hourly steady state emission limits for each CTG are:

Pounds VOC with Duct Firing Pounds: 7.2

VOC without Duct Firing: 3.4

**Verification:** The project owner shall submit to the CPM and APCO CTG source test emissions data demonstrating compliance with this condition as required by condition **AQ-8** and shall provide operating data that establishes ongoing compliance with this condition using a determined relationship with CO emissions, previously approved by the CPM and APCO using source test data, as part of the Quarterly Operation Reports (**AQ-22**).

Analysis

Data derived from the December 2011 source tests were used to establish the initial correlation between CO and VOC. The 2011 tests were conducted by The Avogadro Group with concurrent testing for CO and VOC conducted on the following dates for the following load scenarios:

- Unit 1 – Baseload w/o duct burners – 11/8/11 (3 test runs)
- Unit 2 - Baseload w/o duct burners – 11/9/11 (3 test runs)
- Unit 1 – Maximum load w/duct burners – 11/11/11 (3 test runs)
- Unit 2 - Maximum load w/duct burners – 11/12/11 (3 test runs)

The summary test results for the above noted concurrent CO and VOC tests are presented in the 2011 test report at Tables 6-5, 6-6, 6-7, and 6-9. The correlation of CO versus VOC data was prepared using the six (6) test data sets for each load scenario, i.e., six values used for baseload w/o duct burners, and six values used for maximum load w/duct burners. The attached spreadsheet shows the data plots for each load scenario as well as the regression analysis for each data set.

As can be seen from the spreadsheet analysis, the correlation for both scenarios is not very robust, with the maximum load with duct burners giving the best correlation. The spreadsheet presents the predicted VOC calculations for a range of CO values, with the resultant VOC mass emissions based on a linear ratio from the average test data. It should be noted that due to the correlation equations, as CO increases the VOC decreases and begins to show “non-real” values. This is due to the small sample size for both scenarios.

**Colusa GS Test Data for CO and VOC**

| | Date | Times | VOC, ppm | CO, ppm | |
|---|---|---|---|---|---|
| Unit 1 | 11/8/2011 | 0900-0930 | 0.57 | 0.18 | |
| | | 1009-1030 | 0.25 | 0.23 | w/o DB |
| | | 1431-1501 | 0.25 | 0.49 | |
| | 11/11/2011 | 1150-1220 | 0.43 | 0.17 | |
| | | 1226-1256 | 0.42 | 0.19 | w DB |
| | | 1304-1334 | 0.21 | 0.3 | |
| Unit 2 | 11/9/2011 | 0905-0935 | 0.19 | 0.5 | |
| | | 0938-1008 | 0.19 | 0.46 | w/o DB |
| | | 1018-1048 | 0.29 | 0.47 | |
| | 11/12/2011 | 0850-0910 | 0.24 | 0.34 | |
| | | 0930-1000 | 0.2 | 0.31 | w DB |
| | | 1015-1045 | 0.15 | 0.35 | |

| Permit Limits | VOC, ppm | CO, ppm |
|---|---|---|
| w/o DB | 1.38 | 3 |
| w DB | 2 | 3 |

| w/o DB | | w DB | |
|---|---|---|---|
| VOC | CO | VOC | CO |
| 0.57 | 0.18 | 0.43 | 0.17 |
| 0.25 | 0.23 | 0.42 | 0.19 |
| 0.25 | 0.49 | 0.21 | 0.3 |
| 0.19 | 0.5 | 0.24 | 0.34 |
| 0.19 | 0.46 | 0.2 | 0.31 |
| 0.29 | 0.47 | 0.15 | 0.35 |

all ppm values are dry at 15% O2
Data from Avogadro Test dated December 2011
CO and VOC data concurrent tests, see test report tables 6-5, 6-6, 6-7, and 6-9.

Without DB




With DB



## SUMMARY OUTPUT - without DB

| *Regression Statistics* | |
|---|---|
| Multiple R | 0.726995721 |
| R Square | 0.528522779 |
| Adjusted R Squ | 0.410653473 |
| Standard Error | 0.109432726 |
| Observations | 6 |

Eq for predicting VOC based on CO:
VOC, ppm = (CO,ppm * -0.7217) + 0.5703

ANOVA

| | *df* | *SS* | *MS* | *F* | *Significance F* |
|---|---|---|---|---|---|
| Regression | 1 | 0.053697914 | 0.053697914 | 4.483972966 | 0.101623317 |
| Residual | 4 | 0.047902086 | 0.011975521 | | |
| Total | 5 | 0.1016 | | | |

| | *Coefficients* | *Standard Error* | *t Stat* | *P-value* | *Lower 95%* | *Upper 95%* | *Lower 95.0%* | *Upper 95.0%* |
|---|---|---|---|---|---|---|---|---|
| Intercept | 0.570278092 | 0.139696681 | 4.082259434 | 0.015070461 | 0.182417927 | 0.958138257 | 0.182417927 | 0.958138257 |
| X Variable 1 | -0.72174616 | 0.340841909 | -2.117539366 | 0.101623317 | -1.66807501 | 0.22458269 | -1.66807501 | 0.22458269 |

## SUMMARY OUTPUT -with DB

| *Regression Statistics* | |
|---|---|
| Multiple R | 0.960221702 |
| R Square | 0.922025717 |
| Adjusted R Squ | 0.902532147 |
| Standard Error | 0.037398713 |
| Observations | 6 |

Eq for predicting VOC based on CO:
VOC, ppm = (CO, ppm * -1.4866) + 0.6863

ANOVA

| | *df* | *SS* | *MS* | *F* | *Significance F* |
|---|---|---|---|---|---|
| Regression | 1 | 0.066155345 | 0.066155345 | 47.29896497 | 0.002341999 |
| Residual | 4 | 0.005594655 | 0.001398664 | | |
| Total | 5 | 0.07175 | | | |

| | *Coefficients* | *Standard Error* | *t Stat* | *P-value* | *Lower 95%* | *Upper 95%* | *Lower 95.0%* | *Upper 95.0%* |
|---|---|---|---|---|---|---|---|---|
| Intercept | 0.686302895 | 0.061722955 | 11.11908683 | 0.000372231 | 0.514932499 | 0.857673291 | 0.514932499 | 0.857673291 |
| X Variable 1 | -1.486636971 | 0.216161881 | -6.877424298 | 0.002341999 | -2.086798567 | -0.886475375 | -2.086798567 | -0.886475375 |

**Emissions Prediction-Range of Results based on Correlations**

Baseload w/o duct burners

Avg VOC ppm at 15% O2 = 0.29

Avg VOC lb/hr = 0.683

| CO Range Range | Predicted VOC, ppm | Predicted VOC, lb/hr | |
|---|---|---|---|
| 0.1 | 0.50 | 1.17 | |
| 0.2 | 0.43 | 1.00 | |
| 0.3 | 0.35 | 0.83 | |
| 0.4 | 0.28 | 0.66 | |
| 0.5 | 0.21 | 0.49 | |
| 0.6 | 0.14 | 0.32 | |
| 0.7 | 0.07 | 0.15 | |
| 0.8 | -0.01 | -0.02 | |
| 0.9 | -0.08 | -0.19 | Non-real |
| 1 | -0.15 | -0.36 | values |

Maximum load w/duct burners

Avg VOC ppm at 15% O2 = 0.275

Avg VOC lb/hr = 0.823

| CO Range Range | Predicted VOC, ppm | Predicted VOC, lb/hr | |
|---|---|---|---|
| 0.1 | 0.54 | 1.61 | |
| 0.2 | 0.39 | 1.16 | |
| 0.3 | 0.24 | 0.72 | |
| 0.4 | 0.09 | 0.27 | |
| 0.5 | -0.06 | -0.17 | |
| 0.6 | -0.21 | -0.62 | |
| 0.7 | -0.35 | -1.06 | |
| 0.8 | -0.50 | -1.51 | Non-real |
| 0.9 | -0.65 | -1.95 | Values |
| 1 | -0.80 | -2.40 | |

# Excess Emission Report

## CT1 - VOC Ppmvdc 1-Hour Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT1_VOC_Ppmvdc_1H
**Total Operating Time:** 1,157.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,003.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,157.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT1 - VOC LbPerHr 1-Hour Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT1_VOC_LbPerHr_1H
**Total Operating Time:** 1,157.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,003.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,157.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT1 - VOC Lb 1-Day Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT1_VOC_Lb_1D
**Total Operating Time:** 52.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 38.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 52.00 Day(s) |
| Total Duration (Online only): | 0.00 Day(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT2 - VOC Ppmvdc 1-Hour Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT2_VOC_Ppmvdc_1H
**Total Operating Time:** 1,168.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 992.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,168.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT2 - VOC LbPerHr 1-Hour Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT2_VOC_LbPerHr_1H
**Total Operating Time:** 1,168.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 992.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,168.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT2 -VOC Lb 1-Day Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT2_VOC_Lb_1D
**Total Operating Time:** 54.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 36.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 54.00 Day(s) |
| Total Duration (Online only): | 0.00 Day(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Daily Summary Report

## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/01/2014 00:00 | 0.4 | 13.9 | 1,626.5 | 0.4 | 1.1 | 1 | 1 | 0 |
| 01/01/2014 01:00 | 0.4 | 13.8 | 1,814.0 | 0.4 | 1.3 | 1 | 1 | 0 |
| 01/01/2014 02:00 | 0.4 | 13.8 | 1,691.3 | 0.4 | 1.2 | 1 | 1 | 0 |
| 01/01/2014 03:00 | 0.0 | 14.7 | 1,099.9 | 0.0 | 0.8 | 1 | 0 | 0 |
| 01/01/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 16:00 | 0.0 | 17.5 | 499.0 | 0.0 | 0.3 | 1 | 0 | 0 |
| 01/01/2014 17:00 | 0.0 | 14.9 | 1,054.7 | 0.0 | 0.7 | 1 | 0 | 0 |
| 01/01/2014 18:00 | 0.1 | 13.7 | 1,768.1 | 0.2 | 1.2 | 1 | 1 | 1 |
| 01/01/2014 19:00 | -0.9 | 12.7 | 2,052.6 | -0.5 | 1.4 | 1 | 1 | 1 |
| 01/01/2014 20:00 | -0.8 | 12.2 | 2,131.8 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/01/2014 21:00 | -0.8 | 12.2 | 2,153.2 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/01/2014 22:00 | -0.8 | 12.6 | 2,063.6 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/01/2014 23:00 | -0.8 | 12.6 | 2,066.6 | -0.4 | 1.4 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.2 | 13.7 | 1,668.4 | -0.1 | 1.2 | 12 # | 9 # | 6 # |
| **Minimum:** | -0.9 | 12.2 | 499.0 | -0.5 | 0.3 | 0 | 0 | 0 |
| **Maximum:** | 0.4 | 17.5 | 2,153.2 | 0.4 | 1.5 | 1 | 1 | 1 |
| **%SI** | 50.0 | 50.0 | 50.0 | 50.0 | 50.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/02/2014 00:00 | -0.8 | 12.7 | 2,043.6 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/02/2014 01:00 | -0.1 | 13.5 | 1,838.8 | 0.1 | 1.3 | 1 | 1 | 1 |
| 01/02/2014 02:00 | 0.4 | 13.8 | 1,587.3 | 0.4 | 1.1 | 1 | 1 | 0 |
| 01/02/2014 03:00 | 0.4 | 13.8 | 1,712.8 | 0.4 | 1.2 | 1 | 1 | 0 |
| 01/02/2014 04:00 | 0.4 | 13.8 | 1,592.0 | 0.4 | 1.1 | 1 | 1 | 0 |
| 01/02/2014 05:00 | -0.2 | 13.5 | 1,800.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 01/02/2014 06:00 | -0.7 | 13.0 | 1,980.8 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/02/2014 07:00 | -0.7 | 13.0 | 1,973.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/02/2014 08:00 | -0.8 | 12.9 | 2,008.7 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/02/2014 09:00 | -0.8 | 12.9 | 2,020.3 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/02/2014 10:00 | -0.8 | 12.9 | 2,013.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/02/2014 11:00 | -0.8 | 12.8 | 2,012.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/02/2014 12:00 | -0.8 | 12.8 | 2,001.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/02/2014 13:00 | -0.8 | 12.8 | 1,991.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/02/2014 14:00 | -0.7 | 13.0 | 1,956.5 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/02/2014 15:00 | -0.8 | 12.8 | 1,989.5 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/02/2014 16:00 | -0.8 | 12.7 | 2,006.8 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/02/2014 17:00 | -0.8 | 12.6 | 2,016.2 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/02/2014 18:00 | -0.8 | 12.2 | 2,114.0 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/02/2014 19:00 | -0.7 | 12.1 | 2,137.2 | -0.2 | 1.5 | 1 | 1 | 1 |
| 01/02/2014 20:00 | -0.8 | 12.2 | 2,117.0 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/02/2014 21:00 | -0.8 | 12.3 | 2,106.4 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/02/2014 22:00 | -0.8 | 12.6 | 2,055.8 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/02/2014 23:00 | -0.8 | 12.3 | 2,116.9 | -0.4 | 1.5 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.6 | 12.9 | 1,966.3 | -0.3 | 1.4 | 24 # | 24 # | 21 # |
| **Minimum:** | -0.8 | 12.1 | 1,587.3 | -0.4 | 1.1 | 1 | 1 | 0 |
| **Maximum:** | 0.4 | 13.8 | 2,137.2 | 0.4 | 1.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/03/2014 00:00 | -0.7 | 12.8 | 2,008.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/03/2014 01:00 | 0.1 | 13.6 | 1,747.2 | 0.2 | 1.2 | 1 | 1 | 1 |
| 01/03/2014 02:00 | 0.4 | 13.9 | 1,318.6 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/03/2014 03:00 | 0.4 | 13.9 | 1,243.4 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/03/2014 04:00 | 0.4 | 13.9 | 1,244.0 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/03/2014 05:00 | 0.3 | 13.9 | 1,246.6 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/03/2014 06:00 | -0.1 | 13.6 | 1,548.9 | 0.1 | 1.1 | 1 | 1 | 1 |
| 01/03/2014 07:00 | -0.5 | 13.2 | 1,896.9 | -0.2 | 1.3 | 1 | 1 | 1 |
| 01/03/2014 08:00 | -0.5 | 13.1 | 1,979.6 | -0.2 | 1.4 | 1 | 1 | 1 |
| 01/03/2014 09:00 | -0.8 | 12.9 | 2,027.5 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/03/2014 10:00 | -0.8 | 12.8 | 2,027.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/03/2014 11:00 | -0.8 | 12.8 | 2,016.2 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/03/2014 12:00 | -0.7 | 12.9 | 1,988.3 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/03/2014 13:00 | -0.7 | 12.9 | 1,975.7 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/03/2014 14:00 | -0.7 | 13.0 | 1,964.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/03/2014 15:00 | -0.5 | 13.1 | 1,934.6 | -0.2 | 1.4 | 1 | 1 | 1 |
| 01/03/2014 16:00 | -0.8 | 12.9 | 1,985.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/03/2014 17:00 | -0.9 | 12.5 | 2,047.8 | -0.5 | 1.4 | 1 | 1 | 1 |
| 01/03/2014 18:00 | -0.8 | 12.2 | 2,131.4 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/03/2014 19:00 | -0.8 | 12.3 | 2,088.7 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/03/2014 20:00 | -0.8 | 12.4 | 2,088.1 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/03/2014 21:00 | -0.5 | 11.7 | 2,219.5 | -0.1 | 1.6 | 1 | 1 | 1 |
| 01/03/2014 22:00 | -0.7 | 11.9 | 2,181.5 | -0.2 | 1.5 | 1 | 1 | 1 |
| 01/03/2014 23:00 | -0.8 | 12.2 | 2,135.6 | -0.4 | 1.5 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.5 | 12.9 | 1,876.9 | -0.2 | 1.3 | 24 # | 24 # | 20 # |
| **Minimum:** | -0.9 | 11.7 | 1,243.4 | -0.5 | 0.9 | 1 | 1 | 0 |
| **Maximum:** | 0.4 | 13.9 | 2,219.5 | 0.4 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/04/2014 00:00 | -0.8 | 12.7 | 2,043.9 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/04/2014 01:00 | -0.8 | 12.6 | 2,065.5 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/04/2014 02:00 | 0.2 | 13.8 | 1,623.6 | 0.4 | 1.1 | 1 | 1 | 1 |
| 01/04/2014 03:00 | 0.4 | 13.8 | 1,596.0 | 0.4 | 1.1 | 1 | 1 | 0 |
| 01/04/2014 04:00 | 0.4 | 13.9 | 1,424.1 | 0.4 | 1.0 | 1 | 1 | 0 |
| 01/04/2014 05:00 | 0.4 | 13.8 | 1,654.2 | 0.4 | 1.2 | 1 | 1 | 0 |
| 01/04/2014 06:00 | 0.4 | 13.8 | 1,672.6 | 0.4 | 1.2 | 1 | 1 | 0 |
| 01/04/2014 07:00 | 0.4 | 13.7 | 1,825.6 | 0.4 | 1.3 | 1 | 1 | 0 |
| 01/04/2014 08:00 | -0.4 | 13.2 | 1,905.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 01/04/2014 09:00 | -1.1 | 12.4 | 2,103.5 | -0.5 | 1.5 | 1 | 1 | 1 |
| 01/04/2014 10:00 | -0.9 | 12.7 | 2,033.4 | -0.5 | 1.4 | 1 | 1 | 1 |
| 01/04/2014 11:00 | -0.7 | 12.9 | 1,972.8 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/04/2014 12:00 | -0.2 | 13.3 | 1,901.9 | -0.1 | 1.3 | 1 | 1 | 1 |
| 01/04/2014 13:00 | -0.2 | 13.5 | 1,856.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 01/04/2014 14:00 | -0.7 | 13.0 | 1,976.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/04/2014 15:00 | -0.8 | 12.7 | 2,017.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/04/2014 16:00 | -0.8 | 12.6 | 2,039.2 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/04/2014 17:00 | -0.8 | 12.5 | 2,081.3 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/04/2014 18:00 | -0.8 | 12.2 | 2,136.7 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/04/2014 19:00 | -0.7 | 12.2 | 2,139.0 | -0.2 | 1.5 | 1 | 1 | 1 |
| 01/04/2014 20:00 | -0.8 | 12.7 | 2,046.9 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/04/2014 21:00 | -0.7 | 11.9 | 2,198.9 | -0.2 | 1.5 | 1 | 1 | 1 |
| 01/04/2014 22:00 | -0.5 | 11.8 | 2,217.8 | -0.1 | 1.6 | 1 | 1 | 1 |
| 01/04/2014 23:00 | -0.7 | 12.6 | 2,043.8 | -0.2 | 1.4 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.4 | 12.9 | 1,940.6 | -0.1 | 1.4 | 24 # | 24 # | 19 # |
| **Minimum:** | -1.1 | 11.8 | 1,424.1 | -0.5 | 1.0 | 1 | 1 | 0 |
| **Maximum:** | 0.4 | 13.9 | 2,217.8 | 0.4 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/05/2014 00:00 | -0.7 | 12.8 | 2,026.9 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/05/2014 01:00 | -0.8 | 12.5 | 2,066.8 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/05/2014 02:00 | 0.2 | 13.8 | 1,616.1 | 0.4 | 1.1 | 1 | 1 | 1 |
| 01/05/2014 03:00 | 0.4 | 13.9 | 1,596.8 | 0.4 | 1.1 | 1 | 1 | 0 |
| 01/05/2014 04:00 | 0.4 | 13.9 | 1,699.9 | 0.4 | 1.2 | 1 | 1 | 0 |
| 01/05/2014 05:00 | 0.4 | 13.8 | 1,827.2 | 0.4 | 1.3 | 1 | 1 | 0 |
| 01/05/2014 06:00 | -0.4 | 13.3 | 1,894.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 01/05/2014 07:00 | -0.9 | 12.4 | 2,089.7 | -0.5 | 1.5 | 1 | 1 | 1 |
| 01/05/2014 08:00 | -0.7 | 11.8 | 2,237.4 | -0.2 | 1.6 | 1 | 1 | 1 |
| 01/05/2014 09:00 | -0.7 | 12.0 | 2,192.0 | -0.2 | 1.5 | 1 | 1 | 1 |
| 01/05/2014 10:00 | -0.8 | 12.6 | 2,055.9 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/05/2014 11:00 | -0.5 | 12.9 | 1,981.7 | -0.2 | 1.4 | 1 | 1 | 1 |
| 01/05/2014 12:00 | -0.2 | 13.3 | 1,906.1 | -0.1 | 1.3 | 1 | 1 | 1 |
| 01/05/2014 13:00 | -0.4 | 13.2 | 1,942.3 | -0.1 | 1.4 | 1 | 1 | 1 |
| 01/05/2014 14:00 | -0.8 | 12.8 | 2,006.5 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/05/2014 15:00 | 0.2 | 13.9 | 1,633.4 | 0.2 | 1.1 | 1 | 1 | 1 |
| 01/05/2014 16:00 | -0.4 | 13.2 | 1,879.9 | -0.1 | 1.3 | 1 | 1 | 1 |
| 01/05/2014 17:00 | -0.7 | 12.0 | 2,170.6 | -0.2 | 1.5 | 1 | 1 | 1 |
| 01/05/2014 18:00 | -0.5 | 11.8 | 2,213.3 | -0.1 | 1.5 | 1 | 1 | 1 |
| 01/05/2014 19:00 | -0.5 | 11.8 | 2,214.0 | -0.1 | 1.5 | 1 | 1 | 1 |
| 01/05/2014 20:00 | -0.5 | 11.7 | 2,224.4 | -0.1 | 1.6 | 1 | 1 | 1 |
| 01/05/2014 21:00 | -0.5 | 11.8 | 2,217.5 | -0.1 | 1.6 | 1 | 1 | 1 |
| 01/05/2014 22:00 | -0.5 | 11.8 | 2,227.7 | -0.1 | 1.6 | 1 | 1 | 1 |
| 01/05/2014 23:00 | -0.7 | 12.1 | 2,171.6 | -0.2 | 1.5 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.4 | 12.7 | 2,003.8 | -0.1 | 1.4 | 24 # | 24 # | 21 # |
| **Minimum:** | -0.9 | 11.7 | 1,596.8 | -0.5 | 1.1 | 1 | 1 | 0 |
| **Maximum:** | 0.4 | 13.9 | 2,237.4 | 0.4 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/06/2014 00:00 | -0.8 | 12.2 | 2,162.5 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/06/2014 01:00 | -0.8 | 12.5 | 2,088.4 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/06/2014 02:00 | -0.8 | 12.3 | 2,124.7 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/06/2014 03:00 | -0.7 | 12.9 | 2,009.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/06/2014 04:00 | -0.5 | 13.0 | 1,999.4 | -0.2 | 1.4 | 1 | 1 | 1 |
| 01/06/2014 05:00 | -0.8 | 12.2 | 2,157.5 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/06/2014 06:00 | -0.8 | 12.6 | 2,063.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/06/2014 07:00 | -0.8 | 12.7 | 2,032.9 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/06/2014 08:00 | -0.8 | 12.3 | 2,147.7 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/06/2014 09:00 | -0.9 | 12.5 | 2,116.1 | -0.5 | 1.5 | 1 | 1 | 1 |
| 01/06/2014 10:00 | -0.9 | 12.3 | 2,149.0 | -0.5 | 1.5 | 1 | 1 | 1 |
| 01/06/2014 11:00 | -0.8 | 12.0 | 2,191.9 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/06/2014 12:00 | -0.7 | 12.0 | 2,202.6 | -0.2 | 1.5 | 1 | 1 | 1 |
| 01/06/2014 13:00 | -0.7 | 11.9 | 2,215.1 | -0.2 | 1.6 | 1 | 1 | 1 |
| 01/06/2014 14:00 | -0.7 | 12.3 | 2,118.5 | -0.2 | 1.5 | 1 | 1 | 1 |
| 01/06/2014 15:00 | -0.7 | 12.9 | 2,002.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/06/2014 16:00 | -0.7 | 12.8 | 2,015.5 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/06/2014 17:00 | -0.9 | 12.6 | 2,072.7 | -0.5 | 1.5 | 1 | 1 | 1 |
| 01/06/2014 18:00 | -0.8 | 12.5 | 2,089.5 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/06/2014 19:00 | -0.7 | 11.9 | 2,219.6 | -0.2 | 1.6 | 1 | 1 | 1 |
| 01/06/2014 20:00 | -0.8 | 12.4 | 2,106.4 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/06/2014 21:00 | -0.7 | 11.9 | 2,236.4 | -0.2 | 1.6 | 1 | 1 | 1 |
| 01/06/2014 22:00 | -0.7 | 11.8 | 2,246.7 | -0.2 | 1.6 | 1 | 1 | 1 |
| 01/06/2014 23:00 | -0.8 | 12.4 | 2,107.4 | -0.4 | 1.5 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.8 | 12.4 | 2,119.8 | -0.4 | 1.5 | 24 # | 24 # | 24 # |
| **Minimum:** | -0.9 | 11.8 | 1,999.4 | -0.5 | 1.4 | 1 | 1 | 1 |
| **Maximum:** | -0.5 | 13.0 | 2,246.7 | -0.2 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/07/2014 00:00 | -0.5 | 13.1 | 1,956.6 | -0.2 | 1.4 | 1 | 1 | 1 |
| 01/07/2014 01:00 | -0.1 | 13.4 | 1,746.2 | 0.1 | 1.2 | 1 | 1 | 1 |
| 01/07/2014 02:00 | 0.4 | 13.9 | 1,487.7 | 0.4 | 1.0 | 1 | 1 | 0 |
| 01/07/2014 03:00 | 0.4 | 13.8 | 1,592.1 | 0.4 | 1.1 | 1 | 1 | 0 |
| 01/07/2014 04:00 | 0.4 | 13.9 | 1,579.1 | 0.4 | 1.1 | 1 | 1 | 0 |
| 01/07/2014 05:00 | 0.4 | 13.9 | 1,595.7 | 0.4 | 1.1 | 1 | 1 | 0 |
| 01/07/2014 06:00 | -0.1 | 13.5 | 1,788.2 | 0.1 | 1.3 | 1 | 1 | 1 |
| 01/07/2014 07:00 | -0.7 | 12.9 | 1,998.5 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/07/2014 08:00 | -0.8 | 12.4 | 2,138.8 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/07/2014 09:00 | -0.8 | 12.4 | 2,129.8 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/07/2014 10:00 | -0.8 | 12.7 | 2,065.3 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/07/2014 11:00 | -0.8 | 12.8 | 2,039.9 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/07/2014 12:00 | -0.8 | 12.0 | 2,213.6 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/07/2014 13:00 | -0.8 | 11.9 | 2,207.8 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/07/2014 14:00 | -0.9 | 12.6 | 2,061.0 | -0.5 | 1.4 | 1 | 1 | 1 |
| 01/07/2014 15:00 | -0.9 | 12.5 | 2,074.1 | -0.5 | 1.5 | 1 | 1 | 1 |
| 01/07/2014 16:00 | -0.7 | 13.0 | 1,981.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/07/2014 17:00 | -0.7 | 13.0 | 1,982.6 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/07/2014 18:00 | -0.9 | 12.7 | 2,035.4 | -0.5 | 1.4 | 1 | 1 | 1 |
| 01/07/2014 19:00 | -0.9 | 12.1 | 2,172.2 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/07/2014 20:00 | -0.7 | 11.8 | 2,221.0 | -0.2 | 1.6 | 1 | 1 | 1 |
| 01/07/2014 21:00 | -0.8 | 12.6 | 2,061.3 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/07/2014 22:00 | -0.8 | 12.8 | 2,036.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/07/2014 23:00 | -0.4 | 13.2 | 1,875.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.5 | 12.9 | 1,960.0 | -0.2 | 1.4 | 24 # | 24 # | 20 # |
| **Minimum:** | -0.9 | 11.8 | 1,487.7 | -0.5 | 1.0 | 1 | 1 | 0 |
| **Maximum:** | 0.4 | 13.9 | 2,221.0 | 0.4 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/08/2014 00:00 | 0.4 | 13.9 | 1,360.2 | 0.4 | 1.0 | 1 | 1 | 0 |
| 01/08/2014 01:00 | 0.4 | 13.9 | 1,310.4 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/08/2014 02:00 | 0.4 | 13.9 | 1,284.3 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/08/2014 03:00 | 0.3 | 13.9 | 1,260.1 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/08/2014 04:00 | 0.3 | 13.9 | 1,293.2 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/08/2014 05:00 | 0.3 | 13.8 | 1,632.4 | 0.4 | 1.1 | 1 | 1 | 0 |
| 01/08/2014 06:00 | -0.1 | 13.6 | 1,700.8 | 0.1 | 1.2 | 1 | 1 | 1 |
| 01/08/2014 07:00 | -0.4 | 13.3 | 1,919.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 01/08/2014 08:00 | -0.5 | 13.0 | 1,994.2 | -0.2 | 1.4 | 1 | 1 | 1 |
| 01/08/2014 09:00 | -0.1 | 13.6 | 1,761.9 | 0.1 | 1.2 | 1 | 1 | 1 |
| 01/08/2014 10:00 | 0.3 | 13.9 | 1,237.5 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/08/2014 11:00 | 0.3 | 13.9 | 1,378.5 | 0.4 | 1.0 | 1 | 1 | 0 |
| 01/08/2014 12:00 | 0.4 | 13.7 | 1,703.6 | 0.4 | 1.2 | 1 | 1 | 0 |
| 01/08/2014 13:00 | 0.4 | 13.9 | 1,480.3 | 0.4 | 1.0 | 1 | 1 | 0 |
| 01/08/2014 14:00 | 0.4 | 13.9 | 1,254.4 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/08/2014 15:00 | 0.4 | 13.9 | 1,400.6 | 0.4 | 1.0 | 1 | 1 | 0 |
| 01/08/2014 16:00 | 0.4 | 13.9 | 1,525.8 | 0.4 | 1.1 | 1 | 1 | 0 |
| 01/08/2014 17:00 | -0.5 | 13.4 | 1,807.0 | -0.2 | 1.3 | 1 | 1 | 1 |
| 01/08/2014 18:00 | 0.4 | 13.9 | 1,432.1 | 0.4 | 1.0 | 1 | 1 | 0 |
| 01/08/2014 19:00 | 0.4 | 13.8 | 1,530.1 | 0.4 | 1.1 | 1 | 1 | 0 |
| 01/08/2014 20:00 | 0.4 | 13.9 | 1,485.5 | 0.4 | 1.0 | 1 | 1 | 0 |
| 01/08/2014 21:00 | 0.4 | 13.9 | 1,488.5 | 0.4 | 1.0 | 1 | 1 | 0 |
| 01/08/2014 22:00 | 0.0 | 15.4 | 726.3 | 0.0 | 0.5 | 1 | 0 | 0 |
| 01/08/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.2 | 13.8 | 1,476.8 | 0.3 | 1.0 | 23 # | 22 # | 5 # |
| **Minimum:** | -0.5 | 13.0 | 726.3 | -0.2 | 0.5 | 0 | 0 | 0 |
| **Maximum:** | 0.4 | 15.4 | 1,994.2 | 0.4 | 1.4 | 1 | 1 | 1 |
| **%SI** | 4.2 | 4.2 | 4.2 | 4.2 | 4.2 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/09/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/10/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/12/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/13/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/14/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/15/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 14:00 | 0.0 | 17.4 | 529.1 | 0.0 | 0.4 | 1 | 0 | 0 |
| 01/29/2014 15:00 | 0.0 | 15.8 | 760.9 | 0.0 | 0.5 | 1 | 0 | 0 |
| 01/29/2014 16:00 | 0.0 | 13.9 | 1,323.7 | 0.0 | 0.9 | 1 | 0 | 0 |
| 01/29/2014 17:00 | 0.4 | 13.8 | 1,541.8 | 0.4 | 1.1 | 1 | 1 | 0 |
| 01/29/2014 18:00 | 0.4 | 13.7 | 1,819.4 | 0.4 | 1.3 | 1 | 1 | 0 |
| 01/29/2014 19:00 | 0.4 | 13.7 | 1,819.3 | 0.4 | 1.3 | 1 | 1 | 0 |
| 01/29/2014 20:00 | 0.4 | 13.8 | 1,752.4 | 0.4 | 1.2 | 1 | 1 | 0 |
| 01/29/2014 21:00 | 0.4 | 13.8 | 1,806.5 | 0.4 | 1.3 | 1 | 1 | 0 |
| 01/29/2014 22:00 | 0.4 | 13.8 | 1,667.6 | 0.4 | 1.2 | 1 | 1 | 0 |
| 01/29/2014 23:00 | 0.3 | 13.9 | 1,291.9 | 0.4 | 0.9 | 1 | 1 | 0 |
| **Average/Sum#:** | 0.3 | 14.4 | 1,431.3 | 0.3 | 1.0 | 10 # | 7 # | 0 # |
| **Minimum:** | 0.0 | 13.7 | 529.1 | 0.0 | 0.4 | 0 | 0 | 0 |
| **Maximum:** | 0.4 | 17.4 | 1,819.4 | 0.4 | 1.3 | 1 | 1 | 0 |
| **%SI** | 58.3 | 58.3 | 58.3 | 58.3 | 58.3 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/30/2014 00:00 | 0.3 | 13.9 | 1,463.8 | 0.4 | 1.0 | 1 | 1 | 0 |
| 01/30/2014 01:00 | 0.3 | 13.8 | 1,752.9 | 0.4 | 1.2 | 1 | 1 | 0 |
| 01/30/2014 02:00 | 0.3 | 13.9 | 1,327.6 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/30/2014 03:00 | 0.3 | 13.9 | 1,257.1 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/30/2014 04:00 | 0.3 | 13.9 | 1,282.4 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/30/2014 05:00 | 0.3 | 14.0 | 1,254.0 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/30/2014 06:00 | 0.3 | 13.9 | 1,447.9 | 0.4 | 1.0 | 1 | 1 | 0 |
| 01/30/2014 07:00 | 0.3 | 14.0 | 1,542.8 | 0.4 | 1.1 | 1 | 1 | 0 |
| 01/30/2014 08:00 | 0.3 | 13.9 | 1,553.6 | 0.4 | 1.1 | 1 | 1 | 0 |
| 01/30/2014 09:00 | 0.3 | 14.0 | 1,242.6 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/30/2014 10:00 | 0.1 | 13.8 | 1,516.0 | 0.2 | 1.1 | 1 | 1 | 1 |
| 01/30/2014 11:00 | 0.1 | 13.8 | 1,804.8 | 0.2 | 1.3 | 1 | 1 | 1 |
| 01/30/2014 12:00 | -0.7 | 13.2 | 1,906.8 | -0.4 | 1.3 | 1 | 1 | 1 |
| 01/30/2014 13:00 | -1.1 | 12.4 | 2,065.3 | -0.5 | 1.4 | 1 | 1 | 1 |
| 01/30/2014 14:00 | -0.8 | 12.0 | 2,168.8 | -0.4 | 1.5 | 1 | 1 | 1 |
| 01/30/2014 15:00 | -0.7 | 11.8 | 2,200.4 | -0.2 | 1.5 | 1 | 1 | 1 |
| 01/30/2014 16:00 | -0.4 | 12.9 | 1,880.9 | -0.1 | 1.3 | 1 | 1 | 1 |
| 01/30/2014 17:00 | 0.2 | 13.9 | 1,571.0 | 0.2 | 1.1 | 1 | 1 | 1 |
| 01/30/2014 18:00 | 0.4 | 13.9 | 1,642.0 | 0.4 | 1.1 | 1 | 1 | 0 |
| 01/30/2014 19:00 | -0.7 | 13.1 | 1,921.0 | -0.4 | 1.3 | 1 | 1 | 1 |
| 01/30/2014 20:00 | -0.9 | 12.5 | 2,045.7 | -0.5 | 1.4 | 1 | 1 | 1 |
| 01/30/2014 21:00 | -0.9 | 12.6 | 2,027.2 | -0.5 | 1.4 | 1 | 1 | 1 |
| 01/30/2014 22:00 | -0.7 | 13.0 | 1,948.7 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/30/2014 23:00 | -0.2 | 13.4 | 1,837.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.1 | 13.4 | 1,694.2 | 0.1 | 1.2 | 24 # | 24 # | 13 # |
| **Minimum:** | -1.1 | 11.8 | 1,242.6 | -0.5 | 0.9 | 1 | 1 | 0 |
| **Maximum:** | 0.4 | 14.0 | 2,200.4 | 0.4 | 1.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/31/2014 00:00 | 0.4 | 13.9 | 1,532.7 | 0.4 | 1.1 | 1 | 1 | 0 |
| 01/31/2014 01:00 | 0.4 | 13.9 | 1,489.3 | 0.4 | 1.0 | 1 | 1 | 0 |
| 01/31/2014 02:00 | 0.4 | 13.9 | 1,620.1 | 0.4 | 1.1 | 1 | 1 | 0 |
| 01/31/2014 03:00 | 0.4 | 14.0 | 1,406.6 | 0.4 | 1.0 | 1 | 1 | 0 |
| 01/31/2014 04:00 | 0.3 | 14.0 | 1,324.5 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/31/2014 05:00 | 0.4 | 13.8 | 1,753.3 | 0.4 | 1.2 | 1 | 1 | 0 |
| 01/31/2014 06:00 | -0.1 | 13.7 | 1,810.4 | 0.1 | 1.3 | 1 | 1 | 1 |
| 01/31/2014 07:00 | 0.4 | 13.8 | 1,823.0 | 0.4 | 1.3 | 1 | 1 | 0 |
| 01/31/2014 08:00 | 0.4 | 13.8 | 1,828.8 | 0.4 | 1.3 | 1 | 1 | 0 |
| 01/31/2014 09:00 | 0.2 | 13.9 | 1,799.9 | 0.2 | 1.3 | 1 | 1 | 1 |
| 01/31/2014 10:00 | -0.1 | 13.8 | 1,813.5 | 0.1 | 1.3 | 1 | 1 | 1 |
| 01/31/2014 11:00 | -0.4 | 13.4 | 1,899.1 | -0.2 | 1.3 | 1 | 1 | 1 |
| 01/31/2014 12:00 | -0.7 | 13.0 | 1,973.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/31/2014 13:00 | -0.7 | 13.0 | 1,976.9 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/31/2014 14:00 | -0.4 | 13.2 | 1,925.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 01/31/2014 15:00 | -0.4 | 13.4 | 1,906.5 | -0.2 | 1.3 | 1 | 1 | 1 |
| 01/31/2014 16:00 | -0.4 | 13.4 | 1,904.1 | -0.2 | 1.3 | 1 | 1 | 1 |
| 01/31/2014 17:00 | -0.4 | 13.3 | 1,923.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 01/31/2014 18:00 | -0.4 | 13.4 | 1,900.1 | -0.2 | 1.3 | 1 | 1 | 1 |
| 01/31/2014 19:00 | -0.9 | 12.7 | 2,054.6 | -0.5 | 1.4 | 1 | 1 | 1 |
| 01/31/2014 20:00 | -0.7 | 12.9 | 1,995.8 | -0.4 | 1.4 | 1 | 1 | 1 |
| 01/31/2014 21:00 | -0.9 | 12.7 | 2,045.1 | -0.5 | 1.4 | 1 | 1 | 1 |
| 01/31/2014 22:00 | -0.9 | 12.4 | 2,114.0 | -0.5 | 1.5 | 1 | 1 | 1 |
| 01/31/2014 23:00 | -0.8 | 12.5 | 2,094.4 | -0.4 | 1.5 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.2 | 13.4 | 1,829.8 | 0.0 | 1.3 | 24 # | 24 # | 16 # |
| **Minimum:** | -0.9 | 12.4 | 1,324.5 | -0.5 | 0.9 | 1 | 1 | 0 |
| **Maximum:** | 0.4 | 14.0 | 2,114.0 | 0.4 | 1.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/01/2014 00:00 | -0.2 | 13.4 | 1,784.0 | -0.1 | 1.2 | 1 | 1 | 1 |
| 02/01/2014 01:00 | 0.4 | 13.9 | 1,621.2 | 0.4 | 1.1 | 1 | 1 | 0 |
| 02/01/2014 02:00 | 0.4 | 13.9 | 1,653.3 | 0.4 | 1.2 | 1 | 1 | 0 |
| 02/01/2014 03:00 | 0.4 | 13.8 | 1,780.3 | 0.4 | 1.2 | 1 | 1 | 0 |
| 02/01/2014 04:00 | 0.4 | 13.9 | 1,462.6 | 0.4 | 1.0 | 1 | 1 | 0 |
| 02/01/2014 05:00 | -0.5 | 13.3 | 1,855.8 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/01/2014 06:00 | -1.1 | 12.0 | 2,210.1 | -0.5 | 1.5 | 1 | 1 | 1 |
| 02/01/2014 07:00 | -0.9 | 12.0 | 2,210.3 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/01/2014 08:00 | -0.9 | 12.3 | 2,157.4 | -0.5 | 1.5 | 1 | 1 | 1 |
| 02/01/2014 09:00 | -0.9 | 12.6 | 2,098.2 | -0.5 | 1.5 | 1 | 1 | 1 |
| 02/01/2014 10:00 | -0.2 | 13.5 | 1,829.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/01/2014 11:00 | 0.4 | 13.9 | 1,561.8 | 0.4 | 1.1 | 1 | 1 | 0 |
| 02/01/2014 12:00 | 0.4 | 13.9 | 1,539.0 | 0.4 | 1.1 | 1 | 1 | 0 |
| 02/01/2014 13:00 | 0.4 | 13.9 | 1,588.2 | 0.4 | 1.1 | 1 | 1 | 0 |
| 02/01/2014 14:00 | 0.4 | 14.0 | 1,441.6 | 0.4 | 1.0 | 1 | 1 | 0 |
| 02/01/2014 15:00 | 0.4 | 14.0 | 1,256.1 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/01/2014 16:00 | 0.4 | 14.0 | 1,306.3 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/01/2014 17:00 | -0.2 | 13.6 | 1,684.2 | -0.1 | 1.2 | 1 | 1 | 1 |
| 02/01/2014 18:00 | -0.8 | 12.9 | 1,993.9 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/01/2014 19:00 | -0.9 | 12.0 | 2,182.5 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/01/2014 20:00 | -0.8 | 11.8 | 2,231.6 | -0.2 | 1.6 | 1 | 1 | 1 |
| 02/01/2014 21:00 | -0.8 | 11.8 | 2,233.4 | -0.2 | 1.6 | 1 | 1 | 1 |
| 02/01/2014 22:00 | -0.8 | 11.9 | 2,229.5 | -0.4 | 1.6 | 1 | 1 | 1 |
| 02/01/2014 23:00 | -0.9 | 12.1 | 2,211.6 | -0.4 | 1.5 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.2 | 13.1 | 1,838.4 | 0.0 | 1.3 | 24 # | 24 # | 14 # |
| **Minimum:** | -1.1 | 11.8 | 1,256.1 | -0.5 | 0.9 | 1 | 1 | 0 |
| **Maximum:** | 0.4 | 14.0 | 2,233.4 | 0.4 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/02/2014 00:00 | -0.9 | 12.3 | 2,147.3 | -0.5 | 1.5 | 1 | 1 | 1 |
| 02/02/2014 01:00 | -0.9 | 12.7 | 2,070.2 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/02/2014 02:00 | -0.9 | 12.7 | 2,064.8 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/02/2014 03:00 | -0.8 | 12.7 | 2,076.0 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/02/2014 04:00 | -0.7 | 13.0 | 2,029.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/02/2014 05:00 | -0.7 | 13.0 | 2,028.9 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/02/2014 06:00 | -0.8 | 12.9 | 2,044.6 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/02/2014 07:00 | -1.1 | 12.1 | 2,193.1 | -0.5 | 1.5 | 1 | 1 | 1 |
| 02/02/2014 08:00 | -1.1 | 12.0 | 2,237.2 | -0.5 | 1.6 | 1 | 1 | 1 |
| 02/02/2014 09:00 | -0.9 | 12.0 | 2,236.5 | -0.4 | 1.6 | 1 | 1 | 1 |
| 02/02/2014 10:00 | -0.9 | 11.9 | 2,229.5 | -0.4 | 1.6 | 1 | 1 | 1 |
| 02/02/2014 11:00 | -0.8 | 11.9 | 2,228.9 | -0.4 | 1.6 | 1 | 1 | 1 |
| 02/02/2014 12:00 | -0.8 | 11.9 | 2,216.7 | -0.4 | 1.6 | 1 | 1 | 1 |
| 02/02/2014 13:00 | -0.8 | 12.0 | 2,195.5 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/02/2014 14:00 | -0.9 | 12.6 | 2,061.3 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/02/2014 15:00 | -0.8 | 11.9 | 2,207.7 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/02/2014 16:00 | -0.7 | 11.8 | 2,240.9 | -0.2 | 1.6 | 1 | 1 | 1 |
| 02/02/2014 17:00 | -0.8 | 12.3 | 2,126.4 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/02/2014 18:00 | -0.4 | 13.1 | 1,951.7 | -0.1 | 1.4 | 1 | 1 | 1 |
| 02/02/2014 19:00 | -0.9 | 12.5 | 2,097.7 | -0.5 | 1.5 | 1 | 1 | 1 |
| 02/02/2014 20:00 | -0.9 | 11.9 | 2,206.3 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/02/2014 21:00 | -0.8 | 11.8 | 2,233.7 | -0.2 | 1.6 | 1 | 1 | 1 |
| 02/02/2014 22:00 | -0.9 | 12.2 | 2,145.2 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/02/2014 23:00 | -0.8 | 11.9 | 2,214.8 | -0.4 | 1.6 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.8 | 12.3 | 2,145.2 | -0.4 | 1.5 | 24 # | 24 # | 24 # |
| **Minimum:** | -1.1 | 11.8 | 1,951.7 | -0.5 | 1.4 | 1 | 1 | 1 |
| **Maximum:** | -0.4 | 13.1 | 2,240.9 | -0.1 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/03/2014 00:00 | -0.8 | 12.0 | 2,190.2 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/03/2014 01:00 | -0.9 | 12.5 | 2,077.3 | -0.5 | 1.5 | 1 | 1 | 1 |
| 02/03/2014 02:00 | -0.7 | 13.0 | 1,988.6 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/03/2014 03:00 | -0.5 | 13.1 | 1,957.6 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/03/2014 04:00 | -0.5 | 13.1 | 2,001.5 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/03/2014 05:00 | -1.1 | 12.6 | 2,098.1 | -0.7 | 1.5 | 1 | 1 | 1 |
| 02/03/2014 06:00 | -0.8 | 12.8 | 2,035.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/03/2014 07:00 | -0.9 | 12.7 | 2,046.9 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/03/2014 08:00 | -1.1 | 12.1 | 2,201.2 | -0.5 | 1.5 | 1 | 1 | 1 |
| 02/03/2014 09:00 | -0.9 | 12.3 | 2,155.8 | -0.5 | 1.5 | 1 | 1 | 1 |
| 02/03/2014 10:00 | -0.9 | 12.7 | 2,060.9 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/03/2014 11:00 | -0.4 | 13.3 | 1,882.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/03/2014 12:00 | -0.4 | 13.2 | 1,914.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/03/2014 13:00 | -0.7 | 13.0 | 1,969.8 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/03/2014 14:00 | -0.8 | 13.0 | 1,987.3 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/03/2014 15:00 | -0.5 | 13.1 | 1,944.2 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/03/2014 16:00 | -0.7 | 13.0 | 1,970.7 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/03/2014 17:00 | -0.8 | 12.6 | 2,057.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/03/2014 18:00 | -0.8 | 11.9 | 2,203.6 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/03/2014 19:00 | -0.7 | 11.7 | 2,241.6 | -0.2 | 1.6 | 1 | 1 | 1 |
| 02/03/2014 20:00 | -0.7 | 11.7 | 2,240.3 | -0.2 | 1.6 | 1 | 1 | 1 |
| 02/03/2014 21:00 | -0.7 | 11.8 | 2,225.8 | -0.2 | 1.6 | 1 | 1 | 1 |
| 02/03/2014 22:00 | -0.8 | 12.0 | 2,191.8 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/03/2014 23:00 | -0.8 | 12.4 | 2,101.1 | -0.4 | 1.5 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.7 | 12.6 | 2,072.7 | -0.4 | 1.5 | 24 # | 24 # | 24 # |
| **Minimum:** | -1.1 | 11.7 | 1,882.4 | -0.7 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.4 | 13.3 | 2,241.6 | -0.1 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/04/2014 00:00 | -0.8 | 12.8 | 2,063.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/04/2014 01:00 | -0.5 | 13.0 | 2,008.1 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/04/2014 02:00 | -0.4 | 13.2 | 1,918.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/04/2014 03:00 | -0.5 | 13.2 | 1,955.3 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/04/2014 04:00 | -0.4 | 13.3 | 1,853.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/04/2014 05:00 | -0.4 | 13.2 | 1,820.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/04/2014 06:00 | -0.7 | 13.0 | 1,983.7 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/04/2014 07:00 | -0.7 | 13.0 | 2,016.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/04/2014 08:00 | -0.7 | 13.0 | 2,019.7 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/04/2014 09:00 | -0.5 | 13.2 | 1,959.7 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/04/2014 10:00 | -0.7 | 13.1 | 1,998.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/04/2014 11:00 | -0.7 | 13.0 | 2,003.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/04/2014 12:00 | -0.5 | 13.1 | 1,963.2 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/04/2014 13:00 | -0.4 | 13.3 | 1,901.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/04/2014 14:00 | -0.8 | 12.9 | 2,003.7 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/04/2014 15:00 | -0.9 | 12.7 | 2,049.0 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/04/2014 16:00 | -0.8 | 12.8 | 2,010.6 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/04/2014 17:00 | -0.8 | 12.9 | 2,015.5 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/04/2014 18:00 | -1.1 | 12.5 | 2,097.9 | -0.5 | 1.5 | 1 | 1 | 1 |
| 02/04/2014 19:00 | -0.9 | 12.0 | 2,193.6 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/04/2014 20:00 | -0.9 | 12.1 | 2,162.3 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/04/2014 21:00 | -0.8 | 11.8 | 2,226.6 | -0.2 | 1.6 | 1 | 1 | 1 |
| 02/04/2014 22:00 | -0.8 | 12.0 | 2,198.2 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/04/2014 23:00 | -0.9 | 12.6 | 2,075.6 | -0.5 | 1.5 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.7 | 12.8 | 2,020.7 | -0.3 | 1.4 | 24 # | 24 # | 24 # |
| **Minimum:** | -1.1 | 11.8 | 1,820.8 | -0.5 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.4 | 13.3 | 2,226.6 | -0.1 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/05/2014 00:00 | -0.8 | 12.8 | 2,023.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/05/2014 01:00 | -0.4 | 13.3 | 1,859.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/05/2014 02:00 | -0.4 | 13.3 | 1,830.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/05/2014 03:00 | -0.4 | 13.3 | 1,838.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/05/2014 04:00 | -0.5 | 13.3 | 1,841.6 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/05/2014 05:00 | -0.5 | 13.3 | 1,874.5 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/05/2014 06:00 | -0.5 | 13.2 | 1,933.1 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/05/2014 07:00 | -1.1 | 12.3 | 2,100.1 | -0.5 | 1.5 | 1 | 1 | 1 |
| 02/05/2014 08:00 | -1.1 | 12.0 | 2,216.6 | -0.5 | 1.6 | 1 | 1 | 1 |
| 02/05/2014 09:00 | -0.7 | 12.9 | 2,048.2 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/05/2014 10:00 | -0.1 | 13.8 | 1,343.5 | 0.1 | 0.9 | 1 | 1 | 1 |
| 02/05/2014 11:00 | -0.2 | 13.5 | 1,551.5 | -0.1 | 1.1 | 1 | 1 | 1 |
| 02/05/2014 12:00 | -1.1 | 11.9 | 2,232.9 | -0.5 | 1.6 | 1 | 1 | 1 |
| 02/05/2014 13:00 | -0.8 | 12.2 | 2,150.7 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/05/2014 14:00 | -0.4 | 13.3 | 1,860.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/05/2014 15:00 | -0.4 | 13.3 | 1,830.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/05/2014 16:00 | -0.4 | 13.3 | 1,851.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/05/2014 17:00 | -0.8 | 12.9 | 2,004.7 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/05/2014 18:00 | -0.9 | 12.6 | 2,055.5 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/05/2014 19:00 | -0.9 | 11.8 | 2,228.3 | -0.4 | 1.6 | 1 | 1 | 1 |
| 02/05/2014 20:00 | -0.8 | 11.7 | 2,248.5 | -0.2 | 1.6 | 1 | 1 | 1 |
| 02/05/2014 21:00 | -0.8 | 11.7 | 2,241.4 | -0.2 | 1.6 | 1 | 1 | 1 |
| 02/05/2014 22:00 | -0.8 | 11.7 | 2,239.6 | -0.2 | 1.6 | 1 | 1 | 1 |
| 02/05/2014 23:00 | -0.8 | 11.7 | 2,239.7 | -0.2 | 1.6 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.7 | 12.7 | 1,985.2 | -0.3 | 1.4 | 24 # | 24 # | 24 # |
| **Minimum:** | -1.1 | 11.7 | 1,343.5 | -0.5 | 0.9 | 1 | 1 | 1 |
| **Maximum:** | -0.1 | 13.8 | 2,248.5 | 0.1 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/06/2014 00:00 | -0.8 | 12.0 | 2,195.1 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/06/2014 01:00 | -0.5 | 13.1 | 1,929.2 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/06/2014 02:00 | -0.4 | 13.2 | 1,817.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 03:00 | -0.4 | 13.2 | 1,819.1 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 04:00 | -0.4 | 13.2 | 1,821.1 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 05:00 | -0.4 | 13.2 | 1,822.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 06:00 | -0.4 | 13.2 | 1,832.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 07:00 | -0.4 | 13.3 | 1,853.9 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 08:00 | -0.5 | 13.2 | 1,917.5 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 09:00 | -0.4 | 13.3 | 1,884.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 10:00 | -0.4 | 13.3 | 1,841.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 11:00 | -0.4 | 13.2 | 1,828.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 12:00 | -0.4 | 13.2 | 1,822.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 13:00 | -0.5 | 13.2 | 1,839.7 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 14:00 | -0.4 | 13.3 | 1,838.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 15:00 | -0.4 | 13.3 | 1,867.1 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 16:00 | -0.4 | 13.3 | 1,832.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 17:00 | -0.4 | 13.3 | 1,875.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 18:00 | -0.4 | 13.3 | 1,849.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 19:00 | -0.4 | 13.3 | 1,908.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 20:00 | -0.4 | 13.3 | 1,854.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 21:00 | -0.4 | 13.3 | 1,839.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 22:00 | -0.4 | 13.3 | 1,841.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/06/2014 23:00 | -0.4 | 13.3 | 1,843.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.4 | 13.2 | 1,865.6 | -0.1 | 1.3 | 24 # | 24 # | 24 # |
| **Minimum:** | -0.8 | 12.0 | 1,817.5 | -0.4 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.4 | 13.3 | 2,195.1 | -0.1 | 1.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/07/2014 00:00 | -0.4 | 13.3 | 1,841.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/07/2014 01:00 | -0.7 | 12.9 | 1,984.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/07/2014 02:00 | -0.8 | 12.6 | 2,037.7 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/07/2014 03:00 | -0.8 | 12.7 | 2,041.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/07/2014 04:00 | -0.8 | 11.9 | 2,187.4 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/07/2014 05:00 | -0.8 | 11.9 | 2,195.9 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/07/2014 06:00 | -0.7 | 11.7 | 2,240.9 | -0.2 | 1.6 | 1 | 1 | 1 |
| 02/07/2014 07:00 | -0.7 | 11.6 | 2,255.0 | -0.2 | 1.6 | 1 | 1 | 1 |
| 02/07/2014 08:00 | -0.7 | 11.6 | 2,259.0 | -0.2 | 1.6 | 1 | 1 | 1 |
| 02/07/2014 09:00 | -0.8 | 12.2 | 2,143.4 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/07/2014 10:00 | -0.8 | 12.8 | 2,020.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/07/2014 11:00 | -0.8 | 12.8 | 2,019.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/07/2014 12:00 | -0.8 | 12.6 | 2,044.8 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/07/2014 13:00 | -0.8 | 12.8 | 1,998.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/07/2014 14:00 | -0.5 | 13.0 | 1,921.9 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/07/2014 15:00 | -0.4 | 13.3 | 1,833.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/07/2014 16:00 | -0.8 | 12.8 | 2,004.3 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/07/2014 17:00 | -0.9 | 12.7 | 2,008.2 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/07/2014 18:00 | -0.9 | 12.5 | 2,065.2 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/07/2014 19:00 | -0.8 | 11.7 | 2,215.9 | -0.2 | 1.6 | 1 | 1 | 1 |
| 02/07/2014 20:00 | -0.9 | 12.5 | 2,055.2 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/07/2014 21:00 | -0.8 | 12.7 | 2,011.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/07/2014 22:00 | -0.8 | 12.7 | 2,011.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/07/2014 23:00 | -0.8 | 12.6 | 2,017.7 | -0.4 | 1.4 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.8 | 12.5 | 2,058.9 | -0.3 | 1.4 | 24 # | 24 # | 24 # |
| **Minimum:** | -0.9 | 11.6 | 1,833.6 | -0.5 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.4 | 13.3 | 2,259.0 | -0.1 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/08/2014 00:00 | -0.7 | 13.1 | 1,918.1 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 01:00 | -0.7 | 13.2 | 1,895.7 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 02:00 | -0.7 | 13.3 | 1,866.7 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 03:00 | -0.8 | 13.4 | 1,857.2 | -0.5 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 04:00 | -0.8 | 13.4 | 1,863.0 | -0.5 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 05:00 | -0.8 | 13.4 | 1,862.5 | -0.5 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 06:00 | -0.7 | 13.4 | 1,844.8 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 07:00 | -0.5 | 13.2 | 1,878.3 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 08:00 | -0.4 | 13.2 | 1,830.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 09:00 | -0.4 | 13.2 | 1,828.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 10:00 | -0.4 | 13.2 | 1,820.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 11:00 | -0.4 | 13.2 | 1,819.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 12:00 | -0.4 | 13.2 | 1,818.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 13:00 | -0.5 | 13.2 | 1,851.6 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 14:00 | -0.4 | 13.2 | 1,813.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 15:00 | -0.5 | 13.2 | 1,815.6 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 16:00 | -0.5 | 13.2 | 1,815.1 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 17:00 | -0.5 | 13.3 | 1,823.8 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 18:00 | -0.5 | 13.0 | 1,923.6 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 19:00 | -0.8 | 12.1 | 2,110.6 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/08/2014 20:00 | -0.8 | 12.5 | 2,024.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/08/2014 21:00 | -0.8 | 12.4 | 2,046.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/08/2014 22:00 | -0.7 | 13.1 | 1,887.9 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/08/2014 23:00 | -0.8 | 13.5 | 1,811.6 | -0.5 | 1.3 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.6 | 13.1 | 1,876.1 | -0.3 | 1.3 | 24 # | 24 # | 24 # |
| **Minimum:** | -0.8 | 12.1 | 1,811.6 | -0.5 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.4 | 13.5 | 2,110.6 | -0.1 | 1.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/09/2014 00:00 | -0.7 | 13.6 | 1,802.2 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/09/2014 01:00 | -0.5 | 13.1 | 1,913.3 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/09/2014 02:00 | -0.9 | 13.5 | 1,816.4 | -0.7 | 1.3 | 1 | 1 | 1 |
| 02/09/2014 03:00 | -0.9 | 13.6 | 1,801.3 | -0.7 | 1.3 | 1 | 1 | 1 |
| 02/09/2014 04:00 | -1.1 | 13.6 | 1,800.4 | -0.8 | 1.3 | 1 | 1 | 1 |
| 02/09/2014 05:00 | -1.1 | 13.6 | 1,798.4 | -0.8 | 1.3 | 1 | 1 | 1 |
| 02/09/2014 06:00 | -0.9 | 13.5 | 1,811.6 | -0.7 | 1.3 | 1 | 1 | 1 |
| 02/09/2014 07:00 | -0.5 | 13.2 | 1,820.6 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/09/2014 08:00 | -0.5 | 13.2 | 1,820.3 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/09/2014 09:00 | -0.5 | 13.2 | 1,820.6 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/09/2014 10:00 | -0.5 | 13.2 | 1,824.6 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/09/2014 11:00 | -0.5 | 13.3 | 1,817.4 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/09/2014 12:00 | -0.4 | 13.3 | 1,812.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/09/2014 13:00 | -0.4 | 13.3 | 1,815.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/09/2014 14:00 | -0.4 | 13.3 | 1,819.9 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/09/2014 15:00 | -0.4 | 13.3 | 1,821.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/09/2014 16:00 | -0.5 | 13.2 | 1,849.4 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/09/2014 17:00 | -0.5 | 13.2 | 1,850.7 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/09/2014 18:00 | -0.7 | 12.9 | 1,939.3 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/09/2014 19:00 | -0.7 | 11.6 | 2,196.6 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/09/2014 20:00 | -0.5 | 11.5 | 2,208.2 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/09/2014 21:00 | -0.5 | 11.5 | 2,209.2 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/09/2014 22:00 | -0.5 | 12.0 | 2,101.9 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/09/2014 23:00 | -0.7 | 12.3 | 2,045.0 | -0.2 | 1.4 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.6 | 13.0 | 1,896.5 | -0.3 | 1.3 | 24 # | 24 # | 24 # |
| **Minimum:** | -1.1 | 11.5 | 1,798.4 | -0.8 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.4 | 13.6 | 2,209.2 | -0.1 | 1.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/10/2014 00:00 | -0.1 | 13.7 | 1,478.2 | 0.1 | 1.0 | 1 | 1 | 1 |
| 02/10/2014 01:00 | 0.4 | 13.8 | 1,335.3 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/10/2014 02:00 | 0.3 | 13.8 | 1,364.4 | 0.4 | 1.0 | 1 | 1 | 0 |
| 02/10/2014 03:00 | 0.3 | 13.9 | 1,242.3 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/10/2014 04:00 | 0.3 | 13.9 | 1,242.3 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/10/2014 05:00 | -0.2 | 13.8 | 1,422.7 | -0.1 | 1.0 | 1 | 1 | 1 |
| 02/10/2014 06:00 | -1.1 | 13.4 | 1,850.4 | -0.7 | 1.3 | 1 | 1 | 1 |
| 02/10/2014 07:00 | -0.5 | 13.2 | 1,884.3 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/10/2014 08:00 | -0.5 | 13.0 | 1,957.4 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/10/2014 09:00 | -0.4 | 13.3 | 1,862.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/10/2014 10:00 | -0.4 | 13.3 | 1,853.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/10/2014 11:00 | -0.4 | 13.3 | 1,833.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/10/2014 12:00 | -0.4 | 13.3 | 1,838.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/10/2014 13:00 | -0.4 | 13.3 | 1,841.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/10/2014 14:00 | -0.4 | 13.3 | 1,845.1 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/10/2014 15:00 | -0.4 | 13.3 | 1,836.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/10/2014 16:00 | -0.4 | 13.3 | 1,835.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/10/2014 17:00 | -0.4 | 13.3 | 1,833.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/10/2014 18:00 | -0.4 | 13.2 | 1,877.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/10/2014 19:00 | -0.9 | 12.7 | 2,006.3 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/10/2014 20:00 | -0.9 | 12.7 | 2,019.7 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/10/2014 21:00 | -0.9 | 12.3 | 2,099.8 | -0.5 | 1.5 | 1 | 1 | 1 |
| 02/10/2014 22:00 | -0.5 | 12.9 | 1,974.1 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/10/2014 23:00 | -1.1 | 13.5 | 1,834.5 | -0.8 | 1.3 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.4 | 13.3 | 1,757.1 | -0.1 | 1.2 | 24 # | 24 # | 20 # |
| **Minimum:** | -1.1 | 12.3 | 1,242.3 | -0.8 | 0.9 | 1 | 1 | 0 |
| **Maximum:** | 0.4 | 13.9 | 2,099.8 | 0.4 | 1.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/11/2014 00:00 | -0.7 | 13.5 | 1,799.6 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/11/2014 01:00 | -0.4 | 13.3 | 1,823.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/11/2014 02:00 | -0.5 | 13.3 | 1,810.0 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/11/2014 03:00 | -0.2 | 13.5 | 1,584.3 | -0.1 | 1.1 | 1 | 1 | 1 |
| 02/11/2014 04:00 | 0.3 | 13.9 | 1,246.2 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/11/2014 05:00 | 0.1 | 13.8 | 1,507.5 | 0.2 | 1.1 | 1 | 1 | 1 |
| 02/11/2014 06:00 | -0.5 | 13.2 | 1,818.4 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/11/2014 07:00 | -0.4 | 13.2 | 1,833.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/11/2014 08:00 | -0.8 | 12.8 | 2,021.3 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/11/2014 09:00 | -0.7 | 12.9 | 1,989.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/11/2014 10:00 | -0.4 | 13.3 | 1,868.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/11/2014 11:00 | -0.4 | 13.3 | 1,834.9 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/11/2014 12:00 | -0.4 | 13.3 | 1,841.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/11/2014 13:00 | -0.4 | 13.3 | 1,843.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/11/2014 14:00 | -0.4 | 13.3 | 1,844.9 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/11/2014 15:00 | -0.4 | 13.3 | 1,843.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/11/2014 16:00 | -0.4 | 13.3 | 1,832.9 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/11/2014 17:00 | -0.4 | 13.3 | 1,842.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/11/2014 18:00 | -0.4 | 13.2 | 1,872.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/11/2014 19:00 | -0.9 | 12.7 | 2,017.7 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/11/2014 20:00 | -0.9 | 12.7 | 2,026.6 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/11/2014 21:00 | -0.9 | 12.3 | 2,103.7 | -0.5 | 1.5 | 1 | 1 | 1 |
| 02/11/2014 22:00 | -0.7 | 12.8 | 1,995.3 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/11/2014 23:00 | -0.4 | 13.1 | 1,921.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.5 | 13.2 | 1,838.4 | -0.2 | 1.3 | 24 # | 24 # | 23 # |
| **Minimum:** | -0.9 | 12.3 | 1,246.2 | -0.5 | 0.9 | 1 | 1 | 0 |
| **Maximum:** | 0.3 | 13.9 | 2,103.7 | 0.4 | 1.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/12/2014 00:00 | -0.4 | 13.2 | 1,854.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/12/2014 01:00 | -0.7 | 12.9 | 1,975.5 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/12/2014 02:00 | -0.7 | 12.9 | 1,982.6 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/12/2014 03:00 | -0.7 | 12.9 | 1,993.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/12/2014 04:00 | -0.8 | 12.8 | 2,004.3 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/12/2014 05:00 | -0.8 | 12.8 | 1,997.7 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/12/2014 06:00 | -0.5 | 13.0 | 1,949.8 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/12/2014 07:00 | -1.1 | 12.5 | 2,041.7 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/12/2014 08:00 | -0.8 | 12.7 | 2,021.6 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/12/2014 09:00 | -0.4 | 13.2 | 1,870.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/12/2014 10:00 | -0.4 | 13.2 | 1,824.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/12/2014 11:00 | -0.4 | 13.2 | 1,824.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/12/2014 12:00 | -0.4 | 13.2 | 1,827.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/12/2014 13:00 | -0.4 | 13.2 | 1,825.1 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/12/2014 14:00 | -0.4 | 13.3 | 1,828.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/12/2014 15:00 | -0.4 | 13.3 | 1,830.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/12/2014 16:00 | -0.4 | 13.3 | 1,829.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/12/2014 17:00 | -0.4 | 13.3 | 1,849.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/12/2014 18:00 | -0.9 | 12.5 | 2,040.0 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/12/2014 19:00 | -0.7 | 11.6 | 2,226.6 | -0.2 | 1.6 | 1 | 1 | 1 |
| 02/12/2014 20:00 | -0.5 | 11.6 | 2,212.9 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/12/2014 21:00 | -0.5 | 11.8 | 2,171.0 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/12/2014 22:00 | -0.7 | 12.4 | 2,075.2 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/12/2014 23:00 | -0.4 | 13.0 | 1,948.2 | -0.1 | 1.4 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.6 | 12.8 | 1,958.5 | -0.2 | 1.4 | 24 # | 24 # | 24 # |
| **Minimum:** | -1.1 | 11.6 | 1,824.0 | -0.5 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.4 | 13.3 | 2,226.6 | -0.1 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/13/2014 00:00 | -0.4 | 13.2 | 1,865.1 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/13/2014 01:00 | -0.4 | 13.2 | 1,827.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/13/2014 02:00 | -0.4 | 13.2 | 1,822.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/13/2014 03:00 | -0.4 | 13.2 | 1,822.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/13/2014 04:00 | -0.4 | 13.2 | 1,815.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/13/2014 05:00 | -0.4 | 13.2 | 1,836.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/13/2014 06:00 | -0.5 | 13.1 | 1,895.3 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/13/2014 07:00 | -0.8 | 12.1 | 2,090.4 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/13/2014 08:00 | -0.7 | 11.7 | 2,213.9 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/13/2014 09:00 | -0.8 | 12.2 | 2,115.7 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/13/2014 10:00 | -0.8 | 12.3 | 2,095.2 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/13/2014 11:00 | -0.8 | 12.3 | 2,096.4 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/13/2014 12:00 | -0.8 | 12.3 | 2,099.8 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/13/2014 13:00 | -0.8 | 12.2 | 2,098.7 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/13/2014 14:00 | -0.8 | 12.2 | 2,100.9 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/13/2014 15:00 | -0.8 | 12.2 | 2,097.8 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/13/2014 16:00 | -0.7 | 12.2 | 2,101.7 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/13/2014 17:00 | -0.7 | 12.1 | 2,119.7 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/13/2014 18:00 | -0.7 | 12.1 | 2,108.1 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/13/2014 19:00 | -0.5 | 11.8 | 2,182.5 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/13/2014 20:00 | -0.5 | 11.5 | 2,229.5 | -0.1 | 1.6 | 1 | 1 | 1 |
| 02/13/2014 21:00 | -0.4 | 11.5 | 2,230.5 | 0.1 | 1.6 | 1 | 1 | 1 |
| 02/13/2014 22:00 | -0.5 | 11.9 | 2,147.2 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/13/2014 23:00 | -0.7 | 12.2 | 2,097.7 | -0.2 | 1.5 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.6 | 12.4 | 2,046.3 | -0.2 | 1.5 | 24 # | 24 # | 24 # |
| **Minimum:** | -0.8 | 11.5 | 1,815.3 | -0.4 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.4 | 13.2 | 2,230.5 | 0.1 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/14/2014 00:00 | -0.5 | 12.7 | 1,996.6 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/14/2014 01:00 | -0.4 | 13.2 | 1,812.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/14/2014 02:00 | -0.4 | 13.2 | 1,835.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/14/2014 03:00 | -0.4 | 13.2 | 1,815.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/14/2014 04:00 | -0.4 | 13.2 | 1,815.1 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/14/2014 05:00 | -0.4 | 13.3 | 1,820.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/14/2014 06:00 | -0.4 | 13.3 | 1,835.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/14/2014 07:00 | -0.4 | 13.1 | 1,878.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/14/2014 08:00 | -0.7 | 12.8 | 1,967.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/14/2014 09:00 | -0.7 | 12.3 | 2,082.0 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/14/2014 10:00 | -0.7 | 12.0 | 2,112.4 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/14/2014 11:00 | -0.5 | 12.0 | 2,118.3 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/14/2014 12:00 | -0.5 | 11.9 | 2,120.8 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/14/2014 13:00 | -0.8 | 11.9 | 2,128.4 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/14/2014 14:00 | -0.4 | 11.8 | 2,131.2 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/14/2014 15:00 | -0.5 | 11.8 | 2,132.8 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/14/2014 16:00 | -0.2 | 12.4 | 1,973.7 | 0.1 | 1.4 | 1 | 1 | 1 |
| 02/14/2014 17:00 | -0.5 | 11.9 | 2,117.3 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/14/2014 18:00 | -0.5 | 11.9 | 2,116.4 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/14/2014 19:00 | -0.7 | 12.3 | 2,043.5 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/14/2014 20:00 | -0.7 | 12.5 | 2,036.7 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/14/2014 21:00 | -0.7 | 12.2 | 2,094.8 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/14/2014 22:00 | -0.7 | 12.1 | 2,107.3 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/14/2014 23:00 | -0.5 | 12.5 | 2,021.2 | -0.2 | 1.4 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.5 | 12.5 | 2,004.7 | -0.2 | 1.4 | 24 # | 24 # | 24 # |
| **Minimum:** | -0.8 | 11.8 | 1,812.6 | -0.4 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.2 | 13.3 | 2,132.8 | 0.1 | 1.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/15/2014 00:00 | -0.7 | 12.6 | 2,003.8 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/15/2014 01:00 | -0.8 | 12.3 | 2,068.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/15/2014 02:00 | -0.5 | 11.8 | 2,179.5 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/15/2014 03:00 | -0.5 | 11.7 | 2,196.4 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/15/2014 04:00 | -0.7 | 12.4 | 2,043.0 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/15/2014 05:00 | -0.7 | 12.7 | 2,000.2 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/15/2014 06:00 | -0.7 | 12.5 | 2,032.2 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/15/2014 07:00 | -0.7 | 12.7 | 1,969.6 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/15/2014 08:00 | -0.7 | 12.7 | 1,986.7 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/15/2014 09:00 | -0.8 | 12.5 | 2,031.5 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/15/2014 10:00 | -0.7 | 12.1 | 2,112.7 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/15/2014 11:00 | -0.5 | 11.6 | 2,213.5 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/15/2014 12:00 | -0.4 | 11.5 | 2,207.0 | 0.1 | 1.5 | 1 | 1 | 1 |
| 02/15/2014 13:00 | -0.5 | 11.8 | 2,154.6 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/15/2014 14:00 | -0.7 | 12.5 | 2,016.7 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/15/2014 15:00 | -0.7 | 12.6 | 1,995.3 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/15/2014 16:00 | -0.5 | 12.8 | 1,964.9 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/15/2014 17:00 | -0.5 | 12.6 | 1,993.7 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/15/2014 18:00 | -0.7 | 12.3 | 2,061.4 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/15/2014 19:00 | -0.4 | 11.6 | 2,196.8 | 0.1 | 1.5 | 1 | 1 | 1 |
| 02/15/2014 20:00 | -0.5 | 11.8 | 2,174.5 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/15/2014 21:00 | -0.4 | 11.7 | 2,187.8 | 0.1 | 1.5 | 1 | 1 | 1 |
| 02/15/2014 22:00 | -0.5 | 12.1 | 2,097.2 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/15/2014 23:00 | -0.4 | 13.0 | 1,896.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.6 | 12.2 | 2,074.3 | -0.2 | 1.4 | 24 # | 24 # | 24 # |
| **Minimum:** | -0.8 | 11.5 | 1,896.6 | -0.4 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.4 | 13.0 | 2,213.5 | 0.1 | 1.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/16/2014 00:00 | -0.4 | 13.3 | 1,833.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/16/2014 01:00 | -0.4 | 13.3 | 1,848.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/16/2014 02:00 | -0.4 | 13.2 | 1,880.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/16/2014 03:00 | -0.2 | 13.5 | 1,701.5 | -0.1 | 1.2 | 1 | 1 | 1 |
| 02/16/2014 04:00 | 0.4 | 13.9 | 1,274.0 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/16/2014 05:00 | 0.4 | 13.8 | 1,472.5 | 0.4 | 1.0 | 1 | 1 | 0 |
| 02/16/2014 06:00 | -0.1 | 13.6 | 1,643.4 | 0.1 | 1.2 | 1 | 1 | 1 |
| 02/16/2014 07:00 | -0.7 | 13.1 | 1,950.7 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/16/2014 08:00 | -0.5 | 13.4 | 1,869.3 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/16/2014 09:00 | -0.7 | 13.7 | 1,826.4 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/16/2014 10:00 | -0.7 | 13.7 | 1,815.4 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/16/2014 11:00 | -0.7 | 13.7 | 1,814.6 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/16/2014 12:00 | -0.7 | 13.7 | 1,815.4 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/16/2014 13:00 | -0.7 | 13.7 | 1,811.9 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/16/2014 14:00 | -0.5 | 13.7 | 1,815.8 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/16/2014 15:00 | -0.5 | 13.6 | 1,832.5 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/16/2014 16:00 | -0.5 | 13.7 | 1,821.6 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/16/2014 17:00 | -0.5 | 13.7 | 1,828.3 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/16/2014 18:00 | -0.7 | 13.1 | 1,922.9 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/16/2014 19:00 | -0.7 | 11.9 | 2,185.4 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/16/2014 20:00 | -0.5 | 11.8 | 2,203.1 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/16/2014 21:00 | -0.5 | 11.8 | 2,202.3 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/16/2014 22:00 | -0.5 | 11.8 | 2,203.8 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/16/2014 23:00 | -0.5 | 12.7 | 2,003.9 | -0.2 | 1.4 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.5 | 13.2 | 1,857.4 | -0.2 | 1.3 | 24 # | 24 # | 22 # |
| **Minimum:** | -0.7 | 11.8 | 1,274.0 | -0.4 | 0.9 | 1 | 1 | 0 |
| **Maximum:** | 0.4 | 13.9 | 2,203.8 | 0.4 | 1.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/17/2014 00:00 | -0.4 | 13.3 | 1,842.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/17/2014 01:00 | -0.4 | 13.3 | 1,828.9 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/17/2014 02:00 | -0.2 | 13.5 | 1,740.3 | -0.1 | 1.2 | 1 | 1 | 1 |
| 02/17/2014 03:00 | 0.3 | 13.9 | 1,295.9 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/17/2014 04:00 | 0.3 | 13.9 | 1,369.9 | 0.4 | 1.0 | 1 | 1 | 0 |
| 02/17/2014 05:00 | -0.2 | 13.6 | 1,574.9 | -0.1 | 1.1 | 1 | 1 | 1 |
| 02/17/2014 06:00 | -0.7 | 13.1 | 1,952.7 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/17/2014 07:00 | -0.8 | 12.9 | 1,991.7 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/17/2014 08:00 | -0.7 | 13.0 | 1,952.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/17/2014 09:00 | -0.5 | 13.3 | 1,886.1 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/17/2014 10:00 | -0.5 | 13.3 | 1,821.6 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/17/2014 11:00 | -0.4 | 13.3 | 1,821.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/17/2014 12:00 | -0.4 | 13.3 | 1,826.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/17/2014 13:00 | -0.4 | 13.3 | 1,826.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/17/2014 14:00 | -0.4 | 13.3 | 1,828.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/17/2014 15:00 | -0.4 | 13.3 | 1,828.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/17/2014 16:00 | -0.4 | 13.3 | 1,826.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/17/2014 17:00 | -0.4 | 13.3 | 1,826.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/17/2014 18:00 | -0.4 | 13.4 | 1,848.0 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/17/2014 19:00 | -0.4 | 13.3 | 1,888.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/17/2014 20:00 | -0.8 | 12.6 | 2,043.5 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/17/2014 21:00 | -0.7 | 12.0 | 2,166.3 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/17/2014 22:00 | -0.7 | 12.7 | 2,012.1 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/17/2014 23:00 | -0.4 | 13.2 | 1,878.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.4 | 13.2 | 1,828.2 | -0.1 | 1.3 | 24 # | 24 # | 22 # |
| **Minimum:** | -0.8 | 12.0 | 1,295.9 | -0.4 | 0.9 | 1 | 1 | 0 |
| **Maximum:** | 0.3 | 13.9 | 2,166.3 | 0.4 | 1.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/18/2014 00:00 | -0.4 | 13.3 | 1,832.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/18/2014 01:00 | -0.4 | 13.3 | 1,825.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/18/2014 02:00 | -0.4 | 13.2 | 1,823.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/18/2014 03:00 | -0.4 | 13.3 | 1,823.1 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/18/2014 04:00 | -0.4 | 13.3 | 1,820.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/18/2014 05:00 | -0.4 | 13.2 | 1,820.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/18/2014 06:00 | -0.5 | 13.2 | 1,862.9 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/18/2014 07:00 | -0.8 | 12.5 | 2,018.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/18/2014 08:00 | -0.7 | 12.4 | 2,083.4 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/18/2014 09:00 | -0.7 | 13.0 | 1,952.9 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/18/2014 10:00 | -0.7 | 13.0 | 1,947.6 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/18/2014 11:00 | -0.7 | 12.7 | 1,994.5 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/18/2014 12:00 | -0.7 | 12.5 | 2,033.7 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/18/2014 13:00 | -0.7 | 12.9 | 1,945.5 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/18/2014 14:00 | -0.4 | 13.3 | 1,825.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/18/2014 15:00 | -0.4 | 13.3 | 1,836.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/18/2014 16:00 | -0.4 | 13.3 | 1,799.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/18/2014 17:00 | -0.5 | 12.9 | 1,924.1 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/18/2014 18:00 | -0.5 | 11.9 | 2,140.5 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/18/2014 19:00 | -0.4 | 11.6 | 2,194.2 | 0.1 | 1.5 | 1 | 1 | 1 |
| 02/18/2014 20:00 | -0.7 | 12.5 | 2,032.5 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/18/2014 21:00 | -0.5 | 11.8 | 2,163.8 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/18/2014 22:00 | -0.5 | 13.2 | 1,882.2 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/18/2014 23:00 | -0.4 | 13.8 | 1,555.5 | -0.2 | 1.1 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.5 | 12.9 | 1,922.4 | -0.2 | 1.4 | 24 # | 24 # | 24 # |
| **Minimum:** | -0.8 | 11.6 | 1,555.5 | -0.4 | 1.1 | 1 | 1 | 1 |
| **Maximum:** | -0.4 | 13.8 | 2,194.2 | 0.1 | 1.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/19/2014 00:00 | 0.3 | 13.9 | 1,234.8 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/19/2014 01:00 | 0.3 | 13.9 | 1,395.8 | 0.4 | 1.0 | 1 | 1 | 0 |
| 02/19/2014 02:00 | 0.0 | 15.0 | 750.2 | 0.0 | 0.5 | 1 | 0 | 0 |
| 02/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 12:00 | 0.0 | 17.5 | 505.2 | 0.0 | 0.4 | 1 | 0 | 0 |
| 02/19/2014 13:00 | 0.0 | 16.9 | 568.7 | 0.0 | 0.4 | 1 | 0 | 0 |
| 02/19/2014 14:00 | 0.0 | 15.3 | 895.0 | 0.0 | 0.6 | 1 | 0 | 0 |
| 02/19/2014 15:00 | 0.4 | 13.9 | 1,283.6 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/19/2014 16:00 | 0.3 | 13.9 | 1,587.8 | 0.4 | 1.1 | 1 | 1 | 0 |
| 02/19/2014 17:00 | 0.3 | 13.9 | 1,723.5 | 0.4 | 1.2 | 1 | 1 | 0 |
| 02/19/2014 18:00 | 0.1 | 13.8 | 1,596.0 | 0.2 | 1.1 | 1 | 1 | 1 |
| 02/19/2014 19:00 | -0.5 | 13.5 | 1,852.6 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/19/2014 20:00 | -0.7 | 12.0 | 2,171.3 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/19/2014 21:00 | -0.4 | 11.7 | 2,223.1 | 0.1 | 1.6 | 1 | 1 | 1 |
| 02/19/2014 22:00 | -0.5 | 12.2 | 2,127.3 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/19/2014 23:00 | -0.5 | 13.5 | 1,851.6 | -0.2 | 1.3 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.1 | 14.1 | 1,451.1 | 0.1 | 1.0 | 15 # | 11 # | 6 # |
| **Minimum:** | -0.7 | 11.7 | 505.2 | -0.2 | 0.4 | 0 | 0 | 0 |
| **Maximum:** | 0.4 | 17.5 | 2,223.1 | 0.4 | 1.6 | 1 | 1 | 1 |
| **%SI** | 37.5 | 37.5 | 37.5 | 37.5 | 37.5 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/20/2014 00:00 | -0.7 | 13.7 | 1,800.2 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/20/2014 01:00 | 0.4 | 13.9 | 1,263.1 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/20/2014 02:00 | 0.4 | 13.9 | 1,238.1 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/20/2014 03:00 | 0.4 | 13.9 | 1,237.4 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/20/2014 04:00 | 0.4 | 13.9 | 1,254.1 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/20/2014 05:00 | 0.3 | 13.9 | 1,306.0 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/20/2014 06:00 | -0.5 | 13.1 | 1,877.8 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/20/2014 07:00 | -0.8 | 12.8 | 2,045.9 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/20/2014 08:00 | -0.7 | 12.3 | 2,121.3 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/20/2014 09:00 | -0.4 | 13.2 | 1,853.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/20/2014 10:00 | -0.4 | 13.3 | 1,812.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/20/2014 11:00 | -0.4 | 13.3 | 1,816.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/20/2014 12:00 | -0.4 | 13.3 | 1,823.1 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/20/2014 13:00 | -0.5 | 13.0 | 1,958.1 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/20/2014 14:00 | -0.4 | 13.4 | 1,845.8 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/20/2014 15:00 | -0.5 | 13.0 | 1,943.7 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/20/2014 16:00 | -0.7 | 12.2 | 2,106.9 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/20/2014 17:00 | -0.2 | 11.5 | 2,238.4 | 0.1 | 1.6 | 1 | 1 | 1 |
| 02/20/2014 18:00 | -0.4 | 11.9 | 2,152.6 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/20/2014 19:00 | -0.2 | 11.5 | 2,242.7 | 0.1 | 1.6 | 1 | 1 | 1 |
| 02/20/2014 20:00 | -0.2 | 11.4 | 2,252.8 | 0.1 | 1.6 | 1 | 1 | 1 |
| 02/20/2014 21:00 | -0.2 | 11.5 | 2,229.4 | 0.1 | 1.6 | 1 | 1 | 1 |
| 02/20/2014 22:00 | -0.2 | 11.5 | 2,237.5 | 0.1 | 1.6 | 1 | 1 | 1 |
| 02/20/2014 23:00 | -0.4 | 11.8 | 2,171.4 | -0.1 | 1.5 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.3 | 12.8 | 1,867.9 | 0.0 | 1.3 | 24 # | 24 # | 19 # |
| **Minimum:** | -0.8 | 11.4 | 1,237.4 | -0.4 | 0.9 | 1 | 1 | 0 |
| **Maximum:** | 0.4 | 13.9 | 2,252.8 | 0.4 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/21/2014 00:00 | -0.5 | 12.5 | 2,036.7 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/21/2014 01:00 | -0.4 | 13.5 | 1,844.1 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/21/2014 02:00 | -0.5 | 13.6 | 1,802.3 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/21/2014 03:00 | -0.5 | 13.6 | 1,802.6 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/21/2014 04:00 | -0.5 | 13.7 | 1,803.4 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/21/2014 05:00 | -0.5 | 13.7 | 1,804.4 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/21/2014 06:00 | -0.5 | 13.6 | 1,826.1 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/21/2014 07:00 | -0.8 | 12.7 | 1,984.8 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/21/2014 08:00 | -0.5 | 11.9 | 2,173.1 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/21/2014 09:00 | -0.4 | 13.1 | 1,918.9 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/21/2014 10:00 | -0.5 | 13.6 | 1,817.5 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/21/2014 11:00 | -0.4 | 13.5 | 1,839.8 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/21/2014 12:00 | -0.5 | 13.6 | 1,820.7 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/21/2014 13:00 | -0.5 | 13.5 | 1,824.2 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/21/2014 14:00 | -0.4 | 13.5 | 1,834.2 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/21/2014 15:00 | -0.2 | 13.5 | 1,831.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/21/2014 16:00 | -0.2 | 13.5 | 1,828.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/21/2014 17:00 | -0.2 | 13.4 | 1,840.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/21/2014 18:00 | -0.7 | 12.7 | 2,002.6 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/21/2014 19:00 | -0.7 | 12.1 | 2,110.8 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/21/2014 20:00 | -0.5 | 12.0 | 2,145.3 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/21/2014 21:00 | -0.4 | 11.7 | 2,211.3 | 0.1 | 1.5 | 1 | 1 | 1 |
| 02/21/2014 22:00 | -0.5 | 12.0 | 2,134.2 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/21/2014 23:00 | -0.7 | 12.4 | 2,067.1 | -0.2 | 1.4 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.5 | 13.0 | 1,929.3 | -0.2 | 1.4 | 24 # | 24 # | 24 # |
| **Minimum:** | -0.8 | 11.7 | 1,802.3 | -0.4 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.2 | 13.7 | 2,211.3 | 0.1 | 1.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/22/2014 00:00 | -0.7 | 12.5 | 2,045.6 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/22/2014 01:00 | -0.5 | 12.8 | 1,995.4 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/22/2014 02:00 | -0.2 | 13.3 | 1,836.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/22/2014 03:00 | -0.7 | 12.9 | 1,962.7 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/22/2014 04:00 | -0.7 | 12.8 | 1,974.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/22/2014 05:00 | -0.5 | 13.2 | 1,897.0 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/22/2014 06:00 | -0.7 | 12.8 | 2,005.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/22/2014 07:00 | -0.7 | 12.8 | 2,007.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/22/2014 08:00 | -0.7 | 12.8 | 1,987.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/22/2014 09:00 | -0.4 | 13.3 | 1,855.1 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/22/2014 10:00 | -0.4 | 13.4 | 1,835.2 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/22/2014 11:00 | -0.4 | 13.4 | 1,842.8 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/22/2014 12:00 | -0.4 | 13.4 | 1,854.0 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/22/2014 13:00 | -0.4 | 13.4 | 1,839.5 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/22/2014 14:00 | -0.5 | 13.0 | 1,917.3 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/22/2014 15:00 | -0.7 | 12.7 | 1,975.3 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/22/2014 16:00 | -0.5 | 13.1 | 1,882.3 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/22/2014 17:00 | -0.4 | 13.3 | 1,839.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/22/2014 18:00 | -0.7 | 12.3 | 2,033.9 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/22/2014 19:00 | -0.5 | 12.2 | 2,058.2 | -0.1 | 1.4 | 1 | 1 | 1 |
| 02/22/2014 20:00 | -0.4 | 11.5 | 2,196.1 | 0.1 | 1.5 | 1 | 1 | 1 |
| 02/22/2014 21:00 | -0.2 | 11.4 | 2,217.3 | 0.1 | 1.6 | 1 | 1 | 1 |
| 02/22/2014 22:00 | -0.2 | 11.4 | 2,223.9 | 0.1 | 1.6 | 1 | 1 | 1 |
| 02/22/2014 23:00 | -0.2 | 11.4 | 2,230.6 | 0.1 | 1.6 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.5 | 12.7 | 1,979.7 | -0.2 | 1.4 | 24 # | 24 # | 24 # |
| **Minimum:** | -0.7 | 11.4 | 1,835.2 | -0.4 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.2 | 13.4 | 2,230.6 | 0.1 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/23/2014 00:00 | -0.4 | 11.8 | 2,190.0 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/23/2014 01:00 | -0.7 | 12.1 | 2,121.4 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/23/2014 02:00 | -0.4 | 11.7 | 2,213.9 | 0.1 | 1.5 | 1 | 1 | 1 |
| 02/23/2014 03:00 | -0.4 | 11.6 | 2,224.5 | 0.1 | 1.6 | 1 | 1 | 1 |
| 02/23/2014 04:00 | -0.5 | 12.2 | 2,097.1 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/23/2014 05:00 | -0.7 | 12.8 | 1,995.7 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/23/2014 06:00 | -0.7 | 12.7 | 2,011.4 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/23/2014 07:00 | -0.5 | 13.0 | 1,974.8 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/23/2014 08:00 | -0.5 | 13.0 | 1,958.3 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/23/2014 09:00 | -0.5 | 13.0 | 1,942.2 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/23/2014 10:00 | -0.2 | 13.5 | 1,818.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/23/2014 11:00 | -0.4 | 13.3 | 1,865.1 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/23/2014 12:00 | -0.4 | 13.2 | 1,894.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/23/2014 13:00 | -0.2 | 13.5 | 1,826.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/23/2014 14:00 | -0.2 | 13.4 | 1,827.9 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/23/2014 15:00 | -0.2 | 13.4 | 1,828.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/23/2014 16:00 | -0.4 | 13.1 | 1,867.1 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/23/2014 17:00 | -0.4 | 13.0 | 1,902.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/23/2014 18:00 | -0.5 | 12.1 | 2,083.2 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/23/2014 19:00 | -0.4 | 11.6 | 2,184.0 | 0.1 | 1.5 | 1 | 1 | 1 |
| 02/23/2014 20:00 | -0.4 | 11.7 | 2,168.3 | 0.1 | 1.5 | 1 | 1 | 1 |
| 02/23/2014 21:00 | -0.4 | 11.7 | 2,169.5 | 0.1 | 1.5 | 1 | 1 | 1 |
| 02/23/2014 22:00 | -0.4 | 11.8 | 2,168.5 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/23/2014 23:00 | -0.5 | 11.9 | 2,147.4 | -0.1 | 1.5 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.4 | 12.5 | 2,020.0 | -0.1 | 1.4 | 24 # | 24 # | 24 # |
| **Minimum:** | -0.7 | 11.6 | 1,818.6 | -0.4 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.2 | 13.5 | 2,224.5 | 0.1 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/24/2014 00:00 | -0.5 | 12.8 | 1,972.0 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/24/2014 01:00 | -0.2 | 13.5 | 1,809.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/24/2014 02:00 | -0.2 | 13.6 | 1,760.5 | -0.1 | 1.2 | 1 | 1 | 1 |
| 02/24/2014 03:00 | 0.4 | 13.9 | 1,246.8 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/24/2014 04:00 | 0.4 | 13.9 | 1,220.7 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/24/2014 05:00 | -0.1 | 13.7 | 1,507.4 | 0.1 | 1.1 | 1 | 1 | 1 |
| 02/24/2014 06:00 | -0.5 | 13.3 | 1,854.9 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/24/2014 07:00 | -0.5 | 13.1 | 1,920.1 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/24/2014 08:00 | -1.5 | 12.6 | 2,041.5 | -0.9 | 1.4 | 1 | 1 | 1 |
| 02/24/2014 09:00 | -0.7 | 13.2 | 1,907.6 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/24/2014 10:00 | -0.7 | 13.7 | 1,804.1 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/24/2014 11:00 | -0.4 | 13.5 | 1,835.6 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/24/2014 12:00 | -0.5 | 13.6 | 1,802.6 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/24/2014 13:00 | -0.5 | 13.6 | 1,798.9 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/24/2014 14:00 | -0.4 | 13.5 | 1,805.9 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/24/2014 15:00 | -0.7 | 12.7 | 1,945.5 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/24/2014 16:00 | -0.7 | 12.8 | 1,939.8 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/24/2014 17:00 | -0.7 | 12.4 | 2,016.4 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/24/2014 18:00 | -0.5 | 11.9 | 2,104.9 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/24/2014 19:00 | -0.4 | 11.5 | 2,185.6 | 0.1 | 1.5 | 1 | 1 | 1 |
| 02/24/2014 20:00 | -0.4 | 11.7 | 2,162.8 | 0.1 | 1.5 | 1 | 1 | 1 |
| 02/24/2014 21:00 | -0.4 | 11.8 | 2,141.3 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/24/2014 22:00 | -0.4 | 11.9 | 2,138.5 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/24/2014 23:00 | -0.4 | 11.9 | 2,144.3 | -0.1 | 1.5 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.4 | 12.9 | 1,877.8 | -0.1 | 1.3 | 24 # | 24 # | 22 # |
| **Minimum:** | -1.5 | 11.5 | 1,220.7 | -0.9 | 0.9 | 1 | 1 | 0 |
| **Maximum:** | 0.4 | 13.9 | 2,185.6 | 0.4 | 1.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/25/2014 00:00 | -0.7 | 12.7 | 2,009.1 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/25/2014 01:00 | -0.5 | 13.0 | 1,938.7 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/25/2014 02:00 | -0.2 | 13.4 | 1,810.1 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/25/2014 03:00 | -0.4 | 13.4 | 1,803.8 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/25/2014 04:00 | -0.4 | 13.4 | 1,801.5 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/25/2014 05:00 | -0.7 | 12.8 | 1,966.9 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/25/2014 06:00 | -0.8 | 12.7 | 1,995.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/25/2014 07:00 | -0.5 | 13.1 | 1,919.2 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/25/2014 08:00 | -0.7 | 12.8 | 1,970.6 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/25/2014 09:00 | -0.2 | 13.4 | 1,805.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/25/2014 10:00 | 0.7 | 0.0 | 1,801.3 | 0.7 | 1.3 | 1 | 1 | 1 |
| 02/25/2014 11:00 | 0.7 | 0.0 | 1,798.5 | 0.7 | 1.3 | 1 | 1 | 1 |
| 02/25/2014 12:00 | 0.7 | 0.0 | 1,808.3 | 0.7 | 1.3 | 1 | 1 | 1 |
| 02/25/2014 13:00 | 0.7 | 0.0 | 1,823.5 | 0.7 | 1.3 | 1 | 1 | 1 |
| 02/25/2014 14:00 | -0.7 | 13.6 | 1,801.5 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/25/2014 15:00 | -0.7 | 13.6 | 1,801.3 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/25/2014 16:00 | -0.7 | 13.3 | 1,845.1 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/25/2014 17:00 | -0.2 | 13.4 | 1,819.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/25/2014 18:00 | -0.7 | 12.9 | 1,937.9 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/25/2014 19:00 | -0.8 | 12.1 | 2,091.8 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/25/2014 20:00 | -0.7 | 11.9 | 2,129.0 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/25/2014 21:00 | -0.8 | 12.4 | 2,040.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/25/2014 22:00 | -0.5 | 13.0 | 1,928.6 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/25/2014 23:00 | -0.8 | 12.1 | 2,113.8 | -0.4 | 1.5 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.6 | 13.0 | 1,906.7 | -0.3 | 1.4 | 24 # | 24 # | 24 # |
| **Minimum:** | -0.8 | 11.9 | 1,798.5 | -0.4 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.2 | 13.6 | 2,129.0 | -0.1 | 1.5 | 1 | 1 | 1 |
| **%SI** | 16.7 | 16.7 | 0.0 | 16.7 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/26/2014 00:00 | -0.5 | 13.0 | 1,912.3 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/26/2014 01:00 | -0.5 | 13.3 | 1,851.2 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/26/2014 02:00 | -0.5 | 13.3 | 1,828.1 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/26/2014 03:00 | -0.5 | 13.3 | 1,823.3 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/26/2014 04:00 | -0.5 | 13.3 | 1,816.2 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/26/2014 05:00 | -0.5 | 13.2 | 1,854.6 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/26/2014 06:00 | -0.9 | 12.4 | 2,054.4 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/26/2014 07:00 | -0.8 | 12.0 | 2,147.2 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/26/2014 08:00 | -0.5 | 11.5 | 2,244.6 | -0.1 | 1.6 | 1 | 1 | 1 |
| 02/26/2014 09:00 | -0.5 | 11.5 | 2,246.6 | -0.1 | 1.6 | 1 | 1 | 1 |
| 02/26/2014 10:00 | -0.5 | 11.5 | 2,258.3 | -0.1 | 1.6 | 1 | 1 | 1 |
| 02/26/2014 11:00 | -0.5 | 11.5 | 2,235.5 | -0.1 | 1.6 | 1 | 1 | 1 |
| 02/26/2014 12:00 | -0.7 | 12.0 | 2,132.2 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/26/2014 13:00 | -0.7 | 11.9 | 2,149.5 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/26/2014 14:00 | -0.7 | 12.3 | 2,068.1 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/26/2014 15:00 | -0.7 | 12.4 | 2,046.8 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/26/2014 16:00 | -0.8 | 12.7 | 1,995.5 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/26/2014 17:00 | -0.7 | 12.1 | 2,112.9 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/26/2014 18:00 | -0.7 | 11.9 | 2,143.3 | -0.2 | 1.5 | 1 | 1 | 1 |
| 02/26/2014 19:00 | -0.5 | 11.4 | 2,244.0 | -0.1 | 1.6 | 1 | 1 | 1 |
| 02/26/2014 20:00 | -0.5 | 11.5 | 2,226.6 | -0.1 | 1.6 | 1 | 1 | 1 |
| 02/26/2014 21:00 | -0.4 | 11.6 | 2,195.3 | 0.1 | 1.5 | 1 | 1 | 1 |
| 02/26/2014 22:00 | -0.5 | 11.7 | 2,170.0 | -0.1 | 1.5 | 1 | 1 | 1 |
| 02/26/2014 23:00 | -0.5 | 12.0 | 2,121.9 | -0.1 | 1.5 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.6 | 12.2 | 2,078.3 | -0.2 | 1.5 | 24 # | 24 # | 24 # |
| **Minimum:** | -0.9 | 11.4 | 1,816.2 | -0.5 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.4 | 13.3 | 2,258.3 | 0.1 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/27/2014 00:00 | -0.7 | 12.7 | 1,969.2 | -0.2 | 1.4 | 1 | 1 | 1 |
| 02/27/2014 01:00 | -0.4 | 13.3 | 1,834.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/27/2014 02:00 | -0.1 | 13.6 | 1,551.1 | 0.1 | 1.1 | 1 | 1 | 1 |
| 02/27/2014 03:00 | 0.4 | 13.9 | 1,277.2 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/27/2014 04:00 | 0.4 | 13.8 | 1,565.2 | 0.4 | 1.1 | 1 | 1 | 0 |
| 02/27/2014 05:00 | -0.2 | 13.4 | 1,717.2 | -0.1 | 1.2 | 1 | 1 | 1 |
| 02/27/2014 06:00 | -0.5 | 13.3 | 1,868.9 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/27/2014 07:00 | -0.7 | 13.3 | 1,851.2 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/27/2014 08:00 | -0.8 | 12.7 | 2,002.5 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/27/2014 09:00 | -1.1 | 13.5 | 1,832.7 | -0.8 | 1.3 | 1 | 1 | 1 |
| 02/27/2014 10:00 | -1.5 | 13.6 | 1,807.6 | -1.1 | 1.3 | 1 | 1 | 1 |
| 02/27/2014 11:00 | -1.2 | 13.6 | 1,804.1 | -0.9 | 1.3 | 1 | 1 | 1 |
| 02/27/2014 12:00 | -0.7 | 13.6 | 1,807.5 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/27/2014 13:00 | -0.5 | 13.5 | 1,816.8 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/27/2014 14:00 | -0.5 | 13.5 | 1,815.3 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/27/2014 15:00 | -0.5 | 13.5 | 1,818.0 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/27/2014 16:00 | -0.5 | 13.5 | 1,824.7 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/27/2014 17:00 | -0.5 | 13.3 | 1,880.6 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/27/2014 18:00 | -0.4 | 13.3 | 1,868.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/27/2014 19:00 | -0.9 | 12.5 | 2,034.9 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/27/2014 20:00 | -0.9 | 12.6 | 2,021.7 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/27/2014 21:00 | -0.9 | 12.6 | 2,032.4 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/27/2014 22:00 | -0.9 | 12.6 | 2,008.7 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/27/2014 23:00 | -0.9 | 12.5 | 2,028.5 | -0.5 | 1.4 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.6 | 13.2 | 1,834.9 | -0.3 | 1.3 | 24 # | 24 # | 22 # |
| **Minimum:** | -1.5 | 12.5 | 1,277.2 | -1.1 | 0.9 | 1 | 1 | 0 |
| **Maximum:** | 0.4 | 13.9 | 2,034.9 | 0.4 | 1.4 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/28/2014 00:00 | -0.5 | 13.1 | 1,881.9 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/28/2014 01:00 | -0.4 | 13.4 | 1,827.7 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/28/2014 02:00 | -0.5 | 13.1 | 1,900.2 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/28/2014 03:00 | -0.4 | 13.4 | 1,829.8 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/28/2014 04:00 | -0.4 | 13.4 | 1,830.2 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/28/2014 05:00 | -0.5 | 13.4 | 1,844.3 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/28/2014 06:00 | -0.5 | 13.4 | 1,846.1 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/28/2014 07:00 | -0.5 | 13.2 | 1,859.8 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/28/2014 08:00 | -0.9 | 12.7 | 2,006.3 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/28/2014 09:00 | -0.9 | 12.1 | 2,126.5 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/28/2014 10:00 | -0.8 | 11.9 | 2,169.0 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/28/2014 11:00 | -0.8 | 11.9 | 2,151.2 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/28/2014 12:00 | -0.8 | 12.1 | 2,112.9 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/28/2014 13:00 | -0.8 | 12.6 | 2,005.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/28/2014 14:00 | -0.4 | 13.3 | 1,857.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/28/2014 15:00 | -0.7 | 13.0 | 1,925.4 | -0.4 | 1.3 | 1 | 1 | 1 |
| 02/28/2014 16:00 | -0.9 | 12.2 | 2,099.2 | -0.4 | 1.5 | 1 | 1 | 1 |
| 02/28/2014 17:00 | -0.9 | 12.4 | 2,056.9 | -0.5 | 1.4 | 1 | 1 | 1 |
| 02/28/2014 18:00 | -0.5 | 13.1 | 1,928.2 | -0.2 | 1.3 | 1 | 1 | 1 |
| 02/28/2014 19:00 | -0.8 | 12.7 | 1,995.6 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/28/2014 20:00 | -0.4 | 13.3 | 1,835.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 02/28/2014 21:00 | -0.7 | 13.0 | 1,951.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/28/2014 22:00 | -0.8 | 12.8 | 1,986.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 02/28/2014 23:00 | -0.9 | 12.6 | 2,025.8 | -0.5 | 1.4 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.7 | 12.8 | 1,960.5 | -0.3 | 1.4 | 24 # | 24 # | 24 # |
| **Minimum:** | -0.9 | 11.9 | 1,827.7 | -0.5 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.4 | 13.4 | 2,169.0 | -0.1 | 1.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/01/2014 00:00 | -0.7 | 13.0 | 1,930.3 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/01/2014 01:00 | -0.4 | 13.3 | 1,848.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/01/2014 02:00 | -0.4 | 13.3 | 1,819.1 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/01/2014 03:00 | -0.4 | 13.3 | 1,819.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/01/2014 04:00 | -0.4 | 13.3 | 1,818.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/01/2014 05:00 | -0.4 | 13.3 | 1,834.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/01/2014 06:00 | -0.4 | 13.3 | 1,821.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/01/2014 07:00 | -0.4 | 13.3 | 1,820.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/01/2014 08:00 | -0.4 | 13.3 | 1,833.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/01/2014 09:00 | -0.4 | 13.3 | 1,820.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/01/2014 10:00 | -0.4 | 13.3 | 1,826.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/01/2014 11:00 | -0.4 | 13.3 | 1,828.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/01/2014 12:00 | -0.4 | 13.3 | 1,832.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/01/2014 13:00 | -0.4 | 13.3 | 1,858.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/01/2014 14:00 | -0.8 | 12.8 | 1,993.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/01/2014 15:00 | -0.8 | 12.8 | 1,997.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/01/2014 16:00 | -0.4 | 13.4 | 1,862.5 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/01/2014 17:00 | -0.4 | 13.4 | 1,831.7 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/01/2014 18:00 | -0.4 | 13.3 | 1,830.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/01/2014 19:00 | -0.7 | 13.0 | 1,937.8 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/01/2014 20:00 | -0.7 | 13.1 | 1,921.6 | -0.4 | 1.3 | 1 | 1 | 1 |
| 03/01/2014 21:00 | -0.8 | 12.8 | 1,981.9 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/01/2014 22:00 | -0.7 | 12.9 | 1,977.7 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/01/2014 23:00 | -0.9 | 12.6 | 2,014.1 | -0.5 | 1.4 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.5 | 13.2 | 1,877.5 | -0.2 | 1.3 | 24 # | 24 # | 24 # |
| **Minimum:** | -0.9 | 12.6 | 1,818.7 | -0.5 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.4 | 13.4 | 2,014.1 | -0.1 | 1.4 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/02/2014 00:00 | -0.5 | 13.2 | 1,906.6 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/02/2014 01:00 | -0.8 | 12.8 | 2,006.7 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/02/2014 02:00 | -0.7 | 13.0 | 1,986.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/02/2014 03:00 | -0.4 | 13.3 | 1,849.9 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/02/2014 04:00 | -0.4 | 13.3 | 1,828.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/02/2014 05:00 | -0.4 | 13.3 | 1,870.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/02/2014 06:00 | -0.7 | 13.0 | 1,971.6 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/02/2014 07:00 | -0.9 | 12.7 | 2,042.2 | -0.5 | 1.4 | 1 | 1 | 1 |
| 03/02/2014 08:00 | -0.8 | 12.7 | 2,035.2 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/02/2014 09:00 | -0.4 | 13.2 | 1,929.4 | -0.1 | 1.4 | 1 | 1 | 1 |
| 03/02/2014 10:00 | -0.8 | 12.8 | 2,018.5 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/02/2014 11:00 | -0.9 | 11.9 | 2,186.1 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/02/2014 12:00 | -0.9 | 12.0 | 2,157.9 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/02/2014 13:00 | -0.7 | 11.7 | 2,207.8 | -0.2 | 1.5 | 1 | 1 | 1 |
| 03/02/2014 14:00 | -0.7 | 11.7 | 2,196.4 | -0.2 | 1.5 | 1 | 1 | 1 |
| 03/02/2014 15:00 | -0.7 | 11.7 | 2,191.4 | -0.2 | 1.5 | 1 | 1 | 1 |
| 03/02/2014 16:00 | -0.7 | 11.7 | 2,186.7 | -0.2 | 1.5 | 1 | 1 | 1 |
| 03/02/2014 17:00 | -0.8 | 11.9 | 2,150.0 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/02/2014 18:00 | -0.8 | 12.2 | 2,075.0 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/02/2014 19:00 | -0.9 | 12.3 | 2,087.9 | -0.5 | 1.5 | 1 | 1 | 1 |
| 03/02/2014 20:00 | -0.8 | 12.6 | 2,023.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/02/2014 21:00 | -0.9 | 12.2 | 2,115.3 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/02/2014 22:00 | -0.7 | 12.7 | 2,030.2 | -0.2 | 1.4 | 1 | 1 | 1 |
| 03/02/2014 23:00 | -0.5 | 12.9 | 1,968.4 | -0.2 | 1.4 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.7 | 12.5 | 2,042.6 | -0.3 | 1.4 | 24 # | 24 # | 24 # |
| **Minimum:** | -0.9 | 11.7 | 1,828.7 | -0.5 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.4 | 13.3 | 2,207.8 | -0.1 | 1.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/03/2014 00:00 | -0.1 | 13.5 | 1,591.3 | 0.1 | 1.1 | 1 | 1 | 1 |
| 03/03/2014 01:00 | 0.4 | 13.8 | 1,430.6 | 0.4 | 1.0 | 1 | 1 | 0 |
| 03/03/2014 02:00 | 0.3 | 13.8 | 1,287.8 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/03/2014 03:00 | 0.3 | 13.8 | 1,285.3 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/03/2014 04:00 | 0.3 | 13.8 | 1,290.9 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/03/2014 05:00 | -0.2 | 13.5 | 1,581.8 | -0.1 | 1.1 | 1 | 1 | 1 |
| 03/03/2014 06:00 | -0.4 | 13.2 | 1,862.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/03/2014 07:00 | -0.8 | 12.8 | 1,982.3 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/03/2014 08:00 | -0.9 | 11.8 | 2,207.6 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/03/2014 09:00 | -0.8 | 12.1 | 2,138.0 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/03/2014 10:00 | -0.7 | 12.9 | 1,977.9 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/03/2014 11:00 | -0.4 | 13.1 | 1,905.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/03/2014 12:00 | -0.4 | 13.2 | 1,860.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/03/2014 13:00 | -0.4 | 13.3 | 1,840.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/03/2014 14:00 | -0.4 | 13.3 | 1,859.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/03/2014 15:00 | -0.4 | 13.2 | 1,900.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/03/2014 16:00 | -0.7 | 12.9 | 1,991.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/03/2014 17:00 | -0.9 | 11.9 | 2,202.4 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/03/2014 18:00 | -0.8 | 12.4 | 2,057.6 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/03/2014 19:00 | -0.8 | 11.8 | 2,193.6 | -0.2 | 1.5 | 1 | 1 | 1 |
| 03/03/2014 20:00 | -0.7 | 11.6 | 2,233.5 | -0.2 | 1.6 | 1 | 1 | 1 |
| 03/03/2014 21:00 | -0.7 | 11.8 | 2,196.1 | -0.2 | 1.5 | 1 | 1 | 1 |
| 03/03/2014 22:00 | -0.5 | 12.9 | 1,941.6 | -0.2 | 1.4 | 1 | 1 | 1 |
| 03/03/2014 23:00 | -0.2 | 13.2 | 1,817.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.4 | 12.9 | 1,859.8 | -0.1 | 1.3 | 24 # | 24 # | 20 # |
| **Minimum:** | -0.9 | 11.6 | 1,285.3 | -0.4 | 0.9 | 1 | 1 | 0 |
| **Maximum:** | 0.4 | 13.8 | 2,233.5 | 0.4 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/04/2014 00:00 | -0.1 | 13.5 | 1,560.1 | 0.1 | 1.1 | 1 | 1 | 1 |
| 03/04/2014 01:00 | 0.4 | 13.8 | 1,255.3 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/04/2014 02:00 | 0.3 | 13.8 | 1,265.9 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/04/2014 03:00 | 0.3 | 13.8 | 1,329.7 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/04/2014 04:00 | 0.3 | 13.8 | 1,276.0 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/04/2014 05:00 | 0.2 | 13.8 | 1,292.1 | 0.3 | 0.9 | 1 | 1 | 0 |
| 03/04/2014 06:00 | -0.2 | 13.6 | 1,583.5 | -0.1 | 1.1 | 1 | 1 | 1 |
| 03/04/2014 07:00 | -0.2 | 13.4 | 1,838.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/04/2014 08:00 | -0.2 | 13.4 | 1,829.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/04/2014 09:00 | 0.1 | 13.8 | 1,430.3 | 0.2 | 1.0 | 1 | 1 | 1 |
| 03/04/2014 10:00 | 0.3 | 13.9 | 1,230.0 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/04/2014 11:00 | 0.3 | 13.9 | 1,230.7 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/04/2014 12:00 | 0.3 | 13.8 | 1,263.7 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/04/2014 13:00 | 0.3 | 13.8 | 1,419.1 | 0.4 | 1.0 | 1 | 1 | 0 |
| 03/04/2014 14:00 | -0.4 | 13.4 | 1,841.4 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/04/2014 15:00 | -0.4 | 13.4 | 1,844.0 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/04/2014 16:00 | -0.4 | 13.4 | 1,844.3 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/04/2014 17:00 | -0.2 | 13.4 | 1,845.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/04/2014 18:00 | -0.4 | 13.3 | 1,882.1 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/04/2014 19:00 | -0.9 | 12.2 | 2,130.6 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/04/2014 20:00 | -0.8 | 12.3 | 2,088.4 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/04/2014 21:00 | -0.8 | 12.8 | 1,996.8 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/04/2014 22:00 | -0.5 | 13.0 | 1,929.5 | -0.2 | 1.4 | 1 | 1 | 1 |
| 03/04/2014 23:00 | -0.2 | 13.4 | 1,836.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.1 | 13.4 | 1,626.8 | 0.1 | 1.2 | 24 # | 24 # | 15 # |
| **Minimum:** | -0.9 | 12.2 | 1,230.0 | -0.4 | 0.9 | 1 | 1 | 0 |
| **Maximum:** | 0.4 | 13.9 | 2,130.6 | 0.4 | 1.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/05/2014 00:00 | -0.2 | 13.4 | 1,857.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/05/2014 01:00 | -0.7 | 12.9 | 1,980.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/05/2014 02:00 | -0.7 | 12.8 | 1,988.8 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/05/2014 03:00 | -0.4 | 13.2 | 1,866.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/05/2014 04:00 | -0.2 | 13.3 | 1,825.9 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/05/2014 05:00 | -0.5 | 13.0 | 1,943.0 | -0.2 | 1.4 | 1 | 1 | 1 |
| 03/05/2014 06:00 | -0.4 | 13.1 | 1,913.1 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/05/2014 07:00 | -0.5 | 13.1 | 1,932.2 | -0.2 | 1.4 | 1 | 1 | 1 |
| 03/05/2014 08:00 | -0.7 | 13.0 | 1,940.2 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/05/2014 09:00 | -0.4 | 13.3 | 1,847.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/05/2014 10:00 | -0.4 | 13.3 | 1,849.1 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/05/2014 11:00 | -0.4 | 13.3 | 1,852.1 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/05/2014 12:00 | -0.4 | 13.3 | 1,852.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/05/2014 13:00 | -0.4 | 13.3 | 1,852.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/05/2014 14:00 | -0.5 | 13.3 | 1,852.8 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/05/2014 15:00 | -0.4 | 13.3 | 1,857.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/05/2014 16:00 | -0.5 | 13.1 | 1,896.2 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/05/2014 17:00 | -0.7 | 12.9 | 1,939.9 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/05/2014 18:00 | -0.7 | 12.9 | 1,945.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/05/2014 19:00 | -0.9 | 12.5 | 2,038.9 | -0.5 | 1.4 | 1 | 1 | 1 |
| 03/05/2014 20:00 | -0.8 | 12.7 | 1,989.2 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/05/2014 21:00 | -0.7 | 12.9 | 1,963.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/05/2014 22:00 | -0.7 | 12.9 | 1,953.3 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/05/2014 23:00 | -0.4 | 13.3 | 1,828.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.5 | 13.1 | 1,906.9 | -0.2 | 1.3 | 24 # | 24 # | 24 # |
| **Minimum:** | -0.9 | 12.5 | 1,825.9 | -0.5 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.2 | 13.4 | 2,038.9 | -0.1 | 1.4 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/06/2014 00:00 | -0.4 | 13.3 | 1,826.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/06/2014 01:00 | -0.4 | 13.3 | 1,783.2 | -0.1 | 1.2 | 1 | 1 | 1 |
| 03/06/2014 02:00 | 0.4 | 13.9 | 1,271.4 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/06/2014 03:00 | 0.0 | 15.8 | 583.3 | 0.0 | 0.4 | 1 | 0 | 0 |
| 03/06/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | -0.1 | 14.1 | 1,366.2 | 0.1 | 1.0 | 4 # | 3 # | 2 # |
| **Minimum:** | -0.4 | 13.3 | 583.3 | -0.1 | 0.4 | 0 | 0 | 0 |
| **Maximum:** | 0.4 | 15.8 | 1,826.7 | 0.4 | 1.3 | 1 | 1 | 1 |
| **%SI** | 83.3 | 83.3 | 83.3 | 83.3 | 83.3 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/07/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 03:00 | 0.0 | 17.5 | 500.2 | 0.0 | 0.4 | 1 | 0 | 0 |
| 03/07/2014 04:00 | 0.0 | 16.6 | 621.9 | 0.0 | 0.4 | 1 | 0 | 0 |
| 03/07/2014 05:00 | 0.0 | 14.9 | 964.7 | 0.0 | 0.7 | 1 | 0 | 0 |
| 03/07/2014 06:00 | 0.4 | 13.9 | 1,449.7 | 0.4 | 1.0 | 1 | 1 | 0 |
| 03/07/2014 07:00 | 0.4 | 13.8 | 1,799.4 | 0.4 | 1.3 | 1 | 1 | 0 |
| 03/07/2014 08:00 | 0.4 | 13.9 | 1,542.5 | 0.4 | 1.1 | 1 | 1 | 0 |
| 03/07/2014 09:00 | 0.4 | 13.9 | 1,332.7 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/07/2014 10:00 | -0.4 | 13.4 | 1,794.3 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/07/2014 11:00 | -0.4 | 13.3 | 1,829.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/07/2014 12:00 | -0.4 | 13.3 | 1,837.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/07/2014 13:00 | -0.4 | 13.4 | 1,836.8 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/07/2014 14:00 | -0.4 | 13.4 | 1,833.6 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/07/2014 15:00 | -0.4 | 13.4 | 1,833.2 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/07/2014 16:00 | -0.4 | 13.3 | 1,857.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/07/2014 17:00 | -0.8 | 12.8 | 2,010.7 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/07/2014 18:00 | -0.8 | 12.8 | 2,013.9 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/07/2014 19:00 | -0.9 | 12.1 | 2,164.4 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/07/2014 20:00 | -0.7 | 11.6 | 2,240.9 | -0.2 | 1.6 | 1 | 1 | 1 |
| 03/07/2014 21:00 | -0.7 | 11.8 | 2,220.3 | -0.2 | 1.6 | 1 | 1 | 1 |
| 03/07/2014 22:00 | -0.7 | 11.8 | 2,219.4 | -0.2 | 1.6 | 1 | 1 | 1 |
| 03/07/2014 23:00 | -0.7 | 12.1 | 2,141.1 | -0.2 | 1.5 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.3 | 13.5 | 1,716.4 | -0.1 | 1.2 | 21 # | 18 # | 14 # |
| **Minimum:** | -0.9 | 11.6 | 500.2 | -0.4 | 0.4 | 0 | 0 | 0 |
| **Maximum:** | 0.4 | 17.5 | 2,240.9 | 0.4 | 1.6 | 1 | 1 | 1 |
| **%SI** | 12.5 | 12.5 | 12.5 | 12.5 | 12.5 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/08/2014 00:00 | -0.2 | 13.2 | 1,925.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/08/2014 01:00 | -0.4 | 13.1 | 1,946.3 | -0.1 | 1.4 | 1 | 1 | 1 |
| 03/08/2014 02:00 | -0.4 | 13.2 | 1,905.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/08/2014 03:00 | -0.4 | 13.2 | 1,886.9 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/08/2014 04:00 | -0.4 | 13.1 | 1,949.1 | -0.1 | 1.4 | 1 | 1 | 1 |
| 03/08/2014 05:00 | -0.7 | 12.9 | 1,993.0 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/08/2014 06:00 | -0.7 | 12.7 | 2,026.4 | -0.2 | 1.4 | 1 | 1 | 1 |
| 03/08/2014 07:00 | -0.5 | 13.0 | 2,003.9 | -0.2 | 1.4 | 1 | 1 | 1 |
| 03/08/2014 08:00 | -0.2 | 13.3 | 1,859.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/08/2014 09:00 | -0.2 | 13.3 | 1,810.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/08/2014 10:00 | -0.2 | 13.3 | 1,811.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/08/2014 11:00 | -0.2 | 13.3 | 1,814.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/08/2014 12:00 | -0.2 | 13.3 | 1,816.4 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/08/2014 13:00 | -0.4 | 13.4 | 1,815.8 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/08/2014 14:00 | -0.2 | 13.4 | 1,814.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/08/2014 15:00 | -0.2 | 13.4 | 1,811.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/08/2014 16:00 | -0.2 | 13.4 | 1,823.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/08/2014 17:00 | -0.4 | 13.3 | 1,851.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/08/2014 18:00 | -0.8 | 12.3 | 2,093.9 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/08/2014 19:00 | -0.8 | 11.9 | 2,180.2 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/08/2014 20:00 | -0.7 | 11.6 | 2,216.1 | -0.2 | 1.6 | 1 | 1 | 1 |
| 03/08/2014 21:00 | -0.5 | 11.6 | 2,211.5 | -0.1 | 1.5 | 1 | 1 | 1 |
| 03/08/2014 22:00 | -0.5 | 11.6 | 2,215.1 | -0.1 | 1.6 | 1 | 1 | 1 |
| 03/08/2014 23:00 | -0.7 | 11.9 | 2,169.4 | -0.2 | 1.5 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.4 | 12.9 | 1,956.3 | -0.2 | 1.4 | 24 # | 24 # | 24 # |
| **Minimum:** | -0.8 | 11.6 | 1,810.5 | -0.4 | 1.3 | 1 | 1 | 1 |
| **Maximum:** | -0.2 | 13.4 | 2,216.1 | -0.1 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/09/2014 00:00 | -0.4 | 13.1 | 1,802.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/09/2014 01:00 | 0.4 | 13.8 | 1,375.4 | 0.4 | 1.0 | 1 | 1 | 0 |
| 03/09/2014 02:00 | 0.0 | 15.7 | 616.2 | 0.0 | 0.4 | 1 | 0 | 0 |
| 03/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 11:00 | 0.0 | 16.9 | 577.4 | 0.0 | 0.4 | 1 | 0 | 0 |
| 03/09/2014 12:00 | 0.0 | 15.1 | 890.5 | 0.0 | 0.6 | 1 | 0 | 0 |
| 03/09/2014 13:00 | 0.3 | 13.9 | 1,349.7 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/09/2014 14:00 | 0.3 | 13.7 | 1,765.6 | 0.4 | 1.2 | 1 | 1 | 0 |
| 03/09/2014 15:00 | 0.3 | 13.7 | 1,758.7 | 0.4 | 1.2 | 1 | 1 | 0 |
| 03/09/2014 16:00 | 0.1 | 13.8 | 1,512.7 | 0.2 | 1.1 | 1 | 1 | 1 |
| 03/09/2014 17:00 | -0.9 | 12.6 | 2,056.3 | -0.5 | 1.4 | 1 | 1 | 1 |
| 03/09/2014 18:00 | -0.8 | 11.8 | 2,200.0 | -0.2 | 1.5 | 1 | 1 | 1 |
| 03/09/2014 19:00 | -0.7 | 11.6 | 2,229.7 | -0.2 | 1.6 | 1 | 1 | 1 |
| 03/09/2014 20:00 | -0.7 | 11.6 | 2,220.8 | -0.2 | 1.6 | 1 | 1 | 1 |
| 03/09/2014 21:00 | -0.5 | 11.6 | 2,221.7 | -0.1 | 1.6 | 1 | 1 | 1 |
| 03/09/2014 22:00 | -0.8 | 12.4 | 2,069.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/09/2014 23:00 | -0.7 | 11.7 | 2,197.3 | -0.2 | 1.5 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.3 | 13.3 | 1,677.7 | 0.0 | 1.2 | 16 # | 13 # | 9 # |
| **Minimum:** | -0.9 | 11.6 | 577.4 | -0.5 | 0.4 | 0 | 0 | 0 |
| **Maximum:** | 0.4 | 16.9 | 2,229.7 | 0.4 | 1.6 | 1 | 1 | 1 |
| **%SI** | 33.3 | 33.3 | 33.3 | 33.3 | 33.3 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/10/2014 00:00 | -0.8 | 12.2 | 2,078.4 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/10/2014 01:00 | 0.1 | 13.8 | 1,308.5 | 0.2 | 0.9 | 1 | 1 | 1 |
| 03/10/2014 02:00 | 0.3 | 13.9 | 1,233.0 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/10/2014 03:00 | 0.3 | 13.9 | 1,236.7 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/10/2014 04:00 | 0.3 | 13.9 | 1,242.6 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/10/2014 05:00 | -0.1 | 13.7 | 1,545.5 | 0.1 | 1.1 | 1 | 1 | 1 |
| 03/10/2014 06:00 | -0.8 | 13.0 | 1,966.8 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/10/2014 07:00 | -0.9 | 12.1 | 2,152.3 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/10/2014 08:00 | -0.8 | 12.3 | 2,104.5 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/10/2014 09:00 | -0.4 | 13.2 | 1,855.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/10/2014 10:00 | -0.4 | 13.3 | 1,815.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/10/2014 11:00 | -0.4 | 13.3 | 1,820.7 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/10/2014 12:00 | -0.4 | 13.3 | 1,821.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/10/2014 13:00 | -0.4 | 13.4 | 1,822.9 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/10/2014 14:00 | -0.4 | 13.4 | 1,826.3 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/10/2014 15:00 | -0.4 | 13.4 | 1,830.1 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/10/2014 16:00 | -0.4 | 13.4 | 1,827.4 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/10/2014 17:00 | -0.4 | 13.4 | 1,826.5 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/10/2014 18:00 | -0.2 | 13.5 | 1,848.8 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/10/2014 19:00 | -0.9 | 12.2 | 2,144.2 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/10/2014 20:00 | -0.7 | 12.4 | 2,082.3 | -0.2 | 1.5 | 1 | 1 | 1 |
| 03/10/2014 21:00 | -0.2 | 13.5 | 1,710.9 | -0.1 | 1.2 | 1 | 1 | 1 |
| 03/10/2014 22:00 | 0.4 | 13.9 | 1,389.4 | 0.4 | 1.0 | 1 | 1 | 0 |
| 03/10/2014 23:00 | 0.0 | 15.9 | 574.3 | 0.0 | 0.4 | 1 | 0 | 0 |
| **Average/Sum#:** | -0.3 | 13.3 | 1,711.0 | -0.1 | 1.2 | 24 # | 23 # | 19 # |
| **Minimum:** | -0.9 | 12.1 | 574.3 | -0.4 | 0.4 | 1 | 0 | 0 |
| **Maximum:** | 0.4 | 15.9 | 2,152.3 | 0.4 | 1.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/11/2014 02:00 | 0.0 | 17.5 | 483.5 | 0.0 | 0.3 | 1 | 0 | 0 |
| 03/11/2014 03:00 | 0.0 | 15.4 | 927.1 | 0.0 | 0.6 | 1 | 0 | 0 |
| 03/11/2014 04:00 | 0.4 | 13.9 | 1,331.6 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/11/2014 05:00 | 0.4 | 13.8 | 1,580.0 | 0.4 | 1.1 | 1 | 1 | 0 |
| 03/11/2014 06:00 | 0.4 | 13.9 | 1,524.1 | 0.4 | 1.1 | 1 | 1 | 0 |
| 03/11/2014 07:00 | 0.3 | 13.7 | 1,762.6 | 0.4 | 1.2 | 1 | 1 | 0 |
| 03/11/2014 08:00 | -0.5 | 13.2 | 1,904.3 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/11/2014 09:00 | -0.4 | 13.3 | 1,812.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/11/2014 10:00 | -0.4 | 13.3 | 1,813.5 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/11/2014 11:00 | -0.4 | 13.4 | 1,815.3 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/11/2014 12:00 | -0.2 | 13.5 | 1,717.4 | -0.1 | 1.2 | 1 | 1 | 1 |
| 03/11/2014 13:00 | 0.4 | 13.9 | 1,329.3 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/11/2014 14:00 | 0.4 | 14.0 | 1,269.2 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/11/2014 15:00 | 0.4 | 14.0 | 1,295.1 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/11/2014 16:00 | 0.4 | 14.0 | 1,370.3 | 0.4 | 1.0 | 1 | 1 | 0 |
| 03/11/2014 17:00 | 0.4 | 14.0 | 1,382.4 | 0.4 | 1.0 | 1 | 1 | 0 |
| 03/11/2014 18:00 | -0.1 | 13.7 | 1,564.9 | 0.1 | 1.1 | 1 | 1 | 1 |
| 03/11/2014 19:00 | -0.8 | 12.5 | 2,069.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/11/2014 20:00 | -0.8 | 12.2 | 2,140.0 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/11/2014 21:00 | -0.8 | 12.5 | 2,081.1 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/11/2014 22:00 | -0.8 | 12.2 | 2,140.6 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/11/2014 23:00 | -0.2 | 13.4 | 1,728.1 | -0.1 | 1.2 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.1 | 13.7 | 1,592.8 | 0.1 | 1.1 | 22 # | 20 # | 11 # |
| **Minimum:** | -0.8 | 12.2 | 483.5 | -0.4 | 0.3 | 0 | 0 | 0 |
| **Maximum:** | 0.4 | 17.5 | 2,140.6 | 0.4 | 1.5 | 1 | 1 | 1 |
| **%SI** | 8.3 | 8.3 | 8.3 | 8.3 | 8.3 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/12/2014 00:00 | 0.4 | 13.9 | 1,271.1 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/12/2014 01:00 | 0.4 | 13.9 | 1,257.2 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/12/2014 02:00 | 0.4 | 13.9 | 1,234.8 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/12/2014 03:00 | 0.4 | 13.9 | 1,226.2 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/12/2014 04:00 | 0.3 | 13.9 | 1,231.0 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/12/2014 05:00 | -0.2 | 13.5 | 1,701.6 | -0.1 | 1.2 | 1 | 1 | 1 |
| 03/12/2014 06:00 | -0.5 | 13.1 | 1,953.6 | -0.2 | 1.4 | 1 | 1 | 1 |
| 03/12/2014 07:00 | -0.8 | 12.0 | 2,152.5 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/12/2014 08:00 | -0.5 | 13.0 | 1,955.3 | -0.2 | 1.4 | 1 | 1 | 1 |
| 03/12/2014 09:00 | -0.2 | 13.3 | 1,830.9 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/12/2014 10:00 | -0.2 | 13.3 | 1,832.0 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/12/2014 11:00 | -0.2 | 13.4 | 1,834.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/12/2014 12:00 | 0.1 | 13.8 | 1,356.4 | 0.2 | 0.9 | 1 | 1 | 1 |
| 03/12/2014 13:00 | 0.4 | 14.0 | 1,372.1 | 0.4 | 1.0 | 1 | 1 | 0 |
| 03/12/2014 14:00 | 0.4 | 14.0 | 1,244.8 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/12/2014 15:00 | 0.4 | 14.0 | 1,243.8 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/12/2014 16:00 | 0.4 | 14.0 | 1,243.9 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/12/2014 17:00 | -0.1 | 13.7 | 1,543.6 | 0.1 | 1.1 | 1 | 1 | 1 |
| 03/12/2014 18:00 | -0.5 | 13.2 | 1,902.3 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/12/2014 19:00 | -0.9 | 12.1 | 2,173.3 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/12/2014 20:00 | -0.8 | 12.0 | 2,191.8 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/12/2014 21:00 | -0.7 | 11.6 | 2,257.8 | -0.2 | 1.6 | 1 | 1 | 1 |
| 03/12/2014 22:00 | -0.7 | 11.6 | 2,254.8 | -0.2 | 1.6 | 1 | 1 | 1 |
| 03/12/2014 23:00 | -0.7 | 12.1 | 2,148.7 | -0.2 | 1.5 | 1 | 1 | 1 |
| **Average/Sum#:** | -0.1 | 13.2 | 1,683.9 | 0.0 | 1.2 | 24 # | 24 # | 15 # |
| **Minimum:** | -0.9 | 11.6 | 1,226.2 | -0.4 | 0.9 | 1 | 1 | 0 |
| **Maximum:** | 0.4 | 14.0 | 2,257.8 | 0.4 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/13/2014 00:00 | 0.1 | 13.6 | 1,674.8 | 0.2 | 1.2 | 1 | 1 | 1 |
| 03/13/2014 01:00 | 0.4 | 13.8 | 1,791.5 | 0.4 | 1.3 | 1 | 1 | 0 |
| 03/13/2014 02:00 | 0.3 | 13.9 | 1,390.1 | 0.4 | 1.0 | 1 | 1 | 0 |
| 03/13/2014 03:00 | 0.3 | 13.9 | 1,373.6 | 0.4 | 1.0 | 1 | 1 | 0 |
| 03/13/2014 04:00 | 0.3 | 13.9 | 1,376.4 | 0.4 | 1.0 | 1 | 1 | 0 |
| 03/13/2014 05:00 | -0.7 | 13.2 | 1,851.8 | -0.4 | 1.3 | 1 | 1 | 1 |
| 03/13/2014 06:00 | -0.7 | 13.1 | 1,960.2 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/13/2014 07:00 | -0.8 | 11.8 | 2,206.5 | -0.2 | 1.5 | 1 | 1 | 1 |
| 03/13/2014 08:00 | -0.8 | 12.5 | 2,092.1 | -0.4 | 1.5 | 1 | 1 | 1 |
| 03/13/2014 09:00 | -0.7 | 12.9 | 1,976.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/13/2014 10:00 | -0.4 | 13.3 | 1,882.3 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/13/2014 11:00 | -0.2 | 13.5 | 1,821.2 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/13/2014 12:00 | -0.4 | 13.3 | 1,887.6 | -0.1 | 1.3 | 1 | 1 | 1 |
| 03/13/2014 13:00 | -0.7 | 13.1 | 1,942.4 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/13/2014 14:00 | -0.7 | 13.1 | 1,947.3 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/13/2014 15:00 | -0.7 | 13.1 | 1,947.1 | -0.4 | 1.4 | 1 | 1 | 1 |
| 03/13/2014 16:00 | -0.5 | 13.2 | 1,893.0 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/13/2014 17:00 | -0.4 | 13.5 | 1,830.1 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/13/2014 18:00 | -0.4 | 13.4 | 1,855.2 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/13/2014 19:00 | -0.7 | 13.1 | 1,922.9 | -0.4 | 1.3 | 1 | 1 | 1 |
| 03/13/2014 20:00 | -0.4 | 13.4 | 1,866.0 | -0.2 | 1.3 | 1 | 1 | 1 |
| 03/13/2014 21:00 | -0.4 | 13.4 | 1,750.8 | -0.2 | 1.2 | 1 | 1 | 1 |
| 03/13/2014 22:00 | 0.4 | 13.9 | 1,038.3 | 0.4 | 0.7 | 1 | 1 | 0 |
| 03/13/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | -0.3 | 13.3 | 1,794.7 | -0.1 | 1.3 | 23 # | 23 # | 18 # |
| **Minimum:** | -0.8 | 11.8 | 1,038.3 | -0.4 | 0.7 | 0 | 0 | 0 |
| **Maximum:** | 0.4 | 13.9 | 2,206.5 | 0.4 | 1.5 | 1 | 1 | 1 |
| **%SI** | 4.2 | 4.2 | 4.2 | 4.2 | 4.2 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/14/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/15/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/30/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 VOC, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 VOC, Ppmvdc 1 Hour(s) | Unit CT1 VOC, LbPerHr 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/31/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/01/2014 00:00 | 0.6 | 13.9 | 1,640.5 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/01/2014 01:00 | 0.6 | 13.8 | 1,818.0 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/01/2014 02:00 | 0.6 | 13.8 | 1,699.2 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/01/2014 03:00 | 0.0 | 14.6 | 1,147.1 | 0.0 | 0.3 | 1 | 0 | 0 |
| 01/01/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 13:00 | 0.0 | 17.7 | 463.0 | 0.0 | 0.1 | 1 | 0 | 0 |
| 01/01/2014 14:00 | 0.0 | 15.2 | 930.0 | 0.0 | 0.3 | 1 | 0 | 0 |
| 01/01/2014 15:00 | 0.6 | 13.8 | 1,651.8 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/01/2014 16:00 | 0.6 | 13.9 | 1,731.6 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/01/2014 17:00 | 0.6 | 13.9 | 1,500.4 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/01/2014 18:00 | 0.5 | 13.7 | 1,763.2 | 0.5 | 0.5 | 1 | 1 | 1 |
| 01/01/2014 19:00 | 0.2 | 12.6 | 2,089.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/01/2014 20:00 | 0.4 | 12.2 | 2,174.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/01/2014 21:00 | 0.4 | 12.1 | 2,193.2 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/01/2014 22:00 | 0.2 | 12.5 | 2,104.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/01/2014 23:00 | 0.2 | 12.5 | 2,107.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 13.7 | 1,667.6 | 0.4 | 0.5 | 15 # | 12 # | 6 # |
| **Minimum:** | 0.0 | 12.1 | 463.0 | 0.0 | 0.1 | 0 | 0 | 0 |
| **Maximum:** | 0.6 | 17.7 | 2,193.2 | 0.6 | 0.7 | 1 | 1 | 1 |
| **%SI** | 37.5 | 37.5 | 37.5 | 37.5 | 37.5 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/02/2014 00:00 | 0.2 | 12.6 | 2,085.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 01:00 | 0.5 | 13.4 | 1,867.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 02:00 | 0.6 | 13.8 | 1,598.2 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/02/2014 03:00 | 0.6 | 13.8 | 1,719.7 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/02/2014 04:00 | 0.6 | 13.8 | 1,598.2 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/02/2014 05:00 | 0.4 | 13.4 | 1,812.1 | 0.4 | 0.5 | 1 | 1 | 1 |
| 01/02/2014 06:00 | 0.2 | 12.8 | 2,024.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 07:00 | 0.2 | 12.9 | 2,019.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 08:00 | 0.2 | 12.8 | 2,059.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 09:00 | 0.2 | 12.8 | 2,069.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 10:00 | 0.2 | 12.8 | 2,059.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 11:00 | 0.2 | 12.7 | 2,048.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 12:00 | 0.2 | 12.7 | 2,032.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 13:00 | 0.4 | 12.7 | 2,020.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 14:00 | 0.4 | 12.8 | 1,982.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 15:00 | 0.4 | 12.7 | 2,009.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 16:00 | 0.4 | 12.6 | 2,031.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 17:00 | 0.4 | 12.5 | 2,049.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 18:00 | 0.4 | 12.2 | 2,142.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 19:00 | 0.5 | 12.0 | 2,171.2 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/02/2014 20:00 | 0.5 | 12.1 | 2,151.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 21:00 | 0.4 | 12.2 | 2,143.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 22:00 | 0.4 | 12.6 | 2,096.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 23:00 | 0.4 | 12.3 | 2,157.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 12.8 | 1,997.8 | 0.5 | 0.6 | 24 # | 24 # | 21 # |
| **Minimum:** | 0.2 | 12.0 | 1,598.2 | 0.4 | 0.5 | 1 | 1 | 0 |
| **Maximum:** | 0.6 | 13.8 | 2,171.2 | 0.6 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/03/2014 00:00 | 0.4 | 12.7 | 2,047.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/03/2014 01:00 | 0.5 | 13.5 | 1,762.2 | 0.5 | 0.5 | 1 | 1 | 1 |
| 01/03/2014 02:00 | 0.6 | 13.9 | 1,324.2 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/03/2014 03:00 | 0.6 | 13.9 | 1,249.2 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/03/2014 04:00 | 0.6 | 13.9 | 1,250.2 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/03/2014 05:00 | 0.6 | 13.9 | 1,252.9 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/03/2014 06:00 | 0.4 | 13.4 | 1,561.2 | 0.4 | 0.5 | 1 | 1 | 1 |
| 01/03/2014 07:00 | 0.2 | 13.1 | 1,943.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/03/2014 08:00 | 0.2 | 13.0 | 2,024.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/03/2014 09:00 | 0.2 | 12.8 | 2,063.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/03/2014 10:00 | 0.2 | 12.7 | 2,076.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/03/2014 11:00 | 0.2 | 12.7 | 2,060.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/03/2014 12:00 | 0.2 | 12.8 | 2,022.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/03/2014 13:00 | 0.2 | 12.8 | 2,006.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/03/2014 14:00 | 0.2 | 12.8 | 1,992.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/03/2014 15:00 | 0.4 | 13.0 | 1,956.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/03/2014 16:00 | 0.2 | 12.7 | 2,001.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/03/2014 17:00 | 0.4 | 12.4 | 2,071.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/03/2014 18:00 | 0.4 | 12.1 | 2,154.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/03/2014 19:00 | 0.4 | 12.3 | 2,120.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/03/2014 20:00 | 0.4 | 12.3 | 2,122.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/03/2014 21:00 | 0.5 | 11.8 | 2,235.0 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/03/2014 22:00 | 0.5 | 11.9 | 2,209.3 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/03/2014 23:00 | 0.5 | 12.1 | 2,168.5 | 0.5 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 12.9 | 1,903.2 | 0.5 | 0.6 | 24 # | 24 # | 20 # |
| **Minimum:** | 0.2 | 11.8 | 1,249.2 | 0.4 | 0.4 | 1 | 1 | 0 |
| **Maximum:** | 0.6 | 13.9 | 2,235.0 | 0.6 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/04/2014 00:00 | 0.4 | 12.6 | 2,081.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/04/2014 01:00 | 0.4 | 12.5 | 2,114.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/04/2014 02:00 | 0.7 | 13.8 | 1,628.9 | 0.7 | 0.5 | 1 | 1 | 1 |
| 01/04/2014 03:00 | 0.6 | 13.9 | 1,596.5 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/04/2014 04:00 | 0.6 | 13.9 | 1,428.6 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/04/2014 05:00 | 0.6 | 13.8 | 1,657.9 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/04/2014 06:00 | 0.6 | 13.8 | 1,681.7 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/04/2014 07:00 | 0.6 | 13.7 | 1,836.6 | 0.6 | 0.6 | 1 | 1 | 0 |
| 01/04/2014 08:00 | 0.4 | 13.2 | 1,925.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/04/2014 09:00 | 0.2 | 12.4 | 2,142.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/04/2014 10:00 | 0.4 | 12.6 | 2,072.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/04/2014 11:00 | 0.4 | 12.8 | 2,006.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/04/2014 12:00 | 0.4 | 13.1 | 1,933.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/04/2014 13:00 | 0.4 | 13.3 | 1,883.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/04/2014 14:00 | 0.4 | 12.8 | 1,991.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/04/2014 15:00 | 0.4 | 12.6 | 2,032.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/04/2014 16:00 | 0.4 | 12.5 | 2,054.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/04/2014 17:00 | 0.4 | 12.4 | 2,096.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/04/2014 18:00 | 0.4 | 12.2 | 2,145.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/04/2014 19:00 | 0.5 | 12.2 | 2,148.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/04/2014 20:00 | 0.4 | 12.6 | 2,061.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/04/2014 21:00 | 0.5 | 12.0 | 2,200.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/04/2014 22:00 | 0.5 | 11.9 | 2,225.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/04/2014 23:00 | 0.4 | 12.6 | 2,072.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.5 | 12.9 | 1,959.1 | 0.5 | 0.6 | 24 # | 24 # | 19 # |
| **Minimum:** | 0.2 | 11.9 | 1,428.6 | 0.4 | 0.4 | 1 | 1 | 0 |
| **Maximum:** | 0.7 | 13.9 | 2,225.8 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/05/2014 00:00 | 0.4 | 12.7 | 2,052.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/05/2014 01:00 | 0.4 | 12.5 | 2,089.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/05/2014 02:00 | 0.7 | 13.8 | 1,619.7 | 0.7 | 0.5 | 1 | 1 | 1 |
| 01/05/2014 03:00 | 0.6 | 13.9 | 1,600.5 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/05/2014 04:00 | 0.6 | 13.9 | 1,700.5 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/05/2014 05:00 | 0.6 | 13.8 | 1,819.0 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/05/2014 06:00 | 0.2 | 13.0 | 1,899.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/05/2014 07:00 | 0.2 | 12.5 | 2,125.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/05/2014 08:00 | 0.5 | 11.9 | 2,260.4 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/05/2014 09:00 | 0.5 | 12.0 | 2,224.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/05/2014 10:00 | 0.4 | 12.6 | 2,092.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/05/2014 11:00 | 0.4 | 12.9 | 2,013.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/05/2014 12:00 | 0.4 | 13.2 | 1,934.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/05/2014 13:00 | 0.4 | 13.0 | 1,953.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/05/2014 14:00 | 0.4 | 12.7 | 2,021.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/05/2014 15:00 | 0.7 | 13.9 | 1,633.4 | 0.7 | 0.5 | 1 | 1 | 1 |
| 01/05/2014 16:00 | 0.5 | 13.1 | 1,882.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/05/2014 17:00 | 0.5 | 12.0 | 2,187.4 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/05/2014 18:00 | 0.5 | 11.8 | 2,225.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/05/2014 19:00 | 0.7 | 11.8 | 2,236.5 | 0.7 | 0.7 | 1 | 1 | 1 |
| 01/05/2014 20:00 | 0.7 | 11.8 | 2,247.7 | 0.7 | 0.7 | 1 | 1 | 1 |
| 01/05/2014 21:00 | 0.7 | 11.8 | 2,247.6 | 0.7 | 0.7 | 1 | 1 | 1 |
| 01/05/2014 22:00 | 0.5 | 11.8 | 2,256.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/05/2014 23:00 | 0.5 | 12.1 | 2,218.5 | 0.5 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.5 | 12.7 | 2,022.6 | 0.5 | 0.6 | 24 # | 24 # | 21 # |
| **Minimum:** | 0.2 | 11.8 | 1,600.5 | 0.4 | 0.5 | 1 | 1 | 0 |
| **Maximum:** | 0.7 | 13.9 | 2,260.4 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/06/2014 00:00 | 0.5 | 12.1 | 2,208.2 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 01:00 | 0.4 | 12.4 | 2,136.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/06/2014 02:00 | 0.4 | 12.3 | 2,171.6 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 03:00 | 0.4 | 12.8 | 2,060.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/06/2014 04:00 | 0.4 | 12.9 | 2,040.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/06/2014 05:00 | 0.4 | 12.2 | 2,210.4 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 06:00 | 0.4 | 12.7 | 2,108.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/06/2014 07:00 | 0.4 | 12.7 | 2,076.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/06/2014 08:00 | 0.4 | 12.2 | 2,195.7 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 09:00 | 0.4 | 12.4 | 2,169.6 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 10:00 | 0.4 | 12.3 | 2,206.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 11:00 | 0.5 | 12.0 | 2,235.2 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 12:00 | 0.5 | 12.0 | 2,238.4 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 13:00 | 0.5 | 11.9 | 2,247.2 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 14:00 | 0.5 | 12.2 | 2,156.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/06/2014 15:00 | 0.4 | 12.8 | 2,037.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/06/2014 16:00 | 0.4 | 12.7 | 2,048.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/06/2014 17:00 | 0.4 | 12.5 | 2,109.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/06/2014 18:00 | 0.4 | 12.4 | 2,128.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/06/2014 19:00 | 0.5 | 11.9 | 2,250.3 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 20:00 | 0.4 | 12.3 | 2,147.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/06/2014 21:00 | 0.5 | 11.8 | 2,262.9 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 22:00 | 0.5 | 11.8 | 2,277.0 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 23:00 | 0.4 | 12.3 | 2,150.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 12.3 | 2,161.4 | 0.5 | 0.7 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.4 | 11.8 | 2,037.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.5 | 12.9 | 2,277.0 | 0.5 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/07/2014 00:00 | 0.4 | 12.9 | 1,997.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/07/2014 01:00 | 0.5 | 13.3 | 1,770.3 | 0.5 | 0.5 | 1 | 1 | 1 |
| 01/07/2014 02:00 | 0.6 | 13.9 | 1,493.5 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/07/2014 03:00 | 0.6 | 13.9 | 1,598.9 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/07/2014 04:00 | 0.6 | 13.9 | 1,581.3 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/07/2014 05:00 | 0.6 | 13.9 | 1,597.1 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/07/2014 06:00 | 0.2 | 13.2 | 1,819.7 | 0.4 | 0.5 | 1 | 1 | 1 |
| 01/07/2014 07:00 | 0.2 | 13.0 | 2,049.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/07/2014 08:00 | 0.4 | 12.3 | 2,204.2 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/07/2014 09:00 | 0.4 | 12.3 | 2,195.2 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/07/2014 10:00 | 0.4 | 12.6 | 2,122.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/07/2014 11:00 | 0.4 | 12.7 | 2,088.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/07/2014 12:00 | 0.5 | 11.9 | 2,247.6 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/07/2014 13:00 | 0.5 | 11.9 | 2,242.9 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/07/2014 14:00 | 0.4 | 12.5 | 2,099.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/07/2014 15:00 | 0.4 | 12.4 | 2,111.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/07/2014 16:00 | 0.4 | 12.8 | 2,017.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/07/2014 17:00 | 0.2 | 12.8 | 2,020.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/07/2014 18:00 | 0.2 | 12.6 | 2,071.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/07/2014 19:00 | 0.4 | 12.0 | 2,205.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/07/2014 20:00 | 0.5 | 11.8 | 2,250.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/07/2014 21:00 | 0.4 | 12.5 | 2,101.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/07/2014 22:00 | 0.4 | 12.7 | 2,076.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/07/2014 23:00 | 0.4 | 13.1 | 1,906.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 12.8 | 1,994.5 | 0.5 | 0.6 | 24 # | 24 # | 20 # |
| **Minimum:** | 0.2 | 11.8 | 1,493.5 | 0.4 | 0.4 | 1 | 1 | 0 |
| **Maximum:** | 0.6 | 13.9 | 2,250.8 | 0.6 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/08/2014 00:00 | 0.6 | 13.9 | 1,365.7 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/08/2014 01:00 | 0.6 | 13.9 | 1,315.8 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/08/2014 02:00 | 0.6 | 13.9 | 1,290.4 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/08/2014 03:00 | 0.6 | 13.9 | 1,265.7 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/08/2014 04:00 | 0.6 | 13.9 | 1,298.1 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/08/2014 05:00 | 0.6 | 13.8 | 1,639.0 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/08/2014 06:00 | 0.4 | 13.4 | 1,723.6 | 0.4 | 0.5 | 1 | 1 | 1 |
| 01/08/2014 07:00 | 0.4 | 13.3 | 1,967.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/08/2014 08:00 | 0.2 | 12.9 | 2,041.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/08/2014 09:00 | 0.5 | 13.5 | 1,787.5 | 0.5 | 0.5 | 1 | 1 | 1 |
| 01/08/2014 10:00 | 0.6 | 13.9 | 1,242.9 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/08/2014 11:00 | 0.6 | 13.9 | 1,383.0 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/08/2014 12:00 | 0.6 | 13.7 | 1,709.3 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/08/2014 13:00 | 0.6 | 13.9 | 1,485.5 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/08/2014 14:00 | 0.6 | 13.9 | 1,259.9 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/08/2014 15:00 | 0.6 | 13.9 | 1,405.6 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/08/2014 16:00 | 0.6 | 13.9 | 1,530.6 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/08/2014 17:00 | 0.4 | 13.4 | 1,806.3 | 0.4 | 0.5 | 1 | 1 | 1 |
| 01/08/2014 18:00 | 0.6 | 13.9 | 1,438.8 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/08/2014 19:00 | 0.6 | 13.9 | 1,537.7 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/08/2014 20:00 | 0.6 | 13.9 | 1,495.5 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/08/2014 21:00 | 0.6 | 13.9 | 1,488.5 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/08/2014 22:00 | 0.0 | 15.4 | 746.3 | 0.0 | 0.2 | 1 | 0 | 0 |
| 01/08/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.5 | 13.8 | 1,488.0 | 0.5 | 0.4 | 23 # | 22 # | 5 # |
| **Minimum:** | 0.0 | 12.9 | 746.3 | 0.0 | 0.2 | 0 | 0 | 0 |
| **Maximum:** | 0.6 | 15.4 | 2,041.8 | 0.6 | 0.6 | 1 | 1 | 1 |
| **%SI** | 4.2 | 4.2 | 4.2 | 4.2 | 4.2 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/09/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/10/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/12/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/13/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/14/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/15/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 08:00 | 0.0 | 17.6 | 504.0 | 0.0 | 0.2 | 1 | 0 | 0 |
| 01/29/2014 09:00 | 0.0 | 17.1 | 609.7 | 0.0 | 0.2 | 1 | 0 | 0 |
| 01/29/2014 10:00 | 0.0 | 17.9 | 630.0 | 0.0 | 0.2 | 1 | 0 | 0 |
| 01/29/2014 11:00 | 0.0 | 17.6 | 640.8 | 0.0 | 0.2 | 1 | 0 | 0 |
| 01/29/2014 12:00 | 0.0 | 14.8 | 1,304.2 | 0.0 | 0.4 | 1 | 0 | 0 |
| 01/29/2014 13:00 | 0.6 | 13.7 | 1,821.8 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/29/2014 14:00 | 0.6 | 13.7 | 1,811.7 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/29/2014 15:00 | 0.6 | 13.8 | 1,657.1 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/29/2014 16:00 | 0.6 | 13.9 | 1,283.9 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/29/2014 17:00 | 0.6 | 13.8 | 1,541.8 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/29/2014 18:00 | 0.6 | 13.7 | 1,816.9 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/29/2014 19:00 | 0.6 | 13.7 | 1,816.0 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/29/2014 20:00 | 0.6 | 13.8 | 1,758.1 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/29/2014 21:00 | 0.6 | 13.8 | 1,813.2 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/29/2014 22:00 | 0.6 | 13.8 | 1,668.8 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/29/2014 23:00 | 0.6 | 13.9 | 1,295.1 | 0.6 | 0.4 | 1 | 1 | 0 |
| **Average/Sum#:** | 0.4 | 14.8 | 1,373.3 | 0.4 | 0.4 | 16 # | 11 # | 0 # |
| **Minimum:** | 0.0 | 13.7 | 504.0 | 0.0 | 0.2 | 0 | 0 | 0 |
| **Maximum:** | 0.6 | 17.9 | 1,821.8 | 0.6 | 0.5 | 1 | 1 | 0 |
| **%SI** | 33.3 | 33.3 | 33.3 | 33.3 | 33.3 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/30/2014 00:00 | 0.6 | 13.9 | 1,466.4 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/30/2014 01:00 | 0.6 | 13.8 | 1,750.8 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/30/2014 02:00 | 0.6 | 13.9 | 1,330.0 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/30/2014 03:00 | 0.6 | 13.9 | 1,261.5 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/30/2014 04:00 | 0.6 | 13.9 | 1,285.1 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/30/2014 05:00 | 0.6 | 13.9 | 1,259.6 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/30/2014 06:00 | 0.6 | 13.9 | 1,452.1 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/30/2014 07:00 | 0.6 | 13.9 | 1,548.5 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/30/2014 08:00 | 0.6 | 13.9 | 1,560.7 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/30/2014 09:00 | 0.6 | 13.9 | 1,247.8 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/30/2014 10:00 | 0.7 | 13.8 | 1,519.4 | 0.7 | 0.5 | 1 | 1 | 1 |
| 01/30/2014 11:00 | 0.2 | 13.1 | 1,950.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/30/2014 12:00 | 0.2 | 12.9 | 1,981.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/30/2014 13:00 | 0.2 | 12.4 | 2,103.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/30/2014 14:00 | 0.5 | 11.9 | 2,194.7 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/30/2014 15:00 | 0.5 | 11.8 | 2,222.2 | 0.5 | 0.7 | 1 | 1 | 1 |
| 01/30/2014 16:00 | 0.5 | 12.8 | 1,882.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/30/2014 17:00 | 0.6 | 13.9 | 1,570.2 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/30/2014 18:00 | 0.6 | 13.9 | 1,640.6 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/30/2014 19:00 | 0.4 | 13.0 | 1,929.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/30/2014 20:00 | 0.4 | 12.5 | 2,085.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/30/2014 21:00 | 0.4 | 12.6 | 2,066.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/30/2014 22:00 | 0.4 | 12.9 | 2,001.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/30/2014 23:00 | 0.2 | 12.9 | 2,003.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.5 | 13.3 | 1,721.4 | 0.5 | 0.5 | 24 # | 24 # | 12 # |
| **Minimum:** | 0.2 | 11.8 | 1,247.8 | 0.4 | 0.4 | 1 | 1 | 0 |
| **Maximum:** | 0.7 | 13.9 | 2,222.2 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/31/2014 00:00 | 0.7 | 13.6 | 1,555.3 | 0.7 | 0.5 | 1 | 1 | 1 |
| 01/31/2014 01:00 | 0.6 | 13.9 | 1,491.4 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/31/2014 02:00 | 0.6 | 14.5 | 1,624.9 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/31/2014 03:00 | 0.6 | 13.9 | 1,411.5 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/31/2014 04:00 | 0.6 | 13.9 | 1,329.4 | 0.6 | 0.4 | 1 | 1 | 0 |
| 01/31/2014 05:00 | 0.6 | 13.8 | 1,769.3 | 0.6 | 0.5 | 1 | 1 | 0 |
| 01/31/2014 06:00 | 0.2 | 13.2 | 1,938.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/31/2014 07:00 | 0.4 | 13.3 | 1,912.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/31/2014 08:00 | 0.2 | 13.1 | 2,002.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/31/2014 09:00 | 0.2 | 13.2 | 1,973.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/31/2014 10:00 | 0.4 | 13.2 | 1,970.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/31/2014 11:00 | 0.4 | 13.2 | 1,958.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/31/2014 12:00 | 0.2 | 12.9 | 2,007.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/31/2014 13:00 | 0.4 | 12.8 | 2,006.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/31/2014 14:00 | 0.4 | 13.1 | 1,960.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/31/2014 15:00 | 0.4 | 13.2 | 1,940.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/31/2014 16:00 | 0.4 | 13.2 | 1,924.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/31/2014 17:00 | 0.4 | 13.1 | 1,952.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/31/2014 18:00 | 0.4 | 13.2 | 1,936.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 01/31/2014 19:00 | 0.4 | 12.6 | 2,088.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/31/2014 20:00 | 0.4 | 12.8 | 2,030.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/31/2014 21:00 | 0.4 | 12.6 | 2,079.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/31/2014 22:00 | 0.4 | 12.3 | 2,144.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 01/31/2014 23:00 | 0.4 | 12.4 | 2,128.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 13.2 | 1,880.7 | 0.5 | 0.6 | 24 # | 24 # | 19 # |
| **Minimum:** | 0.2 | 12.3 | 1,329.4 | 0.4 | 0.4 | 1 | 1 | 0 |
| **Maximum:** | 0.7 | 14.5 | 2,144.4 | 0.7 | 0.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/01/2014 00:00 | 0.5 | 13.3 | 1,810.9 | 0.5 | 0.5 | 1 | 1 | 1 |
| 02/01/2014 01:00 | 0.6 | 13.9 | 1,623.7 | 0.6 | 0.5 | 1 | 1 | 0 |
| 02/01/2014 02:00 | 0.6 | 13.9 | 1,658.6 | 0.6 | 0.5 | 1 | 1 | 0 |
| 02/01/2014 03:00 | 0.6 | 13.8 | 1,786.0 | 0.6 | 0.5 | 1 | 1 | 0 |
| 02/01/2014 04:00 | 0.6 | 13.9 | 1,468.3 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/01/2014 05:00 | 0.4 | 13.3 | 1,870.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/01/2014 06:00 | 0.4 | 11.9 | 2,252.9 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/01/2014 07:00 | 0.5 | 12.0 | 2,254.5 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/01/2014 08:00 | 0.4 | 12.2 | 2,206.7 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/01/2014 09:00 | 0.4 | 12.5 | 2,146.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/01/2014 10:00 | 0.5 | 13.4 | 1,854.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/01/2014 11:00 | 0.6 | 13.9 | 1,570.9 | 0.6 | 0.5 | 1 | 1 | 0 |
| 02/01/2014 12:00 | 0.6 | 13.9 | 1,539.8 | 0.6 | 0.5 | 1 | 1 | 0 |
| 02/01/2014 13:00 | 0.6 | 13.9 | 1,590.7 | 0.6 | 0.5 | 1 | 1 | 0 |
| 02/01/2014 14:00 | 0.6 | 13.9 | 1,443.1 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/01/2014 15:00 | 0.6 | 13.9 | 1,262.0 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/01/2014 16:00 | 0.6 | 13.9 | 1,312.7 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/01/2014 17:00 | 0.5 | 13.6 | 1,689.6 | 0.5 | 0.5 | 1 | 1 | 1 |
| 02/01/2014 18:00 | 0.2 | 12.8 | 2,031.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/01/2014 19:00 | 0.5 | 12.0 | 2,215.4 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/01/2014 20:00 | 0.5 | 11.8 | 2,261.9 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/01/2014 21:00 | 0.5 | 11.8 | 2,268.9 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/01/2014 22:00 | 0.5 | 11.9 | 2,268.3 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/01/2014 23:00 | 0.5 | 12.0 | 2,255.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.5 | 13.1 | 1,860.2 | 0.5 | 0.6 | 24 # | 24 # | 14 # |
| **Minimum:** | 0.2 | 11.8 | 1,262.0 | 0.4 | 0.4 | 1 | 1 | 0 |
| **Maximum:** | 0.6 | 13.9 | 2,268.9 | 0.6 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/02/2014 00:00 | 0.4 | 12.3 | 2,194.0 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 01:00 | 0.2 | 12.6 | 2,104.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/02/2014 02:00 | 0.2 | 12.7 | 2,103.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/02/2014 03:00 | 0.2 | 12.7 | 2,107.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/02/2014 04:00 | 0.2 | 12.9 | 2,058.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/02/2014 05:00 | 0.2 | 12.9 | 2,060.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/02/2014 06:00 | 0.2 | 12.8 | 2,075.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/02/2014 07:00 | 0.4 | 12.2 | 2,227.4 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 08:00 | 0.4 | 12.0 | 2,267.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 09:00 | 0.4 | 12.0 | 2,268.6 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 10:00 | 0.5 | 11.9 | 2,269.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 11:00 | 0.5 | 11.9 | 2,269.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 12:00 | 0.5 | 11.9 | 2,259.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 13:00 | 0.5 | 12.0 | 2,241.0 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 14:00 | 0.4 | 12.5 | 2,109.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/02/2014 15:00 | 0.5 | 11.9 | 2,243.7 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 16:00 | 0.5 | 11.8 | 2,274.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 17:00 | 0.4 | 12.2 | 2,174.6 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 18:00 | 0.4 | 13.1 | 1,994.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/02/2014 19:00 | 0.4 | 12.4 | 2,143.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/02/2014 20:00 | 0.5 | 11.9 | 2,247.7 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 21:00 | 0.5 | 11.8 | 2,272.7 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 22:00 | 0.4 | 12.1 | 2,196.3 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 23:00 | 0.5 | 11.9 | 2,251.9 | 0.5 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 12.3 | 2,184.0 | 0.5 | 0.7 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 11.8 | 1,994.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.5 | 13.1 | 2,274.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/03/2014 00:00 | 0.5 | 12.0 | 2,238.4 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/03/2014 01:00 | 0.4 | 12.5 | 2,128.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/03/2014 02:00 | 0.4 | 12.9 | 2,034.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/03/2014 03:00 | 0.4 | 13.0 | 1,999.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/03/2014 04:00 | 0.2 | 13.0 | 2,048.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/03/2014 05:00 | 0.2 | 12.6 | 2,138.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/03/2014 06:00 | 0.2 | 12.9 | 2,085.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/03/2014 07:00 | 0.2 | 12.7 | 2,098.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/03/2014 08:00 | 0.4 | 12.1 | 2,252.0 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/03/2014 09:00 | 0.4 | 12.2 | 2,209.6 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/03/2014 10:00 | 0.4 | 12.6 | 2,112.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/03/2014 11:00 | 0.4 | 13.2 | 1,929.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/03/2014 12:00 | 0.4 | 13.2 | 1,952.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/03/2014 13:00 | 0.2 | 12.9 | 2,015.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/03/2014 14:00 | 0.2 | 12.9 | 2,020.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/03/2014 15:00 | 0.4 | 13.0 | 1,979.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/03/2014 16:00 | 0.2 | 12.9 | 2,005.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/03/2014 17:00 | 0.4 | 12.6 | 2,088.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/03/2014 18:00 | 0.5 | 11.9 | 2,232.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/03/2014 19:00 | 0.5 | 11.8 | 2,268.7 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/03/2014 20:00 | 0.5 | 11.8 | 2,271.7 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/03/2014 21:00 | 0.5 | 11.8 | 2,268.2 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/03/2014 22:00 | 0.5 | 12.0 | 2,242.9 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/03/2014 23:00 | 0.4 | 12.3 | 2,152.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 12.5 | 2,115.5 | 0.5 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 11.8 | 1,929.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.5 | 13.2 | 2,271.7 | 0.5 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/04/2014 00:00 | 0.2 | 12.7 | 2,099.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 01:00 | 0.2 | 13.0 | 2,038.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 02:00 | 0.4 | 13.1 | 1,954.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 03:00 | 0.4 | 13.1 | 2,010.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 04:00 | 0.4 | 13.2 | 1,901.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 05:00 | 0.4 | 13.2 | 1,871.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 06:00 | 0.2 | 12.7 | 2,031.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 07:00 | 0.2 | 12.8 | 2,063.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 08:00 | 0.2 | 12.9 | 2,065.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 09:00 | 0.4 | 13.1 | 2,011.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 10:00 | 0.2 | 13.0 | 2,046.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 11:00 | 0.2 | 12.9 | 2,047.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 12:00 | 0.4 | 13.0 | 2,006.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 13:00 | 0.4 | 13.2 | 1,948.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 14:00 | 0.2 | 12.8 | 2,035.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 15:00 | 0.2 | 12.6 | 2,081.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 16:00 | 0.2 | 12.7 | 2,043.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 17:00 | 0.2 | 12.8 | 2,050.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 18:00 | 0.4 | 12.4 | 2,134.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 19:00 | 0.5 | 12.0 | 2,225.6 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/04/2014 20:00 | 0.4 | 12.1 | 2,200.3 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/04/2014 21:00 | 0.5 | 11.9 | 2,253.6 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/04/2014 22:00 | 0.5 | 12.0 | 2,238.7 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/04/2014 23:00 | 0.4 | 12.5 | 2,126.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.3 | 12.7 | 2,062.0 | 0.4 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 11.9 | 1,871.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.5 | 13.2 | 2,253.6 | 0.5 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/05/2014 00:00 | 0.2 | 12.8 | 2,068.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/05/2014 01:00 | 0.4 | 13.2 | 1,905.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/05/2014 02:00 | 0.4 | 13.2 | 1,874.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/05/2014 03:00 | 0.4 | 13.2 | 1,874.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/05/2014 04:00 | 0.4 | 13.2 | 1,875.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/05/2014 05:00 | 0.4 | 13.2 | 1,915.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/05/2014 06:00 | 0.2 | 13.0 | 1,976.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/05/2014 07:00 | 0.2 | 12.5 | 2,146.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/05/2014 08:00 | 0.4 | 12.0 | 2,261.9 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/05/2014 09:00 | 0.4 | 12.8 | 2,099.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/05/2014 10:00 | 0.7 | 13.8 | 1,351.7 | 0.7 | 0.4 | 1 | 1 | 1 |
| 02/05/2014 11:00 | 0.5 | 13.5 | 1,561.4 | 0.5 | 0.5 | 1 | 1 | 1 |
| 02/05/2014 12:00 | 0.4 | 11.9 | 2,276.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/05/2014 13:00 | 0.4 | 12.1 | 2,193.5 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/05/2014 14:00 | 0.4 | 13.2 | 1,908.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/05/2014 15:00 | 0.4 | 13.2 | 1,882.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/05/2014 16:00 | 0.2 | 13.2 | 1,903.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/05/2014 17:00 | 0.2 | 12.8 | 2,042.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/05/2014 18:00 | 0.2 | 12.6 | 2,087.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/05/2014 19:00 | 0.4 | 11.9 | 2,237.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/05/2014 20:00 | 0.5 | 11.9 | 2,256.9 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/05/2014 21:00 | 0.5 | 11.9 | 2,258.5 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/05/2014 22:00 | 0.5 | 11.9 | 2,260.5 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/05/2014 23:00 | 0.5 | 11.9 | 2,260.5 | 0.5 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 12.7 | 2,020.0 | 0.5 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 11.9 | 1,351.7 | 0.4 | 0.4 | 1 | 1 | 1 |
| **Maximum:** | 0.7 | 13.8 | 2,276.8 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/06/2014 00:00 | 0.5 | 12.0 | 2,221.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/06/2014 01:00 | 0.4 | 13.0 | 1,976.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 02:00 | 0.4 | 13.1 | 1,868.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 03:00 | 0.4 | 13.1 | 1,869.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 04:00 | 0.4 | 13.1 | 1,873.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 05:00 | 0.4 | 13.1 | 1,873.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 06:00 | 0.4 | 13.1 | 1,882.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 07:00 | 0.4 | 13.2 | 1,904.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 08:00 | 0.2 | 13.1 | 1,959.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 09:00 | 0.4 | 13.2 | 1,929.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 10:00 | 0.4 | 13.2 | 1,887.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 11:00 | 0.4 | 13.2 | 1,875.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 12:00 | 0.4 | 13.2 | 1,862.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 13:00 | 0.4 | 13.2 | 1,869.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 14:00 | 0.4 | 13.2 | 1,867.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 15:00 | 0.4 | 13.2 | 1,902.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 16:00 | 0.4 | 13.2 | 1,868.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 17:00 | 0.4 | 13.2 | 1,916.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 18:00 | 0.4 | 13.3 | 1,900.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 19:00 | 0.4 | 13.2 | 1,945.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 20:00 | 0.4 | 13.2 | 1,895.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 21:00 | 0.4 | 13.2 | 1,881.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 22:00 | 0.4 | 13.2 | 1,882.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 23:00 | 0.4 | 13.2 | 1,882.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 13.1 | 1,908.3 | 0.4 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 12.0 | 1,862.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.5 | 13.3 | 2,221.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/07/2014 00:00 | 0.4 | 13.2 | 1,882.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/07/2014 01:00 | 0.2 | 12.9 | 2,024.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/07/2014 02:00 | 0.2 | 12.6 | 2,081.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/07/2014 03:00 | 0.2 | 12.7 | 2,077.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/07/2014 04:00 | 0.4 | 12.0 | 2,210.5 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/07/2014 05:00 | 0.4 | 12.0 | 2,217.4 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/07/2014 06:00 | 0.5 | 11.8 | 2,250.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/07/2014 07:00 | 0.5 | 11.8 | 2,265.4 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/07/2014 08:00 | 0.5 | 11.8 | 2,275.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/07/2014 09:00 | 0.4 | 12.2 | 2,174.2 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/07/2014 10:00 | 0.2 | 12.7 | 2,056.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/07/2014 11:00 | 0.2 | 12.7 | 2,056.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/07/2014 12:00 | 0.2 | 12.6 | 2,080.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/07/2014 13:00 | 0.2 | 12.7 | 2,035.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/07/2014 14:00 | 0.4 | 12.9 | 1,965.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/07/2014 15:00 | 0.4 | 13.2 | 1,881.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/07/2014 16:00 | 0.2 | 12.8 | 2,032.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/07/2014 17:00 | 0.2 | 12.7 | 2,037.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/07/2014 18:00 | 0.2 | 12.5 | 2,090.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/07/2014 19:00 | 0.5 | 11.9 | 2,228.9 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/07/2014 20:00 | 0.4 | 12.5 | 2,068.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/07/2014 21:00 | 0.2 | 12.6 | 2,062.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/07/2014 22:00 | 0.2 | 12.6 | 2,064.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/07/2014 23:00 | 0.2 | 12.6 | 2,069.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.3 | 12.5 | 2,091.2 | 0.4 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 11.8 | 1,881.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.5 | 13.2 | 2,275.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/08/2014 00:00 | 0.4 | 13.0 | 1,964.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 01:00 | 0.4 | 13.1 | 1,947.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 02:00 | 0.4 | 13.3 | 1,906.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 03:00 | 0.4 | 13.3 | 1,897.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 04:00 | 0.4 | 13.9 | 1,904.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 05:00 | 0.4 | 13.3 | 1,903.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 06:00 | 0.4 | 13.4 | 1,886.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 07:00 | 0.4 | 13.2 | 1,921.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 08:00 | 0.4 | 13.2 | 1,873.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 09:00 | 0.4 | 13.3 | 1,842.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 10:00 | 0.4 | 13.1 | 1,865.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 11:00 | 0.4 | 13.2 | 1,869.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 12:00 | 0.4 | 13.2 | 1,872.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 13:00 | 0.4 | 13.1 | 1,904.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 14:00 | 0.4 | 13.2 | 1,863.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 15:00 | 0.4 | 13.2 | 1,865.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 16:00 | 0.4 | 13.2 | 1,866.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 17:00 | 0.4 | 13.2 | 1,875.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 18:00 | 0.2 | 12.9 | 1,974.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 19:00 | 0.4 | 12.0 | 2,158.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 20:00 | 0.2 | 12.5 | 2,067.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 21:00 | 0.2 | 12.3 | 2,094.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 22:00 | 0.4 | 13.0 | 1,929.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 23:00 | 0.4 | 13.4 | 1,845.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 13.1 | 1,920.8 | 0.4 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 12.0 | 1,842.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.4 | 13.9 | 2,158.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/09/2014 00:00 | 0.4 | 13.5 | 1,839.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 01:00 | 0.2 | 13.0 | 1,940.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 02:00 | 0.4 | 13.4 | 1,853.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 03:00 | 0.4 | 13.5 | 1,840.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 04:00 | 0.4 | 13.5 | 1,839.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 05:00 | 0.4 | 13.5 | 1,835.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 06:00 | 0.4 | 13.4 | 1,849.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 07:00 | 0.2 | 13.2 | 1,861.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 08:00 | 0.2 | 13.2 | 1,858.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 09:00 | 0.4 | 13.2 | 1,862.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 10:00 | 0.4 | 13.2 | 1,862.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 11:00 | 0.4 | 13.2 | 1,853.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 12:00 | 0.4 | 13.2 | 1,853.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 13:00 | 0.4 | 13.2 | 1,853.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 14:00 | 0.4 | 13.2 | 1,856.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 15:00 | 0.4 | 13.2 | 1,857.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 16:00 | 0.4 | 13.2 | 1,884.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 17:00 | 0.4 | 13.1 | 1,889.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 18:00 | 0.2 | 12.8 | 1,977.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 19:00 | 0.5 | 11.6 | 2,238.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/09/2014 20:00 | 0.5 | 11.6 | 2,251.3 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/09/2014 21:00 | 0.5 | 11.6 | 2,254.3 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/09/2014 22:00 | 0.5 | 12.0 | 2,148.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 23:00 | 0.4 | 12.3 | 2,085.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 13.0 | 1,935.3 | 0.4 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 11.6 | 1,835.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.5 | 13.5 | 2,254.3 | 0.5 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/10/2014 00:00 | 0.7 | 13.7 | 1,487.5 | 0.7 | 0.4 | 1 | 1 | 1 |
| 02/10/2014 01:00 | 0.6 | 13.8 | 1,337.8 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/10/2014 02:00 | 0.6 | 13.8 | 1,369.2 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/10/2014 03:00 | 0.6 | 13.8 | 1,248.3 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/10/2014 04:00 | 0.6 | 13.8 | 1,248.4 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/10/2014 05:00 | 0.7 | 13.7 | 1,429.4 | 0.7 | 0.4 | 1 | 1 | 1 |
| 02/10/2014 06:00 | 0.4 | 13.3 | 1,888.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 07:00 | 0.4 | 13.1 | 1,930.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 08:00 | 0.2 | 12.9 | 2,006.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 09:00 | 0.4 | 13.2 | 1,908.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 10:00 | 0.4 | 13.1 | 1,903.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 11:00 | 0.4 | 13.2 | 1,877.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 12:00 | 0.4 | 13.2 | 1,875.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 13:00 | 0.4 | 13.2 | 1,876.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 14:00 | 0.4 | 13.2 | 1,869.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 15:00 | 0.4 | 13.2 | 1,872.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 16:00 | 0.4 | 13.2 | 1,873.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 17:00 | 0.4 | 13.2 | 1,872.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 18:00 | 0.4 | 13.1 | 1,916.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 19:00 | 0.2 | 12.6 | 2,038.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 20:00 | 0.2 | 12.6 | 2,051.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 21:00 | 0.2 | 12.2 | 2,137.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 22:00 | 0.2 | 12.8 | 2,009.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 23:00 | 0.4 | 13.4 | 1,863.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 13.2 | 1,787.2 | 0.5 | 0.6 | 24 # | 24 # | 20 # |
| **Minimum:** | 0.2 | 12.2 | 1,248.3 | 0.4 | 0.4 | 1 | 1 | 0 |
| **Maximum:** | 0.7 | 13.8 | 2,137.8 | 0.7 | 0.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/11/2014 00:00 | 0.4 | 13.3 | 1,870.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 01:00 | 0.4 | 13.2 | 1,857.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 02:00 | 0.4 | 13.2 | 1,875.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 03:00 | 0.5 | 13.4 | 1,603.0 | 0.5 | 0.5 | 1 | 1 | 1 |
| 02/11/2014 04:00 | 0.6 | 13.9 | 1,250.9 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/11/2014 05:00 | 0.7 | 13.8 | 1,513.4 | 0.7 | 0.5 | 1 | 1 | 1 |
| 02/11/2014 06:00 | 0.4 | 13.1 | 1,862.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 07:00 | 0.4 | 13.1 | 1,876.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 08:00 | 0.2 | 12.7 | 2,064.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 09:00 | 0.2 | 12.8 | 2,028.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 10:00 | 0.4 | 13.1 | 1,916.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 11:00 | 0.4 | 13.2 | 1,876.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 12:00 | 0.4 | 13.2 | 1,876.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 13:00 | 0.4 | 13.3 | 1,875.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 14:00 | 0.4 | 13.3 | 1,876.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 15:00 | 0.4 | 13.3 | 1,877.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 16:00 | 0.4 | 13.3 | 1,867.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 17:00 | 0.4 | 13.3 | 1,875.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 18:00 | 0.4 | 13.2 | 1,910.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 19:00 | 0.2 | 12.6 | 2,039.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 20:00 | 0.2 | 12.7 | 2,047.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 21:00 | 0.2 | 12.3 | 2,127.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 22:00 | 0.2 | 12.7 | 2,021.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 23:00 | 0.4 | 13.0 | 1,953.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 13.1 | 1,872.6 | 0.4 | 0.6 | 24 # | 24 # | 23 # |
| **Minimum:** | 0.2 | 12.3 | 1,250.9 | 0.4 | 0.4 | 1 | 1 | 0 |
| **Maximum:** | 0.7 | 13.9 | 2,127.2 | 0.7 | 0.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/12/2014 00:00 | 0.4 | 13.2 | 1,893.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 01:00 | 0.2 | 12.9 | 2,007.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 02:00 | 0.2 | 12.9 | 2,009.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 03:00 | 0.2 | 12.9 | 2,016.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 04:00 | 0.2 | 12.8 | 2,027.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 05:00 | 0.2 | 12.8 | 2,024.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 06:00 | 0.2 | 12.9 | 1,986.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 07:00 | 0.2 | 12.6 | 2,074.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 08:00 | 0.2 | 12.7 | 2,060.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 09:00 | 0.4 | 13.1 | 1,916.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 10:00 | 0.4 | 13.1 | 1,868.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 11:00 | 0.4 | 13.1 | 1,872.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 12:00 | 0.4 | 13.2 | 1,874.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 13:00 | 0.4 | 13.2 | 1,872.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 14:00 | 0.4 | 13.2 | 1,870.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 15:00 | 0.4 | 13.2 | 1,870.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 16:00 | 0.4 | 13.2 | 1,870.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 17:00 | 0.4 | 13.2 | 1,887.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 18:00 | 0.2 | 12.5 | 2,068.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 19:00 | 0.5 | 11.6 | 2,281.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/12/2014 20:00 | 0.5 | 11.5 | 2,303.9 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/12/2014 21:00 | 0.5 | 11.6 | 2,268.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/12/2014 22:00 | 0.4 | 12.1 | 2,176.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/12/2014 23:00 | 0.2 | 12.7 | 2,024.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.3 | 12.8 | 2,005.2 | 0.4 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 11.5 | 1,868.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.5 | 13.2 | 2,303.9 | 0.5 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/13/2014 00:00 | 0.4 | 13.1 | 1,905.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 01:00 | 0.4 | 13.2 | 1,872.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 02:00 | 0.4 | 13.1 | 1,865.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 03:00 | 0.4 | 13.1 | 1,865.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 04:00 | 0.4 | 13.1 | 1,863.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 05:00 | 0.4 | 13.1 | 1,881.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 06:00 | 0.2 | 13.0 | 1,932.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 07:00 | 0.2 | 12.4 | 2,113.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 08:00 | 0.4 | 11.8 | 2,236.4 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/13/2014 09:00 | 0.4 | 12.2 | 2,146.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 10:00 | 0.4 | 12.3 | 2,125.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 11:00 | 0.4 | 12.3 | 2,124.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 12:00 | 0.4 | 12.3 | 2,126.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 13:00 | 0.4 | 12.2 | 2,124.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 14:00 | 0.4 | 12.2 | 2,126.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 15:00 | 0.4 | 12.2 | 2,126.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 16:00 | 0.4 | 12.2 | 2,127.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 17:00 | 0.4 | 12.1 | 2,143.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 18:00 | 0.4 | 12.1 | 2,134.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 19:00 | 0.5 | 11.8 | 2,221.2 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/13/2014 20:00 | 0.5 | 11.5 | 2,273.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/13/2014 21:00 | 0.5 | 11.5 | 2,278.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/13/2014 22:00 | 0.5 | 11.7 | 2,224.2 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/13/2014 23:00 | 0.5 | 11.9 | 2,187.7 | 0.5 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 12.4 | 2,084.4 | 0.5 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 11.5 | 1,863.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.5 | 13.2 | 2,278.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/14/2014 00:00 | 0.4 | 12.5 | 2,042.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 01:00 | 0.4 | 13.2 | 1,856.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 02:00 | 0.4 | 13.2 | 1,879.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 03:00 | 0.4 | 13.2 | 1,864.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 04:00 | 0.4 | 13.2 | 1,859.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 05:00 | 0.4 | 13.2 | 1,861.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 06:00 | 0.4 | 13.2 | 1,876.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 07:00 | 0.4 | 13.1 | 1,913.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 08:00 | 0.2 | 12.8 | 2,000.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 09:00 | 0.4 | 12.3 | 2,110.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 10:00 | 0.4 | 12.1 | 2,137.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 11:00 | 0.5 | 12.0 | 2,140.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 12:00 | 0.5 | 12.0 | 2,142.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 13:00 | 0.4 | 11.9 | 2,149.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 14:00 | 0.5 | 11.9 | 2,150.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 15:00 | 0.5 | 11.9 | 2,155.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 16:00 | 0.5 | 12.0 | 2,126.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 17:00 | 0.5 | 12.0 | 2,145.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 18:00 | 0.5 | 12.0 | 2,151.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 19:00 | 0.4 | 12.3 | 2,080.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 20:00 | 0.4 | 12.4 | 2,059.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 21:00 | 0.4 | 12.2 | 2,119.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 22:00 | 0.4 | 12.1 | 2,136.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 23:00 | 0.4 | 12.5 | 2,046.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 12.5 | 2,041.9 | 0.5 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 11.9 | 1,856.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.5 | 13.2 | 2,155.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/15/2014 00:00 | 0.2 | 12.6 | 2,025.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 01:00 | 0.4 | 12.4 | 2,092.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 02:00 | 0.5 | 11.9 | 2,201.5 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/15/2014 03:00 | 0.5 | 11.8 | 2,220.2 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/15/2014 04:00 | 0.4 | 12.4 | 2,075.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 05:00 | 0.4 | 12.7 | 2,028.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 06:00 | 0.2 | 12.7 | 2,070.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 07:00 | 0.4 | 12.8 | 2,004.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 08:00 | 0.4 | 12.7 | 2,020.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 09:00 | 0.2 | 12.6 | 2,058.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 10:00 | 0.4 | 12.2 | 2,143.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 11:00 | 0.5 | 11.7 | 2,241.6 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/15/2014 12:00 | 0.5 | 11.6 | 2,245.6 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/15/2014 13:00 | 0.5 | 11.8 | 2,191.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/15/2014 14:00 | 0.4 | 12.5 | 2,042.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 15:00 | 0.4 | 12.6 | 2,015.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 16:00 | 0.4 | 12.7 | 1,981.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 17:00 | 0.4 | 12.6 | 2,008.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 18:00 | 0.4 | 12.3 | 2,084.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 19:00 | 0.5 | 11.7 | 2,223.0 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/15/2014 20:00 | 0.5 | 11.8 | 2,205.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/15/2014 21:00 | 0.5 | 11.8 | 2,218.5 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/15/2014 22:00 | 0.4 | 12.1 | 2,134.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 23:00 | 0.4 | 13.0 | 1,941.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 12.3 | 2,103.1 | 0.5 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 11.6 | 1,941.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.5 | 13.0 | 2,245.6 | 0.5 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/16/2014 00:00 | 0.4 | 13.3 | 1,883.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/16/2014 01:00 | 0.4 | 13.3 | 1,891.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/16/2014 02:00 | 0.4 | 13.2 | 1,916.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/16/2014 03:00 | 0.5 | 13.4 | 1,730.0 | 0.5 | 0.5 | 1 | 1 | 1 |
| 02/16/2014 04:00 | 0.6 | 13.9 | 1,277.6 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/16/2014 05:00 | 0.6 | 13.8 | 1,478.7 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/16/2014 06:00 | 0.4 | 13.4 | 1,657.8 | 0.4 | 0.5 | 1 | 1 | 1 |
| 02/16/2014 07:00 | 0.2 | 13.0 | 1,985.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/16/2014 08:00 | 0.5 | 13.4 | 1,895.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/16/2014 09:00 | 0.5 | 13.6 | 1,856.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/16/2014 10:00 | 0.5 | 13.6 | 1,851.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/16/2014 11:00 | 0.5 | 13.6 | 1,849.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/16/2014 12:00 | 0.5 | 13.6 | 1,848.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/16/2014 13:00 | 0.5 | 13.6 | 1,836.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/16/2014 14:00 | 0.5 | 13.5 | 1,840.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/16/2014 15:00 | 0.5 | 13.5 | 1,856.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/16/2014 16:00 | 0.5 | 13.5 | 1,841.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/16/2014 17:00 | 0.5 | 13.5 | 1,844.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/16/2014 18:00 | 0.4 | 13.0 | 1,947.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/16/2014 19:00 | 0.5 | 11.9 | 2,221.9 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/16/2014 20:00 | 0.5 | 11.7 | 2,253.2 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/16/2014 21:00 | 0.5 | 11.7 | 2,255.4 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/16/2014 22:00 | 0.5 | 11.7 | 2,255.5 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/16/2014 23:00 | 0.4 | 12.6 | 2,051.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.5 | 13.1 | 1,888.5 | 0.5 | 0.6 | 24 # | 24 # | 22 # |
| **Minimum:** | 0.2 | 11.7 | 1,277.6 | 0.4 | 0.4 | 1 | 1 | 0 |
| **Maximum:** | 0.6 | 13.9 | 2,255.5 | 0.6 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/17/2014 00:00 | 0.4 | 13.2 | 1,891.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 01:00 | 0.4 | 13.2 | 1,877.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 02:00 | 0.5 | 13.4 | 1,769.9 | 0.5 | 0.5 | 1 | 1 | 1 |
| 02/17/2014 03:00 | 0.6 | 13.9 | 1,300.1 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/17/2014 04:00 | 0.6 | 13.8 | 1,374.2 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/17/2014 05:00 | 0.7 | 13.9 | 1,555.7 | 0.7 | 0.5 | 1 | 1 | 1 |
| 02/17/2014 06:00 | 0.7 | 13.8 | 1,826.7 | 0.7 | 0.5 | 1 | 1 | 1 |
| 02/17/2014 07:00 | 0.6 | 13.8 | 1,832.0 | 0.6 | 0.5 | 1 | 1 | 0 |
| 02/17/2014 08:00 | 0.7 | 13.8 | 1,805.0 | 0.7 | 0.5 | 1 | 1 | 1 |
| 02/17/2014 09:00 | 0.7 | 13.9 | 1,768.2 | 0.7 | 0.5 | 1 | 1 | 1 |
| 02/17/2014 10:00 | 0.4 | 13.2 | 1,867.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 11:00 | 0.4 | 13.2 | 1,865.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 12:00 | 0.4 | 13.2 | 1,864.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 13:00 | 0.4 | 13.3 | 1,860.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 14:00 | 0.4 | 13.3 | 1,863.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 15:00 | 0.4 | 13.3 | 1,869.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 16:00 | 0.4 | 13.3 | 1,864.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 17:00 | 0.4 | 13.3 | 1,863.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 18:00 | 0.4 | 13.3 | 1,889.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 19:00 | 0.4 | 13.2 | 1,927.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 20:00 | 0.2 | 12.5 | 2,085.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 21:00 | 0.5 | 11.9 | 2,210.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/17/2014 22:00 | 0.4 | 12.7 | 2,054.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 23:00 | 0.4 | 13.1 | 1,920.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.5 | 13.3 | 1,833.6 | 0.5 | 0.6 | 24 # | 24 # | 21 # |
| **Minimum:** | 0.2 | 11.9 | 1,300.1 | 0.4 | 0.4 | 1 | 1 | 0 |
| **Maximum:** | 0.7 | 13.9 | 2,210.1 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/18/2014 00:00 | 0.4 | 13.2 | 1,872.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 01:00 | 0.4 | 13.2 | 1,870.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 02:00 | 0.4 | 13.2 | 1,866.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 03:00 | 0.4 | 13.2 | 1,867.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 04:00 | 0.4 | 13.2 | 1,866.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 05:00 | 0.4 | 13.2 | 1,866.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 06:00 | 0.4 | 13.1 | 1,902.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 07:00 | 0.4 | 12.7 | 2,058.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 08:00 | 0.4 | 12.3 | 2,130.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 09:00 | 0.4 | 12.9 | 1,990.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 10:00 | 0.2 | 12.9 | 1,988.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 11:00 | 0.4 | 12.7 | 2,033.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 12:00 | 0.4 | 12.4 | 2,074.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 13:00 | 0.4 | 12.8 | 1,987.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 14:00 | 0.4 | 13.2 | 1,862.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 15:00 | 0.4 | 13.2 | 1,882.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 16:00 | 0.4 | 13.3 | 1,837.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 17:00 | 0.4 | 12.8 | 1,968.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 18:00 | 0.5 | 11.9 | 2,188.5 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/18/2014 19:00 | 0.7 | 11.6 | 2,243.4 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/18/2014 20:00 | 0.4 | 12.5 | 2,075.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 21:00 | 0.5 | 11.8 | 2,209.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/18/2014 22:00 | 0.5 | 13.1 | 1,918.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 23:00 | 0.7 | 13.7 | 1,565.3 | 0.7 | 0.5 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 12.8 | 1,963.6 | 0.5 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 11.6 | 1,565.3 | 0.4 | 0.5 | 1 | 1 | 1 |
| **Maximum:** | 0.7 | 13.7 | 2,243.4 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/19/2014 00:00 | 0.6 | 13.9 | 1,241.6 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/19/2014 01:00 | 0.6 | 13.9 | 1,402.1 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/19/2014 02:00 | 0.0 | 15.8 | 600.1 | 0.0 | 0.2 | 1 | 0 | 0 |
| 02/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 17:00 | 0.0 | 17.2 | 530.6 | 0.0 | 0.2 | 1 | 0 | 0 |
| 02/19/2014 18:00 | 0.0 | 14.1 | 1,477.2 | 0.0 | 0.4 | 1 | 0 | 1 |
| 02/19/2014 19:00 | 0.4 | 13.1 | 1,956.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/19/2014 20:00 | 0.5 | 11.9 | 2,225.4 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/19/2014 21:00 | 0.7 | 11.6 | 2,280.7 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/19/2014 22:00 | 0.5 | 12.1 | 2,180.2 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/19/2014 23:00 | 0.5 | 13.4 | 1,892.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 13.7 | 1,578.6 | 0.4 | 0.5 | 10 # | 7 # | 6 # |
| **Minimum:** | 0.0 | 11.6 | 530.6 | 0.0 | 0.2 | 0 | 0 | 0 |
| **Maximum:** | 0.7 | 17.2 | 2,280.7 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 58.3 | 58.3 | 58.3 | 58.3 | 58.3 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/20/2014 00:00 | 0.5 | 13.6 | 1,844.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/20/2014 01:00 | 0.6 | 13.9 | 1,268.8 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/20/2014 02:00 | 0.6 | 13.9 | 1,243.8 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/20/2014 03:00 | 0.6 | 13.9 | 1,243.0 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/20/2014 04:00 | 0.6 | 13.9 | 1,258.6 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/20/2014 05:00 | 0.6 | 13.9 | 1,310.8 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/20/2014 06:00 | 0.2 | 12.7 | 1,890.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/20/2014 07:00 | 0.4 | 12.6 | 2,083.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/20/2014 08:00 | 0.5 | 12.4 | 2,113.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/20/2014 09:00 | 0.5 | 13.1 | 1,901.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/20/2014 10:00 | 0.5 | 13.2 | 1,858.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/20/2014 11:00 | 0.5 | 13.2 | 1,855.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/20/2014 12:00 | 0.5 | 13.3 | 1,857.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/20/2014 13:00 | 0.4 | 12.9 | 1,963.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/20/2014 14:00 | 0.5 | 13.3 | 1,868.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/20/2014 15:00 | 0.5 | 12.9 | 1,956.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/20/2014 16:00 | 0.7 | 12.2 | 2,094.5 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/20/2014 17:00 | 0.7 | 11.7 | 2,195.1 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/20/2014 18:00 | 0.7 | 12.0 | 2,138.7 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/20/2014 19:00 | 0.7 | 11.8 | 2,202.0 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/20/2014 20:00 | 0.7 | 11.7 | 2,217.6 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/20/2014 21:00 | 0.7 | 11.8 | 2,208.8 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/20/2014 22:00 | 0.7 | 11.7 | 2,214.3 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/20/2014 23:00 | 0.7 | 12.0 | 2,169.5 | 0.7 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.6 | 12.8 | 1,873.3 | 0.6 | 0.6 | 24 # | 24 # | 19 # |
| **Minimum:** | 0.2 | 11.7 | 1,243.0 | 0.4 | 0.4 | 1 | 1 | 0 |
| **Maximum:** | 0.7 | 13.9 | 2,217.6 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/21/2014 00:00 | 0.5 | 12.5 | 2,056.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 01:00 | 0.7 | 13.4 | 1,882.1 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 02:00 | 0.7 | 13.6 | 1,840.0 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 03:00 | 0.5 | 13.6 | 1,842.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 04:00 | 0.5 | 13.6 | 1,841.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 05:00 | 0.5 | 13.6 | 1,841.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 06:00 | 0.5 | 13.5 | 1,860.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 07:00 | 0.4 | 12.9 | 2,004.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 08:00 | 0.7 | 12.0 | 2,171.1 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/21/2014 09:00 | 0.5 | 13.1 | 1,941.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 10:00 | 0.7 | 13.5 | 1,845.1 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 11:00 | 0.7 | 13.4 | 1,860.3 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 12:00 | 0.7 | 13.4 | 1,848.8 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 13:00 | 0.7 | 13.4 | 1,844.5 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 14:00 | 0.7 | 13.4 | 1,840.1 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 15:00 | 0.5 | 13.4 | 1,834.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 16:00 | 0.5 | 13.4 | 1,830.0 | 0.5 | 0.5 | 1 | 1 | 1 |
| 02/21/2014 17:00 | 0.5 | 13.3 | 1,843.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 18:00 | 0.5 | 12.6 | 1,997.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 19:00 | 0.5 | 12.2 | 2,101.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 20:00 | 0.7 | 12.1 | 2,125.6 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 21:00 | 0.7 | 11.9 | 2,176.4 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/21/2014 22:00 | 0.7 | 12.1 | 2,116.5 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/21/2014 23:00 | 0.5 | 12.4 | 2,063.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.6 | 13.0 | 1,942.0 | 0.6 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.4 | 11.9 | 1,830.0 | 0.5 | 0.5 | 1 | 1 | 1 |
| **Maximum:** | 0.7 | 13.6 | 2,176.4 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/22/2014 00:00 | 0.5 | 12.5 | 2,043.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 01:00 | 0.5 | 12.7 | 1,999.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 02:00 | 0.5 | 13.2 | 1,866.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 03:00 | 0.4 | 12.8 | 1,980.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 04:00 | 0.4 | 12.7 | 2,001.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 05:00 | 0.4 | 13.1 | 1,934.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 06:00 | 0.4 | 12.7 | 2,027.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 07:00 | 0.4 | 12.7 | 2,034.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 08:00 | 0.4 | 12.8 | 2,013.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 09:00 | 0.4 | 13.2 | 1,897.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 10:00 | 0.4 | 13.3 | 1,873.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 11:00 | 0.4 | 13.3 | 1,872.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 12:00 | 0.4 | 13.2 | 1,877.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 13:00 | 0.4 | 13.2 | 1,866.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 14:00 | 0.4 | 12.9 | 1,945.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 15:00 | 0.5 | 12.6 | 1,981.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 16:00 | 0.5 | 13.0 | 1,895.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 17:00 | 0.5 | 12.5 | 1,994.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 18:00 | 0.5 | 12.3 | 2,040.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 19:00 | 0.5 | 12.2 | 2,063.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 20:00 | 0.7 | 11.8 | 2,165.5 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 21:00 | 0.7 | 11.7 | 2,184.5 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/22/2014 22:00 | 0.7 | 11.7 | 2,189.5 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/22/2014 23:00 | 0.7 | 11.7 | 2,200.0 | 0.7 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.5 | 12.7 | 1,997.8 | 0.5 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.4 | 11.7 | 1,866.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.7 | 13.3 | 2,200.0 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/23/2014 00:00 | 0.7 | 12.0 | 2,187.7 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/23/2014 01:00 | 0.5 | 12.2 | 2,134.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 02:00 | 0.7 | 11.9 | 2,200.1 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/23/2014 03:00 | 0.7 | 11.8 | 2,210.6 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/23/2014 04:00 | 0.5 | 12.3 | 2,112.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 05:00 | 0.4 | 12.7 | 2,025.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 06:00 | 0.4 | 12.6 | 2,038.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 07:00 | 0.4 | 12.8 | 2,003.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 08:00 | 0.4 | 12.9 | 1,987.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 09:00 | 0.4 | 13.0 | 1,971.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 10:00 | 0.5 | 13.4 | 1,851.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 11:00 | 0.5 | 13.2 | 1,891.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 12:00 | 0.4 | 13.1 | 1,914.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 13:00 | 0.5 | 13.3 | 1,859.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 14:00 | 0.5 | 13.3 | 1,854.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 15:00 | 0.5 | 13.2 | 1,864.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 16:00 | 0.4 | 13.0 | 1,885.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 17:00 | 0.5 | 12.9 | 1,925.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 18:00 | 0.5 | 12.2 | 2,077.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 19:00 | 0.7 | 11.8 | 2,156.8 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 20:00 | 0.7 | 11.9 | 2,147.8 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 21:00 | 0.7 | 11.9 | 2,148.3 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 22:00 | 0.7 | 11.9 | 2,149.0 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 23:00 | 0.7 | 12.0 | 2,133.0 | 0.7 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.5 | 12.6 | 2,030.4 | 0.6 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.4 | 11.8 | 1,851.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.7 | 13.4 | 2,210.6 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/24/2014 00:00 | 0.4 | 12.8 | 1,999.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/24/2014 01:00 | 0.5 | 13.4 | 1,851.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/24/2014 02:00 | 0.5 | 13.5 | 1,796.7 | 0.5 | 0.5 | 1 | 1 | 1 |
| 02/24/2014 03:00 | 0.6 | 13.9 | 1,254.6 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/24/2014 04:00 | 0.6 | 13.9 | 1,230.8 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/24/2014 05:00 | 0.5 | 13.6 | 1,527.4 | 0.5 | 0.5 | 1 | 1 | 1 |
| 02/24/2014 06:00 | 0.4 | 13.2 | 1,895.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/24/2014 07:00 | 0.4 | 13.0 | 1,952.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/24/2014 08:00 | -0.1 | 12.5 | 2,083.2 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/24/2014 09:00 | 0.5 | 13.1 | 1,941.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/24/2014 10:00 | 0.5 | 13.5 | 1,830.0 | 0.5 | 0.5 | 1 | 1 | 1 |
| 02/24/2014 11:00 | 0.5 | 13.4 | 1,856.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/24/2014 12:00 | 0.5 | 13.4 | 1,828.8 | 0.5 | 0.5 | 1 | 1 | 1 |
| 02/24/2014 13:00 | 0.5 | 13.4 | 1,831.0 | 0.5 | 0.5 | 1 | 1 | 1 |
| 02/24/2014 14:00 | 0.5 | 13.3 | 1,825.2 | 0.5 | 0.5 | 1 | 1 | 1 |
| 02/24/2014 15:00 | 0.4 | 12.6 | 1,972.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/24/2014 16:00 | 0.4 | 12.6 | 1,965.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/24/2014 17:00 | 0.5 | 12.3 | 2,039.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/24/2014 18:00 | 0.7 | 11.9 | 2,113.2 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/24/2014 19:00 | 0.7 | 11.7 | 2,174.1 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/24/2014 20:00 | 0.7 | 11.8 | 2,156.1 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/24/2014 21:00 | 0.7 | 11.9 | 2,142.8 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/24/2014 22:00 | 0.7 | 12.0 | 2,144.1 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/24/2014 23:00 | 0.7 | 11.9 | 2,153.7 | 0.7 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.5 | 12.9 | 1,898.6 | 0.5 | 0.6 | 24 # | 24 # | 22 # |
| **Minimum:** | -0.1 | 11.7 | 1,230.8 | 0.1 | 0.4 | 1 | 1 | 0 |
| **Maximum:** | 0.7 | 13.9 | 2,174.1 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/25/2014 00:00 | 0.5 | 12.6 | 2,039.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 01:00 | 0.4 | 12.9 | 1,971.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 02:00 | 0.4 | 13.3 | 1,851.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 03:00 | 0.4 | 13.3 | 1,843.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 04:00 | 0.4 | 13.3 | 1,846.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 05:00 | 0.4 | 12.8 | 1,996.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 06:00 | 0.4 | 12.7 | 2,022.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 07:00 | 0.4 | 13.0 | 1,953.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 08:00 | 0.4 | 12.7 | 2,004.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 09:00 | 0.5 | 13.3 | 1,848.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 10:00 | 0.5 | 13.4 | 1,835.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 11:00 | 0.5 | 13.4 | 1,824.8 | 0.5 | 0.5 | 1 | 1 | 1 |
| 02/25/2014 12:00 | 0.5 | 13.4 | 1,828.1 | 0.5 | 0.5 | 1 | 1 | 1 |
| 02/25/2014 13:00 | 0.5 | 13.4 | 1,841.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 14:00 | 0.5 | 13.4 | 1,825.4 | 0.5 | 0.5 | 1 | 1 | 1 |
| 02/25/2014 15:00 | 0.5 | 13.4 | 1,828.5 | 0.5 | 0.5 | 1 | 1 | 1 |
| 02/25/2014 16:00 | 0.4 | 13.2 | 1,873.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 17:00 | 0.4 | 13.3 | 1,855.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 18:00 | 0.4 | 12.8 | 1,959.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 19:00 | 0.5 | 12.2 | 2,100.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 20:00 | 0.5 | 12.0 | 2,129.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 21:00 | 0.4 | 12.4 | 2,053.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 22:00 | 0.4 | 12.9 | 1,949.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 23:00 | 0.5 | 12.1 | 2,117.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 13.0 | 1,933.4 | 0.5 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.4 | 12.0 | 1,824.8 | 0.4 | 0.5 | 1 | 1 | 1 |
| **Maximum:** | 0.5 | 13.4 | 2,129.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/26/2014 00:00 | 0.4 | 12.9 | 1,941.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 01:00 | 0.4 | 13.2 | 1,881.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 02:00 | 0.4 | 13.2 | 1,868.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 03:00 | 0.2 | 13.2 | 1,865.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 04:00 | 0.2 | 13.2 | 1,861.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 05:00 | 0.2 | 13.1 | 1,900.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 06:00 | 0.4 | 12.2 | 2,075.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 07:00 | 0.5 | 12.1 | 2,156.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 08:00 | 0.7 | 11.7 | 2,226.5 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/26/2014 09:00 | 0.7 | 11.7 | 2,232.8 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/26/2014 10:00 | 0.7 | 0.0 | 2,238.4 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/26/2014 11:00 | 0.7 | 0.0 | 2,182.3 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/26/2014 12:00 | 0.7 | 0.0 | 2,038.6 | 0.7 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 13:00 | 0.7 | 0.0 | 2,172.9 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/26/2014 14:00 | 0.4 | 12.2 | 2,103.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 15:00 | 0.4 | 12.3 | 2,085.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 16:00 | 0.4 | 12.6 | 2,026.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 17:00 | 0.5 | 12.2 | 2,130.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 18:00 | 0.5 | 12.0 | 2,158.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 19:00 | 0.7 | 11.7 | 2,226.8 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/26/2014 20:00 | 0.7 | 11.7 | 2,213.9 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/26/2014 21:00 | 0.7 | 11.8 | 2,197.6 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/26/2014 22:00 | 0.7 | 11.8 | 2,178.5 | 0.7 | 0.7 | 1 | 1 | 1 |
| 02/26/2014 23:00 | 0.5 | 12.0 | 2,135.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.5 | 12.3 | 2,087.4 | 0.5 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 11.7 | 1,861.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.7 | 13.2 | 2,238.4 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 16.7 | 16.7 | 0.0 | 16.7 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/27/2014 00:00 | 0.4 | 12.7 | 2,001.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 01:00 | 0.4 | 13.2 | 1,883.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 02:00 | 0.7 | 13.6 | 1,567.6 | 0.7 | 0.5 | 1 | 1 | 1 |
| 02/27/2014 03:00 | 0.6 | 13.9 | 1,283.7 | 0.6 | 0.4 | 1 | 1 | 0 |
| 02/27/2014 04:00 | 0.6 | 13.8 | 1,567.1 | 0.6 | 0.5 | 1 | 1 | 0 |
| 02/27/2014 05:00 | 0.5 | 13.4 | 1,724.2 | 0.5 | 0.5 | 1 | 1 | 1 |
| 02/27/2014 06:00 | 0.2 | 13.1 | 1,915.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 07:00 | 0.4 | 13.3 | 1,888.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 08:00 | 0.4 | 12.5 | 2,045.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 09:00 | 0.4 | 13.4 | 1,861.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 10:00 | 0.2 | 13.5 | 1,847.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 11:00 | 0.2 | 13.5 | 1,844.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 12:00 | 0.4 | 13.5 | 1,845.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 13:00 | 0.5 | 13.4 | 1,848.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 14:00 | 0.5 | 13.4 | 1,844.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 15:00 | 0.5 | 13.4 | 1,846.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 16:00 | 0.5 | 13.4 | 1,847.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 17:00 | 0.4 | 13.2 | 1,908.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 18:00 | 0.4 | 13.1 | 1,912.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 19:00 | 0.2 | 12.4 | 2,082.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 20:00 | 0.2 | 12.5 | 2,062.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 21:00 | 0.2 | 12.5 | 2,070.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 22:00 | 0.2 | 12.6 | 2,048.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 23:00 | 0.2 | 12.4 | 2,072.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 13.2 | 1,867.5 | 0.5 | 0.6 | 24 # | 24 # | 22 # |
| **Minimum:** | 0.2 | 12.4 | 1,283.7 | 0.4 | 0.4 | 1 | 1 | 0 |
| **Maximum:** | 0.7 | 13.9 | 2,082.2 | 0.7 | 0.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/28/2014 00:00 | 0.4 | 13.1 | 1,927.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 01:00 | 0.4 | 13.3 | 1,882.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 02:00 | 0.4 | 13.0 | 1,945.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 03:00 | 0.4 | 13.3 | 1,881.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 04:00 | 0.4 | 13.3 | 1,883.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 05:00 | 0.4 | 13.2 | 1,898.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 06:00 | 0.4 | 13.3 | 1,893.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 07:00 | 0.4 | 13.2 | 1,906.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 08:00 | 0.2 | 12.6 | 2,047.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 09:00 | 0.4 | 12.0 | 2,177.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/28/2014 10:00 | 0.4 | 11.8 | 2,222.3 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/28/2014 11:00 | 0.4 | 11.9 | 2,203.3 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/28/2014 12:00 | 0.4 | 12.0 | 2,168.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| 02/28/2014 13:00 | 0.4 | 12.5 | 2,052.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 14:00 | 0.4 | 13.1 | 1,900.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 15:00 | 0.2 | 12.9 | 1,972.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 16:00 | 0.4 | 12.1 | 2,146.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 17:00 | 0.2 | 12.3 | 2,103.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 18:00 | 0.4 | 12.9 | 1,979.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 19:00 | 0.2 | 12.6 | 2,035.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 20:00 | 0.4 | 13.2 | 1,877.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 21:00 | 0.2 | 12.9 | 1,986.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 22:00 | 0.2 | 12.7 | 2,026.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 23:00 | 0.2 | 12.5 | 2,067.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.3 | 12.7 | 2,007.7 | 0.4 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 11.8 | 1,877.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.4 | 13.3 | 2,222.3 | 0.5 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/01/2014 00:00 | 0.2 | 12.9 | 1,971.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 01:00 | 0.4 | 13.2 | 1,893.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 02:00 | 0.4 | 13.2 | 1,865.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 03:00 | 0.4 | 13.2 | 1,869.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 04:00 | 0.4 | 13.2 | 1,871.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 05:00 | 0.4 | 13.2 | 1,884.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 06:00 | 0.4 | 13.2 | 1,868.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 07:00 | 0.4 | 13.2 | 1,868.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 08:00 | 0.4 | 13.2 | 1,878.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 09:00 | 0.4 | 13.2 | 1,873.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 10:00 | 0.4 | 13.2 | 1,877.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 11:00 | 0.4 | 13.3 | 1,872.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 12:00 | 0.4 | 13.3 | 1,868.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 13:00 | 0.4 | 13.2 | 1,893.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 14:00 | 0.2 | 12.8 | 2,023.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 15:00 | 0.2 | 12.7 | 2,030.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 16:00 | 0.4 | 13.3 | 1,903.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 17:00 | 0.4 | 13.3 | 1,868.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 18:00 | 0.4 | 13.3 | 1,870.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 19:00 | 0.2 | 12.9 | 1,978.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 20:00 | 0.4 | 12.9 | 1,960.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 21:00 | 0.2 | 12.7 | 2,017.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 22:00 | 0.2 | 12.8 | 2,018.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 23:00 | 0.2 | 12.6 | 2,050.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.3 | 13.1 | 1,919.8 | 0.4 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 12.6 | 1,865.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.4 | 13.3 | 2,050.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/02/2014 00:00 | 0.4 | 13.1 | 1,939.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 01:00 | 0.2 | 12.8 | 2,041.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 02:00 | 0.4 | 12.9 | 2,022.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 03:00 | 0.4 | 13.2 | 1,890.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 04:00 | 0.4 | 13.2 | 1,866.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 05:00 | 0.4 | 13.2 | 1,913.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 06:00 | 0.2 | 12.8 | 2,008.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 07:00 | 0.2 | 12.7 | 2,089.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 08:00 | 0.2 | 12.7 | 2,082.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 09:00 | 0.4 | 13.1 | 1,975.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 10:00 | 0.2 | 12.7 | 2,065.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 11:00 | 0.4 | 11.9 | 2,233.3 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/02/2014 12:00 | 0.4 | 12.0 | 2,209.0 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/02/2014 13:00 | 0.5 | 11.7 | 2,259.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/02/2014 14:00 | 0.5 | 11.7 | 2,250.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/02/2014 15:00 | 0.5 | 11.7 | 2,242.0 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/02/2014 16:00 | 0.5 | 11.7 | 2,239.2 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/02/2014 17:00 | 0.5 | 11.9 | 2,202.4 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/02/2014 18:00 | 0.4 | 12.2 | 2,125.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 19:00 | 0.4 | 12.2 | 2,131.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 20:00 | 0.2 | 12.5 | 2,066.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 21:00 | 0.4 | 12.2 | 2,163.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 22:00 | 0.2 | 12.7 | 2,076.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 23:00 | 0.4 | 12.9 | 2,027.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 12.5 | 2,088.4 | 0.5 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 11.7 | 1,866.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.5 | 13.2 | 2,259.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/03/2014 00:00 | 0.5 | 13.5 | 1,613.7 | 0.5 | 0.5 | 1 | 1 | 1 |
| 03/03/2014 01:00 | 0.6 | 13.8 | 1,436.4 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/03/2014 02:00 | 0.6 | 13.8 | 1,291.1 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/03/2014 03:00 | 0.6 | 13.8 | 1,288.6 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/03/2014 04:00 | 0.6 | 13.8 | 1,294.1 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/03/2014 05:00 | 0.5 | 13.5 | 1,596.4 | 0.5 | 0.5 | 1 | 1 | 1 |
| 03/03/2014 06:00 | 0.4 | 13.1 | 1,911.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/03/2014 07:00 | 0.4 | 12.8 | 2,030.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/03/2014 08:00 | 0.5 | 11.9 | 2,222.6 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/03/2014 09:00 | 0.5 | 12.0 | 2,166.8 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/03/2014 10:00 | 0.4 | 12.7 | 2,023.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/03/2014 11:00 | 0.4 | 13.0 | 1,948.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/03/2014 12:00 | 0.4 | 13.1 | 1,904.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/03/2014 13:00 | 0.4 | 13.2 | 1,882.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/03/2014 14:00 | 0.4 | 13.1 | 1,906.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/03/2014 15:00 | 0.4 | 13.1 | 1,947.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/03/2014 16:00 | 0.4 | 12.8 | 2,036.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/03/2014 17:00 | 0.5 | 11.9 | 2,217.5 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/03/2014 18:00 | 0.5 | 12.3 | 2,097.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/03/2014 19:00 | 0.7 | 11.9 | 2,205.8 | 0.7 | 0.7 | 1 | 1 | 1 |
| 03/03/2014 20:00 | 0.7 | 11.7 | 2,237.8 | 0.7 | 0.7 | 1 | 1 | 1 |
| 03/03/2014 21:00 | 0.7 | 11.8 | 2,218.3 | 0.7 | 0.7 | 1 | 1 | 1 |
| 03/03/2014 22:00 | 0.4 | 12.7 | 1,990.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/03/2014 23:00 | 0.4 | 13.1 | 1,866.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.5 | 12.9 | 1,888.9 | 0.5 | 0.6 | 24 # | 24 # | 20 # |
| **Minimum:** | 0.4 | 11.7 | 1,288.6 | 0.4 | 0.4 | 1 | 1 | 0 |
| **Maximum:** | 0.7 | 13.8 | 2,237.8 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/04/2014 00:00 | 0.5 | 13.4 | 1,579.0 | 0.5 | 0.5 | 1 | 1 | 1 |
| 03/04/2014 01:00 | 0.6 | 13.8 | 1,260.2 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/04/2014 02:00 | 0.6 | 13.8 | 1,269.8 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/04/2014 03:00 | 0.6 | 13.8 | 1,332.1 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/04/2014 04:00 | 0.6 | 13.8 | 1,279.9 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/04/2014 05:00 | 0.6 | 13.8 | 1,296.3 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/04/2014 06:00 | 0.5 | 13.4 | 1,591.9 | 0.5 | 0.5 | 1 | 1 | 1 |
| 03/04/2014 07:00 | 0.4 | 13.3 | 1,879.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/04/2014 08:00 | 0.4 | 13.3 | 1,868.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/04/2014 09:00 | 0.7 | 13.8 | 1,445.9 | 0.7 | 0.4 | 1 | 1 | 1 |
| 03/04/2014 10:00 | 0.6 | 13.9 | 1,236.5 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/04/2014 11:00 | 0.6 | 13.9 | 1,237.4 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/04/2014 12:00 | 0.6 | 13.8 | 1,268.1 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/04/2014 13:00 | 0.6 | 13.8 | 1,421.1 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/04/2014 14:00 | 0.4 | 13.3 | 1,856.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/04/2014 15:00 | 0.4 | 13.3 | 1,875.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/04/2014 16:00 | 0.4 | 13.3 | 1,876.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/04/2014 17:00 | 0.4 | 13.3 | 1,875.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/04/2014 18:00 | 0.4 | 13.2 | 1,910.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/04/2014 19:00 | 0.5 | 12.2 | 2,137.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/04/2014 20:00 | 0.5 | 12.2 | 2,111.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/04/2014 21:00 | 0.4 | 12.6 | 2,027.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/04/2014 22:00 | 0.4 | 12.9 | 1,958.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/04/2014 23:00 | 0.4 | 13.3 | 1,869.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.5 | 13.4 | 1,644.4 | 0.5 | 0.5 | 24 # | 24 # | 15 # |
| **Minimum:** | 0.4 | 12.2 | 1,236.5 | 0.4 | 0.4 | 1 | 1 | 0 |
| **Maximum:** | 0.7 | 13.9 | 2,137.8 | 0.7 | 0.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/05/2014 00:00 | 0.4 | 13.2 | 1,890.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 01:00 | 0.4 | 12.7 | 2,011.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 02:00 | 0.4 | 12.7 | 2,025.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 03:00 | 0.4 | 13.1 | 1,903.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 04:00 | 0.4 | 13.2 | 1,865.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 05:00 | 0.4 | 12.9 | 1,981.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 06:00 | 0.4 | 13.1 | 1,952.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 07:00 | 0.4 | 12.9 | 1,971.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 08:00 | 0.4 | 12.9 | 1,976.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 09:00 | 0.4 | 13.1 | 1,890.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 10:00 | 0.4 | 13.1 | 1,891.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 11:00 | 0.4 | 13.2 | 1,891.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 12:00 | 0.4 | 13.2 | 1,892.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 13:00 | 0.4 | 13.2 | 1,892.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 14:00 | 0.4 | 13.2 | 1,892.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 15:00 | 0.4 | 13.1 | 1,894.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 16:00 | 0.4 | 12.9 | 1,935.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 17:00 | 0.4 | 12.8 | 1,973.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 18:00 | 0.4 | 12.8 | 1,980.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 19:00 | 0.4 | 12.4 | 2,076.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 20:00 | 0.4 | 12.5 | 2,033.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 21:00 | 0.4 | 12.7 | 2,006.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 22:00 | 0.4 | 12.7 | 1,992.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 23:00 | 0.4 | 13.1 | 1,871.2 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 12.9 | 1,945.5 | 0.5 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.4 | 12.4 | 1,865.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.4 | 13.2 | 2,076.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/06/2014 00:00 | 0.4 | 13.2 | 1,867.0 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/06/2014 01:00 | 0.4 | 13.3 | 1,817.9 | 0.4 | 0.5 | 1 | 1 | 1 |
| 03/06/2014 02:00 | 0.6 | 13.9 | 1,275.8 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/06/2014 03:00 | 0.0 | 15.6 | 633.1 | 0.0 | 0.2 | 1 | 0 | 0 |
| 03/06/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.4 | 14.0 | 1,398.5 | 0.4 | 0.4 | 4 # | 3 # | 2 # |
| **Minimum:** | 0.0 | 13.2 | 633.1 | 0.0 | 0.2 | 0 | 0 | 0 |
| **Maximum:** | 0.6 | 15.6 | 1,867.0 | 0.6 | 0.6 | 1 | 1 | 1 |
| **%SI** | 83.3 | 83.3 | 83.3 | 83.3 | 83.3 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/07/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 07:00 | 0.0 | 17.5 | 493.3 | 0.0 | 0.1 | 1 | 0 | 0 |
| 03/07/2014 08:00 | 0.0 | 14.9 | 1,127.5 | 0.0 | 0.3 | 1 | 0 | 0 |
| 03/07/2014 09:00 | 0.6 | 13.9 | 1,337.3 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/07/2014 10:00 | 0.5 | 13.3 | 1,814.7 | 0.5 | 0.5 | 1 | 1 | 1 |
| 03/07/2014 11:00 | 0.5 | 13.2 | 1,860.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/07/2014 12:00 | 0.5 | 13.3 | 1,859.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/07/2014 13:00 | 0.5 | 13.3 | 1,856.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/07/2014 14:00 | 0.5 | 13.3 | 1,859.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/07/2014 15:00 | 0.5 | 13.3 | 1,858.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/07/2014 16:00 | 0.5 | 13.2 | 1,886.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/07/2014 17:00 | 0.4 | 12.7 | 2,027.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/07/2014 18:00 | 0.4 | 12.6 | 2,038.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/07/2014 19:00 | 0.5 | 11.9 | 2,213.7 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/07/2014 20:00 | 0.7 | 11.6 | 2,292.8 | 0.7 | 0.7 | 1 | 1 | 1 |
| 03/07/2014 21:00 | 0.7 | 11.6 | 2,288.2 | 0.7 | 0.7 | 1 | 1 | 1 |
| 03/07/2014 22:00 | 0.7 | 11.6 | 2,286.8 | 0.7 | 0.7 | 1 | 1 | 1 |
| 03/07/2014 23:00 | 0.5 | 11.9 | 2,225.4 | 0.5 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.5 | 13.1 | 1,842.7 | 0.5 | 0.6 | 17 # | 15 # | 14 # |
| **Minimum:** | 0.0 | 11.6 | 493.3 | 0.0 | 0.1 | 0 | 0 | 0 |
| **Maximum:** | 0.7 | 17.5 | 2,292.8 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 29.2 | 29.2 | 29.2 | 29.2 | 29.2 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/08/2014 00:00 | 0.4 | 12.8 | 2,018.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 01:00 | 0.4 | 12.9 | 2,000.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 02:00 | 0.4 | 13.0 | 1,950.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 03:00 | 0.4 | 13.1 | 1,927.4 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 04:00 | 0.4 | 13.0 | 1,982.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 05:00 | 0.4 | 12.8 | 2,027.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 06:00 | 0.4 | 12.6 | 2,065.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 07:00 | 0.4 | 12.7 | 2,044.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 08:00 | 0.5 | 13.1 | 1,907.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 09:00 | 0.5 | 13.2 | 1,854.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 10:00 | 0.5 | 13.2 | 1,854.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 11:00 | 0.5 | 13.2 | 1,852.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 12:00 | 0.5 | 13.2 | 1,852.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 13:00 | 0.5 | 13.3 | 1,855.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 14:00 | 0.5 | 13.3 | 1,852.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 15:00 | 0.5 | 13.3 | 1,852.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 16:00 | 0.5 | 13.3 | 1,862.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 17:00 | 0.5 | 13.2 | 1,888.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 18:00 | 0.4 | 12.2 | 2,136.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 19:00 | 0.5 | 11.6 | 2,249.6 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/08/2014 20:00 | 0.7 | 11.5 | 2,269.4 | 0.7 | 0.7 | 1 | 1 | 1 |
| 03/08/2014 21:00 | 0.7 | 11.5 | 2,262.4 | 0.7 | 0.7 | 1 | 1 | 1 |
| 03/08/2014 22:00 | 0.7 | 11.5 | 2,264.1 | 0.7 | 0.7 | 1 | 1 | 1 |
| 03/08/2014 23:00 | 0.7 | 11.7 | 2,225.8 | 0.7 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.5 | 12.7 | 2,002.4 | 0.5 | 0.6 | 24 # | 24 # | 24 # |
| **Minimum:** | 0.4 | 11.5 | 1,852.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.7 | 13.3 | 2,269.4 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/09/2014 00:00 | 0.5 | 13.0 | 1,824.6 | 0.5 | 0.5 | 1 | 1 | 1 |
| 03/09/2014 01:00 | 0.6 | 13.8 | 1,378.9 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/09/2014 02:00 | 0.0 | 15.4 | 658.8 | 0.0 | 0.2 | 1 | 0 | 0 |
| 03/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 15:00 | 0.0 | 17.1 | 537.7 | 0.0 | 0.2 | 1 | 0 | 0 |
| 03/09/2014 16:00 | 0.0 | 14.1 | 1,407.2 | 0.0 | 0.4 | 1 | 0 | 1 |
| 03/09/2014 17:00 | 0.4 | 12.5 | 2,074.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/09/2014 18:00 | 0.5 | 11.7 | 2,217.4 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/09/2014 19:00 | 0.5 | 11.6 | 2,244.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/09/2014 20:00 | 0.7 | 11.6 | 2,247.3 | 0.7 | 0.7 | 1 | 1 | 1 |
| 03/09/2014 21:00 | 0.7 | 11.6 | 2,247.7 | 0.7 | 0.7 | 1 | 1 | 1 |
| 03/09/2014 22:00 | 0.7 | 13.5 | 1,798.9 | 0.7 | 0.5 | 1 | 1 | 1 |
| 03/09/2014 23:00 | 0.6 | 13.6 | 1,799.0 | 0.6 | 0.5 | 1 | 1 | 0 |
| **Average/Sum#:** | 0.4 | 13.3 | 1,703.0 | 0.4 | 0.5 | 12 # | 9 # | 8 # |
| **Minimum:** | 0.0 | 11.6 | 537.7 | 0.0 | 0.2 | 0 | 0 | 0 |
| **Maximum:** | 0.7 | 17.1 | 2,247.7 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 50.0 | 50.0 | 50.0 | 50.0 | 50.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/10/2014 00:00 | 0.6 | 13.6 | 1,800.2 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/10/2014 01:00 | 0.6 | 13.8 | 1,314.1 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/10/2014 02:00 | 0.6 | 13.8 | 1,240.8 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/10/2014 03:00 | 0.6 | 13.8 | 1,244.4 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/10/2014 04:00 | 0.6 | 13.8 | 1,250.3 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/10/2014 05:00 | 0.6 | 13.8 | 1,529.0 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/10/2014 06:00 | 0.6 | 13.7 | 1,788.7 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/10/2014 07:00 | 0.7 | 13.7 | 1,816.3 | 0.7 | 0.5 | 1 | 1 | 1 |
| 03/10/2014 08:00 | 0.5 | 13.2 | 1,892.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/10/2014 09:00 | 0.4 | 13.1 | 1,904.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/10/2014 10:00 | 0.5 | 13.2 | 1,854.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/10/2014 11:00 | 0.5 | 13.3 | 1,859.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/10/2014 12:00 | 0.5 | 13.3 | 1,859.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/10/2014 13:00 | 0.5 | 13.2 | 1,862.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/10/2014 14:00 | 0.5 | 13.2 | 1,864.9 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/10/2014 15:00 | 0.5 | 13.3 | 1,867.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/10/2014 16:00 | 0.5 | 13.3 | 1,865.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/10/2014 17:00 | 0.5 | 13.3 | 1,862.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/10/2014 18:00 | 0.5 | 13.3 | 1,871.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/10/2014 19:00 | 0.4 | 12.1 | 2,169.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/10/2014 20:00 | 0.4 | 12.3 | 2,125.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/10/2014 21:00 | 0.5 | 13.4 | 1,740.7 | 0.5 | 0.5 | 1 | 1 | 1 |
| 03/10/2014 22:00 | 0.6 | 13.9 | 1,394.2 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/10/2014 23:00 | 0.0 | 15.7 | 609.4 | 0.0 | 0.2 | 1 | 0 | 0 |
| **Average/Sum#:** | 0.5 | 13.5 | 1,691.2 | 0.5 | 0.5 | 24 # | 23 # | 15 # |
| **Minimum:** | 0.0 | 12.1 | 609.4 | 0.0 | 0.2 | 1 | 0 | 0 |
| **Maximum:** | 0.7 | 15.7 | 2,169.1 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/11/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/11/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/11/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/11/2014 05:00 | 0.0 | 18.0 | 414.7 | 0.0 | 0.1 | 1 | 0 | 0 |
| 03/11/2014 06:00 | 0.0 | 15.3 | 885.5 | 0.0 | 0.3 | 1 | 0 | 0 |
| 03/11/2014 07:00 | 0.6 | 13.7 | 1,769.7 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/11/2014 08:00 | 0.5 | 13.4 | 1,856.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/11/2014 09:00 | 0.5 | 13.2 | 1,859.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/11/2014 10:00 | 0.5 | 13.3 | 1,857.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/11/2014 11:00 | 0.4 | 13.3 | 1,854.3 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/11/2014 12:00 | 0.5 | 13.4 | 1,739.7 | 0.5 | 0.5 | 1 | 1 | 1 |
| 03/11/2014 13:00 | 0.6 | 13.9 | 1,335.9 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/11/2014 14:00 | 0.6 | 13.9 | 1,276.5 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/11/2014 15:00 | 0.6 | 13.9 | 1,303.3 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/11/2014 16:00 | 0.6 | 13.9 | 1,378.4 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/11/2014 17:00 | 0.6 | 13.9 | 1,387.2 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/11/2014 18:00 | 0.5 | 13.6 | 1,569.9 | 0.5 | 0.5 | 1 | 1 | 1 |
| 03/11/2014 19:00 | 0.4 | 12.4 | 2,086.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/11/2014 20:00 | 0.4 | 12.1 | 2,179.3 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/11/2014 21:00 | 0.4 | 12.4 | 2,129.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/11/2014 22:00 | 0.4 | 12.1 | 2,197.0 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/11/2014 23:00 | 0.4 | 13.2 | 1,762.9 | 0.4 | 0.5 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.4 | 13.6 | 1,623.3 | 0.5 | 0.5 | 19 # | 17 # | 11 # |
| **Minimum:** | 0.0 | 12.1 | 414.7 | 0.0 | 0.1 | 0 | 0 | 0 |
| **Maximum:** | 0.6 | 18.0 | 2,197.0 | 0.6 | 0.7 | 1 | 1 | 1 |
| **%SI** | 20.8 | 20.8 | 20.8 | 20.8 | 20.8 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/12/2014 00:00 | 0.6 | 13.9 | 1,280.3 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/12/2014 01:00 | 0.6 | 13.9 | 1,263.7 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/12/2014 02:00 | 0.6 | 13.9 | 1,242.0 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/12/2014 03:00 | 0.6 | 13.9 | 1,233.2 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/12/2014 04:00 | 0.6 | 13.9 | 1,237.6 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/12/2014 05:00 | 0.4 | 13.4 | 1,731.8 | 0.4 | 0.5 | 1 | 1 | 1 |
| 03/12/2014 06:00 | 0.2 | 12.9 | 1,989.9 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/12/2014 07:00 | 0.4 | 12.1 | 2,199.2 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/12/2014 08:00 | 0.4 | 12.9 | 2,014.0 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/12/2014 09:00 | 0.5 | 13.3 | 1,866.7 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/12/2014 10:00 | 0.5 | 13.3 | 1,854.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/12/2014 11:00 | 0.5 | 13.3 | 1,854.1 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/12/2014 12:00 | 0.7 | 13.8 | 1,361.4 | 0.7 | 0.4 | 1 | 1 | 1 |
| 03/12/2014 13:00 | 0.6 | 13.9 | 1,378.0 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/12/2014 14:00 | 0.6 | 13.9 | 1,253.4 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/12/2014 15:00 | 0.6 | 13.9 | 1,253.0 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/12/2014 16:00 | 0.6 | 13.9 | 1,252.1 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/12/2014 17:00 | 0.7 | 13.6 | 1,546.0 | 0.7 | 0.5 | 1 | 1 | 1 |
| 03/12/2014 18:00 | 0.4 | 13.2 | 1,915.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/12/2014 19:00 | 0.4 | 12.1 | 2,176.1 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/12/2014 20:00 | 0.4 | 12.0 | 2,202.9 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/12/2014 21:00 | 0.5 | 11.7 | 2,269.6 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/12/2014 22:00 | 0.5 | 11.7 | 2,273.9 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/12/2014 23:00 | 0.5 | 12.1 | 2,181.9 | 0.5 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.5 | 13.2 | 1,701.3 | 0.5 | 0.5 | 24 # | 24 # | 15 # |
| **Minimum:** | 0.2 | 11.7 | 1,233.2 | 0.4 | 0.4 | 1 | 1 | 0 |
| **Maximum:** | 0.7 | 13.9 | 2,273.9 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/13/2014 00:00 | 0.7 | 13.6 | 1,675.7 | 0.7 | 0.5 | 1 | 1 | 1 |
| 03/13/2014 01:00 | 0.6 | 13.8 | 1,773.5 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/13/2014 02:00 | 0.6 | 13.9 | 1,392.7 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/13/2014 03:00 | 0.6 | 13.9 | 1,377.1 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/13/2014 04:00 | 0.6 | 13.9 | 1,379.6 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/13/2014 05:00 | 0.4 | 13.2 | 1,875.1 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/13/2014 06:00 | 0.2 | 12.9 | 1,996.7 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/13/2014 07:00 | 0.5 | 11.8 | 2,257.9 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/13/2014 08:00 | 0.4 | 12.2 | 2,169.2 | 0.5 | 0.7 | 1 | 1 | 1 |
| 03/13/2014 09:00 | 0.4 | 12.7 | 2,024.3 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/13/2014 10:00 | 0.5 | 13.1 | 1,916.2 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/13/2014 11:00 | 0.5 | 13.4 | 1,856.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/13/2014 12:00 | 0.4 | 13.2 | 1,918.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/13/2014 13:00 | 0.4 | 13.0 | 1,970.4 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/13/2014 14:00 | 0.4 | 12.9 | 1,972.8 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/13/2014 15:00 | 0.4 | 12.9 | 1,971.5 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/13/2014 16:00 | 0.4 | 13.1 | 1,918.6 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/13/2014 17:00 | 0.4 | 13.3 | 1,859.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/13/2014 18:00 | 0.4 | 13.2 | 1,882.8 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/13/2014 19:00 | 0.4 | 13.0 | 1,954.6 | 0.5 | 0.6 | 1 | 1 | 1 |
| 03/13/2014 20:00 | 0.4 | 13.2 | 1,896.5 | 0.4 | 0.6 | 1 | 1 | 1 |
| 03/13/2014 21:00 | 0.5 | 13.3 | 1,771.4 | 0.5 | 0.5 | 1 | 1 | 1 |
| 03/13/2014 22:00 | 0.6 | 13.9 | 1,499.3 | 0.6 | 0.4 | 1 | 1 | 0 |
| 03/13/2014 23:00 | 0.6 | 13.9 | 1,753.4 | 0.6 | 0.5 | 1 | 1 | 0 |
| **Average/Sum#:** | 0.5 | 13.2 | 1,836.0 | 0.5 | 0.6 | 24 # | 24 # | 18 # |
| **Minimum:** | 0.2 | 11.8 | 1,377.1 | 0.4 | 0.4 | 1 | 1 | 0 |
| **Maximum:** | 0.7 | 13.9 | 2,257.9 | 0.7 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/14/2014 00:00 | 0.6 | 13.9 | 1,753.3 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/14/2014 01:00 | 0.0 | 14.4 | 1,429.9 | 0.0 | 0.4 | 1 | 0 | 0 |
| 03/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 06:00 | 0.0 | 19.8 | 150.0 | 0.0 | 0.0 | 1 | 0 | 0 |
| 03/14/2014 07:00 | 0.0 | 15.9 | 825.8 | 0.0 | 0.2 | 1 | 0 | 0 |
| 03/14/2014 08:00 | 0.6 | 13.8 | 1,790.3 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/14/2014 09:00 | 0.6 | 13.7 | 1,802.4 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/14/2014 10:00 | 0.6 | 13.7 | 1,795.9 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/14/2014 11:00 | 0.6 | 13.7 | 1,785.4 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/14/2014 12:00 | 0.6 | 13.7 | 1,776.7 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/14/2014 13:00 | 0.6 | 13.7 | 1,767.6 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/14/2014 14:00 | 0.6 | 13.7 | 1,761.3 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/14/2014 15:00 | 0.6 | 13.7 | 1,758.4 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/14/2014 16:00 | 0.6 | 13.7 | 1,748.3 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/14/2014 17:00 | 0.6 | 13.8 | 1,745.2 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/14/2014 18:00 | 0.6 | 13.8 | 1,745.6 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/14/2014 19:00 | 0.6 | 13.7 | 1,759.6 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/14/2014 20:00 | 0.6 | 13.7 | 1,766.4 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/14/2014 21:00 | 0.6 | 13.7 | 1,773.2 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/14/2014 22:00 | 0.6 | 13.7 | 1,781.2 | 0.6 | 0.5 | 1 | 1 | 0 |
| 03/14/2014 23:00 | 0.6 | 13.7 | 1,787.2 | 0.6 | 0.5 | 1 | 1 | 0 |
| **Average/Sum#:** | 0.5 | 14.2 | 1,625.2 | 0.5 | 0.5 | 20 # | 17 # | 0 # |
| **Minimum:** | 0.0 | 13.7 | 150.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.6 | 19.8 | 1,802.4 | 0.6 | 0.5 | 1 | 1 | 0 |
| **%SI** | 16.7 | 16.7 | 16.7 | 16.7 | 16.7 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/15/2014 00:00 | 0.0 | 15.6 | 664.5 | 0.0 | 0.2 | 1 | 0 | 0 |
| 03/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 15.6 | 664.5 | 0.0 | 0.2 | 1 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 15.6 | 664.5 | 0.0 | 0.2 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 15.6 | 664.5 | 0.0 | 0.2 | 1 | 0 | 0 |
| **%SI** | 95.8 | 95.8 | 95.8 | 95.8 | 95.8 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/30/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - VOC

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 VOC, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 VOC, Ppmvdc 1 Hour(s) | Unit CT2 VOC, LbPerHr 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/31/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# ATTACHMENT 6

## Hourly Emissions $NO_x$ (AQ-15)

# Excess Emission Report

## CT1 - NOx Lb 1-Day Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT1_NOx_Lb_1D
**Total Operating Time:** 1,178.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 982.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,178.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT2 - NOx Lb 1-Day Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT2_NOx_Lb_1D
**Total Operating Time:** 1,193.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 967.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,193.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/01/2014 00:00 | 0.9 | 13.9 | 1,626.5 | 0.8 | 4.90 | 1 | 1 | 0 |
| 01/01/2014 01:00 | 1.0 | 13.8 | 1,814.0 | 0.8 | 5.40 | 1 | 1 | 0 |
| 01/01/2014 02:00 | 0.9 | 13.8 | 1,691.3 | 0.7 | 5.10 | 1 | 1 | 0 |
| 01/01/2014 03:00 | 2.8 | 14.7 | 1,099.9 | 2.7 | 5.28 | 1 | 0 | 0 |
| 01/01/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 16:00 | 28.8 | 17.5 | 499.0 | 50.0 | 56.92 | 1 | 0 | 0 |
| 01/01/2014 17:00 | 19.1 | 14.9 | 1,054.7 | 18.8 | 72.80 | 1 | 0 | 0 |
| 01/01/2014 18:00 | 0.9 | 13.7 | 1,768.1 | 0.7 | 5.30 | 1 | 1 | 1 |
| 01/01/2014 19:00 | 1.1 | 12.7 | 2,052.6 | 0.8 | 6.20 | 1 | 1 | 1 |
| 01/01/2014 20:00 | 1.4 | 12.2 | 2,131.8 | 0.9 | 6.40 | 1 | 1 | 1 |
| 01/01/2014 21:00 | 1.4 | 12.2 | 2,153.2 | 0.9 | 6.50 | 1 | 1 | 1 |
| 01/01/2014 22:00 | 1.2 | 12.6 | 2,063.6 | 0.9 | 6.20 | 1 | 1 | 1 |
| 01/01/2014 23:00 | 1.2 | 12.6 | 2,066.6 | 0.9 | 6.20 | 1 | 1 | 1 |
| **Average/Sum#:** | 5.1 | 13.7 | 1,668.4 | 6.6 | 187.20 # | 12 # | 9 # | 6 # |
| **Minimum:** | 0.9 | 12.2 | 499.0 | 0.7 | 4.90 | 0 | 0 | 0 |
| **Maximum:** | 28.8 | 17.5 | 2,153.2 | 50.0 | 72.80 | 1 | 1 | 1 |
| **%SI** | 50.0 | 50.0 | 50.0 | 50.0 | 50.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/02/2014 00:00 | 1.2 | 12.7 | 2,043.6 | 0.9 | 6.10 | 1 | 1 | 1 |
| 01/02/2014 01:00 | 1.1 | 13.5 | 1,838.8 | 0.9 | 5.50 | 1 | 1 | 1 |
| 01/02/2014 02:00 | 0.8 | 13.8 | 1,587.3 | 0.7 | 3.20 | 1 | 1 | 0 |
| 01/02/2014 03:00 | 0.9 | 13.8 | 1,712.8 | 0.7 | 5.10 | 1 | 1 | 0 |
| 01/02/2014 04:00 | 0.8 | 13.8 | 1,592.0 | 0.7 | 3.20 | 1 | 1 | 0 |
| 01/02/2014 05:00 | 0.9 | 13.5 | 1,800.6 | 0.7 | 5.40 | 1 | 1 | 1 |
| 01/02/2014 06:00 | 1.1 | 13.0 | 1,980.8 | 0.8 | 5.90 | 1 | 1 | 1 |
| 01/02/2014 07:00 | 1.1 | 13.0 | 1,973.4 | 0.8 | 5.90 | 1 | 1 | 1 |
| 01/02/2014 08:00 | 1.1 | 12.9 | 2,008.7 | 0.8 | 6.00 | 1 | 1 | 1 |
| 01/02/2014 09:00 | 1.1 | 12.9 | 2,020.3 | 0.8 | 6.10 | 1 | 1 | 1 |
| 01/02/2014 10:00 | 1.1 | 12.9 | 2,013.0 | 0.8 | 6.00 | 1 | 1 | 1 |
| 01/02/2014 11:00 | 1.2 | 12.8 | 2,012.1 | 0.9 | 6.00 | 1 | 1 | 1 |
| 01/02/2014 12:00 | 1.2 | 12.8 | 2,001.0 | 0.9 | 6.00 | 1 | 1 | 1 |
| 01/02/2014 13:00 | 1.2 | 12.8 | 1,991.0 | 0.9 | 6.00 | 1 | 1 | 1 |
| 01/02/2014 14:00 | 1.2 | 13.0 | 1,956.5 | 0.9 | 5.90 | 1 | 1 | 1 |
| 01/02/2014 15:00 | 1.2 | 12.8 | 1,989.5 | 0.9 | 6.00 | 1 | 1 | 1 |
| 01/02/2014 16:00 | 1.3 | 12.7 | 2,006.8 | 0.9 | 6.00 | 1 | 1 | 1 |
| 01/02/2014 17:00 | 1.3 | 12.6 | 2,016.2 | 0.9 | 6.00 | 1 | 1 | 1 |
| 01/02/2014 18:00 | 1.4 | 12.2 | 2,114.0 | 0.9 | 6.30 | 1 | 1 | 1 |
| 01/02/2014 19:00 | 1.5 | 12.1 | 2,137.2 | 1.0 | 8.50 | 1 | 1 | 1 |
| 01/02/2014 20:00 | 1.4 | 12.2 | 2,117.0 | 0.9 | 6.40 | 1 | 1 | 1 |
| 01/02/2014 21:00 | 1.4 | 12.3 | 2,106.4 | 1.0 | 8.40 | 1 | 1 | 1 |
| 01/02/2014 22:00 | 1.2 | 12.6 | 2,055.8 | 0.9 | 6.20 | 1 | 1 | 1 |
| 01/02/2014 23:00 | 1.4 | 12.3 | 2,116.9 | 1.0 | 8.50 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.2 | 12.9 | 1,966.3 | 0.9 | 144.60 # | 24 # | 24 # | 21 # |
| **Minimum:** | 0.8 | 12.1 | 1,587.3 | 0.7 | 3.20 | 1 | 1 | 0 |
| **Maximum:** | 1.5 | 13.8 | 2,137.2 | 1.0 | 8.50 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/03/2014 00:00 | 1.2 | 12.8 | 2,008.1 | 0.9 | 6.00 | 1 | 1 | 1 |
| 01/03/2014 01:00 | 1.0 | 13.6 | 1,747.2 | 0.8 | 5.20 | 1 | 1 | 1 |
| 01/03/2014 02:00 | 0.7 | 13.9 | 1,318.6 | 0.6 | 2.60 | 1 | 1 | 0 |
| 01/03/2014 03:00 | 0.7 | 13.9 | 1,243.4 | 0.6 | 2.50 | 1 | 1 | 0 |
| 01/03/2014 04:00 | 0.7 | 13.9 | 1,244.0 | 0.6 | 2.50 | 1 | 1 | 0 |
| 01/03/2014 05:00 | 0.7 | 13.9 | 1,246.6 | 0.6 | 2.50 | 1 | 1 | 0 |
| 01/03/2014 06:00 | 0.9 | 13.6 | 1,548.9 | 0.7 | 4.60 | 1 | 1 | 1 |
| 01/03/2014 07:00 | 1.1 | 13.2 | 1,896.9 | 0.8 | 5.70 | 1 | 1 | 1 |
| 01/03/2014 08:00 | 1.1 | 13.1 | 1,979.6 | 0.8 | 5.90 | 1 | 1 | 1 |
| 01/03/2014 09:00 | 1.1 | 12.9 | 2,027.5 | 0.8 | 6.10 | 1 | 1 | 1 |
| 01/03/2014 10:00 | 1.1 | 12.8 | 2,027.1 | 0.8 | 6.10 | 1 | 1 | 1 |
| 01/03/2014 11:00 | 1.1 | 12.8 | 2,016.2 | 0.8 | 6.00 | 1 | 1 | 1 |
| 01/03/2014 12:00 | 1.2 | 12.9 | 1,988.3 | 0.9 | 6.00 | 1 | 1 | 1 |
| 01/03/2014 13:00 | 1.2 | 12.9 | 1,975.7 | 0.9 | 5.90 | 1 | 1 | 1 |
| 01/03/2014 14:00 | 1.2 | 13.0 | 1,964.4 | 0.9 | 5.90 | 1 | 1 | 1 |
| 01/03/2014 15:00 | 1.2 | 13.1 | 1,934.6 | 0.9 | 5.80 | 1 | 1 | 1 |
| 01/03/2014 16:00 | 1.2 | 12.9 | 1,985.0 | 0.9 | 6.00 | 1 | 1 | 1 |
| 01/03/2014 17:00 | 1.3 | 12.5 | 2,047.8 | 0.9 | 6.10 | 1 | 1 | 1 |
| 01/03/2014 18:00 | 1.4 | 12.2 | 2,131.4 | 0.9 | 6.40 | 1 | 1 | 1 |
| 01/03/2014 19:00 | 1.4 | 12.3 | 2,088.7 | 1.0 | 8.40 | 1 | 1 | 1 |
| 01/03/2014 20:00 | 1.3 | 12.4 | 2,088.1 | 0.9 | 6.30 | 1 | 1 | 1 |
| 01/03/2014 21:00 | 1.6 | 11.7 | 2,219.5 | 1.0 | 8.90 | 1 | 1 | 1 |
| 01/03/2014 22:00 | 1.6 | 11.9 | 2,181.5 | 1.0 | 8.70 | 1 | 1 | 1 |
| 01/03/2014 23:00 | 1.5 | 12.2 | 2,135.6 | 1.0 | 8.50 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.1 | 12.9 | 1,876.9 | 0.8 | 138.60 # | 24 # | 24 # | 20 # |
| **Minimum:** | 0.7 | 11.7 | 1,243.4 | 0.6 | 2.50 | 1 | 1 | 0 |
| **Maximum:** | 1.6 | 13.9 | 2,219.5 | 1.0 | 8.90 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/04/2014 00:00 | 1.2 | 12.7 | 2,043.9 | 0.9 | 6.10 | 1 | 1 | 1 |
| 01/04/2014 01:00 | 1.2 | 12.6 | 2,065.5 | 0.9 | 6.20 | 1 | 1 | 1 |
| 01/04/2014 02:00 | 0.8 | 13.8 | 1,623.6 | 0.7 | 3.20 | 1 | 1 | 1 |
| 01/04/2014 03:00 | 0.8 | 13.8 | 1,596.0 | 0.7 | 3.20 | 1 | 1 | 0 |
| 01/04/2014 04:00 | 0.6 | 13.9 | 1,424.1 | 0.5 | 2.80 | 1 | 1 | 0 |
| 01/04/2014 05:00 | 0.8 | 13.8 | 1,654.2 | 0.7 | 3.30 | 1 | 1 | 0 |
| 01/04/2014 06:00 | 0.9 | 13.8 | 1,672.6 | 0.7 | 5.00 | 1 | 1 | 0 |
| 01/04/2014 07:00 | 1.0 | 13.7 | 1,825.6 | 0.8 | 5.50 | 1 | 1 | 0 |
| 01/04/2014 08:00 | 1.0 | 13.2 | 1,905.0 | 0.8 | 5.70 | 1 | 1 | 1 |
| 01/04/2014 09:00 | 1.3 | 12.4 | 2,103.5 | 0.9 | 6.30 | 1 | 1 | 1 |
| 01/04/2014 10:00 | 1.2 | 12.7 | 2,033.4 | 0.9 | 6.10 | 1 | 1 | 1 |
| 01/04/2014 11:00 | 1.2 | 12.9 | 1,972.8 | 0.9 | 5.90 | 1 | 1 | 1 |
| 01/04/2014 12:00 | 1.2 | 13.3 | 1,901.9 | 0.9 | 5.70 | 1 | 1 | 1 |
| 01/04/2014 13:00 | 1.0 | 13.5 | 1,856.6 | 0.8 | 5.60 | 1 | 1 | 1 |
| 01/04/2014 14:00 | 1.3 | 13.0 | 1,976.0 | 1.0 | 7.90 | 1 | 1 | 1 |
| 01/04/2014 15:00 | 1.4 | 12.7 | 2,017.1 | 1.0 | 8.10 | 1 | 1 | 1 |
| 01/04/2014 16:00 | 1.5 | 12.6 | 2,039.2 | 1.1 | 8.20 | 1 | 1 | 1 |
| 01/04/2014 17:00 | 1.5 | 12.5 | 2,081.3 | 1.1 | 8.30 | 1 | 1 | 1 |
| 01/04/2014 18:00 | 1.5 | 12.2 | 2,136.7 | 1.0 | 8.50 | 1 | 1 | 1 |
| 01/04/2014 19:00 | 1.5 | 12.2 | 2,139.0 | 1.0 | 8.60 | 1 | 1 | 1 |
| 01/04/2014 20:00 | 1.4 | 12.7 | 2,046.9 | 1.0 | 8.20 | 1 | 1 | 1 |
| 01/04/2014 21:00 | 1.6 | 11.9 | 2,198.9 | 1.0 | 8.80 | 1 | 1 | 1 |
| 01/04/2014 22:00 | 1.6 | 11.8 | 2,217.8 | 1.0 | 8.90 | 1 | 1 | 1 |
| 01/04/2014 23:00 | 1.4 | 12.6 | 2,043.8 | 1.0 | 8.20 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.2 | 12.9 | 1,940.6 | 0.9 | 154.30 # | 24 # | 24 # | 19 # |
| **Minimum:** | 0.6 | 11.8 | 1,424.1 | 0.5 | 2.80 | 1 | 1 | 0 |
| **Maximum:** | 1.6 | 13.9 | 2,217.8 | 1.1 | 8.90 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/05/2014 00:00 | 1.3 | 12.8 | 2,026.9 | 0.9 | 6.10 | 1 | 1 | 1 |
| 01/05/2014 01:00 | 1.4 | 12.5 | 2,066.8 | 1.0 | 8.30 | 1 | 1 | 1 |
| 01/05/2014 02:00 | 0.9 | 13.8 | 1,616.1 | 0.7 | 4.80 | 1 | 1 | 1 |
| 01/05/2014 03:00 | 0.9 | 13.9 | 1,596.8 | 0.8 | 4.80 | 1 | 1 | 0 |
| 01/05/2014 04:00 | 1.0 | 13.9 | 1,699.9 | 0.8 | 5.10 | 1 | 1 | 0 |
| 01/05/2014 05:00 | 1.1 | 13.8 | 1,827.2 | 0.9 | 5.50 | 1 | 1 | 0 |
| 01/05/2014 06:00 | 1.1 | 13.3 | 1,894.2 | 0.9 | 5.70 | 1 | 1 | 1 |
| 01/05/2014 07:00 | 1.4 | 12.4 | 2,089.7 | 1.0 | 8.40 | 1 | 1 | 1 |
| 01/05/2014 08:00 | 1.6 | 11.8 | 2,237.4 | 1.0 | 8.90 | 1 | 1 | 1 |
| 01/05/2014 09:00 | 1.6 | 12.0 | 2,192.0 | 1.1 | 8.80 | 1 | 1 | 1 |
| 01/05/2014 10:00 | 1.4 | 12.6 | 2,055.9 | 1.0 | 8.20 | 1 | 1 | 1 |
| 01/05/2014 11:00 | 1.3 | 12.9 | 1,981.7 | 1.0 | 7.90 | 1 | 1 | 1 |
| 01/05/2014 12:00 | 1.2 | 13.3 | 1,906.1 | 0.9 | 5.70 | 1 | 1 | 1 |
| 01/05/2014 13:00 | 1.3 | 13.2 | 1,942.3 | 1.0 | 7.80 | 1 | 1 | 1 |
| 01/05/2014 14:00 | 1.4 | 12.8 | 2,006.5 | 1.0 | 8.00 | 1 | 1 | 1 |
| 01/05/2014 15:00 | 1.0 | 13.9 | 1,633.4 | 0.8 | 4.90 | 1 | 1 | 1 |
| 01/05/2014 16:00 | 1.2 | 13.2 | 1,879.9 | 0.9 | 5.60 | 1 | 1 | 1 |
| 01/05/2014 17:00 | 1.6 | 12.0 | 2,170.6 | 1.1 | 8.70 | 1 | 1 | 1 |
| 01/05/2014 18:00 | 1.6 | 11.8 | 2,213.3 | 1.0 | 8.90 | 1 | 1 | 1 |
| 01/05/2014 19:00 | 1.6 | 11.8 | 2,214.0 | 1.0 | 8.90 | 1 | 1 | 1 |
| 01/05/2014 20:00 | 1.6 | 11.7 | 2,224.4 | 1.0 | 8.90 | 1 | 1 | 1 |
| 01/05/2014 21:00 | 1.6 | 11.8 | 2,217.5 | 1.0 | 8.90 | 1 | 1 | 1 |
| 01/05/2014 22:00 | 1.6 | 11.8 | 2,227.7 | 1.0 | 8.90 | 1 | 1 | 1 |
| 01/05/2014 23:00 | 1.5 | 12.1 | 2,171.6 | 1.0 | 8.70 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.3 | 12.7 | 2,003.8 | 1.0 | 176.40 # | 24 # | 24 # | 21 # |
| **Minimum:** | 0.9 | 11.7 | 1,596.8 | 0.7 | 4.80 | 1 | 1 | 0 |
| **Maximum:** | 1.6 | 13.9 | 2,237.4 | 1.1 | 8.90 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/06/2014 00:00 | 1.5 | 12.2 | 2,162.5 | 1.0 | 8.70 | 1 | 1 | 1 |
| 01/06/2014 01:00 | 1.4 | 12.5 | 2,088.4 | 1.0 | 8.40 | 1 | 1 | 1 |
| 01/06/2014 02:00 | 1.4 | 12.3 | 2,124.7 | 1.0 | 8.50 | 1 | 1 | 1 |
| 01/06/2014 03:00 | 1.3 | 12.9 | 2,009.4 | 1.0 | 8.00 | 1 | 1 | 1 |
| 01/06/2014 04:00 | 1.3 | 13.0 | 1,999.4 | 1.0 | 8.00 | 1 | 1 | 1 |
| 01/06/2014 05:00 | 1.5 | 12.2 | 2,157.5 | 1.0 | 8.60 | 1 | 1 | 1 |
| 01/06/2014 06:00 | 1.3 | 12.6 | 2,063.4 | 0.9 | 6.20 | 1 | 1 | 1 |
| 01/06/2014 07:00 | 1.4 | 12.7 | 2,032.9 | 1.0 | 8.10 | 1 | 1 | 1 |
| 01/06/2014 08:00 | 1.5 | 12.3 | 2,147.7 | 1.0 | 8.60 | 1 | 1 | 1 |
| 01/06/2014 09:00 | 1.3 | 12.5 | 2,116.1 | 0.9 | 6.30 | 1 | 1 | 1 |
| 01/06/2014 10:00 | 1.4 | 12.3 | 2,149.0 | 1.0 | 8.60 | 1 | 1 | 1 |
| 01/06/2014 11:00 | 1.6 | 12.0 | 2,191.9 | 1.1 | 8.80 | 1 | 1 | 1 |
| 01/06/2014 12:00 | 1.6 | 12.0 | 2,202.6 | 1.1 | 8.80 | 1 | 1 | 1 |
| 01/06/2014 13:00 | 1.6 | 11.9 | 2,215.1 | 1.0 | 8.90 | 1 | 1 | 1 |
| 01/06/2014 14:00 | 1.5 | 12.3 | 2,118.5 | 1.0 | 8.50 | 1 | 1 | 1 |
| 01/06/2014 15:00 | 1.2 | 12.9 | 2,002.1 | 0.9 | 6.00 | 1 | 1 | 1 |
| 01/06/2014 16:00 | 1.2 | 12.8 | 2,015.5 | 0.9 | 6.00 | 1 | 1 | 1 |
| 01/06/2014 17:00 | 1.3 | 12.6 | 2,072.7 | 0.9 | 6.20 | 1 | 1 | 1 |
| 01/06/2014 18:00 | 1.3 | 12.5 | 2,089.5 | 0.9 | 6.30 | 1 | 1 | 1 |
| 01/06/2014 19:00 | 1.6 | 11.9 | 2,219.6 | 1.0 | 8.90 | 1 | 1 | 1 |
| 01/06/2014 20:00 | 1.4 | 12.4 | 2,106.4 | 1.0 | 8.40 | 1 | 1 | 1 |
| 01/06/2014 21:00 | 1.6 | 11.9 | 2,236.4 | 1.0 | 8.90 | 1 | 1 | 1 |
| 01/06/2014 22:00 | 1.6 | 11.8 | 2,246.7 | 1.0 | 9.00 | 1 | 1 | 1 |
| 01/06/2014 23:00 | 1.4 | 12.4 | 2,107.4 | 1.0 | 8.40 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.4 | 12.4 | 2,119.8 | 1.0 | 191.10 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.2 | 11.8 | 1,999.4 | 0.9 | 6.00 | 1 | 1 | 1 |
| **Maximum:** | 1.6 | 13.0 | 2,246.7 | 1.1 | 9.00 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/07/2014 00:00 | 1.2 | 13.1 | 1,956.6 | 0.9 | 5.90 | 1 | 1 | 1 |
| 01/07/2014 01:00 | 1.0 | 13.4 | 1,746.2 | 0.8 | 5.20 | 1 | 1 | 1 |
| 01/07/2014 02:00 | 0.8 | 13.9 | 1,487.7 | 0.7 | 3.00 | 1 | 1 | 0 |
| 01/07/2014 03:00 | 0.8 | 13.8 | 1,592.1 | 0.7 | 3.20 | 1 | 1 | 0 |
| 01/07/2014 04:00 | 0.8 | 13.9 | 1,579.1 | 0.7 | 3.20 | 1 | 1 | 0 |
| 01/07/2014 05:00 | 0.9 | 13.9 | 1,595.7 | 0.8 | 4.80 | 1 | 1 | 0 |
| 01/07/2014 06:00 | 1.0 | 13.5 | 1,788.2 | 0.8 | 5.40 | 1 | 1 | 1 |
| 01/07/2014 07:00 | 1.1 | 12.9 | 1,998.5 | 0.8 | 6.00 | 1 | 1 | 1 |
| 01/07/2014 08:00 | 1.4 | 12.4 | 2,138.8 | 1.0 | 8.60 | 1 | 1 | 1 |
| 01/07/2014 09:00 | 1.4 | 12.4 | 2,129.8 | 1.0 | 8.50 | 1 | 1 | 1 |
| 01/07/2014 10:00 | 1.2 | 12.7 | 2,065.3 | 0.9 | 6.20 | 1 | 1 | 1 |
| 01/07/2014 11:00 | 1.2 | 12.8 | 2,039.9 | 0.9 | 6.10 | 1 | 1 | 1 |
| 01/07/2014 12:00 | 1.6 | 12.0 | 2,213.6 | 1.1 | 8.90 | 1 | 1 | 1 |
| 01/07/2014 13:00 | 1.6 | 11.9 | 2,207.8 | 1.0 | 8.80 | 1 | 1 | 1 |
| 01/07/2014 14:00 | 1.4 | 12.6 | 2,061.0 | 1.0 | 8.20 | 1 | 1 | 1 |
| 01/07/2014 15:00 | 1.4 | 12.5 | 2,074.1 | 1.0 | 8.30 | 1 | 1 | 1 |
| 01/07/2014 16:00 | 1.2 | 13.0 | 1,981.0 | 0.9 | 5.90 | 1 | 1 | 1 |
| 01/07/2014 17:00 | 1.2 | 13.0 | 1,982.6 | 0.9 | 5.90 | 1 | 1 | 1 |
| 01/07/2014 18:00 | 1.3 | 12.7 | 2,035.4 | 0.9 | 6.10 | 1 | 1 | 1 |
| 01/07/2014 19:00 | 1.5 | 12.1 | 2,172.2 | 1.0 | 8.70 | 1 | 1 | 1 |
| 01/07/2014 20:00 | 1.6 | 11.8 | 2,221.0 | 1.0 | 8.90 | 1 | 1 | 1 |
| 01/07/2014 21:00 | 1.3 | 12.6 | 2,061.3 | 0.9 | 6.20 | 1 | 1 | 1 |
| 01/07/2014 22:00 | 1.2 | 12.8 | 2,036.4 | 0.9 | 6.10 | 1 | 1 | 1 |
| 01/07/2014 23:00 | 1.1 | 13.2 | 1,875.4 | 0.8 | 5.60 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.2 | 12.9 | 1,960.0 | 0.9 | 153.70 # | 24 # | 24 # | 20 # |
| **Minimum:** | 0.8 | 11.8 | 1,487.7 | 0.7 | 3.00 | 1 | 1 | 0 |
| **Maximum:** | 1.6 | 13.9 | 2,221.0 | 1.1 | 8.90 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/08/2014 00:00 | 0.8 | 13.9 | 1,360.2 | 0.7 | 2.70 | 1 | 1 | 0 |
| 01/08/2014 01:00 | 0.7 | 13.9 | 1,310.4 | 0.6 | 2.60 | 1 | 1 | 0 |
| 01/08/2014 02:00 | 0.7 | 13.9 | 1,284.3 | 0.6 | 2.60 | 1 | 1 | 0 |
| 01/08/2014 03:00 | 0.7 | 13.9 | 1,260.1 | 0.6 | 2.50 | 1 | 1 | 0 |
| 01/08/2014 04:00 | 0.8 | 13.9 | 1,293.2 | 0.7 | 2.60 | 1 | 1 | 0 |
| 01/08/2014 05:00 | 0.9 | 13.8 | 1,632.4 | 0.7 | 4.90 | 1 | 1 | 0 |
| 01/08/2014 06:00 | 0.9 | 13.6 | 1,700.8 | 0.7 | 5.10 | 1 | 1 | 1 |
| 01/08/2014 07:00 | 1.3 | 13.3 | 1,919.2 | 1.0 | 7.70 | 1 | 1 | 1 |
| 01/08/2014 08:00 | 1.2 | 13.0 | 1,994.2 | 0.9 | 6.00 | 1 | 1 | 1 |
| 01/08/2014 09:00 | 1.0 | 13.6 | 1,761.9 | 0.8 | 5.30 | 1 | 1 | 1 |
| 01/08/2014 10:00 | 0.6 | 13.9 | 1,237.5 | 0.5 | 2.50 | 1 | 1 | 0 |
| 01/08/2014 11:00 | 0.7 | 13.9 | 1,378.5 | 0.6 | 2.80 | 1 | 1 | 0 |
| 01/08/2014 12:00 | 0.9 | 13.7 | 1,703.6 | 0.7 | 5.10 | 1 | 1 | 0 |
| 01/08/2014 13:00 | 0.7 | 13.9 | 1,480.3 | 0.6 | 3.00 | 1 | 1 | 0 |
| 01/08/2014 14:00 | 0.7 | 13.9 | 1,254.4 | 0.6 | 2.50 | 1 | 1 | 0 |
| 01/08/2014 15:00 | 0.8 | 13.9 | 1,400.6 | 0.7 | 2.80 | 1 | 1 | 0 |
| 01/08/2014 16:00 | 0.8 | 13.9 | 1,525.8 | 0.7 | 3.10 | 1 | 1 | 0 |
| 01/08/2014 17:00 | 1.1 | 13.4 | 1,807.0 | 0.9 | 5.40 | 1 | 1 | 1 |
| 01/08/2014 18:00 | 0.6 | 13.9 | 1,432.1 | 0.5 | 2.90 | 1 | 1 | 0 |
| 01/08/2014 19:00 | 0.6 | 13.8 | 1,530.1 | 0.5 | 3.10 | 1 | 1 | 0 |
| 01/08/2014 20:00 | 0.6 | 13.9 | 1,485.5 | 0.5 | 3.00 | 1 | 1 | 0 |
| 01/08/2014 21:00 | 0.6 | 13.9 | 1,488.5 | 0.5 | 3.00 | 1 | 1 | 0 |
| 01/08/2014 22:00 | 4.4 | 15.4 | 726.3 | 4.7 | 3.32 | 1 | 0 | 0 |
| 01/08/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 1.0 | 13.8 | 1,476.8 | 0.8 | 84.52 # | 23 # | 22 # | 5 # |
| **Minimum:** | 0.6 | 13.0 | 726.3 | 0.5 | 2.50 | 0 | 0 | 0 |
| **Maximum:** | 4.4 | 15.4 | 1,994.2 | 4.7 | 7.70 | 1 | 1 | 1 |
| **%SI** | 4.2 | 4.2 | 4.2 | 4.2 | 4.17 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/09/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/10/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/12/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/13/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/14/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/15/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 14:00 | 34.7 | 17.4 | 529.1 | 58.5 | 94.45 | 1 | 0 | 0 |
| 01/29/2014 15:00 | 25.9 | 15.8 | 760.9 | 30.0 | 83.70 | 1 | 0 | 0 |
| 01/29/2014 16:00 | 0.7 | 13.9 | 1,323.7 | 0.6 | 2.60 | 1 | 0 | 0 |
| 01/29/2014 17:00 | 0.8 | 13.8 | 1,541.8 | 0.7 | 3.10 | 1 | 1 | 0 |
| 01/29/2014 18:00 | 1.0 | 13.7 | 1,819.4 | 0.8 | 5.50 | 1 | 1 | 0 |
| 01/29/2014 19:00 | 1.0 | 13.7 | 1,819.3 | 0.8 | 5.50 | 1 | 1 | 0 |
| 01/29/2014 20:00 | 0.9 | 13.8 | 1,752.4 | 0.7 | 5.30 | 1 | 1 | 0 |
| 01/29/2014 21:00 | 0.9 | 13.8 | 1,806.5 | 0.7 | 5.40 | 1 | 1 | 0 |
| 01/29/2014 22:00 | 0.8 | 13.8 | 1,667.6 | 0.7 | 3.30 | 1 | 1 | 0 |
| 01/29/2014 23:00 | 0.6 | 13.9 | 1,291.9 | 0.5 | 2.60 | 1 | 1 | 0 |
| **Average/Sum#:** | 6.7 | 14.4 | 1,431.3 | 9.4 | 211.45 # | 10 # | 7 # | 0 # |
| **Minimum:** | 0.6 | 13.7 | 529.1 | 0.5 | 2.60 | 0 | 0 | 0 |
| **Maximum:** | 34.7 | 17.4 | 1,819.4 | 58.5 | 94.45 | 1 | 1 | 0 |
| **%SI** | 58.3 | 58.3 | 58.3 | 58.3 | 58.33 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/30/2014 00:00 | 0.7 | 13.9 | 1,463.8 | 0.6 | 2.90 | 1 | 1 | 0 |
| 01/30/2014 01:00 | 1.0 | 13.8 | 1,752.9 | 0.8 | 5.30 | 1 | 1 | 0 |
| 01/30/2014 02:00 | 0.7 | 13.9 | 1,327.6 | 0.6 | 2.70 | 1 | 1 | 0 |
| 01/30/2014 03:00 | 0.6 | 13.9 | 1,257.1 | 0.5 | 2.50 | 1 | 1 | 0 |
| 01/30/2014 04:00 | 0.7 | 13.9 | 1,282.4 | 0.6 | 2.60 | 1 | 1 | 0 |
| 01/30/2014 05:00 | 0.6 | 14.0 | 1,254.0 | 0.5 | 2.50 | 1 | 1 | 0 |
| 01/30/2014 06:00 | 0.7 | 13.9 | 1,447.9 | 0.6 | 2.90 | 1 | 1 | 0 |
| 01/30/2014 07:00 | 0.8 | 14.0 | 1,542.8 | 0.7 | 4.60 | 1 | 1 | 0 |
| 01/30/2014 08:00 | 0.8 | 13.9 | 1,553.6 | 0.7 | 3.10 | 1 | 1 | 0 |
| 01/30/2014 09:00 | 0.6 | 14.0 | 1,242.6 | 0.5 | 2.50 | 1 | 1 | 0 |
| 01/30/2014 10:00 | 0.8 | 13.8 | 1,516.0 | 0.7 | 3.00 | 1 | 1 | 1 |
| 01/30/2014 11:00 | 0.9 | 13.8 | 1,804.8 | 0.7 | 5.40 | 1 | 1 | 1 |
| 01/30/2014 12:00 | 1.1 | 13.2 | 1,906.8 | 0.8 | 5.70 | 1 | 1 | 1 |
| 01/30/2014 13:00 | 1.3 | 12.4 | 2,065.3 | 0.9 | 6.20 | 1 | 1 | 1 |
| 01/30/2014 14:00 | 1.6 | 12.0 | 2,168.8 | 1.1 | 8.70 | 1 | 1 | 1 |
| 01/30/2014 15:00 | 1.5 | 11.8 | 2,200.4 | 1.0 | 8.80 | 1 | 1 | 1 |
| 01/30/2014 16:00 | 1.2 | 12.9 | 1,880.9 | 0.9 | 5.60 | 1 | 1 | 1 |
| 01/30/2014 17:00 | 0.8 | 13.9 | 1,571.0 | 0.7 | 3.10 | 1 | 1 | 1 |
| 01/30/2014 18:00 | 0.8 | 13.9 | 1,642.0 | 0.7 | 3.30 | 1 | 1 | 0 |
| 01/30/2014 19:00 | 1.1 | 13.1 | 1,921.0 | 0.8 | 5.80 | 1 | 1 | 1 |
| 01/30/2014 20:00 | 1.2 | 12.5 | 2,045.7 | 0.8 | 6.10 | 1 | 1 | 1 |
| 01/30/2014 21:00 | 1.3 | 12.6 | 2,027.2 | 0.9 | 6.10 | 1 | 1 | 1 |
| 01/30/2014 22:00 | 1.1 | 13.0 | 1,948.7 | 0.8 | 5.80 | 1 | 1 | 1 |
| 01/30/2014 23:00 | 1.0 | 13.4 | 1,837.7 | 0.8 | 5.50 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.0 | 13.4 | 1,694.2 | 0.7 | 110.70 # | 24 # | 24 # | 13 # |
| **Minimum:** | 0.6 | 11.8 | 1,242.6 | 0.5 | 2.50 | 1 | 1 | 0 |
| **Maximum:** | 1.6 | 14.0 | 2,200.4 | 1.1 | 8.80 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 01/31/2014 00:00 | 0.7 | 13.9 | 1,532.7 | 0.6 | 3.10 | 1 | 1 | 0 |
| 01/31/2014 01:00 | 0.7 | 13.9 | 1,489.3 | 0.6 | 3.00 | 1 | 1 | 0 |
| 01/31/2014 02:00 | 0.9 | 13.9 | 1,620.1 | 0.8 | 4.90 | 1 | 1 | 0 |
| 01/31/2014 03:00 | 0.7 | 14.0 | 1,406.6 | 0.6 | 2.80 | 1 | 1 | 0 |
| 01/31/2014 04:00 | 0.7 | 14.0 | 1,324.5 | 0.6 | 2.60 | 1 | 1 | 0 |
| 01/31/2014 05:00 | 1.0 | 13.8 | 1,753.3 | 0.8 | 5.30 | 1 | 1 | 0 |
| 01/31/2014 06:00 | 0.9 | 13.7 | 1,810.4 | 0.7 | 5.40 | 1 | 1 | 1 |
| 01/31/2014 07:00 | 1.0 | 13.8 | 1,823.0 | 0.8 | 5.50 | 1 | 1 | 0 |
| 01/31/2014 08:00 | 0.9 | 13.8 | 1,828.8 | 0.7 | 5.50 | 1 | 1 | 0 |
| 01/31/2014 09:00 | 0.8 | 13.9 | 1,799.9 | 0.7 | 3.60 | 1 | 1 | 1 |
| 01/31/2014 10:00 | 0.9 | 13.8 | 1,813.5 | 0.7 | 5.40 | 1 | 1 | 1 |
| 01/31/2014 11:00 | 1.0 | 13.4 | 1,899.1 | 0.8 | 5.70 | 1 | 1 | 1 |
| 01/31/2014 12:00 | 1.1 | 13.0 | 1,973.4 | 0.8 | 5.90 | 1 | 1 | 1 |
| 01/31/2014 13:00 | 1.2 | 13.0 | 1,976.9 | 0.9 | 5.90 | 1 | 1 | 1 |
| 01/31/2014 14:00 | 1.1 | 13.2 | 1,925.2 | 0.8 | 5.80 | 1 | 1 | 1 |
| 01/31/2014 15:00 | 1.0 | 13.4 | 1,906.5 | 0.8 | 5.70 | 1 | 1 | 1 |
| 01/31/2014 16:00 | 1.1 | 13.4 | 1,904.1 | 0.9 | 5.70 | 1 | 1 | 1 |
| 01/31/2014 17:00 | 1.0 | 13.3 | 1,923.5 | 0.8 | 5.80 | 1 | 1 | 1 |
| 01/31/2014 18:00 | 1.0 | 13.4 | 1,900.1 | 0.8 | 5.70 | 1 | 1 | 1 |
| 01/31/2014 19:00 | 1.2 | 12.7 | 2,054.6 | 0.9 | 6.20 | 1 | 1 | 1 |
| 01/31/2014 20:00 | 1.2 | 12.9 | 1,995.8 | 0.9 | 6.00 | 1 | 1 | 1 |
| 01/31/2014 21:00 | 1.2 | 12.7 | 2,045.1 | 0.9 | 6.10 | 1 | 1 | 1 |
| 01/31/2014 22:00 | 1.3 | 12.4 | 2,114.0 | 0.9 | 6.30 | 1 | 1 | 1 |
| 01/31/2014 23:00 | 1.3 | 12.5 | 2,094.4 | 0.9 | 6.30 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.0 | 13.4 | 1,829.8 | 0.8 | 124.20 # | 24 # | 24 # | 16 # |
| **Minimum:** | 0.7 | 12.4 | 1,324.5 | 0.6 | 2.60 | 1 | 1 | 0 |
| **Maximum:** | 1.3 | 14.0 | 2,114.0 | 0.9 | 6.30 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/01/2014 00:00 | 1.0 | 13.4 | 1,784.0 | 0.8 | 5.40 | 1 | 1 | 1 |
| 02/01/2014 01:00 | 0.8 | 13.9 | 1,621.2 | 0.7 | 3.20 | 1 | 1 | 0 |
| 02/01/2014 02:00 | 0.8 | 13.9 | 1,653.3 | 0.7 | 3.30 | 1 | 1 | 0 |
| 02/01/2014 03:00 | 0.9 | 13.8 | 1,780.3 | 0.7 | 5.30 | 1 | 1 | 0 |
| 02/01/2014 04:00 | 0.6 | 13.9 | 1,462.6 | 0.5 | 2.90 | 1 | 1 | 0 |
| 02/01/2014 05:00 | 1.0 | 13.3 | 1,855.8 | 0.8 | 5.60 | 1 | 1 | 1 |
| 02/01/2014 06:00 | 1.5 | 12.0 | 2,210.1 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/01/2014 07:00 | 1.5 | 12.0 | 2,210.3 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/01/2014 08:00 | 1.3 | 12.3 | 2,157.4 | 0.9 | 6.50 | 1 | 1 | 1 |
| 02/01/2014 09:00 | 1.2 | 12.6 | 2,098.2 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/01/2014 10:00 | 1.0 | 13.5 | 1,829.8 | 0.8 | 5.50 | 1 | 1 | 1 |
| 02/01/2014 11:00 | 0.8 | 13.9 | 1,561.8 | 0.7 | 3.10 | 1 | 1 | 0 |
| 02/01/2014 12:00 | 0.8 | 13.9 | 1,539.0 | 0.7 | 3.10 | 1 | 1 | 0 |
| 02/01/2014 13:00 | 0.9 | 13.9 | 1,588.2 | 0.8 | 4.80 | 1 | 1 | 0 |
| 02/01/2014 14:00 | 0.8 | 14.0 | 1,441.6 | 0.7 | 4.30 | 1 | 1 | 0 |
| 02/01/2014 15:00 | 0.7 | 14.0 | 1,256.1 | 0.6 | 2.50 | 1 | 1 | 0 |
| 02/01/2014 16:00 | 0.7 | 14.0 | 1,306.3 | 0.6 | 2.60 | 1 | 1 | 0 |
| 02/01/2014 17:00 | 1.0 | 13.6 | 1,684.2 | 0.8 | 5.10 | 1 | 1 | 1 |
| 02/01/2014 18:00 | 1.2 | 12.9 | 1,993.9 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/01/2014 19:00 | 1.5 | 12.0 | 2,182.5 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/01/2014 20:00 | 1.6 | 11.8 | 2,231.6 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/01/2014 21:00 | 1.6 | 11.8 | 2,233.4 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/01/2014 22:00 | 1.6 | 11.9 | 2,229.5 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/01/2014 23:00 | 1.5 | 12.1 | 2,211.6 | 1.0 | 8.80 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.1 | 13.1 | 1,838.4 | 0.8 | 137.30 # | 24 # | 24 # | 14 # |
| **Minimum:** | 0.6 | 11.8 | 1,256.1 | 0.5 | 2.50 | 1 | 1 | 0 |
| **Maximum:** | 1.6 | 14.0 | 2,233.4 | 1.0 | 8.90 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/02/2014 00:00 | 1.4 | 12.3 | 2,147.3 | 1.0 | 8.60 | 1 | 1 | 1 |
| 02/02/2014 01:00 | 1.1 | 12.7 | 2,070.2 | 0.8 | 6.20 | 1 | 1 | 1 |
| 02/02/2014 02:00 | 1.1 | 12.7 | 2,064.8 | 0.8 | 6.20 | 1 | 1 | 1 |
| 02/02/2014 03:00 | 1.2 | 12.7 | 2,076.0 | 0.9 | 6.20 | 1 | 1 | 1 |
| 02/02/2014 04:00 | 1.1 | 13.0 | 2,029.1 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/02/2014 05:00 | 1.1 | 13.0 | 2,028.9 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/02/2014 06:00 | 1.1 | 12.9 | 2,044.6 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/02/2014 07:00 | 1.5 | 12.1 | 2,193.1 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/02/2014 08:00 | 1.5 | 12.0 | 2,237.2 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/02/2014 09:00 | 1.5 | 12.0 | 2,236.5 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/02/2014 10:00 | 1.5 | 11.9 | 2,229.5 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/02/2014 11:00 | 1.6 | 11.9 | 2,228.9 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/02/2014 12:00 | 1.6 | 11.9 | 2,216.7 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/02/2014 13:00 | 1.5 | 12.0 | 2,195.5 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/02/2014 14:00 | 1.2 | 12.6 | 2,061.3 | 0.9 | 6.20 | 1 | 1 | 1 |
| 02/02/2014 15:00 | 1.5 | 11.9 | 2,207.7 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/02/2014 16:00 | 1.6 | 11.8 | 2,240.9 | 1.0 | 9.00 | 1 | 1 | 1 |
| 02/02/2014 17:00 | 1.3 | 12.3 | 2,126.4 | 0.9 | 6.40 | 1 | 1 | 1 |
| 02/02/2014 18:00 | 1.1 | 13.1 | 1,951.7 | 0.8 | 5.90 | 1 | 1 | 1 |
| 02/02/2014 19:00 | 1.2 | 12.5 | 2,097.7 | 0.8 | 6.30 | 1 | 1 | 1 |
| 02/02/2014 20:00 | 1.5 | 11.9 | 2,206.3 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/02/2014 21:00 | 1.6 | 11.8 | 2,233.7 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/02/2014 22:00 | 1.4 | 12.2 | 2,145.2 | 0.9 | 6.40 | 1 | 1 | 1 |
| 02/02/2014 23:00 | 1.5 | 11.9 | 2,214.8 | 1.0 | 8.90 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.4 | 12.3 | 2,145.2 | 0.9 | 183.20 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.1 | 11.8 | 1,951.7 | 0.8 | 5.90 | 1 | 1 | 1 |
| **Maximum:** | 1.6 | 13.1 | 2,240.9 | 1.0 | 9.00 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/03/2014 00:00 | 1.5 | 12.0 | 2,190.2 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/03/2014 01:00 | 1.1 | 12.5 | 2,077.3 | 0.8 | 6.20 | 1 | 1 | 1 |
| 02/03/2014 02:00 | 1.1 | 13.0 | 1,988.6 | 0.8 | 6.00 | 1 | 1 | 1 |
| 02/03/2014 03:00 | 1.0 | 13.1 | 1,957.6 | 0.8 | 5.90 | 1 | 1 | 1 |
| 02/03/2014 04:00 | 1.1 | 13.1 | 2,001.5 | 0.8 | 6.00 | 1 | 1 | 1 |
| 02/03/2014 05:00 | 1.2 | 12.6 | 2,098.1 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/03/2014 06:00 | 1.1 | 12.8 | 2,035.0 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/03/2014 07:00 | 1.2 | 12.7 | 2,046.9 | 0.9 | 6.10 | 1 | 1 | 1 |
| 02/03/2014 08:00 | 1.4 | 12.1 | 2,201.2 | 0.9 | 6.60 | 1 | 1 | 1 |
| 02/03/2014 09:00 | 1.3 | 12.3 | 2,155.8 | 0.9 | 6.50 | 1 | 1 | 1 |
| 02/03/2014 10:00 | 1.2 | 12.7 | 2,060.9 | 0.9 | 6.20 | 1 | 1 | 1 |
| 02/03/2014 11:00 | 1.0 | 13.3 | 1,882.4 | 0.8 | 5.60 | 1 | 1 | 1 |
| 02/03/2014 12:00 | 1.1 | 13.2 | 1,914.5 | 0.8 | 5.70 | 1 | 1 | 1 |
| 02/03/2014 13:00 | 1.1 | 13.0 | 1,969.8 | 0.8 | 5.90 | 1 | 1 | 1 |
| 02/03/2014 14:00 | 1.2 | 13.0 | 1,987.3 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/03/2014 15:00 | 1.2 | 13.1 | 1,944.2 | 0.9 | 5.80 | 1 | 1 | 1 |
| 02/03/2014 16:00 | 1.2 | 13.0 | 1,970.7 | 0.9 | 5.90 | 1 | 1 | 1 |
| 02/03/2014 17:00 | 1.3 | 12.6 | 2,057.4 | 0.9 | 6.20 | 1 | 1 | 1 |
| 02/03/2014 18:00 | 1.6 | 11.9 | 2,203.6 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/03/2014 19:00 | 1.7 | 11.7 | 2,241.6 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/03/2014 20:00 | 1.6 | 11.7 | 2,240.3 | 1.0 | 9.00 | 1 | 1 | 1 |
| 02/03/2014 21:00 | 1.6 | 11.8 | 2,225.8 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/03/2014 22:00 | 1.5 | 12.0 | 2,191.8 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/03/2014 23:00 | 1.3 | 12.4 | 2,101.1 | 0.9 | 6.30 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.3 | 12.6 | 2,072.7 | 0.9 | 162.60 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.0 | 11.7 | 1,882.4 | 0.8 | 5.60 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.3 | 2,241.6 | 1.1 | 9.00 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/04/2014 00:00 | 1.2 | 12.8 | 2,063.1 | 0.9 | 6.20 | 1 | 1 | 1 |
| 02/04/2014 01:00 | 1.1 | 13.0 | 2,008.1 | 0.8 | 6.00 | 1 | 1 | 1 |
| 02/04/2014 02:00 | 1.1 | 13.2 | 1,918.2 | 0.8 | 5.80 | 1 | 1 | 1 |
| 02/04/2014 03:00 | 1.1 | 13.2 | 1,955.3 | 0.8 | 5.90 | 1 | 1 | 1 |
| 02/04/2014 04:00 | 1.0 | 13.3 | 1,853.3 | 0.8 | 5.60 | 1 | 1 | 1 |
| 02/04/2014 05:00 | 1.0 | 13.2 | 1,820.8 | 0.8 | 5.50 | 1 | 1 | 1 |
| 02/04/2014 06:00 | 1.1 | 13.0 | 1,983.7 | 0.8 | 6.00 | 1 | 1 | 1 |
| 02/04/2014 07:00 | 1.1 | 13.0 | 2,016.1 | 0.8 | 6.00 | 1 | 1 | 1 |
| 02/04/2014 08:00 | 1.1 | 13.0 | 2,019.7 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/04/2014 09:00 | 1.1 | 13.2 | 1,959.7 | 0.8 | 5.90 | 1 | 1 | 1 |
| 02/04/2014 10:00 | 1.2 | 13.1 | 1,998.1 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/04/2014 11:00 | 1.2 | 13.0 | 2,003.0 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/04/2014 12:00 | 1.2 | 13.1 | 1,963.2 | 0.9 | 5.90 | 1 | 1 | 1 |
| 02/04/2014 13:00 | 1.1 | 13.3 | 1,901.2 | 0.9 | 5.70 | 1 | 1 | 1 |
| 02/04/2014 14:00 | 1.2 | 12.9 | 2,003.7 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/04/2014 15:00 | 1.3 | 12.7 | 2,049.0 | 0.9 | 6.10 | 1 | 1 | 1 |
| 02/04/2014 16:00 | 1.2 | 12.8 | 2,010.6 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/04/2014 17:00 | 1.2 | 12.9 | 2,015.5 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/04/2014 18:00 | 1.3 | 12.5 | 2,097.9 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/04/2014 19:00 | 1.6 | 12.0 | 2,193.6 | 1.1 | 8.80 | 1 | 1 | 1 |
| 02/04/2014 20:00 | 1.5 | 12.1 | 2,162.3 | 1.0 | 8.60 | 1 | 1 | 1 |
| 02/04/2014 21:00 | 1.6 | 11.8 | 2,226.6 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/04/2014 22:00 | 1.6 | 12.0 | 2,198.2 | 1.1 | 8.80 | 1 | 1 | 1 |
| 02/04/2014 23:00 | 1.3 | 12.6 | 2,075.6 | 0.9 | 6.20 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.2 | 12.8 | 2,020.7 | 0.9 | 154.30 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.0 | 11.8 | 1,820.8 | 0.8 | 5.50 | 1 | 1 | 1 |
| **Maximum:** | 1.6 | 13.3 | 2,226.6 | 1.1 | 8.90 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/05/2014 00:00 | 1.2 | 12.8 | 2,023.4 | 0.9 | 6.10 | 1 | 1 | 1 |
| 02/05/2014 01:00 | 1.1 | 13.3 | 1,859.3 | 0.9 | 5.60 | 1 | 1 | 1 |
| 02/05/2014 02:00 | 1.1 | 13.3 | 1,830.4 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/05/2014 03:00 | 1.1 | 13.3 | 1,838.8 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/05/2014 04:00 | 1.1 | 13.3 | 1,841.6 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/05/2014 05:00 | 1.0 | 13.3 | 1,874.5 | 0.8 | 5.60 | 1 | 1 | 1 |
| 02/05/2014 06:00 | 1.1 | 13.2 | 1,933.1 | 0.8 | 5.80 | 1 | 1 | 1 |
| 02/05/2014 07:00 | 1.4 | 12.3 | 2,100.1 | 1.0 | 8.40 | 1 | 1 | 1 |
| 02/05/2014 08:00 | 1.5 | 12.0 | 2,216.6 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/05/2014 09:00 | 1.2 | 12.9 | 2,048.2 | 0.9 | 6.10 | 1 | 1 | 1 |
| 02/05/2014 10:00 | 0.7 | 13.8 | 1,343.5 | 0.6 | 2.70 | 1 | 1 | 1 |
| 02/05/2014 11:00 | 0.8 | 13.5 | 1,551.5 | 0.6 | 3.10 | 1 | 1 | 1 |
| 02/05/2014 12:00 | 1.5 | 11.9 | 2,232.9 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/05/2014 13:00 | 1.4 | 12.2 | 2,150.7 | 0.9 | 6.50 | 1 | 1 | 1 |
| 02/05/2014 14:00 | 1.1 | 13.3 | 1,860.8 | 0.9 | 5.60 | 1 | 1 | 1 |
| 02/05/2014 15:00 | 1.1 | 13.3 | 1,830.0 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/05/2014 16:00 | 1.1 | 13.3 | 1,851.8 | 0.9 | 5.60 | 1 | 1 | 1 |
| 02/05/2014 17:00 | 1.2 | 12.9 | 2,004.7 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/05/2014 18:00 | 1.3 | 12.6 | 2,055.5 | 0.9 | 6.20 | 1 | 1 | 1 |
| 02/05/2014 19:00 | 1.6 | 11.8 | 2,228.3 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/05/2014 20:00 | 1.7 | 11.7 | 2,248.5 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/05/2014 21:00 | 1.6 | 11.7 | 2,241.4 | 1.0 | 9.00 | 1 | 1 | 1 |
| 02/05/2014 22:00 | 1.6 | 11.7 | 2,239.6 | 1.0 | 9.00 | 1 | 1 | 1 |
| 02/05/2014 23:00 | 1.6 | 11.7 | 2,239.7 | 1.0 | 9.00 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.3 | 12.7 | 1,985.2 | 0.9 | 158.00 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.7 | 11.7 | 1,343.5 | 0.6 | 2.70 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.8 | 2,248.5 | 1.1 | 9.00 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/06/2014 00:00 | 1.5 | 12.0 | 2,195.1 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/06/2014 01:00 | 1.0 | 13.1 | 1,929.2 | 0.8 | 5.80 | 1 | 1 | 1 |
| 02/06/2014 02:00 | 0.9 | 13.2 | 1,817.5 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/06/2014 03:00 | 0.9 | 13.2 | 1,819.1 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/06/2014 04:00 | 0.9 | 13.2 | 1,821.1 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/06/2014 05:00 | 0.9 | 13.2 | 1,822.4 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/06/2014 06:00 | 0.9 | 13.2 | 1,832.2 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/06/2014 07:00 | 1.1 | 13.3 | 1,853.9 | 0.9 | 5.60 | 1 | 1 | 1 |
| 02/06/2014 08:00 | 0.9 | 13.2 | 1,917.5 | 0.7 | 5.80 | 1 | 1 | 1 |
| 02/06/2014 09:00 | 0.9 | 13.3 | 1,884.6 | 0.7 | 5.70 | 1 | 1 | 1 |
| 02/06/2014 10:00 | 0.9 | 13.3 | 1,841.8 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/06/2014 11:00 | 0.9 | 13.2 | 1,828.7 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/06/2014 12:00 | 0.9 | 13.2 | 1,822.5 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/06/2014 13:00 | 0.9 | 13.2 | 1,839.7 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/06/2014 14:00 | 0.9 | 13.3 | 1,838.2 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/06/2014 15:00 | 0.9 | 13.3 | 1,867.1 | 0.7 | 5.60 | 1 | 1 | 1 |
| 02/06/2014 16:00 | 0.9 | 13.3 | 1,832.6 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/06/2014 17:00 | 1.0 | 13.3 | 1,875.0 | 0.8 | 5.60 | 1 | 1 | 1 |
| 02/06/2014 18:00 | 0.9 | 13.3 | 1,849.7 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/06/2014 19:00 | 0.9 | 13.3 | 1,908.3 | 0.7 | 5.70 | 1 | 1 | 1 |
| 02/06/2014 20:00 | 0.9 | 13.3 | 1,854.7 | 0.7 | 5.60 | 1 | 1 | 1 |
| 02/06/2014 21:00 | 0.9 | 13.3 | 1,839.6 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/06/2014 22:00 | 0.9 | 13.3 | 1,841.4 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/06/2014 23:00 | 0.9 | 13.3 | 1,843.3 | 0.7 | 5.50 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.9 | 13.2 | 1,865.6 | 0.7 | 136.70 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.9 | 12.0 | 1,817.5 | 0.7 | 5.50 | 1 | 1 | 1 |
| **Maximum:** | 1.5 | 13.3 | 2,195.1 | 1.0 | 8.80 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/07/2014 00:00 | 0.9 | 13.3 | 1,841.4 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/07/2014 01:00 | 1.0 | 12.9 | 1,984.4 | 0.7 | 6.00 | 1 | 1 | 1 |
| 02/07/2014 02:00 | 1.1 | 12.6 | 2,037.7 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/07/2014 03:00 | 1.1 | 12.7 | 2,041.1 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/07/2014 04:00 | 1.4 | 11.9 | 2,187.4 | 0.9 | 6.60 | 1 | 1 | 1 |
| 02/07/2014 05:00 | 1.4 | 11.9 | 2,195.9 | 0.9 | 6.60 | 1 | 1 | 1 |
| 02/07/2014 06:00 | 1.6 | 11.7 | 2,240.9 | 1.0 | 9.00 | 1 | 1 | 1 |
| 02/07/2014 07:00 | 1.6 | 11.6 | 2,255.0 | 1.0 | 9.00 | 1 | 1 | 1 |
| 02/07/2014 08:00 | 1.6 | 11.6 | 2,259.0 | 1.0 | 9.00 | 1 | 1 | 1 |
| 02/07/2014 09:00 | 1.3 | 12.2 | 2,143.4 | 0.9 | 6.40 | 1 | 1 | 1 |
| 02/07/2014 10:00 | 1.0 | 12.8 | 2,020.4 | 0.7 | 6.10 | 1 | 1 | 1 |
| 02/07/2014 11:00 | 1.0 | 12.8 | 2,019.4 | 0.7 | 6.10 | 1 | 1 | 1 |
| 02/07/2014 12:00 | 1.0 | 12.6 | 2,044.8 | 0.7 | 6.10 | 1 | 1 | 1 |
| 02/07/2014 13:00 | 1.0 | 12.8 | 1,998.0 | 0.7 | 6.00 | 1 | 1 | 1 |
| 02/07/2014 14:00 | 0.9 | 13.0 | 1,921.9 | 0.7 | 3.80 | 1 | 1 | 1 |
| 02/07/2014 15:00 | 0.8 | 13.3 | 1,833.6 | 0.6 | 3.70 | 1 | 1 | 1 |
| 02/07/2014 16:00 | 1.0 | 12.8 | 2,004.3 | 0.7 | 6.00 | 1 | 1 | 1 |
| 02/07/2014 17:00 | 1.0 | 12.7 | 2,008.2 | 0.7 | 6.00 | 1 | 1 | 1 |
| 02/07/2014 18:00 | 1.1 | 12.5 | 2,065.2 | 0.8 | 6.20 | 1 | 1 | 1 |
| 02/07/2014 19:00 | 1.4 | 11.7 | 2,215.9 | 0.9 | 6.60 | 1 | 1 | 1 |
| 02/07/2014 20:00 | 1.1 | 12.5 | 2,055.2 | 0.8 | 6.20 | 1 | 1 | 1 |
| 02/07/2014 21:00 | 1.0 | 12.7 | 2,011.0 | 0.7 | 6.00 | 1 | 1 | 1 |
| 02/07/2014 22:00 | 1.0 | 12.7 | 2,011.4 | 0.7 | 6.00 | 1 | 1 | 1 |
| 02/07/2014 23:00 | 1.0 | 12.6 | 2,017.7 | 0.7 | 6.10 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.1 | 12.5 | 2,058.9 | 0.8 | 151.20 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.8 | 11.6 | 1,833.6 | 0.6 | 3.70 | 1 | 1 | 1 |
| **Maximum:** | 1.6 | 13.3 | 2,259.0 | 1.0 | 9.00 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/08/2014 00:00 | 1.0 | 13.1 | 1,918.1 | 0.8 | 5.80 | 1 | 1 | 1 |
| 02/08/2014 01:00 | 0.9 | 13.2 | 1,895.7 | 0.7 | 5.70 | 1 | 1 | 1 |
| 02/08/2014 02:00 | 0.9 | 13.3 | 1,866.7 | 0.7 | 5.60 | 1 | 1 | 1 |
| 02/08/2014 03:00 | 0.8 | 13.4 | 1,857.2 | 0.6 | 3.70 | 1 | 1 | 1 |
| 02/08/2014 04:00 | 0.8 | 13.4 | 1,863.0 | 0.6 | 3.70 | 1 | 1 | 1 |
| 02/08/2014 05:00 | 0.8 | 13.4 | 1,862.5 | 0.6 | 3.70 | 1 | 1 | 1 |
| 02/08/2014 06:00 | 0.9 | 13.4 | 1,844.8 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/08/2014 07:00 | 0.9 | 13.2 | 1,878.3 | 0.7 | 5.60 | 1 | 1 | 1 |
| 02/08/2014 08:00 | 0.9 | 13.2 | 1,830.3 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/08/2014 09:00 | 0.9 | 13.2 | 1,828.0 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/08/2014 10:00 | 0.8 | 13.2 | 1,820.4 | 0.6 | 3.60 | 1 | 1 | 1 |
| 02/08/2014 11:00 | 0.8 | 13.2 | 1,819.0 | 0.6 | 3.60 | 1 | 1 | 1 |
| 02/08/2014 12:00 | 0.8 | 13.2 | 1,818.4 | 0.6 | 3.60 | 1 | 1 | 1 |
| 02/08/2014 13:00 | 0.8 | 13.2 | 1,851.6 | 0.6 | 3.70 | 1 | 1 | 1 |
| 02/08/2014 14:00 | 0.8 | 13.2 | 1,813.2 | 0.6 | 3.60 | 1 | 1 | 1 |
| 02/08/2014 15:00 | 0.8 | 13.2 | 1,815.6 | 0.6 | 3.60 | 1 | 1 | 1 |
| 02/08/2014 16:00 | 0.8 | 13.2 | 1,815.1 | 0.6 | 3.60 | 1 | 1 | 1 |
| 02/08/2014 17:00 | 0.8 | 13.3 | 1,823.8 | 0.6 | 3.60 | 1 | 1 | 1 |
| 02/08/2014 18:00 | 1.0 | 13.0 | 1,923.6 | 0.7 | 5.80 | 1 | 1 | 1 |
| 02/08/2014 19:00 | 1.3 | 12.1 | 2,110.6 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/08/2014 20:00 | 1.1 | 12.5 | 2,024.4 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/08/2014 21:00 | 1.2 | 12.4 | 2,046.0 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/08/2014 22:00 | 1.0 | 13.1 | 1,887.9 | 0.8 | 5.70 | 1 | 1 | 1 |
| 02/08/2014 23:00 | 0.9 | 13.5 | 1,811.6 | 0.7 | 5.40 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.9 | 13.1 | 1,876.1 | 0.7 | 114.60 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.8 | 12.1 | 1,811.6 | 0.6 | 3.60 | 1 | 1 | 1 |
| **Maximum:** | 1.3 | 13.5 | 2,110.6 | 0.9 | 6.30 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/09/2014 00:00 | 0.9 | 13.6 | 1,802.2 | 0.7 | 5.40 | 1 | 1 | 1 |
| 02/09/2014 01:00 | 1.1 | 13.1 | 1,913.3 | 0.8 | 5.70 | 1 | 1 | 1 |
| 02/09/2014 02:00 | 0.9 | 13.5 | 1,816.4 | 0.7 | 5.40 | 1 | 1 | 1 |
| 02/09/2014 03:00 | 0.9 | 13.6 | 1,801.3 | 0.7 | 5.40 | 1 | 1 | 1 |
| 02/09/2014 04:00 | 0.9 | 13.6 | 1,800.4 | 0.7 | 5.40 | 1 | 1 | 1 |
| 02/09/2014 05:00 | 0.9 | 13.6 | 1,798.4 | 0.7 | 5.40 | 1 | 1 | 1 |
| 02/09/2014 06:00 | 0.9 | 13.5 | 1,811.6 | 0.7 | 5.40 | 1 | 1 | 1 |
| 02/09/2014 07:00 | 0.9 | 13.2 | 1,820.6 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/09/2014 08:00 | 0.9 | 13.2 | 1,820.3 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/09/2014 09:00 | 0.9 | 13.2 | 1,820.6 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/09/2014 10:00 | 0.9 | 13.2 | 1,824.6 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/09/2014 11:00 | 0.9 | 13.3 | 1,817.4 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/09/2014 12:00 | 0.9 | 13.3 | 1,812.2 | 0.7 | 5.40 | 1 | 1 | 1 |
| 02/09/2014 13:00 | 0.9 | 13.3 | 1,815.2 | 0.7 | 5.40 | 1 | 1 | 1 |
| 02/09/2014 14:00 | 0.9 | 13.3 | 1,819.9 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/09/2014 15:00 | 0.8 | 13.3 | 1,821.4 | 0.6 | 3.60 | 1 | 1 | 1 |
| 02/09/2014 16:00 | 0.9 | 13.2 | 1,849.4 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/09/2014 17:00 | 0.9 | 13.2 | 1,850.7 | 0.7 | 5.60 | 1 | 1 | 1 |
| 02/09/2014 18:00 | 1.0 | 12.9 | 1,939.3 | 0.7 | 5.80 | 1 | 1 | 1 |
| 02/09/2014 19:00 | 1.6 | 11.6 | 2,196.6 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/09/2014 20:00 | 1.6 | 11.5 | 2,208.2 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/09/2014 21:00 | 1.6 | 11.5 | 2,209.2 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/09/2014 22:00 | 1.3 | 12.0 | 2,101.9 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/09/2014 23:00 | 1.2 | 12.3 | 2,045.0 | 0.8 | 6.10 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.0 | 13.0 | 1,896.5 | 0.8 | 141.20 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.8 | 11.5 | 1,798.4 | 0.6 | 3.60 | 1 | 1 | 1 |
| **Maximum:** | 1.6 | 13.6 | 2,209.2 | 1.0 | 8.80 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/10/2014 00:00 | 0.6 | 13.7 | 1,478.2 | 0.5 | 3.00 | 1 | 1 | 1 |
| 02/10/2014 01:00 | 0.6 | 13.8 | 1,335.3 | 0.5 | 2.70 | 1 | 1 | 0 |
| 02/10/2014 02:00 | 0.6 | 13.8 | 1,364.4 | 0.5 | 2.70 | 1 | 1 | 0 |
| 02/10/2014 03:00 | 0.5 | 13.9 | 1,242.3 | 0.4 | 2.50 | 1 | 1 | 0 |
| 02/10/2014 04:00 | 0.5 | 13.9 | 1,242.3 | 0.4 | 2.50 | 1 | 1 | 0 |
| 02/10/2014 05:00 | 0.6 | 13.8 | 1,422.7 | 0.5 | 2.80 | 1 | 1 | 1 |
| 02/10/2014 06:00 | 0.9 | 13.4 | 1,850.4 | 0.7 | 5.60 | 1 | 1 | 1 |
| 02/10/2014 07:00 | 0.9 | 13.2 | 1,884.3 | 0.7 | 5.70 | 1 | 1 | 1 |
| 02/10/2014 08:00 | 1.0 | 13.0 | 1,957.4 | 0.7 | 5.90 | 1 | 1 | 1 |
| 02/10/2014 09:00 | 0.9 | 13.3 | 1,862.7 | 0.7 | 5.60 | 1 | 1 | 1 |
| 02/10/2014 10:00 | 0.9 | 13.3 | 1,853.7 | 0.7 | 5.60 | 1 | 1 | 1 |
| 02/10/2014 11:00 | 0.9 | 13.3 | 1,833.3 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/10/2014 12:00 | 0.9 | 13.3 | 1,838.5 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/10/2014 13:00 | 0.9 | 13.3 | 1,841.6 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/10/2014 14:00 | 0.9 | 13.3 | 1,845.1 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/10/2014 15:00 | 0.9 | 13.3 | 1,836.2 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/10/2014 16:00 | 0.9 | 13.3 | 1,835.0 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/10/2014 17:00 | 0.9 | 13.3 | 1,833.8 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/10/2014 18:00 | 0.9 | 13.2 | 1,877.6 | 0.7 | 5.60 | 1 | 1 | 1 |
| 02/10/2014 19:00 | 1.1 | 12.7 | 2,006.3 | 0.8 | 6.00 | 1 | 1 | 1 |
| 02/10/2014 20:00 | 1.1 | 12.7 | 2,019.7 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/10/2014 21:00 | 1.2 | 12.3 | 2,099.8 | 0.8 | 6.30 | 1 | 1 | 1 |
| 02/10/2014 22:00 | 1.0 | 12.9 | 1,974.1 | 0.7 | 5.90 | 1 | 1 | 1 |
| 02/10/2014 23:00 | 0.9 | 13.5 | 1,834.5 | 0.7 | 5.50 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.9 | 13.3 | 1,757.1 | 0.7 | 118.50 # | 24 # | 24 # | 20 # |
| **Minimum:** | 0.5 | 12.3 | 1,242.3 | 0.4 | 2.50 | 1 | 1 | 0 |
| **Maximum:** | 1.2 | 13.9 | 2,099.8 | 0.8 | 6.30 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/11/2014 00:00 | 0.9 | 13.5 | 1,799.6 | 0.7 | 5.40 | 1 | 1 | 1 |
| 02/11/2014 01:00 | 0.9 | 13.3 | 1,823.2 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/11/2014 02:00 | 0.9 | 13.3 | 1,810.0 | 0.7 | 5.40 | 1 | 1 | 1 |
| 02/11/2014 03:00 | 0.8 | 13.5 | 1,584.3 | 0.6 | 3.20 | 1 | 1 | 1 |
| 02/11/2014 04:00 | 0.5 | 13.9 | 1,246.2 | 0.4 | 2.50 | 1 | 1 | 0 |
| 02/11/2014 05:00 | 0.7 | 13.8 | 1,507.5 | 0.6 | 3.00 | 1 | 1 | 1 |
| 02/11/2014 06:00 | 0.9 | 13.2 | 1,818.4 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/11/2014 07:00 | 1.0 | 13.2 | 1,833.3 | 0.8 | 5.50 | 1 | 1 | 1 |
| 02/11/2014 08:00 | 1.1 | 12.8 | 2,021.3 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/11/2014 09:00 | 1.1 | 12.9 | 1,989.0 | 0.8 | 6.00 | 1 | 1 | 1 |
| 02/11/2014 10:00 | 0.9 | 13.3 | 1,868.5 | 0.7 | 5.60 | 1 | 1 | 1 |
| 02/11/2014 11:00 | 0.9 | 13.3 | 1,834.9 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/11/2014 12:00 | 0.9 | 13.3 | 1,841.6 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/11/2014 13:00 | 0.9 | 13.3 | 1,843.5 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/11/2014 14:00 | 0.9 | 13.3 | 1,844.9 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/11/2014 15:00 | 0.9 | 13.3 | 1,843.0 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/11/2014 16:00 | 0.9 | 13.3 | 1,832.9 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/11/2014 17:00 | 0.9 | 13.3 | 1,842.8 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/11/2014 18:00 | 0.9 | 13.2 | 1,872.2 | 0.7 | 5.60 | 1 | 1 | 1 |
| 02/11/2014 19:00 | 1.1 | 12.7 | 2,017.7 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/11/2014 20:00 | 1.1 | 12.7 | 2,026.6 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/11/2014 21:00 | 1.3 | 12.3 | 2,103.7 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/11/2014 22:00 | 1.1 | 12.8 | 1,995.3 | 0.8 | 6.00 | 1 | 1 | 1 |
| 02/11/2014 23:00 | 1.0 | 13.1 | 1,921.6 | 0.8 | 5.80 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.9 | 13.2 | 1,838.4 | 0.7 | 128.10 # | 24 # | 24 # | 23 # |
| **Minimum:** | 0.5 | 12.3 | 1,246.2 | 0.4 | 2.50 | 1 | 1 | 0 |
| **Maximum:** | 1.3 | 13.9 | 2,103.7 | 0.9 | 6.30 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/12/2014 00:00 | 0.9 | 13.2 | 1,854.5 | 0.7 | 5.60 | 1 | 1 | 1 |
| 02/12/2014 01:00 | 1.0 | 12.9 | 1,975.5 | 0.7 | 5.90 | 1 | 1 | 1 |
| 02/12/2014 02:00 | 1.0 | 12.9 | 1,982.6 | 0.7 | 5.90 | 1 | 1 | 1 |
| 02/12/2014 03:00 | 1.0 | 12.9 | 1,993.4 | 0.7 | 6.00 | 1 | 1 | 1 |
| 02/12/2014 04:00 | 1.1 | 12.8 | 2,004.3 | 0.8 | 6.00 | 1 | 1 | 1 |
| 02/12/2014 05:00 | 1.1 | 12.8 | 1,997.7 | 0.8 | 6.00 | 1 | 1 | 1 |
| 02/12/2014 06:00 | 1.0 | 13.0 | 1,949.8 | 0.7 | 5.80 | 1 | 1 | 1 |
| 02/12/2014 07:00 | 1.2 | 12.5 | 2,041.7 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/12/2014 08:00 | 1.1 | 12.7 | 2,021.6 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/12/2014 09:00 | 0.9 | 13.2 | 1,870.8 | 0.7 | 5.60 | 1 | 1 | 1 |
| 02/12/2014 10:00 | 1.0 | 13.2 | 1,824.2 | 0.8 | 5.50 | 1 | 1 | 1 |
| 02/12/2014 11:00 | 0.9 | 13.2 | 1,824.0 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/12/2014 12:00 | 0.9 | 13.2 | 1,827.5 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/12/2014 13:00 | 0.9 | 13.2 | 1,825.1 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/12/2014 14:00 | 0.9 | 13.3 | 1,828.6 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/12/2014 15:00 | 0.9 | 13.3 | 1,830.2 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/12/2014 16:00 | 0.9 | 13.3 | 1,829.2 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/12/2014 17:00 | 0.9 | 13.3 | 1,849.4 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/12/2014 18:00 | 1.2 | 12.5 | 2,040.0 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/12/2014 19:00 | 1.7 | 11.6 | 2,226.6 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/12/2014 20:00 | 1.7 | 11.6 | 2,212.9 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/12/2014 21:00 | 1.5 | 11.8 | 2,171.0 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/12/2014 22:00 | 1.2 | 12.4 | 2,075.2 | 0.8 | 6.20 | 1 | 1 | 1 |
| 02/12/2014 23:00 | 1.1 | 13.0 | 1,948.2 | 0.8 | 5.80 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.1 | 12.8 | 1,958.5 | 0.8 | 147.60 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.9 | 11.6 | 1,824.0 | 0.7 | 5.50 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.3 | 2,226.6 | 1.1 | 8.90 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/13/2014 00:00 | 0.9 | 13.2 | 1,865.1 | 0.7 | 5.60 | 1 | 1 | 1 |
| 02/13/2014 01:00 | 0.9 | 13.2 | 1,827.7 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/13/2014 02:00 | 0.9 | 13.2 | 1,822.5 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/13/2014 03:00 | 0.9 | 13.2 | 1,822.4 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/13/2014 04:00 | 0.9 | 13.2 | 1,815.3 | 0.7 | 5.40 | 1 | 1 | 1 |
| 02/13/2014 05:00 | 0.9 | 13.2 | 1,836.6 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/13/2014 06:00 | 1.0 | 13.1 | 1,895.3 | 0.8 | 5.70 | 1 | 1 | 1 |
| 02/13/2014 07:00 | 1.4 | 12.1 | 2,090.4 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/13/2014 08:00 | 1.6 | 11.7 | 2,213.9 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/13/2014 09:00 | 1.4 | 12.2 | 2,115.7 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/13/2014 10:00 | 1.3 | 12.3 | 2,095.2 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/13/2014 11:00 | 1.3 | 12.3 | 2,096.4 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/13/2014 12:00 | 1.3 | 12.3 | 2,099.8 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/13/2014 13:00 | 1.3 | 12.2 | 2,098.7 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/13/2014 14:00 | 1.3 | 12.2 | 2,100.9 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/13/2014 15:00 | 1.3 | 12.2 | 2,097.8 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/13/2014 16:00 | 1.3 | 12.2 | 2,101.7 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/13/2014 17:00 | 1.4 | 12.1 | 2,119.7 | 0.9 | 6.40 | 1 | 1 | 1 |
| 02/13/2014 18:00 | 1.4 | 12.1 | 2,108.1 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/13/2014 19:00 | 1.5 | 11.8 | 2,182.5 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/13/2014 20:00 | 1.7 | 11.5 | 2,229.5 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/13/2014 21:00 | 1.7 | 11.5 | 2,230.5 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/13/2014 22:00 | 1.5 | 11.9 | 2,147.2 | 1.0 | 8.60 | 1 | 1 | 1 |
| 02/13/2014 23:00 | 1.3 | 12.2 | 2,097.7 | 0.9 | 6.30 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.3 | 12.4 | 2,046.3 | 0.9 | 158.40 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.9 | 11.5 | 1,815.3 | 0.7 | 5.40 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.2 | 2,230.5 | 1.1 | 8.90 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/14/2014 00:00 | 1.1 | 12.7 | 1,996.6 | 0.8 | 6.00 | 1 | 1 | 1 |
| 02/14/2014 01:00 | 0.9 | 13.2 | 1,812.6 | 0.7 | 5.40 | 1 | 1 | 1 |
| 02/14/2014 02:00 | 0.9 | 13.2 | 1,835.7 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/14/2014 03:00 | 0.9 | 13.2 | 1,815.6 | 0.7 | 5.40 | 1 | 1 | 1 |
| 02/14/2014 04:00 | 0.9 | 13.2 | 1,815.1 | 0.7 | 5.40 | 1 | 1 | 1 |
| 02/14/2014 05:00 | 0.9 | 13.3 | 1,820.0 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/14/2014 06:00 | 0.9 | 13.3 | 1,835.0 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/14/2014 07:00 | 1.0 | 13.1 | 1,878.7 | 0.8 | 5.60 | 1 | 1 | 1 |
| 02/14/2014 08:00 | 1.1 | 12.8 | 1,967.0 | 0.8 | 5.90 | 1 | 1 | 1 |
| 02/14/2014 09:00 | 1.3 | 12.3 | 2,082.0 | 0.9 | 6.20 | 1 | 1 | 1 |
| 02/14/2014 10:00 | 1.4 | 12.0 | 2,112.4 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/14/2014 11:00 | 1.5 | 12.0 | 2,118.3 | 1.0 | 8.50 | 1 | 1 | 1 |
| 02/14/2014 12:00 | 1.6 | 11.9 | 2,120.8 | 1.0 | 8.50 | 1 | 1 | 1 |
| 02/14/2014 13:00 | 1.6 | 11.9 | 2,128.4 | 1.0 | 8.50 | 1 | 1 | 1 |
| 02/14/2014 14:00 | 1.5 | 11.8 | 2,131.2 | 1.0 | 8.50 | 1 | 1 | 1 |
| 02/14/2014 15:00 | 1.6 | 11.8 | 2,132.8 | 1.0 | 8.50 | 1 | 1 | 1 |
| 02/14/2014 16:00 | 1.3 | 12.4 | 1,973.7 | 0.9 | 5.90 | 1 | 1 | 1 |
| 02/14/2014 17:00 | 1.5 | 11.9 | 2,117.3 | 1.0 | 8.50 | 1 | 1 | 1 |
| 02/14/2014 18:00 | 1.5 | 11.9 | 2,116.4 | 1.0 | 8.50 | 1 | 1 | 1 |
| 02/14/2014 19:00 | 1.3 | 12.3 | 2,043.5 | 0.9 | 6.10 | 1 | 1 | 1 |
| 02/14/2014 20:00 | 1.2 | 12.5 | 2,036.7 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/14/2014 21:00 | 1.3 | 12.2 | 2,094.8 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/14/2014 22:00 | 1.4 | 12.1 | 2,107.3 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/14/2014 23:00 | 1.2 | 12.5 | 2,021.2 | 0.8 | 6.10 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.2 | 12.5 | 2,004.7 | 0.9 | 159.00 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.9 | 11.8 | 1,812.6 | 0.7 | 5.40 | 1 | 1 | 1 |
| **Maximum:** | 1.6 | 13.3 | 2,132.8 | 1.0 | 8.50 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/15/2014 00:00 | 1.1 | 12.6 | 2,003.8 | 0.8 | 6.00 | 1 | 1 | 1 |
| 02/15/2014 01:00 | 1.3 | 12.3 | 2,068.4 | 0.9 | 6.20 | 1 | 1 | 1 |
| 02/15/2014 02:00 | 1.6 | 11.8 | 2,179.5 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/15/2014 03:00 | 1.6 | 11.7 | 2,196.4 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/15/2014 04:00 | 1.3 | 12.4 | 2,043.0 | 0.9 | 6.10 | 1 | 1 | 1 |
| 02/15/2014 05:00 | 1.1 | 12.7 | 2,000.2 | 0.8 | 6.00 | 1 | 1 | 1 |
| 02/15/2014 06:00 | 1.2 | 12.5 | 2,032.2 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/15/2014 07:00 | 1.2 | 12.7 | 1,969.6 | 0.9 | 5.90 | 1 | 1 | 1 |
| 02/15/2014 08:00 | 1.1 | 12.7 | 1,986.7 | 0.8 | 6.00 | 1 | 1 | 1 |
| 02/15/2014 09:00 | 1.2 | 12.5 | 2,031.5 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/15/2014 10:00 | 1.3 | 12.1 | 2,112.7 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/15/2014 11:00 | 1.7 | 11.6 | 2,213.5 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/15/2014 12:00 | 1.7 | 11.5 | 2,207.0 | 1.1 | 8.80 | 1 | 1 | 1 |
| 02/15/2014 13:00 | 1.6 | 11.8 | 2,154.6 | 1.0 | 8.60 | 1 | 1 | 1 |
| 02/15/2014 14:00 | 1.3 | 12.5 | 2,016.7 | 0.9 | 6.10 | 1 | 1 | 1 |
| 02/15/2014 15:00 | 1.2 | 12.6 | 1,995.3 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/15/2014 16:00 | 1.2 | 12.8 | 1,964.9 | 0.9 | 5.90 | 1 | 1 | 1 |
| 02/15/2014 17:00 | 1.2 | 12.6 | 1,993.7 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/15/2014 18:00 | 1.3 | 12.3 | 2,061.4 | 0.9 | 6.20 | 1 | 1 | 1 |
| 02/15/2014 19:00 | 1.7 | 11.6 | 2,196.8 | 1.1 | 8.80 | 1 | 1 | 1 |
| 02/15/2014 20:00 | 1.6 | 11.8 | 2,174.5 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/15/2014 21:00 | 1.7 | 11.7 | 2,187.8 | 1.1 | 8.80 | 1 | 1 | 1 |
| 02/15/2014 22:00 | 1.4 | 12.1 | 2,097.2 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/15/2014 23:00 | 1.0 | 13.0 | 1,896.6 | 0.7 | 5.70 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.4 | 12.2 | 2,074.3 | 0.9 | 167.00 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.0 | 11.5 | 1,896.6 | 0.7 | 5.70 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.0 | 2,213.5 | 1.1 | 8.90 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/16/2014 00:00 | 0.9 | 13.3 | 1,833.4 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/16/2014 01:00 | 1.0 | 13.3 | 1,848.5 | 0.8 | 5.50 | 1 | 1 | 1 |
| 02/16/2014 02:00 | 1.1 | 13.2 | 1,880.7 | 0.8 | 5.60 | 1 | 1 | 1 |
| 02/16/2014 03:00 | 1.0 | 13.5 | 1,701.5 | 0.8 | 5.10 | 1 | 1 | 1 |
| 02/16/2014 04:00 | 0.7 | 13.9 | 1,274.0 | 0.6 | 2.50 | 1 | 1 | 0 |
| 02/16/2014 05:00 | 0.8 | 13.8 | 1,472.5 | 0.7 | 2.90 | 1 | 1 | 0 |
| 02/16/2014 06:00 | 0.9 | 13.6 | 1,643.4 | 0.7 | 4.90 | 1 | 1 | 1 |
| 02/16/2014 07:00 | 1.3 | 13.1 | 1,950.7 | 1.0 | 7.80 | 1 | 1 | 1 |
| 02/16/2014 08:00 | 1.2 | 13.4 | 1,869.3 | 0.9 | 5.60 | 1 | 1 | 1 |
| 02/16/2014 09:00 | 1.1 | 13.7 | 1,826.4 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/16/2014 10:00 | 1.0 | 13.7 | 1,815.4 | 0.8 | 5.40 | 1 | 1 | 1 |
| 02/16/2014 11:00 | 1.1 | 13.7 | 1,814.6 | 0.9 | 5.40 | 1 | 1 | 1 |
| 02/16/2014 12:00 | 1.1 | 13.7 | 1,815.4 | 0.9 | 5.40 | 1 | 1 | 1 |
| 02/16/2014 13:00 | 1.1 | 13.7 | 1,811.9 | 0.9 | 5.40 | 1 | 1 | 1 |
| 02/16/2014 14:00 | 1.1 | 13.7 | 1,815.8 | 0.9 | 5.40 | 1 | 1 | 1 |
| 02/16/2014 15:00 | 1.1 | 13.6 | 1,832.5 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/16/2014 16:00 | 1.1 | 13.7 | 1,821.6 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/16/2014 17:00 | 1.1 | 13.7 | 1,828.3 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/16/2014 18:00 | 1.1 | 13.1 | 1,922.9 | 0.8 | 5.80 | 1 | 1 | 1 |
| 02/16/2014 19:00 | 1.6 | 11.9 | 2,185.4 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/16/2014 20:00 | 1.6 | 11.8 | 2,203.1 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/16/2014 21:00 | 1.6 | 11.8 | 2,202.3 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/16/2014 22:00 | 1.6 | 11.8 | 2,203.8 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/16/2014 23:00 | 1.3 | 12.7 | 2,003.9 | 0.9 | 6.00 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.1 | 13.2 | 1,857.4 | 0.9 | 141.30 # | 24 # | 24 # | 22 # |
| **Minimum:** | 0.7 | 11.8 | 1,274.0 | 0.6 | 2.50 | 1 | 1 | 0 |
| **Maximum:** | 1.6 | 13.9 | 2,203.8 | 1.0 | 8.80 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/17/2014 00:00 | 1.1 | 13.3 | 1,842.6 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/17/2014 01:00 | 1.1 | 13.3 | 1,828.9 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/17/2014 02:00 | 1.0 | 13.5 | 1,740.3 | 0.8 | 5.20 | 1 | 1 | 1 |
| 02/17/2014 03:00 | 0.7 | 13.9 | 1,295.9 | 0.6 | 2.60 | 1 | 1 | 0 |
| 02/17/2014 04:00 | 0.7 | 13.9 | 1,369.9 | 0.6 | 2.70 | 1 | 1 | 0 |
| 02/17/2014 05:00 | 0.9 | 13.6 | 1,574.9 | 0.7 | 4.70 | 1 | 1 | 1 |
| 02/17/2014 06:00 | 1.2 | 13.1 | 1,952.7 | 0.9 | 5.90 | 1 | 1 | 1 |
| 02/17/2014 07:00 | 1.1 | 12.9 | 1,991.7 | 0.8 | 6.00 | 1 | 1 | 1 |
| 02/17/2014 08:00 | 1.2 | 13.0 | 1,952.0 | 0.9 | 5.90 | 1 | 1 | 1 |
| 02/17/2014 09:00 | 1.1 | 13.3 | 1,886.1 | 0.9 | 5.70 | 1 | 1 | 1 |
| 02/17/2014 10:00 | 1.0 | 13.3 | 1,821.6 | 0.8 | 5.50 | 1 | 1 | 1 |
| 02/17/2014 11:00 | 1.1 | 13.3 | 1,821.5 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/17/2014 12:00 | 1.1 | 13.3 | 1,826.5 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/17/2014 13:00 | 1.1 | 13.3 | 1,826.8 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/17/2014 14:00 | 1.1 | 13.3 | 1,828.0 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/17/2014 15:00 | 1.1 | 13.3 | 1,828.3 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/17/2014 16:00 | 1.1 | 13.3 | 1,826.7 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/17/2014 17:00 | 1.1 | 13.3 | 1,826.3 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/17/2014 18:00 | 1.1 | 13.4 | 1,848.0 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/17/2014 19:00 | 1.1 | 13.3 | 1,888.7 | 0.9 | 5.70 | 1 | 1 | 1 |
| 02/17/2014 20:00 | 1.3 | 12.6 | 2,043.5 | 0.9 | 6.10 | 1 | 1 | 1 |
| 02/17/2014 21:00 | 1.6 | 12.0 | 2,166.3 | 1.1 | 8.70 | 1 | 1 | 1 |
| 02/17/2014 22:00 | 1.3 | 12.7 | 2,012.1 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/17/2014 23:00 | 1.0 | 13.2 | 1,878.5 | 0.8 | 5.60 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.1 | 13.2 | 1,828.2 | 0.9 | 131.30 # | 24 # | 24 # | 22 # |
| **Minimum:** | 0.7 | 12.0 | 1,295.9 | 0.6 | 2.60 | 1 | 1 | 0 |
| **Maximum:** | 1.6 | 13.9 | 2,166.3 | 1.1 | 8.70 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/18/2014 00:00 | 1.1 | 13.3 | 1,832.5 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/18/2014 01:00 | 1.1 | 13.3 | 1,825.5 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/18/2014 02:00 | 1.0 | 13.2 | 1,823.8 | 0.8 | 5.50 | 1 | 1 | 1 |
| 02/18/2014 03:00 | 1.0 | 13.3 | 1,823.1 | 0.8 | 5.50 | 1 | 1 | 1 |
| 02/18/2014 04:00 | 1.0 | 13.3 | 1,820.0 | 0.8 | 5.50 | 1 | 1 | 1 |
| 02/18/2014 05:00 | 1.0 | 13.2 | 1,820.6 | 0.8 | 5.50 | 1 | 1 | 1 |
| 02/18/2014 06:00 | 1.0 | 13.2 | 1,862.9 | 0.8 | 5.60 | 1 | 1 | 1 |
| 02/18/2014 07:00 | 1.2 | 12.5 | 2,018.1 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/18/2014 08:00 | 1.4 | 12.4 | 2,083.4 | 1.0 | 8.30 | 1 | 1 | 1 |
| 02/18/2014 09:00 | 1.2 | 13.0 | 1,952.9 | 0.9 | 5.90 | 1 | 1 | 1 |
| 02/18/2014 10:00 | 1.1 | 13.0 | 1,947.6 | 0.8 | 5.80 | 1 | 1 | 1 |
| 02/18/2014 11:00 | 1.3 | 12.7 | 1,994.5 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/18/2014 12:00 | 1.3 | 12.5 | 2,033.7 | 0.9 | 6.10 | 1 | 1 | 1 |
| 02/18/2014 13:00 | 1.2 | 12.9 | 1,945.5 | 0.9 | 5.80 | 1 | 1 | 1 |
| 02/18/2014 14:00 | 1.0 | 13.3 | 1,825.4 | 0.8 | 5.50 | 1 | 1 | 1 |
| 02/18/2014 15:00 | 1.0 | 13.3 | 1,836.4 | 0.8 | 5.50 | 1 | 1 | 1 |
| 02/18/2014 16:00 | 1.0 | 13.3 | 1,799.0 | 0.8 | 5.40 | 1 | 1 | 1 |
| 02/18/2014 17:00 | 1.2 | 12.9 | 1,924.1 | 0.9 | 5.80 | 1 | 1 | 1 |
| 02/18/2014 18:00 | 1.6 | 11.9 | 2,140.5 | 1.0 | 8.60 | 1 | 1 | 1 |
| 02/18/2014 19:00 | 1.6 | 11.6 | 2,194.2 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/18/2014 20:00 | 1.3 | 12.5 | 2,032.5 | 0.9 | 6.10 | 1 | 1 | 1 |
| 02/18/2014 21:00 | 1.6 | 11.8 | 2,163.8 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/18/2014 22:00 | 1.1 | 13.2 | 1,882.2 | 0.8 | 5.60 | 1 | 1 | 1 |
| 02/18/2014 23:00 | 0.9 | 13.8 | 1,555.5 | 0.7 | 4.70 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.2 | 12.9 | 1,922.4 | 0.9 | 147.30 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.9 | 11.6 | 1,555.5 | 0.7 | 4.70 | 1 | 1 | 1 |
| **Maximum:** | 1.6 | 13.8 | 2,194.2 | 1.0 | 8.80 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/19/2014 00:00 | 0.6 | 13.9 | 1,234.8 | 0.5 | 2.50 | 1 | 1 | 0 |
| 02/19/2014 01:00 | 0.8 | 13.9 | 1,395.8 | 0.7 | 2.80 | 1 | 1 | 0 |
| 02/19/2014 02:00 | 4.9 | 15.0 | 750.2 | 4.9 | 2.43 | 1 | 0 | 0 |
| 02/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 12:00 | 34.3 | 17.5 | 505.2 | 59.5 | 69.68 | 1 | 0 | 0 |
| 02/19/2014 13:00 | 13.0 | 16.9 | 568.7 | 19.2 | 40.40 | 1 | 0 | 0 |
| 02/19/2014 14:00 | 16.2 | 15.3 | 895.0 | 17.1 | 56.40 | 1 | 0 | 0 |
| 02/19/2014 15:00 | 0.6 | 13.9 | 1,283.6 | 0.5 | 2.60 | 1 | 1 | 0 |
| 02/19/2014 16:00 | 0.9 | 13.9 | 1,587.8 | 0.8 | 4.80 | 1 | 1 | 0 |
| 02/19/2014 17:00 | 1.0 | 13.9 | 1,723.5 | 0.8 | 5.20 | 1 | 1 | 0 |
| 02/19/2014 18:00 | 0.9 | 13.8 | 1,596.0 | 0.7 | 4.80 | 1 | 1 | 1 |
| 02/19/2014 19:00 | 1.0 | 13.5 | 1,852.6 | 0.8 | 5.60 | 1 | 1 | 1 |
| 02/19/2014 20:00 | 1.5 | 12.0 | 2,171.3 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/19/2014 21:00 | 1.6 | 11.7 | 2,223.1 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/19/2014 22:00 | 1.5 | 12.2 | 2,127.3 | 1.0 | 8.50 | 1 | 1 | 1 |
| 02/19/2014 23:00 | 1.2 | 13.5 | 1,851.6 | 1.0 | 7.40 | 1 | 1 | 1 |
| **Average/Sum#:** | 5.3 | 14.1 | 1,451.1 | 7.3 | 230.71 # | 15 # | 11 # | 6 # |
| **Minimum:** | 0.6 | 11.7 | 505.2 | 0.5 | 2.43 | 0 | 0 | 0 |
| **Maximum:** | 34.3 | 17.5 | 2,223.1 | 59.5 | 69.68 | 1 | 1 | 1 |
| **%SI** | 37.5 | 37.5 | 37.5 | 37.5 | 37.50 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/20/2014 00:00 | 1.0 | 13.7 | 1,800.2 | 0.8 | 5.40 | 1 | 1 | 1 |
| 02/20/2014 01:00 | 0.7 | 13.9 | 1,263.1 | 0.6 | 2.50 | 1 | 1 | 0 |
| 02/20/2014 02:00 | 0.7 | 13.9 | 1,238.1 | 0.6 | 2.50 | 1 | 1 | 0 |
| 02/20/2014 03:00 | 0.7 | 13.9 | 1,237.4 | 0.6 | 2.50 | 1 | 1 | 0 |
| 02/20/2014 04:00 | 0.7 | 13.9 | 1,254.1 | 0.6 | 2.50 | 1 | 1 | 0 |
| 02/20/2014 05:00 | 0.7 | 13.9 | 1,306.0 | 0.6 | 2.60 | 1 | 1 | 0 |
| 02/20/2014 06:00 | 1.1 | 13.1 | 1,877.8 | 0.8 | 5.60 | 1 | 1 | 1 |
| 02/20/2014 07:00 | 1.3 | 12.8 | 2,045.9 | 0.9 | 6.10 | 1 | 1 | 1 |
| 02/20/2014 08:00 | 1.4 | 12.3 | 2,121.3 | 1.0 | 8.50 | 1 | 1 | 1 |
| 02/20/2014 09:00 | 1.1 | 13.2 | 1,853.7 | 0.8 | 5.60 | 1 | 1 | 1 |
| 02/20/2014 10:00 | 1.1 | 13.3 | 1,812.2 | 0.9 | 5.40 | 1 | 1 | 1 |
| 02/20/2014 11:00 | 1.1 | 13.3 | 1,816.3 | 0.9 | 5.40 | 1 | 1 | 1 |
| 02/20/2014 12:00 | 1.1 | 13.3 | 1,823.1 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/20/2014 13:00 | 1.3 | 13.0 | 1,958.1 | 1.0 | 7.80 | 1 | 1 | 1 |
| 02/20/2014 14:00 | 1.1 | 13.4 | 1,845.8 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/20/2014 15:00 | 1.3 | 13.0 | 1,943.7 | 1.0 | 7.80 | 1 | 1 | 1 |
| 02/20/2014 16:00 | 1.5 | 12.2 | 2,106.9 | 1.0 | 8.40 | 1 | 1 | 1 |
| 02/20/2014 17:00 | 1.6 | 11.5 | 2,238.4 | 1.0 | 9.00 | 1 | 1 | 1 |
| 02/20/2014 18:00 | 1.5 | 11.9 | 2,152.6 | 1.0 | 8.60 | 1 | 1 | 1 |
| 02/20/2014 19:00 | 1.6 | 11.5 | 2,242.7 | 1.0 | 9.00 | 1 | 1 | 1 |
| 02/20/2014 20:00 | 1.6 | 11.4 | 2,252.8 | 1.0 | 9.00 | 1 | 1 | 1 |
| 02/20/2014 21:00 | 1.6 | 11.5 | 2,229.4 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/20/2014 22:00 | 1.6 | 11.5 | 2,237.5 | 1.0 | 9.00 | 1 | 1 | 1 |
| 02/20/2014 23:00 | 1.6 | 11.8 | 2,171.4 | 1.0 | 8.70 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.2 | 12.8 | 1,867.9 | 0.9 | 151.80 # | 24 # | 24 # | 19 # |
| **Minimum:** | 0.7 | 11.4 | 1,237.4 | 0.6 | 2.50 | 1 | 1 | 0 |
| **Maximum:** | 1.6 | 13.9 | 2,252.8 | 1.0 | 9.00 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/21/2014 00:00 | 1.4 | 12.5 | 2,036.7 | 1.0 | 8.10 | 1 | 1 | 1 |
| 02/21/2014 01:00 | 1.1 | 13.5 | 1,844.1 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/21/2014 02:00 | 1.0 | 13.6 | 1,802.3 | 0.8 | 5.40 | 1 | 1 | 1 |
| 02/21/2014 03:00 | 1.0 | 13.6 | 1,802.6 | 0.8 | 5.40 | 1 | 1 | 1 |
| 02/21/2014 04:00 | 1.0 | 13.7 | 1,803.4 | 0.8 | 5.40 | 1 | 1 | 1 |
| 02/21/2014 05:00 | 1.1 | 13.7 | 1,804.4 | 0.9 | 5.40 | 1 | 1 | 1 |
| 02/21/2014 06:00 | 1.1 | 13.6 | 1,826.1 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/21/2014 07:00 | 1.4 | 12.7 | 1,984.8 | 1.0 | 7.90 | 1 | 1 | 1 |
| 02/21/2014 08:00 | 1.6 | 11.9 | 2,173.1 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/21/2014 09:00 | 1.2 | 13.1 | 1,918.9 | 0.9 | 5.80 | 1 | 1 | 1 |
| 02/21/2014 10:00 | 1.1 | 13.6 | 1,817.5 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/21/2014 11:00 | 1.1 | 13.5 | 1,839.8 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/21/2014 12:00 | 1.0 | 13.6 | 1,820.7 | 0.8 | 5.50 | 1 | 1 | 1 |
| 02/21/2014 13:00 | 1.1 | 13.5 | 1,824.2 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/21/2014 14:00 | 1.3 | 13.5 | 1,834.2 | 1.0 | 7.30 | 1 | 1 | 1 |
| 02/21/2014 15:00 | 1.4 | 13.5 | 1,831.3 | 1.1 | 7.30 | 1 | 1 | 1 |
| 02/21/2014 16:00 | 1.4 | 13.5 | 1,828.0 | 1.1 | 7.30 | 1 | 1 | 1 |
| 02/21/2014 17:00 | 1.4 | 13.4 | 1,840.3 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/21/2014 18:00 | 1.5 | 12.7 | 2,002.6 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/21/2014 19:00 | 1.5 | 12.1 | 2,110.8 | 1.0 | 8.40 | 1 | 1 | 1 |
| 02/21/2014 20:00 | 1.6 | 12.0 | 2,145.3 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/21/2014 21:00 | 1.6 | 11.7 | 2,211.3 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/21/2014 22:00 | 1.5 | 12.0 | 2,134.2 | 1.0 | 8.50 | 1 | 1 | 1 |
| 02/21/2014 23:00 | 1.5 | 12.4 | 2,067.1 | 1.0 | 8.30 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.3 | 13.0 | 1,929.3 | 1.0 | 165.00 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.0 | 11.7 | 1,802.3 | 0.8 | 5.40 | 1 | 1 | 1 |
| **Maximum:** | 1.6 | 13.7 | 2,211.3 | 1.1 | 8.80 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/22/2014 00:00 | 1.4 | 12.5 | 2,045.6 | 1.0 | 8.20 | 1 | 1 | 1 |
| 02/22/2014 01:00 | 1.3 | 12.8 | 1,995.4 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/22/2014 02:00 | 1.1 | 13.3 | 1,836.2 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/22/2014 03:00 | 1.2 | 12.9 | 1,962.7 | 0.9 | 5.90 | 1 | 1 | 1 |
| 02/22/2014 04:00 | 1.3 | 12.8 | 1,974.4 | 0.9 | 5.90 | 1 | 1 | 1 |
| 02/22/2014 05:00 | 1.1 | 13.2 | 1,897.0 | 0.8 | 5.70 | 1 | 1 | 1 |
| 02/22/2014 06:00 | 1.2 | 12.8 | 2,005.1 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/22/2014 07:00 | 1.2 | 12.8 | 2,007.0 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/22/2014 08:00 | 1.3 | 12.8 | 1,987.4 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/22/2014 09:00 | 1.1 | 13.3 | 1,855.1 | 0.9 | 5.60 | 1 | 1 | 1 |
| 02/22/2014 10:00 | 1.1 | 13.4 | 1,835.2 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/22/2014 11:00 | 1.1 | 13.4 | 1,842.8 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/22/2014 12:00 | 1.1 | 13.4 | 1,854.0 | 0.9 | 5.60 | 1 | 1 | 1 |
| 02/22/2014 13:00 | 1.0 | 13.4 | 1,839.5 | 0.8 | 5.50 | 1 | 1 | 1 |
| 02/22/2014 14:00 | 1.2 | 13.0 | 1,917.3 | 0.9 | 5.80 | 1 | 1 | 1 |
| 02/22/2014 15:00 | 1.5 | 12.7 | 1,975.3 | 1.1 | 7.90 | 1 | 1 | 1 |
| 02/22/2014 16:00 | 1.4 | 13.1 | 1,882.3 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/22/2014 17:00 | 1.1 | 13.3 | 1,839.8 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/22/2014 18:00 | 1.4 | 12.3 | 2,033.9 | 1.0 | 8.10 | 1 | 1 | 1 |
| 02/22/2014 19:00 | 1.5 | 12.2 | 2,058.2 | 1.0 | 8.20 | 1 | 1 | 1 |
| 02/22/2014 20:00 | 1.6 | 11.5 | 2,196.1 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/22/2014 21:00 | 1.6 | 11.4 | 2,217.3 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/22/2014 22:00 | 1.6 | 11.4 | 2,223.9 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/22/2014 23:00 | 1.6 | 11.4 | 2,230.6 | 1.0 | 8.90 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.3 | 12.7 | 1,979.7 | 0.9 | 161.40 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.0 | 11.4 | 1,835.2 | 0.8 | 5.50 | 1 | 1 | 1 |
| **Maximum:** | 1.6 | 13.4 | 2,230.6 | 1.1 | 8.90 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/23/2014 00:00 | 1.6 | 11.8 | 2,190.0 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/23/2014 01:00 | 1.5 | 12.1 | 2,121.4 | 1.0 | 8.50 | 1 | 1 | 1 |
| 02/23/2014 02:00 | 1.6 | 11.7 | 2,213.9 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/23/2014 03:00 | 1.6 | 11.6 | 2,224.5 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/23/2014 04:00 | 1.4 | 12.2 | 2,097.1 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/23/2014 05:00 | 1.2 | 12.8 | 1,995.7 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/23/2014 06:00 | 1.2 | 12.7 | 2,011.4 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/23/2014 07:00 | 1.1 | 13.0 | 1,974.8 | 0.8 | 5.90 | 1 | 1 | 1 |
| 02/23/2014 08:00 | 1.2 | 13.0 | 1,958.3 | 0.9 | 5.90 | 1 | 1 | 1 |
| 02/23/2014 09:00 | 1.2 | 13.0 | 1,942.2 | 0.9 | 5.80 | 1 | 1 | 1 |
| 02/23/2014 10:00 | 1.1 | 13.5 | 1,818.6 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/23/2014 11:00 | 1.2 | 13.3 | 1,865.1 | 0.9 | 5.60 | 1 | 1 | 1 |
| 02/23/2014 12:00 | 1.2 | 13.2 | 1,894.3 | 0.9 | 5.70 | 1 | 1 | 1 |
| 02/23/2014 13:00 | 1.1 | 13.5 | 1,826.0 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/23/2014 14:00 | 1.1 | 13.4 | 1,827.9 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/23/2014 15:00 | 1.1 | 13.4 | 1,828.5 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/23/2014 16:00 | 1.3 | 13.1 | 1,867.1 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/23/2014 17:00 | 1.2 | 13.0 | 1,902.4 | 0.9 | 5.70 | 1 | 1 | 1 |
| 02/23/2014 18:00 | 1.5 | 12.1 | 2,083.2 | 1.0 | 8.30 | 1 | 1 | 1 |
| 02/23/2014 19:00 | 1.6 | 11.6 | 2,184.0 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/23/2014 20:00 | 1.6 | 11.7 | 2,168.3 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/23/2014 21:00 | 1.6 | 11.7 | 2,169.5 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/23/2014 22:00 | 1.6 | 11.8 | 2,168.5 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/23/2014 23:00 | 1.6 | 11.9 | 2,147.4 | 1.0 | 8.60 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.4 | 12.5 | 2,020.0 | 0.9 | 169.20 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.1 | 11.6 | 1,818.6 | 0.8 | 5.50 | 1 | 1 | 1 |
| **Maximum:** | 1.6 | 13.5 | 2,224.5 | 1.0 | 8.90 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/24/2014 00:00 | 1.3 | 12.8 | 1,972.0 | 0.9 | 5.90 | 1 | 1 | 1 |
| 02/24/2014 01:00 | 1.1 | 13.5 | 1,809.7 | 0.9 | 5.40 | 1 | 1 | 1 |
| 02/24/2014 02:00 | 1.0 | 13.6 | 1,760.5 | 0.8 | 5.30 | 1 | 1 | 1 |
| 02/24/2014 03:00 | 0.7 | 13.9 | 1,246.8 | 0.6 | 2.50 | 1 | 1 | 0 |
| 02/24/2014 04:00 | 0.7 | 13.9 | 1,220.7 | 0.6 | 2.40 | 1 | 1 | 0 |
| 02/24/2014 05:00 | 0.9 | 13.7 | 1,507.4 | 0.7 | 4.50 | 1 | 1 | 1 |
| 02/24/2014 06:00 | 1.1 | 13.3 | 1,854.9 | 0.9 | 5.60 | 1 | 1 | 1 |
| 02/24/2014 07:00 | 1.3 | 13.1 | 1,920.1 | 1.0 | 7.70 | 1 | 1 | 1 |
| 02/24/2014 08:00 | 1.3 | 12.6 | 2,041.5 | 0.9 | 6.10 | 1 | 1 | 1 |
| 02/24/2014 09:00 | 1.2 | 13.2 | 1,907.6 | 0.9 | 5.70 | 1 | 1 | 1 |
| 02/24/2014 10:00 | 1.1 | 13.7 | 1,804.1 | 0.9 | 5.40 | 1 | 1 | 1 |
| 02/24/2014 11:00 | 1.2 | 13.5 | 1,835.6 | 1.0 | 7.30 | 1 | 1 | 1 |
| 02/24/2014 12:00 | 1.1 | 13.6 | 1,802.6 | 0.9 | 5.40 | 1 | 1 | 1 |
| 02/24/2014 13:00 | 0.9 | 13.6 | 1,798.9 | 0.7 | 5.40 | 1 | 1 | 1 |
| 02/24/2014 14:00 | 1.1 | 13.5 | 1,805.9 | 0.9 | 5.40 | 1 | 1 | 1 |
| 02/24/2014 15:00 | 1.4 | 12.7 | 1,945.5 | 1.0 | 7.80 | 1 | 1 | 1 |
| 02/24/2014 16:00 | 1.4 | 12.8 | 1,939.8 | 1.0 | 7.80 | 1 | 1 | 1 |
| 02/24/2014 17:00 | 1.5 | 12.4 | 2,016.4 | 1.0 | 8.10 | 1 | 1 | 1 |
| 02/24/2014 18:00 | 1.6 | 11.9 | 2,104.9 | 1.0 | 8.40 | 1 | 1 | 1 |
| 02/24/2014 19:00 | 1.6 | 11.5 | 2,185.6 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/24/2014 20:00 | 1.6 | 11.7 | 2,162.8 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/24/2014 21:00 | 1.6 | 11.8 | 2,141.3 | 1.0 | 8.60 | 1 | 1 | 1 |
| 02/24/2014 22:00 | 1.6 | 11.9 | 2,138.5 | 1.0 | 8.60 | 1 | 1 | 1 |
| 02/24/2014 23:00 | 1.6 | 11.9 | 2,144.3 | 1.0 | 8.60 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.2 | 12.9 | 1,877.8 | 0.9 | 155.30 # | 24 # | 24 # | 22 # |
| **Minimum:** | 0.7 | 11.5 | 1,220.7 | 0.6 | 2.40 | 1 | 1 | 0 |
| **Maximum:** | 1.6 | 13.9 | 2,185.6 | 1.0 | 8.70 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/25/2014 00:00 | 1.3 | 12.7 | 2,009.1 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/25/2014 01:00 | 1.2 | 13.0 | 1,938.7 | 0.9 | 5.80 | 1 | 1 | 1 |
| 02/25/2014 02:00 | 1.0 | 13.4 | 1,810.1 | 0.8 | 5.40 | 1 | 1 | 1 |
| 02/25/2014 03:00 | 1.0 | 13.4 | 1,803.8 | 0.8 | 5.40 | 1 | 1 | 1 |
| 02/25/2014 04:00 | 1.1 | 13.4 | 1,801.5 | 0.9 | 5.40 | 1 | 1 | 1 |
| 02/25/2014 05:00 | 1.3 | 12.8 | 1,966.9 | 0.9 | 5.90 | 1 | 1 | 1 |
| 02/25/2014 06:00 | 1.3 | 12.7 | 1,995.0 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/25/2014 07:00 | 2.3 | 13.1 | 1,919.2 | 1.7 | 11.50 | 1 | 1 | 1 |
| 02/25/2014 08:00 | 1.0 | 12.8 | 1,970.6 | 0.7 | 5.90 | 1 | 1 | 1 |
| 02/25/2014 09:00 | 1.0 | 13.4 | 1,805.0 | 0.8 | 5.40 | 1 | 1 | 1 |
| 02/25/2014 10:00 | 0.0 | 0.0 | 1,801.3 | 0.0 | 0.00 | 1 | 1 | 1 |
| 02/25/2014 11:00 | 0.0 | 0.0 | 1,798.5 | 0.0 | 0.00 | 1 | 1 | 1 |
| 02/25/2014 12:00 | 0.0 | 0.0 | 1,808.3 | 0.0 | 0.00 | 1 | 1 | 1 |
| 02/25/2014 13:00 | 0.0 | 0.0 | 1,823.5 | 0.0 | 0.00 | 1 | 1 | 1 |
| 02/25/2014 14:00 | 0.8 | 13.6 | 1,801.5 | 0.6 | 3.60 | 1 | 1 | 1 |
| 02/25/2014 15:00 | 0.8 | 13.6 | 1,801.3 | 0.6 | 3.60 | 1 | 1 | 1 |
| 02/25/2014 16:00 | 1.0 | 13.3 | 1,845.1 | 0.8 | 5.50 | 1 | 1 | 1 |
| 02/25/2014 17:00 | 1.0 | 13.4 | 1,819.2 | 0.8 | 5.50 | 1 | 1 | 1 |
| 02/25/2014 18:00 | 1.1 | 12.9 | 1,937.9 | 0.8 | 5.80 | 1 | 1 | 1 |
| 02/25/2014 19:00 | 1.5 | 12.1 | 2,091.8 | 1.0 | 8.40 | 1 | 1 | 1 |
| 02/25/2014 20:00 | 1.6 | 11.9 | 2,129.0 | 1.0 | 8.50 | 1 | 1 | 1 |
| 02/25/2014 21:00 | 1.3 | 12.4 | 2,040.1 | 0.9 | 6.10 | 1 | 1 | 1 |
| 02/25/2014 22:00 | 1.1 | 13.0 | 1,928.6 | 0.8 | 5.80 | 1 | 1 | 1 |
| 02/25/2014 23:00 | 1.5 | 12.1 | 2,113.8 | 1.0 | 8.50 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.2 | 13.0 | 1,906.7 | 0.9 | 124.00 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.8 | 11.9 | 1,798.5 | 0.6 | 3.60 | 1 | 1 | 1 |
| **Maximum:** | 2.3 | 13.6 | 2,129.0 | 1.7 | 11.50 | 1 | 1 | 1 |
| **%SI** | 16.7 | 16.7 | 0.0 | 16.7 | 16.67 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/26/2014 00:00 | 1.1 | 13.0 | 1,912.3 | 0.8 | 5.70 | 1 | 1 | 1 |
| 02/26/2014 01:00 | 1.1 | 13.3 | 1,851.2 | 0.9 | 5.60 | 1 | 1 | 1 |
| 02/26/2014 02:00 | 1.1 | 13.3 | 1,828.1 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/26/2014 03:00 | 1.1 | 13.3 | 1,823.3 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/26/2014 04:00 | 1.1 | 13.3 | 1,816.2 | 0.9 | 5.40 | 1 | 1 | 1 |
| 02/26/2014 05:00 | 1.1 | 13.2 | 1,854.6 | 0.8 | 5.60 | 1 | 1 | 1 |
| 02/26/2014 06:00 | 1.4 | 12.4 | 2,054.4 | 1.0 | 8.20 | 1 | 1 | 1 |
| 02/26/2014 07:00 | 1.5 | 12.0 | 2,147.2 | 1.0 | 8.60 | 1 | 1 | 1 |
| 02/26/2014 08:00 | 1.7 | 11.5 | 2,244.6 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/26/2014 09:00 | 1.7 | 11.5 | 2,246.6 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/26/2014 10:00 | 1.7 | 11.5 | 2,258.3 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/26/2014 11:00 | 1.6 | 11.5 | 2,235.5 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/26/2014 12:00 | 1.4 | 12.0 | 2,132.2 | 0.9 | 6.40 | 1 | 1 | 1 |
| 02/26/2014 13:00 | 1.5 | 11.9 | 2,149.5 | 1.0 | 8.60 | 1 | 1 | 1 |
| 02/26/2014 14:00 | 1.3 | 12.3 | 2,068.1 | 0.9 | 6.20 | 1 | 1 | 1 |
| 02/26/2014 15:00 | 1.3 | 12.4 | 2,046.8 | 0.9 | 6.10 | 1 | 1 | 1 |
| 02/26/2014 16:00 | 1.1 | 12.7 | 1,995.5 | 0.8 | 6.00 | 1 | 1 | 1 |
| 02/26/2014 17:00 | 1.4 | 12.1 | 2,112.9 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/26/2014 18:00 | 1.5 | 11.9 | 2,143.3 | 1.0 | 8.60 | 1 | 1 | 1 |
| 02/26/2014 19:00 | 1.7 | 11.4 | 2,244.0 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/26/2014 20:00 | 1.7 | 11.5 | 2,226.6 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/26/2014 21:00 | 1.6 | 11.6 | 2,195.3 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/26/2014 22:00 | 1.6 | 11.7 | 2,170.0 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/26/2014 23:00 | 1.4 | 12.0 | 2,121.9 | 0.9 | 6.40 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.4 | 12.2 | 2,078.3 | 1.0 | 176.00 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.1 | 11.4 | 1,816.2 | 0.8 | 5.40 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.3 | 2,258.3 | 1.1 | 9.00 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/27/2014 00:00 | 1.1 | 12.7 | 1,969.2 | 0.8 | 5.90 | 1 | 1 | 1 |
| 02/27/2014 01:00 | 0.9 | 13.3 | 1,834.0 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/27/2014 02:00 | 0.8 | 13.6 | 1,551.1 | 0.6 | 3.10 | 1 | 1 | 1 |
| 02/27/2014 03:00 | 0.6 | 13.9 | 1,277.2 | 0.5 | 2.60 | 1 | 1 | 0 |
| 02/27/2014 04:00 | 0.8 | 13.8 | 1,565.2 | 0.7 | 3.10 | 1 | 1 | 0 |
| 02/27/2014 05:00 | 0.9 | 13.4 | 1,717.2 | 0.7 | 5.20 | 1 | 1 | 1 |
| 02/27/2014 06:00 | 1.0 | 13.3 | 1,868.9 | 0.8 | 5.60 | 1 | 1 | 1 |
| 02/27/2014 07:00 | 1.1 | 13.3 | 1,851.2 | 0.9 | 5.60 | 1 | 1 | 1 |
| 02/27/2014 08:00 | 1.2 | 12.7 | 2,002.5 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/27/2014 09:00 | 1.0 | 13.5 | 1,832.7 | 0.8 | 5.50 | 1 | 1 | 1 |
| 02/27/2014 10:00 | 0.9 | 13.6 | 1,807.6 | 0.7 | 5.40 | 1 | 1 | 1 |
| 02/27/2014 11:00 | 0.9 | 13.6 | 1,804.1 | 0.7 | 5.40 | 1 | 1 | 1 |
| 02/27/2014 12:00 | 0.9 | 13.6 | 1,807.5 | 0.7 | 5.40 | 1 | 1 | 1 |
| 02/27/2014 13:00 | 0.9 | 13.5 | 1,816.8 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/27/2014 14:00 | 0.9 | 13.5 | 1,815.3 | 0.7 | 5.40 | 1 | 1 | 1 |
| 02/27/2014 15:00 | 0.9 | 13.5 | 1,818.0 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/27/2014 16:00 | 1.0 | 13.5 | 1,824.7 | 0.8 | 5.50 | 1 | 1 | 1 |
| 02/27/2014 17:00 | 1.0 | 13.3 | 1,880.6 | 0.8 | 5.60 | 1 | 1 | 1 |
| 02/27/2014 18:00 | 0.9 | 13.3 | 1,868.0 | 0.7 | 5.60 | 1 | 1 | 1 |
| 02/27/2014 19:00 | 1.2 | 12.5 | 2,034.9 | 0.8 | 6.10 | 1 | 1 | 1 |
| 02/27/2014 20:00 | 1.2 | 12.6 | 2,021.7 | 0.9 | 6.10 | 1 | 1 | 1 |
| 02/27/2014 21:00 | 1.2 | 12.6 | 2,032.4 | 0.9 | 6.10 | 1 | 1 | 1 |
| 02/27/2014 22:00 | 1.2 | 12.6 | 2,008.7 | 0.9 | 6.00 | 1 | 1 | 1 |
| 02/27/2014 23:00 | 1.2 | 12.5 | 2,028.5 | 0.8 | 6.10 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.0 | 13.2 | 1,834.9 | 0.8 | 127.80 # | 24 # | 24 # | 22 # |
| **Minimum:** | 0.6 | 12.5 | 1,277.2 | 0.5 | 2.60 | 1 | 1 | 0 |
| **Maximum:** | 1.2 | 13.9 | 2,034.9 | 0.9 | 6.10 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 02/28/2014 00:00 | 1.0 | 13.1 | 1,881.9 | 0.8 | 5.60 | 1 | 1 | 1 |
| 02/28/2014 01:00 | 0.9 | 13.4 | 1,827.7 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/28/2014 02:00 | 1.0 | 13.1 | 1,900.2 | 0.8 | 5.70 | 1 | 1 | 1 |
| 02/28/2014 03:00 | 0.9 | 13.4 | 1,829.8 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/28/2014 04:00 | 0.9 | 13.4 | 1,830.2 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/28/2014 05:00 | 0.9 | 13.4 | 1,844.3 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/28/2014 06:00 | 0.9 | 13.4 | 1,846.1 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/28/2014 07:00 | 1.0 | 13.2 | 1,859.8 | 0.8 | 5.60 | 1 | 1 | 1 |
| 02/28/2014 08:00 | 1.1 | 12.7 | 2,006.3 | 0.8 | 6.00 | 1 | 1 | 1 |
| 02/28/2014 09:00 | 1.3 | 12.1 | 2,126.5 | 0.9 | 6.40 | 1 | 1 | 1 |
| 02/28/2014 10:00 | 1.5 | 11.9 | 2,169.0 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/28/2014 11:00 | 1.4 | 11.9 | 2,151.2 | 0.9 | 6.50 | 1 | 1 | 1 |
| 02/28/2014 12:00 | 1.3 | 12.1 | 2,112.9 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/28/2014 13:00 | 1.1 | 12.6 | 2,005.4 | 0.8 | 6.00 | 1 | 1 | 1 |
| 02/28/2014 14:00 | 0.9 | 13.3 | 1,857.0 | 0.7 | 5.60 | 1 | 1 | 1 |
| 02/28/2014 15:00 | 1.0 | 13.0 | 1,925.4 | 0.7 | 5.80 | 1 | 1 | 1 |
| 02/28/2014 16:00 | 1.2 | 12.2 | 2,099.2 | 0.8 | 6.30 | 1 | 1 | 1 |
| 02/28/2014 17:00 | 1.2 | 12.4 | 2,056.9 | 0.8 | 6.20 | 1 | 1 | 1 |
| 02/28/2014 18:00 | 1.0 | 13.1 | 1,928.2 | 0.8 | 5.80 | 1 | 1 | 1 |
| 02/28/2014 19:00 | 1.1 | 12.7 | 1,995.6 | 0.8 | 6.00 | 1 | 1 | 1 |
| 02/28/2014 20:00 | 0.9 | 13.3 | 1,835.5 | 0.7 | 5.50 | 1 | 1 | 1 |
| 02/28/2014 21:00 | 1.1 | 13.0 | 1,951.1 | 0.8 | 5.90 | 1 | 1 | 1 |
| 02/28/2014 22:00 | 1.0 | 12.8 | 1,986.0 | 0.7 | 6.00 | 1 | 1 | 1 |
| 02/28/2014 23:00 | 1.1 | 12.6 | 2,025.8 | 0.8 | 6.10 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.1 | 12.8 | 1,960.5 | 0.8 | 143.50 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.9 | 11.9 | 1,827.7 | 0.7 | 5.50 | 1 | 1 | 1 |
| **Maximum:** | 1.5 | 13.4 | 2,169.0 | 1.0 | 8.70 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/01/2014 00:00 | 1.0 | 13.0 | 1,930.3 | 0.7 | 5.80 | 1 | 1 | 1 |
| 03/01/2014 01:00 | 0.9 | 13.3 | 1,848.8 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/01/2014 02:00 | 0.9 | 13.3 | 1,819.1 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/01/2014 03:00 | 0.9 | 13.3 | 1,819.8 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/01/2014 04:00 | 0.9 | 13.3 | 1,818.7 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/01/2014 05:00 | 0.9 | 13.3 | 1,834.2 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/01/2014 06:00 | 0.9 | 13.3 | 1,821.4 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/01/2014 07:00 | 1.0 | 13.3 | 1,820.6 | 0.8 | 5.50 | 1 | 1 | 1 |
| 03/01/2014 08:00 | 0.9 | 13.3 | 1,833.4 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/01/2014 09:00 | 0.9 | 13.3 | 1,820.8 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/01/2014 10:00 | 0.9 | 13.3 | 1,826.2 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/01/2014 11:00 | 0.9 | 13.3 | 1,828.4 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/01/2014 12:00 | 1.0 | 13.3 | 1,832.0 | 0.8 | 5.50 | 1 | 1 | 1 |
| 03/01/2014 13:00 | 1.0 | 13.3 | 1,858.2 | 0.8 | 5.60 | 1 | 1 | 1 |
| 03/01/2014 14:00 | 1.1 | 12.8 | 1,993.1 | 0.8 | 6.00 | 1 | 1 | 1 |
| 03/01/2014 15:00 | 1.1 | 12.8 | 1,997.0 | 0.8 | 6.00 | 1 | 1 | 1 |
| 03/01/2014 16:00 | 0.9 | 13.4 | 1,862.5 | 0.7 | 5.60 | 1 | 1 | 1 |
| 03/01/2014 17:00 | 0.9 | 13.4 | 1,831.7 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/01/2014 18:00 | 0.9 | 13.3 | 1,830.7 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/01/2014 19:00 | 1.0 | 13.0 | 1,937.8 | 0.7 | 5.80 | 1 | 1 | 1 |
| 03/01/2014 20:00 | 1.1 | 13.1 | 1,921.6 | 0.8 | 5.80 | 1 | 1 | 1 |
| 03/01/2014 21:00 | 1.2 | 12.8 | 1,981.9 | 0.9 | 5.90 | 1 | 1 | 1 |
| 03/01/2014 22:00 | 1.1 | 12.9 | 1,977.7 | 0.8 | 5.90 | 1 | 1 | 1 |
| 03/01/2014 23:00 | 1.2 | 12.6 | 2,014.1 | 0.9 | 6.00 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.0 | 13.2 | 1,877.5 | 0.7 | 135.40 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.9 | 12.6 | 1,818.7 | 0.7 | 5.50 | 1 | 1 | 1 |
| **Maximum:** | 1.2 | 13.4 | 2,014.1 | 0.9 | 6.00 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/02/2014 00:00 | 1.0 | 13.2 | 1,906.6 | 0.8 | 5.70 | 1 | 1 | 1 |
| 03/02/2014 01:00 | 1.1 | 12.8 | 2,006.7 | 0.8 | 6.00 | 1 | 1 | 1 |
| 03/02/2014 02:00 | 1.0 | 13.0 | 1,986.0 | 0.7 | 6.00 | 1 | 1 | 1 |
| 03/02/2014 03:00 | 0.9 | 13.3 | 1,849.9 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/02/2014 04:00 | 0.9 | 13.3 | 1,828.7 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/02/2014 05:00 | 0.9 | 13.3 | 1,870.8 | 0.7 | 5.60 | 1 | 1 | 1 |
| 03/02/2014 06:00 | 1.0 | 13.0 | 1,971.6 | 0.7 | 5.90 | 1 | 1 | 1 |
| 03/02/2014 07:00 | 1.2 | 12.7 | 2,042.2 | 0.9 | 6.10 | 1 | 1 | 1 |
| 03/02/2014 08:00 | 1.1 | 12.7 | 2,035.2 | 0.8 | 6.10 | 1 | 1 | 1 |
| 03/02/2014 09:00 | 1.0 | 13.2 | 1,929.4 | 0.8 | 5.80 | 1 | 1 | 1 |
| 03/02/2014 10:00 | 1.0 | 12.8 | 2,018.5 | 0.7 | 6.10 | 1 | 1 | 1 |
| 03/02/2014 11:00 | 1.5 | 11.9 | 2,186.1 | 1.0 | 8.70 | 1 | 1 | 1 |
| 03/02/2014 12:00 | 1.4 | 12.0 | 2,157.9 | 0.9 | 6.50 | 1 | 1 | 1 |
| 03/02/2014 13:00 | 1.6 | 11.7 | 2,207.8 | 1.0 | 8.80 | 1 | 1 | 1 |
| 03/02/2014 14:00 | 1.6 | 11.7 | 2,196.4 | 1.0 | 8.80 | 1 | 1 | 1 |
| 03/02/2014 15:00 | 1.6 | 11.7 | 2,191.4 | 1.0 | 8.80 | 1 | 1 | 1 |
| 03/02/2014 16:00 | 1.6 | 11.7 | 2,186.7 | 1.0 | 8.70 | 1 | 1 | 1 |
| 03/02/2014 17:00 | 1.5 | 11.9 | 2,150.0 | 1.0 | 8.60 | 1 | 1 | 1 |
| 03/02/2014 18:00 | 1.3 | 12.2 | 2,075.0 | 0.9 | 6.20 | 1 | 1 | 1 |
| 03/02/2014 19:00 | 1.3 | 12.3 | 2,087.9 | 0.9 | 6.30 | 1 | 1 | 1 |
| 03/02/2014 20:00 | 1.2 | 12.6 | 2,023.0 | 0.9 | 6.10 | 1 | 1 | 1 |
| 03/02/2014 21:00 | 1.4 | 12.2 | 2,115.3 | 0.9 | 6.30 | 1 | 1 | 1 |
| 03/02/2014 22:00 | 1.1 | 12.7 | 2,030.2 | 0.8 | 6.10 | 1 | 1 | 1 |
| 03/02/2014 23:00 | 1.0 | 12.9 | 1,968.4 | 0.7 | 5.90 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.2 | 12.5 | 2,042.6 | 0.8 | 160.10 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.9 | 11.7 | 1,828.7 | 0.7 | 5.50 | 1 | 1 | 1 |
| **Maximum:** | 1.6 | 13.3 | 2,207.8 | 1.0 | 8.80 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/03/2014 00:00 | 0.8 | 13.5 | 1,591.3 | 0.6 | 3.20 | 1 | 1 | 1 |
| 03/03/2014 01:00 | 0.7 | 13.8 | 1,430.6 | 0.6 | 2.90 | 1 | 1 | 0 |
| 03/03/2014 02:00 | 0.6 | 13.8 | 1,287.8 | 0.5 | 2.60 | 1 | 1 | 0 |
| 03/03/2014 03:00 | 0.6 | 13.8 | 1,285.3 | 0.5 | 2.60 | 1 | 1 | 0 |
| 03/03/2014 04:00 | 0.6 | 13.8 | 1,290.9 | 0.5 | 2.60 | 1 | 1 | 0 |
| 03/03/2014 05:00 | 0.8 | 13.5 | 1,581.8 | 0.6 | 3.20 | 1 | 1 | 1 |
| 03/03/2014 06:00 | 0.9 | 13.2 | 1,862.6 | 0.7 | 5.60 | 1 | 1 | 1 |
| 03/03/2014 07:00 | 1.1 | 12.8 | 1,982.3 | 0.8 | 5.90 | 1 | 1 | 1 |
| 03/03/2014 08:00 | 1.6 | 11.8 | 2,207.6 | 1.0 | 8.80 | 1 | 1 | 1 |
| 03/03/2014 09:00 | 1.5 | 12.1 | 2,138.0 | 1.0 | 8.60 | 1 | 1 | 1 |
| 03/03/2014 10:00 | 1.2 | 12.9 | 1,977.9 | 0.9 | 5.90 | 1 | 1 | 1 |
| 03/03/2014 11:00 | 1.1 | 13.1 | 1,905.2 | 0.8 | 5.70 | 1 | 1 | 1 |
| 03/03/2014 12:00 | 1.1 | 13.2 | 1,860.5 | 0.8 | 5.60 | 1 | 1 | 1 |
| 03/03/2014 13:00 | 0.9 | 13.3 | 1,840.4 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/03/2014 14:00 | 0.9 | 13.3 | 1,859.5 | 0.7 | 5.60 | 1 | 1 | 1 |
| 03/03/2014 15:00 | 0.9 | 13.2 | 1,900.0 | 0.7 | 5.70 | 1 | 1 | 1 |
| 03/03/2014 16:00 | 1.0 | 12.9 | 1,991.4 | 0.7 | 6.00 | 1 | 1 | 1 |
| 03/03/2014 17:00 | 1.4 | 11.9 | 2,202.4 | 0.9 | 6.60 | 1 | 1 | 1 |
| 03/03/2014 18:00 | 1.3 | 12.4 | 2,057.6 | 0.9 | 6.20 | 1 | 1 | 1 |
| 03/03/2014 19:00 | 1.5 | 11.8 | 2,193.6 | 1.0 | 8.80 | 1 | 1 | 1 |
| 03/03/2014 20:00 | 1.7 | 11.6 | 2,233.5 | 1.1 | 8.90 | 1 | 1 | 1 |
| 03/03/2014 21:00 | 1.6 | 11.8 | 2,196.1 | 1.0 | 8.80 | 1 | 1 | 1 |
| 03/03/2014 22:00 | 1.1 | 12.9 | 1,941.6 | 0.8 | 5.80 | 1 | 1 | 1 |
| 03/03/2014 23:00 | 0.9 | 13.2 | 1,817.3 | 0.7 | 5.50 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.1 | 12.9 | 1,859.8 | 0.8 | 136.60 # | 24 # | 24 # | 20 # |
| **Minimum:** | 0.6 | 11.6 | 1,285.3 | 0.5 | 2.60 | 1 | 1 | 0 |
| **Maximum:** | 1.7 | 13.8 | 2,233.5 | 1.1 | 8.90 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/04/2014 00:00 | 0.8 | 13.5 | 1,560.1 | 0.6 | 3.10 | 1 | 1 | 1 |
| 03/04/2014 01:00 | 0.6 | 13.8 | 1,255.3 | 0.5 | 2.50 | 1 | 1 | 0 |
| 03/04/2014 02:00 | 0.6 | 13.8 | 1,265.9 | 0.5 | 2.50 | 1 | 1 | 0 |
| 03/04/2014 03:00 | 0.6 | 13.8 | 1,329.7 | 0.5 | 2.70 | 1 | 1 | 0 |
| 03/04/2014 04:00 | 0.6 | 13.8 | 1,276.0 | 0.5 | 2.60 | 1 | 1 | 0 |
| 03/04/2014 05:00 | 0.6 | 13.8 | 1,292.1 | 0.5 | 2.60 | 1 | 1 | 0 |
| 03/04/2014 06:00 | 0.8 | 13.6 | 1,583.5 | 0.6 | 3.20 | 1 | 1 | 1 |
| 03/04/2014 07:00 | 1.0 | 13.4 | 1,838.3 | 0.8 | 5.50 | 1 | 1 | 1 |
| 03/04/2014 08:00 | 1.0 | 13.4 | 1,829.2 | 0.8 | 5.50 | 1 | 1 | 1 |
| 03/04/2014 09:00 | 0.7 | 13.8 | 1,430.3 | 0.6 | 2.90 | 1 | 1 | 1 |
| 03/04/2014 10:00 | 0.6 | 13.9 | 1,230.0 | 0.5 | 2.50 | 1 | 1 | 0 |
| 03/04/2014 11:00 | 0.6 | 13.9 | 1,230.7 | 0.5 | 2.50 | 1 | 1 | 0 |
| 03/04/2014 12:00 | 0.7 | 13.8 | 1,263.7 | 0.6 | 2.50 | 1 | 1 | 0 |
| 03/04/2014 13:00 | 0.8 | 13.8 | 1,419.1 | 0.7 | 2.80 | 1 | 1 | 0 |
| 03/04/2014 14:00 | 1.0 | 13.4 | 1,841.4 | 0.8 | 5.50 | 1 | 1 | 1 |
| 03/04/2014 15:00 | 1.0 | 13.4 | 1,844.0 | 0.8 | 5.50 | 1 | 1 | 1 |
| 03/04/2014 16:00 | 1.0 | 13.4 | 1,844.3 | 0.8 | 5.50 | 1 | 1 | 1 |
| 03/04/2014 17:00 | 1.0 | 13.4 | 1,845.5 | 0.8 | 5.50 | 1 | 1 | 1 |
| 03/04/2014 18:00 | 1.0 | 13.3 | 1,882.1 | 0.8 | 5.60 | 1 | 1 | 1 |
| 03/04/2014 19:00 | 1.3 | 12.2 | 2,130.6 | 0.9 | 6.40 | 1 | 1 | 1 |
| 03/04/2014 20:00 | 1.4 | 12.3 | 2,088.4 | 1.0 | 8.40 | 1 | 1 | 1 |
| 03/04/2014 21:00 | 1.2 | 12.8 | 1,996.8 | 0.9 | 6.00 | 1 | 1 | 1 |
| 03/04/2014 22:00 | 1.1 | 13.0 | 1,929.5 | 0.8 | 5.80 | 1 | 1 | 1 |
| 03/04/2014 23:00 | 0.9 | 13.4 | 1,836.0 | 0.7 | 5.50 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.9 | 13.4 | 1,626.8 | 0.7 | 103.10 # | 24 # | 24 # | 15 # |
| **Minimum:** | 0.6 | 12.2 | 1,230.0 | 0.5 | 2.50 | 1 | 1 | 0 |
| **Maximum:** | 1.4 | 13.9 | 2,130.6 | 1.0 | 8.40 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/05/2014 00:00 | 0.9 | 13.4 | 1,857.5 | 0.7 | 5.60 | 1 | 1 | 1 |
| 03/05/2014 01:00 | 1.1 | 12.9 | 1,980.0 | 0.8 | 5.90 | 1 | 1 | 1 |
| 03/05/2014 02:00 | 1.1 | 12.8 | 1,988.8 | 0.8 | 6.00 | 1 | 1 | 1 |
| 03/05/2014 03:00 | 1.0 | 13.2 | 1,866.8 | 0.8 | 5.60 | 1 | 1 | 1 |
| 03/05/2014 04:00 | 0.9 | 13.3 | 1,825.9 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/05/2014 05:00 | 1.0 | 13.0 | 1,943.0 | 0.7 | 5.80 | 1 | 1 | 1 |
| 03/05/2014 06:00 | 1.0 | 13.1 | 1,913.1 | 0.8 | 5.70 | 1 | 1 | 1 |
| 03/05/2014 07:00 | 1.0 | 13.1 | 1,932.2 | 0.8 | 5.80 | 1 | 1 | 1 |
| 03/05/2014 08:00 | 1.0 | 13.0 | 1,940.2 | 0.7 | 5.80 | 1 | 1 | 1 |
| 03/05/2014 09:00 | 0.9 | 13.3 | 1,847.5 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/05/2014 10:00 | 0.9 | 13.3 | 1,849.1 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/05/2014 11:00 | 0.9 | 13.3 | 1,852.1 | 0.7 | 5.60 | 1 | 1 | 1 |
| 03/05/2014 12:00 | 0.9 | 13.3 | 1,852.4 | 0.7 | 5.60 | 1 | 1 | 1 |
| 03/05/2014 13:00 | 0.9 | 13.3 | 1,852.3 | 0.7 | 5.60 | 1 | 1 | 1 |
| 03/05/2014 14:00 | 0.9 | 13.3 | 1,852.8 | 0.7 | 5.60 | 1 | 1 | 1 |
| 03/05/2014 15:00 | 0.9 | 13.3 | 1,857.7 | 0.7 | 5.60 | 1 | 1 | 1 |
| 03/05/2014 16:00 | 0.9 | 13.1 | 1,896.2 | 0.7 | 5.70 | 1 | 1 | 1 |
| 03/05/2014 17:00 | 1.0 | 12.9 | 1,939.9 | 0.7 | 5.80 | 1 | 1 | 1 |
| 03/05/2014 18:00 | 1.1 | 12.9 | 1,945.0 | 0.8 | 5.80 | 1 | 1 | 1 |
| 03/05/2014 19:00 | 1.2 | 12.5 | 2,038.9 | 0.8 | 6.10 | 1 | 1 | 1 |
| 03/05/2014 20:00 | 1.1 | 12.7 | 1,989.2 | 0.8 | 6.00 | 1 | 1 | 1 |
| 03/05/2014 21:00 | 1.0 | 12.9 | 1,963.1 | 0.7 | 5.90 | 1 | 1 | 1 |
| 03/05/2014 22:00 | 1.0 | 12.9 | 1,953.3 | 0.7 | 5.90 | 1 | 1 | 1 |
| 03/05/2014 23:00 | 0.8 | 13.3 | 1,828.5 | 0.6 | 3.70 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.0 | 13.1 | 1,906.9 | 0.7 | 135.60 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.8 | 12.5 | 1,825.9 | 0.6 | 3.70 | 1 | 1 | 1 |
| **Maximum:** | 1.2 | 13.4 | 2,038.9 | 0.8 | 6.10 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/06/2014 00:00 | 0.8 | 13.3 | 1,826.7 | 0.6 | 3.70 | 1 | 1 | 1 |
| 03/06/2014 01:00 | 0.9 | 13.3 | 1,783.2 | 0.7 | 5.30 | 1 | 1 | 1 |
| 03/06/2014 02:00 | 0.6 | 13.9 | 1,271.4 | 0.5 | 2.50 | 1 | 1 | 0 |
| 03/06/2014 03:00 | 3.2 | 15.8 | 583.3 | 3.7 | 1.89 | 1 | 0 | 0 |
| 03/06/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 1.4 | 14.1 | 1,366.2 | 1.4 | 13.39 # | 4 # | 3 # | 2 # |
| **Minimum:** | 0.6 | 13.3 | 583.3 | 0.5 | 1.89 | 0 | 0 | 0 |
| **Maximum:** | 3.2 | 15.8 | 1,826.7 | 3.7 | 5.30 | 1 | 1 | 1 |
| **%SI** | 83.3 | 83.3 | 83.3 | 83.3 | 83.33 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/07/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/07/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/07/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/07/2014 03:00 | 31.7 | 17.5 | 500.2 | 55.0 | 62.93 | 1 | 0 | 0 |
| 03/07/2014 04:00 | 18.3 | 16.6 | 621.9 | 25.1 | 57.80 | 1 | 0 | 0 |
| 03/07/2014 05:00 | 14.7 | 14.9 | 964.7 | 14.5 | 51.10 | 1 | 0 | 0 |
| 03/07/2014 06:00 | 0.6 | 13.9 | 1,449.7 | 0.5 | 2.90 | 1 | 1 | 0 |
| 03/07/2014 07:00 | 0.9 | 13.8 | 1,799.4 | 0.7 | 5.40 | 1 | 1 | 0 |
| 03/07/2014 08:00 | 0.6 | 13.9 | 1,542.5 | 0.5 | 3.10 | 1 | 1 | 0 |
| 03/07/2014 09:00 | 0.7 | 13.9 | 1,332.7 | 0.6 | 2.70 | 1 | 1 | 0 |
| 03/07/2014 10:00 | 0.9 | 13.4 | 1,794.3 | 0.7 | 5.40 | 1 | 1 | 1 |
| 03/07/2014 11:00 | 0.9 | 13.3 | 1,829.0 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/07/2014 12:00 | 0.9 | 13.3 | 1,837.2 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/07/2014 13:00 | 0.9 | 13.4 | 1,836.8 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/07/2014 14:00 | 0.9 | 13.4 | 1,833.6 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/07/2014 15:00 | 0.9 | 13.4 | 1,833.2 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/07/2014 16:00 | 1.0 | 13.3 | 1,857.8 | 0.8 | 5.60 | 1 | 1 | 1 |
| 03/07/2014 17:00 | 1.1 | 12.8 | 2,010.7 | 0.8 | 6.00 | 1 | 1 | 1 |
| 03/07/2014 18:00 | 1.1 | 12.8 | 2,013.9 | 0.8 | 6.00 | 1 | 1 | 1 |
| 03/07/2014 19:00 | 1.3 | 12.1 | 2,164.4 | 0.9 | 6.50 | 1 | 1 | 1 |
| 03/07/2014 20:00 | 1.6 | 11.6 | 2,240.9 | 1.0 | 9.00 | 1 | 1 | 1 |
| 03/07/2014 21:00 | 1.6 | 11.8 | 2,220.3 | 1.0 | 8.90 | 1 | 1 | 1 |
| 03/07/2014 22:00 | 1.5 | 11.8 | 2,219.4 | 1.0 | 8.90 | 1 | 1 | 1 |
| 03/07/2014 23:00 | 1.4 | 12.1 | 2,141.1 | 0.9 | 6.40 | 1 | 1 | 1 |
| **Average/Sum#:** | 4.0 | 13.5 | 1,716.4 | 5.2 | 276.13 # | 21 # | 18 # | 14 # |
| **Minimum:** | 0.6 | 11.6 | 500.2 | 0.5 | 2.70 | 0 | 0 | 0 |
| **Maximum:** | 31.7 | 17.5 | 2,240.9 | 55.0 | 62.93 | 1 | 1 | 1 |
| **%SI** | 12.5 | 12.5 | 12.5 | 12.5 | 12.50 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/08/2014 00:00 | 0.9 | 13.2 | 1,925.7 | 0.7 | 5.80 | 1 | 1 | 1 |
| 03/08/2014 01:00 | 1.0 | 13.1 | 1,946.3 | 0.8 | 5.80 | 1 | 1 | 1 |
| 03/08/2014 02:00 | 1.0 | 13.2 | 1,905.0 | 0.8 | 5.70 | 1 | 1 | 1 |
| 03/08/2014 03:00 | 1.0 | 13.2 | 1,886.9 | 0.8 | 5.70 | 1 | 1 | 1 |
| 03/08/2014 04:00 | 1.1 | 13.1 | 1,949.1 | 0.8 | 5.80 | 1 | 1 | 1 |
| 03/08/2014 05:00 | 1.1 | 12.9 | 1,993.0 | 0.8 | 6.00 | 1 | 1 | 1 |
| 03/08/2014 06:00 | 1.1 | 12.7 | 2,026.4 | 0.8 | 6.10 | 1 | 1 | 1 |
| 03/08/2014 07:00 | 1.1 | 13.0 | 2,003.9 | 0.8 | 6.00 | 1 | 1 | 1 |
| 03/08/2014 08:00 | 0.9 | 13.3 | 1,859.3 | 0.7 | 5.60 | 1 | 1 | 1 |
| 03/08/2014 09:00 | 0.9 | 13.3 | 1,810.5 | 0.7 | 5.40 | 1 | 1 | 1 |
| 03/08/2014 10:00 | 0.9 | 13.3 | 1,811.0 | 0.7 | 5.40 | 1 | 1 | 1 |
| 03/08/2014 11:00 | 0.9 | 13.3 | 1,814.6 | 0.7 | 5.40 | 1 | 1 | 1 |
| 03/08/2014 12:00 | 0.9 | 13.3 | 1,816.4 | 0.7 | 5.40 | 1 | 1 | 1 |
| 03/08/2014 13:00 | 0.9 | 13.4 | 1,815.8 | 0.7 | 5.40 | 1 | 1 | 1 |
| 03/08/2014 14:00 | 0.9 | 13.4 | 1,814.2 | 0.7 | 5.40 | 1 | 1 | 1 |
| 03/08/2014 15:00 | 0.9 | 13.4 | 1,811.8 | 0.7 | 5.40 | 1 | 1 | 1 |
| 03/08/2014 16:00 | 0.9 | 13.4 | 1,823.0 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/08/2014 17:00 | 1.0 | 13.3 | 1,851.6 | 0.8 | 5.60 | 1 | 1 | 1 |
| 03/08/2014 18:00 | 1.3 | 12.3 | 2,093.9 | 0.9 | 6.30 | 1 | 1 | 1 |
| 03/08/2014 19:00 | 1.4 | 11.9 | 2,180.2 | 0.9 | 6.50 | 1 | 1 | 1 |
| 03/08/2014 20:00 | 1.6 | 11.6 | 2,216.1 | 1.0 | 8.90 | 1 | 1 | 1 |
| 03/08/2014 21:00 | 1.6 | 11.6 | 2,211.5 | 1.0 | 8.80 | 1 | 1 | 1 |
| 03/08/2014 22:00 | 1.6 | 11.6 | 2,215.1 | 1.0 | 8.90 | 1 | 1 | 1 |
| 03/08/2014 23:00 | 1.4 | 11.9 | 2,169.4 | 0.9 | 6.50 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.1 | 12.9 | 1,956.3 | 0.8 | 147.30 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.9 | 11.6 | 1,810.5 | 0.7 | 5.40 | 1 | 1 | 1 |
| **Maximum:** | 1.6 | 13.4 | 2,216.1 | 1.0 | 8.90 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/09/2014 00:00 | 0.9 | 13.1 | 1,802.8 | 0.7 | 5.40 | 1 | 1 | 1 |
| 03/09/2014 01:00 | 0.6 | 13.8 | 1,375.4 | 0.5 | 2.80 | 1 | 1 | 0 |
| 03/09/2014 02:00 | 3.2 | 15.7 | 616.2 | 3.6 | 1.84 | 1 | 0 | 0 |
| 03/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 11:00 | 19.5 | 16.9 | 577.4 | 28.8 | 48.96 | 1 | 0 | 0 |
| 03/09/2014 12:00 | 11.7 | 15.1 | 890.5 | 11.9 | 39.20 | 1 | 0 | 0 |
| 03/09/2014 13:00 | 0.4 | 13.9 | 1,349.7 | 0.3 | 1.30 | 1 | 1 | 0 |
| 03/09/2014 14:00 | 0.9 | 13.7 | 1,765.6 | 0.7 | 5.30 | 1 | 1 | 0 |
| 03/09/2014 15:00 | 1.0 | 13.7 | 1,758.7 | 0.8 | 5.30 | 1 | 1 | 0 |
| 03/09/2014 16:00 | 0.6 | 13.8 | 1,512.7 | 0.5 | 3.00 | 1 | 1 | 1 |
| 03/09/2014 17:00 | 1.0 | 12.6 | 2,056.3 | 0.7 | 6.20 | 1 | 1 | 1 |
| 03/09/2014 18:00 | 1.4 | 11.8 | 2,200.0 | 0.9 | 6.60 | 1 | 1 | 1 |
| 03/09/2014 19:00 | 1.6 | 11.6 | 2,229.7 | 1.0 | 8.90 | 1 | 1 | 1 |
| 03/09/2014 20:00 | 1.6 | 11.6 | 2,220.8 | 1.0 | 8.90 | 1 | 1 | 1 |
| 03/09/2014 21:00 | 1.6 | 11.6 | 2,221.7 | 1.0 | 8.90 | 1 | 1 | 1 |
| 03/09/2014 22:00 | 1.2 | 12.4 | 2,069.1 | 0.8 | 6.20 | 1 | 1 | 1 |
| 03/09/2014 23:00 | 1.6 | 11.7 | 2,197.3 | 1.0 | 8.80 | 1 | 1 | 1 |
| **Average/Sum#:** | 3.1 | 13.3 | 1,677.7 | 3.4 | 167.60 # | 16 # | 13 # | 9 # |
| **Minimum:** | 0.4 | 11.6 | 577.4 | 0.3 | 1.30 | 0 | 0 | 0 |
| **Maximum:** | 19.5 | 16.9 | 2,229.7 | 28.8 | 48.96 | 1 | 1 | 1 |
| **%SI** | 33.3 | 33.3 | 33.3 | 33.3 | 33.33 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/10/2014 00:00 | 1.3 | 12.2 | 2,078.4 | 0.9 | 6.20 | 1 | 1 | 1 |
| 03/10/2014 01:00 | 0.6 | 13.8 | 1,308.5 | 0.5 | 2.60 | 1 | 1 | 1 |
| 03/10/2014 02:00 | 0.5 | 13.9 | 1,233.0 | 0.4 | 2.50 | 1 | 1 | 0 |
| 03/10/2014 03:00 | 0.5 | 13.9 | 1,236.7 | 0.4 | 2.50 | 1 | 1 | 0 |
| 03/10/2014 04:00 | 0.6 | 13.9 | 1,242.6 | 0.5 | 2.50 | 1 | 1 | 0 |
| 03/10/2014 05:00 | 0.7 | 13.7 | 1,545.5 | 0.6 | 3.10 | 1 | 1 | 1 |
| 03/10/2014 06:00 | 1.0 | 13.0 | 1,966.8 | 0.7 | 5.90 | 1 | 1 | 1 |
| 03/10/2014 07:00 | 1.5 | 12.1 | 2,152.3 | 1.0 | 8.60 | 1 | 1 | 1 |
| 03/10/2014 08:00 | 1.4 | 12.3 | 2,104.5 | 1.0 | 8.40 | 1 | 1 | 1 |
| 03/10/2014 09:00 | 0.9 | 13.2 | 1,855.3 | 0.7 | 5.60 | 1 | 1 | 1 |
| 03/10/2014 10:00 | 0.9 | 13.3 | 1,815.5 | 0.7 | 5.40 | 1 | 1 | 1 |
| 03/10/2014 11:00 | 1.0 | 13.3 | 1,820.7 | 0.8 | 5.50 | 1 | 1 | 1 |
| 03/10/2014 12:00 | 0.9 | 13.3 | 1,821.2 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/10/2014 13:00 | 1.0 | 13.4 | 1,822.9 | 0.8 | 5.50 | 1 | 1 | 1 |
| 03/10/2014 14:00 | 1.0 | 13.4 | 1,826.3 | 0.8 | 5.50 | 1 | 1 | 1 |
| 03/10/2014 15:00 | 1.0 | 13.4 | 1,830.1 | 0.8 | 5.50 | 1 | 1 | 1 |
| 03/10/2014 16:00 | 1.0 | 13.4 | 1,827.4 | 0.8 | 5.50 | 1 | 1 | 1 |
| 03/10/2014 17:00 | 1.0 | 13.4 | 1,826.5 | 0.8 | 5.50 | 1 | 1 | 1 |
| 03/10/2014 18:00 | 1.0 | 13.5 | 1,848.8 | 0.8 | 5.50 | 1 | 1 | 1 |
| 03/10/2014 19:00 | 1.4 | 12.2 | 2,144.2 | 0.9 | 6.40 | 1 | 1 | 1 |
| 03/10/2014 20:00 | 1.3 | 12.4 | 2,082.3 | 0.9 | 6.20 | 1 | 1 | 1 |
| 03/10/2014 21:00 | 1.0 | 13.5 | 1,710.9 | 0.8 | 5.10 | 1 | 1 | 1 |
| 03/10/2014 22:00 | 0.7 | 13.9 | 1,389.4 | 0.6 | 2.80 | 1 | 1 | 0 |
| 03/10/2014 23:00 | 4.5 | 15.9 | 574.3 | 5.3 | 2.65 | 1 | 0 | 0 |
| **Average/Sum#:** | 1.1 | 13.3 | 1,711.0 | 0.9 | 120.45 # | 24 # | 23 # | 19 # |
| **Minimum:** | 0.5 | 12.1 | 574.3 | 0.4 | 2.50 | 1 | 0 | 0 |
| **Maximum:** | 4.5 | 15.9 | 2,152.3 | 5.3 | 8.60 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/11/2014 02:00 | 1.7 | 17.5 | 483.5 | 3.0 | 3.18 | 1 | 0 | 0 |
| 03/11/2014 03:00 | 11.3 | 15.4 | 927.1 | 12.1 | 41.70 | 1 | 0 | 0 |
| 03/11/2014 04:00 | 0.5 | 13.9 | 1,331.6 | 0.4 | 2.70 | 1 | 1 | 0 |
| 03/11/2014 05:00 | 0.9 | 13.8 | 1,580.0 | 0.7 | 4.70 | 1 | 1 | 0 |
| 03/11/2014 06:00 | 0.8 | 13.9 | 1,524.1 | 0.7 | 3.00 | 1 | 1 | 0 |
| 03/11/2014 07:00 | 0.9 | 13.7 | 1,762.6 | 0.7 | 5.30 | 1 | 1 | 0 |
| 03/11/2014 08:00 | 1.0 | 13.2 | 1,904.3 | 0.8 | 5.70 | 1 | 1 | 1 |
| 03/11/2014 09:00 | 1.1 | 13.3 | 1,812.0 | 0.9 | 5.40 | 1 | 1 | 1 |
| 03/11/2014 10:00 | 1.1 | 13.3 | 1,813.5 | 0.9 | 5.40 | 1 | 1 | 1 |
| 03/11/2014 11:00 | 1.0 | 13.4 | 1,815.3 | 0.8 | 5.40 | 1 | 1 | 1 |
| 03/11/2014 12:00 | 1.0 | 13.5 | 1,717.4 | 0.8 | 5.20 | 1 | 1 | 1 |
| 03/11/2014 13:00 | 0.7 | 13.9 | 1,329.3 | 0.6 | 2.70 | 1 | 1 | 0 |
| 03/11/2014 14:00 | 0.7 | 14.0 | 1,269.2 | 0.6 | 2.50 | 1 | 1 | 0 |
| 03/11/2014 15:00 | 0.7 | 14.0 | 1,295.1 | 0.6 | 2.60 | 1 | 1 | 0 |
| 03/11/2014 16:00 | 0.8 | 14.0 | 1,370.3 | 0.7 | 4.10 | 1 | 1 | 0 |
| 03/11/2014 17:00 | 0.8 | 14.0 | 1,382.4 | 0.7 | 4.10 | 1 | 1 | 0 |
| 03/11/2014 18:00 | 0.9 | 13.7 | 1,564.9 | 0.7 | 4.70 | 1 | 1 | 1 |
| 03/11/2014 19:00 | 1.3 | 12.5 | 2,069.1 | 0.9 | 6.20 | 1 | 1 | 1 |
| 03/11/2014 20:00 | 1.4 | 12.2 | 2,140.0 | 0.9 | 6.40 | 1 | 1 | 1 |
| 03/11/2014 21:00 | 1.2 | 12.5 | 2,081.1 | 0.8 | 6.20 | 1 | 1 | 1 |
| 03/11/2014 22:00 | 1.4 | 12.2 | 2,140.6 | 0.9 | 6.40 | 1 | 1 | 1 |
| 03/11/2014 23:00 | 1.0 | 13.4 | 1,728.1 | 0.8 | 5.20 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.5 | 13.7 | 1,592.8 | 1.4 | 138.78 # | 22 # | 20 # | 11 # |
| **Minimum:** | 0.5 | 12.2 | 483.5 | 0.4 | 2.50 | 0 | 0 | 0 |
| **Maximum:** | 11.3 | 17.5 | 2,140.6 | 12.1 | 41.70 | 1 | 1 | 1 |
| **%SI** | 8.3 | 8.3 | 8.3 | 8.3 | 8.33 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/12/2014 00:00 | 0.7 | 13.9 | 1,271.1 | 0.6 | 2.50 | 1 | 1 | 0 |
| 03/12/2014 01:00 | 0.6 | 13.9 | 1,257.2 | 0.5 | 2.50 | 1 | 1 | 0 |
| 03/12/2014 02:00 | 0.6 | 13.9 | 1,234.8 | 0.5 | 2.50 | 1 | 1 | 0 |
| 03/12/2014 03:00 | 0.6 | 13.9 | 1,226.2 | 0.5 | 2.50 | 1 | 1 | 0 |
| 03/12/2014 04:00 | 0.6 | 13.9 | 1,231.0 | 0.5 | 2.50 | 1 | 1 | 0 |
| 03/12/2014 05:00 | 0.9 | 13.5 | 1,701.6 | 0.7 | 5.10 | 1 | 1 | 1 |
| 03/12/2014 06:00 | 1.1 | 13.1 | 1,953.6 | 0.8 | 5.90 | 1 | 1 | 1 |
| 03/12/2014 07:00 | 1.4 | 12.0 | 2,152.5 | 0.9 | 6.50 | 1 | 1 | 1 |
| 03/12/2014 08:00 | 1.1 | 13.0 | 1,955.3 | 0.8 | 5.90 | 1 | 1 | 1 |
| 03/12/2014 09:00 | 1.0 | 13.3 | 1,830.9 | 0.8 | 5.50 | 1 | 1 | 1 |
| 03/12/2014 10:00 | 0.9 | 13.3 | 1,832.0 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/12/2014 11:00 | 0.9 | 13.4 | 1,834.2 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/12/2014 12:00 | 0.7 | 13.8 | 1,356.4 | 0.6 | 2.70 | 1 | 1 | 1 |
| 03/12/2014 13:00 | 0.8 | 14.0 | 1,372.1 | 0.7 | 4.10 | 1 | 1 | 0 |
| 03/12/2014 14:00 | 0.8 | 14.0 | 1,244.8 | 0.7 | 3.70 | 1 | 1 | 0 |
| 03/12/2014 15:00 | 0.8 | 14.0 | 1,243.8 | 0.7 | 3.70 | 1 | 1 | 0 |
| 03/12/2014 16:00 | 0.8 | 14.0 | 1,243.9 | 0.7 | 3.70 | 1 | 1 | 0 |
| 03/12/2014 17:00 | 0.9 | 13.7 | 1,543.6 | 0.7 | 4.60 | 1 | 1 | 1 |
| 03/12/2014 18:00 | 1.0 | 13.2 | 1,902.3 | 0.8 | 5.70 | 1 | 1 | 1 |
| 03/12/2014 19:00 | 1.4 | 12.1 | 2,173.3 | 0.9 | 6.50 | 1 | 1 | 1 |
| 03/12/2014 20:00 | 1.5 | 12.0 | 2,191.8 | 1.0 | 8.80 | 1 | 1 | 1 |
| 03/12/2014 21:00 | 1.6 | 11.6 | 2,257.8 | 1.0 | 9.00 | 1 | 1 | 1 |
| 03/12/2014 22:00 | 1.7 | 11.6 | 2,254.8 | 1.1 | 9.00 | 1 | 1 | 1 |
| 03/12/2014 23:00 | 1.4 | 12.1 | 2,148.7 | 0.9 | 6.40 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.0 | 13.2 | 1,683.9 | 0.7 | 120.30 # | 24 # | 24 # | 15 # |
| **Minimum:** | 0.6 | 11.6 | 1,226.2 | 0.5 | 2.50 | 1 | 1 | 0 |
| **Maximum:** | 1.7 | 14.0 | 2,257.8 | 1.1 | 9.00 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/13/2014 00:00 | 0.8 | 13.6 | 1,674.8 | 0.6 | 3.30 | 1 | 1 | 1 |
| 03/13/2014 01:00 | 1.0 | 13.8 | 1,791.5 | 0.8 | 5.40 | 1 | 1 | 0 |
| 03/13/2014 02:00 | 0.7 | 13.9 | 1,390.1 | 0.6 | 2.80 | 1 | 1 | 0 |
| 03/13/2014 03:00 | 0.7 | 13.9 | 1,373.6 | 0.6 | 2.70 | 1 | 1 | 0 |
| 03/13/2014 04:00 | 0.7 | 13.9 | 1,376.4 | 0.6 | 2.80 | 1 | 1 | 0 |
| 03/13/2014 05:00 | 1.0 | 13.2 | 1,851.8 | 0.8 | 5.60 | 1 | 1 | 1 |
| 03/13/2014 06:00 | 1.1 | 13.1 | 1,960.2 | 0.8 | 5.90 | 1 | 1 | 1 |
| 03/13/2014 07:00 | 1.5 | 11.8 | 2,206.5 | 1.0 | 8.80 | 1 | 1 | 1 |
| 03/13/2014 08:00 | 1.3 | 12.5 | 2,092.1 | 0.9 | 6.30 | 1 | 1 | 1 |
| 03/13/2014 09:00 | 1.2 | 12.9 | 1,976.1 | 0.9 | 5.90 | 1 | 1 | 1 |
| 03/13/2014 10:00 | 1.0 | 13.3 | 1,882.3 | 0.8 | 5.60 | 1 | 1 | 1 |
| 03/13/2014 11:00 | 0.9 | 13.5 | 1,821.2 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/13/2014 12:00 | 1.0 | 13.3 | 1,887.6 | 0.8 | 5.70 | 1 | 1 | 1 |
| 03/13/2014 13:00 | 1.0 | 13.1 | 1,942.4 | 0.8 | 5.80 | 1 | 1 | 1 |
| 03/13/2014 14:00 | 1.0 | 13.1 | 1,947.3 | 0.8 | 5.80 | 1 | 1 | 1 |
| 03/13/2014 15:00 | 1.0 | 13.1 | 1,947.1 | 0.8 | 5.80 | 1 | 1 | 1 |
| 03/13/2014 16:00 | 1.0 | 13.2 | 1,893.0 | 0.8 | 5.70 | 1 | 1 | 1 |
| 03/13/2014 17:00 | 0.9 | 13.5 | 1,830.1 | 0.7 | 5.50 | 1 | 1 | 1 |
| 03/13/2014 18:00 | 0.9 | 13.4 | 1,855.2 | 0.7 | 5.60 | 1 | 1 | 1 |
| 03/13/2014 19:00 | 1.0 | 13.1 | 1,922.9 | 0.8 | 5.80 | 1 | 1 | 1 |
| 03/13/2014 20:00 | 0.9 | 13.4 | 1,866.0 | 0.7 | 5.60 | 1 | 1 | 1 |
| 03/13/2014 21:00 | 1.0 | 13.4 | 1,750.8 | 0.8 | 5.30 | 1 | 1 | 1 |
| 03/13/2014 22:00 | 0.7 | 13.9 | 1,038.3 | 0.6 | 0.15 | 1 | 1 | 0 |
| 03/13/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 1.0 | 13.3 | 1,794.7 | 0.8 | 117.35 # | 23 # | 23 # | 18 # |
| **Minimum:** | 0.7 | 11.8 | 1,038.3 | 0.6 | 0.15 | 0 | 0 | 0 |
| **Maximum:** | 1.5 | 13.9 | 2,206.5 | 1.0 | 8.80 | 1 | 1 | 1 |
| **%SI** | 4.2 | 4.2 | 4.2 | 4.2 | 4.17 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/14/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/15/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/30/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 NOx, Ppm 1 Hour(s) | Unit CT1 O2, Dry, Pct 1 Hour(s) | Unit CT1 Hr, MBtuPerHr 1 Hour(s) | Unit CT1 NOx, Ppmvdc 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 UnitOn, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) | Unit CT1 DBOn, TF 1 Hour(s) |
| 03/31/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/01/2014 00:00 | 1.2 | 13.9 | 1,640.5 | 1.0 | 6.60 | 1 | 1 | 0 |
| 01/01/2014 01:00 | 1.3 | 13.8 | 1,818.0 | 1.1 | 7.30 | 1 | 1 | 0 |
| 01/01/2014 02:00 | 1.2 | 13.8 | 1,699.2 | 1.0 | 6.80 | 1 | 1 | 0 |
| 01/01/2014 03:00 | 4.2 | 14.6 | 1,147.1 | 3.9 | 8.86 | 1 | 0 | 0 |
| 01/01/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/01/2014 13:00 | 32.0 | 17.7 | 463.0 | 59.0 | 67.34 | 1 | 0 | 0 |
| 01/01/2014 14:00 | 18.7 | 15.2 | 930.0 | 19.4 | 66.00 | 1 | 0 | 0 |
| 01/01/2014 15:00 | 1.1 | 13.8 | 1,651.8 | 0.9 | 5.00 | 1 | 1 | 0 |
| 01/01/2014 16:00 | 1.2 | 13.9 | 1,731.6 | 1.0 | 6.90 | 1 | 1 | 0 |
| 01/01/2014 17:00 | 1.1 | 13.9 | 1,500.4 | 0.9 | 4.50 | 1 | 1 | 0 |
| 01/01/2014 18:00 | 1.3 | 13.7 | 1,763.2 | 1.1 | 7.10 | 1 | 1 | 1 |
| 01/01/2014 19:00 | 1.6 | 12.6 | 2,089.9 | 1.1 | 8.40 | 1 | 1 | 1 |
| 01/01/2014 20:00 | 1.7 | 12.2 | 2,174.1 | 1.2 | 8.70 | 1 | 1 | 1 |
| 01/01/2014 21:00 | 1.6 | 12.1 | 2,193.2 | 1.1 | 8.80 | 1 | 1 | 1 |
| 01/01/2014 22:00 | 1.6 | 12.5 | 2,104.1 | 1.1 | 8.40 | 1 | 1 | 1 |
| 01/01/2014 23:00 | 1.6 | 12.5 | 2,107.3 | 1.1 | 8.40 | 1 | 1 | 1 |
| **Average/Sum#:** | 4.8 | 13.7 | 1,667.6 | 6.3 | 229.10 # | 15 # | 12 # | 6 # |
| **Minimum:** | 1.1 | 12.1 | 463.0 | 0.9 | 4.50 | 0 | 0 | 0 |
| **Maximum:** | 32.0 | 17.7 | 2,193.2 | 59.0 | 67.34 | 1 | 1 | 1 |
| **%SI** | 37.5 | 37.5 | 37.5 | 37.5 | 37.50 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/02/2014 00:00 | 1.6 | 12.6 | 2,085.4 | 1.1 | 8.30 | 1 | 1 | 1 |
| 01/02/2014 01:00 | 1.4 | 13.4 | 1,867.0 | 1.1 | 7.50 | 1 | 1 | 1 |
| 01/02/2014 02:00 | 1.3 | 13.8 | 1,598.2 | 1.1 | 6.40 | 1 | 1 | 0 |
| 01/02/2014 03:00 | 1.3 | 13.8 | 1,719.7 | 1.1 | 6.90 | 1 | 1 | 0 |
| 01/02/2014 04:00 | 1.2 | 13.8 | 1,598.2 | 1.0 | 6.40 | 1 | 1 | 0 |
| 01/02/2014 05:00 | 1.4 | 13.4 | 1,812.1 | 1.1 | 7.20 | 1 | 1 | 1 |
| 01/02/2014 06:00 | 1.3 | 12.8 | 2,024.5 | 0.9 | 6.10 | 1 | 1 | 1 |
| 01/02/2014 07:00 | 1.6 | 12.9 | 2,019.3 | 1.2 | 8.10 | 1 | 1 | 1 |
| 01/02/2014 08:00 | 1.6 | 12.8 | 2,059.6 | 1.2 | 8.20 | 1 | 1 | 1 |
| 01/02/2014 09:00 | 1.6 | 12.8 | 2,069.5 | 1.2 | 8.30 | 1 | 1 | 1 |
| 01/02/2014 10:00 | 1.6 | 12.8 | 2,059.7 | 1.2 | 8.20 | 1 | 1 | 1 |
| 01/02/2014 11:00 | 1.6 | 12.7 | 2,048.9 | 1.2 | 8.20 | 1 | 1 | 1 |
| 01/02/2014 12:00 | 1.6 | 12.7 | 2,032.4 | 1.2 | 8.10 | 1 | 1 | 1 |
| 01/02/2014 13:00 | 1.6 | 12.7 | 2,020.1 | 1.2 | 8.10 | 1 | 1 | 1 |
| 01/02/2014 14:00 | 1.6 | 12.8 | 1,982.5 | 1.2 | 7.90 | 1 | 1 | 1 |
| 01/02/2014 15:00 | 1.6 | 12.7 | 2,009.2 | 1.2 | 8.00 | 1 | 1 | 1 |
| 01/02/2014 16:00 | 1.6 | 12.6 | 2,031.2 | 1.1 | 8.10 | 1 | 1 | 1 |
| 01/02/2014 17:00 | 1.6 | 12.5 | 2,049.2 | 1.1 | 8.20 | 1 | 1 | 1 |
| 01/02/2014 18:00 | 1.6 | 12.2 | 2,142.6 | 1.1 | 8.60 | 1 | 1 | 1 |
| 01/02/2014 19:00 | 1.6 | 12.0 | 2,171.2 | 1.1 | 8.70 | 1 | 1 | 1 |
| 01/02/2014 20:00 | 1.6 | 12.1 | 2,151.4 | 1.1 | 8.60 | 1 | 1 | 1 |
| 01/02/2014 21:00 | 1.6 | 12.2 | 2,143.0 | 1.1 | 8.60 | 1 | 1 | 1 |
| 01/02/2014 22:00 | 1.6 | 12.6 | 2,096.2 | 1.1 | 8.40 | 1 | 1 | 1 |
| 01/02/2014 23:00 | 1.6 | 12.3 | 2,157.1 | 1.1 | 8.60 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.5 | 12.8 | 1,997.8 | 1.1 | 189.70 # | 24 # | 24 # | 21 # |
| **Minimum:** | 1.2 | 12.0 | 1,598.2 | 0.9 | 6.10 | 1 | 1 | 0 |
| **Maximum:** | 1.6 | 13.8 | 2,171.2 | 1.2 | 8.70 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/03/2014 00:00 | 1.6 | 12.7 | 2,047.0 | 1.2 | 8.20 | 1 | 1 | 1 |
| 01/03/2014 01:00 | 1.3 | 13.5 | 1,762.2 | 1.0 | 7.00 | 1 | 1 | 1 |
| 01/03/2014 02:00 | 1.2 | 13.9 | 1,324.2 | 1.0 | 5.30 | 1 | 1 | 0 |
| 01/03/2014 03:00 | 1.2 | 13.9 | 1,249.2 | 1.0 | 5.00 | 1 | 1 | 0 |
| 01/03/2014 04:00 | 1.2 | 13.9 | 1,250.2 | 1.0 | 5.00 | 1 | 1 | 0 |
| 01/03/2014 05:00 | 1.2 | 13.9 | 1,252.9 | 1.0 | 5.00 | 1 | 1 | 0 |
| 01/03/2014 06:00 | 1.4 | 13.4 | 1,561.2 | 1.1 | 6.20 | 1 | 1 | 1 |
| 01/03/2014 07:00 | 1.5 | 13.1 | 1,943.4 | 1.1 | 7.80 | 1 | 1 | 1 |
| 01/03/2014 08:00 | 1.6 | 13.0 | 2,024.6 | 1.2 | 8.10 | 1 | 1 | 1 |
| 01/03/2014 09:00 | 1.6 | 12.8 | 2,063.8 | 1.2 | 8.30 | 1 | 1 | 1 |
| 01/03/2014 10:00 | 1.6 | 12.7 | 2,076.6 | 1.2 | 8.30 | 1 | 1 | 1 |
| 01/03/2014 11:00 | 1.6 | 12.7 | 2,060.2 | 1.2 | 8.20 | 1 | 1 | 1 |
| 01/03/2014 12:00 | 1.6 | 12.8 | 2,022.6 | 1.2 | 8.10 | 1 | 1 | 1 |
| 01/03/2014 13:00 | 1.6 | 12.8 | 2,006.2 | 1.2 | 8.00 | 1 | 1 | 1 |
| 01/03/2014 14:00 | 1.6 | 12.8 | 1,992.8 | 1.2 | 8.00 | 1 | 1 | 1 |
| 01/03/2014 15:00 | 1.4 | 13.0 | 1,956.7 | 1.0 | 7.80 | 1 | 1 | 1 |
| 01/03/2014 16:00 | 1.6 | 12.7 | 2,001.6 | 1.2 | 8.00 | 1 | 1 | 1 |
| 01/03/2014 17:00 | 1.6 | 12.4 | 2,071.7 | 1.1 | 8.30 | 1 | 1 | 1 |
| 01/03/2014 18:00 | 1.7 | 12.1 | 2,154.3 | 1.1 | 8.60 | 1 | 1 | 1 |
| 01/03/2014 19:00 | 1.6 | 12.3 | 2,120.3 | 1.1 | 8.50 | 1 | 1 | 1 |
| 01/03/2014 20:00 | 1.6 | 12.3 | 2,122.5 | 1.1 | 8.50 | 1 | 1 | 1 |
| 01/03/2014 21:00 | 1.6 | 11.8 | 2,235.0 | 1.0 | 8.90 | 1 | 1 | 1 |
| 01/03/2014 22:00 | 1.7 | 11.9 | 2,209.3 | 1.1 | 8.80 | 1 | 1 | 1 |
| 01/03/2014 23:00 | 1.6 | 12.1 | 2,168.5 | 1.1 | 8.70 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.5 | 12.9 | 1,903.2 | 1.1 | 182.60 # | 24 # | 24 # | 20 # |
| **Minimum:** | 1.2 | 11.8 | 1,249.2 | 1.0 | 5.00 | 1 | 1 | 0 |
| **Maximum:** | 1.7 | 13.9 | 2,235.0 | 1.2 | 8.90 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/04/2014 00:00 | 1.6 | 12.6 | 2,081.3 | 1.1 | 8.30 | 1 | 1 | 1 |
| 01/04/2014 01:00 | 1.6 | 12.5 | 2,114.8 | 1.1 | 8.50 | 1 | 1 | 1 |
| 01/04/2014 02:00 | 1.2 | 13.8 | 1,628.9 | 1.0 | 6.50 | 1 | 1 | 1 |
| 01/04/2014 03:00 | 1.3 | 13.9 | 1,596.5 | 1.1 | 6.40 | 1 | 1 | 0 |
| 01/04/2014 04:00 | 1.0 | 13.9 | 1,428.6 | 0.8 | 4.30 | 1 | 1 | 0 |
| 01/04/2014 05:00 | 1.2 | 13.8 | 1,657.9 | 1.0 | 6.60 | 1 | 1 | 0 |
| 01/04/2014 06:00 | 1.1 | 13.8 | 1,681.7 | 0.9 | 5.00 | 1 | 1 | 0 |
| 01/04/2014 07:00 | 1.3 | 13.7 | 1,836.6 | 1.1 | 7.30 | 1 | 1 | 0 |
| 01/04/2014 08:00 | 1.5 | 13.2 | 1,925.6 | 1.1 | 7.70 | 1 | 1 | 1 |
| 01/04/2014 09:00 | 1.6 | 12.4 | 2,142.9 | 1.1 | 8.60 | 1 | 1 | 1 |
| 01/04/2014 10:00 | 1.6 | 12.6 | 2,072.4 | 1.1 | 8.30 | 1 | 1 | 1 |
| 01/04/2014 11:00 | 1.5 | 12.8 | 2,006.7 | 1.1 | 8.00 | 1 | 1 | 1 |
| 01/04/2014 12:00 | 1.5 | 13.1 | 1,933.3 | 1.1 | 7.70 | 1 | 1 | 1 |
| 01/04/2014 13:00 | 1.5 | 13.3 | 1,883.9 | 1.2 | 7.50 | 1 | 1 | 1 |
| 01/04/2014 14:00 | 1.5 | 12.8 | 1,991.3 | 1.1 | 8.00 | 1 | 1 | 1 |
| 01/04/2014 15:00 | 1.6 | 12.6 | 2,032.4 | 1.1 | 8.10 | 1 | 1 | 1 |
| 01/04/2014 16:00 | 1.6 | 12.5 | 2,054.0 | 1.1 | 8.20 | 1 | 1 | 1 |
| 01/04/2014 17:00 | 1.6 | 12.4 | 2,096.4 | 1.1 | 8.40 | 1 | 1 | 1 |
| 01/04/2014 18:00 | 1.6 | 12.2 | 2,145.1 | 1.1 | 8.60 | 1 | 1 | 1 |
| 01/04/2014 19:00 | 1.6 | 12.2 | 2,148.6 | 1.1 | 8.60 | 1 | 1 | 1 |
| 01/04/2014 20:00 | 1.6 | 12.6 | 2,061.6 | 1.1 | 8.20 | 1 | 1 | 1 |
| 01/04/2014 21:00 | 1.7 | 12.0 | 2,200.1 | 1.1 | 8.80 | 1 | 1 | 1 |
| 01/04/2014 22:00 | 1.6 | 11.9 | 2,225.8 | 1.0 | 8.90 | 1 | 1 | 1 |
| 01/04/2014 23:00 | 1.6 | 12.6 | 2,072.0 | 1.1 | 8.30 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.5 | 12.9 | 1,959.1 | 1.1 | 184.80 # | 24 # | 24 # | 19 # |
| **Minimum:** | 1.0 | 11.9 | 1,428.6 | 0.8 | 4.30 | 1 | 1 | 0 |
| **Maximum:** | 1.7 | 13.9 | 2,225.8 | 1.2 | 8.90 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/05/2014 00:00 | 1.6 | 12.7 | 2,052.7 | 1.2 | 8.20 | 1 | 1 | 1 |
| 01/05/2014 01:00 | 1.6 | 12.5 | 2,089.2 | 1.1 | 8.40 | 1 | 1 | 1 |
| 01/05/2014 02:00 | 1.2 | 13.8 | 1,619.7 | 1.0 | 6.50 | 1 | 1 | 1 |
| 01/05/2014 03:00 | 1.2 | 13.9 | 1,600.5 | 1.0 | 6.40 | 1 | 1 | 0 |
| 01/05/2014 04:00 | 1.2 | 13.9 | 1,700.5 | 1.0 | 6.80 | 1 | 1 | 0 |
| 01/05/2014 05:00 | 1.4 | 13.8 | 1,819.0 | 1.2 | 7.30 | 1 | 1 | 0 |
| 01/05/2014 06:00 | 1.5 | 13.0 | 1,899.5 | 1.1 | 7.60 | 1 | 1 | 1 |
| 01/05/2014 07:00 | 1.6 | 12.5 | 2,125.2 | 1.1 | 8.50 | 1 | 1 | 1 |
| 01/05/2014 08:00 | 1.6 | 11.9 | 2,260.4 | 1.0 | 9.00 | 1 | 1 | 1 |
| 01/05/2014 09:00 | 1.6 | 12.0 | 2,224.1 | 1.1 | 8.90 | 1 | 1 | 1 |
| 01/05/2014 10:00 | 1.6 | 12.6 | 2,092.8 | 1.1 | 8.40 | 1 | 1 | 1 |
| 01/05/2014 11:00 | 1.5 | 12.9 | 2,013.8 | 1.1 | 8.10 | 1 | 1 | 1 |
| 01/05/2014 12:00 | 1.4 | 13.2 | 1,934.8 | 1.1 | 7.70 | 1 | 1 | 1 |
| 01/05/2014 13:00 | 1.4 | 13.0 | 1,953.0 | 1.0 | 7.80 | 1 | 1 | 1 |
| 01/05/2014 14:00 | 1.5 | 12.7 | 2,021.7 | 1.1 | 8.10 | 1 | 1 | 1 |
| 01/05/2014 15:00 | 1.1 | 13.9 | 1,633.4 | 0.9 | 4.90 | 1 | 1 | 1 |
| 01/05/2014 16:00 | 1.4 | 13.1 | 1,882.7 | 1.1 | 7.50 | 1 | 1 | 1 |
| 01/05/2014 17:00 | 1.6 | 12.0 | 2,187.4 | 1.1 | 8.70 | 1 | 1 | 1 |
| 01/05/2014 18:00 | 1.6 | 11.8 | 2,225.8 | 1.0 | 8.90 | 1 | 1 | 1 |
| 01/05/2014 19:00 | 1.7 | 11.8 | 2,236.5 | 1.1 | 8.90 | 1 | 1 | 1 |
| 01/05/2014 20:00 | 1.6 | 11.8 | 2,247.7 | 1.0 | 9.00 | 1 | 1 | 1 |
| 01/05/2014 21:00 | 1.6 | 11.8 | 2,247.6 | 1.0 | 9.00 | 1 | 1 | 1 |
| 01/05/2014 22:00 | 1.6 | 11.8 | 2,256.8 | 1.0 | 9.00 | 1 | 1 | 1 |
| 01/05/2014 23:00 | 1.6 | 12.1 | 2,218.5 | 1.1 | 8.90 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.5 | 12.7 | 2,022.6 | 1.1 | 192.50 # | 24 # | 24 # | 21 # |
| **Minimum:** | 1.1 | 11.8 | 1,600.5 | 0.9 | 4.90 | 1 | 1 | 0 |
| **Maximum:** | 1.7 | 13.9 | 2,260.4 | 1.2 | 9.00 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/06/2014 00:00 | 1.6 | 12.1 | 2,208.2 | 1.1 | 8.80 | 1 | 1 | 1 |
| 01/06/2014 01:00 | 1.6 | 12.4 | 2,136.7 | 1.1 | 8.50 | 1 | 1 | 1 |
| 01/06/2014 02:00 | 1.6 | 12.3 | 2,171.6 | 1.1 | 8.70 | 1 | 1 | 1 |
| 01/06/2014 03:00 | 1.5 | 12.8 | 2,060.7 | 1.1 | 8.20 | 1 | 1 | 1 |
| 01/06/2014 04:00 | 1.5 | 12.9 | 2,040.1 | 1.1 | 8.20 | 1 | 1 | 1 |
| 01/06/2014 05:00 | 1.6 | 12.2 | 2,210.4 | 1.1 | 8.80 | 1 | 1 | 1 |
| 01/06/2014 06:00 | 1.4 | 12.7 | 2,108.3 | 1.0 | 8.40 | 1 | 1 | 1 |
| 01/06/2014 07:00 | 1.5 | 12.7 | 2,076.6 | 1.1 | 8.30 | 1 | 1 | 1 |
| 01/06/2014 08:00 | 1.6 | 12.2 | 2,195.7 | 1.1 | 8.80 | 1 | 1 | 1 |
| 01/06/2014 09:00 | 1.6 | 12.4 | 2,169.6 | 1.1 | 8.70 | 1 | 1 | 1 |
| 01/06/2014 10:00 | 1.6 | 12.3 | 2,206.1 | 1.1 | 8.80 | 1 | 1 | 1 |
| 01/06/2014 11:00 | 1.7 | 12.0 | 2,235.2 | 1.1 | 8.90 | 1 | 1 | 1 |
| 01/06/2014 12:00 | 1.6 | 12.0 | 2,238.4 | 1.1 | 9.00 | 1 | 1 | 1 |
| 01/06/2014 13:00 | 1.6 | 11.9 | 2,247.2 | 1.0 | 9.00 | 1 | 1 | 1 |
| 01/06/2014 14:00 | 1.6 | 12.2 | 2,156.8 | 1.1 | 8.60 | 1 | 1 | 1 |
| 01/06/2014 15:00 | 1.6 | 12.8 | 2,037.1 | 1.2 | 8.10 | 1 | 1 | 1 |
| 01/06/2014 16:00 | 1.6 | 12.7 | 2,048.0 | 1.2 | 8.20 | 1 | 1 | 1 |
| 01/06/2014 17:00 | 1.6 | 12.5 | 2,109.7 | 1.1 | 8.40 | 1 | 1 | 1 |
| 01/06/2014 18:00 | 1.6 | 12.4 | 2,128.3 | 1.1 | 8.50 | 1 | 1 | 1 |
| 01/06/2014 19:00 | 1.6 | 11.9 | 2,250.3 | 1.0 | 9.00 | 1 | 1 | 1 |
| 01/06/2014 20:00 | 1.6 | 12.3 | 2,147.9 | 1.1 | 8.60 | 1 | 1 | 1 |
| 01/06/2014 21:00 | 1.6 | 11.8 | 2,262.9 | 1.0 | 9.10 | 1 | 1 | 1 |
| 01/06/2014 22:00 | 1.7 | 11.8 | 2,277.0 | 1.1 | 9.10 | 1 | 1 | 1 |
| 01/06/2014 23:00 | 1.6 | 12.3 | 2,150.8 | 1.1 | 8.60 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.6 | 12.3 | 2,161.4 | 1.1 | 207.30 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.4 | 11.8 | 2,037.1 | 1.0 | 8.10 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 12.9 | 2,277.0 | 1.2 | 9.10 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/07/2014 00:00 | 1.5 | 12.9 | 1,997.7 | 1.1 | 8.00 | 1 | 1 | 1 |
| 01/07/2014 01:00 | 1.4 | 13.3 | 1,770.3 | 1.1 | 7.10 | 1 | 1 | 1 |
| 01/07/2014 02:00 | 1.2 | 13.9 | 1,493.5 | 1.0 | 6.00 | 1 | 1 | 0 |
| 01/07/2014 03:00 | 1.4 | 13.9 | 1,598.9 | 1.2 | 6.40 | 1 | 1 | 0 |
| 01/07/2014 04:00 | 1.3 | 13.9 | 1,581.3 | 1.1 | 6.30 | 1 | 1 | 0 |
| 01/07/2014 05:00 | 1.3 | 13.9 | 1,597.1 | 1.1 | 6.40 | 1 | 1 | 0 |
| 01/07/2014 06:00 | 1.5 | 13.2 | 1,819.7 | 1.1 | 7.30 | 1 | 1 | 1 |
| 01/07/2014 07:00 | 1.5 | 13.0 | 2,049.2 | 1.1 | 8.20 | 1 | 1 | 1 |
| 01/07/2014 08:00 | 1.6 | 12.3 | 2,204.2 | 1.1 | 8.80 | 1 | 1 | 1 |
| 01/07/2014 09:00 | 1.6 | 12.3 | 2,195.2 | 1.1 | 8.80 | 1 | 1 | 1 |
| 01/07/2014 10:00 | 1.6 | 12.6 | 2,122.4 | 1.1 | 8.50 | 1 | 1 | 1 |
| 01/07/2014 11:00 | 1.6 | 12.7 | 2,088.7 | 1.2 | 8.40 | 1 | 1 | 1 |
| 01/07/2014 12:00 | 1.6 | 11.9 | 2,247.6 | 1.0 | 9.00 | 1 | 1 | 1 |
| 01/07/2014 13:00 | 1.7 | 11.9 | 2,242.9 | 1.1 | 9.00 | 1 | 1 | 1 |
| 01/07/2014 14:00 | 1.6 | 12.5 | 2,099.0 | 1.1 | 8.40 | 1 | 1 | 1 |
| 01/07/2014 15:00 | 1.6 | 12.4 | 2,111.6 | 1.1 | 8.40 | 1 | 1 | 1 |
| 01/07/2014 16:00 | 1.5 | 12.8 | 2,017.6 | 1.1 | 8.10 | 1 | 1 | 1 |
| 01/07/2014 17:00 | 1.5 | 12.8 | 2,020.0 | 1.1 | 8.10 | 1 | 1 | 1 |
| 01/07/2014 18:00 | 1.6 | 12.6 | 2,071.8 | 1.1 | 8.30 | 1 | 1 | 1 |
| 01/07/2014 19:00 | 1.6 | 12.0 | 2,205.8 | 1.1 | 8.80 | 1 | 1 | 1 |
| 01/07/2014 20:00 | 1.6 | 11.8 | 2,250.8 | 1.0 | 9.00 | 1 | 1 | 1 |
| 01/07/2014 21:00 | 1.6 | 12.5 | 2,101.3 | 1.1 | 8.40 | 1 | 1 | 1 |
| 01/07/2014 22:00 | 1.6 | 12.7 | 2,076.2 | 1.2 | 8.30 | 1 | 1 | 1 |
| 01/07/2014 23:00 | 1.4 | 13.1 | 1,906.0 | 1.1 | 7.60 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.5 | 12.8 | 1,994.5 | 1.1 | 191.60 # | 24 # | 24 # | 20 # |
| **Minimum:** | 1.2 | 11.8 | 1,493.5 | 1.0 | 6.00 | 1 | 1 | 0 |
| **Maximum:** | 1.7 | 13.9 | 2,250.8 | 1.2 | 9.00 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/08/2014 00:00 | 1.2 | 13.9 | 1,365.7 | 1.0 | 5.50 | 1 | 1 | 0 |
| 01/08/2014 01:00 | 1.1 | 13.9 | 1,315.8 | 0.9 | 3.90 | 1 | 1 | 0 |
| 01/08/2014 02:00 | 1.2 | 13.9 | 1,290.4 | 1.0 | 5.20 | 1 | 1 | 0 |
| 01/08/2014 03:00 | 1.2 | 13.9 | 1,265.7 | 1.0 | 5.10 | 1 | 1 | 0 |
| 01/08/2014 04:00 | 1.4 | 13.9 | 1,298.1 | 1.2 | 5.20 | 1 | 1 | 0 |
| 01/08/2014 05:00 | 1.3 | 13.8 | 1,639.0 | 1.1 | 6.60 | 1 | 1 | 0 |
| 01/08/2014 06:00 | 1.4 | 13.4 | 1,723.6 | 1.1 | 6.90 | 1 | 1 | 1 |
| 01/08/2014 07:00 | 1.5 | 13.3 | 1,967.3 | 1.2 | 7.90 | 1 | 1 | 1 |
| 01/08/2014 08:00 | 1.5 | 12.9 | 2,041.8 | 1.1 | 8.20 | 1 | 1 | 1 |
| 01/08/2014 09:00 | 1.3 | 13.5 | 1,787.5 | 1.0 | 7.20 | 1 | 1 | 1 |
| 01/08/2014 10:00 | 1.0 | 13.9 | 1,242.9 | 0.8 | 3.70 | 1 | 1 | 0 |
| 01/08/2014 11:00 | 1.2 | 13.9 | 1,383.0 | 1.0 | 5.50 | 1 | 1 | 0 |
| 01/08/2014 12:00 | 1.2 | 13.7 | 1,709.3 | 1.0 | 6.80 | 1 | 1 | 0 |
| 01/08/2014 13:00 | 1.2 | 13.9 | 1,485.5 | 1.0 | 5.90 | 1 | 1 | 0 |
| 01/08/2014 14:00 | 1.2 | 13.9 | 1,259.9 | 1.0 | 5.00 | 1 | 1 | 0 |
| 01/08/2014 15:00 | 1.3 | 13.9 | 1,405.6 | 1.1 | 5.60 | 1 | 1 | 0 |
| 01/08/2014 16:00 | 1.3 | 13.9 | 1,530.6 | 1.1 | 6.10 | 1 | 1 | 0 |
| 01/08/2014 17:00 | 1.4 | 13.4 | 1,806.3 | 1.1 | 7.20 | 1 | 1 | 1 |
| 01/08/2014 18:00 | 1.0 | 13.9 | 1,438.8 | 0.8 | 4.30 | 1 | 1 | 0 |
| 01/08/2014 19:00 | 1.1 | 13.9 | 1,537.7 | 0.9 | 4.60 | 1 | 1 | 0 |
| 01/08/2014 20:00 | 1.2 | 13.9 | 1,495.5 | 1.0 | 6.00 | 1 | 1 | 0 |
| 01/08/2014 21:00 | 1.1 | 13.9 | 1,488.5 | 0.9 | 4.50 | 1 | 1 | 0 |
| 01/08/2014 22:00 | 7.8 | 15.4 | 746.3 | 8.4 | 6.47 | 1 | 0 | 0 |
| 01/08/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 1.5 | 13.8 | 1,488.0 | 1.3 | 133.37 # | 23 # | 22 # | 5 # |
| **Minimum:** | 1.0 | 12.9 | 746.3 | 0.8 | 3.70 | 0 | 0 | 0 |
| **Maximum:** | 7.8 | 15.4 | 2,041.8 | 8.4 | 8.20 | 1 | 1 | 1 |
| **%SI** | 4.2 | 4.2 | 4.2 | 4.2 | 4.17 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/09/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/09/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/10/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/10/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/11/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/12/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/12/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/13/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/13/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/14/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/14/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/15/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 01/29/2014 08:00 | 34.0 | 17.6 | 504.0 | 60.8 | 71.13 | 1 | 0 | 0 |
| 01/29/2014 09:00 | 35.5 | 17.1 | 609.7 | 55.1 | 123.80 | 1 | 0 | 0 |
| 01/29/2014 10:00 | 9.2 | 17.9 | 630.0 | 18.1 | 42.20 | 1 | 0 | 0 |
| 01/29/2014 11:00 | 12.7 | 17.6 | 640.8 | 22.7 | 53.80 | 1 | 0 | 0 |
| 01/29/2014 12:00 | 12.1 | 14.8 | 1,304.2 | 11.7 | 56.10 | 1 | 0 | 0 |
| 01/29/2014 13:00 | 1.2 | 13.7 | 1,821.8 | 1.0 | 7.30 | 1 | 1 | 0 |
| 01/29/2014 14:00 | 1.2 | 13.7 | 1,811.7 | 1.0 | 7.20 | 1 | 1 | 0 |
| 01/29/2014 15:00 | 1.0 | 13.8 | 1,657.1 | 0.8 | 5.00 | 1 | 1 | 0 |
| 01/29/2014 16:00 | 0.7 | 13.9 | 1,283.9 | 0.6 | 2.60 | 1 | 1 | 0 |
| 01/29/2014 17:00 | 1.0 | 13.8 | 1,541.8 | 0.8 | 4.60 | 1 | 1 | 0 |
| 01/29/2014 18:00 | 1.2 | 13.7 | 1,816.9 | 1.0 | 7.30 | 1 | 1 | 0 |
| 01/29/2014 19:00 | 1.2 | 13.7 | 1,816.0 | 1.0 | 7.30 | 1 | 1 | 0 |
| 01/29/2014 20:00 | 1.1 | 13.8 | 1,758.1 | 0.9 | 5.30 | 1 | 1 | 0 |
| 01/29/2014 21:00 | 1.1 | 13.8 | 1,813.2 | 0.9 | 5.40 | 1 | 1 | 0 |
| 01/29/2014 22:00 | 1.0 | 13.8 | 1,668.8 | 0.8 | 5.00 | 1 | 1 | 0 |
| 01/29/2014 23:00 | 0.9 | 13.9 | 1,295.1 | 0.8 | 3.90 | 1 | 1 | 0 |
| **Average/Sum#:** | 7.2 | 14.8 | 1,373.3 | 11.1 | 407.93 # | 16 # | 11 # | 0 # |
| **Minimum:** | 0.7 | 13.7 | 504.0 | 0.6 | 2.60 | 0 | 0 | 0 |
| **Maximum:** | 35.5 | 17.9 | 1,821.8 | 60.8 | 123.80 | 1 | 1 | 0 |
| **%SI** | 33.3 | 33.3 | 33.3 | 33.3 | 33.33 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/30/2014 00:00 | 1.0 | 13.9 | 1,466.4 | 0.8 | 4.40 | 1 | 1 | 0 |
| 01/30/2014 01:00 | 1.2 | 13.8 | 1,750.8 | 1.0 | 7.00 | 1 | 1 | 0 |
| 01/30/2014 02:00 | 0.9 | 13.9 | 1,330.0 | 0.8 | 4.00 | 1 | 1 | 0 |
| 01/30/2014 03:00 | 1.0 | 13.9 | 1,261.5 | 0.8 | 3.80 | 1 | 1 | 0 |
| 01/30/2014 04:00 | 1.0 | 13.9 | 1,285.1 | 0.8 | 3.90 | 1 | 1 | 0 |
| 01/30/2014 05:00 | 1.0 | 13.9 | 1,259.6 | 0.8 | 3.80 | 1 | 1 | 0 |
| 01/30/2014 06:00 | 1.2 | 13.9 | 1,452.1 | 1.0 | 5.80 | 1 | 1 | 0 |
| 01/30/2014 07:00 | 1.0 | 13.9 | 1,548.5 | 0.8 | 4.60 | 1 | 1 | 0 |
| 01/30/2014 08:00 | 1.0 | 13.9 | 1,560.7 | 0.8 | 4.70 | 1 | 1 | 0 |
| 01/30/2014 09:00 | 0.9 | 13.9 | 1,247.8 | 0.8 | 3.70 | 1 | 1 | 0 |
| 01/30/2014 10:00 | 1.1 | 13.8 | 1,519.4 | 0.9 | 4.60 | 1 | 1 | 1 |
| 01/30/2014 11:00 | 1.5 | 13.1 | 1,950.8 | 1.1 | 7.80 | 1 | 1 | 1 |
| 01/30/2014 12:00 | 1.5 | 12.9 | 1,981.3 | 1.1 | 7.90 | 1 | 1 | 1 |
| 01/30/2014 13:00 | 1.6 | 12.4 | 2,103.5 | 1.1 | 8.40 | 1 | 1 | 1 |
| 01/30/2014 14:00 | 1.6 | 11.9 | 2,194.7 | 1.0 | 8.80 | 1 | 1 | 1 |
| 01/30/2014 15:00 | 1.7 | 11.8 | 2,222.2 | 1.1 | 8.90 | 1 | 1 | 1 |
| 01/30/2014 16:00 | 1.3 | 12.8 | 1,882.1 | 0.9 | 5.60 | 1 | 1 | 1 |
| 01/30/2014 17:00 | 1.0 | 13.9 | 1,570.2 | 0.8 | 4.70 | 1 | 1 | 0 |
| 01/30/2014 18:00 | 1.1 | 13.9 | 1,640.6 | 0.9 | 4.90 | 1 | 1 | 0 |
| 01/30/2014 19:00 | 1.5 | 13.0 | 1,929.1 | 1.1 | 7.70 | 1 | 1 | 1 |
| 01/30/2014 20:00 | 1.6 | 12.5 | 2,085.7 | 1.1 | 8.30 | 1 | 1 | 1 |
| 01/30/2014 21:00 | 1.5 | 12.6 | 2,066.1 | 1.1 | 8.30 | 1 | 1 | 1 |
| 01/30/2014 22:00 | 1.3 | 12.9 | 2,001.7 | 1.0 | 8.00 | 1 | 1 | 1 |
| 01/30/2014 23:00 | 1.5 | 12.9 | 2,003.3 | 1.1 | 8.00 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.3 | 13.3 | 1,721.4 | 0.9 | 147.60 # | 24 # | 24 # | 12 # |
| **Minimum:** | 0.9 | 11.8 | 1,247.8 | 0.8 | 3.70 | 1 | 1 | 0 |
| **Maximum:** | 1.7 | 13.9 | 2,222.2 | 1.1 | 8.90 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 01/31/2014 00:00 | 1.1 | 13.6 | 1,555.3 | 0.9 | 4.70 | 1 | 1 | 1 |
| 01/31/2014 01:00 | 1.1 | 13.9 | 1,491.4 | 0.9 | 4.50 | 1 | 1 | 0 |
| 01/31/2014 02:00 | 1.2 | 14.5 | 1,624.9 | 1.1 | 6.50 | 1 | 1 | 0 |
| 01/31/2014 03:00 | 1.1 | 13.9 | 1,411.5 | 0.9 | 4.20 | 1 | 1 | 0 |
| 01/31/2014 04:00 | 1.2 | 13.9 | 1,329.4 | 1.0 | 5.30 | 1 | 1 | 0 |
| 01/31/2014 05:00 | 1.3 | 13.8 | 1,769.3 | 1.1 | 7.10 | 1 | 1 | 0 |
| 01/31/2014 06:00 | 1.3 | 13.2 | 1,938.4 | 1.0 | 7.80 | 1 | 1 | 1 |
| 01/31/2014 07:00 | 1.3 | 13.3 | 1,912.7 | 1.0 | 7.70 | 1 | 1 | 1 |
| 01/31/2014 08:00 | 1.5 | 13.1 | 2,002.4 | 1.1 | 8.00 | 1 | 1 | 1 |
| 01/31/2014 09:00 | 1.5 | 13.2 | 1,973.7 | 1.1 | 7.90 | 1 | 1 | 1 |
| 01/31/2014 10:00 | 1.4 | 13.2 | 1,970.2 | 1.1 | 7.90 | 1 | 1 | 1 |
| 01/31/2014 11:00 | 1.5 | 13.2 | 1,958.9 | 1.1 | 7.80 | 1 | 1 | 1 |
| 01/31/2014 12:00 | 1.5 | 12.9 | 2,007.4 | 1.1 | 8.00 | 1 | 1 | 1 |
| 01/31/2014 13:00 | 1.5 | 12.8 | 2,006.8 | 1.1 | 8.00 | 1 | 1 | 1 |
| 01/31/2014 14:00 | 1.5 | 13.1 | 1,960.3 | 1.1 | 7.80 | 1 | 1 | 1 |
| 01/31/2014 15:00 | 1.4 | 13.2 | 1,940.3 | 1.1 | 7.80 | 1 | 1 | 1 |
| 01/31/2014 16:00 | 1.5 | 13.2 | 1,924.4 | 1.1 | 7.70 | 1 | 1 | 1 |
| 01/31/2014 17:00 | 1.5 | 13.1 | 1,952.9 | 1.1 | 7.80 | 1 | 1 | 1 |
| 01/31/2014 18:00 | 1.5 | 13.2 | 1,936.5 | 1.1 | 7.70 | 1 | 1 | 1 |
| 01/31/2014 19:00 | 1.5 | 12.6 | 2,088.0 | 1.1 | 8.40 | 1 | 1 | 1 |
| 01/31/2014 20:00 | 1.6 | 12.8 | 2,030.5 | 1.2 | 8.10 | 1 | 1 | 1 |
| 01/31/2014 21:00 | 1.6 | 12.6 | 2,079.5 | 1.1 | 8.30 | 1 | 1 | 1 |
| 01/31/2014 22:00 | 1.6 | 12.3 | 2,144.4 | 1.1 | 8.60 | 1 | 1 | 1 |
| 01/31/2014 23:00 | 1.5 | 12.4 | 2,128.8 | 1.0 | 8.50 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.4 | 13.2 | 1,880.7 | 1.1 | 176.10 # | 24 # | 24 # | 19 # |
| **Minimum:** | 1.1 | 12.3 | 1,329.4 | 0.9 | 4.20 | 1 | 1 | 0 |
| **Maximum:** | 1.6 | 14.5 | 2,144.4 | 1.2 | 8.60 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/01/2014 00:00 | 1.5 | 13.3 | 1,810.9 | 1.2 | 7.20 | 1 | 1 | 1 |
| 02/01/2014 01:00 | 1.1 | 13.9 | 1,623.7 | 0.9 | 4.90 | 1 | 1 | 0 |
| 02/01/2014 02:00 | 1.2 | 13.9 | 1,658.6 | 1.0 | 6.60 | 1 | 1 | 0 |
| 02/01/2014 03:00 | 1.2 | 13.8 | 1,786.0 | 1.0 | 7.10 | 1 | 1 | 0 |
| 02/01/2014 04:00 | 1.0 | 13.9 | 1,468.3 | 0.8 | 4.40 | 1 | 1 | 0 |
| 02/01/2014 05:00 | 1.4 | 13.3 | 1,870.7 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/01/2014 06:00 | 1.7 | 11.9 | 2,252.9 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/01/2014 07:00 | 1.7 | 12.0 | 2,254.5 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/01/2014 08:00 | 1.7 | 12.2 | 2,206.7 | 1.2 | 8.80 | 1 | 1 | 1 |
| 02/01/2014 09:00 | 1.6 | 12.5 | 2,146.8 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/01/2014 10:00 | 1.4 | 13.4 | 1,854.3 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/01/2014 11:00 | 1.1 | 13.9 | 1,570.9 | 0.9 | 4.70 | 1 | 1 | 0 |
| 02/01/2014 12:00 | 1.1 | 13.9 | 1,539.8 | 0.9 | 4.60 | 1 | 1 | 0 |
| 02/01/2014 13:00 | 1.1 | 13.9 | 1,590.7 | 0.9 | 4.80 | 1 | 1 | 0 |
| 02/01/2014 14:00 | 1.0 | 13.9 | 1,443.1 | 0.8 | 4.30 | 1 | 1 | 0 |
| 02/01/2014 15:00 | 1.1 | 13.9 | 1,262.0 | 0.9 | 3.80 | 1 | 1 | 0 |
| 02/01/2014 16:00 | 1.1 | 13.9 | 1,312.7 | 0.9 | 3.90 | 1 | 1 | 0 |
| 02/01/2014 17:00 | 1.4 | 13.6 | 1,689.6 | 1.1 | 6.80 | 1 | 1 | 1 |
| 02/01/2014 18:00 | 1.6 | 12.8 | 2,031.8 | 1.2 | 8.10 | 1 | 1 | 1 |
| 02/01/2014 19:00 | 1.6 | 12.0 | 2,215.4 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/01/2014 20:00 | 1.6 | 11.8 | 2,261.9 | 1.0 | 9.00 | 1 | 1 | 1 |
| 02/01/2014 21:00 | 1.7 | 11.8 | 2,268.9 | 1.1 | 9.10 | 1 | 1 | 1 |
| 02/01/2014 22:00 | 1.7 | 11.9 | 2,268.3 | 1.1 | 9.10 | 1 | 1 | 1 |
| 02/01/2014 23:00 | 1.7 | 12.0 | 2,255.1 | 1.1 | 9.00 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.4 | 13.1 | 1,860.2 | 1.0 | 166.60 # | 24 # | 24 # | 14 # |
| **Minimum:** | 1.0 | 11.8 | 1,262.0 | 0.8 | 3.80 | 1 | 1 | 0 |
| **Maximum:** | 1.7 | 13.9 | 2,268.9 | 1.2 | 9.10 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/02/2014 00:00 | 1.6 | 12.3 | 2,194.0 | 1.1 | 8.80 | 1 | 1 | 1 |
| 02/02/2014 01:00 | 1.6 | 12.6 | 2,104.3 | 1.1 | 8.40 | 1 | 1 | 1 |
| 02/02/2014 02:00 | 1.6 | 12.7 | 2,103.9 | 1.2 | 8.40 | 1 | 1 | 1 |
| 02/02/2014 03:00 | 1.6 | 12.7 | 2,107.0 | 1.2 | 8.40 | 1 | 1 | 1 |
| 02/02/2014 04:00 | 1.6 | 12.9 | 2,058.6 | 1.2 | 8.20 | 1 | 1 | 1 |
| 02/02/2014 05:00 | 1.6 | 12.9 | 2,060.9 | 1.2 | 8.20 | 1 | 1 | 1 |
| 02/02/2014 06:00 | 1.5 | 12.8 | 2,075.1 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/02/2014 07:00 | 1.7 | 12.2 | 2,227.4 | 1.2 | 8.90 | 1 | 1 | 1 |
| 02/02/2014 08:00 | 1.7 | 12.0 | 2,267.1 | 1.1 | 9.10 | 1 | 1 | 1 |
| 02/02/2014 09:00 | 1.7 | 12.0 | 2,268.6 | 1.1 | 9.10 | 1 | 1 | 1 |
| 02/02/2014 10:00 | 1.7 | 11.9 | 2,269.1 | 1.1 | 9.10 | 1 | 1 | 1 |
| 02/02/2014 11:00 | 1.7 | 11.9 | 2,269.8 | 1.1 | 9.10 | 1 | 1 | 1 |
| 02/02/2014 12:00 | 1.7 | 11.9 | 2,259.8 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/02/2014 13:00 | 1.6 | 12.0 | 2,241.0 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/02/2014 14:00 | 1.6 | 12.5 | 2,109.3 | 1.1 | 8.40 | 1 | 1 | 1 |
| 02/02/2014 15:00 | 1.6 | 11.9 | 2,243.7 | 1.0 | 9.00 | 1 | 1 | 1 |
| 02/02/2014 16:00 | 1.7 | 11.8 | 2,274.8 | 1.1 | 9.10 | 1 | 1 | 1 |
| 02/02/2014 17:00 | 1.6 | 12.2 | 2,174.6 | 1.1 | 8.70 | 1 | 1 | 1 |
| 02/02/2014 18:00 | 1.5 | 13.1 | 1,994.5 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/02/2014 19:00 | 1.6 | 12.4 | 2,143.2 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/02/2014 20:00 | 1.7 | 11.9 | 2,247.7 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/02/2014 21:00 | 1.7 | 11.8 | 2,272.7 | 1.1 | 9.10 | 1 | 1 | 1 |
| 02/02/2014 22:00 | 1.6 | 12.1 | 2,196.3 | 1.1 | 8.80 | 1 | 1 | 1 |
| 02/02/2014 23:00 | 1.7 | 11.9 | 2,251.9 | 1.1 | 9.00 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.6 | 12.3 | 2,184.0 | 1.1 | 209.70 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.5 | 11.8 | 1,994.5 | 1.0 | 8.00 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.1 | 2,274.8 | 1.2 | 9.10 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/03/2014 00:00 | 1.7 | 12.0 | 2,238.4 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/03/2014 01:00 | 1.6 | 12.5 | 2,128.7 | 1.1 | 8.50 | 1 | 1 | 1 |
| 02/03/2014 02:00 | 1.6 | 12.9 | 2,034.6 | 1.2 | 8.10 | 1 | 1 | 1 |
| 02/03/2014 03:00 | 1.5 | 13.0 | 1,999.9 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/03/2014 04:00 | 1.4 | 13.0 | 2,048.2 | 1.0 | 8.20 | 1 | 1 | 1 |
| 02/03/2014 05:00 | 1.6 | 12.6 | 2,138.5 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/03/2014 06:00 | 1.3 | 12.9 | 2,085.2 | 1.0 | 8.30 | 1 | 1 | 1 |
| 02/03/2014 07:00 | 1.6 | 12.7 | 2,098.8 | 1.2 | 8.40 | 1 | 1 | 1 |
| 02/03/2014 08:00 | 1.7 | 12.1 | 2,252.0 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/03/2014 09:00 | 1.6 | 12.2 | 2,209.6 | 1.1 | 8.80 | 1 | 1 | 1 |
| 02/03/2014 10:00 | 1.6 | 12.6 | 2,112.1 | 1.1 | 8.40 | 1 | 1 | 1 |
| 02/03/2014 11:00 | 1.4 | 13.2 | 1,929.4 | 1.1 | 7.70 | 1 | 1 | 1 |
| 02/03/2014 12:00 | 1.5 | 13.2 | 1,952.6 | 1.1 | 7.80 | 1 | 1 | 1 |
| 02/03/2014 13:00 | 1.6 | 12.9 | 2,015.6 | 1.2 | 8.10 | 1 | 1 | 1 |
| 02/03/2014 14:00 | 1.5 | 12.9 | 2,020.1 | 1.1 | 8.10 | 1 | 1 | 1 |
| 02/03/2014 15:00 | 1.5 | 13.0 | 1,979.0 | 1.1 | 7.90 | 1 | 1 | 1 |
| 02/03/2014 16:00 | 1.5 | 12.9 | 2,005.2 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/03/2014 17:00 | 1.6 | 12.6 | 2,088.4 | 1.1 | 8.40 | 1 | 1 | 1 |
| 02/03/2014 18:00 | 1.7 | 11.9 | 2,232.1 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/03/2014 19:00 | 1.6 | 11.8 | 2,268.7 | 1.0 | 9.10 | 1 | 1 | 1 |
| 02/03/2014 20:00 | 1.7 | 11.8 | 2,271.7 | 1.1 | 9.10 | 1 | 1 | 1 |
| 02/03/2014 21:00 | 1.7 | 11.8 | 2,268.2 | 1.1 | 9.10 | 1 | 1 | 1 |
| 02/03/2014 22:00 | 1.6 | 12.0 | 2,242.9 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/03/2014 23:00 | 1.6 | 12.3 | 2,152.5 | 1.1 | 8.60 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.6 | 12.5 | 2,115.5 | 1.1 | 203.10 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.3 | 11.8 | 1,929.4 | 1.0 | 7.70 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.2 | 2,271.7 | 1.2 | 9.10 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/04/2014 00:00 | 1.6 | 12.7 | 2,099.3 | 1.2 | 8.40 | 1 | 1 | 1 |
| 02/04/2014 01:00 | 1.5 | 13.0 | 2,038.0 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/04/2014 02:00 | 1.5 | 13.1 | 1,954.6 | 1.1 | 7.80 | 1 | 1 | 1 |
| 02/04/2014 03:00 | 1.5 | 13.1 | 2,010.8 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/04/2014 04:00 | 1.5 | 13.2 | 1,901.3 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/04/2014 05:00 | 1.5 | 13.2 | 1,871.6 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/04/2014 06:00 | 1.5 | 12.7 | 2,031.7 | 1.1 | 8.10 | 1 | 1 | 1 |
| 02/04/2014 07:00 | 1.5 | 12.8 | 2,063.2 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/04/2014 08:00 | 1.6 | 12.9 | 2,065.8 | 1.2 | 8.30 | 1 | 1 | 1 |
| 02/04/2014 09:00 | 1.5 | 13.1 | 2,011.3 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/04/2014 10:00 | 1.5 | 13.0 | 2,046.8 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/04/2014 11:00 | 1.6 | 12.9 | 2,047.4 | 1.2 | 8.20 | 1 | 1 | 1 |
| 02/04/2014 12:00 | 1.5 | 13.0 | 2,006.9 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/04/2014 13:00 | 1.5 | 13.2 | 1,948.5 | 1.1 | 7.80 | 1 | 1 | 1 |
| 02/04/2014 14:00 | 1.6 | 12.8 | 2,035.1 | 1.2 | 8.10 | 1 | 1 | 1 |
| 02/04/2014 15:00 | 1.6 | 12.6 | 2,081.1 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/04/2014 16:00 | 1.6 | 12.7 | 2,043.6 | 1.2 | 8.20 | 1 | 1 | 1 |
| 02/04/2014 17:00 | 1.6 | 12.8 | 2,050.9 | 1.2 | 8.20 | 1 | 1 | 1 |
| 02/04/2014 18:00 | 1.6 | 12.4 | 2,134.8 | 1.1 | 8.50 | 1 | 1 | 1 |
| 02/04/2014 19:00 | 1.6 | 12.0 | 2,225.6 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/04/2014 20:00 | 1.6 | 12.1 | 2,200.3 | 1.1 | 8.80 | 1 | 1 | 1 |
| 02/04/2014 21:00 | 1.6 | 11.9 | 2,253.6 | 1.0 | 9.00 | 1 | 1 | 1 |
| 02/04/2014 22:00 | 1.7 | 12.0 | 2,238.7 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/04/2014 23:00 | 1.6 | 12.5 | 2,126.1 | 1.1 | 8.50 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.6 | 12.7 | 2,062.0 | 1.1 | 197.90 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.5 | 11.9 | 1,871.6 | 1.0 | 7.50 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.2 | 2,253.6 | 1.2 | 9.00 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/05/2014 00:00 | 1.6 | 12.8 | 2,068.9 | 1.2 | 8.30 | 1 | 1 | 1 |
| 02/05/2014 01:00 | 1.5 | 13.2 | 1,905.0 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/05/2014 02:00 | 1.5 | 13.2 | 1,874.2 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/05/2014 03:00 | 1.5 | 13.2 | 1,874.3 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/05/2014 04:00 | 1.5 | 13.2 | 1,875.6 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/05/2014 05:00 | 1.5 | 13.2 | 1,915.1 | 1.1 | 7.70 | 1 | 1 | 1 |
| 02/05/2014 06:00 | 1.1 | 13.0 | 1,976.7 | 0.8 | 5.90 | 1 | 1 | 1 |
| 02/05/2014 07:00 | 1.6 | 12.5 | 2,146.0 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/05/2014 08:00 | 1.7 | 12.0 | 2,261.9 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/05/2014 09:00 | 1.6 | 12.8 | 2,099.0 | 1.2 | 8.40 | 1 | 1 | 1 |
| 02/05/2014 10:00 | 1.1 | 13.8 | 1,351.7 | 0.9 | 4.10 | 1 | 1 | 1 |
| 02/05/2014 11:00 | 1.2 | 13.5 | 1,561.4 | 1.0 | 6.20 | 1 | 1 | 1 |
| 02/05/2014 12:00 | 1.7 | 11.9 | 2,276.8 | 1.1 | 9.10 | 1 | 1 | 1 |
| 02/05/2014 13:00 | 1.7 | 12.1 | 2,193.5 | 1.1 | 8.80 | 1 | 1 | 1 |
| 02/05/2014 14:00 | 1.5 | 13.2 | 1,908.9 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/05/2014 15:00 | 1.5 | 13.2 | 1,882.8 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/05/2014 16:00 | 1.5 | 13.2 | 1,903.9 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/05/2014 17:00 | 1.6 | 12.8 | 2,042.7 | 1.2 | 8.20 | 1 | 1 | 1 |
| 02/05/2014 18:00 | 1.6 | 12.6 | 2,087.6 | 1.1 | 8.40 | 1 | 1 | 1 |
| 02/05/2014 19:00 | 1.7 | 11.9 | 2,237.1 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/05/2014 20:00 | 1.7 | 11.9 | 2,256.9 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/05/2014 21:00 | 1.7 | 11.9 | 2,258.5 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/05/2014 22:00 | 1.7 | 11.9 | 2,260.5 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/05/2014 23:00 | 1.7 | 11.9 | 2,260.5 | 1.1 | 9.00 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.5 | 12.7 | 2,020.0 | 1.1 | 190.40 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.1 | 11.9 | 1,351.7 | 0.8 | 4.10 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.8 | 2,276.8 | 1.2 | 9.10 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/06/2014 00:00 | 1.7 | 12.0 | 2,221.8 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/06/2014 01:00 | 1.5 | 13.0 | 1,976.1 | 1.1 | 7.90 | 1 | 1 | 1 |
| 02/06/2014 02:00 | 1.5 | 13.1 | 1,868.8 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/06/2014 03:00 | 1.5 | 13.1 | 1,869.3 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/06/2014 04:00 | 1.5 | 13.1 | 1,873.7 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/06/2014 05:00 | 1.5 | 13.1 | 1,873.9 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/06/2014 06:00 | 1.5 | 13.1 | 1,882.7 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/06/2014 07:00 | 1.5 | 13.2 | 1,904.9 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/06/2014 08:00 | 1.3 | 13.1 | 1,959.9 | 1.0 | 7.80 | 1 | 1 | 1 |
| 02/06/2014 09:00 | 1.5 | 13.2 | 1,929.3 | 1.1 | 7.70 | 1 | 1 | 1 |
| 02/06/2014 10:00 | 1.5 | 13.2 | 1,887.2 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/06/2014 11:00 | 1.4 | 13.2 | 1,875.3 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/06/2014 12:00 | 1.5 | 13.2 | 1,862.9 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/06/2014 13:00 | 1.3 | 13.2 | 1,869.6 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/06/2014 14:00 | 1.3 | 13.2 | 1,867.9 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/06/2014 15:00 | 1.4 | 13.2 | 1,902.4 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/06/2014 16:00 | 1.4 | 13.2 | 1,868.7 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/06/2014 17:00 | 1.4 | 13.2 | 1,916.9 | 1.1 | 7.70 | 1 | 1 | 1 |
| 02/06/2014 18:00 | 1.4 | 13.3 | 1,900.5 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/06/2014 19:00 | 1.3 | 13.2 | 1,945.5 | 1.0 | 7.80 | 1 | 1 | 1 |
| 02/06/2014 20:00 | 1.4 | 13.2 | 1,895.1 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/06/2014 21:00 | 1.4 | 13.2 | 1,881.5 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/06/2014 22:00 | 1.4 | 13.2 | 1,882.3 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/06/2014 23:00 | 1.4 | 13.2 | 1,882.8 | 1.1 | 7.50 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.4 | 13.1 | 1,908.3 | 1.1 | 183.20 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.3 | 12.0 | 1,862.9 | 1.0 | 7.50 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.3 | 2,221.8 | 1.1 | 8.90 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/07/2014 00:00 | 1.4 | 13.2 | 1,882.5 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/07/2014 01:00 | 1.5 | 12.9 | 2,024.1 | 1.1 | 8.10 | 1 | 1 | 1 |
| 02/07/2014 02:00 | 1.6 | 12.6 | 2,081.3 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/07/2014 03:00 | 1.5 | 12.7 | 2,077.5 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/07/2014 04:00 | 1.7 | 12.0 | 2,210.5 | 1.1 | 8.80 | 1 | 1 | 1 |
| 02/07/2014 05:00 | 1.7 | 12.0 | 2,217.4 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/07/2014 06:00 | 1.8 | 11.8 | 2,250.8 | 1.2 | 9.00 | 1 | 1 | 1 |
| 02/07/2014 07:00 | 1.7 | 11.8 | 2,265.4 | 1.1 | 9.10 | 1 | 1 | 1 |
| 02/07/2014 08:00 | 1.8 | 11.8 | 2,275.1 | 1.2 | 9.10 | 1 | 1 | 1 |
| 02/07/2014 09:00 | 1.6 | 12.2 | 2,174.2 | 1.1 | 8.70 | 1 | 1 | 1 |
| 02/07/2014 10:00 | 1.5 | 12.7 | 2,056.8 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/07/2014 11:00 | 1.5 | 12.7 | 2,056.8 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/07/2014 12:00 | 1.5 | 12.6 | 2,080.8 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/07/2014 13:00 | 1.5 | 12.7 | 2,035.6 | 1.1 | 8.10 | 1 | 1 | 1 |
| 02/07/2014 14:00 | 1.5 | 12.9 | 1,965.1 | 1.1 | 7.90 | 1 | 1 | 1 |
| 02/07/2014 15:00 | 1.4 | 13.2 | 1,881.0 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/07/2014 16:00 | 1.5 | 12.8 | 2,032.9 | 1.1 | 8.10 | 1 | 1 | 1 |
| 02/07/2014 17:00 | 1.5 | 12.7 | 2,037.2 | 1.1 | 8.10 | 1 | 1 | 1 |
| 02/07/2014 18:00 | 1.5 | 12.5 | 2,090.4 | 1.1 | 8.40 | 1 | 1 | 1 |
| 02/07/2014 19:00 | 1.8 | 11.9 | 2,228.9 | 1.2 | 8.90 | 1 | 1 | 1 |
| 02/07/2014 20:00 | 1.5 | 12.5 | 2,068.1 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/07/2014 21:00 | 1.4 | 12.6 | 2,062.8 | 1.0 | 8.30 | 1 | 1 | 1 |
| 02/07/2014 22:00 | 1.5 | 12.6 | 2,064.2 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/07/2014 23:00 | 1.5 | 12.6 | 2,069.9 | 1.1 | 8.30 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.6 | 12.5 | 2,091.2 | 1.1 | 200.70 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.4 | 11.8 | 1,881.0 | 1.0 | 7.50 | 1 | 1 | 1 |
| **Maximum:** | 1.8 | 13.2 | 2,275.1 | 1.2 | 9.10 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/08/2014 00:00 | 1.5 | 13.0 | 1,964.4 | 1.1 | 7.90 | 1 | 1 | 1 |
| 02/08/2014 01:00 | 1.5 | 13.1 | 1,947.6 | 1.1 | 7.80 | 1 | 1 | 1 |
| 02/08/2014 02:00 | 1.4 | 13.3 | 1,906.6 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/08/2014 03:00 | 1.4 | 13.3 | 1,897.2 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/08/2014 04:00 | 1.4 | 13.9 | 1,904.3 | 1.2 | 7.60 | 1 | 1 | 1 |
| 02/08/2014 05:00 | 1.4 | 13.3 | 1,903.8 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/08/2014 06:00 | 1.3 | 13.4 | 1,886.9 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/08/2014 07:00 | 1.4 | 13.2 | 1,921.9 | 1.1 | 7.70 | 1 | 1 | 1 |
| 02/08/2014 08:00 | 1.4 | 13.2 | 1,873.5 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/08/2014 09:00 | 1.3 | 13.3 | 1,842.4 | 1.0 | 7.40 | 1 | 1 | 1 |
| 02/08/2014 10:00 | 1.3 | 13.1 | 1,865.4 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/08/2014 11:00 | 1.3 | 13.2 | 1,869.0 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/08/2014 12:00 | 1.3 | 13.2 | 1,872.6 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/08/2014 13:00 | 1.3 | 13.1 | 1,904.2 | 1.0 | 7.60 | 1 | 1 | 1 |
| 02/08/2014 14:00 | 1.3 | 13.2 | 1,863.2 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/08/2014 15:00 | 1.3 | 13.2 | 1,865.2 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/08/2014 16:00 | 1.3 | 13.2 | 1,866.2 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/08/2014 17:00 | 1.3 | 13.2 | 1,875.1 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/08/2014 18:00 | 1.4 | 12.9 | 1,974.8 | 1.0 | 7.90 | 1 | 1 | 1 |
| 02/08/2014 19:00 | 1.7 | 12.0 | 2,158.2 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/08/2014 20:00 | 1.5 | 12.5 | 2,067.6 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/08/2014 21:00 | 1.6 | 12.3 | 2,094.9 | 1.1 | 8.40 | 1 | 1 | 1 |
| 02/08/2014 22:00 | 1.2 | 13.0 | 1,929.5 | 0.9 | 5.80 | 1 | 1 | 1 |
| 02/08/2014 23:00 | 1.2 | 13.4 | 1,845.1 | 0.9 | 5.50 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.4 | 13.1 | 1,920.8 | 1.0 | 180.80 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.2 | 12.0 | 1,842.4 | 0.9 | 5.50 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.9 | 2,158.2 | 1.2 | 8.60 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/09/2014 00:00 | 1.1 | 13.5 | 1,839.1 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/09/2014 01:00 | 1.5 | 13.0 | 1,940.7 | 1.1 | 7.80 | 1 | 1 | 1 |
| 02/09/2014 02:00 | 1.2 | 13.4 | 1,853.5 | 0.9 | 5.60 | 1 | 1 | 1 |
| 02/09/2014 03:00 | 1.2 | 13.5 | 1,840.4 | 1.0 | 7.40 | 1 | 1 | 1 |
| 02/09/2014 04:00 | 1.2 | 13.5 | 1,839.9 | 1.0 | 7.40 | 1 | 1 | 1 |
| 02/09/2014 05:00 | 1.1 | 13.5 | 1,835.6 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/09/2014 06:00 | 1.2 | 13.4 | 1,849.1 | 0.9 | 5.50 | 1 | 1 | 1 |
| 02/09/2014 07:00 | 1.3 | 13.2 | 1,861.2 | 1.0 | 7.40 | 1 | 1 | 1 |
| 02/09/2014 08:00 | 1.3 | 13.2 | 1,858.6 | 1.0 | 7.40 | 1 | 1 | 1 |
| 02/09/2014 09:00 | 1.3 | 13.2 | 1,862.5 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/09/2014 10:00 | 1.3 | 13.2 | 1,862.4 | 1.0 | 7.40 | 1 | 1 | 1 |
| 02/09/2014 11:00 | 1.3 | 13.2 | 1,853.9 | 1.0 | 7.40 | 1 | 1 | 1 |
| 02/09/2014 12:00 | 1.3 | 13.2 | 1,853.3 | 1.0 | 7.40 | 1 | 1 | 1 |
| 02/09/2014 13:00 | 1.3 | 13.2 | 1,853.5 | 1.0 | 7.40 | 1 | 1 | 1 |
| 02/09/2014 14:00 | 1.2 | 13.2 | 1,856.5 | 0.9 | 5.60 | 1 | 1 | 1 |
| 02/09/2014 15:00 | 1.2 | 13.2 | 1,857.4 | 0.9 | 5.60 | 1 | 1 | 1 |
| 02/09/2014 16:00 | 1.3 | 13.2 | 1,884.8 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/09/2014 17:00 | 1.3 | 13.1 | 1,889.1 | 1.0 | 7.60 | 1 | 1 | 1 |
| 02/09/2014 18:00 | 1.4 | 12.8 | 1,977.9 | 1.0 | 7.90 | 1 | 1 | 1 |
| 02/09/2014 19:00 | 1.7 | 11.6 | 2,238.1 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/09/2014 20:00 | 1.7 | 11.6 | 2,251.3 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/09/2014 21:00 | 1.7 | 11.6 | 2,254.3 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/09/2014 22:00 | 1.7 | 12.0 | 2,148.9 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/09/2014 23:00 | 1.6 | 12.3 | 2,085.8 | 1.1 | 8.30 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.4 | 13.0 | 1,935.3 | 1.0 | 174.70 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.1 | 11.6 | 1,835.6 | 0.9 | 5.50 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.5 | 2,254.3 | 1.1 | 9.00 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/10/2014 00:00 | 1.0 | 13.7 | 1,487.5 | 0.8 | 4.50 | 1 | 1 | 1 |
| 02/10/2014 01:00 | 0.9 | 13.8 | 1,337.8 | 0.7 | 4.00 | 1 | 1 | 0 |
| 02/10/2014 02:00 | 0.9 | 13.8 | 1,369.2 | 0.7 | 4.10 | 1 | 1 | 0 |
| 02/10/2014 03:00 | 0.8 | 13.8 | 1,248.3 | 0.7 | 2.50 | 1 | 1 | 0 |
| 02/10/2014 04:00 | 0.9 | 13.8 | 1,248.4 | 0.7 | 3.70 | 1 | 1 | 0 |
| 02/10/2014 05:00 | 1.0 | 13.7 | 1,429.4 | 0.8 | 4.30 | 1 | 1 | 1 |
| 02/10/2014 06:00 | 1.4 | 13.3 | 1,888.4 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/10/2014 07:00 | 1.5 | 13.1 | 1,930.3 | 1.1 | 7.70 | 1 | 1 | 1 |
| 02/10/2014 08:00 | 1.5 | 12.9 | 2,006.3 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/10/2014 09:00 | 1.4 | 13.2 | 1,908.2 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/10/2014 10:00 | 1.4 | 13.1 | 1,903.6 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/10/2014 11:00 | 1.4 | 13.2 | 1,877.4 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/10/2014 12:00 | 1.4 | 13.2 | 1,875.5 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/10/2014 13:00 | 1.3 | 13.2 | 1,876.7 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/10/2014 14:00 | 1.3 | 13.2 | 1,869.1 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/10/2014 15:00 | 1.3 | 13.2 | 1,872.7 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/10/2014 16:00 | 1.3 | 13.2 | 1,873.6 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/10/2014 17:00 | 1.3 | 13.2 | 1,872.8 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/10/2014 18:00 | 1.4 | 13.1 | 1,916.5 | 1.1 | 7.70 | 1 | 1 | 1 |
| 02/10/2014 19:00 | 1.5 | 12.6 | 2,038.8 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/10/2014 20:00 | 1.6 | 12.6 | 2,051.2 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/10/2014 21:00 | 1.7 | 12.2 | 2,137.8 | 1.2 | 8.60 | 1 | 1 | 1 |
| 02/10/2014 22:00 | 1.6 | 12.8 | 2,009.1 | 1.2 | 8.00 | 1 | 1 | 1 |
| 02/10/2014 23:00 | 1.2 | 13.4 | 1,863.4 | 0.9 | 5.60 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.3 | 13.2 | 1,787.2 | 1.0 | 160.40 # | 24 # | 24 # | 20 # |
| **Minimum:** | 0.8 | 12.2 | 1,248.3 | 0.7 | 2.50 | 1 | 1 | 0 |
| **Maximum:** | 1.7 | 13.8 | 2,137.8 | 1.2 | 8.60 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/11/2014 00:00 | 1.3 | 13.3 | 1,870.1 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/11/2014 01:00 | 1.3 | 13.2 | 1,857.0 | 1.0 | 7.40 | 1 | 1 | 1 |
| 02/11/2014 02:00 | 1.4 | 13.2 | 1,875.5 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/11/2014 03:00 | 1.1 | 13.4 | 1,603.0 | 0.9 | 4.80 | 1 | 1 | 1 |
| 02/11/2014 04:00 | 1.0 | 13.9 | 1,250.9 | 0.8 | 3.80 | 1 | 1 | 0 |
| 02/11/2014 05:00 | 1.0 | 13.8 | 1,513.4 | 0.8 | 4.50 | 1 | 1 | 1 |
| 02/11/2014 06:00 | 1.4 | 13.1 | 1,862.5 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/11/2014 07:00 | 1.4 | 13.1 | 1,876.7 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/11/2014 08:00 | 1.6 | 12.7 | 2,064.3 | 1.2 | 8.30 | 1 | 1 | 1 |
| 02/11/2014 09:00 | 1.6 | 12.8 | 2,028.3 | 1.2 | 8.10 | 1 | 1 | 1 |
| 02/11/2014 10:00 | 1.5 | 13.1 | 1,916.4 | 1.1 | 7.70 | 1 | 1 | 1 |
| 02/11/2014 11:00 | 1.5 | 13.2 | 1,876.1 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/11/2014 12:00 | 1.4 | 13.2 | 1,876.2 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/11/2014 13:00 | 1.4 | 13.3 | 1,875.3 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/11/2014 14:00 | 1.4 | 13.3 | 1,876.5 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/11/2014 15:00 | 1.4 | 13.3 | 1,877.5 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/11/2014 16:00 | 1.4 | 13.3 | 1,867.6 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/11/2014 17:00 | 1.4 | 13.3 | 1,875.3 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/11/2014 18:00 | 1.4 | 13.2 | 1,910.0 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/11/2014 19:00 | 1.6 | 12.6 | 2,039.1 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/11/2014 20:00 | 1.6 | 12.7 | 2,047.2 | 1.2 | 8.20 | 1 | 1 | 1 |
| 02/11/2014 21:00 | 1.6 | 12.3 | 2,127.2 | 1.1 | 8.50 | 1 | 1 | 1 |
| 02/11/2014 22:00 | 1.6 | 12.7 | 2,021.8 | 1.2 | 8.10 | 1 | 1 | 1 |
| 02/11/2014 23:00 | 1.5 | 13.0 | 1,953.8 | 1.1 | 7.80 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.4 | 13.1 | 1,872.6 | 1.1 | 175.50 # | 24 # | 24 # | 23 # |
| **Minimum:** | 1.0 | 12.3 | 1,250.9 | 0.8 | 3.80 | 1 | 1 | 0 |
| **Maximum:** | 1.6 | 13.9 | 2,127.2 | 1.2 | 8.50 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/12/2014 00:00 | 1.4 | 13.2 | 1,893.3 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/12/2014 01:00 | 1.5 | 12.9 | 2,007.0 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/12/2014 02:00 | 1.5 | 12.9 | 2,009.8 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/12/2014 03:00 | 1.5 | 12.9 | 2,016.0 | 1.1 | 8.10 | 1 | 1 | 1 |
| 02/12/2014 04:00 | 1.5 | 12.8 | 2,027.2 | 1.1 | 8.10 | 1 | 1 | 1 |
| 02/12/2014 05:00 | 1.5 | 12.8 | 2,024.2 | 1.1 | 8.10 | 1 | 1 | 1 |
| 02/12/2014 06:00 | 1.3 | 12.9 | 1,986.7 | 1.0 | 7.90 | 1 | 1 | 1 |
| 02/12/2014 07:00 | 1.6 | 12.6 | 2,074.5 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/12/2014 08:00 | 1.5 | 12.7 | 2,060.1 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/12/2014 09:00 | 1.4 | 13.1 | 1,916.5 | 1.1 | 7.70 | 1 | 1 | 1 |
| 02/12/2014 10:00 | 1.5 | 13.1 | 1,868.8 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/12/2014 11:00 | 1.4 | 13.1 | 1,872.0 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/12/2014 12:00 | 1.4 | 13.2 | 1,874.3 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/12/2014 13:00 | 1.4 | 13.2 | 1,872.5 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/12/2014 14:00 | 1.3 | 13.2 | 1,870.9 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/12/2014 15:00 | 1.3 | 13.2 | 1,870.9 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/12/2014 16:00 | 1.3 | 13.2 | 1,870.3 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/12/2014 17:00 | 1.3 | 13.2 | 1,887.0 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/12/2014 18:00 | 1.6 | 12.5 | 2,068.2 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/12/2014 19:00 | 1.7 | 11.6 | 2,281.8 | 1.1 | 9.10 | 1 | 1 | 1 |
| 02/12/2014 20:00 | 1.7 | 11.5 | 2,303.9 | 1.1 | 9.20 | 1 | 1 | 1 |
| 02/12/2014 21:00 | 1.7 | 11.6 | 2,268.1 | 1.1 | 9.10 | 1 | 1 | 1 |
| 02/12/2014 22:00 | 1.7 | 12.1 | 2,176.1 | 1.1 | 8.70 | 1 | 1 | 1 |
| 02/12/2014 23:00 | 1.4 | 12.7 | 2,024.7 | 1.0 | 8.10 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.5 | 12.8 | 2,005.2 | 1.1 | 192.50 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.3 | 11.5 | 1,868.8 | 1.0 | 7.50 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.2 | 2,303.9 | 1.1 | 9.20 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/13/2014 00:00 | 1.2 | 13.1 | 1,905.0 | 0.9 | 5.70 | 1 | 1 | 1 |
| 02/13/2014 01:00 | 1.2 | 13.2 | 1,872.5 | 0.9 | 5.60 | 1 | 1 | 1 |
| 02/13/2014 02:00 | 1.2 | 13.1 | 1,865.1 | 0.9 | 5.60 | 1 | 1 | 1 |
| 02/13/2014 03:00 | 1.2 | 13.1 | 1,865.3 | 0.9 | 5.60 | 1 | 1 | 1 |
| 02/13/2014 04:00 | 1.2 | 13.1 | 1,863.5 | 0.9 | 5.60 | 1 | 1 | 1 |
| 02/13/2014 05:00 | 1.3 | 13.1 | 1,881.9 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/13/2014 06:00 | 1.5 | 13.0 | 1,932.6 | 1.1 | 7.70 | 1 | 1 | 1 |
| 02/13/2014 07:00 | 1.5 | 12.4 | 2,113.6 | 1.0 | 8.50 | 1 | 1 | 1 |
| 02/13/2014 08:00 | 1.7 | 11.8 | 2,236.4 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/13/2014 09:00 | 1.7 | 12.2 | 2,146.8 | 1.2 | 8.60 | 1 | 1 | 1 |
| 02/13/2014 10:00 | 1.7 | 12.3 | 2,125.2 | 1.2 | 8.50 | 1 | 1 | 1 |
| 02/13/2014 11:00 | 1.7 | 12.3 | 2,124.6 | 1.2 | 8.50 | 1 | 1 | 1 |
| 02/13/2014 12:00 | 1.7 | 12.3 | 2,126.0 | 1.2 | 8.50 | 1 | 1 | 1 |
| 02/13/2014 13:00 | 1.7 | 12.2 | 2,124.5 | 1.2 | 8.50 | 1 | 1 | 1 |
| 02/13/2014 14:00 | 1.7 | 12.2 | 2,126.3 | 1.2 | 8.50 | 1 | 1 | 1 |
| 02/13/2014 15:00 | 1.7 | 12.2 | 2,126.0 | 1.2 | 8.50 | 1 | 1 | 1 |
| 02/13/2014 16:00 | 1.7 | 12.2 | 2,127.9 | 1.2 | 8.50 | 1 | 1 | 1 |
| 02/13/2014 17:00 | 1.7 | 12.1 | 2,143.0 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/13/2014 18:00 | 1.7 | 12.1 | 2,134.7 | 1.1 | 8.50 | 1 | 1 | 1 |
| 02/13/2014 19:00 | 1.7 | 11.8 | 2,221.2 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/13/2014 20:00 | 1.7 | 11.5 | 2,273.8 | 1.1 | 9.10 | 1 | 1 | 1 |
| 02/13/2014 21:00 | 1.7 | 11.5 | 2,278.1 | 1.1 | 9.10 | 1 | 1 | 1 |
| 02/13/2014 22:00 | 1.7 | 11.7 | 2,224.2 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/13/2014 23:00 | 1.7 | 11.9 | 2,187.7 | 1.1 | 8.80 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.6 | 12.4 | 2,084.4 | 1.1 | 190.70 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.2 | 11.5 | 1,863.5 | 0.9 | 5.60 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.2 | 2,278.1 | 1.2 | 9.10 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/14/2014 00:00 | 1.5 | 12.5 | 2,042.2 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/14/2014 01:00 | 1.3 | 13.2 | 1,856.8 | 1.0 | 7.40 | 1 | 1 | 1 |
| 02/14/2014 02:00 | 1.4 | 13.2 | 1,879.6 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/14/2014 03:00 | 1.4 | 13.2 | 1,864.0 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/14/2014 04:00 | 1.4 | 13.2 | 1,859.7 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/14/2014 05:00 | 1.4 | 13.2 | 1,861.3 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/14/2014 06:00 | 1.5 | 13.2 | 1,876.3 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/14/2014 07:00 | 1.3 | 13.1 | 1,913.9 | 1.0 | 7.70 | 1 | 1 | 1 |
| 02/14/2014 08:00 | 1.5 | 12.8 | 2,000.6 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/14/2014 09:00 | 1.6 | 12.3 | 2,110.1 | 1.1 | 8.40 | 1 | 1 | 1 |
| 02/14/2014 10:00 | 1.7 | 12.1 | 2,137.9 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/14/2014 11:00 | 1.7 | 12.0 | 2,140.1 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/14/2014 12:00 | 1.7 | 12.0 | 2,142.3 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/14/2014 13:00 | 1.7 | 11.9 | 2,149.2 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/14/2014 14:00 | 1.7 | 11.9 | 2,150.1 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/14/2014 15:00 | 1.7 | 11.9 | 2,155.5 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/14/2014 16:00 | 1.6 | 12.0 | 2,126.5 | 1.1 | 8.50 | 1 | 1 | 1 |
| 02/14/2014 17:00 | 1.7 | 12.0 | 2,145.9 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/14/2014 18:00 | 1.7 | 12.0 | 2,151.4 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/14/2014 19:00 | 1.6 | 12.3 | 2,080.0 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/14/2014 20:00 | 1.6 | 12.4 | 2,059.8 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/14/2014 21:00 | 1.7 | 12.2 | 2,119.4 | 1.2 | 8.50 | 1 | 1 | 1 |
| 02/14/2014 22:00 | 1.7 | 12.1 | 2,136.6 | 1.1 | 8.50 | 1 | 1 | 1 |
| 02/14/2014 23:00 | 1.6 | 12.5 | 2,046.8 | 1.1 | 8.20 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.6 | 12.5 | 2,041.9 | 1.1 | 196.00 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.3 | 11.9 | 1,856.8 | 1.0 | 7.40 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.2 | 2,155.5 | 1.2 | 8.60 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/15/2014 00:00 | 1.5 | 12.6 | 2,025.0 | 1.1 | 8.10 | 1 | 1 | 1 |
| 02/15/2014 01:00 | 1.6 | 12.4 | 2,092.2 | 1.1 | 8.40 | 1 | 1 | 1 |
| 02/15/2014 02:00 | 1.7 | 11.9 | 2,201.5 | 1.1 | 8.80 | 1 | 1 | 1 |
| 02/15/2014 03:00 | 1.7 | 11.8 | 2,220.2 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/15/2014 04:00 | 1.6 | 12.4 | 2,075.8 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/15/2014 05:00 | 1.6 | 12.7 | 2,028.7 | 1.2 | 8.10 | 1 | 1 | 1 |
| 02/15/2014 06:00 | 1.4 | 12.7 | 2,070.0 | 1.0 | 8.30 | 1 | 1 | 1 |
| 02/15/2014 07:00 | 1.4 | 12.8 | 2,004.4 | 1.0 | 8.00 | 1 | 1 | 1 |
| 02/15/2014 08:00 | 1.6 | 12.7 | 2,020.8 | 1.2 | 8.10 | 1 | 1 | 1 |
| 02/15/2014 09:00 | 1.6 | 12.6 | 2,058.5 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/15/2014 10:00 | 1.7 | 12.2 | 2,143.2 | 1.2 | 8.60 | 1 | 1 | 1 |
| 02/15/2014 11:00 | 1.8 | 11.7 | 2,241.6 | 1.2 | 9.00 | 1 | 1 | 1 |
| 02/15/2014 12:00 | 1.7 | 11.6 | 2,245.6 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/15/2014 13:00 | 1.7 | 11.8 | 2,191.8 | 1.1 | 8.80 | 1 | 1 | 1 |
| 02/15/2014 14:00 | 1.6 | 12.5 | 2,042.2 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/15/2014 15:00 | 1.6 | 12.6 | 2,015.1 | 1.1 | 8.10 | 1 | 1 | 1 |
| 02/15/2014 16:00 | 1.6 | 12.7 | 1,981.8 | 1.2 | 7.90 | 1 | 1 | 1 |
| 02/15/2014 17:00 | 1.6 | 12.6 | 2,008.1 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/15/2014 18:00 | 1.6 | 12.3 | 2,084.6 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/15/2014 19:00 | 1.7 | 11.7 | 2,223.0 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/15/2014 20:00 | 1.7 | 11.8 | 2,205.8 | 1.1 | 8.80 | 1 | 1 | 1 |
| 02/15/2014 21:00 | 1.7 | 11.8 | 2,218.5 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/15/2014 22:00 | 1.7 | 12.1 | 2,134.5 | 1.1 | 8.50 | 1 | 1 | 1 |
| 02/15/2014 23:00 | 1.5 | 13.0 | 1,941.7 | 1.1 | 7.80 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.6 | 12.3 | 2,103.1 | 1.1 | 202.00 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.4 | 11.6 | 1,941.7 | 1.0 | 7.80 | 1 | 1 | 1 |
| **Maximum:** | 1.8 | 13.0 | 2,245.6 | 1.2 | 9.00 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/16/2014 00:00 | 1.4 | 13.3 | 1,883.2 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/16/2014 01:00 | 1.5 | 13.3 | 1,891.2 | 1.2 | 7.60 | 1 | 1 | 1 |
| 02/16/2014 02:00 | 1.4 | 13.2 | 1,916.2 | 1.1 | 7.70 | 1 | 1 | 1 |
| 02/16/2014 03:00 | 1.4 | 13.4 | 1,730.0 | 1.1 | 6.90 | 1 | 1 | 1 |
| 02/16/2014 04:00 | 1.2 | 13.9 | 1,277.6 | 1.0 | 5.10 | 1 | 1 | 0 |
| 02/16/2014 05:00 | 1.3 | 13.8 | 1,478.7 | 1.1 | 5.90 | 1 | 1 | 0 |
| 02/16/2014 06:00 | 1.3 | 13.4 | 1,657.8 | 1.0 | 6.60 | 1 | 1 | 1 |
| 02/16/2014 07:00 | 1.5 | 13.0 | 1,985.0 | 1.1 | 7.90 | 1 | 1 | 1 |
| 02/16/2014 08:00 | 1.5 | 13.4 | 1,895.8 | 1.2 | 7.60 | 1 | 1 | 1 |
| 02/16/2014 09:00 | 1.4 | 13.6 | 1,856.3 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/16/2014 10:00 | 1.3 | 13.6 | 1,851.8 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/16/2014 11:00 | 1.5 | 13.6 | 1,849.8 | 1.2 | 7.40 | 1 | 1 | 1 |
| 02/16/2014 12:00 | 1.4 | 13.6 | 1,848.0 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/16/2014 13:00 | 1.5 | 13.6 | 1,836.9 | 1.2 | 7.30 | 1 | 1 | 1 |
| 02/16/2014 14:00 | 1.5 | 13.5 | 1,840.2 | 1.2 | 7.40 | 1 | 1 | 1 |
| 02/16/2014 15:00 | 1.4 | 13.5 | 1,856.6 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/16/2014 16:00 | 1.4 | 13.5 | 1,841.2 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/16/2014 17:00 | 1.4 | 13.5 | 1,844.0 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/16/2014 18:00 | 1.4 | 13.0 | 1,947.4 | 1.0 | 7.80 | 1 | 1 | 1 |
| 02/16/2014 19:00 | 1.7 | 11.9 | 2,221.9 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/16/2014 20:00 | 1.7 | 11.7 | 2,253.2 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/16/2014 21:00 | 1.7 | 11.7 | 2,255.4 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/16/2014 22:00 | 1.7 | 11.7 | 2,255.5 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/16/2014 23:00 | 1.6 | 12.6 | 2,051.1 | 1.1 | 8.20 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.5 | 13.1 | 1,888.5 | 1.1 | 181.20 # | 24 # | 24 # | 22 # |
| **Minimum:** | 1.2 | 11.7 | 1,277.6 | 1.0 | 5.10 | 1 | 1 | 0 |
| **Maximum:** | 1.7 | 13.9 | 2,255.5 | 1.2 | 9.00 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/17/2014 00:00 | 1.5 | 13.2 | 1,891.1 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/17/2014 01:00 | 1.5 | 13.2 | 1,877.8 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/17/2014 02:00 | 1.4 | 13.4 | 1,769.9 | 1.1 | 7.10 | 1 | 1 | 1 |
| 02/17/2014 03:00 | 1.3 | 13.9 | 1,300.1 | 1.1 | 5.20 | 1 | 1 | 0 |
| 02/17/2014 04:00 | 1.3 | 13.8 | 1,374.2 | 1.1 | 5.50 | 1 | 1 | 0 |
| 02/17/2014 05:00 | 1.2 | 13.9 | 1,555.7 | 1.0 | 6.20 | 1 | 1 | 1 |
| 02/17/2014 06:00 | 1.2 | 13.8 | 1,826.7 | 1.0 | 7.30 | 1 | 1 | 1 |
| 02/17/2014 07:00 | 1.2 | 13.8 | 1,832.0 | 1.0 | 7.30 | 1 | 1 | 0 |
| 02/17/2014 08:00 | 1.2 | 13.8 | 1,805.0 | 1.0 | 7.20 | 1 | 1 | 1 |
| 02/17/2014 09:00 | 1.2 | 13.9 | 1,768.2 | 1.0 | 7.10 | 1 | 1 | 1 |
| 02/17/2014 10:00 | 1.5 | 13.2 | 1,867.8 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/17/2014 11:00 | 1.5 | 13.2 | 1,865.9 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/17/2014 12:00 | 1.4 | 13.2 | 1,864.2 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/17/2014 13:00 | 1.4 | 13.3 | 1,860.9 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/17/2014 14:00 | 1.5 | 13.3 | 1,863.1 | 1.2 | 7.50 | 1 | 1 | 1 |
| 02/17/2014 15:00 | 1.5 | 13.3 | 1,869.3 | 1.2 | 7.50 | 1 | 1 | 1 |
| 02/17/2014 16:00 | 1.5 | 13.3 | 1,864.6 | 1.2 | 7.50 | 1 | 1 | 1 |
| 02/17/2014 17:00 | 1.5 | 13.3 | 1,863.4 | 1.2 | 7.50 | 1 | 1 | 1 |
| 02/17/2014 18:00 | 1.5 | 13.3 | 1,889.0 | 1.2 | 7.60 | 1 | 1 | 1 |
| 02/17/2014 19:00 | 1.4 | 13.2 | 1,927.2 | 1.1 | 7.70 | 1 | 1 | 1 |
| 02/17/2014 20:00 | 1.6 | 12.5 | 2,085.2 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/17/2014 21:00 | 1.6 | 11.9 | 2,210.1 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/17/2014 22:00 | 1.6 | 12.7 | 2,054.3 | 1.2 | 8.20 | 1 | 1 | 1 |
| 02/17/2014 23:00 | 1.5 | 13.1 | 1,920.8 | 1.1 | 7.70 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.4 | 13.3 | 1,833.6 | 1.1 | 176.20 # | 24 # | 24 # | 21 # |
| **Minimum:** | 1.2 | 11.9 | 1,300.1 | 1.0 | 5.20 | 1 | 1 | 0 |
| **Maximum:** | 1.6 | 13.9 | 2,210.1 | 1.2 | 8.80 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/18/2014 00:00 | 1.5 | 13.2 | 1,872.7 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/18/2014 01:00 | 1.5 | 13.2 | 1,870.4 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/18/2014 02:00 | 1.4 | 13.2 | 1,866.6 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/18/2014 03:00 | 1.5 | 13.2 | 1,867.1 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/18/2014 04:00 | 1.4 | 13.2 | 1,866.2 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/18/2014 05:00 | 1.4 | 13.2 | 1,866.6 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/18/2014 06:00 | 1.2 | 13.1 | 1,902.9 | 0.9 | 5.70 | 1 | 1 | 1 |
| 02/18/2014 07:00 | 1.6 | 12.7 | 2,058.6 | 1.2 | 8.20 | 1 | 1 | 1 |
| 02/18/2014 08:00 | 1.6 | 12.3 | 2,130.3 | 1.1 | 8.50 | 1 | 1 | 1 |
| 02/18/2014 09:00 | 1.5 | 12.9 | 1,990.3 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/18/2014 10:00 | 1.5 | 12.9 | 1,988.6 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/18/2014 11:00 | 1.6 | 12.7 | 2,033.7 | 1.2 | 8.10 | 1 | 1 | 1 |
| 02/18/2014 12:00 | 1.5 | 12.4 | 2,074.4 | 1.0 | 8.30 | 1 | 1 | 1 |
| 02/18/2014 13:00 | 1.6 | 12.8 | 1,987.1 | 1.2 | 7.90 | 1 | 1 | 1 |
| 02/18/2014 14:00 | 1.5 | 13.2 | 1,862.2 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/18/2014 15:00 | 1.3 | 13.2 | 1,882.1 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/18/2014 16:00 | 1.5 | 13.3 | 1,837.2 | 1.2 | 7.30 | 1 | 1 | 1 |
| 02/18/2014 17:00 | 1.5 | 12.8 | 1,968.4 | 1.1 | 7.90 | 1 | 1 | 1 |
| 02/18/2014 18:00 | 1.7 | 11.9 | 2,188.5 | 1.1 | 8.80 | 1 | 1 | 1 |
| 02/18/2014 19:00 | 1.7 | 11.6 | 2,243.4 | 1.1 | 9.00 | 1 | 1 | 1 |
| 02/18/2014 20:00 | 1.6 | 12.5 | 2,075.4 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/18/2014 21:00 | 1.7 | 11.8 | 2,209.1 | 1.1 | 8.80 | 1 | 1 | 1 |
| 02/18/2014 22:00 | 1.5 | 13.1 | 1,918.6 | 1.1 | 7.70 | 1 | 1 | 1 |
| 02/18/2014 23:00 | 1.2 | 13.7 | 1,565.3 | 1.0 | 6.30 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.5 | 12.8 | 1,963.6 | 1.1 | 186.70 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.2 | 11.6 | 1,565.3 | 0.9 | 5.70 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.7 | 2,243.4 | 1.2 | 9.00 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/19/2014 00:00 | 1.0 | 13.9 | 1,241.6 | 0.8 | 3.70 | 1 | 1 | 0 |
| 02/19/2014 01:00 | 1.2 | 13.9 | 1,402.1 | 1.0 | 5.60 | 1 | 1 | 0 |
| 02/19/2014 02:00 | 7.3 | 15.8 | 600.1 | 8.4 | 4.28 | 1 | 0 | 0 |
| 02/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 02/19/2014 17:00 | 38.4 | 17.2 | 530.6 | 61.2 | 92.32 | 1 | 0 | 0 |
| 02/19/2014 18:00 | 13.6 | 14.1 | 1,477.2 | 11.8 | 63.50 | 1 | 0 | 1 |
| 02/19/2014 19:00 | 1.4 | 13.1 | 1,956.2 | 1.1 | 7.80 | 1 | 1 | 1 |
| 02/19/2014 20:00 | 1.7 | 11.9 | 2,225.4 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/19/2014 21:00 | 1.7 | 11.6 | 2,280.7 | 1.1 | 9.10 | 1 | 1 | 1 |
| 02/19/2014 22:00 | 1.5 | 12.1 | 2,180.2 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/19/2014 23:00 | 1.4 | 13.4 | 1,892.3 | 1.1 | 7.60 | 1 | 1 | 1 |
| **Average/Sum#:** | 6.9 | 13.7 | 1,578.6 | 8.9 | 211.50 # | 10 # | 7 # | 6 # |
| **Minimum:** | 1.0 | 11.6 | 530.6 | 0.8 | 3.70 | 0 | 0 | 0 |
| **Maximum:** | 38.4 | 17.2 | 2,280.7 | 61.2 | 92.32 | 1 | 1 | 1 |
| **%SI** | 58.3 | 58.3 | 58.3 | 58.3 | 58.33 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/20/2014 00:00 | 1.4 | 13.6 | 1,844.0 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/20/2014 01:00 | 1.2 | 13.9 | 1,268.8 | 1.0 | 5.10 | 1 | 1 | 0 |
| 02/20/2014 02:00 | 1.2 | 13.9 | 1,243.8 | 1.0 | 5.00 | 1 | 1 | 0 |
| 02/20/2014 03:00 | 1.2 | 13.9 | 1,243.0 | 1.0 | 5.00 | 1 | 1 | 0 |
| 02/20/2014 04:00 | 1.3 | 13.9 | 1,258.6 | 1.1 | 5.00 | 1 | 1 | 0 |
| 02/20/2014 05:00 | 1.3 | 13.9 | 1,310.8 | 1.1 | 5.20 | 1 | 1 | 0 |
| 02/20/2014 06:00 | 1.4 | 12.7 | 1,890.1 | 1.0 | 7.60 | 1 | 1 | 1 |
| 02/20/2014 07:00 | 1.6 | 12.6 | 2,083.6 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/20/2014 08:00 | 1.5 | 12.4 | 2,113.6 | 1.0 | 8.50 | 1 | 1 | 1 |
| 02/20/2014 09:00 | 1.5 | 13.1 | 1,901.1 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/20/2014 10:00 | 1.5 | 13.2 | 1,858.4 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/20/2014 11:00 | 1.5 | 13.2 | 1,855.8 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/20/2014 12:00 | 1.4 | 13.3 | 1,857.0 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/20/2014 13:00 | 1.5 | 12.9 | 1,963.7 | 1.1 | 7.90 | 1 | 1 | 1 |
| 02/20/2014 14:00 | 1.4 | 13.3 | 1,868.9 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/20/2014 15:00 | 1.4 | 12.9 | 1,956.9 | 1.0 | 7.80 | 1 | 1 | 1 |
| 02/20/2014 16:00 | 1.6 | 12.2 | 2,094.5 | 1.1 | 8.40 | 1 | 1 | 1 |
| 02/20/2014 17:00 | 1.6 | 11.7 | 2,195.1 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/20/2014 18:00 | 1.6 | 12.0 | 2,138.7 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/20/2014 19:00 | 1.6 | 11.8 | 2,202.0 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/20/2014 20:00 | 1.7 | 11.7 | 2,217.6 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/20/2014 21:00 | 1.6 | 11.8 | 2,208.8 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/20/2014 22:00 | 1.6 | 11.7 | 2,214.3 | 1.0 | 8.90 | 1 | 1 | 1 |
| 02/20/2014 23:00 | 1.6 | 12.0 | 2,169.5 | 1.1 | 8.70 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.5 | 12.8 | 1,873.3 | 1.1 | 180.00 # | 24 # | 24 # | 19 # |
| **Minimum:** | 1.2 | 11.7 | 1,243.0 | 1.0 | 5.00 | 1 | 1 | 0 |
| **Maximum:** | 1.7 | 13.9 | 2,217.6 | 1.1 | 8.90 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/21/2014 00:00 | 1.6 | 12.5 | 2,056.4 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/21/2014 01:00 | 1.4 | 13.4 | 1,882.1 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/21/2014 02:00 | 1.4 | 13.6 | 1,840.0 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/21/2014 03:00 | 1.4 | 13.6 | 1,842.0 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/21/2014 04:00 | 1.4 | 13.6 | 1,841.4 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/21/2014 05:00 | 1.4 | 13.6 | 1,841.8 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/21/2014 06:00 | 1.2 | 13.5 | 1,860.0 | 1.0 | 7.40 | 1 | 1 | 1 |
| 02/21/2014 07:00 | 1.6 | 12.9 | 2,004.0 | 1.2 | 8.00 | 1 | 1 | 1 |
| 02/21/2014 08:00 | 1.6 | 12.0 | 2,171.1 | 1.1 | 8.70 | 1 | 1 | 1 |
| 02/21/2014 09:00 | 1.5 | 13.1 | 1,941.2 | 1.1 | 7.80 | 1 | 1 | 1 |
| 02/21/2014 10:00 | 1.4 | 13.5 | 1,845.1 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/21/2014 11:00 | 1.3 | 13.4 | 1,860.3 | 1.0 | 7.40 | 1 | 1 | 1 |
| 02/21/2014 12:00 | 1.4 | 13.4 | 1,848.8 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/21/2014 13:00 | 1.4 | 13.4 | 1,844.5 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/21/2014 14:00 | 1.5 | 13.4 | 1,840.1 | 1.2 | 7.40 | 1 | 1 | 1 |
| 02/21/2014 15:00 | 1.4 | 13.4 | 1,834.4 | 1.1 | 7.30 | 1 | 1 | 1 |
| 02/21/2014 16:00 | 1.5 | 13.4 | 1,830.0 | 1.2 | 7.30 | 1 | 1 | 1 |
| 02/21/2014 17:00 | 1.5 | 13.3 | 1,843.8 | 1.2 | 7.40 | 1 | 1 | 1 |
| 02/21/2014 18:00 | 1.6 | 12.6 | 1,997.1 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/21/2014 19:00 | 1.6 | 12.2 | 2,101.2 | 1.1 | 8.40 | 1 | 1 | 1 |
| 02/21/2014 20:00 | 1.6 | 12.1 | 2,125.6 | 1.1 | 8.50 | 1 | 1 | 1 |
| 02/21/2014 21:00 | 1.7 | 11.9 | 2,176.4 | 1.1 | 8.70 | 1 | 1 | 1 |
| 02/21/2014 22:00 | 1.6 | 12.1 | 2,116.5 | 1.1 | 8.50 | 1 | 1 | 1 |
| 02/21/2014 23:00 | 1.6 | 12.4 | 2,063.0 | 1.1 | 8.30 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.5 | 13.0 | 1,942.0 | 1.1 | 186.60 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.2 | 11.9 | 1,830.0 | 1.0 | 7.30 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.6 | 2,176.4 | 1.2 | 8.70 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/22/2014 00:00 | 1.6 | 12.5 | 2,043.8 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/22/2014 01:00 | 1.5 | 12.7 | 1,999.6 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/22/2014 02:00 | 1.5 | 13.2 | 1,866.1 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/22/2014 03:00 | 1.5 | 12.8 | 1,980.5 | 1.1 | 7.90 | 1 | 1 | 1 |
| 02/22/2014 04:00 | 1.5 | 12.7 | 2,001.3 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/22/2014 05:00 | 1.4 | 13.1 | 1,934.3 | 1.1 | 7.70 | 1 | 1 | 1 |
| 02/22/2014 06:00 | 1.5 | 12.7 | 2,027.0 | 1.1 | 8.10 | 1 | 1 | 1 |
| 02/22/2014 07:00 | 1.6 | 12.7 | 2,034.0 | 1.2 | 8.10 | 1 | 1 | 1 |
| 02/22/2014 08:00 | 1.6 | 12.8 | 2,013.3 | 1.2 | 8.10 | 1 | 1 | 1 |
| 02/22/2014 09:00 | 1.5 | 13.2 | 1,897.6 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/22/2014 10:00 | 1.5 | 13.3 | 1,873.2 | 1.2 | 7.50 | 1 | 1 | 1 |
| 02/22/2014 11:00 | 1.5 | 13.3 | 1,872.0 | 1.2 | 7.50 | 1 | 1 | 1 |
| 02/22/2014 12:00 | 1.4 | 13.2 | 1,877.7 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/22/2014 13:00 | 1.4 | 13.2 | 1,866.5 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/22/2014 14:00 | 1.5 | 12.9 | 1,945.8 | 1.1 | 7.80 | 1 | 1 | 1 |
| 02/22/2014 15:00 | 1.5 | 12.6 | 1,981.2 | 1.1 | 7.90 | 1 | 1 | 1 |
| 02/22/2014 16:00 | 1.5 | 13.0 | 1,895.9 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/22/2014 17:00 | 1.5 | 12.5 | 1,994.2 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/22/2014 18:00 | 1.6 | 12.3 | 2,040.8 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/22/2014 19:00 | 1.6 | 12.2 | 2,063.5 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/22/2014 20:00 | 1.6 | 11.8 | 2,165.5 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/22/2014 21:00 | 1.7 | 11.7 | 2,184.5 | 1.1 | 8.70 | 1 | 1 | 1 |
| 02/22/2014 22:00 | 1.6 | 11.7 | 2,189.5 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/22/2014 23:00 | 1.6 | 11.7 | 2,200.0 | 1.0 | 8.80 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.5 | 12.7 | 1,997.8 | 1.1 | 192.00 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.4 | 11.7 | 1,866.1 | 1.0 | 7.50 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.3 | 2,200.0 | 1.2 | 8.80 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/23/2014 00:00 | 1.6 | 12.0 | 2,187.7 | 1.1 | 8.80 | 1 | 1 | 1 |
| 02/23/2014 01:00 | 1.6 | 12.2 | 2,134.1 | 1.1 | 8.50 | 1 | 1 | 1 |
| 02/23/2014 02:00 | 1.6 | 11.9 | 2,200.1 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/23/2014 03:00 | 1.6 | 11.8 | 2,210.6 | 1.0 | 8.80 | 1 | 1 | 1 |
| 02/23/2014 04:00 | 1.6 | 12.3 | 2,112.2 | 1.1 | 8.40 | 1 | 1 | 1 |
| 02/23/2014 05:00 | 1.6 | 12.7 | 2,025.2 | 1.2 | 8.10 | 1 | 1 | 1 |
| 02/23/2014 06:00 | 1.5 | 12.6 | 2,038.4 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/23/2014 07:00 | 1.5 | 12.8 | 2,003.3 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/23/2014 08:00 | 1.5 | 12.9 | 1,987.5 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/23/2014 09:00 | 1.5 | 13.0 | 1,971.1 | 1.1 | 7.90 | 1 | 1 | 1 |
| 02/23/2014 10:00 | 1.4 | 13.4 | 1,851.2 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/23/2014 11:00 | 1.4 | 13.2 | 1,891.1 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/23/2014 12:00 | 1.5 | 13.1 | 1,914.6 | 1.1 | 7.70 | 1 | 1 | 1 |
| 02/23/2014 13:00 | 1.3 | 13.3 | 1,859.9 | 1.0 | 7.40 | 1 | 1 | 1 |
| 02/23/2014 14:00 | 1.3 | 13.3 | 1,854.1 | 1.0 | 7.40 | 1 | 1 | 1 |
| 02/23/2014 15:00 | 1.4 | 13.2 | 1,864.0 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/23/2014 16:00 | 1.4 | 13.0 | 1,885.8 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/23/2014 17:00 | 1.5 | 12.9 | 1,925.3 | 1.1 | 7.70 | 1 | 1 | 1 |
| 02/23/2014 18:00 | 1.6 | 12.2 | 2,077.7 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/23/2014 19:00 | 1.7 | 11.8 | 2,156.8 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/23/2014 20:00 | 1.6 | 11.9 | 2,147.8 | 1.0 | 8.60 | 1 | 1 | 1 |
| 02/23/2014 21:00 | 1.6 | 11.9 | 2,148.3 | 1.0 | 8.60 | 1 | 1 | 1 |
| 02/23/2014 22:00 | 1.7 | 11.9 | 2,149.0 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/23/2014 23:00 | 1.6 | 12.0 | 2,133.0 | 1.1 | 8.50 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.5 | 12.6 | 2,030.4 | 1.1 | 194.90 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.3 | 11.8 | 1,851.2 | 1.0 | 7.40 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.4 | 2,210.6 | 1.2 | 8.80 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/24/2014 00:00 | 1.6 | 12.8 | 1,999.2 | 1.2 | 8.00 | 1 | 1 | 1 |
| 02/24/2014 01:00 | 1.4 | 13.4 | 1,851.7 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/24/2014 02:00 | 1.4 | 13.5 | 1,796.7 | 1.1 | 7.20 | 1 | 1 | 1 |
| 02/24/2014 03:00 | 1.2 | 13.9 | 1,254.6 | 1.0 | 5.00 | 1 | 1 | 0 |
| 02/24/2014 04:00 | 1.2 | 13.9 | 1,230.8 | 1.0 | 4.90 | 1 | 1 | 0 |
| 02/24/2014 05:00 | 1.3 | 13.6 | 1,527.4 | 1.1 | 6.10 | 1 | 1 | 1 |
| 02/24/2014 06:00 | 1.2 | 13.2 | 1,895.6 | 0.9 | 5.70 | 1 | 1 | 1 |
| 02/24/2014 07:00 | 1.5 | 13.0 | 1,952.8 | 1.1 | 7.80 | 1 | 1 | 1 |
| 02/24/2014 08:00 | 1.5 | 12.5 | 2,083.2 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/24/2014 09:00 | 1.5 | 13.1 | 1,941.3 | 1.1 | 7.80 | 1 | 1 | 1 |
| 02/24/2014 10:00 | 1.4 | 13.5 | 1,830.0 | 1.1 | 7.30 | 1 | 1 | 1 |
| 02/24/2014 11:00 | 1.4 | 13.4 | 1,856.1 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/24/2014 12:00 | 1.4 | 13.4 | 1,828.8 | 1.1 | 7.30 | 1 | 1 | 1 |
| 02/24/2014 13:00 | 1.4 | 13.4 | 1,831.0 | 1.1 | 7.30 | 1 | 1 | 1 |
| 02/24/2014 14:00 | 1.5 | 13.3 | 1,825.2 | 1.2 | 7.30 | 1 | 1 | 1 |
| 02/24/2014 15:00 | 1.6 | 12.6 | 1,972.5 | 1.1 | 7.90 | 1 | 1 | 1 |
| 02/24/2014 16:00 | 1.6 | 12.6 | 1,965.9 | 1.1 | 7.90 | 1 | 1 | 1 |
| 02/24/2014 17:00 | 1.6 | 12.3 | 2,039.5 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/24/2014 18:00 | 1.6 | 11.9 | 2,113.2 | 1.0 | 8.50 | 1 | 1 | 1 |
| 02/24/2014 19:00 | 1.6 | 11.7 | 2,174.1 | 1.0 | 8.70 | 1 | 1 | 1 |
| 02/24/2014 20:00 | 1.6 | 11.8 | 2,156.1 | 1.0 | 8.60 | 1 | 1 | 1 |
| 02/24/2014 21:00 | 1.6 | 11.9 | 2,142.8 | 1.0 | 8.60 | 1 | 1 | 1 |
| 02/24/2014 22:00 | 1.6 | 12.0 | 2,144.1 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/24/2014 23:00 | 1.6 | 11.9 | 2,153.7 | 1.0 | 8.60 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.5 | 12.9 | 1,898.6 | 1.1 | 180.40 # | 24 # | 24 # | 22 # |
| **Minimum:** | 1.2 | 11.7 | 1,230.8 | 0.9 | 4.90 | 1 | 1 | 0 |
| **Maximum:** | 1.6 | 13.9 | 2,174.1 | 1.2 | 8.70 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/25/2014 00:00 | 1.6 | 12.6 | 2,039.8 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/25/2014 01:00 | 1.6 | 12.9 | 1,971.1 | 1.2 | 7.90 | 1 | 1 | 1 |
| 02/25/2014 02:00 | 1.4 | 13.3 | 1,851.7 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/25/2014 03:00 | 1.5 | 13.3 | 1,843.8 | 1.2 | 7.40 | 1 | 1 | 1 |
| 02/25/2014 04:00 | 1.5 | 13.3 | 1,846.4 | 1.2 | 7.40 | 1 | 1 | 1 |
| 02/25/2014 05:00 | 1.5 | 12.8 | 1,996.3 | 1.1 | 8.00 | 1 | 1 | 1 |
| 02/25/2014 06:00 | 1.5 | 12.7 | 2,022.4 | 1.1 | 8.10 | 1 | 1 | 1 |
| 02/25/2014 07:00 | 1.5 | 13.0 | 1,953.3 | 1.1 | 7.80 | 1 | 1 | 1 |
| 02/25/2014 08:00 | 1.6 | 12.7 | 2,004.7 | 1.2 | 8.00 | 1 | 1 | 1 |
| 02/25/2014 09:00 | 1.5 | 13.3 | 1,848.2 | 1.2 | 7.40 | 1 | 1 | 1 |
| 02/25/2014 10:00 | 1.5 | 13.4 | 1,835.8 | 1.2 | 7.30 | 1 | 1 | 1 |
| 02/25/2014 11:00 | 1.4 | 13.4 | 1,824.8 | 1.1 | 7.30 | 1 | 1 | 1 |
| 02/25/2014 12:00 | 1.4 | 13.4 | 1,828.1 | 1.1 | 7.30 | 1 | 1 | 1 |
| 02/25/2014 13:00 | 1.4 | 13.4 | 1,841.3 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/25/2014 14:00 | 1.4 | 13.4 | 1,825.4 | 1.1 | 7.30 | 1 | 1 | 1 |
| 02/25/2014 15:00 | 1.4 | 13.4 | 1,828.5 | 1.1 | 7.30 | 1 | 1 | 1 |
| 02/25/2014 16:00 | 1.3 | 13.2 | 1,873.1 | 1.0 | 7.50 | 1 | 1 | 1 |
| 02/25/2014 17:00 | 1.4 | 13.3 | 1,855.4 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/25/2014 18:00 | 1.5 | 12.8 | 1,959.8 | 1.1 | 7.80 | 1 | 1 | 1 |
| 02/25/2014 19:00 | 1.6 | 12.2 | 2,100.0 | 1.1 | 8.40 | 1 | 1 | 1 |
| 02/25/2014 20:00 | 1.7 | 12.0 | 2,129.9 | 1.1 | 8.50 | 1 | 1 | 1 |
| 02/25/2014 21:00 | 1.6 | 12.4 | 2,053.7 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/25/2014 22:00 | 1.5 | 12.9 | 1,949.9 | 1.1 | 7.80 | 1 | 1 | 1 |
| 02/25/2014 23:00 | 1.7 | 12.1 | 2,117.9 | 1.1 | 8.50 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.5 | 13.0 | 1,933.4 | 1.1 | 185.60 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.3 | 12.0 | 1,824.8 | 1.0 | 7.30 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.4 | 2,129.9 | 1.2 | 8.50 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/26/2014 00:00 | 1.6 | 12.9 | 1,941.8 | 1.2 | 7.80 | 1 | 1 | 1 |
| 02/26/2014 01:00 | 1.5 | 13.2 | 1,881.5 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/26/2014 02:00 | 1.5 | 13.2 | 1,868.4 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/26/2014 03:00 | 1.5 | 13.2 | 1,865.7 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/26/2014 04:00 | 1.5 | 13.2 | 1,861.0 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/26/2014 05:00 | 1.5 | 13.1 | 1,900.5 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/26/2014 06:00 | 1.5 | 12.2 | 2,075.7 | 1.0 | 8.30 | 1 | 1 | 1 |
| 02/26/2014 07:00 | 1.7 | 12.1 | 2,156.2 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/26/2014 08:00 | 1.7 | 11.7 | 2,226.5 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/26/2014 09:00 | 1.7 | 11.7 | 2,232.8 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/26/2014 10:00 | 0.0 | 0.0 | 2,238.4 | 0.0 | 0.00 | 1 | 1 | 1 |
| 02/26/2014 11:00 | 0.0 | 0.0 | 2,182.3 | 0.0 | 0.00 | 1 | 1 | 1 |
| 02/26/2014 12:00 | 0.0 | 0.0 | 2,038.6 | 0.0 | 0.00 | 1 | 1 | 1 |
| 02/26/2014 13:00 | 0.0 | 0.0 | 2,172.9 | 0.0 | 0.00 | 1 | 1 | 1 |
| 02/26/2014 14:00 | 1.3 | 12.2 | 2,103.1 | 0.9 | 6.30 | 1 | 1 | 1 |
| 02/26/2014 15:00 | 1.4 | 12.3 | 2,085.7 | 1.0 | 8.30 | 1 | 1 | 1 |
| 02/26/2014 16:00 | 1.6 | 12.6 | 2,026.2 | 1.1 | 8.10 | 1 | 1 | 1 |
| 02/26/2014 17:00 | 1.7 | 12.2 | 2,130.2 | 1.2 | 8.50 | 1 | 1 | 1 |
| 02/26/2014 18:00 | 1.7 | 12.0 | 2,158.7 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/26/2014 19:00 | 1.7 | 11.7 | 2,226.8 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/26/2014 20:00 | 1.7 | 11.7 | 2,213.9 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/26/2014 21:00 | 1.7 | 11.8 | 2,197.6 | 1.1 | 8.80 | 1 | 1 | 1 |
| 02/26/2014 22:00 | 1.7 | 11.8 | 2,178.5 | 1.1 | 8.70 | 1 | 1 | 1 |
| 02/26/2014 23:00 | 1.7 | 12.0 | 2,135.1 | 1.1 | 8.50 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.6 | 12.3 | 2,087.4 | 1.1 | 163.60 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.3 | 11.7 | 1,861.0 | 0.9 | 6.30 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.2 | 2,238.4 | 1.2 | 8.90 | 1 | 1 | 1 |
| **%SI** | 16.7 | 16.7 | 0.0 | 16.7 | 16.67 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/27/2014 00:00 | 1.6 | 12.7 | 2,001.5 | 1.2 | 8.00 | 1 | 1 | 1 |
| 02/27/2014 01:00 | 1.4 | 13.2 | 1,883.6 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/27/2014 02:00 | 1.3 | 13.6 | 1,567.6 | 1.1 | 6.30 | 1 | 1 | 1 |
| 02/27/2014 03:00 | 1.2 | 13.9 | 1,283.7 | 1.0 | 5.10 | 1 | 1 | 0 |
| 02/27/2014 04:00 | 1.2 | 13.8 | 1,567.1 | 1.0 | 6.30 | 1 | 1 | 0 |
| 02/27/2014 05:00 | 1.3 | 13.4 | 1,724.2 | 1.0 | 6.90 | 1 | 1 | 1 |
| 02/27/2014 06:00 | 1.5 | 13.1 | 1,915.1 | 1.1 | 7.70 | 1 | 1 | 1 |
| 02/27/2014 07:00 | 1.4 | 13.3 | 1,888.2 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/27/2014 08:00 | 1.6 | 12.5 | 2,045.3 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/27/2014 09:00 | 1.4 | 13.4 | 1,861.6 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/27/2014 10:00 | 1.3 | 13.5 | 1,847.9 | 1.0 | 7.40 | 1 | 1 | 1 |
| 02/27/2014 11:00 | 1.3 | 13.5 | 1,844.8 | 1.0 | 7.40 | 1 | 1 | 1 |
| 02/27/2014 12:00 | 1.3 | 13.5 | 1,845.7 | 1.0 | 7.40 | 1 | 1 | 1 |
| 02/27/2014 13:00 | 1.4 | 13.4 | 1,848.3 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/27/2014 14:00 | 1.4 | 13.4 | 1,844.9 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/27/2014 15:00 | 1.3 | 13.4 | 1,846.8 | 1.0 | 7.40 | 1 | 1 | 1 |
| 02/27/2014 16:00 | 1.4 | 13.4 | 1,847.7 | 1.1 | 7.40 | 1 | 1 | 1 |
| 02/27/2014 17:00 | 1.4 | 13.2 | 1,908.5 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/27/2014 18:00 | 1.5 | 13.1 | 1,912.8 | 1.1 | 7.70 | 1 | 1 | 1 |
| 02/27/2014 19:00 | 1.6 | 12.4 | 2,082.2 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/27/2014 20:00 | 1.6 | 12.5 | 2,062.4 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/27/2014 21:00 | 1.6 | 12.5 | 2,070.2 | 1.1 | 8.30 | 1 | 1 | 1 |
| 02/27/2014 22:00 | 1.6 | 12.6 | 2,048.2 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/27/2014 23:00 | 1.6 | 12.4 | 2,072.5 | 1.1 | 8.30 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.4 | 13.2 | 1,867.5 | 1.1 | 179.40 # | 24 # | 24 # | 22 # |
| **Minimum:** | 1.2 | 12.4 | 1,283.7 | 1.0 | 5.10 | 1 | 1 | 0 |
| **Maximum:** | 1.6 | 13.9 | 2,082.2 | 1.2 | 8.30 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 02/28/2014 00:00 | 1.5 | 13.1 | 1,927.9 | 1.1 | 7.70 | 1 | 1 | 1 |
| 02/28/2014 01:00 | 1.5 | 13.3 | 1,882.3 | 1.2 | 7.50 | 1 | 1 | 1 |
| 02/28/2014 02:00 | 1.5 | 13.0 | 1,945.5 | 1.1 | 7.80 | 1 | 1 | 1 |
| 02/28/2014 03:00 | 1.5 | 13.3 | 1,881.5 | 1.2 | 7.50 | 1 | 1 | 1 |
| 02/28/2014 04:00 | 1.5 | 13.3 | 1,883.9 | 1.2 | 7.50 | 1 | 1 | 1 |
| 02/28/2014 05:00 | 1.5 | 13.2 | 1,898.3 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/28/2014 06:00 | 1.5 | 13.3 | 1,893.0 | 1.2 | 7.60 | 1 | 1 | 1 |
| 02/28/2014 07:00 | 1.5 | 13.2 | 1,906.3 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/28/2014 08:00 | 1.6 | 12.6 | 2,047.7 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/28/2014 09:00 | 1.7 | 12.0 | 2,177.8 | 1.1 | 8.70 | 1 | 1 | 1 |
| 02/28/2014 10:00 | 1.7 | 11.8 | 2,222.3 | 1.1 | 8.90 | 1 | 1 | 1 |
| 02/28/2014 11:00 | 1.7 | 11.9 | 2,203.3 | 1.1 | 8.80 | 1 | 1 | 1 |
| 02/28/2014 12:00 | 1.7 | 12.0 | 2,168.1 | 1.1 | 8.70 | 1 | 1 | 1 |
| 02/28/2014 13:00 | 1.5 | 12.5 | 2,052.2 | 1.1 | 8.20 | 1 | 1 | 1 |
| 02/28/2014 14:00 | 1.4 | 13.1 | 1,900.5 | 1.1 | 7.60 | 1 | 1 | 1 |
| 02/28/2014 15:00 | 1.5 | 12.9 | 1,972.4 | 1.1 | 7.90 | 1 | 1 | 1 |
| 02/28/2014 16:00 | 1.6 | 12.1 | 2,146.4 | 1.1 | 8.60 | 1 | 1 | 1 |
| 02/28/2014 17:00 | 1.6 | 12.3 | 2,103.7 | 1.1 | 8.40 | 1 | 1 | 1 |
| 02/28/2014 18:00 | 1.5 | 12.9 | 1,979.1 | 1.1 | 7.90 | 1 | 1 | 1 |
| 02/28/2014 19:00 | 1.6 | 12.6 | 2,035.5 | 1.1 | 8.10 | 1 | 1 | 1 |
| 02/28/2014 20:00 | 1.5 | 13.2 | 1,877.1 | 1.1 | 7.50 | 1 | 1 | 1 |
| 02/28/2014 21:00 | 1.5 | 12.9 | 1,986.4 | 1.1 | 7.90 | 1 | 1 | 1 |
| 02/28/2014 22:00 | 1.6 | 12.7 | 2,026.5 | 1.2 | 8.10 | 1 | 1 | 1 |
| 02/28/2014 23:00 | 1.6 | 12.5 | 2,067.6 | 1.1 | 8.30 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.6 | 12.7 | 2,007.7 | 1.1 | 192.60 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.4 | 11.8 | 1,877.1 | 1.1 | 7.50 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.3 | 2,222.3 | 1.2 | 8.90 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/01/2014 00:00 | 1.5 | 12.9 | 1,971.9 | 1.1 | 7.90 | 1 | 1 | 1 |
| 03/01/2014 01:00 | 1.4 | 13.2 | 1,893.2 | 1.1 | 7.60 | 1 | 1 | 1 |
| 03/01/2014 02:00 | 1.5 | 13.2 | 1,865.6 | 1.1 | 7.50 | 1 | 1 | 1 |
| 03/01/2014 03:00 | 1.5 | 13.2 | 1,869.1 | 1.1 | 7.50 | 1 | 1 | 1 |
| 03/01/2014 04:00 | 1.5 | 13.2 | 1,871.7 | 1.1 | 7.50 | 1 | 1 | 1 |
| 03/01/2014 05:00 | 1.5 | 13.2 | 1,884.0 | 1.1 | 7.50 | 1 | 1 | 1 |
| 03/01/2014 06:00 | 1.5 | 13.2 | 1,868.0 | 1.1 | 7.50 | 1 | 1 | 1 |
| 03/01/2014 07:00 | 1.5 | 13.2 | 1,868.0 | 1.1 | 7.50 | 1 | 1 | 1 |
| 03/01/2014 08:00 | 1.5 | 13.2 | 1,878.7 | 1.1 | 7.50 | 1 | 1 | 1 |
| 03/01/2014 09:00 | 1.5 | 13.2 | 1,873.3 | 1.1 | 7.50 | 1 | 1 | 1 |
| 03/01/2014 10:00 | 1.5 | 13.2 | 1,877.2 | 1.1 | 7.50 | 1 | 1 | 1 |
| 03/01/2014 11:00 | 1.5 | 13.3 | 1,872.5 | 1.2 | 7.50 | 1 | 1 | 1 |
| 03/01/2014 12:00 | 1.5 | 13.3 | 1,868.8 | 1.2 | 7.50 | 1 | 1 | 1 |
| 03/01/2014 13:00 | 1.5 | 13.2 | 1,893.2 | 1.1 | 7.60 | 1 | 1 | 1 |
| 03/01/2014 14:00 | 1.5 | 12.8 | 2,023.4 | 1.1 | 8.10 | 1 | 1 | 1 |
| 03/01/2014 15:00 | 1.6 | 12.7 | 2,030.8 | 1.2 | 8.10 | 1 | 1 | 1 |
| 03/01/2014 16:00 | 1.3 | 13.3 | 1,903.3 | 1.0 | 7.60 | 1 | 1 | 1 |
| 03/01/2014 17:00 | 1.5 | 13.3 | 1,868.5 | 1.2 | 7.50 | 1 | 1 | 1 |
| 03/01/2014 18:00 | 1.5 | 13.3 | 1,870.0 | 1.2 | 7.50 | 1 | 1 | 1 |
| 03/01/2014 19:00 | 1.5 | 12.9 | 1,978.2 | 1.1 | 7.90 | 1 | 1 | 1 |
| 03/01/2014 20:00 | 1.4 | 12.9 | 1,960.0 | 1.0 | 7.80 | 1 | 1 | 1 |
| 03/01/2014 21:00 | 1.6 | 12.7 | 2,017.3 | 1.2 | 8.10 | 1 | 1 | 1 |
| 03/01/2014 22:00 | 1.6 | 12.8 | 2,018.3 | 1.2 | 8.10 | 1 | 1 | 1 |
| 03/01/2014 23:00 | 1.6 | 12.6 | 2,050.9 | 1.1 | 8.20 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.5 | 13.1 | 1,919.8 | 1.1 | 184.50 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.3 | 12.6 | 1,865.6 | 1.0 | 7.50 | 1 | 1 | 1 |
| **Maximum:** | 1.6 | 13.3 | 2,050.9 | 1.2 | 8.20 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/02/2014 00:00 | 1.3 | 13.1 | 1,939.7 | 1.0 | 7.80 | 1 | 1 | 1 |
| 03/02/2014 01:00 | 1.5 | 12.8 | 2,041.9 | 1.1 | 8.20 | 1 | 1 | 1 |
| 03/02/2014 02:00 | 1.5 | 12.9 | 2,022.7 | 1.1 | 8.10 | 1 | 1 | 1 |
| 03/02/2014 03:00 | 1.5 | 13.2 | 1,890.2 | 1.1 | 7.60 | 1 | 1 | 1 |
| 03/02/2014 04:00 | 1.5 | 13.2 | 1,866.3 | 1.1 | 7.50 | 1 | 1 | 1 |
| 03/02/2014 05:00 | 1.5 | 13.2 | 1,913.8 | 1.1 | 7.70 | 1 | 1 | 1 |
| 03/02/2014 06:00 | 1.2 | 12.8 | 2,008.6 | 0.9 | 6.00 | 1 | 1 | 1 |
| 03/02/2014 07:00 | 1.6 | 12.7 | 2,089.0 | 1.2 | 8.40 | 1 | 1 | 1 |
| 03/02/2014 08:00 | 1.6 | 12.7 | 2,082.1 | 1.2 | 8.30 | 1 | 1 | 1 |
| 03/02/2014 09:00 | 1.5 | 13.1 | 1,975.3 | 1.1 | 7.90 | 1 | 1 | 1 |
| 03/02/2014 10:00 | 1.6 | 12.7 | 2,065.0 | 1.2 | 8.30 | 1 | 1 | 1 |
| 03/02/2014 11:00 | 1.7 | 11.9 | 2,233.3 | 1.1 | 8.90 | 1 | 1 | 1 |
| 03/02/2014 12:00 | 1.7 | 12.0 | 2,209.0 | 1.1 | 8.80 | 1 | 1 | 1 |
| 03/02/2014 13:00 | 1.7 | 11.7 | 2,259.8 | 1.1 | 9.00 | 1 | 1 | 1 |
| 03/02/2014 14:00 | 1.7 | 11.7 | 2,250.8 | 1.1 | 9.00 | 1 | 1 | 1 |
| 03/02/2014 15:00 | 1.7 | 11.7 | 2,242.0 | 1.1 | 9.00 | 1 | 1 | 1 |
| 03/02/2014 16:00 | 1.7 | 11.7 | 2,239.2 | 1.1 | 9.00 | 1 | 1 | 1 |
| 03/02/2014 17:00 | 1.7 | 11.9 | 2,202.4 | 1.1 | 8.80 | 1 | 1 | 1 |
| 03/02/2014 18:00 | 1.7 | 12.2 | 2,125.7 | 1.2 | 8.50 | 1 | 1 | 1 |
| 03/02/2014 19:00 | 1.6 | 12.2 | 2,131.3 | 1.1 | 8.50 | 1 | 1 | 1 |
| 03/02/2014 20:00 | 1.6 | 12.5 | 2,066.1 | 1.1 | 8.30 | 1 | 1 | 1 |
| 03/02/2014 21:00 | 1.6 | 12.2 | 2,163.2 | 1.1 | 8.70 | 1 | 1 | 1 |
| 03/02/2014 22:00 | 1.4 | 12.7 | 2,076.1 | 1.0 | 8.30 | 1 | 1 | 1 |
| 03/02/2014 23:00 | 1.3 | 12.9 | 2,027.0 | 1.0 | 8.10 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.6 | 12.5 | 2,088.4 | 1.1 | 198.70 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.2 | 11.7 | 1,866.3 | 0.9 | 6.00 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.2 | 2,259.8 | 1.2 | 9.00 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/03/2014 00:00 | 1.2 | 13.5 | 1,613.7 | 1.0 | 6.50 | 1 | 1 | 1 |
| 03/03/2014 01:00 | 1.1 | 13.8 | 1,436.4 | 0.9 | 4.30 | 1 | 1 | 0 |
| 03/03/2014 02:00 | 1.0 | 13.8 | 1,291.1 | 0.8 | 3.90 | 1 | 1 | 0 |
| 03/03/2014 03:00 | 1.0 | 13.8 | 1,288.6 | 0.8 | 3.90 | 1 | 1 | 0 |
| 03/03/2014 04:00 | 1.0 | 13.8 | 1,294.1 | 0.8 | 3.90 | 1 | 1 | 0 |
| 03/03/2014 05:00 | 1.2 | 13.5 | 1,596.4 | 1.0 | 6.40 | 1 | 1 | 1 |
| 03/03/2014 06:00 | 1.5 | 13.1 | 1,911.0 | 1.1 | 7.60 | 1 | 1 | 1 |
| 03/03/2014 07:00 | 1.5 | 12.8 | 2,030.9 | 1.1 | 8.10 | 1 | 1 | 1 |
| 03/03/2014 08:00 | 1.7 | 11.9 | 2,222.6 | 1.1 | 8.90 | 1 | 1 | 1 |
| 03/03/2014 09:00 | 1.6 | 12.0 | 2,166.8 | 1.1 | 8.70 | 1 | 1 | 1 |
| 03/03/2014 10:00 | 1.6 | 12.7 | 2,023.6 | 1.2 | 8.10 | 1 | 1 | 1 |
| 03/03/2014 11:00 | 1.4 | 13.0 | 1,948.7 | 1.0 | 7.80 | 1 | 1 | 1 |
| 03/03/2014 12:00 | 1.5 | 13.1 | 1,904.7 | 1.1 | 7.60 | 1 | 1 | 1 |
| 03/03/2014 13:00 | 1.5 | 13.2 | 1,882.1 | 1.1 | 7.50 | 1 | 1 | 1 |
| 03/03/2014 14:00 | 1.5 | 13.1 | 1,906.3 | 1.1 | 7.60 | 1 | 1 | 1 |
| 03/03/2014 15:00 | 1.4 | 13.1 | 1,947.9 | 1.1 | 7.80 | 1 | 1 | 1 |
| 03/03/2014 16:00 | 1.5 | 12.8 | 2,036.3 | 1.1 | 8.10 | 1 | 1 | 1 |
| 03/03/2014 17:00 | 1.7 | 11.9 | 2,217.5 | 1.1 | 8.90 | 1 | 1 | 1 |
| 03/03/2014 18:00 | 1.6 | 12.3 | 2,097.7 | 1.1 | 8.40 | 1 | 1 | 1 |
| 03/03/2014 19:00 | 1.6 | 11.9 | 2,205.8 | 1.0 | 8.80 | 1 | 1 | 1 |
| 03/03/2014 20:00 | 1.7 | 11.7 | 2,237.8 | 1.1 | 9.00 | 1 | 1 | 1 |
| 03/03/2014 21:00 | 1.6 | 11.8 | 2,218.3 | 1.0 | 8.90 | 1 | 1 | 1 |
| 03/03/2014 22:00 | 1.6 | 12.7 | 1,990.1 | 1.2 | 8.00 | 1 | 1 | 1 |
| 03/03/2014 23:00 | 1.5 | 13.1 | 1,866.1 | 1.1 | 7.50 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.4 | 12.9 | 1,888.9 | 1.0 | 176.20 # | 24 # | 24 # | 20 # |
| **Minimum:** | 1.0 | 11.7 | 1,288.6 | 0.8 | 3.90 | 1 | 1 | 0 |
| **Maximum:** | 1.7 | 13.8 | 2,237.8 | 1.2 | 9.00 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/04/2014 00:00 | 1.3 | 13.4 | 1,579.0 | 1.0 | 6.30 | 1 | 1 | 1 |
| 03/04/2014 01:00 | 1.1 | 13.8 | 1,260.2 | 0.9 | 3.80 | 1 | 1 | 0 |
| 03/04/2014 02:00 | 1.1 | 13.8 | 1,269.8 | 0.9 | 3.80 | 1 | 1 | 0 |
| 03/04/2014 03:00 | 1.1 | 13.8 | 1,332.1 | 0.9 | 4.00 | 1 | 1 | 0 |
| 03/04/2014 04:00 | 1.1 | 13.8 | 1,279.9 | 0.9 | 3.80 | 1 | 1 | 0 |
| 03/04/2014 05:00 | 1.1 | 13.8 | 1,296.3 | 0.9 | 3.90 | 1 | 1 | 0 |
| 03/04/2014 06:00 | 1.1 | 13.4 | 1,591.9 | 0.9 | 4.80 | 1 | 1 | 1 |
| 03/04/2014 07:00 | 1.4 | 13.3 | 1,879.6 | 1.1 | 7.50 | 1 | 1 | 1 |
| 03/04/2014 08:00 | 1.5 | 13.3 | 1,868.8 | 1.2 | 7.50 | 1 | 1 | 1 |
| 03/04/2014 09:00 | 1.1 | 13.8 | 1,445.9 | 0.9 | 4.30 | 1 | 1 | 1 |
| 03/04/2014 10:00 | 1.1 | 13.9 | 1,236.5 | 0.9 | 3.70 | 1 | 1 | 0 |
| 03/04/2014 11:00 | 1.1 | 13.9 | 1,237.4 | 0.9 | 3.70 | 1 | 1 | 0 |
| 03/04/2014 12:00 | 1.3 | 13.8 | 1,268.1 | 1.1 | 5.10 | 1 | 1 | 0 |
| 03/04/2014 13:00 | 1.3 | 13.8 | 1,421.1 | 1.1 | 5.70 | 1 | 1 | 0 |
| 03/04/2014 14:00 | 1.4 | 13.3 | 1,856.8 | 1.1 | 7.40 | 1 | 1 | 1 |
| 03/04/2014 15:00 | 1.5 | 13.3 | 1,875.4 | 1.2 | 7.50 | 1 | 1 | 1 |
| 03/04/2014 16:00 | 1.5 | 13.3 | 1,876.9 | 1.2 | 7.50 | 1 | 1 | 1 |
| 03/04/2014 17:00 | 1.5 | 13.3 | 1,875.0 | 1.2 | 7.50 | 1 | 1 | 1 |
| 03/04/2014 18:00 | 1.5 | 13.2 | 1,910.3 | 1.1 | 7.60 | 1 | 1 | 1 |
| 03/04/2014 19:00 | 1.6 | 12.2 | 2,137.8 | 1.1 | 8.60 | 1 | 1 | 1 |
| 03/04/2014 20:00 | 1.6 | 12.2 | 2,111.7 | 1.1 | 8.40 | 1 | 1 | 1 |
| 03/04/2014 21:00 | 1.6 | 12.6 | 2,027.7 | 1.1 | 8.10 | 1 | 1 | 1 |
| 03/04/2014 22:00 | 1.5 | 12.9 | 1,958.9 | 1.1 | 7.80 | 1 | 1 | 1 |
| 03/04/2014 23:00 | 1.5 | 13.3 | 1,869.3 | 1.2 | 7.50 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.3 | 13.4 | 1,644.4 | 1.0 | 145.80 # | 24 # | 24 # | 15 # |
| **Minimum:** | 1.1 | 12.2 | 1,236.5 | 0.9 | 3.70 | 1 | 1 | 0 |
| **Maximum:** | 1.6 | 13.9 | 2,137.8 | 1.2 | 8.60 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/05/2014 00:00 | 1.5 | 13.2 | 1,890.2 | 1.1 | 7.60 | 1 | 1 | 1 |
| 03/05/2014 01:00 | 1.5 | 12.7 | 2,011.5 | 1.1 | 8.00 | 1 | 1 | 1 |
| 03/05/2014 02:00 | 1.6 | 12.7 | 2,025.2 | 1.2 | 8.10 | 1 | 1 | 1 |
| 03/05/2014 03:00 | 1.3 | 13.1 | 1,903.1 | 1.0 | 7.60 | 1 | 1 | 1 |
| 03/05/2014 04:00 | 1.3 | 13.2 | 1,865.7 | 1.0 | 7.50 | 1 | 1 | 1 |
| 03/05/2014 05:00 | 1.4 | 12.9 | 1,981.8 | 1.0 | 7.90 | 1 | 1 | 1 |
| 03/05/2014 06:00 | 1.4 | 13.1 | 1,952.2 | 1.1 | 7.80 | 1 | 1 | 1 |
| 03/05/2014 07:00 | 1.5 | 12.9 | 1,971.2 | 1.1 | 7.90 | 1 | 1 | 1 |
| 03/05/2014 08:00 | 1.5 | 12.9 | 1,976.6 | 1.1 | 7.90 | 1 | 1 | 1 |
| 03/05/2014 09:00 | 1.5 | 13.1 | 1,890.0 | 1.1 | 7.60 | 1 | 1 | 1 |
| 03/05/2014 10:00 | 1.5 | 13.1 | 1,891.0 | 1.1 | 7.60 | 1 | 1 | 1 |
| 03/05/2014 11:00 | 1.5 | 13.2 | 1,891.5 | 1.1 | 7.60 | 1 | 1 | 1 |
| 03/05/2014 12:00 | 1.5 | 13.2 | 1,892.0 | 1.1 | 7.60 | 1 | 1 | 1 |
| 03/05/2014 13:00 | 1.5 | 13.2 | 1,892.5 | 1.1 | 7.60 | 1 | 1 | 1 |
| 03/05/2014 14:00 | 1.4 | 13.2 | 1,892.9 | 1.1 | 7.60 | 1 | 1 | 1 |
| 03/05/2014 15:00 | 1.4 | 13.1 | 1,894.4 | 1.1 | 7.60 | 1 | 1 | 1 |
| 03/05/2014 16:00 | 1.4 | 12.9 | 1,935.8 | 1.0 | 7.70 | 1 | 1 | 1 |
| 03/05/2014 17:00 | 1.6 | 12.8 | 1,973.3 | 1.2 | 7.90 | 1 | 1 | 1 |
| 03/05/2014 18:00 | 1.5 | 12.8 | 1,980.1 | 1.1 | 7.90 | 1 | 1 | 1 |
| 03/05/2014 19:00 | 1.6 | 12.4 | 2,076.0 | 1.1 | 8.30 | 1 | 1 | 1 |
| 03/05/2014 20:00 | 1.6 | 12.5 | 2,033.9 | 1.1 | 8.10 | 1 | 1 | 1 |
| 03/05/2014 21:00 | 1.4 | 12.7 | 2,006.6 | 1.0 | 8.00 | 1 | 1 | 1 |
| 03/05/2014 22:00 | 1.5 | 12.7 | 1,992.2 | 1.1 | 8.00 | 1 | 1 | 1 |
| 03/05/2014 23:00 | 1.4 | 13.1 | 1,871.2 | 1.1 | 7.50 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.5 | 12.9 | 1,945.5 | 1.1 | 186.90 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.3 | 12.4 | 1,865.7 | 1.0 | 7.50 | 1 | 1 | 1 |
| **Maximum:** | 1.6 | 13.2 | 2,076.0 | 1.2 | 8.30 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/06/2014 00:00 | 1.4 | 13.2 | 1,867.0 | 1.1 | 7.50 | 1 | 1 | 1 |
| 03/06/2014 01:00 | 1.5 | 13.3 | 1,817.9 | 1.2 | 7.30 | 1 | 1 | 1 |
| 03/06/2014 02:00 | 1.0 | 13.9 | 1,275.8 | 0.8 | 3.80 | 1 | 1 | 0 |
| 03/06/2014 03:00 | 6.3 | 15.6 | 633.1 | 7.0 | 4.13 | 1 | 0 | 0 |
| 03/06/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/06/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 2.6 | 14.0 | 1,398.5 | 2.5 | 22.73 # | 4 # | 3 # | 2 # |
| **Minimum:** | 1.0 | 13.2 | 633.1 | 0.8 | 3.80 | 0 | 0 | 0 |
| **Maximum:** | 6.3 | 15.6 | 1,867.0 | 7.0 | 7.50 | 1 | 1 | 1 |
| **%SI** | 83.3 | 83.3 | 83.3 | 83.3 | 83.33 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/07/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/07/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/07/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/07/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/07/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/07/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/07/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/07/2014 07:00 | 36.9 | 17.5 | 493.3 | 64.0 | 73.33 | 1 | 0 | 0 |
| 03/07/2014 08:00 | 21.9 | 14.9 | 1,127.5 | 21.5 | 89.10 | 1 | 0 | 0 |
| 03/07/2014 09:00 | 0.9 | 13.9 | 1,337.3 | 0.8 | 4.00 | 1 | 1 | 0 |
| 03/07/2014 10:00 | 1.4 | 13.3 | 1,814.7 | 1.1 | 7.30 | 1 | 1 | 1 |
| 03/07/2014 11:00 | 1.3 | 13.2 | 1,860.7 | 1.0 | 7.40 | 1 | 1 | 1 |
| 03/07/2014 12:00 | 1.3 | 13.3 | 1,859.7 | 1.0 | 7.40 | 1 | 1 | 1 |
| 03/07/2014 13:00 | 1.5 | 13.3 | 1,856.2 | 1.2 | 7.40 | 1 | 1 | 1 |
| 03/07/2014 14:00 | 1.5 | 13.3 | 1,859.1 | 1.2 | 7.40 | 1 | 1 | 1 |
| 03/07/2014 15:00 | 1.5 | 13.3 | 1,858.6 | 1.2 | 7.40 | 1 | 1 | 1 |
| 03/07/2014 16:00 | 1.3 | 13.2 | 1,886.6 | 1.0 | 7.50 | 1 | 1 | 1 |
| 03/07/2014 17:00 | 1.5 | 12.7 | 2,027.0 | 1.1 | 8.10 | 1 | 1 | 1 |
| 03/07/2014 18:00 | 1.6 | 12.6 | 2,038.6 | 1.1 | 8.20 | 1 | 1 | 1 |
| 03/07/2014 19:00 | 1.7 | 11.9 | 2,213.7 | 1.1 | 8.90 | 1 | 1 | 1 |
| 03/07/2014 20:00 | 1.7 | 11.6 | 2,292.8 | 1.1 | 9.20 | 1 | 1 | 1 |
| 03/07/2014 21:00 | 1.7 | 11.6 | 2,288.2 | 1.1 | 9.20 | 1 | 1 | 1 |
| 03/07/2014 22:00 | 1.7 | 11.6 | 2,286.8 | 1.1 | 9.10 | 1 | 1 | 1 |
| 03/07/2014 23:00 | 1.7 | 11.9 | 2,225.4 | 1.1 | 8.90 | 1 | 1 | 1 |
| **Average/Sum#:** | 4.8 | 13.1 | 1,842.7 | 6.0 | 279.83 # | 17 # | 15 # | 14 # |
| **Minimum:** | 0.9 | 11.6 | 493.3 | 0.8 | 4.00 | 0 | 0 | 0 |
| **Maximum:** | 36.9 | 17.5 | 2,292.8 | 64.0 | 89.10 | 1 | 1 | 1 |
| **%SI** | 29.2 | 29.2 | 29.2 | 29.2 | 29.17 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/08/2014 00:00 | 1.6 | 12.8 | 2,018.3 | 1.2 | 8.10 | 1 | 1 | 1 |
| 03/08/2014 01:00 | 1.5 | 12.9 | 2,000.5 | 1.1 | 8.00 | 1 | 1 | 1 |
| 03/08/2014 02:00 | 1.5 | 13.0 | 1,950.6 | 1.1 | 7.80 | 1 | 1 | 1 |
| 03/08/2014 03:00 | 1.5 | 13.1 | 1,927.4 | 1.1 | 7.70 | 1 | 1 | 1 |
| 03/08/2014 04:00 | 1.5 | 13.0 | 1,982.3 | 1.1 | 7.90 | 1 | 1 | 1 |
| 03/08/2014 05:00 | 1.6 | 12.8 | 2,027.5 | 1.2 | 8.10 | 1 | 1 | 1 |
| 03/08/2014 06:00 | 1.6 | 12.6 | 2,065.9 | 1.1 | 8.30 | 1 | 1 | 1 |
| 03/08/2014 07:00 | 1.6 | 12.7 | 2,044.0 | 1.2 | 8.20 | 1 | 1 | 1 |
| 03/08/2014 08:00 | 1.5 | 13.1 | 1,907.1 | 1.1 | 7.60 | 1 | 1 | 1 |
| 03/08/2014 09:00 | 1.5 | 13.2 | 1,854.3 | 1.1 | 7.40 | 1 | 1 | 1 |
| 03/08/2014 10:00 | 1.5 | 13.2 | 1,854.7 | 1.1 | 7.40 | 1 | 1 | 1 |
| 03/08/2014 11:00 | 1.4 | 13.2 | 1,852.1 | 1.1 | 7.40 | 1 | 1 | 1 |
| 03/08/2014 12:00 | 1.5 | 13.2 | 1,852.5 | 1.1 | 7.40 | 1 | 1 | 1 |
| 03/08/2014 13:00 | 1.5 | 13.3 | 1,855.5 | 1.2 | 7.40 | 1 | 1 | 1 |
| 03/08/2014 14:00 | 1.5 | 13.3 | 1,852.6 | 1.2 | 7.40 | 1 | 1 | 1 |
| 03/08/2014 15:00 | 1.5 | 13.3 | 1,852.7 | 1.2 | 7.40 | 1 | 1 | 1 |
| 03/08/2014 16:00 | 1.5 | 13.3 | 1,862.8 | 1.2 | 7.50 | 1 | 1 | 1 |
| 03/08/2014 17:00 | 1.4 | 13.2 | 1,888.1 | 1.1 | 7.60 | 1 | 1 | 1 |
| 03/08/2014 18:00 | 1.7 | 12.2 | 2,136.8 | 1.2 | 8.50 | 1 | 1 | 1 |
| 03/08/2014 19:00 | 1.7 | 11.6 | 2,249.6 | 1.1 | 9.00 | 1 | 1 | 1 |
| 03/08/2014 20:00 | 1.7 | 11.5 | 2,269.4 | 1.1 | 9.10 | 1 | 1 | 1 |
| 03/08/2014 21:00 | 1.7 | 11.5 | 2,262.4 | 1.1 | 9.00 | 1 | 1 | 1 |
| 03/08/2014 22:00 | 1.7 | 11.5 | 2,264.1 | 1.1 | 9.10 | 1 | 1 | 1 |
| 03/08/2014 23:00 | 1.7 | 11.7 | 2,225.8 | 1.1 | 8.90 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.6 | 12.7 | 2,002.4 | 1.1 | 192.20 # | 24 # | 24 # | 24 # |
| **Minimum:** | 1.4 | 11.5 | 1,852.1 | 1.1 | 7.40 | 1 | 1 | 1 |
| **Maximum:** | 1.7 | 13.3 | 2,269.4 | 1.2 | 9.10 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/09/2014 00:00 | 1.4 | 13.0 | 1,824.6 | 1.0 | 7.30 | 1 | 1 | 1 |
| 03/09/2014 01:00 | 1.0 | 13.8 | 1,378.9 | 0.8 | 4.10 | 1 | 1 | 0 |
| 03/09/2014 02:00 | 6.3 | 15.4 | 658.8 | 6.8 | 3.80 | 1 | 0 | 0 |
| 03/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/09/2014 15:00 | 30.7 | 17.1 | 537.7 | 47.7 | 73.79 | 1 | 0 | 0 |
| 03/09/2014 16:00 | 10.5 | 14.1 | 1,407.2 | 9.1 | 47.80 | 1 | 0 | 1 |
| 03/09/2014 17:00 | 1.6 | 12.5 | 2,074.9 | 1.1 | 8.30 | 1 | 1 | 1 |
| 03/09/2014 18:00 | 1.7 | 11.7 | 2,217.4 | 1.1 | 8.90 | 1 | 1 | 1 |
| 03/09/2014 19:00 | 1.7 | 11.6 | 2,244.1 | 1.1 | 9.00 | 1 | 1 | 1 |
| 03/09/2014 20:00 | 1.7 | 11.6 | 2,247.3 | 1.1 | 9.00 | 1 | 1 | 1 |
| 03/09/2014 21:00 | 1.7 | 11.6 | 2,247.7 | 1.1 | 9.00 | 1 | 1 | 1 |
| 03/09/2014 22:00 | 1.1 | 13.5 | 1,798.9 | 0.9 | 5.40 | 1 | 1 | 1 |
| 03/09/2014 23:00 | 1.1 | 13.6 | 1,799.0 | 0.9 | 5.40 | 1 | 1 | 0 |
| **Average/Sum#:** | 5.0 | 13.3 | 1,703.0 | 6.1 | 191.79 # | 12 # | 9 # | 8 # |
| **Minimum:** | 1.0 | 11.6 | 537.7 | 0.8 | 3.80 | 0 | 0 | 0 |
| **Maximum:** | 30.7 | 17.1 | 2,247.7 | 47.7 | 73.79 | 1 | 1 | 1 |
| **%SI** | 50.0 | 50.0 | 50.0 | 50.0 | 50.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/10/2014 00:00 | 1.1 | 13.6 | 1,800.2 | 0.9 | 5.40 | 1 | 1 | 0 |
| 03/10/2014 01:00 | 1.0 | 13.8 | 1,314.1 | 0.8 | 3.90 | 1 | 1 | 0 |
| 03/10/2014 02:00 | 0.9 | 13.8 | 1,240.8 | 0.7 | 3.70 | 1 | 1 | 0 |
| 03/10/2014 03:00 | 1.1 | 13.8 | 1,244.4 | 0.9 | 3.70 | 1 | 1 | 0 |
| 03/10/2014 04:00 | 1.1 | 13.8 | 1,250.3 | 0.9 | 3.80 | 1 | 1 | 0 |
| 03/10/2014 05:00 | 1.1 | 13.8 | 1,529.0 | 0.9 | 4.60 | 1 | 1 | 0 |
| 03/10/2014 06:00 | 1.2 | 13.7 | 1,788.7 | 1.0 | 7.20 | 1 | 1 | 0 |
| 03/10/2014 07:00 | 1.1 | 13.7 | 1,816.3 | 0.9 | 5.40 | 1 | 1 | 1 |
| 03/10/2014 08:00 | 1.3 | 13.2 | 1,892.3 | 1.0 | 7.60 | 1 | 1 | 1 |
| 03/10/2014 09:00 | 1.4 | 13.1 | 1,904.6 | 1.1 | 7.60 | 1 | 1 | 1 |
| 03/10/2014 10:00 | 1.5 | 13.2 | 1,854.8 | 1.1 | 7.40 | 1 | 1 | 1 |
| 03/10/2014 11:00 | 1.5 | 13.3 | 1,859.9 | 1.2 | 7.40 | 1 | 1 | 1 |
| 03/10/2014 12:00 | 1.5 | 13.3 | 1,859.8 | 1.2 | 7.40 | 1 | 1 | 1 |
| 03/10/2014 13:00 | 1.5 | 13.2 | 1,862.0 | 1.1 | 7.40 | 1 | 1 | 1 |
| 03/10/2014 14:00 | 1.5 | 13.2 | 1,864.9 | 1.1 | 7.50 | 1 | 1 | 1 |
| 03/10/2014 15:00 | 1.5 | 13.3 | 1,867.7 | 1.2 | 7.50 | 1 | 1 | 1 |
| 03/10/2014 16:00 | 1.5 | 13.3 | 1,865.5 | 1.2 | 7.50 | 1 | 1 | 1 |
| 03/10/2014 17:00 | 1.5 | 13.3 | 1,862.5 | 1.2 | 7.50 | 1 | 1 | 1 |
| 03/10/2014 18:00 | 1.4 | 13.3 | 1,871.4 | 1.1 | 7.50 | 1 | 1 | 1 |
| 03/10/2014 19:00 | 1.6 | 12.1 | 2,169.1 | 1.1 | 8.70 | 1 | 1 | 1 |
| 03/10/2014 20:00 | 1.6 | 12.3 | 2,125.2 | 1.1 | 8.50 | 1 | 1 | 1 |
| 03/10/2014 21:00 | 1.4 | 13.4 | 1,740.7 | 1.1 | 7.00 | 1 | 1 | 1 |
| 03/10/2014 22:00 | 1.2 | 13.9 | 1,394.2 | 1.0 | 5.60 | 1 | 1 | 0 |
| 03/10/2014 23:00 | 8.9 | 15.7 | 609.4 | 10.1 | 5.18 | 1 | 0 | 0 |
| **Average/Sum#:** | 1.6 | 13.5 | 1,691.2 | 1.4 | 154.98 # | 24 # | 23 # | 15 # |
| **Minimum:** | 0.9 | 12.1 | 609.4 | 0.7 | 3.70 | 1 | 0 | 0 |
| **Maximum:** | 8.9 | 15.7 | 2,169.1 | 10.1 | 8.70 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/11/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/11/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/11/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/11/2014 05:00 | 22.0 | 18.0 | 414.7 | 44.8 | 21.89 | 1 | 0 | 0 |
| 03/11/2014 06:00 | 29.1 | 15.3 | 885.5 | 30.7 | 100.10 | 1 | 0 | 0 |
| 03/11/2014 07:00 | 1.2 | 13.7 | 1,769.7 | 1.0 | 7.10 | 1 | 1 | 0 |
| 03/11/2014 08:00 | 1.4 | 13.4 | 1,856.8 | 1.1 | 7.40 | 1 | 1 | 1 |
| 03/11/2014 09:00 | 1.5 | 13.2 | 1,859.0 | 1.1 | 7.40 | 1 | 1 | 1 |
| 03/11/2014 10:00 | 0.0 | 13.3 | 1,857.2 | 0.0 | 0.00 | 1 | 1 | 1 |
| 03/11/2014 11:00 | 0.0 | 13.3 | 1,854.3 | 0.0 | 0.00 | 1 | 1 | 1 |
| 03/11/2014 12:00 | 0.0 | 13.4 | 1,739.7 | 0.0 | 0.00 | 1 | 1 | 1 |
| 03/11/2014 13:00 | 1.3 | 13.9 | 1,335.9 | 1.1 | 5.30 | 1 | 1 | 0 |
| 03/11/2014 14:00 | 1.4 | 13.9 | 1,276.5 | 1.2 | 5.10 | 1 | 1 | 0 |
| 03/11/2014 15:00 | 1.2 | 13.9 | 1,303.3 | 1.0 | 5.20 | 1 | 1 | 0 |
| 03/11/2014 16:00 | 1.3 | 13.9 | 1,378.4 | 1.1 | 5.50 | 1 | 1 | 0 |
| 03/11/2014 17:00 | 1.3 | 13.9 | 1,387.2 | 1.1 | 5.50 | 1 | 1 | 0 |
| 03/11/2014 18:00 | 1.2 | 13.6 | 1,569.9 | 1.0 | 6.30 | 1 | 1 | 1 |
| 03/11/2014 19:00 | 1.5 | 12.4 | 2,086.0 | 1.0 | 8.30 | 1 | 1 | 1 |
| 03/11/2014 20:00 | 1.7 | 12.1 | 2,179.3 | 1.1 | 8.70 | 1 | 1 | 1 |
| 03/11/2014 21:00 | 1.6 | 12.4 | 2,129.2 | 1.1 | 8.50 | 1 | 1 | 1 |
| 03/11/2014 22:00 | 1.7 | 12.1 | 2,197.0 | 1.1 | 8.80 | 1 | 1 | 1 |
| 03/11/2014 23:00 | 1.4 | 13.2 | 1,762.9 | 1.1 | 7.10 | 1 | 1 | 1 |
| **Average/Sum#:** | 4.4 | 13.6 | 1,623.3 | 5.7 | 218.19 # | 19 # | 17 # | 11 # |
| **Minimum:** | 1.2 | 12.1 | 414.7 | 1.0 | 5.10 | 0 | 0 | 0 |
| **Maximum:** | 29.1 | 18.0 | 2,197.0 | 44.8 | 100.10 | 1 | 1 | 1 |
| **%SI** | 33.3 | 20.8 | 20.8 | 33.3 | 33.33 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/12/2014 00:00 | 1.1 | 13.9 | 1,280.3 | 0.9 | 3.80 | 1 | 1 | 0 |
| 03/12/2014 01:00 | 1.2 | 13.9 | 1,263.7 | 1.0 | 5.10 | 1 | 1 | 0 |
| 03/12/2014 02:00 | 1.2 | 13.9 | 1,242.0 | 1.0 | 5.00 | 1 | 1 | 0 |
| 03/12/2014 03:00 | 1.2 | 13.9 | 1,233.2 | 1.0 | 4.90 | 1 | 1 | 0 |
| 03/12/2014 04:00 | 1.2 | 13.9 | 1,237.6 | 1.0 | 5.00 | 1 | 1 | 0 |
| 03/12/2014 05:00 | 1.4 | 13.4 | 1,731.8 | 1.1 | 6.90 | 1 | 1 | 1 |
| 03/12/2014 06:00 | 1.5 | 12.9 | 1,989.9 | 1.1 | 8.00 | 1 | 1 | 1 |
| 03/12/2014 07:00 | 1.6 | 12.1 | 2,199.2 | 1.1 | 8.80 | 1 | 1 | 1 |
| 03/12/2014 08:00 | 1.5 | 12.9 | 2,014.0 | 1.1 | 8.10 | 1 | 1 | 1 |
| 03/12/2014 09:00 | 1.4 | 13.3 | 1,866.7 | 1.1 | 7.50 | 1 | 1 | 1 |
| 03/12/2014 10:00 | 1.4 | 13.3 | 1,854.1 | 1.1 | 7.40 | 1 | 1 | 1 |
| 03/12/2014 11:00 | 1.2 | 13.3 | 1,854.1 | 0.9 | 5.60 | 1 | 1 | 1 |
| 03/12/2014 12:00 | 1.1 | 13.8 | 1,361.4 | 0.9 | 4.10 | 1 | 1 | 1 |
| 03/12/2014 13:00 | 1.3 | 13.9 | 1,378.0 | 1.1 | 5.50 | 1 | 1 | 0 |
| 03/12/2014 14:00 | 1.3 | 13.9 | 1,253.4 | 1.1 | 5.00 | 1 | 1 | 0 |
| 03/12/2014 15:00 | 1.4 | 13.9 | 1,253.0 | 1.2 | 5.00 | 1 | 1 | 0 |
| 03/12/2014 16:00 | 1.4 | 13.9 | 1,252.1 | 1.2 | 5.00 | 1 | 1 | 0 |
| 03/12/2014 17:00 | 1.3 | 13.6 | 1,546.0 | 1.1 | 6.20 | 1 | 1 | 1 |
| 03/12/2014 18:00 | 1.4 | 13.2 | 1,915.5 | 1.1 | 7.70 | 1 | 1 | 1 |
| 03/12/2014 19:00 | 1.7 | 12.1 | 2,176.1 | 1.1 | 8.70 | 1 | 1 | 1 |
| 03/12/2014 20:00 | 1.7 | 12.0 | 2,202.9 | 1.1 | 8.80 | 1 | 1 | 1 |
| 03/12/2014 21:00 | 1.7 | 11.7 | 2,269.6 | 1.1 | 9.10 | 1 | 1 | 1 |
| 03/12/2014 22:00 | 1.7 | 11.7 | 2,273.9 | 1.1 | 9.10 | 1 | 1 | 1 |
| 03/12/2014 23:00 | 1.7 | 12.1 | 2,181.9 | 1.1 | 8.70 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.4 | 13.2 | 1,701.3 | 1.1 | 159.00 # | 24 # | 24 # | 15 # |
| **Minimum:** | 1.1 | 11.7 | 1,233.2 | 0.9 | 3.80 | 1 | 1 | 0 |
| **Maximum:** | 1.7 | 13.9 | 2,273.9 | 1.2 | 9.10 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/13/2014 00:00 | 1.3 | 13.6 | 1,675.7 | 1.1 | 6.70 | 1 | 1 | 1 |
| 03/13/2014 01:00 | 1.4 | 13.8 | 1,773.5 | 1.2 | 7.10 | 1 | 1 | 0 |
| 03/13/2014 02:00 | 1.1 | 13.9 | 1,392.7 | 0.9 | 4.20 | 1 | 1 | 0 |
| 03/13/2014 03:00 | 1.2 | 13.9 | 1,377.1 | 1.0 | 5.50 | 1 | 1 | 0 |
| 03/13/2014 04:00 | 1.2 | 13.9 | 1,379.6 | 1.0 | 5.50 | 1 | 1 | 0 |
| 03/13/2014 05:00 | 1.5 | 13.2 | 1,875.1 | 1.1 | 7.50 | 1 | 1 | 1 |
| 03/13/2014 06:00 | 1.5 | 12.9 | 1,996.7 | 1.1 | 8.00 | 1 | 1 | 1 |
| 03/13/2014 07:00 | 1.7 | 11.8 | 2,257.9 | 1.1 | 9.00 | 1 | 1 | 1 |
| 03/13/2014 08:00 | 1.7 | 12.2 | 2,169.2 | 1.2 | 8.70 | 1 | 1 | 1 |
| 03/13/2014 09:00 | 1.6 | 12.7 | 2,024.3 | 1.2 | 8.10 | 1 | 1 | 1 |
| 03/13/2014 10:00 | 1.5 | 13.1 | 1,916.2 | 1.1 | 7.70 | 1 | 1 | 1 |
| 03/13/2014 11:00 | 1.2 | 13.4 | 1,856.5 | 0.9 | 5.60 | 1 | 1 | 1 |
| 03/13/2014 12:00 | 1.4 | 13.2 | 1,918.8 | 1.1 | 7.70 | 1 | 1 | 1 |
| 03/13/2014 13:00 | 1.6 | 13.0 | 1,970.4 | 1.2 | 7.90 | 1 | 1 | 1 |
| 03/13/2014 14:00 | 1.6 | 12.9 | 1,972.8 | 1.2 | 7.90 | 1 | 1 | 1 |
| 03/13/2014 15:00 | 1.6 | 12.9 | 1,971.5 | 1.2 | 7.90 | 1 | 1 | 1 |
| 03/13/2014 16:00 | 1.5 | 13.1 | 1,918.6 | 1.1 | 7.70 | 1 | 1 | 1 |
| 03/13/2014 17:00 | 1.5 | 13.3 | 1,859.8 | 1.2 | 7.40 | 1 | 1 | 1 |
| 03/13/2014 18:00 | 1.5 | 13.2 | 1,882.8 | 1.1 | 7.50 | 1 | 1 | 1 |
| 03/13/2014 19:00 | 1.5 | 13.0 | 1,954.6 | 1.1 | 7.80 | 1 | 1 | 1 |
| 03/13/2014 20:00 | 1.4 | 13.2 | 1,896.5 | 1.1 | 7.60 | 1 | 1 | 1 |
| 03/13/2014 21:00 | 1.4 | 13.3 | 1,771.4 | 1.1 | 7.10 | 1 | 1 | 1 |
| 03/13/2014 22:00 | 1.0 | 13.9 | 1,499.3 | 0.8 | 4.50 | 1 | 1 | 0 |
| 03/13/2014 23:00 | 1.1 | 13.9 | 1,753.4 | 0.9 | 5.30 | 1 | 1 | 0 |
| **Average/Sum#:** | 1.4 | 13.2 | 1,836.0 | 1.1 | 169.90 # | 24 # | 24 # | 18 # |
| **Minimum:** | 1.0 | 11.8 | 1,377.1 | 0.8 | 4.20 | 1 | 1 | 0 |
| **Maximum:** | 1.7 | 13.9 | 2,257.9 | 1.2 | 9.00 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/14/2014 00:00 | 1.1 | 13.9 | 1,753.3 | 0.9 | 5.30 | 1 | 1 | 0 |
| 03/14/2014 01:00 | 2.7 | 14.4 | 1,429.9 | 2.5 | 10.71 | 1 | 0 | 0 |
| 03/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/14/2014 06:00 | 0.0 | 19.8 | 150.0 | 0.0 | 0.00 | 1 | 0 | 0 |
| 03/14/2014 07:00 | 24.9 | 15.9 | 825.8 | 29.4 | 89.20 | 1 | 0 | 0 |
| 03/14/2014 08:00 | 1.1 | 13.8 | 1,790.3 | 0.9 | 5.40 | 1 | 1 | 0 |
| 03/14/2014 09:00 | 1.4 | 13.7 | 1,802.4 | 1.1 | 7.20 | 1 | 1 | 0 |
| 03/14/2014 10:00 | 1.4 | 13.7 | 1,795.9 | 1.1 | 7.20 | 1 | 1 | 0 |
| 03/14/2014 11:00 | 1.4 | 13.7 | 1,785.4 | 1.1 | 7.10 | 1 | 1 | 0 |
| 03/14/2014 12:00 | 1.4 | 13.7 | 1,776.7 | 1.1 | 7.10 | 1 | 1 | 0 |
| 03/14/2014 13:00 | 1.4 | 13.7 | 1,767.6 | 1.1 | 7.10 | 1 | 1 | 0 |
| 03/14/2014 14:00 | 1.4 | 13.7 | 1,761.3 | 1.1 | 7.00 | 1 | 1 | 0 |
| 03/14/2014 15:00 | 1.4 | 13.7 | 1,758.4 | 1.1 | 7.00 | 1 | 1 | 0 |
| 03/14/2014 16:00 | 1.4 | 13.7 | 1,748.3 | 1.1 | 7.00 | 1 | 1 | 0 |
| 03/14/2014 17:00 | 1.4 | 13.8 | 1,745.2 | 1.2 | 7.00 | 1 | 1 | 0 |
| 03/14/2014 18:00 | 1.4 | 13.8 | 1,745.6 | 1.2 | 7.00 | 1 | 1 | 0 |
| 03/14/2014 19:00 | 1.4 | 13.7 | 1,759.6 | 1.1 | 7.00 | 1 | 1 | 0 |
| 03/14/2014 20:00 | 1.4 | 13.7 | 1,766.4 | 1.1 | 7.10 | 1 | 1 | 0 |
| 03/14/2014 21:00 | 1.4 | 13.7 | 1,773.2 | 1.1 | 7.10 | 1 | 1 | 0 |
| 03/14/2014 22:00 | 1.4 | 13.7 | 1,781.2 | 1.1 | 7.10 | 1 | 1 | 0 |
| 03/14/2014 23:00 | 1.4 | 13.7 | 1,787.2 | 1.1 | 7.10 | 1 | 1 | 0 |
| **Average/Sum#:** | 2.5 | 14.2 | 1,625.2 | 2.5 | 216.71 # | 20 # | 17 # | 0 # |
| **Minimum:** | 0.0 | 13.7 | 150.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 24.9 | 19.8 | 1,802.4 | 29.4 | 89.20 | 1 | 1 | 0 |
| **%SI** | 16.7 | 16.7 | 16.7 | 16.7 | 16.67 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/15/2014 00:00 | 6.0 | 15.6 | 664.5 | 6.7 | 4.15 | 1 | 0 | 0 |
| 03/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 6.0 | 15.6 | 664.5 | 6.7 | 4.15 # | 1 # | 0 # | 0 # |
| **Minimum:** | 6.0 | 15.6 | 664.5 | 6.7 | 4.15 | 0 | 0 | 0 |
| **Maximum:** | 6.0 | 15.6 | 664.5 | 6.7 | 4.15 | 1 | 0 | 0 |
| **%SI** | 95.8 | 95.8 | 95.8 | 95.8 | 95.83 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/29/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/30/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/30/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - NOx

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 NOx, Ppm 1 Hour(s) | Unit CT2 O2, Dry, Pct 1 Hour(s) | Unit CT2 Hr, MBtuPerHr 1 Hour(s) | Unit CT2 NOx, Ppmvdc 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 UnitOn, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) | Unit CT2 DBOn, TF 1 Hour(s) |
| 03/31/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| 03/31/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.00 | 0 | 0 | 0 |

# ATTACHMENT 7
## Hourly Emissions CO (AQ-16)

# Excess Emission Report

## CT1 - CO Lb 1-Day Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT1_CO_Lb_1D
**Total Operating Time:** 1,178.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 982.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,178.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT2 - CO Lb 1-Day Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT2_CO_Lb_1D
**Total Operating Time:** 1,193.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 967.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,193.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/01/2014 00:00 | 0.3 | 13.9 | 1,626.5 | 0.3 | 0.9 | 1 | 1 | 0 |
| 01/01/2014 01:00 | 0.3 | 13.8 | 1,814.0 | 0.3 | 1.0 | 1 | 1 | 0 |
| 01/01/2014 02:00 | 0.3 | 13.8 | 1,691.3 | 0.2 | 0.9 | 1 | 1 | 0 |
| 01/01/2014 03:00 | 8.2 | 14.7 | 1,099.9 | 0.0 | 9.2 | 1 | 0 | 0 |
| 01/01/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| 01/01/2014 16:00 | 23.4 | 17.5 | 499.0 | 0.0 | 28.1 | 1 | 1 | 0 |
| 01/01/2014 17:00 | 20.7 | 14.9 | 1,054.7 | 0.0 | 48.1 | 1 | 1 | 0 |
| 01/01/2014 18:00 | 0.4 | 13.7 | 1,768.1 | 0.0 | 1.3 | 1 | 1 | 1 |
| 01/01/2014 19:00 | 1.1 | 12.7 | 2,052.6 | 0.0 | 3.6 | 1 | 1 | 1 |
| 01/01/2014 20:00 | 1.0 | 12.2 | 2,131.8 | 0.6 | 3.2 | 1 | 1 | 1 |
| 01/01/2014 21:00 | 1.0 | 12.2 | 2,153.2 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/01/2014 22:00 | 1.0 | 12.6 | 2,063.6 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/01/2014 23:00 | 1.0 | 12.6 | 2,066.6 | 0.7 | 3.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 4.9 | 13.7 | 1,668.4 | 0.5 | 106.2 # | 12 # | 12 # | 6 # |
| **Minimum:** | 0.3 | 12.2 | 499.0 | 0.2 | 0.9 | 0 | 0 | 0 |
| **Maximum:** | 23.4 | 17.5 | 2,153.2 | 0.7 | 48.1 | 1 | 1 | 1 |
| **%SI** | 50.0 | 50.0 | 50.0 | 70.8 | 50.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/02/2014 00:00 | 1.0 | 12.7 | 2,043.6 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/02/2014 01:00 | 0.5 | 13.5 | 1,838.8 | 0.6 | 1.6 | 1 | 1 | 1 |
| 01/02/2014 02:00 | 0.3 | 13.8 | 1,587.3 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/02/2014 03:00 | 0.3 | 13.8 | 1,712.8 | 0.3 | 1.0 | 1 | 1 | 0 |
| 01/02/2014 04:00 | 0.3 | 13.8 | 1,592.0 | 0.2 | 0.9 | 1 | 1 | 0 |
| 01/02/2014 05:00 | 0.6 | 13.5 | 1,800.6 | 0.3 | 1.9 | 1 | 1 | 1 |
| 01/02/2014 06:00 | 0.9 | 13.0 | 1,980.8 | 0.5 | 3.0 | 1 | 1 | 1 |
| 01/02/2014 07:00 | 0.9 | 13.0 | 1,973.4 | 0.6 | 3.0 | 1 | 1 | 1 |
| 01/02/2014 08:00 | 1.0 | 12.9 | 2,008.7 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/02/2014 09:00 | 1.0 | 12.9 | 2,020.3 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/02/2014 10:00 | 1.0 | 12.9 | 2,013.0 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/02/2014 11:00 | 1.0 | 12.8 | 2,012.1 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/02/2014 12:00 | 1.0 | 12.8 | 2,001.0 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/02/2014 13:00 | 1.0 | 12.8 | 1,991.0 | 0.7 | 3.2 | 1 | 1 | 1 |
| 01/02/2014 14:00 | 0.9 | 13.0 | 1,956.5 | 0.7 | 2.9 | 1 | 1 | 1 |
| 01/02/2014 15:00 | 1.0 | 12.8 | 1,989.5 | 0.7 | 3.2 | 1 | 1 | 1 |
| 01/02/2014 16:00 | 1.0 | 12.7 | 2,006.8 | 0.7 | 3.2 | 1 | 1 | 1 |
| 01/02/2014 17:00 | 1.0 | 12.6 | 2,016.2 | 0.7 | 3.2 | 1 | 1 | 1 |
| 01/02/2014 18:00 | 1.0 | 12.2 | 2,114.0 | 0.7 | 3.2 | 1 | 1 | 1 |
| 01/02/2014 19:00 | 0.9 | 12.1 | 2,137.2 | 0.7 | 2.9 | 1 | 1 | 1 |
| 01/02/2014 20:00 | 1.0 | 12.2 | 2,117.0 | 0.7 | 3.2 | 1 | 1 | 1 |
| 01/02/2014 21:00 | 1.0 | 12.3 | 2,106.4 | 0.7 | 3.2 | 1 | 1 | 1 |
| 01/02/2014 22:00 | 1.0 | 12.6 | 2,055.8 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/02/2014 23:00 | 1.0 | 12.3 | 2,116.9 | 0.7 | 3.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.9 | 12.9 | 1,966.3 | 0.6 | 66.9 # | 24 # | 24 # | 21 # |
| **Minimum:** | 0.3 | 12.1 | 1,587.3 | 0.2 | 0.9 | 1 | 1 | 0 |
| **Maximum:** | 1.0 | 13.8 | 2,137.2 | 0.7 | 3.3 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/03/2014 00:00 | 0.9 | 12.8 | 2,008.1 | 0.7 | 2.9 | 1 | 1 | 1 |
| 01/03/2014 01:00 | 0.4 | 13.6 | 1,747.2 | 0.6 | 1.3 | 1 | 1 | 1 |
| 01/03/2014 02:00 | 0.3 | 13.9 | 1,318.6 | 0.4 | 0.7 | 1 | 1 | 0 |
| 01/03/2014 03:00 | 0.3 | 13.9 | 1,243.4 | 0.3 | 0.7 | 1 | 1 | 0 |
| 01/03/2014 04:00 | 0.3 | 13.9 | 1,244.0 | 0.3 | 0.7 | 1 | 1 | 0 |
| 01/03/2014 05:00 | 0.4 | 13.9 | 1,246.6 | 0.3 | 0.9 | 1 | 1 | 0 |
| 01/03/2014 06:00 | 0.5 | 13.6 | 1,548.9 | 0.3 | 1.4 | 1 | 1 | 1 |
| 01/03/2014 07:00 | 0.8 | 13.2 | 1,896.9 | 0.4 | 2.6 | 1 | 1 | 1 |
| 01/03/2014 08:00 | 0.8 | 13.1 | 1,979.6 | 0.5 | 2.7 | 1 | 1 | 1 |
| 01/03/2014 09:00 | 1.0 | 12.9 | 2,027.5 | 0.6 | 3.3 | 1 | 1 | 1 |
| 01/03/2014 10:00 | 1.0 | 12.8 | 2,027.1 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/03/2014 11:00 | 1.0 | 12.8 | 2,016.2 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/03/2014 12:00 | 0.9 | 12.9 | 1,988.3 | 0.7 | 3.0 | 1 | 1 | 1 |
| 01/03/2014 13:00 | 0.9 | 12.9 | 1,975.7 | 0.7 | 2.9 | 1 | 1 | 1 |
| 01/03/2014 14:00 | 0.9 | 13.0 | 1,964.4 | 0.7 | 3.0 | 1 | 1 | 1 |
| 01/03/2014 15:00 | 0.8 | 13.1 | 1,934.6 | 0.7 | 2.6 | 1 | 1 | 1 |
| 01/03/2014 16:00 | 1.0 | 12.9 | 1,985.0 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/03/2014 17:00 | 1.1 | 12.5 | 2,047.8 | 0.7 | 3.5 | 1 | 1 | 1 |
| 01/03/2014 18:00 | 1.0 | 12.2 | 2,131.4 | 0.7 | 3.2 | 1 | 1 | 1 |
| 01/03/2014 19:00 | 1.0 | 12.3 | 2,088.7 | 0.7 | 3.2 | 1 | 1 | 1 |
| 01/03/2014 20:00 | 1.0 | 12.4 | 2,088.1 | 0.7 | 3.2 | 1 | 1 | 1 |
| 01/03/2014 21:00 | 0.8 | 11.7 | 2,219.5 | 0.6 | 2.5 | 1 | 1 | 1 |
| 01/03/2014 22:00 | 0.9 | 11.9 | 2,181.5 | 0.6 | 2.9 | 1 | 1 | 1 |
| 01/03/2014 23:00 | 1.0 | 12.2 | 2,135.6 | 0.6 | 3.2 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.8 | 12.9 | 1,876.9 | 0.6 | 60.3 # | 24 # | 24 # | 20 # |
| **Minimum:** | 0.3 | 11.7 | 1,243.4 | 0.3 | 0.7 | 1 | 1 | 0 |
| **Maximum:** | 1.1 | 13.9 | 2,219.5 | 0.7 | 3.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/04/2014 00:00 | 1.0 | 12.7 | 2,043.9 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/04/2014 01:00 | 1.0 | 12.6 | 2,065.5 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/04/2014 02:00 | 0.3 | 13.8 | 1,623.6 | 0.5 | 0.9 | 1 | 1 | 1 |
| 01/04/2014 03:00 | 0.3 | 13.8 | 1,596.0 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/04/2014 04:00 | 0.3 | 13.9 | 1,424.1 | 0.2 | 0.8 | 1 | 1 | 0 |
| 01/04/2014 05:00 | 0.3 | 13.8 | 1,654.2 | 0.2 | 0.9 | 1 | 1 | 0 |
| 01/04/2014 06:00 | 0.3 | 13.8 | 1,672.6 | 0.2 | 0.9 | 1 | 1 | 0 |
| 01/04/2014 07:00 | 0.3 | 13.7 | 1,825.6 | 0.2 | 1.0 | 1 | 1 | 0 |
| 01/04/2014 08:00 | 0.7 | 13.2 | 1,905.0 | 0.3 | 2.3 | 1 | 1 | 1 |
| 01/04/2014 09:00 | 1.2 | 12.4 | 2,103.5 | 0.5 | 3.9 | 1 | 1 | 1 |
| 01/04/2014 10:00 | 1.1 | 12.7 | 2,033.4 | 0.7 | 3.6 | 1 | 1 | 1 |
| 01/04/2014 11:00 | 0.9 | 12.9 | 1,972.8 | 0.8 | 2.9 | 1 | 1 | 1 |
| 01/04/2014 12:00 | 0.6 | 13.3 | 1,901.9 | 0.7 | 2.0 | 1 | 1 | 1 |
| 01/04/2014 13:00 | 0.6 | 13.5 | 1,856.6 | 0.6 | 2.0 | 1 | 1 | 1 |
| 01/04/2014 14:00 | 0.9 | 13.0 | 1,976.0 | 0.6 | 3.0 | 1 | 1 | 1 |
| 01/04/2014 15:00 | 1.0 | 12.7 | 2,017.1 | 0.6 | 3.2 | 1 | 1 | 1 |
| 01/04/2014 16:00 | 1.0 | 12.6 | 2,039.2 | 0.7 | 3.2 | 1 | 1 | 1 |
| 01/04/2014 17:00 | 1.0 | 12.5 | 2,081.3 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/04/2014 18:00 | 1.0 | 12.2 | 2,136.7 | 0.7 | 3.2 | 1 | 1 | 1 |
| 01/04/2014 19:00 | 0.9 | 12.2 | 2,139.0 | 0.7 | 2.9 | 1 | 1 | 1 |
| 01/04/2014 20:00 | 1.0 | 12.7 | 2,046.9 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/04/2014 21:00 | 0.9 | 11.9 | 2,198.9 | 0.6 | 2.9 | 1 | 1 | 1 |
| 01/04/2014 22:00 | 0.8 | 11.8 | 2,217.8 | 0.6 | 2.6 | 1 | 1 | 1 |
| 01/04/2014 23:00 | 0.9 | 12.6 | 2,043.8 | 0.6 | 2.9 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.8 | 12.9 | 1,940.6 | 0.6 | 59.2 # | 24 # | 24 # | 19 # |
| **Minimum:** | 0.3 | 11.8 | 1,424.1 | 0.2 | 0.8 | 1 | 1 | 0 |
| **Maximum:** | 1.2 | 13.9 | 2,217.8 | 0.8 | 3.9 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/05/2014 00:00 | 0.9 | 12.8 | 2,026.9 | 0.6 | 3.0 | 1 | 1 | 1 |
| 01/05/2014 01:00 | 1.0 | 12.5 | 2,066.8 | 0.7 | 3.2 | 1 | 1 | 1 |
| 01/05/2014 02:00 | 0.3 | 13.8 | 1,616.1 | 0.5 | 0.9 | 1 | 1 | 1 |
| 01/05/2014 03:00 | 0.2 | 13.9 | 1,596.8 | 0.4 | 0.6 | 1 | 1 | 0 |
| 01/05/2014 04:00 | 0.3 | 13.9 | 1,699.9 | 0.2 | 1.0 | 1 | 1 | 0 |
| 01/05/2014 05:00 | 0.3 | 13.8 | 1,827.2 | 0.2 | 1.0 | 1 | 1 | 0 |
| 01/05/2014 06:00 | 0.7 | 13.3 | 1,894.2 | 0.3 | 2.3 | 1 | 1 | 1 |
| 01/05/2014 07:00 | 1.1 | 12.4 | 2,089.7 | 0.5 | 3.6 | 1 | 1 | 1 |
| 01/05/2014 08:00 | 0.9 | 11.8 | 2,237.4 | 0.6 | 2.9 | 1 | 1 | 1 |
| 01/05/2014 09:00 | 0.9 | 12.0 | 2,192.0 | 0.7 | 2.9 | 1 | 1 | 1 |
| 01/05/2014 10:00 | 1.0 | 12.6 | 2,055.9 | 0.6 | 3.3 | 1 | 1 | 1 |
| 01/05/2014 11:00 | 0.8 | 12.9 | 1,981.7 | 0.6 | 2.6 | 1 | 1 | 1 |
| 01/05/2014 12:00 | 0.6 | 13.3 | 1,906.1 | 0.6 | 2.0 | 1 | 1 | 1 |
| 01/05/2014 13:00 | 0.7 | 13.2 | 1,942.3 | 0.5 | 2.3 | 1 | 1 | 1 |
| 01/05/2014 14:00 | 1.0 | 12.8 | 2,006.5 | 0.6 | 3.3 | 1 | 1 | 1 |
| 01/05/2014 15:00 | 0.3 | 13.9 | 1,633.4 | 0.5 | 0.9 | 1 | 1 | 1 |
| 01/05/2014 16:00 | 0.7 | 13.2 | 1,879.9 | 0.5 | 2.3 | 1 | 1 | 1 |
| 01/05/2014 17:00 | 0.9 | 12.0 | 2,170.6 | 0.5 | 2.9 | 1 | 1 | 1 |
| 01/05/2014 18:00 | 0.8 | 11.8 | 2,213.3 | 0.5 | 2.6 | 1 | 1 | 1 |
| 01/05/2014 19:00 | 0.8 | 11.8 | 2,214.0 | 0.5 | 2.6 | 1 | 1 | 1 |
| 01/05/2014 20:00 | 0.8 | 11.7 | 2,224.4 | 0.5 | 2.6 | 1 | 1 | 1 |
| 01/05/2014 21:00 | 0.8 | 11.8 | 2,217.5 | 0.5 | 2.6 | 1 | 1 | 1 |
| 01/05/2014 22:00 | 0.8 | 11.8 | 2,227.7 | 0.5 | 2.6 | 1 | 1 | 1 |
| 01/05/2014 23:00 | 0.9 | 12.1 | 2,171.6 | 0.5 | 2.9 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.7 | 12.7 | 2,003.8 | 0.5 | 56.9 # | 24 # | 24 # | 21 # |
| **Minimum:** | 0.2 | 11.7 | 1,596.8 | 0.2 | 0.6 | 1 | 1 | 0 |
| **Maximum:** | 1.1 | 13.9 | 2,237.4 | 0.7 | 3.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/06/2014 00:00 | 1.0 | 12.2 | 2,162.5 | 0.6 | 3.3 | 1 | 1 | 1 |
| 01/06/2014 01:00 | 1.0 | 12.5 | 2,088.4 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/06/2014 02:00 | 1.0 | 12.3 | 2,124.7 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/06/2014 03:00 | 0.9 | 12.9 | 2,009.4 | 0.7 | 3.0 | 1 | 1 | 1 |
| 01/06/2014 04:00 | 0.8 | 13.0 | 1,999.4 | 0.7 | 2.7 | 1 | 1 | 1 |
| 01/06/2014 05:00 | 1.0 | 12.2 | 2,157.5 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/06/2014 06:00 | 1.0 | 12.6 | 2,063.4 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/06/2014 07:00 | 1.0 | 12.7 | 2,032.9 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/06/2014 08:00 | 1.0 | 12.3 | 2,147.7 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/06/2014 09:00 | 1.1 | 12.5 | 2,116.1 | 0.7 | 3.7 | 1 | 1 | 1 |
| 01/06/2014 10:00 | 1.1 | 12.3 | 2,149.0 | 0.8 | 3.6 | 1 | 1 | 1 |
| 01/06/2014 11:00 | 1.0 | 12.0 | 2,191.9 | 0.8 | 3.3 | 1 | 1 | 1 |
| 01/06/2014 12:00 | 0.9 | 12.0 | 2,202.6 | 0.7 | 2.9 | 1 | 1 | 1 |
| 01/06/2014 13:00 | 0.9 | 11.9 | 2,215.1 | 0.6 | 2.9 | 1 | 1 | 1 |
| 01/06/2014 14:00 | 0.9 | 12.3 | 2,118.5 | 0.6 | 2.9 | 1 | 1 | 1 |
| 01/06/2014 15:00 | 0.9 | 12.9 | 2,002.1 | 0.6 | 3.0 | 1 | 1 | 1 |
| 01/06/2014 16:00 | 0.9 | 12.8 | 2,015.5 | 0.7 | 3.0 | 1 | 1 | 1 |
| 01/06/2014 17:00 | 1.1 | 12.6 | 2,072.7 | 0.7 | 3.6 | 1 | 1 | 1 |
| 01/06/2014 18:00 | 1.0 | 12.5 | 2,089.5 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/06/2014 19:00 | 0.9 | 11.9 | 2,219.6 | 0.7 | 2.9 | 1 | 1 | 1 |
| 01/06/2014 20:00 | 1.0 | 12.4 | 2,106.4 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/06/2014 21:00 | 0.9 | 11.9 | 2,236.4 | 0.6 | 3.0 | 1 | 1 | 1 |
| 01/06/2014 22:00 | 0.9 | 11.8 | 2,246.7 | 0.6 | 2.9 | 1 | 1 | 1 |
| 01/06/2014 23:00 | 1.0 | 12.4 | 2,107.4 | 0.6 | 3.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.0 | 12.4 | 2,119.8 | 0.7 | 76.4 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.8 | 11.8 | 1,999.4 | 0.6 | 2.7 | 1 | 1 | 1 |
| **Maximum:** | 1.1 | 13.0 | 2,246.7 | 0.8 | 3.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/07/2014 00:00 | 0.8 | 13.1 | 1,956.6 | 0.6 | 2.7 | 1 | 1 | 1 |
| 01/07/2014 01:00 | 0.5 | 13.4 | 1,746.2 | 0.6 | 1.5 | 1 | 1 | 1 |
| 01/07/2014 02:00 | 0.3 | 13.9 | 1,487.7 | 0.4 | 0.8 | 1 | 1 | 0 |
| 01/07/2014 03:00 | 0.3 | 13.8 | 1,592.1 | 0.3 | 0.9 | 1 | 1 | 0 |
| 01/07/2014 04:00 | 0.3 | 13.9 | 1,579.1 | 0.3 | 0.9 | 1 | 1 | 0 |
| 01/07/2014 05:00 | 0.3 | 13.9 | 1,595.7 | 0.3 | 0.9 | 1 | 1 | 0 |
| 01/07/2014 06:00 | 0.5 | 13.5 | 1,788.2 | 0.3 | 1.6 | 1 | 1 | 1 |
| 01/07/2014 07:00 | 0.9 | 12.9 | 1,998.5 | 0.5 | 3.0 | 1 | 1 | 1 |
| 01/07/2014 08:00 | 1.0 | 12.4 | 2,138.8 | 0.6 | 3.3 | 1 | 1 | 1 |
| 01/07/2014 09:00 | 1.0 | 12.4 | 2,129.8 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/07/2014 10:00 | 1.0 | 12.7 | 2,065.3 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/07/2014 11:00 | 1.0 | 12.8 | 2,039.9 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/07/2014 12:00 | 1.0 | 12.0 | 2,213.6 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/07/2014 13:00 | 1.0 | 11.9 | 2,207.8 | 0.7 | 3.2 | 1 | 1 | 1 |
| 01/07/2014 14:00 | 1.1 | 12.6 | 2,061.0 | 0.7 | 3.6 | 1 | 1 | 1 |
| 01/07/2014 15:00 | 1.1 | 12.5 | 2,074.1 | 0.8 | 3.6 | 1 | 1 | 1 |
| 01/07/2014 16:00 | 0.9 | 13.0 | 1,981.0 | 0.8 | 3.0 | 1 | 1 | 1 |
| 01/07/2014 17:00 | 0.9 | 13.0 | 1,982.6 | 0.7 | 3.0 | 1 | 1 | 1 |
| 01/07/2014 18:00 | 1.1 | 12.7 | 2,035.4 | 0.7 | 3.6 | 1 | 1 | 1 |
| 01/07/2014 19:00 | 1.1 | 12.1 | 2,172.2 | 0.7 | 3.6 | 1 | 1 | 1 |
| 01/07/2014 20:00 | 0.9 | 11.8 | 2,221.0 | 0.7 | 2.9 | 1 | 1 | 1 |
| 01/07/2014 21:00 | 1.0 | 12.6 | 2,061.3 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/07/2014 22:00 | 1.0 | 12.8 | 2,036.4 | 0.7 | 3.3 | 1 | 1 | 1 |
| 01/07/2014 23:00 | 0.7 | 13.2 | 1,875.4 | 0.6 | 2.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.8 | 12.9 | 1,960.0 | 0.6 | 64.2 # | 24 # | 24 # | 20 # |
| **Minimum:** | 0.3 | 11.8 | 1,487.7 | 0.3 | 0.8 | 1 | 1 | 0 |
| **Maximum:** | 1.1 | 13.9 | 2,221.0 | 0.8 | 3.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/08/2014 00:00 | 0.3 | 13.9 | 1,360.2 | 0.5 | 0.8 | 1 | 1 | 0 |
| 01/08/2014 01:00 | 0.3 | 13.9 | 1,310.4 | 0.4 | 0.7 | 1 | 1 | 0 |
| 01/08/2014 02:00 | 0.3 | 13.9 | 1,284.3 | 0.3 | 0.7 | 1 | 1 | 0 |
| 01/08/2014 03:00 | 0.4 | 13.9 | 1,260.1 | 0.3 | 1.0 | 1 | 1 | 0 |
| 01/08/2014 04:00 | 0.4 | 13.9 | 1,293.2 | 0.3 | 1.0 | 1 | 1 | 0 |
| 01/08/2014 05:00 | 0.4 | 13.8 | 1,632.4 | 0.3 | 1.2 | 1 | 1 | 0 |
| 01/08/2014 06:00 | 0.5 | 13.6 | 1,700.8 | 0.3 | 1.5 | 1 | 1 | 1 |
| 01/08/2014 07:00 | 0.7 | 13.3 | 1,919.2 | 0.4 | 2.3 | 1 | 1 | 1 |
| 01/08/2014 08:00 | 0.8 | 13.0 | 1,994.2 | 0.5 | 2.7 | 1 | 1 | 1 |
| 01/08/2014 09:00 | 0.5 | 13.6 | 1,761.9 | 0.5 | 1.6 | 1 | 1 | 1 |
| 01/08/2014 10:00 | 0.4 | 13.9 | 1,237.5 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/08/2014 11:00 | 0.4 | 13.9 | 1,378.5 | 0.3 | 1.0 | 1 | 1 | 0 |
| 01/08/2014 12:00 | 0.3 | 13.7 | 1,703.6 | 0.3 | 0.9 | 1 | 1 | 0 |
| 01/08/2014 13:00 | 0.3 | 13.9 | 1,480.3 | 0.3 | 0.8 | 1 | 1 | 0 |
| 01/08/2014 14:00 | 0.3 | 13.9 | 1,254.4 | 0.3 | 0.7 | 1 | 1 | 0 |
| 01/08/2014 15:00 | 0.3 | 13.9 | 1,400.6 | 0.3 | 0.8 | 1 | 1 | 0 |
| 01/08/2014 16:00 | 0.3 | 13.9 | 1,525.8 | 0.3 | 0.9 | 1 | 1 | 0 |
| 01/08/2014 17:00 | 0.8 | 13.4 | 1,807.0 | 0.4 | 2.5 | 1 | 1 | 1 |
| 01/08/2014 18:00 | 0.3 | 13.9 | 1,432.1 | 0.4 | 0.8 | 1 | 1 | 0 |
| 01/08/2014 19:00 | 0.3 | 13.8 | 1,530.1 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/08/2014 20:00 | 0.3 | 13.9 | 1,485.5 | 0.3 | 0.8 | 1 | 1 | 0 |
| 01/08/2014 21:00 | 0.3 | 13.9 | 1,488.5 | 0.3 | 0.8 | 1 | 1 | 0 |
| 01/08/2014 22:00 | 9.9 | 15.4 | 726.3 | 0.0 | 4.7 | 1 | 0 | 0 |
| 01/08/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.8 | 13.8 | 1,476.8 | 0.4 | 30.0 # | 23 # | 22 # | 5 # |
| **Minimum:** | 0.3 | 13.0 | 726.3 | 0.3 | 0.7 | 0 | 0 | 0 |
| **Maximum:** | 9.9 | 15.4 | 1,994.2 | 0.5 | 4.7 | 1 | 1 | 1 |
| **%SI** | 4.2 | 4.2 | 4.2 | 8.3 | 4.2 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/09/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/10/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/12/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/13/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/14/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/15/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| 01/29/2014 14:00 | 73.3 | 17.4 | 529.1 | 0.0 | 121.4 | 1 | 1 | 0 |
| 01/29/2014 15:00 | 20.5 | 15.8 | 760.9 | 0.0 | 40.4 | 1 | 1 | 0 |
| 01/29/2014 16:00 | 0.3 | 13.9 | 1,323.7 | 0.0 | 0.7 | 1 | 1 | 0 |
| 01/29/2014 17:00 | 0.3 | 13.8 | 1,541.8 | 0.0 | 0.9 | 1 | 1 | 0 |
| 01/29/2014 18:00 | 0.3 | 13.7 | 1,819.4 | 0.0 | 1.0 | 1 | 1 | 0 |
| 01/29/2014 19:00 | 0.3 | 13.7 | 1,819.3 | 0.2 | 1.0 | 1 | 1 | 0 |
| 01/29/2014 20:00 | 0.3 | 13.8 | 1,752.4 | 0.2 | 1.0 | 1 | 1 | 0 |
| 01/29/2014 21:00 | 0.3 | 13.8 | 1,806.5 | 0.2 | 1.0 | 1 | 1 | 0 |
| 01/29/2014 22:00 | 0.3 | 13.8 | 1,667.6 | 0.2 | 0.9 | 1 | 1 | 0 |
| 01/29/2014 23:00 | 0.4 | 13.9 | 1,291.9 | 0.2 | 1.0 | 1 | 1 | 0 |
| **Average/Sum#:** | 9.6 | 14.4 | 1,431.3 | 0.2 | 169.3 # | 10 # | 11 # | 0 # |
| **Minimum:** | 0.3 | 13.7 | 529.1 | 0.2 | 0.7 | 0 | 0 | 0 |
| **Maximum:** | 73.3 | 17.4 | 1,819.4 | 0.2 | 121.4 | 1 | 1 | 0 |
| **%SI** | 58.3 | 58.3 | 58.3 | 79.2 | 58.3 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/30/2014 00:00 | 0.4 | 13.9 | 1,463.8 | 0.3 | 1.1 | 1 | 1 | 0 |
| 01/30/2014 01:00 | 0.4 | 13.8 | 1,752.9 | 0.3 | 1.3 | 1 | 1 | 0 |
| 01/30/2014 02:00 | 0.4 | 13.9 | 1,327.6 | 0.3 | 1.0 | 1 | 1 | 0 |
| 01/30/2014 03:00 | 0.4 | 13.9 | 1,257.1 | 0.3 | 0.9 | 1 | 1 | 0 |
| 01/30/2014 04:00 | 0.4 | 13.9 | 1,282.4 | 0.3 | 1.0 | 1 | 1 | 0 |
| 01/30/2014 05:00 | 0.4 | 14.0 | 1,254.0 | 0.3 | 1.0 | 1 | 1 | 0 |
| 01/30/2014 06:00 | 0.4 | 13.9 | 1,447.9 | 0.3 | 1.1 | 1 | 1 | 0 |
| 01/30/2014 07:00 | 0.4 | 14.0 | 1,542.8 | 0.3 | 1.2 | 1 | 1 | 0 |
| 01/30/2014 08:00 | 0.4 | 13.9 | 1,553.6 | 0.3 | 1.2 | 1 | 1 | 0 |
| 01/30/2014 09:00 | 0.4 | 14.0 | 1,242.6 | 0.3 | 1.0 | 1 | 1 | 0 |
| 01/30/2014 10:00 | 0.4 | 13.8 | 1,516.0 | 0.3 | 1.1 | 1 | 1 | 1 |
| 01/30/2014 11:00 | 0.4 | 13.8 | 1,804.8 | 0.3 | 1.3 | 1 | 1 | 1 |
| 01/30/2014 12:00 | 0.9 | 13.2 | 1,906.8 | 0.4 | 2.9 | 1 | 1 | 1 |
| 01/30/2014 13:00 | 1.2 | 12.4 | 2,065.3 | 0.6 | 3.9 | 1 | 1 | 1 |
| 01/30/2014 14:00 | 1.0 | 12.0 | 2,168.8 | 0.7 | 3.2 | 1 | 1 | 1 |
| 01/30/2014 15:00 | 0.9 | 11.8 | 2,200.4 | 0.7 | 2.9 | 1 | 1 | 1 |
| 01/30/2014 16:00 | 0.7 | 12.9 | 1,880.9 | 0.6 | 2.2 | 1 | 1 | 1 |
| 01/30/2014 17:00 | 0.3 | 13.9 | 1,571.0 | 0.5 | 0.9 | 1 | 1 | 1 |
| 01/30/2014 18:00 | 0.3 | 13.9 | 1,642.0 | 0.4 | 0.9 | 1 | 1 | 0 |
| 01/30/2014 19:00 | 0.9 | 13.1 | 1,921.0 | 0.4 | 2.9 | 1 | 1 | 1 |
| 01/30/2014 20:00 | 1.1 | 12.5 | 2,045.7 | 0.6 | 3.5 | 1 | 1 | 1 |
| 01/30/2014 21:00 | 1.1 | 12.6 | 2,027.2 | 0.8 | 3.5 | 1 | 1 | 1 |
| 01/30/2014 22:00 | 0.9 | 13.0 | 1,948.7 | 0.8 | 2.9 | 1 | 1 | 1 |
| 01/30/2014 23:00 | 0.6 | 13.4 | 1,837.7 | 0.7 | 1.9 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.6 | 13.4 | 1,694.2 | 0.5 | 44.8 # | 24 # | 24 # | 13 # |
| **Minimum:** | 0.3 | 11.8 | 1,242.6 | 0.3 | 0.9 | 1 | 1 | 0 |
| **Maximum:** | 1.2 | 14.0 | 2,200.4 | 0.8 | 3.9 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/31/2014 00:00 | 0.3 | 13.9 | 1,532.7 | 0.5 | 0.9 | 1 | 1 | 0 |
| 01/31/2014 01:00 | 0.3 | 13.9 | 1,489.3 | 0.4 | 0.8 | 1 | 1 | 0 |
| 01/31/2014 02:00 | 0.3 | 13.9 | 1,620.1 | 0.3 | 0.9 | 1 | 1 | 0 |
| 01/31/2014 03:00 | 0.3 | 14.0 | 1,406.6 | 0.3 | 0.8 | 1 | 1 | 0 |
| 01/31/2014 04:00 | 0.4 | 14.0 | 1,324.5 | 0.3 | 1.0 | 1 | 1 | 0 |
| 01/31/2014 05:00 | 0.3 | 13.8 | 1,753.3 | 0.3 | 1.0 | 1 | 1 | 0 |
| 01/31/2014 06:00 | 0.5 | 13.7 | 1,810.4 | 0.3 | 1.7 | 1 | 1 | 1 |
| 01/31/2014 07:00 | 0.3 | 13.8 | 1,823.0 | 0.3 | 1.0 | 1 | 1 | 0 |
| 01/31/2014 08:00 | 0.3 | 13.8 | 1,828.8 | 0.3 | 1.0 | 1 | 1 | 0 |
| 01/31/2014 09:00 | 0.3 | 13.9 | 1,799.9 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/31/2014 10:00 | 0.5 | 13.8 | 1,813.5 | 0.3 | 1.7 | 1 | 1 | 1 |
| 01/31/2014 11:00 | 0.7 | 13.4 | 1,899.1 | 0.4 | 2.3 | 1 | 1 | 1 |
| 01/31/2014 12:00 | 0.9 | 13.0 | 1,973.4 | 0.6 | 3.0 | 1 | 1 | 1 |
| 01/31/2014 13:00 | 0.9 | 13.0 | 1,976.9 | 0.7 | 3.0 | 1 | 1 | 1 |
| 01/31/2014 14:00 | 0.7 | 13.2 | 1,925.2 | 0.6 | 2.3 | 1 | 1 | 1 |
| 01/31/2014 15:00 | 0.7 | 13.4 | 1,906.5 | 0.6 | 2.4 | 1 | 1 | 1 |
| 01/31/2014 16:00 | 0.7 | 13.4 | 1,904.1 | 0.6 | 2.3 | 1 | 1 | 1 |
| 01/31/2014 17:00 | 0.7 | 13.3 | 1,923.5 | 0.6 | 2.3 | 1 | 1 | 1 |
| 01/31/2014 18:00 | 0.7 | 13.4 | 1,900.1 | 0.6 | 2.3 | 1 | 1 | 1 |
| 01/31/2014 19:00 | 1.1 | 12.7 | 2,054.6 | 0.6 | 3.6 | 1 | 1 | 1 |
| 01/31/2014 20:00 | 0.9 | 12.9 | 1,995.8 | 0.7 | 3.0 | 1 | 1 | 1 |
| 01/31/2014 21:00 | 1.1 | 12.7 | 2,045.1 | 0.8 | 3.6 | 1 | 1 | 1 |
| 01/31/2014 22:00 | 1.1 | 12.4 | 2,114.0 | 0.8 | 3.6 | 1 | 1 | 1 |
| 01/31/2014 23:00 | 1.0 | 12.5 | 2,094.4 | 0.8 | 3.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.6 | 13.4 | 1,829.8 | 0.5 | 48.8 # | 24 # | 24 # | 16 # |
| **Minimum:** | 0.3 | 12.4 | 1,324.5 | 0.2 | 0.8 | 1 | 1 | 0 |
| **Maximum:** | 1.1 | 14.0 | 2,114.0 | 0.8 | 3.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/01/2014 00:00 | 0.6 | 13.4 | 1,784.0 | 0.7 | 1.9 | 1 | 1 | 1 |
| 02/01/2014 01:00 | 0.3 | 13.9 | 1,621.2 | 0.5 | 0.9 | 1 | 1 | 0 |
| 02/01/2014 02:00 | 0.3 | 13.9 | 1,653.3 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/01/2014 03:00 | 0.3 | 13.8 | 1,780.3 | 0.3 | 1.0 | 1 | 1 | 0 |
| 02/01/2014 04:00 | 0.3 | 13.9 | 1,462.6 | 0.3 | 0.8 | 1 | 1 | 0 |
| 02/01/2014 05:00 | 0.8 | 13.3 | 1,855.8 | 0.4 | 2.6 | 1 | 1 | 1 |
| 02/01/2014 06:00 | 1.2 | 12.0 | 2,210.1 | 0.6 | 3.9 | 1 | 1 | 1 |
| 02/01/2014 07:00 | 1.1 | 12.0 | 2,210.3 | 0.7 | 3.6 | 1 | 1 | 1 |
| 02/01/2014 08:00 | 1.1 | 12.3 | 2,157.4 | 0.8 | 3.6 | 1 | 1 | 1 |
| 02/01/2014 09:00 | 1.1 | 12.6 | 2,098.2 | 0.8 | 3.7 | 1 | 1 | 1 |
| 02/01/2014 10:00 | 0.6 | 13.5 | 1,829.8 | 0.7 | 2.0 | 1 | 1 | 1 |
| 02/01/2014 11:00 | 0.3 | 13.9 | 1,561.8 | 0.5 | 0.9 | 1 | 1 | 0 |
| 02/01/2014 12:00 | 0.3 | 13.9 | 1,539.0 | 0.4 | 0.9 | 1 | 1 | 0 |
| 02/01/2014 13:00 | 0.3 | 13.9 | 1,588.2 | 0.3 | 0.9 | 1 | 1 | 0 |
| 02/01/2014 14:00 | 0.3 | 14.0 | 1,441.6 | 0.3 | 0.8 | 1 | 1 | 0 |
| 02/01/2014 15:00 | 0.3 | 14.0 | 1,256.1 | 0.3 | 0.7 | 1 | 1 | 0 |
| 02/01/2014 16:00 | 0.3 | 14.0 | 1,306.3 | 0.3 | 0.8 | 1 | 1 | 0 |
| 02/01/2014 17:00 | 0.6 | 13.6 | 1,684.2 | 0.4 | 1.8 | 1 | 1 | 1 |
| 02/01/2014 18:00 | 1.0 | 12.9 | 1,993.9 | 0.5 | 3.3 | 1 | 1 | 1 |
| 02/01/2014 19:00 | 1.1 | 12.0 | 2,182.5 | 0.6 | 3.6 | 1 | 1 | 1 |
| 02/01/2014 20:00 | 1.0 | 11.8 | 2,231.6 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/01/2014 21:00 | 1.0 | 11.8 | 2,233.4 | 0.6 | 3.2 | 1 | 1 | 1 |
| 02/01/2014 22:00 | 1.0 | 11.9 | 2,229.5 | 0.6 | 3.3 | 1 | 1 | 1 |
| 02/01/2014 23:00 | 1.1 | 12.1 | 2,211.6 | 0.7 | 3.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.7 | 13.1 | 1,838.4 | 0.5 | 52.0 # | 24 # | 24 # | 14 # |
| **Minimum:** | 0.3 | 11.8 | 1,256.1 | 0.3 | 0.7 | 1 | 1 | 0 |
| **Maximum:** | 1.2 | 14.0 | 2,233.4 | 0.8 | 3.9 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/02/2014 00:00 | 1.1 | 12.3 | 2,147.3 | 0.7 | 3.6 | 1 | 1 | 1 |
| 02/02/2014 01:00 | 1.1 | 12.7 | 2,070.2 | 0.8 | 3.7 | 1 | 1 | 1 |
| 02/02/2014 02:00 | 1.1 | 12.7 | 2,064.8 | 0.8 | 3.7 | 1 | 1 | 1 |
| 02/02/2014 03:00 | 1.0 | 12.7 | 2,076.0 | 0.8 | 3.3 | 1 | 1 | 1 |
| 02/02/2014 04:00 | 0.9 | 13.0 | 2,029.1 | 0.7 | 3.1 | 1 | 1 | 1 |
| 02/02/2014 05:00 | 0.9 | 13.0 | 2,028.9 | 0.7 | 3.1 | 1 | 1 | 1 |
| 02/02/2014 06:00 | 1.0 | 12.9 | 2,044.6 | 0.7 | 3.4 | 1 | 1 | 1 |
| 02/02/2014 07:00 | 1.2 | 12.1 | 2,193.1 | 0.7 | 3.9 | 1 | 1 | 1 |
| 02/02/2014 08:00 | 1.2 | 12.0 | 2,237.2 | 0.8 | 4.0 | 1 | 1 | 1 |
| 02/02/2014 09:00 | 1.1 | 12.0 | 2,236.5 | 0.8 | 3.7 | 1 | 1 | 1 |
| 02/02/2014 10:00 | 1.1 | 11.9 | 2,229.5 | 0.7 | 3.6 | 1 | 1 | 1 |
| 02/02/2014 11:00 | 1.0 | 11.9 | 2,228.9 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/02/2014 12:00 | 1.0 | 11.9 | 2,216.7 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/02/2014 13:00 | 1.0 | 12.0 | 2,195.5 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/02/2014 14:00 | 1.1 | 12.6 | 2,061.3 | 0.7 | 3.6 | 1 | 1 | 1 |
| 02/02/2014 15:00 | 1.0 | 11.9 | 2,207.7 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/02/2014 16:00 | 0.9 | 11.8 | 2,240.9 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/02/2014 17:00 | 1.0 | 12.3 | 2,126.4 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/02/2014 18:00 | 0.7 | 13.1 | 1,951.7 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/02/2014 19:00 | 1.1 | 12.5 | 2,097.7 | 0.7 | 3.6 | 1 | 1 | 1 |
| 02/02/2014 20:00 | 1.1 | 11.9 | 2,206.3 | 0.7 | 3.6 | 1 | 1 | 1 |
| 02/02/2014 21:00 | 1.0 | 11.8 | 2,233.7 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/02/2014 22:00 | 1.1 | 12.2 | 2,145.2 | 0.7 | 3.6 | 1 | 1 | 1 |
| 02/02/2014 23:00 | 1.0 | 11.9 | 2,214.8 | 0.7 | 3.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.0 | 12.3 | 2,145.2 | 0.7 | 81.6 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.7 | 11.8 | 1,951.7 | 0.6 | 2.3 | 1 | 1 | 1 |
| **Maximum:** | 1.2 | 13.1 | 2,240.9 | 0.8 | 4.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/03/2014 00:00 | 1.0 | 12.0 | 2,190.2 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/03/2014 01:00 | 1.1 | 12.5 | 2,077.3 | 0.7 | 3.6 | 1 | 1 | 1 |
| 02/03/2014 02:00 | 0.9 | 13.0 | 1,988.6 | 0.7 | 3.0 | 1 | 1 | 1 |
| 02/03/2014 03:00 | 0.8 | 13.1 | 1,957.6 | 0.7 | 2.7 | 1 | 1 | 1 |
| 02/03/2014 04:00 | 0.8 | 13.1 | 2,001.5 | 0.6 | 2.7 | 1 | 1 | 1 |
| 02/03/2014 05:00 | 1.2 | 12.6 | 2,098.1 | 0.7 | 4.0 | 1 | 1 | 1 |
| 02/03/2014 06:00 | 1.0 | 12.8 | 2,035.0 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/03/2014 07:00 | 1.1 | 12.7 | 2,046.9 | 0.8 | 3.6 | 1 | 1 | 1 |
| 02/03/2014 08:00 | 1.2 | 12.1 | 2,201.2 | 0.8 | 4.0 | 1 | 1 | 1 |
| 02/03/2014 09:00 | 1.1 | 12.3 | 2,155.8 | 0.8 | 3.6 | 1 | 1 | 1 |
| 02/03/2014 10:00 | 1.1 | 12.7 | 2,060.9 | 0.8 | 3.7 | 1 | 1 | 1 |
| 02/03/2014 11:00 | 0.7 | 13.3 | 1,882.4 | 0.7 | 2.3 | 1 | 1 | 1 |
| 02/03/2014 12:00 | 0.7 | 13.2 | 1,914.5 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/03/2014 13:00 | 0.9 | 13.0 | 1,969.8 | 0.6 | 3.0 | 1 | 1 | 1 |
| 02/03/2014 14:00 | 1.0 | 13.0 | 1,987.3 | 0.6 | 3.3 | 1 | 1 | 1 |
| 02/03/2014 15:00 | 0.8 | 13.1 | 1,944.2 | 0.7 | 2.6 | 1 | 1 | 1 |
| 02/03/2014 16:00 | 0.9 | 13.0 | 1,970.7 | 0.7 | 3.0 | 1 | 1 | 1 |
| 02/03/2014 17:00 | 1.0 | 12.6 | 2,057.4 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/03/2014 18:00 | 1.0 | 11.9 | 2,203.6 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/03/2014 19:00 | 0.9 | 11.7 | 2,241.6 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/03/2014 20:00 | 0.9 | 11.7 | 2,240.3 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/03/2014 21:00 | 0.9 | 11.8 | 2,225.8 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/03/2014 22:00 | 1.0 | 12.0 | 2,191.8 | 0.6 | 3.3 | 1 | 1 | 1 |
| 02/03/2014 23:00 | 1.0 | 12.4 | 2,101.1 | 0.7 | 3.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.0 | 12.6 | 2,072.7 | 0.7 | 75.8 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.7 | 11.7 | 1,882.4 | 0.6 | 2.3 | 1 | 1 | 1 |
| **Maximum:** | 1.2 | 13.3 | 2,241.6 | 0.8 | 4.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/04/2014 00:00 | 1.0 | 12.8 | 2,063.1 | 0.7 | 3.4 | 1 | 1 | 1 |
| 02/04/2014 01:00 | 0.8 | 13.0 | 2,008.1 | 0.7 | 2.7 | 1 | 1 | 1 |
| 02/04/2014 02:00 | 0.7 | 13.2 | 1,918.2 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/04/2014 03:00 | 0.8 | 13.2 | 1,955.3 | 0.6 | 2.7 | 1 | 1 | 1 |
| 02/04/2014 04:00 | 0.7 | 13.3 | 1,853.3 | 0.5 | 2.3 | 1 | 1 | 1 |
| 02/04/2014 05:00 | 0.7 | 13.2 | 1,820.8 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/04/2014 06:00 | 0.9 | 13.0 | 1,983.7 | 0.6 | 3.0 | 1 | 1 | 1 |
| 02/04/2014 07:00 | 0.9 | 13.0 | 2,016.1 | 0.6 | 3.0 | 1 | 1 | 1 |
| 02/04/2014 08:00 | 0.9 | 13.0 | 2,019.7 | 0.7 | 3.0 | 1 | 1 | 1 |
| 02/04/2014 09:00 | 0.8 | 13.2 | 1,959.7 | 0.7 | 2.7 | 1 | 1 | 1 |
| 02/04/2014 10:00 | 0.9 | 13.1 | 1,998.1 | 0.7 | 3.0 | 1 | 1 | 1 |
| 02/04/2014 11:00 | 0.9 | 13.0 | 2,003.0 | 0.7 | 3.0 | 1 | 1 | 1 |
| 02/04/2014 12:00 | 0.8 | 13.1 | 1,963.2 | 0.7 | 2.7 | 1 | 1 | 1 |
| 02/04/2014 13:00 | 0.7 | 13.3 | 1,901.2 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/04/2014 14:00 | 1.0 | 12.9 | 2,003.7 | 0.6 | 3.3 | 1 | 1 | 1 |
| 02/04/2014 15:00 | 1.1 | 12.7 | 2,049.0 | 0.7 | 3.6 | 1 | 1 | 1 |
| 02/04/2014 16:00 | 1.0 | 12.8 | 2,010.6 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/04/2014 17:00 | 1.0 | 12.9 | 2,015.5 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/04/2014 18:00 | 1.2 | 12.5 | 2,097.9 | 0.7 | 4.0 | 1 | 1 | 1 |
| 02/04/2014 19:00 | 1.1 | 12.0 | 2,193.6 | 0.7 | 3.6 | 1 | 1 | 1 |
| 02/04/2014 20:00 | 1.1 | 12.1 | 2,162.3 | 0.7 | 3.6 | 1 | 1 | 1 |
| 02/04/2014 21:00 | 1.0 | 11.8 | 2,226.6 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/04/2014 22:00 | 1.0 | 12.0 | 2,198.2 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/04/2014 23:00 | 1.1 | 12.6 | 2,075.6 | 0.7 | 3.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.9 | 12.8 | 2,020.7 | 0.7 | 73.1 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.7 | 11.8 | 1,820.8 | 0.5 | 2.2 | 1 | 1 | 1 |
| **Maximum:** | 1.2 | 13.3 | 2,226.6 | 0.7 | 4.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/05/2014 00:00 | 1.0 | 12.8 | 2,023.4 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/05/2014 01:00 | 0.7 | 13.3 | 1,859.3 | 0.7 | 2.3 | 1 | 1 | 1 |
| 02/05/2014 02:00 | 0.7 | 13.3 | 1,830.4 | 0.6 | 2.2 | 1 | 1 | 1 |
| 02/05/2014 03:00 | 0.7 | 13.3 | 1,838.8 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/05/2014 04:00 | 0.8 | 13.3 | 1,841.6 | 0.5 | 2.6 | 1 | 1 | 1 |
| 02/05/2014 05:00 | 0.8 | 13.3 | 1,874.5 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/05/2014 06:00 | 0.8 | 13.2 | 1,933.1 | 0.6 | 2.7 | 1 | 1 | 1 |
| 02/05/2014 07:00 | 1.2 | 12.3 | 2,100.1 | 0.7 | 3.9 | 1 | 1 | 1 |
| 02/05/2014 08:00 | 1.2 | 12.0 | 2,216.6 | 0.7 | 3.9 | 1 | 1 | 1 |
| 02/05/2014 09:00 | 0.9 | 12.9 | 2,048.2 | 0.8 | 3.0 | 1 | 1 | 1 |
| 02/05/2014 10:00 | 0.5 | 13.8 | 1,343.5 | 0.6 | 1.2 | 1 | 1 | 1 |
| 02/05/2014 11:00 | 0.6 | 13.5 | 1,551.5 | 0.5 | 1.7 | 1 | 1 | 1 |
| 02/05/2014 12:00 | 1.2 | 11.9 | 2,232.9 | 0.6 | 3.9 | 1 | 1 | 1 |
| 02/05/2014 13:00 | 1.0 | 12.2 | 2,150.7 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/05/2014 14:00 | 0.7 | 13.3 | 1,860.8 | 0.7 | 2.3 | 1 | 1 | 1 |
| 02/05/2014 15:00 | 0.7 | 13.3 | 1,830.0 | 0.6 | 2.2 | 1 | 1 | 1 |
| 02/05/2014 16:00 | 0.7 | 13.3 | 1,851.8 | 0.5 | 2.3 | 1 | 1 | 1 |
| 02/05/2014 17:00 | 1.0 | 12.9 | 2,004.7 | 0.6 | 3.3 | 1 | 1 | 1 |
| 02/05/2014 18:00 | 1.1 | 12.6 | 2,055.5 | 0.7 | 3.6 | 1 | 1 | 1 |
| 02/05/2014 19:00 | 1.1 | 11.8 | 2,228.3 | 0.7 | 3.6 | 1 | 1 | 1 |
| 02/05/2014 20:00 | 1.0 | 11.7 | 2,248.5 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/05/2014 21:00 | 1.0 | 11.7 | 2,241.4 | 0.6 | 3.2 | 1 | 1 | 1 |
| 02/05/2014 22:00 | 1.0 | 11.7 | 2,239.6 | 0.6 | 3.2 | 1 | 1 | 1 |
| 02/05/2014 23:00 | 1.0 | 11.7 | 2,239.7 | 0.6 | 3.2 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.9 | 12.7 | 1,985.2 | 0.6 | 68.9 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.5 | 11.7 | 1,343.5 | 0.5 | 1.2 | 1 | 1 | 1 |
| **Maximum:** | 1.2 | 13.8 | 2,248.5 | 0.8 | 3.9 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/06/2014 00:00 | 1.0 | 12.0 | 2,195.1 | 0.6 | 3.3 | 1 | 1 | 1 |
| 02/06/2014 01:00 | 0.8 | 13.1 | 1,929.2 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/06/2014 02:00 | 0.7 | 13.2 | 1,817.5 | 0.6 | 2.2 | 1 | 1 | 1 |
| 02/06/2014 03:00 | 0.7 | 13.2 | 1,819.1 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/06/2014 04:00 | 0.7 | 13.2 | 1,821.1 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/06/2014 05:00 | 0.7 | 13.2 | 1,822.4 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/06/2014 06:00 | 0.7 | 13.2 | 1,832.2 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/06/2014 07:00 | 0.7 | 13.3 | 1,853.9 | 0.5 | 2.3 | 1 | 1 | 1 |
| 02/06/2014 08:00 | 0.8 | 13.2 | 1,917.5 | 0.5 | 2.6 | 1 | 1 | 1 |
| 02/06/2014 09:00 | 0.7 | 13.3 | 1,884.6 | 0.5 | 2.3 | 1 | 1 | 1 |
| 02/06/2014 10:00 | 0.7 | 13.3 | 1,841.8 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/06/2014 11:00 | 0.7 | 13.2 | 1,828.7 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/06/2014 12:00 | 0.7 | 13.2 | 1,822.5 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/06/2014 13:00 | 0.8 | 13.2 | 1,839.7 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/06/2014 14:00 | 0.7 | 13.3 | 1,838.2 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/06/2014 15:00 | 0.7 | 13.3 | 1,867.1 | 0.5 | 2.3 | 1 | 1 | 1 |
| 02/06/2014 16:00 | 0.7 | 13.3 | 1,832.6 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/06/2014 17:00 | 0.7 | 13.3 | 1,875.0 | 0.5 | 2.3 | 1 | 1 | 1 |
| 02/06/2014 18:00 | 0.7 | 13.3 | 1,849.7 | 0.5 | 2.3 | 1 | 1 | 1 |
| 02/06/2014 19:00 | 0.7 | 13.3 | 1,908.3 | 0.5 | 2.3 | 1 | 1 | 1 |
| 02/06/2014 20:00 | 0.7 | 13.3 | 1,854.7 | 0.5 | 2.3 | 1 | 1 | 1 |
| 02/06/2014 21:00 | 0.7 | 13.3 | 1,839.6 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/06/2014 22:00 | 0.7 | 13.3 | 1,841.4 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/06/2014 23:00 | 0.7 | 13.3 | 1,843.3 | 0.5 | 2.2 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.7 | 13.2 | 1,865.6 | 0.5 | 55.7 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.7 | 12.0 | 1,817.5 | 0.5 | 2.2 | 1 | 1 | 1 |
| **Maximum:** | 1.0 | 13.3 | 2,195.1 | 0.6 | 3.3 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/07/2014 00:00 | 0.7 | 13.3 | 1,841.4 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/07/2014 01:00 | 0.9 | 12.9 | 1,984.4 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/07/2014 02:00 | 1.0 | 12.6 | 2,037.7 | 0.6 | 3.2 | 1 | 1 | 1 |
| 02/07/2014 03:00 | 1.0 | 12.7 | 2,041.1 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/07/2014 04:00 | 1.0 | 11.9 | 2,187.4 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/07/2014 05:00 | 1.0 | 11.9 | 2,195.9 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/07/2014 06:00 | 0.9 | 11.7 | 2,240.9 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/07/2014 07:00 | 0.9 | 11.6 | 2,255.0 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/07/2014 08:00 | 0.9 | 11.6 | 2,259.0 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/07/2014 09:00 | 1.0 | 12.2 | 2,143.4 | 0.6 | 3.3 | 1 | 1 | 1 |
| 02/07/2014 10:00 | 1.0 | 12.8 | 2,020.4 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/07/2014 11:00 | 1.0 | 12.8 | 2,019.4 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/07/2014 12:00 | 1.0 | 12.6 | 2,044.8 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/07/2014 13:00 | 1.0 | 12.8 | 1,998.0 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/07/2014 14:00 | 0.8 | 13.0 | 1,921.9 | 0.7 | 2.6 | 1 | 1 | 1 |
| 02/07/2014 15:00 | 0.7 | 13.3 | 1,833.6 | 0.6 | 2.2 | 1 | 1 | 1 |
| 02/07/2014 16:00 | 1.0 | 12.8 | 2,004.3 | 0.6 | 3.3 | 1 | 1 | 1 |
| 02/07/2014 17:00 | 1.1 | 12.7 | 2,008.2 | 0.7 | 3.6 | 1 | 1 | 1 |
| 02/07/2014 18:00 | 1.1 | 12.5 | 2,065.2 | 0.8 | 3.6 | 1 | 1 | 1 |
| 02/07/2014 19:00 | 1.0 | 11.7 | 2,215.9 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/07/2014 20:00 | 1.1 | 12.5 | 2,055.2 | 0.7 | 3.6 | 1 | 1 | 1 |
| 02/07/2014 21:00 | 1.0 | 12.7 | 2,011.0 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/07/2014 22:00 | 1.0 | 12.7 | 2,011.4 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/07/2014 23:00 | 1.0 | 12.6 | 2,017.7 | 0.7 | 3.2 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.0 | 12.5 | 2,058.9 | 0.7 | 74.9 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.7 | 11.6 | 1,833.6 | 0.5 | 2.2 | 1 | 1 | 1 |
| **Maximum:** | 1.1 | 13.3 | 2,259.0 | 0.8 | 3.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/08/2014 00:00 | 0.9 | 13.1 | 1,918.1 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/08/2014 01:00 | 0.9 | 13.2 | 1,895.7 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/08/2014 02:00 | 0.9 | 13.3 | 1,866.7 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/08/2014 03:00 | 1.0 | 13.4 | 1,857.2 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/08/2014 04:00 | 1.0 | 13.4 | 1,863.0 | 0.8 | 3.3 | 1 | 1 | 1 |
| 02/08/2014 05:00 | 1.0 | 13.4 | 1,862.5 | 0.8 | 3.3 | 1 | 1 | 1 |
| 02/08/2014 06:00 | 0.9 | 13.4 | 1,844.8 | 0.8 | 2.9 | 1 | 1 | 1 |
| 02/08/2014 07:00 | 0.8 | 13.2 | 1,878.3 | 0.7 | 2.6 | 1 | 1 | 1 |
| 02/08/2014 08:00 | 0.7 | 13.2 | 1,830.3 | 0.6 | 2.2 | 1 | 1 | 1 |
| 02/08/2014 09:00 | 0.7 | 13.2 | 1,828.0 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/08/2014 10:00 | 0.7 | 13.2 | 1,820.4 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/08/2014 11:00 | 0.7 | 13.2 | 1,819.0 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/08/2014 12:00 | 0.7 | 13.2 | 1,818.4 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/08/2014 13:00 | 0.8 | 13.2 | 1,851.6 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/08/2014 14:00 | 0.7 | 13.2 | 1,813.2 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/08/2014 15:00 | 0.8 | 13.2 | 1,815.6 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/08/2014 16:00 | 0.8 | 13.2 | 1,815.1 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/08/2014 17:00 | 0.8 | 13.3 | 1,823.8 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/08/2014 18:00 | 0.8 | 13.0 | 1,923.6 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/08/2014 19:00 | 1.0 | 12.1 | 2,110.6 | 0.6 | 3.2 | 1 | 1 | 1 |
| 02/08/2014 20:00 | 1.0 | 12.5 | 2,024.4 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/08/2014 21:00 | 1.0 | 12.4 | 2,046.0 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/08/2014 22:00 | 0.9 | 13.1 | 1,887.9 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/08/2014 23:00 | 1.0 | 13.5 | 1,811.6 | 0.7 | 3.2 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.9 | 13.1 | 1,876.1 | 0.6 | 65.6 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.7 | 12.1 | 1,811.6 | 0.5 | 2.2 | 1 | 1 | 1 |
| **Maximum:** | 1.0 | 13.5 | 2,110.6 | 0.8 | 3.3 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/09/2014 00:00 | 0.9 | 13.6 | 1,802.2 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/09/2014 01:00 | 0.8 | 13.1 | 1,913.3 | 0.7 | 2.6 | 1 | 1 | 1 |
| 02/09/2014 02:00 | 1.1 | 13.5 | 1,816.4 | 0.7 | 3.6 | 1 | 1 | 1 |
| 02/09/2014 03:00 | 1.1 | 13.6 | 1,801.3 | 0.8 | 3.6 | 1 | 1 | 1 |
| 02/09/2014 04:00 | 1.2 | 13.6 | 1,800.4 | 0.9 | 3.9 | 1 | 1 | 1 |
| 02/09/2014 05:00 | 1.2 | 13.6 | 1,798.4 | 1.0 | 3.9 | 1 | 1 | 1 |
| 02/09/2014 06:00 | 1.1 | 13.5 | 1,811.6 | 1.0 | 3.6 | 1 | 1 | 1 |
| 02/09/2014 07:00 | 0.8 | 13.2 | 1,820.6 | 0.8 | 2.5 | 1 | 1 | 1 |
| 02/09/2014 08:00 | 0.8 | 13.2 | 1,820.3 | 0.7 | 2.5 | 1 | 1 | 1 |
| 02/09/2014 09:00 | 0.8 | 13.2 | 1,820.6 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/09/2014 10:00 | 0.8 | 13.2 | 1,824.6 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/09/2014 11:00 | 0.8 | 13.3 | 1,817.4 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/09/2014 12:00 | 0.7 | 13.3 | 1,812.2 | 0.6 | 2.2 | 1 | 1 | 1 |
| 02/09/2014 13:00 | 0.7 | 13.3 | 1,815.2 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/09/2014 14:00 | 0.7 | 13.3 | 1,819.9 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/09/2014 15:00 | 0.7 | 13.3 | 1,821.4 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/09/2014 16:00 | 0.8 | 13.2 | 1,849.4 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/09/2014 17:00 | 0.8 | 13.2 | 1,850.7 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/09/2014 18:00 | 0.9 | 12.9 | 1,939.3 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/09/2014 19:00 | 0.9 | 11.6 | 2,196.6 | 0.6 | 2.8 | 1 | 1 | 1 |
| 02/09/2014 20:00 | 0.8 | 11.5 | 2,208.2 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/09/2014 21:00 | 0.8 | 11.5 | 2,209.2 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/09/2014 22:00 | 0.8 | 12.0 | 2,101.9 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/09/2014 23:00 | 0.9 | 12.3 | 2,045.0 | 0.5 | 2.8 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.9 | 13.0 | 1,896.5 | 0.7 | 66.4 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.7 | 11.5 | 1,798.4 | 0.5 | 2.2 | 1 | 1 | 1 |
| **Maximum:** | 1.2 | 13.6 | 2,209.2 | 1.0 | 3.9 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/10/2014 00:00 | 0.5 | 13.7 | 1,478.2 | 0.5 | 1.4 | 1 | 1 | 1 |
| 02/10/2014 01:00 | 0.3 | 13.8 | 1,335.3 | 0.4 | 0.7 | 1 | 1 | 0 |
| 02/10/2014 02:00 | 0.4 | 13.8 | 1,364.4 | 0.3 | 1.0 | 1 | 1 | 0 |
| 02/10/2014 03:00 | 0.4 | 13.9 | 1,242.3 | 0.3 | 0.9 | 1 | 1 | 0 |
| 02/10/2014 04:00 | 0.4 | 13.9 | 1,242.3 | 0.3 | 0.9 | 1 | 1 | 0 |
| 02/10/2014 05:00 | 0.6 | 13.8 | 1,422.7 | 0.4 | 1.6 | 1 | 1 | 1 |
| 02/10/2014 06:00 | 1.2 | 13.4 | 1,850.4 | 0.6 | 3.9 | 1 | 1 | 1 |
| 02/10/2014 07:00 | 0.8 | 13.2 | 1,884.3 | 0.7 | 2.6 | 1 | 1 | 1 |
| 02/10/2014 08:00 | 0.8 | 13.0 | 1,957.4 | 0.7 | 2.6 | 1 | 1 | 1 |
| 02/10/2014 09:00 | 0.7 | 13.3 | 1,862.7 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/10/2014 10:00 | 0.7 | 13.3 | 1,853.7 | 0.5 | 2.3 | 1 | 1 | 1 |
| 02/10/2014 11:00 | 0.7 | 13.3 | 1,833.3 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/10/2014 12:00 | 0.7 | 13.3 | 1,838.5 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/10/2014 13:00 | 0.7 | 13.3 | 1,841.6 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/10/2014 14:00 | 0.7 | 13.3 | 1,845.1 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/10/2014 15:00 | 0.7 | 13.3 | 1,836.2 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/10/2014 16:00 | 0.7 | 13.3 | 1,835.0 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/10/2014 17:00 | 0.7 | 13.3 | 1,833.8 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/10/2014 18:00 | 0.7 | 13.2 | 1,877.6 | 0.5 | 2.3 | 1 | 1 | 1 |
| 02/10/2014 19:00 | 1.1 | 12.7 | 2,006.3 | 0.6 | 3.6 | 1 | 1 | 1 |
| 02/10/2014 20:00 | 1.1 | 12.7 | 2,019.7 | 0.7 | 3.6 | 1 | 1 | 1 |
| 02/10/2014 21:00 | 1.1 | 12.3 | 2,099.8 | 0.8 | 3.5 | 1 | 1 | 1 |
| 02/10/2014 22:00 | 0.8 | 12.9 | 1,974.1 | 0.7 | 2.6 | 1 | 1 | 1 |
| 02/10/2014 23:00 | 1.2 | 13.5 | 1,834.5 | 0.8 | 3.9 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.7 | 13.3 | 1,757.1 | 0.5 | 55.1 # | 24 # | 24 # | 20 # |
| **Minimum:** | 0.3 | 12.3 | 1,242.3 | 0.3 | 0.7 | 1 | 1 | 0 |
| **Maximum:** | 1.2 | 13.9 | 2,099.8 | 0.8 | 3.9 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/11/2014 00:00 | 0.9 | 13.5 | 1,799.6 | 0.8 | 2.9 | 1 | 1 | 1 |
| 02/11/2014 01:00 | 0.7 | 13.3 | 1,823.2 | 0.7 | 2.2 | 1 | 1 | 1 |
| 02/11/2014 02:00 | 0.8 | 13.3 | 1,810.0 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/11/2014 03:00 | 0.6 | 13.5 | 1,584.3 | 0.5 | 1.7 | 1 | 1 | 1 |
| 02/11/2014 04:00 | 0.4 | 13.9 | 1,246.2 | 0.5 | 0.9 | 1 | 1 | 0 |
| 02/11/2014 05:00 | 0.4 | 13.8 | 1,507.5 | 0.4 | 1.1 | 1 | 1 | 1 |
| 02/11/2014 06:00 | 0.8 | 13.2 | 1,818.4 | 0.4 | 2.5 | 1 | 1 | 1 |
| 02/11/2014 07:00 | 0.7 | 13.2 | 1,833.3 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/11/2014 08:00 | 1.0 | 12.8 | 2,021.3 | 0.6 | 3.3 | 1 | 1 | 1 |
| 02/11/2014 09:00 | 0.9 | 12.9 | 1,989.0 | 0.6 | 3.0 | 1 | 1 | 1 |
| 02/11/2014 10:00 | 0.7 | 13.3 | 1,868.5 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/11/2014 11:00 | 0.7 | 13.3 | 1,834.9 | 0.6 | 2.2 | 1 | 1 | 1 |
| 02/11/2014 12:00 | 0.7 | 13.3 | 1,841.6 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/11/2014 13:00 | 0.7 | 13.3 | 1,843.5 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/11/2014 14:00 | 0.7 | 13.3 | 1,844.9 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/11/2014 15:00 | 0.7 | 13.3 | 1,843.0 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/11/2014 16:00 | 0.7 | 13.3 | 1,832.9 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/11/2014 17:00 | 0.7 | 13.3 | 1,842.8 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/11/2014 18:00 | 0.7 | 13.2 | 1,872.2 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/11/2014 19:00 | 1.1 | 12.7 | 2,017.7 | 0.6 | 3.6 | 1 | 1 | 1 |
| 02/11/2014 20:00 | 1.1 | 12.7 | 2,026.6 | 0.7 | 3.6 | 1 | 1 | 1 |
| 02/11/2014 21:00 | 1.1 | 12.3 | 2,103.7 | 0.8 | 3.6 | 1 | 1 | 1 |
| 02/11/2014 22:00 | 0.9 | 12.8 | 1,995.3 | 0.8 | 2.9 | 1 | 1 | 1 |
| 02/11/2014 23:00 | 0.7 | 13.1 | 1,921.6 | 0.7 | 2.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.8 | 13.2 | 1,838.4 | 0.6 | 58.2 # | 24 # | 24 # | 23 # |
| **Minimum:** | 0.4 | 12.3 | 1,246.2 | 0.4 | 0.9 | 1 | 1 | 0 |
| **Maximum:** | 1.1 | 13.9 | 2,103.7 | 0.8 | 3.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/12/2014 00:00 | 0.7 | 13.2 | 1,854.5 | 0.6 | 2.2 | 1 | 1 | 1 |
| 02/12/2014 01:00 | 0.9 | 12.9 | 1,975.5 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/12/2014 02:00 | 0.9 | 12.9 | 1,982.6 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/12/2014 03:00 | 0.9 | 12.9 | 1,993.4 | 0.7 | 3.0 | 1 | 1 | 1 |
| 02/12/2014 04:00 | 1.0 | 12.8 | 2,004.3 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/12/2014 05:00 | 1.0 | 12.8 | 1,997.7 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/12/2014 06:00 | 0.8 | 13.0 | 1,949.8 | 0.7 | 2.6 | 1 | 1 | 1 |
| 02/12/2014 07:00 | 1.2 | 12.5 | 2,041.7 | 0.7 | 3.9 | 1 | 1 | 1 |
| 02/12/2014 08:00 | 1.0 | 12.7 | 2,021.6 | 0.7 | 3.3 | 1 | 1 | 1 |
| 02/12/2014 09:00 | 0.7 | 13.2 | 1,870.8 | 0.7 | 2.2 | 1 | 1 | 1 |
| 02/12/2014 10:00 | 0.7 | 13.2 | 1,824.2 | 0.6 | 2.2 | 1 | 1 | 1 |
| 02/12/2014 11:00 | 0.7 | 13.2 | 1,824.0 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/12/2014 12:00 | 0.7 | 13.2 | 1,827.5 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/12/2014 13:00 | 0.7 | 13.2 | 1,825.1 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/12/2014 14:00 | 0.7 | 13.3 | 1,828.6 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/12/2014 15:00 | 0.7 | 13.3 | 1,830.2 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/12/2014 16:00 | 0.7 | 13.3 | 1,829.2 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/12/2014 17:00 | 0.7 | 13.3 | 1,849.4 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/12/2014 18:00 | 1.1 | 12.5 | 2,040.0 | 0.6 | 3.5 | 1 | 1 | 1 |
| 02/12/2014 19:00 | 0.9 | 11.6 | 2,226.6 | 0.6 | 2.8 | 1 | 1 | 1 |
| 02/12/2014 20:00 | 0.8 | 11.6 | 2,212.9 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/12/2014 21:00 | 0.8 | 11.8 | 2,171.0 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/12/2014 22:00 | 0.9 | 12.4 | 2,075.2 | 0.5 | 2.9 | 1 | 1 | 1 |
| 02/12/2014 23:00 | 0.7 | 13.0 | 1,948.2 | 0.5 | 2.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.8 | 12.8 | 1,958.5 | 0.6 | 63.7 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.7 | 11.6 | 1,824.0 | 0.5 | 2.2 | 1 | 1 | 1 |
| **Maximum:** | 1.2 | 13.3 | 2,226.6 | 0.7 | 3.9 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/13/2014 00:00 | 0.7 | 13.2 | 1,865.1 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/13/2014 01:00 | 0.7 | 13.2 | 1,827.7 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/13/2014 02:00 | 0.7 | 13.2 | 1,822.5 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/13/2014 03:00 | 0.7 | 13.2 | 1,822.4 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/13/2014 04:00 | 0.7 | 13.2 | 1,815.3 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/13/2014 05:00 | 0.7 | 13.2 | 1,836.6 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/13/2014 06:00 | 0.8 | 13.1 | 1,895.3 | 0.5 | 2.6 | 1 | 1 | 1 |
| 02/13/2014 07:00 | 1.0 | 12.1 | 2,090.4 | 0.6 | 3.1 | 1 | 1 | 1 |
| 02/13/2014 08:00 | 0.9 | 11.7 | 2,213.9 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/13/2014 09:00 | 1.0 | 12.2 | 2,115.7 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/13/2014 10:00 | 1.0 | 12.3 | 2,095.2 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/13/2014 11:00 | 1.0 | 12.3 | 2,096.4 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/13/2014 12:00 | 1.0 | 12.3 | 2,099.8 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/13/2014 13:00 | 1.0 | 12.2 | 2,098.7 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/13/2014 14:00 | 1.0 | 12.2 | 2,100.9 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/13/2014 15:00 | 1.0 | 12.2 | 2,097.8 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/13/2014 16:00 | 0.9 | 12.2 | 2,101.7 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/13/2014 17:00 | 0.9 | 12.1 | 2,119.7 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/13/2014 18:00 | 0.9 | 12.1 | 2,108.1 | 0.6 | 2.8 | 1 | 1 | 1 |
| 02/13/2014 19:00 | 0.8 | 11.8 | 2,182.5 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/13/2014 20:00 | 0.8 | 11.5 | 2,229.5 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/13/2014 21:00 | 0.7 | 11.5 | 2,230.5 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/13/2014 22:00 | 0.8 | 11.9 | 2,147.2 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/13/2014 23:00 | 0.9 | 12.2 | 2,097.7 | 0.5 | 2.9 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.9 | 12.4 | 2,046.3 | 0.6 | 65.4 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.7 | 11.5 | 1,815.3 | 0.5 | 2.2 | 1 | 1 | 1 |
| **Maximum:** | 1.0 | 13.2 | 2,230.5 | 0.7 | 3.2 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/14/2014 00:00 | 0.8 | 12.7 | 1,996.6 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/14/2014 01:00 | 0.7 | 13.2 | 1,812.6 | 0.6 | 2.2 | 1 | 1 | 1 |
| 02/14/2014 02:00 | 0.7 | 13.2 | 1,835.7 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/14/2014 03:00 | 0.7 | 13.2 | 1,815.6 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/14/2014 04:00 | 0.7 | 13.2 | 1,815.1 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/14/2014 05:00 | 0.7 | 13.3 | 1,820.0 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/14/2014 06:00 | 0.7 | 13.3 | 1,835.0 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/14/2014 07:00 | 0.7 | 13.1 | 1,878.7 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/14/2014 08:00 | 0.9 | 12.8 | 1,967.0 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/14/2014 09:00 | 0.9 | 12.3 | 2,082.0 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/14/2014 10:00 | 0.9 | 12.0 | 2,112.4 | 0.6 | 2.8 | 1 | 1 | 1 |
| 02/14/2014 11:00 | 0.8 | 12.0 | 2,118.3 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/14/2014 12:00 | 0.8 | 11.9 | 2,120.8 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/14/2014 13:00 | 1.0 | 11.9 | 2,128.4 | 0.6 | 3.1 | 1 | 1 | 1 |
| 02/14/2014 14:00 | 0.7 | 11.8 | 2,131.2 | 0.6 | 2.2 | 1 | 1 | 1 |
| 02/14/2014 15:00 | 0.8 | 11.8 | 2,132.8 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/14/2014 16:00 | 0.6 | 12.4 | 1,973.7 | 0.5 | 1.8 | 1 | 1 | 1 |
| 02/14/2014 17:00 | 0.8 | 11.9 | 2,117.3 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/14/2014 18:00 | 0.8 | 11.9 | 2,116.4 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/14/2014 19:00 | 0.9 | 12.3 | 2,043.5 | 0.5 | 2.8 | 1 | 1 | 1 |
| 02/14/2014 20:00 | 0.9 | 12.5 | 2,036.7 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/14/2014 21:00 | 0.9 | 12.2 | 2,094.8 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/14/2014 22:00 | 0.9 | 12.1 | 2,107.3 | 0.6 | 2.8 | 1 | 1 | 1 |
| 02/14/2014 23:00 | 0.8 | 12.5 | 2,021.2 | 0.6 | 2.5 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.8 | 12.5 | 2,004.7 | 0.6 | 60.1 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.6 | 11.8 | 1,812.6 | 0.5 | 1.8 | 1 | 1 | 1 |
| **Maximum:** | 1.0 | 13.3 | 2,132.8 | 0.6 | 3.1 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/15/2014 00:00 | 0.9 | 12.6 | 2,003.8 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/15/2014 01:00 | 1.0 | 12.3 | 2,068.4 | 0.6 | 3.2 | 1 | 1 | 1 |
| 02/15/2014 02:00 | 0.8 | 11.8 | 2,179.5 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/15/2014 03:00 | 0.8 | 11.7 | 2,196.4 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/15/2014 04:00 | 0.9 | 12.4 | 2,043.0 | 0.5 | 2.9 | 1 | 1 | 1 |
| 02/15/2014 05:00 | 0.9 | 12.7 | 2,000.2 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/15/2014 06:00 | 0.9 | 12.5 | 2,032.2 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/15/2014 07:00 | 0.9 | 12.7 | 1,969.6 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/15/2014 08:00 | 0.9 | 12.7 | 1,986.7 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/15/2014 09:00 | 1.0 | 12.5 | 2,031.5 | 0.6 | 3.2 | 1 | 1 | 1 |
| 02/15/2014 10:00 | 0.9 | 12.1 | 2,112.7 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/15/2014 11:00 | 0.8 | 11.6 | 2,213.5 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/15/2014 12:00 | 0.7 | 11.5 | 2,207.0 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/15/2014 13:00 | 0.8 | 11.8 | 2,154.6 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/15/2014 14:00 | 0.9 | 12.5 | 2,016.7 | 0.5 | 2.9 | 1 | 1 | 1 |
| 02/15/2014 15:00 | 0.9 | 12.6 | 1,995.3 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/15/2014 16:00 | 0.8 | 12.8 | 1,964.9 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/15/2014 17:00 | 0.8 | 12.6 | 1,993.7 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/15/2014 18:00 | 0.9 | 12.3 | 2,061.4 | 0.6 | 2.8 | 1 | 1 | 1 |
| 02/15/2014 19:00 | 0.7 | 11.6 | 2,196.8 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/15/2014 20:00 | 0.8 | 11.8 | 2,174.5 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/15/2014 21:00 | 0.7 | 11.7 | 2,187.8 | 0.4 | 2.2 | 1 | 1 | 1 |
| 02/15/2014 22:00 | 0.8 | 12.1 | 2,097.2 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/15/2014 23:00 | 0.7 | 13.0 | 1,896.6 | 0.5 | 2.2 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.8 | 12.2 | 2,074.3 | 0.6 | 64.2 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.7 | 11.5 | 1,896.6 | 0.4 | 2.2 | 1 | 1 | 1 |
| **Maximum:** | 1.0 | 13.0 | 2,213.5 | 0.6 | 3.2 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/16/2014 00:00 | 0.7 | 13.3 | 1,833.4 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/16/2014 01:00 | 0.7 | 13.3 | 1,848.5 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/16/2014 02:00 | 0.7 | 13.2 | 1,880.7 | 0.5 | 2.3 | 1 | 1 | 1 |
| 02/16/2014 03:00 | 0.6 | 13.5 | 1,701.5 | 0.5 | 1.8 | 1 | 1 | 1 |
| 02/16/2014 04:00 | 0.3 | 13.9 | 1,274.0 | 0.4 | 0.7 | 1 | 1 | 0 |
| 02/16/2014 05:00 | 0.3 | 13.8 | 1,472.5 | 0.3 | 0.8 | 1 | 1 | 0 |
| 02/16/2014 06:00 | 0.5 | 13.6 | 1,643.4 | 0.3 | 1.5 | 1 | 1 | 1 |
| 02/16/2014 07:00 | 0.9 | 13.1 | 1,950.7 | 0.4 | 3.0 | 1 | 1 | 1 |
| 02/16/2014 08:00 | 0.8 | 13.4 | 1,869.3 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/16/2014 09:00 | 0.9 | 13.7 | 1,826.4 | 0.7 | 3.0 | 1 | 1 | 1 |
| 02/16/2014 10:00 | 0.9 | 13.7 | 1,815.4 | 0.7 | 3.0 | 1 | 1 | 1 |
| 02/16/2014 11:00 | 0.9 | 13.7 | 1,814.6 | 0.7 | 3.0 | 1 | 1 | 1 |
| 02/16/2014 12:00 | 0.9 | 13.7 | 1,815.4 | 0.7 | 3.0 | 1 | 1 | 1 |
| 02/16/2014 13:00 | 0.9 | 13.7 | 1,811.9 | 0.7 | 3.0 | 1 | 1 | 1 |
| 02/16/2014 14:00 | 0.8 | 13.7 | 1,815.8 | 0.7 | 2.7 | 1 | 1 | 1 |
| 02/16/2014 15:00 | 0.8 | 13.6 | 1,832.5 | 0.7 | 2.7 | 1 | 1 | 1 |
| 02/16/2014 16:00 | 0.8 | 13.7 | 1,821.6 | 0.7 | 2.7 | 1 | 1 | 1 |
| 02/16/2014 17:00 | 0.8 | 13.7 | 1,828.3 | 0.7 | 2.7 | 1 | 1 | 1 |
| 02/16/2014 18:00 | 0.9 | 13.1 | 1,922.9 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/16/2014 19:00 | 0.9 | 11.9 | 2,185.4 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/16/2014 20:00 | 0.8 | 11.8 | 2,203.1 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/16/2014 21:00 | 0.8 | 11.8 | 2,202.3 | 0.5 | 2.6 | 1 | 1 | 1 |
| 02/16/2014 22:00 | 0.8 | 11.8 | 2,203.8 | 0.5 | 2.6 | 1 | 1 | 1 |
| 02/16/2014 23:00 | 0.8 | 12.7 | 2,003.9 | 0.5 | 2.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.8 | 13.2 | 1,857.4 | 0.6 | 59.1 # | 24 # | 24 # | 22 # |
| **Minimum:** | 0.3 | 11.8 | 1,274.0 | 0.3 | 0.7 | 1 | 1 | 0 |
| **Maximum:** | 0.9 | 13.9 | 2,203.8 | 0.7 | 3.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/17/2014 00:00 | 0.7 | 13.3 | 1,842.6 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/17/2014 01:00 | 0.7 | 13.3 | 1,828.9 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/17/2014 02:00 | 0.6 | 13.5 | 1,740.3 | 0.5 | 1.9 | 1 | 1 | 1 |
| 02/17/2014 03:00 | 0.4 | 13.9 | 1,295.9 | 0.4 | 1.0 | 1 | 1 | 0 |
| 02/17/2014 04:00 | 0.4 | 13.9 | 1,369.9 | 0.4 | 1.0 | 1 | 1 | 0 |
| 02/17/2014 05:00 | 0.6 | 13.6 | 1,574.9 | 0.4 | 1.7 | 1 | 1 | 1 |
| 02/17/2014 06:00 | 0.9 | 13.1 | 1,952.7 | 0.5 | 3.0 | 1 | 1 | 1 |
| 02/17/2014 07:00 | 1.0 | 12.9 | 1,991.7 | 0.6 | 3.3 | 1 | 1 | 1 |
| 02/17/2014 08:00 | 0.9 | 13.0 | 1,952.0 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/17/2014 09:00 | 0.8 | 13.3 | 1,886.1 | 0.7 | 2.6 | 1 | 1 | 1 |
| 02/17/2014 10:00 | 0.8 | 13.3 | 1,821.6 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/17/2014 11:00 | 0.7 | 13.3 | 1,821.5 | 0.6 | 2.2 | 1 | 1 | 1 |
| 02/17/2014 12:00 | 0.7 | 13.3 | 1,826.5 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/17/2014 13:00 | 0.7 | 13.3 | 1,826.8 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/17/2014 14:00 | 0.7 | 13.3 | 1,828.0 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/17/2014 15:00 | 0.7 | 13.3 | 1,828.3 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/17/2014 16:00 | 0.7 | 13.3 | 1,826.7 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/17/2014 17:00 | 0.7 | 13.3 | 1,826.3 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/17/2014 18:00 | 0.7 | 13.4 | 1,848.0 | 0.5 | 2.3 | 1 | 1 | 1 |
| 02/17/2014 19:00 | 0.7 | 13.3 | 1,888.7 | 0.5 | 2.3 | 1 | 1 | 1 |
| 02/17/2014 20:00 | 1.0 | 12.6 | 2,043.5 | 0.6 | 3.3 | 1 | 1 | 1 |
| 02/17/2014 21:00 | 0.9 | 12.0 | 2,166.3 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/17/2014 22:00 | 0.9 | 12.7 | 2,012.1 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/17/2014 23:00 | 0.7 | 13.2 | 1,878.5 | 0.6 | 2.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.7 | 13.2 | 1,828.2 | 0.5 | 55.7 # | 24 # | 24 # | 22 # |
| **Minimum:** | 0.4 | 12.0 | 1,295.9 | 0.4 | 1.0 | 1 | 1 | 0 |
| **Maximum:** | 1.0 | 13.9 | 2,166.3 | 0.7 | 3.3 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/18/2014 00:00 | 0.7 | 13.3 | 1,832.5 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/18/2014 01:00 | 0.7 | 13.3 | 1,825.5 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/18/2014 02:00 | 0.7 | 13.2 | 1,823.8 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/18/2014 03:00 | 0.7 | 13.3 | 1,823.1 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/18/2014 04:00 | 0.7 | 13.3 | 1,820.0 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/18/2014 05:00 | 0.7 | 13.2 | 1,820.6 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/18/2014 06:00 | 0.8 | 13.2 | 1,862.9 | 0.5 | 2.6 | 1 | 1 | 1 |
| 02/18/2014 07:00 | 1.0 | 12.5 | 2,018.1 | 0.6 | 3.2 | 1 | 1 | 1 |
| 02/18/2014 08:00 | 0.9 | 12.4 | 2,083.4 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/18/2014 09:00 | 0.9 | 13.0 | 1,952.9 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/18/2014 10:00 | 0.9 | 13.0 | 1,947.6 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/18/2014 11:00 | 0.9 | 12.7 | 1,994.5 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/18/2014 12:00 | 0.9 | 12.5 | 2,033.7 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/18/2014 13:00 | 0.9 | 12.9 | 1,945.5 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/18/2014 14:00 | 0.7 | 13.3 | 1,825.4 | 0.6 | 2.2 | 1 | 1 | 1 |
| 02/18/2014 15:00 | 0.7 | 13.3 | 1,836.4 | 0.6 | 2.2 | 1 | 1 | 1 |
| 02/18/2014 16:00 | 0.7 | 13.3 | 1,799.0 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/18/2014 17:00 | 0.8 | 12.9 | 1,924.1 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/18/2014 18:00 | 0.8 | 11.9 | 2,140.5 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/18/2014 19:00 | 0.7 | 11.6 | 2,194.2 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/18/2014 20:00 | 0.9 | 12.5 | 2,032.5 | 0.5 | 2.9 | 1 | 1 | 1 |
| 02/18/2014 21:00 | 0.8 | 11.8 | 2,163.8 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/18/2014 22:00 | 0.8 | 13.2 | 1,882.2 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/18/2014 23:00 | 0.7 | 13.8 | 1,555.5 | 0.6 | 2.0 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.8 | 12.9 | 1,922.4 | 0.6 | 60.2 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.7 | 11.6 | 1,555.5 | 0.5 | 2.0 | 1 | 1 | 1 |
| **Maximum:** | 1.0 | 13.8 | 2,194.2 | 0.7 | 3.2 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/19/2014 00:00 | 0.4 | 13.9 | 1,234.8 | 0.5 | 0.9 | 1 | 1 | 0 |
| 02/19/2014 01:00 | 0.4 | 13.9 | 1,395.8 | 0.4 | 1.1 | 1 | 1 | 0 |
| 02/19/2014 02:00 | 13.9 | 15.0 | 750.2 | 0.0 | 4.2 | 1 | 0 | 0 |
| 02/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 12:00 | 20.1 | 17.5 | 505.2 | 0.0 | 24.8 | 1 | 0 | 0 |
| 02/19/2014 13:00 | 11.2 | 16.9 | 568.7 | 0.0 | 21.0 | 1 | 0 | 0 |
| 02/19/2014 14:00 | 27.8 | 15.3 | 895.0 | 0.0 | 58.7 | 1 | 0 | 0 |
| 02/19/2014 15:00 | 0.3 | 13.9 | 1,283.6 | 0.0 | 0.7 | 1 | 0 | 0 |
| 02/19/2014 16:00 | 0.4 | 13.9 | 1,587.8 | 0.0 | 1.2 | 1 | 0 | 0 |
| 02/19/2014 17:00 | 0.4 | 13.9 | 1,723.5 | 0.3 | 1.3 | 1 | 0 | 0 |
| 02/19/2014 18:00 | 0.4 | 13.8 | 1,596.0 | 0.3 | 1.2 | 1 | 0 | 1 |
| 02/19/2014 19:00 | 0.8 | 13.5 | 1,852.6 | 0.4 | 2.6 | 1 | 1 | 1 |
| 02/19/2014 20:00 | 0.9 | 12.0 | 2,171.3 | 0.5 | 2.9 | 1 | 1 | 1 |
| 02/19/2014 21:00 | 0.7 | 11.7 | 2,223.1 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/19/2014 22:00 | 0.8 | 12.2 | 2,127.3 | 0.5 | 2.6 | 1 | 1 | 1 |
| 02/19/2014 23:00 | 0.8 | 13.5 | 1,851.6 | 0.5 | 2.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 5.3 | 14.1 | 1,451.1 | 0.4 | 128.0 # | 15 # | 7 # | 6 # |
| **Minimum:** | 0.3 | 11.7 | 505.2 | 0.3 | 0.7 | 0 | 0 | 0 |
| **Maximum:** | 27.8 | 17.5 | 2,223.1 | 0.5 | 58.7 | 1 | 1 | 1 |
| **%SI** | 37.5 | 37.5 | 37.5 | 62.5 | 37.5 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/20/2014 00:00 | 0.9 | 13.7 | 1,800.2 | 0.6 | 3.0 | 1 | 1 | 1 |
| 02/20/2014 01:00 | 0.3 | 13.9 | 1,263.1 | 0.5 | 0.7 | 1 | 1 | 0 |
| 02/20/2014 02:00 | 0.3 | 13.9 | 1,238.1 | 0.4 | 0.7 | 1 | 1 | 0 |
| 02/20/2014 03:00 | 0.3 | 13.9 | 1,237.4 | 0.3 | 0.7 | 1 | 1 | 0 |
| 02/20/2014 04:00 | 0.3 | 13.9 | 1,254.1 | 0.3 | 0.7 | 1 | 1 | 0 |
| 02/20/2014 05:00 | 0.4 | 13.9 | 1,306.0 | 0.3 | 1.0 | 1 | 1 | 0 |
| 02/20/2014 06:00 | 0.8 | 13.1 | 1,877.8 | 0.4 | 2.5 | 1 | 1 | 1 |
| 02/20/2014 07:00 | 1.0 | 12.8 | 2,045.9 | 0.5 | 3.3 | 1 | 1 | 1 |
| 02/20/2014 08:00 | 0.9 | 12.3 | 2,121.3 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/20/2014 09:00 | 0.7 | 13.2 | 1,853.7 | 0.6 | 2.2 | 1 | 1 | 1 |
| 02/20/2014 10:00 | 0.7 | 13.3 | 1,812.2 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/20/2014 11:00 | 0.7 | 13.3 | 1,816.3 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/20/2014 12:00 | 0.7 | 13.3 | 1,823.1 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/20/2014 13:00 | 0.8 | 13.0 | 1,958.1 | 0.5 | 2.6 | 1 | 1 | 1 |
| 02/20/2014 14:00 | 0.7 | 13.4 | 1,845.8 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/20/2014 15:00 | 0.8 | 13.0 | 1,943.7 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/20/2014 16:00 | 0.9 | 12.2 | 2,106.9 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/20/2014 17:00 | 0.6 | 11.5 | 2,238.4 | 0.5 | 1.9 | 1 | 1 | 1 |
| 02/20/2014 18:00 | 0.7 | 11.9 | 2,152.6 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/20/2014 19:00 | 0.6 | 11.5 | 2,242.7 | 0.4 | 1.9 | 1 | 1 | 1 |
| 02/20/2014 20:00 | 0.6 | 11.4 | 2,252.8 | 0.4 | 1.9 | 1 | 1 | 1 |
| 02/20/2014 21:00 | 0.6 | 11.5 | 2,229.4 | 0.4 | 1.9 | 1 | 1 | 1 |
| 02/20/2014 22:00 | 0.6 | 11.5 | 2,237.5 | 0.4 | 1.9 | 1 | 1 | 1 |
| 02/20/2014 23:00 | 0.7 | 11.8 | 2,171.4 | 0.4 | 2.2 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.7 | 12.8 | 1,867.9 | 0.5 | 48.6 # | 24 # | 24 # | 19 # |
| **Minimum:** | 0.3 | 11.4 | 1,237.4 | 0.3 | 0.7 | 1 | 1 | 0 |
| **Maximum:** | 1.0 | 13.9 | 2,252.8 | 0.6 | 3.3 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/21/2014 00:00 | 0.8 | 12.5 | 2,036.7 | 0.5 | 2.6 | 1 | 1 | 1 |
| 02/21/2014 01:00 | 0.7 | 13.5 | 1,844.1 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/21/2014 02:00 | 0.8 | 13.6 | 1,802.3 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/21/2014 03:00 | 0.8 | 13.6 | 1,802.6 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/21/2014 04:00 | 0.8 | 13.7 | 1,803.4 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/21/2014 05:00 | 0.8 | 13.7 | 1,804.4 | 0.7 | 2.6 | 1 | 1 | 1 |
| 02/21/2014 06:00 | 0.8 | 13.6 | 1,826.1 | 0.7 | 2.6 | 1 | 1 | 1 |
| 02/21/2014 07:00 | 1.0 | 12.7 | 1,984.8 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/21/2014 08:00 | 0.8 | 11.9 | 2,173.1 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/21/2014 09:00 | 0.7 | 13.1 | 1,918.9 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/21/2014 10:00 | 0.8 | 13.6 | 1,817.5 | 0.5 | 2.6 | 1 | 1 | 1 |
| 02/21/2014 11:00 | 0.7 | 13.5 | 1,839.8 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/21/2014 12:00 | 0.8 | 13.6 | 1,820.7 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/21/2014 13:00 | 0.8 | 13.5 | 1,824.2 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/21/2014 14:00 | 0.7 | 13.5 | 1,834.2 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/21/2014 15:00 | 0.6 | 13.5 | 1,831.3 | 0.6 | 2.0 | 1 | 1 | 1 |
| 02/21/2014 16:00 | 0.6 | 13.5 | 1,828.0 | 0.5 | 2.0 | 1 | 1 | 1 |
| 02/21/2014 17:00 | 0.6 | 13.4 | 1,840.3 | 0.5 | 1.9 | 1 | 1 | 1 |
| 02/21/2014 18:00 | 0.9 | 12.7 | 2,002.6 | 0.5 | 2.9 | 1 | 1 | 1 |
| 02/21/2014 19:00 | 0.9 | 12.1 | 2,110.8 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/21/2014 20:00 | 0.8 | 12.0 | 2,145.3 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/21/2014 21:00 | 0.7 | 11.7 | 2,211.3 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/21/2014 22:00 | 0.8 | 12.0 | 2,134.2 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/21/2014 23:00 | 0.9 | 12.4 | 2,067.1 | 0.5 | 2.9 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.8 | 13.0 | 1,929.3 | 0.6 | 60.2 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.6 | 11.7 | 1,802.3 | 0.5 | 1.9 | 1 | 1 | 1 |
| **Maximum:** | 1.0 | 13.7 | 2,211.3 | 0.7 | 3.2 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/22/2014 00:00 | 0.9 | 12.5 | 2,045.6 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/22/2014 01:00 | 0.8 | 12.8 | 1,995.4 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/22/2014 02:00 | 0.6 | 13.3 | 1,836.2 | 0.6 | 1.9 | 1 | 1 | 1 |
| 02/22/2014 03:00 | 0.9 | 12.9 | 1,962.7 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/22/2014 04:00 | 0.9 | 12.8 | 1,974.4 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/22/2014 05:00 | 0.8 | 13.2 | 1,897.0 | 0.7 | 2.6 | 1 | 1 | 1 |
| 02/22/2014 06:00 | 0.9 | 12.8 | 2,005.1 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/22/2014 07:00 | 0.9 | 12.8 | 2,007.0 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/22/2014 08:00 | 0.9 | 12.8 | 1,987.4 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/22/2014 09:00 | 0.7 | 13.3 | 1,855.1 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/22/2014 10:00 | 0.7 | 13.4 | 1,835.2 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/22/2014 11:00 | 0.7 | 13.4 | 1,842.8 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/22/2014 12:00 | 0.7 | 13.4 | 1,854.0 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/22/2014 13:00 | 0.7 | 13.4 | 1,839.5 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/22/2014 14:00 | 0.8 | 13.0 | 1,917.3 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/22/2014 15:00 | 0.9 | 12.7 | 1,975.3 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/22/2014 16:00 | 0.8 | 13.1 | 1,882.3 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/22/2014 17:00 | 0.7 | 13.3 | 1,839.8 | 0.6 | 2.2 | 1 | 1 | 1 |
| 02/22/2014 18:00 | 0.9 | 12.3 | 2,033.9 | 0.6 | 2.8 | 1 | 1 | 1 |
| 02/22/2014 19:00 | 0.8 | 12.2 | 2,058.2 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/22/2014 20:00 | 0.7 | 11.5 | 2,196.1 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/22/2014 21:00 | 0.6 | 11.4 | 2,217.3 | 0.4 | 1.8 | 1 | 1 | 1 |
| 02/22/2014 22:00 | 0.6 | 11.4 | 2,223.9 | 0.4 | 1.9 | 1 | 1 | 1 |
| 02/22/2014 23:00 | 0.6 | 11.4 | 2,230.6 | 0.4 | 1.9 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.8 | 12.7 | 1,979.7 | 0.6 | 59.3 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.6 | 11.4 | 1,835.2 | 0.4 | 1.8 | 1 | 1 | 1 |
| **Maximum:** | 0.9 | 13.4 | 2,230.6 | 0.7 | 2.9 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/23/2014 00:00 | 0.7 | 11.8 | 2,190.0 | 0.4 | 2.2 | 1 | 1 | 1 |
| 02/23/2014 01:00 | 0.9 | 12.1 | 2,121.4 | 0.5 | 2.9 | 1 | 1 | 1 |
| 02/23/2014 02:00 | 0.7 | 11.7 | 2,213.9 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/23/2014 03:00 | 0.7 | 11.6 | 2,224.5 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/23/2014 04:00 | 0.8 | 12.2 | 2,097.1 | 0.4 | 2.5 | 1 | 1 | 1 |
| 02/23/2014 05:00 | 0.9 | 12.8 | 1,995.7 | 0.5 | 2.9 | 1 | 1 | 1 |
| 02/23/2014 06:00 | 0.9 | 12.7 | 2,011.4 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/23/2014 07:00 | 0.8 | 13.0 | 1,974.8 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/23/2014 08:00 | 0.8 | 13.0 | 1,958.3 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/23/2014 09:00 | 0.8 | 13.0 | 1,942.2 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/23/2014 10:00 | 0.6 | 13.5 | 1,818.6 | 0.6 | 1.9 | 1 | 1 | 1 |
| 02/23/2014 11:00 | 0.7 | 13.3 | 1,865.1 | 0.5 | 2.3 | 1 | 1 | 1 |
| 02/23/2014 12:00 | 0.7 | 13.2 | 1,894.3 | 0.5 | 2.3 | 1 | 1 | 1 |
| 02/23/2014 13:00 | 0.6 | 13.5 | 1,826.0 | 0.5 | 2.0 | 1 | 1 | 1 |
| 02/23/2014 14:00 | 0.6 | 13.4 | 1,827.9 | 0.5 | 1.9 | 1 | 1 | 1 |
| 02/23/2014 15:00 | 0.6 | 13.4 | 1,828.5 | 0.5 | 1.9 | 1 | 1 | 1 |
| 02/23/2014 16:00 | 0.7 | 13.1 | 1,867.1 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/23/2014 17:00 | 0.7 | 13.0 | 1,902.4 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/23/2014 18:00 | 0.8 | 12.1 | 2,083.2 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/23/2014 19:00 | 0.7 | 11.6 | 2,184.0 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/23/2014 20:00 | 0.7 | 11.7 | 2,168.3 | 0.4 | 2.2 | 1 | 1 | 1 |
| 02/23/2014 21:00 | 0.7 | 11.7 | 2,169.5 | 0.4 | 2.2 | 1 | 1 | 1 |
| 02/23/2014 22:00 | 0.7 | 11.8 | 2,168.5 | 0.4 | 2.2 | 1 | 1 | 1 |
| 02/23/2014 23:00 | 0.8 | 11.9 | 2,147.4 | 0.5 | 2.5 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.7 | 12.5 | 2,020.0 | 0.5 | 56.1 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.6 | 11.6 | 1,818.6 | 0.4 | 1.9 | 1 | 1 | 1 |
| **Maximum:** | 0.9 | 13.5 | 2,224.5 | 0.6 | 2.9 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/24/2014 00:00 | 0.8 | 12.8 | 1,972.0 | 0.5 | 2.6 | 1 | 1 | 1 |
| 02/24/2014 01:00 | 0.6 | 13.5 | 1,809.7 | 0.5 | 1.9 | 1 | 1 | 1 |
| 02/24/2014 02:00 | 0.6 | 13.6 | 1,760.5 | 0.5 | 1.9 | 1 | 1 | 1 |
| 02/24/2014 03:00 | 0.3 | 13.9 | 1,246.8 | 0.4 | 0.7 | 1 | 1 | 0 |
| 02/24/2014 04:00 | 0.3 | 13.9 | 1,220.7 | 0.4 | 0.7 | 1 | 1 | 0 |
| 02/24/2014 05:00 | 0.5 | 13.7 | 1,507.4 | 0.3 | 1.4 | 1 | 1 | 1 |
| 02/24/2014 06:00 | 0.8 | 13.3 | 1,854.9 | 0.4 | 2.6 | 1 | 1 | 1 |
| 02/24/2014 07:00 | 0.8 | 13.1 | 1,920.1 | 0.5 | 2.6 | 1 | 1 | 1 |
| 02/24/2014 08:00 | 1.5 | 12.6 | 2,041.5 | 0.8 | 4.9 | 1 | 1 | 1 |
| 02/24/2014 09:00 | 0.9 | 13.2 | 1,907.6 | 0.8 | 2.9 | 1 | 1 | 1 |
| 02/24/2014 10:00 | 0.9 | 13.7 | 1,804.1 | 0.8 | 3.0 | 1 | 1 | 1 |
| 02/24/2014 11:00 | 0.7 | 13.5 | 1,835.6 | 0.7 | 2.3 | 1 | 1 | 1 |
| 02/24/2014 12:00 | 0.8 | 13.6 | 1,802.6 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/24/2014 13:00 | 0.8 | 13.6 | 1,798.9 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/24/2014 14:00 | 0.7 | 13.5 | 1,805.9 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/24/2014 15:00 | 0.9 | 12.7 | 1,945.5 | 0.6 | 2.8 | 1 | 1 | 1 |
| 02/24/2014 16:00 | 0.9 | 12.8 | 1,939.8 | 0.6 | 2.8 | 1 | 1 | 1 |
| 02/24/2014 17:00 | 0.9 | 12.4 | 2,016.4 | 0.6 | 2.8 | 1 | 1 | 1 |
| 02/24/2014 18:00 | 0.8 | 11.9 | 2,104.9 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/24/2014 19:00 | 0.7 | 11.5 | 2,185.6 | 0.5 | 2.1 | 1 | 1 | 1 |
| 02/24/2014 20:00 | 0.7 | 11.7 | 2,162.8 | 0.4 | 2.2 | 1 | 1 | 1 |
| 02/24/2014 21:00 | 0.7 | 11.8 | 2,141.3 | 0.4 | 2.2 | 1 | 1 | 1 |
| 02/24/2014 22:00 | 0.7 | 11.9 | 2,138.5 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/24/2014 23:00 | 0.7 | 11.9 | 2,144.3 | 0.5 | 2.2 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.8 | 12.9 | 1,877.8 | 0.5 | 56.8 # | 24 # | 24 # | 22 # |
| **Minimum:** | 0.3 | 11.5 | 1,220.7 | 0.3 | 0.7 | 1 | 1 | 0 |
| **Maximum:** | 1.5 | 13.9 | 2,185.6 | 0.8 | 4.9 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/25/2014 00:00 | 0.9 | 12.7 | 2,009.1 | 0.5 | 2.9 | 1 | 1 | 1 |
| 02/25/2014 01:00 | 0.8 | 13.0 | 1,938.7 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/25/2014 02:00 | 0.6 | 13.4 | 1,810.1 | 0.6 | 1.9 | 1 | 1 | 1 |
| 02/25/2014 03:00 | 0.7 | 13.4 | 1,803.8 | 0.6 | 2.2 | 1 | 1 | 1 |
| 02/25/2014 04:00 | 0.7 | 13.4 | 1,801.5 | 0.6 | 2.2 | 1 | 1 | 1 |
| 02/25/2014 05:00 | 0.9 | 12.8 | 1,966.9 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/25/2014 06:00 | 1.0 | 12.7 | 1,995.0 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/25/2014 07:00 | 0.8 | 13.1 | 1,919.2 | 0.7 | 2.6 | 1 | 1 | 1 |
| 02/25/2014 08:00 | 0.9 | 12.8 | 1,970.6 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/25/2014 09:00 | 0.6 | 13.4 | 1,805.0 | 0.6 | 1.9 | 1 | 1 | 1 |
| 02/25/2014 10:00 | 0.0 | 0.0 | 1,801.3 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/25/2014 11:00 | 0.0 | 0.0 | 1,798.5 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/25/2014 12:00 | 0.0 | 0.0 | 1,808.3 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/25/2014 13:00 | 0.0 | 0.0 | 1,823.5 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/25/2014 14:00 | 0.9 | 13.6 | 1,801.5 | 0.0 | 2.9 | 1 | 1 | 1 |
| 02/25/2014 15:00 | 0.9 | 13.6 | 1,801.3 | 0.0 | 2.9 | 1 | 1 | 1 |
| 02/25/2014 16:00 | 0.9 | 13.3 | 1,845.1 | 0.7 | 2.9 | 1 | 1 | 1 |
| 02/25/2014 17:00 | 0.6 | 13.4 | 1,819.2 | 0.6 | 1.9 | 1 | 1 | 1 |
| 02/25/2014 18:00 | 0.9 | 12.9 | 1,937.9 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/25/2014 19:00 | 1.0 | 12.1 | 2,091.8 | 0.6 | 3.1 | 1 | 1 | 1 |
| 02/25/2014 20:00 | 0.9 | 11.9 | 2,129.0 | 0.7 | 2.8 | 1 | 1 | 1 |
| 02/25/2014 21:00 | 1.0 | 12.4 | 2,040.1 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/25/2014 22:00 | 0.8 | 13.0 | 1,928.6 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/25/2014 23:00 | 1.0 | 12.1 | 2,113.8 | 0.7 | 3.2 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.8 | 13.0 | 1,906.7 | 0.6 | 53.7 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.6 | 11.9 | 1,798.5 | 0.5 | 1.9 | 1 | 1 | 1 |
| **Maximum:** | 1.0 | 13.6 | 2,129.0 | 0.7 | 3.2 | 1 | 1 | 1 |
| **%SI** | 16.7 | 16.7 | 0.0 | 25.0 | 16.7 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/26/2014 00:00 | 0.8 | 13.0 | 1,912.3 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/26/2014 01:00 | 0.8 | 13.3 | 1,851.2 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/26/2014 02:00 | 0.8 | 13.3 | 1,828.1 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/26/2014 03:00 | 0.8 | 13.3 | 1,823.3 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/26/2014 04:00 | 0.8 | 13.3 | 1,816.2 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/26/2014 05:00 | 0.8 | 13.2 | 1,854.6 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/26/2014 06:00 | 1.1 | 12.4 | 2,054.4 | 0.7 | 3.5 | 1 | 1 | 1 |
| 02/26/2014 07:00 | 1.0 | 12.0 | 2,147.2 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/26/2014 08:00 | 0.8 | 11.5 | 2,244.6 | 0.7 | 2.5 | 1 | 1 | 1 |
| 02/26/2014 09:00 | 0.8 | 11.5 | 2,246.6 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/26/2014 10:00 | 0.8 | 11.5 | 2,258.3 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/26/2014 11:00 | 0.8 | 11.5 | 2,235.5 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/26/2014 12:00 | 0.9 | 12.0 | 2,132.2 | 0.5 | 2.8 | 1 | 1 | 1 |
| 02/26/2014 13:00 | 0.9 | 11.9 | 2,149.5 | 0.6 | 2.8 | 1 | 1 | 1 |
| 02/26/2014 14:00 | 0.9 | 12.3 | 2,068.1 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/26/2014 15:00 | 0.9 | 12.4 | 2,046.8 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/26/2014 16:00 | 1.0 | 12.7 | 1,995.5 | 0.6 | 3.2 | 1 | 1 | 1 |
| 02/26/2014 17:00 | 0.9 | 12.1 | 2,112.9 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/26/2014 18:00 | 0.9 | 11.9 | 2,143.3 | 0.6 | 2.8 | 1 | 1 | 1 |
| 02/26/2014 19:00 | 0.8 | 11.4 | 2,244.0 | 0.6 | 2.5 | 1 | 1 | 1 |
| 02/26/2014 20:00 | 0.8 | 11.5 | 2,226.6 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/26/2014 21:00 | 0.7 | 11.6 | 2,195.3 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/26/2014 22:00 | 0.8 | 11.7 | 2,170.0 | 0.5 | 2.5 | 1 | 1 | 1 |
| 02/26/2014 23:00 | 0.8 | 12.0 | 2,121.9 | 0.5 | 2.5 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.9 | 12.2 | 2,078.3 | 0.6 | 64.4 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.7 | 11.4 | 1,816.2 | 0.5 | 2.2 | 1 | 1 | 1 |
| **Maximum:** | 1.1 | 13.3 | 2,258.3 | 0.7 | 3.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/27/2014 00:00 | 0.9 | 12.7 | 1,969.2 | 0.5 | 2.9 | 1 | 1 | 1 |
| 02/27/2014 01:00 | 0.7 | 13.3 | 1,834.0 | 0.5 | 2.2 | 1 | 1 | 1 |
| 02/27/2014 02:00 | 0.5 | 13.6 | 1,551.1 | 0.5 | 1.4 | 1 | 1 | 1 |
| 02/27/2014 03:00 | 0.3 | 13.9 | 1,277.2 | 0.4 | 0.7 | 1 | 1 | 0 |
| 02/27/2014 04:00 | 0.3 | 13.8 | 1,565.2 | 0.3 | 0.9 | 1 | 1 | 0 |
| 02/27/2014 05:00 | 0.6 | 13.4 | 1,717.2 | 0.3 | 1.8 | 1 | 1 | 1 |
| 02/27/2014 06:00 | 0.8 | 13.3 | 1,868.9 | 0.4 | 2.6 | 1 | 1 | 1 |
| 02/27/2014 07:00 | 0.9 | 13.3 | 1,851.2 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/27/2014 08:00 | 1.0 | 12.7 | 2,002.5 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/27/2014 09:00 | 1.2 | 13.5 | 1,832.7 | 0.8 | 3.9 | 1 | 1 | 1 |
| 02/27/2014 10:00 | 1.5 | 13.6 | 1,807.6 | 1.0 | 4.9 | 1 | 1 | 1 |
| 02/27/2014 11:00 | 1.3 | 13.6 | 1,804.1 | 1.1 | 4.2 | 1 | 1 | 1 |
| 02/27/2014 12:00 | 0.9 | 13.6 | 1,807.5 | 1.0 | 2.9 | 1 | 1 | 1 |
| 02/27/2014 13:00 | 0.8 | 13.5 | 1,816.8 | 0.8 | 2.6 | 1 | 1 | 1 |
| 02/27/2014 14:00 | 0.8 | 13.5 | 1,815.3 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/27/2014 15:00 | 0.8 | 13.5 | 1,818.0 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/27/2014 16:00 | 0.8 | 13.5 | 1,824.7 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/27/2014 17:00 | 0.8 | 13.3 | 1,880.6 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/27/2014 18:00 | 0.7 | 13.3 | 1,868.0 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/27/2014 19:00 | 1.1 | 12.5 | 2,034.9 | 0.6 | 3.5 | 1 | 1 | 1 |
| 02/27/2014 20:00 | 1.1 | 12.6 | 2,021.7 | 0.7 | 3.5 | 1 | 1 | 1 |
| 02/27/2014 21:00 | 1.1 | 12.6 | 2,032.4 | 0.8 | 3.6 | 1 | 1 | 1 |
| 02/27/2014 22:00 | 1.1 | 12.6 | 2,008.7 | 0.8 | 3.5 | 1 | 1 | 1 |
| 02/27/2014 23:00 | 1.1 | 12.5 | 2,028.5 | 0.8 | 3.5 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.9 | 13.2 | 1,834.9 | 0.7 | 67.4 # | 24 # | 24 # | 22 # |
| **Minimum:** | 0.3 | 12.5 | 1,277.2 | 0.3 | 0.7 | 1 | 1 | 0 |
| **Maximum:** | 1.5 | 13.9 | 2,034.9 | 1.1 | 4.9 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/28/2014 00:00 | 0.8 | 13.1 | 1,881.9 | 0.7 | 2.5 | 1 | 1 | 1 |
| 02/28/2014 01:00 | 0.7 | 13.4 | 1,827.7 | 0.7 | 2.3 | 1 | 1 | 1 |
| 02/28/2014 02:00 | 0.8 | 13.1 | 1,900.2 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/28/2014 03:00 | 0.7 | 13.4 | 1,829.8 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/28/2014 04:00 | 0.7 | 13.4 | 1,830.2 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/28/2014 05:00 | 0.8 | 13.4 | 1,844.3 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/28/2014 06:00 | 0.8 | 13.4 | 1,846.1 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/28/2014 07:00 | 0.8 | 13.2 | 1,859.8 | 0.6 | 2.6 | 1 | 1 | 1 |
| 02/28/2014 08:00 | 1.1 | 12.7 | 2,006.3 | 0.7 | 3.6 | 1 | 1 | 1 |
| 02/28/2014 09:00 | 1.1 | 12.1 | 2,126.5 | 0.7 | 3.5 | 1 | 1 | 1 |
| 02/28/2014 10:00 | 1.0 | 11.9 | 2,169.0 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/28/2014 11:00 | 1.0 | 11.9 | 2,151.2 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/28/2014 12:00 | 1.0 | 12.1 | 2,112.9 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/28/2014 13:00 | 1.0 | 12.6 | 2,005.4 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/28/2014 14:00 | 0.7 | 13.3 | 1,857.0 | 0.6 | 2.3 | 1 | 1 | 1 |
| 02/28/2014 15:00 | 0.9 | 13.0 | 1,925.4 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/28/2014 16:00 | 1.1 | 12.2 | 2,099.2 | 0.6 | 3.5 | 1 | 1 | 1 |
| 02/28/2014 17:00 | 1.1 | 12.4 | 2,056.9 | 0.7 | 3.5 | 1 | 1 | 1 |
| 02/28/2014 18:00 | 0.8 | 13.1 | 1,928.2 | 0.7 | 2.6 | 1 | 1 | 1 |
| 02/28/2014 19:00 | 1.0 | 12.7 | 1,995.6 | 0.7 | 3.2 | 1 | 1 | 1 |
| 02/28/2014 20:00 | 0.7 | 13.3 | 1,835.5 | 0.6 | 2.2 | 1 | 1 | 1 |
| 02/28/2014 21:00 | 0.9 | 13.0 | 1,951.1 | 0.6 | 2.9 | 1 | 1 | 1 |
| 02/28/2014 22:00 | 1.0 | 12.8 | 1,986.0 | 0.6 | 3.2 | 1 | 1 | 1 |
| 02/28/2014 23:00 | 1.1 | 12.6 | 2,025.8 | 0.7 | 3.5 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.9 | 12.8 | 1,960.5 | 0.7 | 69.5 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.7 | 11.9 | 1,827.7 | 0.6 | 2.2 | 1 | 1 | 1 |
| **Maximum:** | 1.1 | 13.4 | 2,169.0 | 0.7 | 3.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/01/2014 00:00 | 0.9 | 13.0 | 1,930.3 | 0.7 | 2.9 | 1 | 1 | 1 |
| 03/01/2014 01:00 | 0.7 | 13.3 | 1,848.8 | 0.7 | 2.2 | 1 | 1 | 1 |
| 03/01/2014 02:00 | 0.7 | 13.3 | 1,819.1 | 0.6 | 2.2 | 1 | 1 | 1 |
| 03/01/2014 03:00 | 0.7 | 13.3 | 1,819.8 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/01/2014 04:00 | 0.7 | 13.3 | 1,818.7 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/01/2014 05:00 | 0.7 | 13.3 | 1,834.2 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/01/2014 06:00 | 0.7 | 13.3 | 1,821.4 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/01/2014 07:00 | 0.7 | 13.3 | 1,820.6 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/01/2014 08:00 | 0.7 | 13.3 | 1,833.4 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/01/2014 09:00 | 0.7 | 13.3 | 1,820.8 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/01/2014 10:00 | 0.7 | 13.3 | 1,826.2 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/01/2014 11:00 | 0.7 | 13.3 | 1,828.4 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/01/2014 12:00 | 0.7 | 13.3 | 1,832.0 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/01/2014 13:00 | 0.7 | 13.3 | 1,858.2 | 0.5 | 2.3 | 1 | 1 | 1 |
| 03/01/2014 14:00 | 1.0 | 12.8 | 1,993.1 | 0.6 | 3.2 | 1 | 1 | 1 |
| 03/01/2014 15:00 | 1.0 | 12.8 | 1,997.0 | 0.6 | 3.3 | 1 | 1 | 1 |
| 03/01/2014 16:00 | 0.7 | 13.4 | 1,862.5 | 0.7 | 2.3 | 1 | 1 | 1 |
| 03/01/2014 17:00 | 0.7 | 13.4 | 1,831.7 | 0.6 | 2.3 | 1 | 1 | 1 |
| 03/01/2014 18:00 | 0.7 | 13.3 | 1,830.7 | 0.6 | 2.2 | 1 | 1 | 1 |
| 03/01/2014 19:00 | 0.9 | 13.0 | 1,937.8 | 0.6 | 2.9 | 1 | 1 | 1 |
| 03/01/2014 20:00 | 0.9 | 13.1 | 1,921.6 | 0.6 | 2.9 | 1 | 1 | 1 |
| 03/01/2014 21:00 | 1.0 | 12.8 | 1,981.9 | 0.7 | 3.2 | 1 | 1 | 1 |
| 03/01/2014 22:00 | 0.9 | 12.9 | 1,977.7 | 0.7 | 2.9 | 1 | 1 | 1 |
| 03/01/2014 23:00 | 1.1 | 12.6 | 2,014.1 | 0.7 | 3.5 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.8 | 13.2 | 1,877.5 | 0.6 | 60.3 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.7 | 12.6 | 1,818.7 | 0.5 | 2.2 | 1 | 1 | 1 |
| **Maximum:** | 1.1 | 13.4 | 2,014.1 | 0.7 | 3.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/02/2014 00:00 | 0.8 | 13.2 | 1,906.6 | 0.7 | 2.6 | 1 | 1 | 1 |
| 03/02/2014 01:00 | 1.0 | 12.8 | 2,006.7 | 0.7 | 3.3 | 1 | 1 | 1 |
| 03/02/2014 02:00 | 0.9 | 13.0 | 1,986.0 | 0.7 | 3.0 | 1 | 1 | 1 |
| 03/02/2014 03:00 | 0.7 | 13.3 | 1,849.9 | 0.6 | 2.3 | 1 | 1 | 1 |
| 03/02/2014 04:00 | 0.7 | 13.3 | 1,828.7 | 0.6 | 2.2 | 1 | 1 | 1 |
| 03/02/2014 05:00 | 0.7 | 13.3 | 1,870.8 | 0.5 | 2.3 | 1 | 1 | 1 |
| 03/02/2014 06:00 | 0.9 | 13.0 | 1,971.6 | 0.6 | 3.0 | 1 | 1 | 1 |
| 03/02/2014 07:00 | 1.1 | 12.7 | 2,042.2 | 0.7 | 3.6 | 1 | 1 | 1 |
| 03/02/2014 08:00 | 1.0 | 12.7 | 2,035.2 | 0.7 | 3.3 | 1 | 1 | 1 |
| 03/02/2014 09:00 | 0.7 | 13.2 | 1,929.4 | 0.7 | 2.3 | 1 | 1 | 1 |
| 03/02/2014 10:00 | 1.0 | 12.8 | 2,018.5 | 0.6 | 3.3 | 1 | 1 | 1 |
| 03/02/2014 11:00 | 1.1 | 11.9 | 2,186.1 | 0.6 | 3.5 | 1 | 1 | 1 |
| 03/02/2014 12:00 | 1.1 | 12.0 | 2,157.9 | 0.7 | 3.5 | 1 | 1 | 1 |
| 03/02/2014 13:00 | 0.9 | 11.7 | 2,207.8 | 0.7 | 2.9 | 1 | 1 | 1 |
| 03/02/2014 14:00 | 0.9 | 11.7 | 2,196.4 | 0.6 | 2.8 | 1 | 1 | 1 |
| 03/02/2014 15:00 | 0.9 | 11.7 | 2,191.4 | 0.6 | 2.8 | 1 | 1 | 1 |
| 03/02/2014 16:00 | 0.9 | 11.7 | 2,186.7 | 0.6 | 2.8 | 1 | 1 | 1 |
| 03/02/2014 17:00 | 1.0 | 11.9 | 2,150.0 | 0.6 | 3.2 | 1 | 1 | 1 |
| 03/02/2014 18:00 | 1.0 | 12.2 | 2,075.0 | 0.7 | 3.1 | 1 | 1 | 1 |
| 03/02/2014 19:00 | 1.1 | 12.3 | 2,087.9 | 0.7 | 3.5 | 1 | 1 | 1 |
| 03/02/2014 20:00 | 1.0 | 12.6 | 2,023.0 | 0.7 | 3.2 | 1 | 1 | 1 |
| 03/02/2014 21:00 | 1.1 | 12.2 | 2,115.3 | 0.7 | 3.5 | 1 | 1 | 1 |
| 03/02/2014 22:00 | 0.9 | 12.7 | 2,030.2 | 0.7 | 2.9 | 1 | 1 | 1 |
| 03/02/2014 23:00 | 0.8 | 12.9 | 1,968.4 | 0.6 | 2.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.9 | 12.5 | 2,042.6 | 0.7 | 71.5 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.7 | 11.7 | 1,828.7 | 0.5 | 2.2 | 1 | 1 | 1 |
| **Maximum:** | 1.1 | 13.3 | 2,207.8 | 0.7 | 3.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/03/2014 00:00 | 0.5 | 13.5 | 1,591.3 | 0.5 | 1.4 | 1 | 1 | 1 |
| 03/03/2014 01:00 | 0.3 | 13.8 | 1,430.6 | 0.4 | 0.8 | 1 | 1 | 0 |
| 03/03/2014 02:00 | 0.4 | 13.8 | 1,287.8 | 0.3 | 1.0 | 1 | 1 | 0 |
| 03/03/2014 03:00 | 0.4 | 13.8 | 1,285.3 | 0.3 | 1.0 | 1 | 1 | 0 |
| 03/03/2014 04:00 | 0.4 | 13.8 | 1,290.9 | 0.3 | 1.0 | 1 | 1 | 0 |
| 03/03/2014 05:00 | 0.6 | 13.5 | 1,581.8 | 0.4 | 1.7 | 1 | 1 | 1 |
| 03/03/2014 06:00 | 0.7 | 13.2 | 1,862.6 | 0.4 | 2.2 | 1 | 1 | 1 |
| 03/03/2014 07:00 | 1.0 | 12.8 | 1,982.3 | 0.6 | 3.2 | 1 | 1 | 1 |
| 03/03/2014 08:00 | 1.1 | 11.8 | 2,207.6 | 0.6 | 3.5 | 1 | 1 | 1 |
| 03/03/2014 09:00 | 1.0 | 12.1 | 2,138.0 | 0.7 | 3.2 | 1 | 1 | 1 |
| 03/03/2014 10:00 | 0.9 | 12.9 | 1,977.9 | 0.7 | 2.9 | 1 | 1 | 1 |
| 03/03/2014 11:00 | 0.7 | 13.1 | 1,905.2 | 0.6 | 2.3 | 1 | 1 | 1 |
| 03/03/2014 12:00 | 0.7 | 13.2 | 1,860.5 | 0.6 | 2.2 | 1 | 1 | 1 |
| 03/03/2014 13:00 | 0.7 | 13.3 | 1,840.4 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/03/2014 14:00 | 0.7 | 13.3 | 1,859.5 | 0.5 | 2.3 | 1 | 1 | 1 |
| 03/03/2014 15:00 | 0.7 | 13.2 | 1,900.0 | 0.5 | 2.3 | 1 | 1 | 1 |
| 03/03/2014 16:00 | 0.9 | 12.9 | 1,991.4 | 0.6 | 3.0 | 1 | 1 | 1 |
| 03/03/2014 17:00 | 1.1 | 11.9 | 2,202.4 | 0.6 | 3.6 | 1 | 1 | 1 |
| 03/03/2014 18:00 | 1.0 | 12.4 | 2,057.6 | 0.7 | 3.2 | 1 | 1 | 1 |
| 03/03/2014 19:00 | 1.0 | 11.8 | 2,193.6 | 0.7 | 3.2 | 1 | 1 | 1 |
| 03/03/2014 20:00 | 0.9 | 11.6 | 2,233.5 | 0.6 | 2.9 | 1 | 1 | 1 |
| 03/03/2014 21:00 | 0.9 | 11.8 | 2,196.1 | 0.6 | 2.9 | 1 | 1 | 1 |
| 03/03/2014 22:00 | 0.8 | 12.9 | 1,941.6 | 0.6 | 2.6 | 1 | 1 | 1 |
| 03/03/2014 23:00 | 0.6 | 13.2 | 1,817.3 | 0.6 | 1.9 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.8 | 12.9 | 1,859.8 | 0.5 | 56.5 # | 24 # | 24 # | 20 # |
| **Minimum:** | 0.3 | 11.6 | 1,285.3 | 0.3 | 0.8 | 1 | 1 | 0 |
| **Maximum:** | 1.1 | 13.8 | 2,233.5 | 0.7 | 3.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/04/2014 00:00 | 0.5 | 13.5 | 1,560.1 | 0.5 | 1.4 | 1 | 1 | 1 |
| 03/04/2014 01:00 | 0.3 | 13.8 | 1,255.3 | 0.4 | 0.7 | 1 | 1 | 0 |
| 03/04/2014 02:00 | 0.4 | 13.8 | 1,265.9 | 0.3 | 0.9 | 1 | 1 | 0 |
| 03/04/2014 03:00 | 0.4 | 13.8 | 1,329.7 | 0.3 | 1.0 | 1 | 1 | 0 |
| 03/04/2014 04:00 | 0.4 | 13.8 | 1,276.0 | 0.3 | 0.9 | 1 | 1 | 0 |
| 03/04/2014 05:00 | 0.5 | 13.8 | 1,292.1 | 0.3 | 1.2 | 1 | 1 | 0 |
| 03/04/2014 06:00 | 0.6 | 13.6 | 1,583.5 | 0.4 | 1.7 | 1 | 1 | 1 |
| 03/04/2014 07:00 | 0.6 | 13.4 | 1,838.3 | 0.5 | 1.9 | 1 | 1 | 1 |
| 03/04/2014 08:00 | 0.6 | 13.4 | 1,829.2 | 0.5 | 1.9 | 1 | 1 | 1 |
| 03/04/2014 09:00 | 0.4 | 13.8 | 1,430.3 | 0.4 | 1.1 | 1 | 1 | 1 |
| 03/04/2014 10:00 | 0.4 | 13.9 | 1,230.0 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/04/2014 11:00 | 0.4 | 13.9 | 1,230.7 | 0.3 | 0.9 | 1 | 1 | 0 |
| 03/04/2014 12:00 | 0.4 | 13.8 | 1,263.7 | 0.3 | 0.9 | 1 | 1 | 0 |
| 03/04/2014 13:00 | 0.4 | 13.8 | 1,419.1 | 0.3 | 1.1 | 1 | 1 | 0 |
| 03/04/2014 14:00 | 0.7 | 13.4 | 1,841.4 | 0.4 | 2.3 | 1 | 1 | 1 |
| 03/04/2014 15:00 | 0.7 | 13.4 | 1,844.0 | 0.5 | 2.3 | 1 | 1 | 1 |
| 03/04/2014 16:00 | 0.7 | 13.4 | 1,844.3 | 0.6 | 2.3 | 1 | 1 | 1 |
| 03/04/2014 17:00 | 0.6 | 13.4 | 1,845.5 | 0.6 | 1.9 | 1 | 1 | 1 |
| 03/04/2014 18:00 | 0.7 | 13.3 | 1,882.1 | 0.5 | 2.3 | 1 | 1 | 1 |
| 03/04/2014 19:00 | 1.1 | 12.2 | 2,130.6 | 0.6 | 3.6 | 1 | 1 | 1 |
| 03/04/2014 20:00 | 1.0 | 12.3 | 2,088.4 | 0.6 | 3.2 | 1 | 1 | 1 |
| 03/04/2014 21:00 | 1.0 | 12.8 | 1,996.8 | 0.7 | 3.3 | 1 | 1 | 1 |
| 03/04/2014 22:00 | 0.8 | 13.0 | 1,929.5 | 0.7 | 2.6 | 1 | 1 | 1 |
| 03/04/2014 23:00 | 0.6 | 13.4 | 1,836.0 | 0.6 | 1.9 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.6 | 13.4 | 1,626.8 | 0.5 | 42.2 # | 24 # | 24 # | 15 # |
| **Minimum:** | 0.3 | 12.2 | 1,230.0 | 0.3 | 0.7 | 1 | 1 | 0 |
| **Maximum:** | 1.1 | 13.9 | 2,130.6 | 0.7 | 3.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/05/2014 00:00 | 0.6 | 13.4 | 1,857.5 | 0.5 | 2.0 | 1 | 1 | 1 |
| 03/05/2014 01:00 | 0.9 | 12.9 | 1,980.0 | 0.6 | 2.9 | 1 | 1 | 1 |
| 03/05/2014 02:00 | 0.9 | 12.8 | 1,988.8 | 0.6 | 2.9 | 1 | 1 | 1 |
| 03/05/2014 03:00 | 0.7 | 13.2 | 1,866.8 | 0.6 | 2.2 | 1 | 1 | 1 |
| 03/05/2014 04:00 | 0.6 | 13.3 | 1,825.9 | 0.6 | 1.9 | 1 | 1 | 1 |
| 03/05/2014 05:00 | 0.8 | 13.0 | 1,943.0 | 0.5 | 2.6 | 1 | 1 | 1 |
| 03/05/2014 06:00 | 0.7 | 13.1 | 1,913.1 | 0.5 | 2.3 | 1 | 1 | 1 |
| 03/05/2014 07:00 | 0.8 | 13.1 | 1,932.2 | 0.6 | 2.6 | 1 | 1 | 1 |
| 03/05/2014 08:00 | 0.9 | 13.0 | 1,940.2 | 0.6 | 2.9 | 1 | 1 | 1 |
| 03/05/2014 09:00 | 0.7 | 13.3 | 1,847.5 | 0.6 | 2.2 | 1 | 1 | 1 |
| 03/05/2014 10:00 | 0.7 | 13.3 | 1,849.1 | 0.6 | 2.2 | 1 | 1 | 1 |
| 03/05/2014 11:00 | 0.7 | 13.3 | 1,852.1 | 0.5 | 2.3 | 1 | 1 | 1 |
| 03/05/2014 12:00 | 0.7 | 13.3 | 1,852.4 | 0.5 | 2.3 | 1 | 1 | 1 |
| 03/05/2014 13:00 | 0.7 | 13.3 | 1,852.3 | 0.5 | 2.3 | 1 | 1 | 1 |
| 03/05/2014 14:00 | 0.8 | 13.3 | 1,852.8 | 0.5 | 2.6 | 1 | 1 | 1 |
| 03/05/2014 15:00 | 0.7 | 13.3 | 1,857.7 | 0.5 | 2.3 | 1 | 1 | 1 |
| 03/05/2014 16:00 | 0.8 | 13.1 | 1,896.2 | 0.6 | 2.6 | 1 | 1 | 1 |
| 03/05/2014 17:00 | 0.9 | 12.9 | 1,939.9 | 0.6 | 2.9 | 1 | 1 | 1 |
| 03/05/2014 18:00 | 0.9 | 12.9 | 1,945.0 | 0.7 | 2.9 | 1 | 1 | 1 |
| 03/05/2014 19:00 | 1.1 | 12.5 | 2,038.9 | 0.7 | 3.5 | 1 | 1 | 1 |
| 03/05/2014 20:00 | 1.0 | 12.7 | 1,989.2 | 0.7 | 3.2 | 1 | 1 | 1 |
| 03/05/2014 21:00 | 0.9 | 12.9 | 1,963.1 | 0.7 | 2.9 | 1 | 1 | 1 |
| 03/05/2014 22:00 | 0.9 | 12.9 | 1,953.3 | 0.7 | 2.9 | 1 | 1 | 1 |
| 03/05/2014 23:00 | 0.7 | 13.3 | 1,828.5 | 0.6 | 2.2 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.8 | 13.1 | 1,906.9 | 0.6 | 61.6 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.6 | 12.5 | 1,825.9 | 0.5 | 1.9 | 1 | 1 | 1 |
| **Maximum:** | 1.1 | 13.4 | 2,038.9 | 0.7 | 3.5 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/06/2014 00:00 | 0.7 | 13.3 | 1,826.7 | 0.6 | 2.2 | 1 | 1 | 1 |
| 03/06/2014 01:00 | 0.7 | 13.3 | 1,783.2 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/06/2014 02:00 | 0.3 | 13.9 | 1,271.4 | 0.4 | 0.7 | 1 | 1 | 0 |
| 03/06/2014 03:00 | 13.1 | 15.8 | 583.3 | 0.0 | 4.6 | 1 | 0 | 0 |
| 03/06/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 3.7 | 14.1 | 1,366.2 | 0.5 | 9.7 # | 4 # | 3 # | 2 # |
| **Minimum:** | 0.3 | 13.3 | 583.3 | 0.4 | 0.7 | 0 | 0 | 0 |
| **Maximum:** | 13.1 | 15.8 | 1,826.7 | 0.6 | 4.6 | 1 | 1 | 1 |
| **%SI** | 83.3 | 83.3 | 83.3 | 87.5 | 83.3 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/07/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 03:00 | 57.3 | 17.5 | 500.2 | 0.0 | 69.0 | 1 | 0 | 0 |
| 03/07/2014 04:00 | 21.1 | 16.6 | 621.9 | 0.0 | 40.3 | 1 | 0 | 0 |
| 03/07/2014 05:00 | 27.9 | 14.9 | 964.7 | 0.0 | 59.2 | 1 | 0 | 0 |
| 03/07/2014 06:00 | 0.3 | 13.9 | 1,449.7 | 0.0 | 0.8 | 1 | 0 | 0 |
| 03/07/2014 07:00 | 0.3 | 13.8 | 1,799.4 | 0.0 | 1.0 | 1 | 0 | 0 |
| 03/07/2014 08:00 | 0.3 | 13.9 | 1,542.5 | 0.3 | 0.9 | 1 | 0 | 0 |
| 03/07/2014 09:00 | 0.3 | 13.9 | 1,332.7 | 0.3 | 0.8 | 1 | 1 | 0 |
| 03/07/2014 10:00 | 0.7 | 13.4 | 1,794.3 | 0.4 | 2.2 | 1 | 1 | 1 |
| 03/07/2014 11:00 | 0.7 | 13.3 | 1,829.0 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/07/2014 12:00 | 0.7 | 13.3 | 1,837.2 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/07/2014 13:00 | 0.7 | 13.4 | 1,836.8 | 0.5 | 2.3 | 1 | 1 | 1 |
| 03/07/2014 14:00 | 0.7 | 13.4 | 1,833.6 | 0.6 | 2.3 | 1 | 1 | 1 |
| 03/07/2014 15:00 | 0.7 | 13.4 | 1,833.2 | 0.6 | 2.3 | 1 | 1 | 1 |
| 03/07/2014 16:00 | 0.7 | 13.3 | 1,857.8 | 0.6 | 2.3 | 1 | 1 | 1 |
| 03/07/2014 17:00 | 1.0 | 12.8 | 2,010.7 | 0.6 | 3.3 | 1 | 1 | 1 |
| 03/07/2014 18:00 | 1.0 | 12.8 | 2,013.9 | 0.6 | 3.3 | 1 | 1 | 1 |
| 03/07/2014 19:00 | 1.1 | 12.1 | 2,164.4 | 0.7 | 3.6 | 1 | 1 | 1 |
| 03/07/2014 20:00 | 0.9 | 11.6 | 2,240.9 | 0.7 | 2.9 | 1 | 1 | 1 |
| 03/07/2014 21:00 | 0.9 | 11.8 | 2,220.3 | 0.6 | 2.9 | 1 | 1 | 1 |
| 03/07/2014 22:00 | 0.9 | 11.8 | 2,219.4 | 0.6 | 2.9 | 1 | 1 | 1 |
| 03/07/2014 23:00 | 0.9 | 12.1 | 2,141.1 | 0.6 | 2.9 | 1 | 1 | 1 |
| **Average/Sum#:** | 5.7 | 13.5 | 1,716.4 | 0.5 | 209.6 # | 21 # | 15 # | 14 # |
| **Minimum:** | 0.3 | 11.6 | 500.2 | 0.3 | 0.8 | 0 | 0 | 0 |
| **Maximum:** | 57.3 | 17.5 | 2,240.9 | 0.7 | 69.0 | 1 | 1 | 1 |
| **%SI** | 12.5 | 12.5 | 12.5 | 33.3 | 12.5 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/08/2014 00:00 | 0.6 | 13.2 | 1,925.7 | 0.6 | 2.0 | 1 | 1 | 1 |
| 03/08/2014 01:00 | 0.7 | 13.1 | 1,946.3 | 0.5 | 2.3 | 1 | 1 | 1 |
| 03/08/2014 02:00 | 0.7 | 13.2 | 1,905.0 | 0.5 | 2.3 | 1 | 1 | 1 |
| 03/08/2014 03:00 | 0.7 | 13.2 | 1,886.9 | 0.5 | 2.3 | 1 | 1 | 1 |
| 03/08/2014 04:00 | 0.7 | 13.1 | 1,949.1 | 0.5 | 2.3 | 1 | 1 | 1 |
| 03/08/2014 05:00 | 0.9 | 12.9 | 1,993.0 | 0.6 | 3.0 | 1 | 1 | 1 |
| 03/08/2014 06:00 | 0.9 | 12.7 | 2,026.4 | 0.6 | 2.9 | 1 | 1 | 1 |
| 03/08/2014 07:00 | 0.8 | 13.0 | 2,003.9 | 0.6 | 2.7 | 1 | 1 | 1 |
| 03/08/2014 08:00 | 0.6 | 13.3 | 1,859.3 | 0.6 | 1.9 | 1 | 1 | 1 |
| 03/08/2014 09:00 | 0.6 | 13.3 | 1,810.5 | 0.5 | 1.9 | 1 | 1 | 1 |
| 03/08/2014 10:00 | 0.6 | 13.3 | 1,811.0 | 0.5 | 1.9 | 1 | 1 | 1 |
| 03/08/2014 11:00 | 0.6 | 13.3 | 1,814.6 | 0.5 | 1.9 | 1 | 1 | 1 |
| 03/08/2014 12:00 | 0.6 | 13.3 | 1,816.4 | 0.5 | 1.9 | 1 | 1 | 1 |
| 03/08/2014 13:00 | 0.7 | 13.4 | 1,815.8 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/08/2014 14:00 | 0.6 | 13.4 | 1,814.2 | 0.5 | 1.9 | 1 | 1 | 1 |
| 03/08/2014 15:00 | 0.6 | 13.4 | 1,811.8 | 0.5 | 1.9 | 1 | 1 | 1 |
| 03/08/2014 16:00 | 0.6 | 13.4 | 1,823.0 | 0.5 | 1.9 | 1 | 1 | 1 |
| 03/08/2014 17:00 | 0.7 | 13.3 | 1,851.6 | 0.5 | 2.3 | 1 | 1 | 1 |
| 03/08/2014 18:00 | 1.0 | 12.3 | 2,093.9 | 0.6 | 3.2 | 1 | 1 | 1 |
| 03/08/2014 19:00 | 1.0 | 11.9 | 2,180.2 | 0.6 | 3.2 | 1 | 1 | 1 |
| 03/08/2014 20:00 | 0.9 | 11.6 | 2,216.1 | 0.7 | 2.8 | 1 | 1 | 1 |
| 03/08/2014 21:00 | 0.8 | 11.6 | 2,211.5 | 0.6 | 2.5 | 1 | 1 | 1 |
| 03/08/2014 22:00 | 0.8 | 11.6 | 2,215.1 | 0.5 | 2.5 | 1 | 1 | 1 |
| 03/08/2014 23:00 | 0.9 | 11.9 | 2,169.4 | 0.5 | 2.9 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.7 | 12.9 | 1,956.3 | 0.5 | 56.6 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.6 | 11.6 | 1,810.5 | 0.5 | 1.9 | 1 | 1 | 1 |
| **Maximum:** | 1.0 | 13.4 | 2,216.1 | 0.7 | 3.2 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/09/2014 00:00 | 0.7 | 13.1 | 1,802.8 | 0.5 | 2.1 | 1 | 1 | 1 |
| 03/09/2014 01:00 | 0.3 | 13.8 | 1,375.4 | 0.4 | 0.8 | 1 | 1 | 0 |
| 03/09/2014 02:00 | 13.9 | 15.7 | 616.2 | 0.0 | 5.0 | 1 | 0 | 0 |
| 03/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 11:00 | 29.4 | 16.9 | 577.4 | 0.0 | 44.8 | 1 | 0 | 0 |
| 03/09/2014 12:00 | 41.5 | 15.1 | 890.5 | 0.0 | 84.2 | 1 | 0 | 0 |
| 03/09/2014 13:00 | 0.4 | 13.9 | 1,349.7 | 0.0 | 1.0 | 1 | 0 | 0 |
| 03/09/2014 14:00 | 0.4 | 13.7 | 1,765.6 | 0.0 | 1.3 | 1 | 0 | 0 |
| 03/09/2014 15:00 | 0.4 | 13.7 | 1,758.7 | 0.3 | 1.3 | 1 | 0 | 0 |
| 03/09/2014 16:00 | 0.4 | 13.8 | 1,512.7 | 0.3 | 1.1 | 1 | 0 | 1 |
| 03/09/2014 17:00 | 1.1 | 12.6 | 2,056.3 | 0.5 | 3.6 | 1 | 1 | 1 |
| 03/09/2014 18:00 | 1.0 | 11.8 | 2,200.0 | 0.6 | 3.2 | 1 | 1 | 1 |
| 03/09/2014 19:00 | 0.9 | 11.6 | 2,229.7 | 0.7 | 2.8 | 1 | 1 | 1 |
| 03/09/2014 20:00 | 0.9 | 11.6 | 2,220.8 | 0.6 | 2.8 | 1 | 1 | 1 |
| 03/09/2014 21:00 | 0.8 | 11.6 | 2,221.7 | 0.6 | 2.5 | 1 | 1 | 1 |
| 03/09/2014 22:00 | 1.0 | 12.4 | 2,069.1 | 0.6 | 3.2 | 1 | 1 | 1 |
| 03/09/2014 23:00 | 0.9 | 11.7 | 2,197.3 | 0.6 | 2.8 | 1 | 1 | 1 |
| **Average/Sum#:** | 5.9 | 13.3 | 1,677.7 | 0.5 | 162.5 # | 16 # | 9 # | 9 # |
| **Minimum:** | 0.3 | 11.6 | 577.4 | 0.3 | 0.8 | 0 | 0 | 0 |
| **Maximum:** | 41.5 | 16.9 | 2,229.7 | 0.7 | 84.2 | 1 | 1 | 1 |
| **%SI** | 33.3 | 33.3 | 33.3 | 54.2 | 33.3 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/10/2014 00:00 | 1.0 | 12.2 | 2,078.4 | 0.7 | 3.2 | 1 | 1 | 1 |
| 03/10/2014 01:00 | 0.4 | 13.8 | 1,308.5 | 0.5 | 1.0 | 1 | 1 | 1 |
| 03/10/2014 02:00 | 0.4 | 13.9 | 1,233.0 | 0.4 | 0.9 | 1 | 1 | 0 |
| 03/10/2014 03:00 | 0.4 | 13.9 | 1,236.7 | 0.3 | 0.9 | 1 | 1 | 0 |
| 03/10/2014 04:00 | 0.4 | 13.9 | 1,242.6 | 0.3 | 0.9 | 1 | 1 | 0 |
| 03/10/2014 05:00 | 0.5 | 13.7 | 1,545.5 | 0.3 | 1.4 | 1 | 1 | 1 |
| 03/10/2014 06:00 | 1.0 | 13.0 | 1,966.8 | 0.5 | 3.3 | 1 | 1 | 1 |
| 03/10/2014 07:00 | 1.1 | 12.1 | 2,152.3 | 0.6 | 3.6 | 1 | 1 | 1 |
| 03/10/2014 08:00 | 1.0 | 12.3 | 2,104.5 | 0.7 | 3.2 | 1 | 1 | 1 |
| 03/10/2014 09:00 | 0.7 | 13.2 | 1,855.3 | 0.6 | 2.2 | 1 | 1 | 1 |
| 03/10/2014 10:00 | 0.7 | 13.3 | 1,815.5 | 0.6 | 2.2 | 1 | 1 | 1 |
| 03/10/2014 11:00 | 0.7 | 13.3 | 1,820.7 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/10/2014 12:00 | 0.7 | 13.3 | 1,821.2 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/10/2014 13:00 | 0.7 | 13.4 | 1,822.9 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/10/2014 14:00 | 0.7 | 13.4 | 1,826.3 | 0.6 | 2.3 | 1 | 1 | 1 |
| 03/10/2014 15:00 | 0.7 | 13.4 | 1,830.1 | 0.6 | 2.3 | 1 | 1 | 1 |
| 03/10/2014 16:00 | 0.7 | 13.4 | 1,827.4 | 0.6 | 2.3 | 1 | 1 | 1 |
| 03/10/2014 17:00 | 0.7 | 13.4 | 1,826.5 | 0.6 | 2.3 | 1 | 1 | 1 |
| 03/10/2014 18:00 | 0.6 | 13.5 | 1,848.8 | 0.6 | 2.0 | 1 | 1 | 1 |
| 03/10/2014 19:00 | 1.1 | 12.2 | 2,144.2 | 0.6 | 3.6 | 1 | 1 | 1 |
| 03/10/2014 20:00 | 0.9 | 12.4 | 2,082.3 | 0.6 | 2.9 | 1 | 1 | 1 |
| 03/10/2014 21:00 | 0.6 | 13.5 | 1,710.9 | 0.6 | 1.8 | 1 | 1 | 1 |
| 03/10/2014 22:00 | 0.3 | 13.9 | 1,389.4 | 0.5 | 0.8 | 1 | 1 | 0 |
| 03/10/2014 23:00 | 13.5 | 15.9 | 574.3 | 0.0 | 4.7 | 1 | 0 | 0 |
| **Average/Sum#:** | 1.2 | 13.3 | 1,711.0 | 0.5 | 54.4 # | 24 # | 23 # | 19 # |
| **Minimum:** | 0.3 | 12.1 | 574.3 | 0.3 | 0.8 | 1 | 0 | 0 |
| **Maximum:** | 13.5 | 15.9 | 2,152.3 | 0.7 | 4.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 4.2 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/11/2014 02:00 | 10.8 | 17.5 | 483.5 | 0.0 | 12.2 | 1 | 0 | 0 |
| 03/11/2014 03:00 | 15.0 | 15.4 | 927.1 | 0.0 | 33.4 | 1 | 0 | 0 |
| 03/11/2014 04:00 | 0.3 | 13.9 | 1,331.6 | 0.0 | 0.8 | 1 | 0 | 0 |
| 03/11/2014 05:00 | 0.3 | 13.8 | 1,580.0 | 0.0 | 0.9 | 1 | 0 | 0 |
| 03/11/2014 06:00 | 0.3 | 13.9 | 1,524.1 | 0.3 | 0.9 | 1 | 0 | 0 |
| 03/11/2014 07:00 | 0.4 | 13.7 | 1,762.6 | 0.3 | 1.3 | 1 | 1 | 0 |
| 03/11/2014 08:00 | 0.8 | 13.2 | 1,904.3 | 0.4 | 2.6 | 1 | 1 | 1 |
| 03/11/2014 09:00 | 0.7 | 13.3 | 1,812.0 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/11/2014 10:00 | 0.7 | 13.3 | 1,813.5 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/11/2014 11:00 | 0.7 | 13.4 | 1,815.3 | 0.5 | 2.2 | 1 | 1 | 1 |
| 03/11/2014 12:00 | 0.6 | 13.5 | 1,717.4 | 0.5 | 1.8 | 1 | 1 | 1 |
| 03/11/2014 13:00 | 0.3 | 13.9 | 1,329.3 | 0.5 | 0.8 | 1 | 1 | 0 |
| 03/11/2014 14:00 | 0.3 | 14.0 | 1,269.2 | 0.4 | 0.7 | 1 | 1 | 0 |
| 03/11/2014 15:00 | 0.3 | 14.0 | 1,295.1 | 0.3 | 0.7 | 1 | 1 | 0 |
| 03/11/2014 16:00 | 0.3 | 14.0 | 1,370.3 | 0.3 | 0.8 | 1 | 1 | 0 |
| 03/11/2014 17:00 | 0.3 | 14.0 | 1,382.4 | 0.3 | 0.8 | 1 | 1 | 0 |
| 03/11/2014 18:00 | 0.5 | 13.7 | 1,564.9 | 0.3 | 1.4 | 1 | 1 | 1 |
| 03/11/2014 19:00 | 1.0 | 12.5 | 2,069.1 | 0.5 | 3.3 | 1 | 1 | 1 |
| 03/11/2014 20:00 | 1.0 | 12.2 | 2,140.0 | 0.6 | 3.2 | 1 | 1 | 1 |
| 03/11/2014 21:00 | 1.0 | 12.5 | 2,081.1 | 0.7 | 3.3 | 1 | 1 | 1 |
| 03/11/2014 22:00 | 1.0 | 12.2 | 2,140.6 | 0.7 | 3.2 | 1 | 1 | 1 |
| 03/11/2014 23:00 | 0.6 | 13.4 | 1,728.1 | 0.6 | 1.8 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.7 | 13.7 | 1,592.8 | 0.5 | 80.5 # | 22 # | 17 # | 11 # |
| **Minimum:** | 0.3 | 12.2 | 483.5 | 0.3 | 0.7 | 0 | 0 | 0 |
| **Maximum:** | 15.0 | 17.5 | 2,140.6 | 0.7 | 33.4 | 1 | 1 | 1 |
| **%SI** | 8.3 | 8.3 | 8.3 | 25.0 | 8.3 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/12/2014 00:00 | 0.3 | 13.9 | 1,271.1 | 0.5 | 0.7 | 1 | 1 | 0 |
| 03/12/2014 01:00 | 0.3 | 13.9 | 1,257.2 | 0.4 | 0.7 | 1 | 1 | 0 |
| 03/12/2014 02:00 | 0.3 | 13.9 | 1,234.8 | 0.3 | 0.7 | 1 | 1 | 0 |
| 03/12/2014 03:00 | 0.3 | 13.9 | 1,226.2 | 0.3 | 0.7 | 1 | 1 | 0 |
| 03/12/2014 04:00 | 0.4 | 13.9 | 1,231.0 | 0.3 | 0.9 | 1 | 1 | 0 |
| 03/12/2014 05:00 | 0.6 | 13.5 | 1,701.6 | 0.4 | 1.8 | 1 | 1 | 1 |
| 03/12/2014 06:00 | 0.8 | 13.1 | 1,953.6 | 0.5 | 2.6 | 1 | 1 | 1 |
| 03/12/2014 07:00 | 1.0 | 12.0 | 2,152.5 | 0.6 | 3.2 | 1 | 1 | 1 |
| 03/12/2014 08:00 | 0.8 | 13.0 | 1,955.3 | 0.6 | 2.6 | 1 | 1 | 1 |
| 03/12/2014 09:00 | 0.6 | 13.3 | 1,830.9 | 0.6 | 1.9 | 1 | 1 | 1 |
| 03/12/2014 10:00 | 0.6 | 13.3 | 1,832.0 | 0.5 | 1.9 | 1 | 1 | 1 |
| 03/12/2014 11:00 | 0.6 | 13.4 | 1,834.2 | 0.5 | 1.9 | 1 | 1 | 1 |
| 03/12/2014 12:00 | 0.4 | 13.8 | 1,356.4 | 0.4 | 1.0 | 1 | 1 | 1 |
| 03/12/2014 13:00 | 0.3 | 14.0 | 1,372.1 | 0.4 | 0.8 | 1 | 1 | 0 |
| 03/12/2014 14:00 | 0.3 | 14.0 | 1,244.8 | 0.3 | 0.7 | 1 | 1 | 0 |
| 03/12/2014 15:00 | 0.3 | 14.0 | 1,243.8 | 0.3 | 0.7 | 1 | 1 | 0 |
| 03/12/2014 16:00 | 0.3 | 14.0 | 1,243.9 | 0.3 | 0.7 | 1 | 1 | 0 |
| 03/12/2014 17:00 | 0.5 | 13.7 | 1,543.6 | 0.3 | 1.4 | 1 | 1 | 1 |
| 03/12/2014 18:00 | 0.8 | 13.2 | 1,902.3 | 0.4 | 2.6 | 1 | 1 | 1 |
| 03/12/2014 19:00 | 1.1 | 12.1 | 2,173.3 | 0.6 | 3.6 | 1 | 1 | 1 |
| 03/12/2014 20:00 | 1.0 | 12.0 | 2,191.8 | 0.7 | 3.3 | 1 | 1 | 1 |
| 03/12/2014 21:00 | 0.9 | 11.6 | 2,257.8 | 0.7 | 2.9 | 1 | 1 | 1 |
| 03/12/2014 22:00 | 0.9 | 11.6 | 2,254.8 | 0.6 | 2.9 | 1 | 1 | 1 |
| 03/12/2014 23:00 | 0.9 | 12.1 | 2,148.7 | 0.6 | 2.9 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.6 | 13.2 | 1,683.9 | 0.5 | 43.1 # | 24 # | 24 # | 15 # |
| **Minimum:** | 0.3 | 11.6 | 1,226.2 | 0.3 | 0.7 | 1 | 1 | 0 |
| **Maximum:** | 1.1 | 14.0 | 2,257.8 | 0.7 | 3.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/13/2014 00:00 | 0.4 | 13.6 | 1,674.8 | 0.5 | 1.2 | 1 | 1 | 1 |
| 03/13/2014 01:00 | 0.3 | 13.8 | 1,791.5 | 0.4 | 1.0 | 1 | 1 | 0 |
| 03/13/2014 02:00 | 0.4 | 13.9 | 1,390.1 | 0.3 | 1.0 | 1 | 1 | 0 |
| 03/13/2014 03:00 | 0.4 | 13.9 | 1,373.6 | 0.3 | 1.0 | 1 | 1 | 0 |
| 03/13/2014 04:00 | 0.4 | 13.9 | 1,376.4 | 0.3 | 1.0 | 1 | 1 | 0 |
| 03/13/2014 05:00 | 0.9 | 13.2 | 1,851.8 | 0.4 | 2.9 | 1 | 1 | 1 |
| 03/13/2014 06:00 | 0.9 | 13.1 | 1,960.2 | 0.6 | 3.0 | 1 | 1 | 1 |
| 03/13/2014 07:00 | 1.0 | 11.8 | 2,206.5 | 0.7 | 3.2 | 1 | 1 | 1 |
| 03/13/2014 08:00 | 1.0 | 12.5 | 2,092.1 | 0.7 | 3.3 | 1 | 1 | 1 |
| 03/13/2014 09:00 | 0.9 | 12.9 | 1,976.1 | 0.7 | 2.9 | 1 | 1 | 1 |
| 03/13/2014 10:00 | 0.7 | 13.3 | 1,882.3 | 0.6 | 2.3 | 1 | 1 | 1 |
| 03/13/2014 11:00 | 0.6 | 13.5 | 1,821.2 | 0.6 | 2.0 | 1 | 1 | 1 |
| 03/13/2014 12:00 | 0.7 | 13.3 | 1,887.6 | 0.5 | 2.3 | 1 | 1 | 1 |
| 03/13/2014 13:00 | 0.9 | 13.1 | 1,942.4 | 0.6 | 3.0 | 1 | 1 | 1 |
| 03/13/2014 14:00 | 0.9 | 13.1 | 1,947.3 | 0.6 | 3.0 | 1 | 1 | 1 |
| 03/13/2014 15:00 | 0.9 | 13.1 | 1,947.1 | 0.7 | 3.0 | 1 | 1 | 1 |
| 03/13/2014 16:00 | 0.8 | 13.2 | 1,893.0 | 0.7 | 2.6 | 1 | 1 | 1 |
| 03/13/2014 17:00 | 0.7 | 13.5 | 1,830.1 | 0.6 | 2.3 | 1 | 1 | 1 |
| 03/13/2014 18:00 | 0.7 | 13.4 | 1,855.2 | 0.6 | 2.3 | 1 | 1 | 1 |
| 03/13/2014 19:00 | 0.9 | 13.1 | 1,922.9 | 0.6 | 2.9 | 1 | 1 | 1 |
| 03/13/2014 20:00 | 0.7 | 13.4 | 1,866.0 | 0.6 | 2.3 | 1 | 1 | 1 |
| 03/13/2014 21:00 | 0.7 | 13.4 | 1,750.8 | 0.6 | 2.2 | 1 | 1 | 1 |
| 03/13/2014 22:00 | 0.3 | 13.9 | 1,038.3 | 0.5 | 0.0 | 1 | 1 | 0 |
| 03/13/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| **Average/Sum#:** | 0.7 | 13.3 | 1,794.7 | 0.6 | 50.7 # | 23 # | 24 # | 18 # |
| **Minimum:** | 0.3 | 11.8 | 1,038.3 | 0.3 | 0.0 | 0 | 1 | 0 |
| **Maximum:** | 1.0 | 13.9 | 2,206.5 | 0.7 | 3.3 | 1 | 1 | 1 |
| **%SI** | 4.2 | 4.2 | 4.2 | 4.2 | 4.2 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/14/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| 03/14/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| 03/14/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| 03/14/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| 03/14/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| 03/14/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| 03/14/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| 03/14/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| 03/14/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| 03/14/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| 03/14/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| 03/14/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| 03/14/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| 03/14/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| 03/14/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| 03/14/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| 03/14/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 17 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 1 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/15/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/30/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT1 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT1 | Unit CT2 | Unit CT1 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/31/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/01/2014 00:00 | 0.0 | 13.9 | 1,640.5 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/01/2014 01:00 | 0.0 | 13.8 | 1,818.0 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/01/2014 02:00 | 0.0 | 13.8 | 1,699.2 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/01/2014 03:00 | 7.0 | 14.6 | 1,147.1 | 0.0 | 9.2 | 1 | 0 | 0 |
| 01/01/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/01/2014 13:00 | 20.5 | 17.7 | 463.0 | 0.0 | 26.3 | 1 | 0 | 0 |
| 01/01/2014 14:00 | 33.6 | 15.2 | 930.0 | 0.0 | 72.4 | 1 | 0 | 0 |
| 01/01/2014 15:00 | 0.0 | 13.8 | 1,651.8 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/01/2014 16:00 | 0.0 | 13.9 | 1,731.6 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/01/2014 17:00 | 0.0 | 13.9 | 1,500.4 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/01/2014 18:00 | 0.1 | 13.7 | 1,763.2 | 0.0 | 0.3 | 1 | 1 | 1 |
| 01/01/2014 19:00 | 0.3 | 12.6 | 2,089.9 | 0.1 | 1.0 | 1 | 1 | 1 |
| 01/01/2014 20:00 | 0.2 | 12.2 | 2,174.1 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/01/2014 21:00 | 0.2 | 12.1 | 2,193.2 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/01/2014 22:00 | 0.3 | 12.5 | 2,104.1 | 0.1 | 1.0 | 1 | 1 | 1 |
| 01/01/2014 23:00 | 0.3 | 12.5 | 2,107.3 | 0.2 | 1.0 | 1 | 1 | 1 |
| **Average/Sum#:** | 4.2 | 13.7 | 1,667.6 | 0.1 | 112.6 # | 15 # | 12 # | 6 # |
| **Minimum:** | 0.0 | 12.1 | 463.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 33.6 | 17.7 | 2,193.2 | 0.2 | 72.4 | 1 | 1 | 1 |
| **%SI** | 37.5 | 37.5 | 37.5 | 58.3 | 37.5 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/02/2014 00:00 | 0.3 | 12.6 | 2,085.4 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/02/2014 01:00 | 0.1 | 13.4 | 1,867.0 | 0.2 | 0.3 | 1 | 1 | 1 |
| 01/02/2014 02:00 | 0.0 | 13.8 | 1,598.2 | 0.1 | 0.0 | 1 | 1 | 0 |
| 01/02/2014 03:00 | 0.0 | 13.8 | 1,719.7 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/02/2014 04:00 | 0.0 | 13.8 | 1,598.2 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/02/2014 05:00 | 0.2 | 13.4 | 1,812.1 | 0.1 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 06:00 | 0.3 | 12.8 | 2,024.5 | 0.1 | 1.0 | 1 | 1 | 1 |
| 01/02/2014 07:00 | 0.3 | 12.9 | 2,019.3 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/02/2014 08:00 | 0.3 | 12.8 | 2,059.6 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/02/2014 09:00 | 0.3 | 12.8 | 2,069.5 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/02/2014 10:00 | 0.3 | 12.8 | 2,059.7 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/02/2014 11:00 | 0.3 | 12.7 | 2,048.9 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/02/2014 12:00 | 0.3 | 12.7 | 2,032.4 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/02/2014 13:00 | 0.2 | 12.7 | 2,020.1 | 0.2 | 0.7 | 1 | 1 | 1 |
| 01/02/2014 14:00 | 0.2 | 12.8 | 1,982.5 | 0.1 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 15:00 | 0.2 | 12.7 | 2,009.2 | 0.1 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 16:00 | 0.2 | 12.6 | 2,031.2 | 0.1 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 17:00 | 0.2 | 12.5 | 2,049.2 | 0.1 | 0.6 | 1 | 1 | 1 |
| 01/02/2014 18:00 | 0.2 | 12.2 | 2,142.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/02/2014 19:00 | 0.1 | 12.0 | 2,171.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/02/2014 20:00 | 0.1 | 12.1 | 2,151.4 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/02/2014 21:00 | 0.2 | 12.2 | 2,143.0 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/02/2014 22:00 | 0.2 | 12.6 | 2,096.2 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/02/2014 23:00 | 0.2 | 12.3 | 2,157.1 | 0.1 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 12.8 | 1,997.8 | 0.1 | 15.4 # | 24 # | 24 # | 21 # |
| **Minimum:** | 0.0 | 12.0 | 1,598.2 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Maximum:** | 0.3 | 13.8 | 2,171.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/03/2014 00:00 | 0.2 | 12.7 | 2,047.0 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/03/2014 01:00 | 0.1 | 13.5 | 1,762.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/03/2014 02:00 | 0.0 | 13.9 | 1,324.2 | 0.1 | 0.0 | 1 | 1 | 0 |
| 01/03/2014 03:00 | 0.0 | 13.9 | 1,249.2 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/03/2014 04:00 | 0.0 | 13.9 | 1,250.2 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/03/2014 05:00 | 0.0 | 13.9 | 1,252.9 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/03/2014 06:00 | 0.2 | 13.4 | 1,561.2 | 0.1 | 0.5 | 1 | 1 | 1 |
| 01/03/2014 07:00 | 0.3 | 13.1 | 1,943.4 | 0.1 | 1.0 | 1 | 1 | 1 |
| 01/03/2014 08:00 | 0.3 | 13.0 | 2,024.6 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/03/2014 09:00 | 0.3 | 12.8 | 2,063.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/03/2014 10:00 | 0.3 | 12.7 | 2,076.6 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/03/2014 11:00 | 0.3 | 12.7 | 2,060.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/03/2014 12:00 | 0.3 | 12.8 | 2,022.6 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/03/2014 13:00 | 0.3 | 12.8 | 2,006.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/03/2014 14:00 | 0.3 | 12.8 | 1,992.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/03/2014 15:00 | 0.2 | 13.0 | 1,956.7 | 0.2 | 0.7 | 1 | 1 | 1 |
| 01/03/2014 16:00 | 0.3 | 12.7 | 2,001.6 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/03/2014 17:00 | 0.2 | 12.4 | 2,071.7 | 0.1 | 0.6 | 1 | 1 | 1 |
| 01/03/2014 18:00 | 0.2 | 12.1 | 2,154.3 | 0.1 | 0.6 | 1 | 1 | 1 |
| 01/03/2014 19:00 | 0.2 | 12.3 | 2,120.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/03/2014 20:00 | 0.2 | 12.3 | 2,122.5 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/03/2014 21:00 | 0.1 | 11.8 | 2,235.0 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/03/2014 22:00 | 0.1 | 11.9 | 2,209.3 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/03/2014 23:00 | 0.1 | 12.1 | 2,168.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 12.9 | 1,903.2 | 0.1 | 14.7 # | 24 # | 24 # | 20 # |
| **Minimum:** | 0.0 | 11.8 | 1,249.2 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Maximum:** | 0.3 | 13.9 | 2,235.0 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/04/2014 00:00 | 0.2 | 12.6 | 2,081.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/04/2014 01:00 | 0.2 | 12.5 | 2,114.8 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/04/2014 02:00 | 0.0 | 13.8 | 1,628.9 | 0.1 | 0.0 | 1 | 1 | 1 |
| 01/04/2014 03:00 | 0.0 | 13.9 | 1,596.5 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/04/2014 04:00 | 0.0 | 13.9 | 1,428.6 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/04/2014 05:00 | 0.0 | 13.8 | 1,657.9 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/04/2014 06:00 | 0.0 | 13.8 | 1,681.7 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/04/2014 07:00 | 0.0 | 13.7 | 1,836.6 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/04/2014 08:00 | 0.2 | 13.2 | 1,925.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/04/2014 09:00 | 0.3 | 12.4 | 2,142.9 | 0.1 | 1.0 | 1 | 1 | 1 |
| 01/04/2014 10:00 | 0.2 | 12.6 | 2,072.4 | 0.2 | 0.7 | 1 | 1 | 1 |
| 01/04/2014 11:00 | 0.2 | 12.8 | 2,006.7 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/04/2014 12:00 | 0.2 | 13.1 | 1,933.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/04/2014 13:00 | 0.2 | 13.3 | 1,883.9 | 0.2 | 0.7 | 1 | 1 | 1 |
| 01/04/2014 14:00 | 0.2 | 12.8 | 1,991.3 | 0.2 | 0.6 | 1 | 1 | 1 |
| 01/04/2014 15:00 | 0.2 | 12.6 | 2,032.4 | 0.1 | 0.6 | 1 | 1 | 1 |
| 01/04/2014 16:00 | 0.2 | 12.5 | 2,054.0 | 0.1 | 0.6 | 1 | 1 | 1 |
| 01/04/2014 17:00 | 0.2 | 12.4 | 2,096.4 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/04/2014 18:00 | 0.2 | 12.2 | 2,145.1 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/04/2014 19:00 | 0.1 | 12.2 | 2,148.6 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/04/2014 20:00 | 0.2 | 12.6 | 2,061.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/04/2014 21:00 | 0.1 | 12.0 | 2,200.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/04/2014 22:00 | 0.1 | 11.9 | 2,225.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/04/2014 23:00 | 0.2 | 12.6 | 2,072.0 | 0.1 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.1 | 12.9 | 1,959.1 | 0.1 | 11.4 # | 24 # | 24 # | 19 # |
| **Minimum:** | 0.0 | 11.9 | 1,428.6 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Maximum:** | 0.3 | 13.9 | 2,225.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/05/2014 00:00 | 0.2 | 12.7 | 2,052.7 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/05/2014 01:00 | 0.2 | 12.5 | 2,089.2 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/05/2014 02:00 | 0.0 | 13.8 | 1,619.7 | 0.1 | 0.0 | 1 | 1 | 1 |
| 01/05/2014 03:00 | 0.0 | 13.9 | 1,600.5 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/05/2014 04:00 | 0.0 | 13.9 | 1,700.5 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/05/2014 05:00 | 0.0 | 13.8 | 1,819.0 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/05/2014 06:00 | 0.3 | 13.0 | 1,899.5 | 0.1 | 1.0 | 1 | 1 | 1 |
| 01/05/2014 07:00 | 0.3 | 12.5 | 2,125.2 | 0.1 | 1.0 | 1 | 1 | 1 |
| 01/05/2014 08:00 | 0.1 | 11.9 | 2,260.4 | 0.2 | 0.3 | 1 | 1 | 1 |
| 01/05/2014 09:00 | 0.1 | 12.0 | 2,224.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/05/2014 10:00 | 0.2 | 12.6 | 2,092.8 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/05/2014 11:00 | 0.2 | 12.9 | 2,013.8 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/05/2014 12:00 | 0.2 | 13.2 | 1,934.8 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/05/2014 13:00 | 0.2 | 13.0 | 1,953.0 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/05/2014 14:00 | 0.2 | 12.7 | 2,021.7 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/05/2014 15:00 | 0.0 | 13.9 | 1,633.4 | 0.1 | 0.0 | 1 | 1 | 1 |
| 01/05/2014 16:00 | 0.1 | 13.1 | 1,882.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/05/2014 17:00 | 0.1 | 12.0 | 2,187.4 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/05/2014 18:00 | 0.1 | 11.8 | 2,225.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/05/2014 19:00 | 0.0 | 11.8 | 2,236.5 | 0.1 | 0.0 | 1 | 1 | 1 |
| 01/05/2014 20:00 | 0.0 | 11.8 | 2,247.7 | 0.0 | 0.0 | 1 | 1 | 1 |
| 01/05/2014 21:00 | 0.0 | 11.8 | 2,247.6 | 0.0 | 0.0 | 1 | 1 | 1 |
| 01/05/2014 22:00 | 0.1 | 11.8 | 2,256.8 | 0.0 | 0.3 | 1 | 1 | 1 |
| 01/05/2014 23:00 | 0.1 | 12.1 | 2,218.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.1 | 12.7 | 2,022.6 | 0.1 | 9.0 # | 24 # | 24 # | 21 # |
| **Minimum:** | 0.0 | 11.8 | 1,600.5 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Maximum:** | 0.3 | 13.9 | 2,260.4 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/06/2014 00:00 | 0.1 | 12.1 | 2,208.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/06/2014 01:00 | 0.2 | 12.4 | 2,136.7 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 02:00 | 0.2 | 12.3 | 2,171.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 03:00 | 0.2 | 12.8 | 2,060.7 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 04:00 | 0.2 | 12.9 | 2,040.1 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 05:00 | 0.2 | 12.2 | 2,210.4 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 06:00 | 0.2 | 12.7 | 2,108.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 07:00 | 0.2 | 12.7 | 2,076.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 08:00 | 0.2 | 12.2 | 2,195.7 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 09:00 | 0.2 | 12.4 | 2,169.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 10:00 | 0.2 | 12.3 | 2,206.1 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 11:00 | 0.1 | 12.0 | 2,235.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/06/2014 12:00 | 0.1 | 12.0 | 2,238.4 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/06/2014 13:00 | 0.1 | 11.9 | 2,247.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/06/2014 14:00 | 0.1 | 12.2 | 2,156.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/06/2014 15:00 | 0.2 | 12.8 | 2,037.1 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 16:00 | 0.2 | 12.7 | 2,048.0 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 17:00 | 0.2 | 12.5 | 2,109.7 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 18:00 | 0.2 | 12.4 | 2,128.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 19:00 | 0.1 | 11.9 | 2,250.3 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/06/2014 20:00 | 0.2 | 12.3 | 2,147.9 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/06/2014 21:00 | 0.1 | 11.8 | 2,262.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/06/2014 22:00 | 0.1 | 11.8 | 2,277.0 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/06/2014 23:00 | 0.2 | 12.3 | 2,150.8 | 0.1 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 12.3 | 2,161.4 | 0.1 | 13.6 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.1 | 11.8 | 2,037.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Maximum:** | 0.2 | 12.9 | 2,277.0 | 0.1 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/07/2014 00:00 | 0.2 | 12.9 | 1,997.7 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/07/2014 01:00 | 0.1 | 13.3 | 1,770.3 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/07/2014 02:00 | 0.0 | 13.9 | 1,493.5 | 0.1 | 0.0 | 1 | 1 | 0 |
| 01/07/2014 03:00 | 0.0 | 13.9 | 1,598.9 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/07/2014 04:00 | 0.0 | 13.9 | 1,581.3 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/07/2014 05:00 | 0.0 | 13.9 | 1,597.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/07/2014 06:00 | 0.3 | 13.2 | 1,819.7 | 0.1 | 0.9 | 1 | 1 | 1 |
| 01/07/2014 07:00 | 0.3 | 13.0 | 2,049.2 | 0.1 | 1.0 | 1 | 1 | 1 |
| 01/07/2014 08:00 | 0.2 | 12.3 | 2,204.2 | 0.2 | 0.7 | 1 | 1 | 1 |
| 01/07/2014 09:00 | 0.2 | 12.3 | 2,195.2 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/07/2014 10:00 | 0.2 | 12.6 | 2,122.4 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/07/2014 11:00 | 0.2 | 12.7 | 2,088.7 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/07/2014 12:00 | 0.1 | 11.9 | 2,247.6 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/07/2014 13:00 | 0.1 | 11.9 | 2,242.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/07/2014 14:00 | 0.2 | 12.5 | 2,099.0 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/07/2014 15:00 | 0.2 | 12.4 | 2,111.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/07/2014 16:00 | 0.2 | 12.8 | 2,017.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/07/2014 17:00 | 0.3 | 12.8 | 2,020.0 | 0.1 | 1.0 | 1 | 1 | 1 |
| 01/07/2014 18:00 | 0.3 | 12.6 | 2,071.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/07/2014 19:00 | 0.2 | 12.0 | 2,205.8 | 0.2 | 0.7 | 1 | 1 | 1 |
| 01/07/2014 20:00 | 0.1 | 11.8 | 2,250.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/07/2014 21:00 | 0.2 | 12.5 | 2,101.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/07/2014 22:00 | 0.2 | 12.7 | 2,076.2 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/07/2014 23:00 | 0.2 | 13.1 | 1,906.0 | 0.1 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 12.8 | 1,994.5 | 0.1 | 13.4 # | 24 # | 24 # | 20 # |
| **Minimum:** | 0.0 | 11.8 | 1,493.5 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Maximum:** | 0.3 | 13.9 | 2,250.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/08/2014 00:00 | 0.0 | 13.9 | 1,365.7 | 0.1 | 0.0 | 1 | 1 | 0 |
| 01/08/2014 01:00 | 0.0 | 13.9 | 1,315.8 | 0.1 | 0.0 | 1 | 1 | 0 |
| 01/08/2014 02:00 | 0.0 | 13.9 | 1,290.4 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/08/2014 03:00 | 0.0 | 13.9 | 1,265.7 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/08/2014 04:00 | 0.0 | 13.9 | 1,298.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/08/2014 05:00 | 0.0 | 13.8 | 1,639.0 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/08/2014 06:00 | 0.2 | 13.4 | 1,723.6 | 0.1 | 0.6 | 1 | 1 | 1 |
| 01/08/2014 07:00 | 0.2 | 13.3 | 1,967.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/08/2014 08:00 | 0.3 | 12.9 | 2,041.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/08/2014 09:00 | 0.1 | 13.5 | 1,787.5 | 0.2 | 0.3 | 1 | 1 | 1 |
| 01/08/2014 10:00 | 0.0 | 13.9 | 1,242.9 | 0.1 | 0.0 | 1 | 1 | 0 |
| 01/08/2014 11:00 | 0.0 | 13.9 | 1,383.0 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/08/2014 12:00 | 0.0 | 13.7 | 1,709.3 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/08/2014 13:00 | 0.0 | 13.9 | 1,485.5 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/08/2014 14:00 | 0.0 | 13.9 | 1,259.9 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/08/2014 15:00 | 0.0 | 13.9 | 1,405.6 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/08/2014 16:00 | 0.0 | 13.9 | 1,530.6 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/08/2014 17:00 | 0.2 | 13.4 | 1,806.3 | 0.1 | 0.6 | 1 | 1 | 1 |
| 01/08/2014 18:00 | 0.0 | 13.9 | 1,438.8 | 0.1 | 0.0 | 1 | 1 | 0 |
| 01/08/2014 19:00 | 0.0 | 13.9 | 1,537.7 | 0.1 | 0.0 | 1 | 1 | 0 |
| 01/08/2014 20:00 | 0.0 | 13.9 | 1,495.5 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/08/2014 21:00 | 0.0 | 13.9 | 1,488.5 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/08/2014 22:00 | 9.6 | 15.4 | 746.3 | 0.0 | 4.8 | 1 | 0 | 0 |
| 01/08/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.5 | 13.8 | 1,488.0 | 0.1 | 8.0 # | 23 # | 22 # | 5 # |
| **Minimum:** | 0.0 | 12.9 | 746.3 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 9.6 | 15.4 | 2,041.8 | 0.2 | 4.8 | 1 | 1 | 1 |
| **%SI** | 4.2 | 4.2 | 4.2 | 8.3 | 4.2 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/09/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/09/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/10/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/10/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/11/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/12/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/12/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/13/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/13/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/14/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/14/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/15/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 01/29/2014 08:00 | 92.1 | 17.6 | 504.0 | 0.0 | 117.1 | 1 | 0 | 0 |
| 01/29/2014 09:00 | 16.0 | 17.1 | 609.7 | 0.0 | 33.9 | 1 | 0 | 0 |
| 01/29/2014 10:00 | 18.0 | 17.9 | 630.0 | 0.0 | 49.9 | 1 | 0 | 0 |
| 01/29/2014 11:00 | 16.8 | 17.6 | 640.8 | 0.0 | 43.1 | 1 | 0 | 0 |
| 01/29/2014 12:00 | 13.0 | 14.8 | 1,304.2 | 0.0 | 36.7 | 1 | 0 | 0 |
| 01/29/2014 13:00 | 0.0 | 13.7 | 1,821.8 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/29/2014 14:00 | 0.0 | 13.7 | 1,811.7 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/29/2014 15:00 | 0.0 | 13.8 | 1,657.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/29/2014 16:00 | 0.0 | 13.9 | 1,283.9 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/29/2014 17:00 | 0.0 | 13.8 | 1,541.8 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/29/2014 18:00 | 0.0 | 13.7 | 1,816.9 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/29/2014 19:00 | 0.0 | 13.7 | 1,816.0 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/29/2014 20:00 | 0.0 | 13.8 | 1,758.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/29/2014 21:00 | 0.0 | 13.8 | 1,813.2 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/29/2014 22:00 | 0.0 | 13.8 | 1,668.8 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/29/2014 23:00 | 0.0 | 13.9 | 1,295.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Average/Sum#:** | 9.7 | 14.8 | 1,373.3 | 0.0 | 280.7 # | 16 # | 11 # | 0 # |
| **Minimum:** | 0.0 | 13.7 | 504.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 92.1 | 17.9 | 1,821.8 | 0.0 | 117.1 | 1 | 1 | 0 |
| **%SI** | 33.3 | 33.3 | 33.3 | 62.5 | 33.3 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/30/2014 00:00 | 0.0 | 13.9 | 1,466.4 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/30/2014 01:00 | 0.0 | 13.8 | 1,750.8 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/30/2014 02:00 | 0.0 | 13.9 | 1,330.0 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/30/2014 03:00 | 0.0 | 13.9 | 1,261.5 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/30/2014 04:00 | 0.0 | 13.9 | 1,285.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/30/2014 05:00 | 0.0 | 13.9 | 1,259.6 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/30/2014 06:00 | 0.0 | 13.9 | 1,452.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/30/2014 07:00 | 0.0 | 13.9 | 1,548.5 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/30/2014 08:00 | 0.0 | 13.9 | 1,560.7 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/30/2014 09:00 | 0.0 | 13.9 | 1,247.8 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/30/2014 10:00 | 0.0 | 13.8 | 1,519.4 | 0.0 | 0.0 | 1 | 1 | 1 |
| 01/30/2014 11:00 | 0.3 | 13.1 | 1,950.8 | 0.1 | 1.0 | 1 | 1 | 1 |
| 01/30/2014 12:00 | 0.3 | 12.9 | 1,981.3 | 0.1 | 1.0 | 1 | 1 | 1 |
| 01/30/2014 13:00 | 0.3 | 12.4 | 2,103.5 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/30/2014 14:00 | 0.1 | 11.9 | 2,194.7 | 0.2 | 0.3 | 1 | 1 | 1 |
| 01/30/2014 15:00 | 0.1 | 11.8 | 2,222.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/30/2014 16:00 | 0.1 | 12.8 | 1,882.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 01/30/2014 17:00 | 0.0 | 13.9 | 1,570.2 | 0.1 | 0.0 | 1 | 1 | 0 |
| 01/30/2014 18:00 | 0.0 | 13.9 | 1,640.6 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/30/2014 19:00 | 0.2 | 13.0 | 1,929.1 | 0.0 | 0.6 | 1 | 1 | 1 |
| 01/30/2014 20:00 | 0.2 | 12.5 | 2,085.7 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/30/2014 21:00 | 0.2 | 12.6 | 2,066.1 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/30/2014 22:00 | 0.2 | 12.9 | 2,001.7 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/30/2014 23:00 | 0.3 | 12.9 | 2,003.3 | 0.1 | 1.0 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.1 | 13.3 | 1,721.4 | 0.1 | 7.6 # | 24 # | 24 # | 12 # |
| **Minimum:** | 0.0 | 11.8 | 1,247.8 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Maximum:** | 0.3 | 13.9 | 2,222.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/31/2014 00:00 | 0.0 | 13.6 | 1,555.3 | 0.1 | 0.0 | 1 | 1 | 1 |
| 01/31/2014 01:00 | 0.0 | 13.9 | 1,491.4 | 0.1 | 0.0 | 1 | 1 | 0 |
| 01/31/2014 02:00 | 0.0 | 14.5 | 1,624.9 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/31/2014 03:00 | 0.0 | 13.9 | 1,411.5 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/31/2014 04:00 | 0.0 | 13.9 | 1,329.4 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/31/2014 05:00 | 0.0 | 13.8 | 1,769.3 | 0.0 | 0.0 | 1 | 1 | 0 |
| 01/31/2014 06:00 | 0.3 | 13.2 | 1,938.4 | 0.1 | 1.0 | 1 | 1 | 1 |
| 01/31/2014 07:00 | 0.2 | 13.3 | 1,912.7 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/31/2014 08:00 | 0.3 | 13.1 | 2,002.4 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/31/2014 09:00 | 0.3 | 13.2 | 1,973.7 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/31/2014 10:00 | 0.2 | 13.2 | 1,970.2 | 0.2 | 0.7 | 1 | 1 | 1 |
| 01/31/2014 11:00 | 0.2 | 13.2 | 1,958.9 | 0.2 | 0.7 | 1 | 1 | 1 |
| 01/31/2014 12:00 | 0.3 | 12.9 | 2,007.4 | 0.2 | 1.0 | 1 | 1 | 1 |
| 01/31/2014 13:00 | 0.2 | 12.8 | 2,006.8 | 0.2 | 0.7 | 1 | 1 | 1 |
| 01/31/2014 14:00 | 0.2 | 13.1 | 1,960.3 | 0.2 | 0.7 | 1 | 1 | 1 |
| 01/31/2014 15:00 | 0.2 | 13.2 | 1,940.3 | 0.2 | 0.7 | 1 | 1 | 1 |
| 01/31/2014 16:00 | 0.2 | 13.2 | 1,924.4 | 0.2 | 0.7 | 1 | 1 | 1 |
| 01/31/2014 17:00 | 0.2 | 13.1 | 1,952.9 | 0.2 | 0.7 | 1 | 1 | 1 |
| 01/31/2014 18:00 | 0.2 | 13.2 | 1,936.5 | 0.2 | 0.7 | 1 | 1 | 1 |
| 01/31/2014 19:00 | 0.2 | 12.6 | 2,088.0 | 0.2 | 0.7 | 1 | 1 | 1 |
| 01/31/2014 20:00 | 0.2 | 12.8 | 2,030.5 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/31/2014 21:00 | 0.2 | 12.6 | 2,079.5 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/31/2014 22:00 | 0.2 | 12.3 | 2,144.4 | 0.1 | 0.7 | 1 | 1 | 1 |
| 01/31/2014 23:00 | 0.2 | 12.4 | 2,128.8 | 0.1 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 13.2 | 1,880.7 | 0.1 | 13.8 # | 24 # | 24 # | 19 # |
| **Minimum:** | 0.0 | 12.3 | 1,329.4 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Maximum:** | 0.3 | 14.5 | 2,144.4 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/01/2014 00:00 | 0.1 | 13.3 | 1,810.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/01/2014 01:00 | 0.0 | 13.9 | 1,623.7 | 0.1 | 0.0 | 1 | 1 | 0 |
| 02/01/2014 02:00 | 0.0 | 13.9 | 1,658.6 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/01/2014 03:00 | 0.0 | 13.8 | 1,786.0 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/01/2014 04:00 | 0.0 | 13.9 | 1,468.3 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/01/2014 05:00 | 0.2 | 13.3 | 1,870.7 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/01/2014 06:00 | 0.2 | 11.9 | 2,252.9 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/01/2014 07:00 | 0.1 | 12.0 | 2,254.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/01/2014 08:00 | 0.2 | 12.2 | 2,206.7 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/01/2014 09:00 | 0.2 | 12.5 | 2,146.8 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/01/2014 10:00 | 0.1 | 13.4 | 1,854.3 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/01/2014 11:00 | 0.0 | 13.9 | 1,570.9 | 0.1 | 0.0 | 1 | 1 | 0 |
| 02/01/2014 12:00 | 0.0 | 13.9 | 1,539.8 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/01/2014 13:00 | 0.0 | 13.9 | 1,590.7 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/01/2014 14:00 | 0.0 | 13.9 | 1,443.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/01/2014 15:00 | 0.0 | 13.9 | 1,262.0 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/01/2014 16:00 | 0.0 | 13.9 | 1,312.7 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/01/2014 17:00 | 0.1 | 13.6 | 1,689.6 | 0.0 | 0.3 | 1 | 1 | 1 |
| 02/01/2014 18:00 | 0.3 | 12.8 | 2,031.8 | 0.1 | 1.0 | 1 | 1 | 1 |
| 02/01/2014 19:00 | 0.1 | 12.0 | 2,215.4 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/01/2014 20:00 | 0.1 | 11.8 | 2,261.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/01/2014 21:00 | 0.1 | 11.8 | 2,268.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/01/2014 22:00 | 0.1 | 11.9 | 2,268.3 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/01/2014 23:00 | 0.1 | 12.0 | 2,255.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.1 | 13.1 | 1,860.2 | 0.1 | 6.5 # | 24 # | 24 # | 14 # |
| **Minimum:** | 0.0 | 11.8 | 1,262.0 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Maximum:** | 0.3 | 13.9 | 2,268.9 | 0.1 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/02/2014 00:00 | 0.2 | 12.3 | 2,194.0 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 01:00 | 0.3 | 12.6 | 2,104.3 | 0.1 | 1.0 | 1 | 1 | 1 |
| 02/02/2014 02:00 | 0.3 | 12.7 | 2,103.9 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/02/2014 03:00 | 0.3 | 12.7 | 2,107.0 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/02/2014 04:00 | 0.3 | 12.9 | 2,058.6 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/02/2014 05:00 | 0.3 | 12.9 | 2,060.9 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/02/2014 06:00 | 0.3 | 12.8 | 2,075.1 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/02/2014 07:00 | 0.2 | 12.2 | 2,227.4 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 08:00 | 0.2 | 12.0 | 2,267.1 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 09:00 | 0.2 | 12.0 | 2,268.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 10:00 | 0.1 | 11.9 | 2,269.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/02/2014 11:00 | 0.1 | 11.9 | 2,269.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/02/2014 12:00 | 0.1 | 11.9 | 2,259.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/02/2014 13:00 | 0.1 | 12.0 | 2,241.0 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/02/2014 14:00 | 0.2 | 12.5 | 2,109.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 15:00 | 0.1 | 11.9 | 2,243.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/02/2014 16:00 | 0.1 | 11.8 | 2,274.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/02/2014 17:00 | 0.2 | 12.2 | 2,174.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 18:00 | 0.2 | 13.1 | 1,994.5 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 19:00 | 0.2 | 12.4 | 2,143.2 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 20:00 | 0.1 | 11.9 | 2,247.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/02/2014 21:00 | 0.1 | 11.8 | 2,272.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/02/2014 22:00 | 0.2 | 12.1 | 2,196.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/02/2014 23:00 | 0.1 | 11.9 | 2,251.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 12.3 | 2,184.0 | 0.1 | 15.0 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.1 | 11.8 | 1,994.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Maximum:** | 0.3 | 13.1 | 2,274.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/03/2014 00:00 | 0.1 | 12.0 | 2,238.4 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/03/2014 01:00 | 0.2 | 12.5 | 2,128.7 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/03/2014 02:00 | 0.2 | 12.9 | 2,034.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/03/2014 03:00 | 0.2 | 13.0 | 1,999.9 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/03/2014 04:00 | 0.3 | 13.0 | 2,048.2 | 0.1 | 1.0 | 1 | 1 | 1 |
| 02/03/2014 05:00 | 0.3 | 12.6 | 2,138.5 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/03/2014 06:00 | 0.3 | 12.9 | 2,085.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/03/2014 07:00 | 0.3 | 12.7 | 2,098.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/03/2014 08:00 | 0.2 | 12.1 | 2,252.0 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/03/2014 09:00 | 0.2 | 12.2 | 2,209.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/03/2014 10:00 | 0.2 | 12.6 | 2,112.1 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/03/2014 11:00 | 0.2 | 13.2 | 1,929.4 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/03/2014 12:00 | 0.2 | 13.2 | 1,952.6 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/03/2014 13:00 | 0.3 | 12.9 | 2,015.6 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/03/2014 14:00 | 0.3 | 12.9 | 2,020.1 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/03/2014 15:00 | 0.2 | 13.0 | 1,979.0 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/03/2014 16:00 | 0.3 | 12.9 | 2,005.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/03/2014 17:00 | 0.2 | 12.6 | 2,088.4 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/03/2014 18:00 | 0.1 | 11.9 | 2,232.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/03/2014 19:00 | 0.1 | 11.8 | 2,268.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/03/2014 20:00 | 0.1 | 11.8 | 2,271.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/03/2014 21:00 | 0.1 | 11.8 | 2,268.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/03/2014 22:00 | 0.1 | 12.0 | 2,242.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/03/2014 23:00 | 0.2 | 12.3 | 2,152.5 | 0.1 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 12.5 | 2,115.5 | 0.1 | 16.5 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.1 | 11.8 | 1,929.4 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Maximum:** | 0.3 | 13.2 | 2,271.7 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/04/2014 00:00 | 0.3 | 12.7 | 2,099.3 | 0.1 | 1.0 | 1 | 1 | 1 |
| 02/04/2014 01:00 | 0.3 | 13.0 | 2,038.0 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/04/2014 02:00 | 0.2 | 13.1 | 1,954.6 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/04/2014 03:00 | 0.2 | 13.1 | 2,010.8 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/04/2014 04:00 | 0.2 | 13.2 | 1,901.3 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/04/2014 05:00 | 0.2 | 13.2 | 1,871.6 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/04/2014 06:00 | 0.3 | 12.7 | 2,031.7 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/04/2014 07:00 | 0.3 | 12.8 | 2,063.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/04/2014 08:00 | 0.3 | 12.9 | 2,065.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/04/2014 09:00 | 0.2 | 13.1 | 2,011.3 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/04/2014 10:00 | 0.3 | 13.0 | 2,046.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/04/2014 11:00 | 0.3 | 12.9 | 2,047.4 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/04/2014 12:00 | 0.2 | 13.0 | 2,006.9 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/04/2014 13:00 | 0.2 | 13.2 | 1,948.5 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/04/2014 14:00 | 0.3 | 12.8 | 2,035.1 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/04/2014 15:00 | 0.3 | 12.6 | 2,081.1 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/04/2014 16:00 | 0.3 | 12.7 | 2,043.6 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/04/2014 17:00 | 0.3 | 12.8 | 2,050.9 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/04/2014 18:00 | 0.2 | 12.4 | 2,134.8 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/04/2014 19:00 | 0.1 | 12.0 | 2,225.6 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/04/2014 20:00 | 0.2 | 12.1 | 2,200.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/04/2014 21:00 | 0.1 | 11.9 | 2,253.6 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/04/2014 22:00 | 0.1 | 12.0 | 2,238.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/04/2014 23:00 | 0.2 | 12.5 | 2,126.1 | 0.1 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 12.7 | 2,062.0 | 0.2 | 18.8 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.1 | 11.9 | 1,871.6 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Maximum:** | 0.3 | 13.2 | 2,253.6 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/05/2014 00:00 | 0.3 | 12.8 | 2,068.9 | 0.1 | 1.0 | 1 | 1 | 1 |
| 02/05/2014 01:00 | 0.2 | 13.2 | 1,905.0 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/05/2014 02:00 | 0.2 | 13.2 | 1,874.2 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/05/2014 03:00 | 0.2 | 13.2 | 1,874.3 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/05/2014 04:00 | 0.2 | 13.2 | 1,875.6 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/05/2014 05:00 | 0.2 | 13.2 | 1,915.1 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/05/2014 06:00 | 0.3 | 13.0 | 1,976.7 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/05/2014 07:00 | 0.3 | 12.5 | 2,146.0 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/05/2014 08:00 | 0.2 | 12.0 | 2,261.9 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/05/2014 09:00 | 0.2 | 12.8 | 2,099.0 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/05/2014 10:00 | 0.0 | 13.8 | 1,351.7 | 0.1 | 0.0 | 1 | 1 | 1 |
| 02/05/2014 11:00 | 0.1 | 13.5 | 1,561.4 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/05/2014 12:00 | 0.2 | 11.9 | 2,276.8 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/05/2014 13:00 | 0.2 | 12.1 | 2,193.5 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/05/2014 14:00 | 0.2 | 13.2 | 1,908.9 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/05/2014 15:00 | 0.2 | 13.2 | 1,882.8 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/05/2014 16:00 | 0.3 | 13.2 | 1,903.9 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/05/2014 17:00 | 0.3 | 12.8 | 2,042.7 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/05/2014 18:00 | 0.3 | 12.6 | 2,087.6 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/05/2014 19:00 | 0.2 | 11.9 | 2,237.1 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/05/2014 20:00 | 0.1 | 11.9 | 2,256.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/05/2014 21:00 | 0.1 | 11.9 | 2,258.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/05/2014 22:00 | 0.1 | 11.9 | 2,260.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/05/2014 23:00 | 0.1 | 11.9 | 2,260.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 12.7 | 2,020.0 | 0.2 | 15.5 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.0 | 11.9 | 1,351.7 | 0.1 | 0.0 | 1 | 1 | 1 |
| **Maximum:** | 0.3 | 13.8 | 2,276.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/06/2014 00:00 | 0.1 | 12.0 | 2,221.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/06/2014 01:00 | 0.2 | 13.0 | 1,976.1 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/06/2014 02:00 | 0.2 | 13.1 | 1,868.8 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 03:00 | 0.2 | 13.1 | 1,869.3 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 04:00 | 0.2 | 13.1 | 1,873.7 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 05:00 | 0.2 | 13.1 | 1,873.9 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 06:00 | 0.2 | 13.1 | 1,882.7 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 07:00 | 0.2 | 13.2 | 1,904.9 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/06/2014 08:00 | 0.3 | 13.1 | 1,959.9 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/06/2014 09:00 | 0.2 | 13.2 | 1,929.3 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/06/2014 10:00 | 0.2 | 13.2 | 1,887.2 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 11:00 | 0.2 | 13.2 | 1,875.3 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 12:00 | 0.2 | 13.2 | 1,862.9 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 13:00 | 0.2 | 13.2 | 1,869.6 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 14:00 | 0.2 | 13.2 | 1,867.9 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 15:00 | 0.2 | 13.2 | 1,902.4 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/06/2014 16:00 | 0.2 | 13.2 | 1,868.7 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 17:00 | 0.2 | 13.2 | 1,916.9 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/06/2014 18:00 | 0.2 | 13.3 | 1,900.5 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/06/2014 19:00 | 0.2 | 13.2 | 1,945.5 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/06/2014 20:00 | 0.2 | 13.2 | 1,895.1 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/06/2014 21:00 | 0.2 | 13.2 | 1,881.5 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 22:00 | 0.2 | 13.2 | 1,882.3 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/06/2014 23:00 | 0.2 | 13.2 | 1,882.8 | 0.2 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 13.1 | 1,908.3 | 0.2 | 15.3 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.1 | 12.0 | 1,862.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Maximum:** | 0.3 | 13.3 | 2,221.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/07/2014 00:00 | 0.2 | 13.2 | 1,882.5 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/07/2014 01:00 | 0.3 | 12.9 | 2,024.1 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/07/2014 02:00 | 0.3 | 12.6 | 2,081.3 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/07/2014 03:00 | 0.3 | 12.7 | 2,077.5 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/07/2014 04:00 | 0.2 | 12.0 | 2,210.5 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/07/2014 05:00 | 0.2 | 12.0 | 2,217.4 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/07/2014 06:00 | 0.1 | 11.8 | 2,250.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/07/2014 07:00 | 0.1 | 11.8 | 2,265.4 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/07/2014 08:00 | 0.1 | 11.8 | 2,275.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/07/2014 09:00 | 0.2 | 12.2 | 2,174.2 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/07/2014 10:00 | 0.3 | 12.7 | 2,056.8 | 0.1 | 1.0 | 1 | 1 | 1 |
| 02/07/2014 11:00 | 0.3 | 12.7 | 2,056.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/07/2014 12:00 | 0.3 | 12.6 | 2,080.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/07/2014 13:00 | 0.3 | 12.7 | 2,035.6 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/07/2014 14:00 | 0.2 | 12.9 | 1,965.1 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/07/2014 15:00 | 0.2 | 13.2 | 1,881.0 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/07/2014 16:00 | 0.3 | 12.8 | 2,032.9 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/07/2014 17:00 | 0.3 | 12.7 | 2,037.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/07/2014 18:00 | 0.3 | 12.5 | 2,090.4 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/07/2014 19:00 | 0.1 | 11.9 | 2,228.9 | 0.2 | 0.3 | 1 | 1 | 1 |
| 02/07/2014 20:00 | 0.2 | 12.5 | 2,068.1 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/07/2014 21:00 | 0.3 | 12.6 | 2,062.8 | 0.1 | 1.0 | 1 | 1 | 1 |
| 02/07/2014 22:00 | 0.3 | 12.6 | 2,064.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/07/2014 23:00 | 0.3 | 12.6 | 2,069.9 | 0.2 | 1.0 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 12.5 | 2,091.2 | 0.2 | 18.8 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.1 | 11.8 | 1,881.0 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Maximum:** | 0.3 | 13.2 | 2,275.1 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/08/2014 00:00 | 0.2 | 13.0 | 1,964.4 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/08/2014 01:00 | 0.2 | 13.1 | 1,947.6 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/08/2014 02:00 | 0.2 | 13.3 | 1,906.6 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/08/2014 03:00 | 0.2 | 13.3 | 1,897.2 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/08/2014 04:00 | 0.2 | 13.9 | 1,904.3 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/08/2014 05:00 | 0.2 | 13.3 | 1,903.8 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/08/2014 06:00 | 0.2 | 13.4 | 1,886.9 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/08/2014 07:00 | 0.2 | 13.2 | 1,921.9 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/08/2014 08:00 | 0.2 | 13.2 | 1,873.5 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 09:00 | 0.2 | 13.3 | 1,842.4 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 10:00 | 0.2 | 13.1 | 1,865.4 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 11:00 | 0.2 | 13.2 | 1,869.0 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 12:00 | 0.2 | 13.2 | 1,872.6 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 13:00 | 0.2 | 13.1 | 1,904.2 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 14:00 | 0.2 | 13.2 | 1,863.2 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 15:00 | 0.2 | 13.2 | 1,865.2 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 16:00 | 0.2 | 13.2 | 1,866.2 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 17:00 | 0.2 | 13.2 | 1,875.1 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 18:00 | 0.3 | 12.9 | 1,974.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/08/2014 19:00 | 0.2 | 12.0 | 2,158.2 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 20:00 | 0.3 | 12.5 | 2,067.6 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/08/2014 21:00 | 0.3 | 12.3 | 2,094.9 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/08/2014 22:00 | 0.2 | 13.0 | 1,929.5 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/08/2014 23:00 | 0.2 | 13.4 | 1,845.1 | 0.2 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 13.1 | 1,920.8 | 0.2 | 16.4 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 12.0 | 1,842.4 | 0.2 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.3 | 13.9 | 2,158.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/09/2014 00:00 | 0.2 | 13.5 | 1,839.1 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/09/2014 01:00 | 0.3 | 13.0 | 1,940.7 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/09/2014 02:00 | 0.2 | 13.4 | 1,853.5 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/09/2014 03:00 | 0.2 | 13.5 | 1,840.4 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/09/2014 04:00 | 0.2 | 13.5 | 1,839.9 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/09/2014 05:00 | 0.2 | 13.5 | 1,835.6 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/09/2014 06:00 | 0.2 | 13.4 | 1,849.1 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/09/2014 07:00 | 0.3 | 13.2 | 1,861.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/09/2014 08:00 | 0.3 | 13.2 | 1,858.6 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/09/2014 09:00 | 0.2 | 13.2 | 1,862.5 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 10:00 | 0.2 | 13.2 | 1,862.4 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 11:00 | 0.2 | 13.2 | 1,853.9 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 12:00 | 0.2 | 13.2 | 1,853.3 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 13:00 | 0.2 | 13.2 | 1,853.5 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 14:00 | 0.2 | 13.2 | 1,856.5 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 15:00 | 0.2 | 13.2 | 1,857.4 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 16:00 | 0.2 | 13.2 | 1,884.8 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 17:00 | 0.2 | 13.1 | 1,889.1 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/09/2014 18:00 | 0.3 | 12.8 | 1,977.9 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/09/2014 19:00 | 0.1 | 11.6 | 2,238.1 | 0.2 | 0.3 | 1 | 1 | 1 |
| 02/09/2014 20:00 | 0.1 | 11.6 | 2,251.3 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/09/2014 21:00 | 0.1 | 11.6 | 2,254.3 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/09/2014 22:00 | 0.1 | 12.0 | 2,148.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/09/2014 23:00 | 0.2 | 12.3 | 2,085.8 | 0.1 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 13.0 | 1,935.3 | 0.2 | 15.4 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.1 | 11.6 | 1,835.6 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Maximum:** | 0.3 | 13.5 | 2,254.3 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/10/2014 00:00 | 0.0 | 13.7 | 1,487.5 | 0.1 | 0.0 | 1 | 1 | 1 |
| 02/10/2014 01:00 | 0.0 | 13.8 | 1,337.8 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/10/2014 02:00 | 0.0 | 13.8 | 1,369.2 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/10/2014 03:00 | 0.0 | 13.8 | 1,248.3 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/10/2014 04:00 | 0.0 | 13.8 | 1,248.4 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/10/2014 05:00 | 0.0 | 13.7 | 1,429.4 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/10/2014 06:00 | 0.2 | 13.3 | 1,888.4 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/10/2014 07:00 | 0.2 | 13.1 | 1,930.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/10/2014 08:00 | 0.3 | 12.9 | 2,006.3 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/10/2014 09:00 | 0.2 | 13.2 | 1,908.2 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/10/2014 10:00 | 0.2 | 13.1 | 1,903.6 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 11:00 | 0.2 | 13.2 | 1,877.4 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 12:00 | 0.2 | 13.2 | 1,875.5 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 13:00 | 0.2 | 13.2 | 1,876.7 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 14:00 | 0.2 | 13.2 | 1,869.1 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 15:00 | 0.2 | 13.2 | 1,872.7 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 16:00 | 0.2 | 13.2 | 1,873.6 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 17:00 | 0.2 | 13.2 | 1,872.8 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 18:00 | 0.2 | 13.1 | 1,916.5 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/10/2014 19:00 | 0.3 | 12.6 | 2,038.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/10/2014 20:00 | 0.3 | 12.6 | 2,051.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/10/2014 21:00 | 0.3 | 12.2 | 2,137.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/10/2014 22:00 | 0.3 | 12.8 | 2,009.1 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/10/2014 23:00 | 0.2 | 13.4 | 1,863.4 | 0.2 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 13.2 | 1,787.2 | 0.1 | 13.2 # | 24 # | 24 # | 20 # |
| **Minimum:** | 0.0 | 12.2 | 1,248.3 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Maximum:** | 0.3 | 13.8 | 2,137.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/11/2014 00:00 | 0.2 | 13.3 | 1,870.1 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 01:00 | 0.2 | 13.2 | 1,857.0 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 02:00 | 0.2 | 13.2 | 1,875.5 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 03:00 | 0.1 | 13.4 | 1,603.0 | 0.2 | 0.3 | 1 | 1 | 1 |
| 02/11/2014 04:00 | 0.0 | 13.9 | 1,250.9 | 0.1 | 0.0 | 1 | 1 | 0 |
| 02/11/2014 05:00 | 0.0 | 13.8 | 1,513.4 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/11/2014 06:00 | 0.2 | 13.1 | 1,862.5 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 07:00 | 0.2 | 13.1 | 1,876.7 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 08:00 | 0.3 | 12.7 | 2,064.3 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/11/2014 09:00 | 0.3 | 12.8 | 2,028.3 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/11/2014 10:00 | 0.2 | 13.1 | 1,916.4 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 11:00 | 0.2 | 13.2 | 1,876.1 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 12:00 | 0.2 | 13.2 | 1,876.2 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 13:00 | 0.2 | 13.3 | 1,875.3 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/11/2014 14:00 | 0.2 | 13.3 | 1,876.5 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/11/2014 15:00 | 0.2 | 13.3 | 1,877.5 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/11/2014 16:00 | 0.2 | 13.3 | 1,867.6 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/11/2014 17:00 | 0.2 | 13.3 | 1,875.3 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/11/2014 18:00 | 0.2 | 13.2 | 1,910.0 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/11/2014 19:00 | 0.3 | 12.6 | 2,039.1 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/11/2014 20:00 | 0.3 | 12.7 | 2,047.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/11/2014 21:00 | 0.3 | 12.3 | 2,127.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/11/2014 22:00 | 0.3 | 12.7 | 2,021.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/11/2014 23:00 | 0.2 | 13.0 | 1,953.8 | 0.2 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 13.1 | 1,872.6 | 0.2 | 15.9 # | 24 # | 24 # | 23 # |
| **Minimum:** | 0.0 | 12.3 | 1,250.9 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Maximum:** | 0.3 | 13.9 | 2,127.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/12/2014 00:00 | 0.2 | 13.2 | 1,893.3 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 01:00 | 0.3 | 12.9 | 2,007.0 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/12/2014 02:00 | 0.3 | 12.9 | 2,009.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/12/2014 03:00 | 0.3 | 12.9 | 2,016.0 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/12/2014 04:00 | 0.3 | 12.8 | 2,027.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/12/2014 05:00 | 0.3 | 12.8 | 2,024.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/12/2014 06:00 | 0.3 | 12.9 | 1,986.7 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/12/2014 07:00 | 0.3 | 12.6 | 2,074.5 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/12/2014 08:00 | 0.3 | 12.7 | 2,060.1 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/12/2014 09:00 | 0.2 | 13.1 | 1,916.5 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 10:00 | 0.2 | 13.1 | 1,868.8 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 11:00 | 0.2 | 13.1 | 1,872.0 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 12:00 | 0.2 | 13.2 | 1,874.3 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 13:00 | 0.2 | 13.2 | 1,872.5 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 14:00 | 0.2 | 13.2 | 1,870.9 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 15:00 | 0.2 | 13.2 | 1,870.9 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 16:00 | 0.2 | 13.2 | 1,870.3 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 17:00 | 0.2 | 13.2 | 1,887.0 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/12/2014 18:00 | 0.3 | 12.5 | 2,068.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/12/2014 19:00 | 0.1 | 11.6 | 2,281.8 | 0.2 | 0.3 | 1 | 1 | 1 |
| 02/12/2014 20:00 | 0.1 | 11.5 | 2,303.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/12/2014 21:00 | 0.1 | 11.6 | 2,268.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/12/2014 22:00 | 0.2 | 12.1 | 2,176.1 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/12/2014 23:00 | 0.3 | 12.7 | 2,024.7 | 0.1 | 1.0 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 12.8 | 2,005.2 | 0.2 | 17.6 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.1 | 11.5 | 1,868.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Maximum:** | 0.3 | 13.2 | 2,303.9 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/13/2014 00:00 | 0.2 | 13.1 | 1,905.0 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 01:00 | 0.2 | 13.2 | 1,872.5 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 02:00 | 0.2 | 13.1 | 1,865.1 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 03:00 | 0.2 | 13.1 | 1,865.3 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 04:00 | 0.2 | 13.1 | 1,863.5 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 05:00 | 0.2 | 13.1 | 1,881.9 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 06:00 | 0.3 | 13.0 | 1,932.6 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/13/2014 07:00 | 0.3 | 12.4 | 2,113.6 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/13/2014 08:00 | 0.2 | 11.8 | 2,236.4 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 09:00 | 0.2 | 12.2 | 2,146.8 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/13/2014 10:00 | 0.2 | 12.3 | 2,125.2 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/13/2014 11:00 | 0.2 | 12.3 | 2,124.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/13/2014 12:00 | 0.2 | 12.3 | 2,126.0 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/13/2014 13:00 | 0.2 | 12.2 | 2,124.5 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 14:00 | 0.2 | 12.2 | 2,126.3 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 15:00 | 0.2 | 12.2 | 2,126.0 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 16:00 | 0.2 | 12.2 | 2,127.9 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 17:00 | 0.2 | 12.1 | 2,143.0 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 18:00 | 0.2 | 12.1 | 2,134.7 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/13/2014 19:00 | 0.1 | 11.8 | 2,221.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/13/2014 20:00 | 0.1 | 11.5 | 2,273.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/13/2014 21:00 | 0.1 | 11.5 | 2,278.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/13/2014 22:00 | 0.1 | 11.7 | 2,224.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/13/2014 23:00 | 0.1 | 11.9 | 2,187.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 12.4 | 2,084.4 | 0.1 | 14.1 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.1 | 11.5 | 1,863.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Maximum:** | 0.3 | 13.2 | 2,278.1 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/14/2014 00:00 | 0.2 | 12.5 | 2,042.2 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 01:00 | 0.2 | 13.2 | 1,856.8 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 02:00 | 0.2 | 13.2 | 1,879.6 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 03:00 | 0.2 | 13.2 | 1,864.0 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 04:00 | 0.2 | 13.2 | 1,859.7 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 05:00 | 0.2 | 13.2 | 1,861.3 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 06:00 | 0.2 | 13.2 | 1,876.3 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 07:00 | 0.2 | 13.1 | 1,913.9 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 08:00 | 0.3 | 12.8 | 2,000.6 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/14/2014 09:00 | 0.2 | 12.3 | 2,110.1 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 10:00 | 0.2 | 12.1 | 2,137.9 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 11:00 | 0.1 | 12.0 | 2,140.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/14/2014 12:00 | 0.1 | 12.0 | 2,142.3 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/14/2014 13:00 | 0.2 | 11.9 | 2,149.2 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 14:00 | 0.1 | 11.9 | 2,150.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/14/2014 15:00 | 0.1 | 11.9 | 2,155.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/14/2014 16:00 | 0.1 | 12.0 | 2,126.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/14/2014 17:00 | 0.1 | 12.0 | 2,145.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/14/2014 18:00 | 0.1 | 12.0 | 2,151.4 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/14/2014 19:00 | 0.2 | 12.3 | 2,080.0 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 20:00 | 0.2 | 12.4 | 2,059.8 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 21:00 | 0.2 | 12.2 | 2,119.4 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 22:00 | 0.2 | 12.1 | 2,136.6 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/14/2014 23:00 | 0.2 | 12.5 | 2,046.8 | 0.1 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 12.5 | 2,041.9 | 0.1 | 12.7 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.1 | 11.9 | 1,856.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Maximum:** | 0.3 | 13.2 | 2,155.5 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/15/2014 00:00 | 0.3 | 12.6 | 2,025.0 | 0.1 | 1.0 | 1 | 1 | 1 |
| 02/15/2014 01:00 | 0.2 | 12.4 | 2,092.2 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/15/2014 02:00 | 0.1 | 11.9 | 2,201.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/15/2014 03:00 | 0.1 | 11.8 | 2,220.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/15/2014 04:00 | 0.2 | 12.4 | 2,075.8 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 05:00 | 0.2 | 12.7 | 2,028.7 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/15/2014 06:00 | 0.3 | 12.7 | 2,070.0 | 0.1 | 1.0 | 1 | 1 | 1 |
| 02/15/2014 07:00 | 0.2 | 12.8 | 2,004.4 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/15/2014 08:00 | 0.2 | 12.7 | 2,020.8 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/15/2014 09:00 | 0.3 | 12.6 | 2,058.5 | 0.1 | 1.0 | 1 | 1 | 1 |
| 02/15/2014 10:00 | 0.2 | 12.2 | 2,143.2 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/15/2014 11:00 | 0.1 | 11.7 | 2,241.6 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/15/2014 12:00 | 0.1 | 11.6 | 2,245.6 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/15/2014 13:00 | 0.1 | 11.8 | 2,191.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/15/2014 14:00 | 0.2 | 12.5 | 2,042.2 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 15:00 | 0.2 | 12.6 | 2,015.1 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 16:00 | 0.2 | 12.7 | 1,981.8 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 17:00 | 0.2 | 12.6 | 2,008.1 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 18:00 | 0.2 | 12.3 | 2,084.6 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 19:00 | 0.1 | 11.7 | 2,223.0 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/15/2014 20:00 | 0.1 | 11.8 | 2,205.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/15/2014 21:00 | 0.1 | 11.8 | 2,218.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/15/2014 22:00 | 0.2 | 12.1 | 2,134.5 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/15/2014 23:00 | 0.2 | 13.0 | 1,941.7 | 0.1 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 12.3 | 2,103.1 | 0.1 | 13.7 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.1 | 11.6 | 1,941.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Maximum:** | 0.3 | 13.0 | 2,245.6 | 0.1 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/16/2014 00:00 | 0.2 | 13.3 | 1,883.2 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/16/2014 01:00 | 0.2 | 13.3 | 1,891.2 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/16/2014 02:00 | 0.2 | 13.2 | 1,916.2 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/16/2014 03:00 | 0.1 | 13.4 | 1,730.0 | 0.2 | 0.3 | 1 | 1 | 1 |
| 02/16/2014 04:00 | 0.0 | 13.9 | 1,277.6 | 0.1 | 0.0 | 1 | 1 | 0 |
| 02/16/2014 05:00 | 0.0 | 13.8 | 1,478.7 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/16/2014 06:00 | 0.2 | 13.4 | 1,657.8 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/16/2014 07:00 | 0.3 | 13.0 | 1,985.0 | 0.1 | 1.0 | 1 | 1 | 1 |
| 02/16/2014 08:00 | 0.1 | 13.4 | 1,895.8 | 0.2 | 0.3 | 1 | 1 | 1 |
| 02/16/2014 09:00 | 0.1 | 13.6 | 1,856.3 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/16/2014 10:00 | 0.1 | 13.6 | 1,851.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/16/2014 11:00 | 0.1 | 13.6 | 1,849.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/16/2014 12:00 | 0.1 | 13.6 | 1,848.0 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/16/2014 13:00 | 0.1 | 13.6 | 1,836.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/16/2014 14:00 | 0.1 | 13.5 | 1,840.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/16/2014 15:00 | 0.1 | 13.5 | 1,856.6 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/16/2014 16:00 | 0.1 | 13.5 | 1,841.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/16/2014 17:00 | 0.1 | 13.5 | 1,844.0 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/16/2014 18:00 | 0.2 | 13.0 | 1,947.4 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/16/2014 19:00 | 0.1 | 11.9 | 2,221.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/16/2014 20:00 | 0.1 | 11.7 | 2,253.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/16/2014 21:00 | 0.1 | 11.7 | 2,255.4 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/16/2014 22:00 | 0.1 | 11.7 | 2,255.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/16/2014 23:00 | 0.2 | 12.6 | 2,051.1 | 0.1 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.1 | 13.1 | 1,888.5 | 0.1 | 9.6 # | 24 # | 24 # | 22 # |
| **Minimum:** | 0.0 | 11.7 | 1,277.6 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Maximum:** | 0.3 | 13.9 | 2,255.5 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/17/2014 00:00 | 0.2 | 13.2 | 1,891.1 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 01:00 | 0.2 | 13.2 | 1,877.8 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 02:00 | 0.1 | 13.4 | 1,769.9 | 0.2 | 0.3 | 1 | 1 | 1 |
| 02/17/2014 03:00 | 0.0 | 13.9 | 1,300.1 | 0.1 | 0.0 | 1 | 1 | 0 |
| 02/17/2014 04:00 | 0.0 | 13.8 | 1,374.2 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/17/2014 05:00 | 0.0 | 13.9 | 1,555.7 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/17/2014 06:00 | 0.0 | 13.8 | 1,826.7 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/17/2014 07:00 | 0.0 | 13.8 | 1,832.0 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/17/2014 08:00 | 0.0 | 13.8 | 1,805.0 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/17/2014 09:00 | 0.0 | 13.9 | 1,768.2 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/17/2014 10:00 | 0.2 | 13.2 | 1,867.8 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 11:00 | 0.2 | 13.2 | 1,865.9 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 12:00 | 0.2 | 13.2 | 1,864.2 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 13:00 | 0.2 | 13.3 | 1,860.9 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 14:00 | 0.2 | 13.3 | 1,863.1 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 15:00 | 0.2 | 13.3 | 1,869.3 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 16:00 | 0.2 | 13.3 | 1,864.6 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 17:00 | 0.2 | 13.3 | 1,863.4 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/17/2014 18:00 | 0.2 | 13.3 | 1,889.0 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/17/2014 19:00 | 0.2 | 13.2 | 1,927.2 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/17/2014 20:00 | 0.3 | 12.5 | 2,085.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/17/2014 21:00 | 0.1 | 11.9 | 2,210.1 | 0.2 | 0.3 | 1 | 1 | 1 |
| 02/17/2014 22:00 | 0.2 | 12.7 | 2,054.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/17/2014 23:00 | 0.2 | 13.1 | 1,920.8 | 0.1 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.1 | 13.3 | 1,833.6 | 0.1 | 10.4 # | 24 # | 24 # | 21 # |
| **Minimum:** | 0.0 | 11.9 | 1,300.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Maximum:** | 0.3 | 13.9 | 2,210.1 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/18/2014 00:00 | 0.2 | 13.2 | 1,872.7 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 01:00 | 0.2 | 13.2 | 1,870.4 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 02:00 | 0.2 | 13.2 | 1,866.6 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 03:00 | 0.2 | 13.2 | 1,867.1 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 04:00 | 0.2 | 13.2 | 1,866.2 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 05:00 | 0.2 | 13.2 | 1,866.6 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 06:00 | 0.2 | 13.1 | 1,902.9 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 07:00 | 0.2 | 12.7 | 2,058.6 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/18/2014 08:00 | 0.2 | 12.3 | 2,130.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/18/2014 09:00 | 0.2 | 12.9 | 1,990.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/18/2014 10:00 | 0.3 | 12.9 | 1,988.6 | 0.1 | 1.0 | 1 | 1 | 1 |
| 02/18/2014 11:00 | 0.2 | 12.7 | 2,033.7 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/18/2014 12:00 | 0.2 | 12.4 | 2,074.4 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 13:00 | 0.2 | 12.8 | 1,987.1 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 14:00 | 0.2 | 13.2 | 1,862.2 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 15:00 | 0.2 | 13.2 | 1,882.1 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 16:00 | 0.2 | 13.3 | 1,837.2 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 17:00 | 0.2 | 12.8 | 1,968.4 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/18/2014 18:00 | 0.1 | 11.9 | 2,188.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/18/2014 19:00 | 0.0 | 11.6 | 2,243.4 | 0.1 | 0.0 | 1 | 1 | 1 |
| 02/18/2014 20:00 | 0.2 | 12.5 | 2,075.4 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/18/2014 21:00 | 0.1 | 11.8 | 2,209.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/18/2014 22:00 | 0.1 | 13.1 | 1,918.6 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/18/2014 23:00 | 0.0 | 13.7 | 1,565.3 | 0.1 | 0.0 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 12.8 | 1,963.6 | 0.1 | 13.2 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.0 | 11.6 | 1,565.3 | 0.1 | 0.0 | 1 | 1 | 1 |
| **Maximum:** | 0.3 | 13.7 | 2,243.4 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/19/2014 00:00 | 0.0 | 13.9 | 1,241.6 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/19/2014 01:00 | 0.0 | 13.9 | 1,402.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/19/2014 02:00 | 13.4 | 15.8 | 600.1 | 0.0 | 4.8 | 1 | 0 | 0 |
| 02/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 02/19/2014 17:00 | 19.0 | 17.2 | 530.6 | 0.0 | 27.7 | 1 | 0 | 0 |
| 02/19/2014 18:00 | 8.4 | 14.1 | 1,477.2 | 0.0 | 24.1 | 1 | 0 | 1 |
| 02/19/2014 19:00 | 0.2 | 13.1 | 1,956.2 | 0.0 | 0.7 | 1 | 1 | 1 |
| 02/19/2014 20:00 | 0.1 | 11.9 | 2,225.4 | 0.0 | 0.3 | 1 | 1 | 1 |
| 02/19/2014 21:00 | 0.0 | 11.6 | 2,280.7 | 0.1 | 0.0 | 1 | 1 | 1 |
| 02/19/2014 22:00 | 0.1 | 12.1 | 2,180.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/19/2014 23:00 | 0.1 | 13.4 | 1,892.3 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 4.1 | 13.7 | 1,578.6 | 0.1 | 58.2 # | 10 # | 7 # | 6 # |
| **Minimum:** | 0.0 | 11.6 | 530.6 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 19.0 | 17.2 | 2,280.7 | 0.1 | 27.7 | 1 | 1 | 1 |
| **%SI** | 58.3 | 58.3 | 58.3 | 79.2 | 58.3 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/20/2014 00:00 | 0.1 | 13.6 | 1,844.0 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/20/2014 01:00 | 0.0 | 13.9 | 1,268.8 | 0.1 | 0.0 | 1 | 1 | 0 |
| 02/20/2014 02:00 | 0.0 | 13.9 | 1,243.8 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/20/2014 03:00 | 0.0 | 13.9 | 1,243.0 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/20/2014 04:00 | 0.0 | 13.9 | 1,258.6 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/20/2014 05:00 | 0.0 | 13.9 | 1,310.8 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/20/2014 06:00 | 0.3 | 12.7 | 1,890.1 | 0.1 | 0.9 | 1 | 1 | 1 |
| 02/20/2014 07:00 | 0.2 | 12.6 | 2,083.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/20/2014 08:00 | 0.1 | 12.4 | 2,113.6 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/20/2014 09:00 | 0.1 | 13.1 | 1,901.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/20/2014 10:00 | 0.1 | 13.2 | 1,858.4 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/20/2014 11:00 | 0.1 | 13.2 | 1,855.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/20/2014 12:00 | 0.1 | 13.3 | 1,857.0 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/20/2014 13:00 | 0.2 | 12.9 | 1,963.7 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/20/2014 14:00 | 0.1 | 13.3 | 1,868.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/20/2014 15:00 | 0.1 | 12.9 | 1,956.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/20/2014 16:00 | 0.0 | 12.2 | 2,094.5 | 0.1 | 0.0 | 1 | 1 | 1 |
| 02/20/2014 17:00 | 0.0 | 11.7 | 2,195.1 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/20/2014 18:00 | 0.0 | 12.0 | 2,138.7 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/20/2014 19:00 | 0.0 | 11.8 | 2,202.0 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/20/2014 20:00 | 0.0 | 11.7 | 2,217.6 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/20/2014 21:00 | 0.0 | 11.8 | 2,208.8 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/20/2014 22:00 | 0.0 | 11.7 | 2,214.3 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/20/2014 23:00 | 0.0 | 12.0 | 2,169.5 | 0.0 | 0.0 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.1 | 12.8 | 1,873.3 | 0.1 | 4.6 # | 24 # | 24 # | 19 # |
| **Minimum:** | 0.0 | 11.7 | 1,243.0 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Maximum:** | 0.3 | 13.9 | 2,217.6 | 0.1 | 0.9 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/21/2014 00:00 | 0.1 | 12.5 | 2,056.4 | 0.0 | 0.3 | 1 | 1 | 1 |
| 02/21/2014 01:00 | 0.0 | 13.4 | 1,882.1 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/21/2014 02:00 | 0.0 | 13.6 | 1,840.0 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/21/2014 03:00 | 0.1 | 13.6 | 1,842.0 | 0.0 | 0.3 | 1 | 1 | 1 |
| 02/21/2014 04:00 | 0.1 | 13.6 | 1,841.4 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/21/2014 05:00 | 0.1 | 13.6 | 1,841.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/21/2014 06:00 | 0.1 | 13.5 | 1,860.0 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/21/2014 07:00 | 0.2 | 12.9 | 2,004.0 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/21/2014 08:00 | 0.0 | 12.0 | 2,171.1 | 0.1 | 0.0 | 1 | 1 | 1 |
| 02/21/2014 09:00 | 0.1 | 13.1 | 1,941.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/21/2014 10:00 | 0.0 | 13.5 | 1,845.1 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/21/2014 11:00 | 0.0 | 13.4 | 1,860.3 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/21/2014 12:00 | 0.0 | 13.4 | 1,848.8 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/21/2014 13:00 | 0.0 | 13.4 | 1,844.5 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/21/2014 14:00 | 0.0 | 13.4 | 1,840.1 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/21/2014 15:00 | 0.1 | 13.4 | 1,834.4 | 0.0 | 0.3 | 1 | 1 | 1 |
| 02/21/2014 16:00 | 0.1 | 13.4 | 1,830.0 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/21/2014 17:00 | 0.1 | 13.3 | 1,843.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/21/2014 18:00 | 0.1 | 12.6 | 1,997.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/21/2014 19:00 | 0.1 | 12.2 | 2,101.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/21/2014 20:00 | 0.0 | 12.1 | 2,125.6 | 0.1 | 0.0 | 1 | 1 | 1 |
| 02/21/2014 21:00 | 0.0 | 11.9 | 2,176.4 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/21/2014 22:00 | 0.0 | 12.1 | 2,116.5 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/21/2014 23:00 | 0.1 | 12.4 | 2,063.0 | 0.0 | 0.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.1 | 13.0 | 1,942.0 | 0.0 | 4.3 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.0 | 11.9 | 1,830.0 | 0.0 | 0.0 | 1 | 1 | 1 |
| **Maximum:** | 0.2 | 13.6 | 2,176.4 | 0.1 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/22/2014 00:00 | 0.1 | 12.5 | 2,043.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/22/2014 01:00 | 0.1 | 12.7 | 1,999.6 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/22/2014 02:00 | 0.1 | 13.2 | 1,866.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/22/2014 03:00 | 0.2 | 12.8 | 1,980.5 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 04:00 | 0.2 | 12.7 | 2,001.3 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 05:00 | 0.2 | 13.1 | 1,934.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/22/2014 06:00 | 0.2 | 12.7 | 2,027.0 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/22/2014 07:00 | 0.2 | 12.7 | 2,034.0 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/22/2014 08:00 | 0.2 | 12.8 | 2,013.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/22/2014 09:00 | 0.2 | 13.2 | 1,897.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/22/2014 10:00 | 0.2 | 13.3 | 1,873.2 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/22/2014 11:00 | 0.2 | 13.3 | 1,872.0 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/22/2014 12:00 | 0.2 | 13.2 | 1,877.7 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 13:00 | 0.2 | 13.2 | 1,866.5 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 14:00 | 0.2 | 12.9 | 1,945.8 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/22/2014 15:00 | 0.1 | 12.6 | 1,981.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/22/2014 16:00 | 0.1 | 13.0 | 1,895.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/22/2014 17:00 | 0.1 | 12.5 | 1,994.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/22/2014 18:00 | 0.1 | 12.3 | 2,040.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/22/2014 19:00 | 0.1 | 12.2 | 2,063.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/22/2014 20:00 | 0.0 | 11.8 | 2,165.5 | 0.1 | 0.0 | 1 | 1 | 1 |
| 02/22/2014 21:00 | 0.0 | 11.7 | 2,184.5 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/22/2014 22:00 | 0.0 | 11.7 | 2,189.5 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/22/2014 23:00 | 0.0 | 11.7 | 2,200.0 | 0.0 | 0.0 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.1 | 12.7 | 1,997.8 | 0.1 | 10.3 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.0 | 11.7 | 1,866.1 | 0.0 | 0.0 | 1 | 1 | 1 |
| **Maximum:** | 0.2 | 13.3 | 2,200.0 | 0.2 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/23/2014 00:00 | 0.0 | 12.0 | 2,187.7 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/23/2014 01:00 | 0.1 | 12.2 | 2,134.1 | 0.0 | 0.3 | 1 | 1 | 1 |
| 02/23/2014 02:00 | 0.0 | 11.9 | 2,200.1 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/23/2014 03:00 | 0.0 | 11.8 | 2,210.6 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/23/2014 04:00 | 0.1 | 12.3 | 2,112.2 | 0.0 | 0.3 | 1 | 1 | 1 |
| 02/23/2014 05:00 | 0.2 | 12.7 | 2,025.2 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/23/2014 06:00 | 0.2 | 12.6 | 2,038.4 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 07:00 | 0.2 | 12.8 | 2,003.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/23/2014 08:00 | 0.2 | 12.9 | 1,987.5 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/23/2014 09:00 | 0.2 | 13.0 | 1,971.1 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/23/2014 10:00 | 0.1 | 13.4 | 1,851.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/23/2014 11:00 | 0.1 | 13.2 | 1,891.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/23/2014 12:00 | 0.2 | 13.1 | 1,914.6 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 13:00 | 0.1 | 13.3 | 1,859.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/23/2014 14:00 | 0.1 | 13.3 | 1,854.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/23/2014 15:00 | 0.1 | 13.2 | 1,864.0 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/23/2014 16:00 | 0.2 | 13.0 | 1,885.8 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/23/2014 17:00 | 0.1 | 12.9 | 1,925.3 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/23/2014 18:00 | 0.1 | 12.2 | 2,077.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/23/2014 19:00 | 0.0 | 11.8 | 2,156.8 | 0.1 | 0.0 | 1 | 1 | 1 |
| 02/23/2014 20:00 | 0.0 | 11.9 | 2,147.8 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/23/2014 21:00 | 0.0 | 11.9 | 2,148.3 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/23/2014 22:00 | 0.0 | 11.9 | 2,149.0 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/23/2014 23:00 | 0.0 | 12.0 | 2,133.0 | 0.0 | 0.0 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.1 | 12.6 | 2,030.4 | 0.1 | 7.3 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.0 | 11.8 | 1,851.2 | 0.0 | 0.0 | 1 | 1 | 1 |
| **Maximum:** | 0.2 | 13.4 | 2,210.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/24/2014 00:00 | 0.2 | 12.8 | 1,999.2 | 0.0 | 0.7 | 1 | 1 | 1 |
| 02/24/2014 01:00 | 0.1 | 13.4 | 1,851.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/24/2014 02:00 | 0.1 | 13.5 | 1,796.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/24/2014 03:00 | 0.0 | 13.9 | 1,254.6 | 0.1 | 0.0 | 1 | 1 | 0 |
| 02/24/2014 04:00 | 0.0 | 13.9 | 1,230.8 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/24/2014 05:00 | 0.1 | 13.6 | 1,527.4 | 0.0 | 0.3 | 1 | 1 | 1 |
| 02/24/2014 06:00 | 0.2 | 13.2 | 1,895.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/24/2014 07:00 | 0.2 | 13.0 | 1,952.8 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/24/2014 08:00 | 0.5 | 12.5 | 2,083.2 | 0.2 | 1.6 | 1 | 1 | 1 |
| 02/24/2014 09:00 | 0.1 | 13.1 | 1,941.3 | 0.2 | 0.3 | 1 | 1 | 1 |
| 02/24/2014 10:00 | 0.1 | 13.5 | 1,830.0 | 0.2 | 0.3 | 1 | 1 | 1 |
| 02/24/2014 11:00 | 0.1 | 13.4 | 1,856.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/24/2014 12:00 | 0.1 | 13.4 | 1,828.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/24/2014 13:00 | 0.1 | 13.4 | 1,831.0 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/24/2014 14:00 | 0.1 | 13.3 | 1,825.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/24/2014 15:00 | 0.2 | 12.6 | 1,972.5 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/24/2014 16:00 | 0.2 | 12.6 | 1,965.9 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/24/2014 17:00 | 0.1 | 12.3 | 2,039.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/24/2014 18:00 | 0.0 | 11.9 | 2,113.2 | 0.1 | 0.0 | 1 | 1 | 1 |
| 02/24/2014 19:00 | 0.0 | 11.7 | 2,174.1 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/24/2014 20:00 | 0.0 | 11.8 | 2,156.1 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/24/2014 21:00 | 0.0 | 11.9 | 2,142.8 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/24/2014 22:00 | 0.0 | 12.0 | 2,144.1 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/24/2014 23:00 | 0.0 | 11.9 | 2,153.7 | 0.0 | 0.0 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.1 | 12.9 | 1,898.6 | 0.1 | 7.9 # | 24 # | 24 # | 22 # |
| **Minimum:** | 0.0 | 11.7 | 1,230.8 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Maximum:** | 0.5 | 13.9 | 2,174.1 | 0.2 | 1.6 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/25/2014 00:00 | 0.1 | 12.6 | 2,039.8 | 0.0 | 0.3 | 1 | 1 | 1 |
| 02/25/2014 01:00 | 0.2 | 12.9 | 1,971.1 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/25/2014 02:00 | 0.2 | 13.3 | 1,851.7 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 03:00 | 0.2 | 13.3 | 1,843.8 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 04:00 | 0.2 | 13.3 | 1,846.4 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 05:00 | 0.2 | 12.8 | 1,996.3 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/25/2014 06:00 | 0.2 | 12.7 | 2,022.4 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/25/2014 07:00 | 0.2 | 13.0 | 1,953.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/25/2014 08:00 | 0.2 | 12.7 | 2,004.7 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 09:00 | 0.1 | 13.3 | 1,848.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/25/2014 10:00 | 0.1 | 13.4 | 1,835.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/25/2014 11:00 | 0.1 | 13.4 | 1,824.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/25/2014 12:00 | 0.1 | 13.4 | 1,828.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/25/2014 13:00 | 0.1 | 13.4 | 1,841.3 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/25/2014 14:00 | 0.1 | 13.4 | 1,825.4 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/25/2014 15:00 | 0.1 | 13.4 | 1,828.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/25/2014 16:00 | 0.2 | 13.2 | 1,873.1 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 17:00 | 0.2 | 13.3 | 1,855.4 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 18:00 | 0.2 | 12.8 | 1,959.8 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 19:00 | 0.1 | 12.2 | 2,100.0 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/25/2014 20:00 | 0.1 | 12.0 | 2,129.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/25/2014 21:00 | 0.2 | 12.4 | 2,053.7 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 22:00 | 0.2 | 12.9 | 1,949.9 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/25/2014 23:00 | 0.1 | 12.1 | 2,117.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 13.0 | 1,933.4 | 0.1 | 11.5 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.1 | 12.0 | 1,824.8 | 0.0 | 0.3 | 1 | 1 | 1 |
| **Maximum:** | 0.2 | 13.4 | 2,129.9 | 0.2 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/26/2014 00:00 | 0.2 | 12.9 | 1,941.8 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 01:00 | 0.2 | 13.2 | 1,881.5 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 02:00 | 0.2 | 13.2 | 1,868.4 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 03:00 | 0.3 | 13.2 | 1,865.7 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/26/2014 04:00 | 0.3 | 13.2 | 1,861.0 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/26/2014 05:00 | 0.3 | 13.1 | 1,900.5 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/26/2014 06:00 | 0.2 | 12.2 | 2,075.7 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 07:00 | 0.1 | 12.1 | 2,156.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/26/2014 08:00 | 0.0 | 11.7 | 2,226.5 | 0.1 | 0.0 | 1 | 1 | 1 |
| 02/26/2014 09:00 | 0.0 | 11.7 | 2,232.8 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/26/2014 10:00 | 0.0 | 0.0 | 2,238.4 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/26/2014 11:00 | 0.0 | 0.0 | 2,182.3 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/26/2014 12:00 | 0.0 | 0.0 | 2,038.6 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/26/2014 13:00 | 0.0 | 0.0 | 2,172.9 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/26/2014 14:00 | 0.2 | 12.2 | 2,103.1 | 0.0 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 15:00 | 0.2 | 12.3 | 2,085.7 | 0.0 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 16:00 | 0.2 | 12.6 | 2,026.2 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/26/2014 17:00 | 0.1 | 12.2 | 2,130.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/26/2014 18:00 | 0.1 | 12.0 | 2,158.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/26/2014 19:00 | 0.0 | 11.7 | 2,226.8 | 0.1 | 0.0 | 1 | 1 | 1 |
| 02/26/2014 20:00 | 0.0 | 11.7 | 2,213.9 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/26/2014 21:00 | 0.0 | 11.8 | 2,197.6 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/26/2014 22:00 | 0.0 | 11.8 | 2,178.5 | 0.0 | 0.0 | 1 | 1 | 1 |
| 02/26/2014 23:00 | 0.1 | 12.0 | 2,135.1 | 0.0 | 0.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.1 | 12.3 | 2,087.4 | 0.1 | 8.4 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.0 | 11.7 | 1,861.0 | 0.0 | 0.0 | 1 | 1 | 1 |
| **Maximum:** | 0.3 | 13.2 | 2,238.4 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 16.7 | 16.7 | 0.0 | 25.0 | 16.7 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/27/2014 00:00 | 0.2 | 12.7 | 2,001.5 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 01:00 | 0.2 | 13.2 | 1,883.6 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 02:00 | 0.0 | 13.6 | 1,567.6 | 0.1 | 0.0 | 1 | 1 | 1 |
| 02/27/2014 03:00 | 0.0 | 13.9 | 1,283.7 | 0.1 | 0.0 | 1 | 1 | 0 |
| 02/27/2014 04:00 | 0.0 | 13.8 | 1,567.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| 02/27/2014 05:00 | 0.1 | 13.4 | 1,724.2 | 0.0 | 0.3 | 1 | 1 | 1 |
| 02/27/2014 06:00 | 0.3 | 13.1 | 1,915.1 | 0.1 | 1.0 | 1 | 1 | 1 |
| 02/27/2014 07:00 | 0.2 | 13.3 | 1,888.2 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/27/2014 08:00 | 0.2 | 12.5 | 2,045.3 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 09:00 | 0.2 | 13.4 | 1,861.6 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/27/2014 10:00 | 0.3 | 13.5 | 1,847.9 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/27/2014 11:00 | 0.3 | 13.5 | 1,844.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/27/2014 12:00 | 0.2 | 13.5 | 1,845.7 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/27/2014 13:00 | 0.1 | 13.4 | 1,848.3 | 0.2 | 0.3 | 1 | 1 | 1 |
| 02/27/2014 14:00 | 0.1 | 13.4 | 1,844.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/27/2014 15:00 | 0.1 | 13.4 | 1,846.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/27/2014 16:00 | 0.1 | 13.4 | 1,847.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 02/27/2014 17:00 | 0.2 | 13.2 | 1,908.5 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/27/2014 18:00 | 0.2 | 13.1 | 1,912.8 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/27/2014 19:00 | 0.3 | 12.4 | 2,082.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/27/2014 20:00 | 0.3 | 12.5 | 2,062.4 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/27/2014 21:00 | 0.3 | 12.5 | 2,070.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/27/2014 22:00 | 0.3 | 12.6 | 2,048.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/27/2014 23:00 | 0.3 | 12.4 | 2,072.5 | 0.2 | 1.0 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 13.2 | 1,867.5 | 0.1 | 14.7 # | 24 # | 24 # | 22 # |
| **Minimum:** | 0.0 | 12.4 | 1,283.7 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Maximum:** | 0.3 | 13.9 | 2,082.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 02/28/2014 00:00 | 0.2 | 13.1 | 1,927.9 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/28/2014 01:00 | 0.2 | 13.3 | 1,882.3 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/28/2014 02:00 | 0.2 | 13.0 | 1,945.5 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/28/2014 03:00 | 0.2 | 13.3 | 1,881.5 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/28/2014 04:00 | 0.2 | 13.3 | 1,883.9 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/28/2014 05:00 | 0.2 | 13.2 | 1,898.3 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/28/2014 06:00 | 0.2 | 13.3 | 1,893.0 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/28/2014 07:00 | 0.2 | 13.2 | 1,906.3 | 0.2 | 0.7 | 1 | 1 | 1 |
| 02/28/2014 08:00 | 0.3 | 12.6 | 2,047.7 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/28/2014 09:00 | 0.2 | 12.0 | 2,177.8 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 10:00 | 0.2 | 11.8 | 2,222.3 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 11:00 | 0.2 | 11.9 | 2,203.3 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 12:00 | 0.2 | 12.0 | 2,168.1 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 13:00 | 0.2 | 12.5 | 2,052.2 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 14:00 | 0.2 | 13.1 | 1,900.5 | 0.1 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 15:00 | 0.3 | 12.9 | 1,972.4 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/28/2014 16:00 | 0.2 | 12.1 | 2,146.4 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 17:00 | 0.3 | 12.3 | 2,103.7 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/28/2014 18:00 | 0.2 | 12.9 | 1,979.1 | 0.1 | 0.7 | 1 | 1 | 1 |
| 02/28/2014 19:00 | 0.3 | 12.6 | 2,035.5 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/28/2014 20:00 | 0.2 | 13.2 | 1,877.1 | 0.2 | 0.6 | 1 | 1 | 1 |
| 02/28/2014 21:00 | 0.3 | 12.9 | 1,986.4 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/28/2014 22:00 | 0.3 | 12.7 | 2,026.5 | 0.2 | 1.0 | 1 | 1 | 1 |
| 02/28/2014 23:00 | 0.3 | 12.5 | 2,067.6 | 0.2 | 1.0 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 12.7 | 2,007.7 | 0.2 | 18.1 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 11.8 | 1,877.1 | 0.1 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.3 | 13.3 | 2,222.3 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/01/2014 00:00 | 0.3 | 12.9 | 1,971.9 | 0.2 | 1.0 | 1 | 1 | 1 |
| 03/01/2014 01:00 | 0.2 | 13.2 | 1,893.2 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 02:00 | 0.2 | 13.2 | 1,865.6 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 03:00 | 0.2 | 13.2 | 1,869.1 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 04:00 | 0.2 | 13.2 | 1,871.7 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 05:00 | 0.2 | 13.2 | 1,884.0 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 06:00 | 0.2 | 13.2 | 1,868.0 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 07:00 | 0.2 | 13.2 | 1,868.0 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 08:00 | 0.2 | 13.2 | 1,878.7 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 09:00 | 0.2 | 13.2 | 1,873.3 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 10:00 | 0.2 | 13.2 | 1,877.2 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 11:00 | 0.2 | 13.3 | 1,872.5 | 0.2 | 0.7 | 1 | 1 | 1 |
| 03/01/2014 12:00 | 0.2 | 13.3 | 1,868.8 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 13:00 | 0.2 | 13.2 | 1,893.2 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 14:00 | 0.3 | 12.8 | 2,023.4 | 0.2 | 1.0 | 1 | 1 | 1 |
| 03/01/2014 15:00 | 0.3 | 12.7 | 2,030.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| 03/01/2014 16:00 | 0.2 | 13.3 | 1,903.3 | 0.2 | 0.7 | 1 | 1 | 1 |
| 03/01/2014 17:00 | 0.2 | 13.3 | 1,868.5 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 18:00 | 0.2 | 13.3 | 1,870.0 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 19:00 | 0.3 | 12.9 | 1,978.2 | 0.2 | 1.0 | 1 | 1 | 1 |
| 03/01/2014 20:00 | 0.2 | 12.9 | 1,960.0 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/01/2014 21:00 | 0.3 | 12.7 | 2,017.3 | 0.2 | 1.0 | 1 | 1 | 1 |
| 03/01/2014 22:00 | 0.3 | 12.8 | 2,018.3 | 0.2 | 1.0 | 1 | 1 | 1 |
| 03/01/2014 23:00 | 0.3 | 12.6 | 2,050.9 | 0.2 | 1.0 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 13.1 | 1,919.8 | 0.2 | 17.4 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 12.6 | 1,865.6 | 0.2 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.3 | 13.3 | 2,050.9 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/02/2014 00:00 | 0.2 | 13.1 | 1,939.7 | 0.2 | 0.7 | 1 | 1 | 1 |
| 03/02/2014 01:00 | 0.3 | 12.8 | 2,041.9 | 0.2 | 1.0 | 1 | 1 | 1 |
| 03/02/2014 02:00 | 0.2 | 12.9 | 2,022.7 | 0.2 | 0.7 | 1 | 1 | 1 |
| 03/02/2014 03:00 | 0.2 | 13.2 | 1,890.2 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 04:00 | 0.2 | 13.2 | 1,866.3 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 05:00 | 0.2 | 13.2 | 1,913.8 | 0.2 | 0.7 | 1 | 1 | 1 |
| 03/02/2014 06:00 | 0.3 | 12.8 | 2,008.6 | 0.2 | 1.0 | 1 | 1 | 1 |
| 03/02/2014 07:00 | 0.3 | 12.7 | 2,089.0 | 0.2 | 1.0 | 1 | 1 | 1 |
| 03/02/2014 08:00 | 0.3 | 12.7 | 2,082.1 | 0.2 | 1.0 | 1 | 1 | 1 |
| 03/02/2014 09:00 | 0.2 | 13.1 | 1,975.3 | 0.2 | 0.7 | 1 | 1 | 1 |
| 03/02/2014 10:00 | 0.3 | 12.7 | 2,065.0 | 0.2 | 1.0 | 1 | 1 | 1 |
| 03/02/2014 11:00 | 0.2 | 11.9 | 2,233.3 | 0.2 | 0.7 | 1 | 1 | 1 |
| 03/02/2014 12:00 | 0.2 | 12.0 | 2,209.0 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/02/2014 13:00 | 0.1 | 11.7 | 2,259.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/02/2014 14:00 | 0.1 | 11.7 | 2,250.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/02/2014 15:00 | 0.1 | 11.7 | 2,242.0 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/02/2014 16:00 | 0.1 | 11.7 | 2,239.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/02/2014 17:00 | 0.1 | 11.9 | 2,202.4 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/02/2014 18:00 | 0.2 | 12.2 | 2,125.7 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 19:00 | 0.2 | 12.2 | 2,131.3 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/02/2014 20:00 | 0.3 | 12.5 | 2,066.1 | 0.1 | 1.0 | 1 | 1 | 1 |
| 03/02/2014 21:00 | 0.2 | 12.2 | 2,163.2 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/02/2014 22:00 | 0.3 | 12.7 | 2,076.1 | 0.2 | 1.0 | 1 | 1 | 1 |
| 03/02/2014 23:00 | 0.2 | 12.9 | 2,027.0 | 0.1 | 0.7 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 12.5 | 2,088.4 | 0.2 | 16.5 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.1 | 11.7 | 1,866.3 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Maximum:** | 0.3 | 13.2 | 2,259.8 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/03/2014 00:00 | 0.1 | 13.5 | 1,613.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/03/2014 01:00 | 0.0 | 13.8 | 1,436.4 | 0.1 | 0.0 | 1 | 1 | 0 |
| 03/03/2014 02:00 | 0.0 | 13.8 | 1,291.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/03/2014 03:00 | 0.0 | 13.8 | 1,288.6 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/03/2014 04:00 | 0.0 | 13.8 | 1,294.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/03/2014 05:00 | 0.1 | 13.5 | 1,596.4 | 0.0 | 0.3 | 1 | 1 | 1 |
| 03/03/2014 06:00 | 0.2 | 13.1 | 1,911.0 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/03/2014 07:00 | 0.2 | 12.8 | 2,030.9 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/03/2014 08:00 | 0.1 | 11.9 | 2,222.6 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/03/2014 09:00 | 0.1 | 12.0 | 2,166.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/03/2014 10:00 | 0.2 | 12.7 | 2,023.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/03/2014 11:00 | 0.2 | 13.0 | 1,948.7 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/03/2014 12:00 | 0.2 | 13.1 | 1,904.7 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/03/2014 13:00 | 0.2 | 13.2 | 1,882.1 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/03/2014 14:00 | 0.2 | 13.1 | 1,906.3 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/03/2014 15:00 | 0.2 | 13.1 | 1,947.9 | 0.2 | 0.7 | 1 | 1 | 1 |
| 03/03/2014 16:00 | 0.2 | 12.8 | 2,036.3 | 0.2 | 0.7 | 1 | 1 | 1 |
| 03/03/2014 17:00 | 0.1 | 11.9 | 2,217.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/03/2014 18:00 | 0.1 | 12.3 | 2,097.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/03/2014 19:00 | 0.0 | 11.9 | 2,205.8 | 0.1 | 0.0 | 1 | 1 | 1 |
| 03/03/2014 20:00 | 0.0 | 11.7 | 2,237.8 | 0.0 | 0.0 | 1 | 1 | 1 |
| 03/03/2014 21:00 | 0.0 | 11.8 | 2,218.3 | 0.0 | 0.0 | 1 | 1 | 1 |
| 03/03/2014 22:00 | 0.2 | 12.7 | 1,990.1 | 0.0 | 0.6 | 1 | 1 | 1 |
| 03/03/2014 23:00 | 0.2 | 13.1 | 1,866.1 | 0.1 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.1 | 12.9 | 1,888.9 | 0.1 | 8.9 # | 24 # | 24 # | 20 # |
| **Minimum:** | 0.0 | 11.7 | 1,288.6 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Maximum:** | 0.2 | 13.8 | 2,237.8 | 0.2 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/04/2014 00:00 | 0.1 | 13.4 | 1,579.0 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/04/2014 01:00 | 0.0 | 13.8 | 1,260.2 | 0.1 | 0.0 | 1 | 1 | 0 |
| 03/04/2014 02:00 | 0.0 | 13.8 | 1,269.8 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/04/2014 03:00 | 0.0 | 13.8 | 1,332.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/04/2014 04:00 | 0.0 | 13.8 | 1,279.9 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/04/2014 05:00 | 0.0 | 13.8 | 1,296.3 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/04/2014 06:00 | 0.1 | 13.4 | 1,591.9 | 0.0 | 0.3 | 1 | 1 | 1 |
| 03/04/2014 07:00 | 0.2 | 13.3 | 1,879.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/04/2014 08:00 | 0.2 | 13.3 | 1,868.8 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/04/2014 09:00 | 0.0 | 13.8 | 1,445.9 | 0.1 | 0.0 | 1 | 1 | 1 |
| 03/04/2014 10:00 | 0.0 | 13.9 | 1,236.5 | 0.1 | 0.0 | 1 | 1 | 0 |
| 03/04/2014 11:00 | 0.0 | 13.9 | 1,237.4 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/04/2014 12:00 | 0.0 | 13.8 | 1,268.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/04/2014 13:00 | 0.0 | 13.8 | 1,421.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/04/2014 14:00 | 0.2 | 13.3 | 1,856.8 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/04/2014 15:00 | 0.2 | 13.3 | 1,875.4 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/04/2014 16:00 | 0.2 | 13.3 | 1,876.9 | 0.2 | 0.7 | 1 | 1 | 1 |
| 03/04/2014 17:00 | 0.2 | 13.3 | 1,875.0 | 0.2 | 0.7 | 1 | 1 | 1 |
| 03/04/2014 18:00 | 0.2 | 13.2 | 1,910.3 | 0.2 | 0.7 | 1 | 1 | 1 |
| 03/04/2014 19:00 | 0.1 | 12.2 | 2,137.8 | 0.2 | 0.3 | 1 | 1 | 1 |
| 03/04/2014 20:00 | 0.1 | 12.2 | 2,111.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/04/2014 21:00 | 0.2 | 12.6 | 2,027.7 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/04/2014 22:00 | 0.2 | 12.9 | 1,958.9 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/04/2014 23:00 | 0.2 | 13.3 | 1,869.3 | 0.1 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.1 | 13.4 | 1,644.4 | 0.1 | 7.7 # | 24 # | 24 # | 15 # |
| **Minimum:** | 0.0 | 12.2 | 1,236.5 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Maximum:** | 0.2 | 13.9 | 2,137.8 | 0.2 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/05/2014 00:00 | 0.2 | 13.2 | 1,890.2 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 01:00 | 0.2 | 12.7 | 2,011.5 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 02:00 | 0.2 | 12.7 | 2,025.2 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/05/2014 03:00 | 0.2 | 13.1 | 1,903.1 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 04:00 | 0.2 | 13.2 | 1,865.7 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 05:00 | 0.2 | 12.9 | 1,981.8 | 0.2 | 0.7 | 1 | 1 | 1 |
| 03/05/2014 06:00 | 0.2 | 13.1 | 1,952.2 | 0.2 | 0.7 | 1 | 1 | 1 |
| 03/05/2014 07:00 | 0.2 | 12.9 | 1,971.2 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/05/2014 08:00 | 0.2 | 12.9 | 1,976.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/05/2014 09:00 | 0.2 | 13.1 | 1,890.0 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 10:00 | 0.2 | 13.1 | 1,891.0 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 11:00 | 0.2 | 13.2 | 1,891.5 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 12:00 | 0.2 | 13.2 | 1,892.0 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 13:00 | 0.2 | 13.2 | 1,892.5 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 14:00 | 0.2 | 13.2 | 1,892.9 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 15:00 | 0.2 | 13.1 | 1,894.4 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 16:00 | 0.2 | 12.9 | 1,935.8 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 17:00 | 0.2 | 12.8 | 1,973.3 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 18:00 | 0.2 | 12.8 | 1,980.1 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 19:00 | 0.2 | 12.4 | 2,076.0 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 20:00 | 0.2 | 12.5 | 2,033.9 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 21:00 | 0.2 | 12.7 | 2,006.6 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 22:00 | 0.2 | 12.7 | 1,992.2 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/05/2014 23:00 | 0.2 | 13.1 | 1,871.2 | 0.1 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.2 | 12.9 | 1,945.5 | 0.2 | 14.9 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.2 | 12.4 | 1,865.7 | 0.1 | 0.6 | 1 | 1 | 1 |
| **Maximum:** | 0.2 | 13.2 | 2,076.0 | 0.2 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/06/2014 00:00 | 0.2 | 13.2 | 1,867.0 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/06/2014 01:00 | 0.2 | 13.3 | 1,817.9 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/06/2014 02:00 | 0.0 | 13.9 | 1,275.8 | 0.1 | 0.0 | 1 | 1 | 0 |
| 03/06/2014 03:00 | 11.6 | 15.6 | 633.1 | 0.0 | 4.6 | 1 | 0 | 0 |
| 03/06/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/06/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 3.0 | 14.0 | 1,398.5 | 0.2 | 5.8 # | 4 # | 3 # | 2 # |
| **Minimum:** | 0.0 | 13.2 | 633.1 | 0.1 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 11.6 | 15.6 | 1,867.0 | 0.2 | 4.6 | 1 | 1 | 1 |
| **%SI** | 83.3 | 83.3 | 83.3 | 87.5 | 83.3 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/07/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/07/2014 07:00 | 62.5 | 17.5 | 493.3 | 0.0 | 75.5 | 1 | 0 | 0 |
| 03/07/2014 08:00 | 11.9 | 14.9 | 1,127.5 | 0.0 | 29.5 | 1 | 0 | 0 |
| 03/07/2014 09:00 | 0.0 | 13.9 | 1,337.3 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/07/2014 10:00 | 0.1 | 13.3 | 1,814.7 | 0.0 | 0.3 | 1 | 1 | 1 |
| 03/07/2014 11:00 | 0.1 | 13.2 | 1,860.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/07/2014 12:00 | 0.1 | 13.3 | 1,859.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/07/2014 13:00 | 0.1 | 13.3 | 1,856.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/07/2014 14:00 | 0.1 | 13.3 | 1,859.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/07/2014 15:00 | 0.1 | 13.3 | 1,858.6 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/07/2014 16:00 | 0.1 | 13.2 | 1,886.6 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/07/2014 17:00 | 0.2 | 12.7 | 2,027.0 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/07/2014 18:00 | 0.2 | 12.6 | 2,038.6 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/07/2014 19:00 | 0.1 | 11.9 | 2,213.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/07/2014 20:00 | 0.0 | 11.6 | 2,292.8 | 0.1 | 0.0 | 1 | 1 | 1 |
| 03/07/2014 21:00 | 0.0 | 11.6 | 2,288.2 | 0.0 | 0.0 | 1 | 1 | 1 |
| 03/07/2014 22:00 | 0.0 | 11.6 | 2,286.8 | 0.0 | 0.0 | 1 | 1 | 1 |
| 03/07/2014 23:00 | 0.1 | 11.9 | 2,225.4 | 0.0 | 0.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 4.5 | 13.1 | 1,842.7 | 0.1 | 109.0 # | 17 # | 15 # | 14 # |
| **Minimum:** | 0.0 | 11.6 | 493.3 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 62.5 | 17.5 | 2,292.8 | 0.1 | 75.5 | 1 | 1 | 1 |
| **%SI** | 29.2 | 29.2 | 29.2 | 45.8 | 29.2 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/08/2014 00:00 | 0.2 | 12.8 | 2,018.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/08/2014 01:00 | 0.2 | 12.9 | 2,000.5 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/08/2014 02:00 | 0.2 | 13.0 | 1,950.6 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/08/2014 03:00 | 0.2 | 13.1 | 1,927.4 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/08/2014 04:00 | 0.2 | 13.0 | 1,982.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/08/2014 05:00 | 0.2 | 12.8 | 2,027.5 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/08/2014 06:00 | 0.2 | 12.6 | 2,065.9 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/08/2014 07:00 | 0.2 | 12.7 | 2,044.0 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/08/2014 08:00 | 0.1 | 13.1 | 1,907.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/08/2014 09:00 | 0.1 | 13.2 | 1,854.3 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/08/2014 10:00 | 0.1 | 13.2 | 1,854.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/08/2014 11:00 | 0.1 | 13.2 | 1,852.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/08/2014 12:00 | 0.1 | 13.2 | 1,852.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/08/2014 13:00 | 0.1 | 13.3 | 1,855.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/08/2014 14:00 | 0.1 | 13.3 | 1,852.6 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/08/2014 15:00 | 0.1 | 13.3 | 1,852.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/08/2014 16:00 | 0.1 | 13.3 | 1,862.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/08/2014 17:00 | 0.1 | 13.2 | 1,888.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/08/2014 18:00 | 0.2 | 12.2 | 2,136.8 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/08/2014 19:00 | 0.1 | 11.6 | 2,249.6 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/08/2014 20:00 | 0.0 | 11.5 | 2,269.4 | 0.1 | 0.0 | 1 | 1 | 1 |
| 03/08/2014 21:00 | 0.0 | 11.5 | 2,262.4 | 0.0 | 0.0 | 1 | 1 | 1 |
| 03/08/2014 22:00 | 0.0 | 11.5 | 2,264.1 | 0.0 | 0.0 | 1 | 1 | 1 |
| 03/08/2014 23:00 | 0.0 | 11.7 | 2,225.8 | 0.0 | 0.0 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.1 | 12.7 | 2,002.4 | 0.1 | 9.5 # | 24 # | 24 # | 24 # |
| **Minimum:** | 0.0 | 11.5 | 1,852.1 | 0.0 | 0.0 | 1 | 1 | 1 |
| **Maximum:** | 0.2 | 13.3 | 2,269.4 | 0.1 | 0.7 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/09/2014 00:00 | 0.1 | 13.0 | 1,824.6 | 0.0 | 0.3 | 1 | 1 | 1 |
| 03/09/2014 01:00 | 0.0 | 13.8 | 1,378.9 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/09/2014 02:00 | 14.6 | 15.4 | 658.8 | 0.0 | 5.3 | 1 | 0 | 0 |
| 03/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/09/2014 15:00 | 26.7 | 17.1 | 537.7 | 0.0 | 38.9 | 1 | 0 | 0 |
| 03/09/2014 16:00 | 7.9 | 14.1 | 1,407.2 | 0.0 | 21.6 | 1 | 0 | 1 |
| 03/09/2014 17:00 | 0.2 | 12.5 | 2,074.9 | 0.0 | 0.7 | 1 | 1 | 1 |
| 03/09/2014 18:00 | 0.1 | 11.7 | 2,217.4 | 0.0 | 0.3 | 1 | 1 | 1 |
| 03/09/2014 19:00 | 0.1 | 11.6 | 2,244.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/09/2014 20:00 | 0.0 | 11.6 | 2,247.3 | 0.1 | 0.0 | 1 | 1 | 1 |
| 03/09/2014 21:00 | 0.0 | 11.6 | 2,247.7 | 0.0 | 0.0 | 1 | 1 | 1 |
| 03/09/2014 22:00 | 0.0 | 13.5 | 1,798.9 | 0.0 | 0.0 | 1 | 1 | 1 |
| 03/09/2014 23:00 | 0.0 | 13.6 | 1,799.0 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Average/Sum#:** | 4.1 | 13.3 | 1,703.0 | 0.0 | 67.4 # | 12 # | 9 # | 8 # |
| **Minimum:** | 0.0 | 11.6 | 537.7 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 26.7 | 17.1 | 2,247.7 | 0.1 | 38.9 | 1 | 1 | 1 |
| **%SI** | 50.0 | 50.0 | 50.0 | 70.8 | 50.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/10/2014 00:00 | 0.0 | 13.6 | 1,800.2 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/10/2014 01:00 | 0.0 | 13.8 | 1,314.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/10/2014 02:00 | 0.0 | 13.8 | 1,240.8 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/10/2014 03:00 | 0.0 | 13.8 | 1,244.4 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/10/2014 04:00 | 0.0 | 13.8 | 1,250.3 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/10/2014 05:00 | 0.0 | 13.8 | 1,529.0 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/10/2014 06:00 | 0.0 | 13.7 | 1,788.7 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/10/2014 07:00 | 0.0 | 13.7 | 1,816.3 | 0.0 | 0.0 | 1 | 1 | 1 |
| 03/10/2014 08:00 | 0.1 | 13.2 | 1,892.3 | 0.0 | 0.3 | 1 | 1 | 1 |
| 03/10/2014 09:00 | 0.2 | 13.1 | 1,904.6 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/10/2014 10:00 | 0.1 | 13.2 | 1,854.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/10/2014 11:00 | 0.1 | 13.3 | 1,859.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/10/2014 12:00 | 0.1 | 13.3 | 1,859.8 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/10/2014 13:00 | 0.1 | 13.2 | 1,862.0 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/10/2014 14:00 | 0.1 | 13.2 | 1,864.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/10/2014 15:00 | 0.1 | 13.3 | 1,867.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/10/2014 16:00 | 0.1 | 13.3 | 1,865.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/10/2014 17:00 | 0.1 | 13.3 | 1,862.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/10/2014 18:00 | 0.1 | 13.3 | 1,871.4 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/10/2014 19:00 | 0.2 | 12.1 | 2,169.1 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/10/2014 20:00 | 0.2 | 12.3 | 2,125.2 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/10/2014 21:00 | 0.1 | 13.4 | 1,740.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/10/2014 22:00 | 0.0 | 13.9 | 1,394.2 | 0.1 | 0.0 | 1 | 1 | 0 |
| 03/10/2014 23:00 | 11.2 | 15.7 | 609.4 | 0.0 | 4.0 | 1 | 0 | 0 |
| **Average/Sum#:** | 0.5 | 13.5 | 1,691.2 | 0.1 | 9.3 # | 24 # | 23 # | 15 # |
| **Minimum:** | 0.0 | 12.1 | 609.4 | 0.0 | 0.0 | 1 | 0 | 0 |
| **Maximum:** | 11.2 | 15.7 | 2,169.1 | 0.1 | 4.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 4.2 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/11/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/11/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/11/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/11/2014 05:00 | 11.1 | 18.0 | 414.7 | 0.0 | 6.7 | 1 | 0 | 0 |
| 03/11/2014 06:00 | 24.0 | 15.3 | 885.5 | 0.0 | 50.1 | 1 | 0 | 0 |
| 03/11/2014 07:00 | 0.0 | 13.7 | 1,769.7 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/11/2014 08:00 | 0.1 | 13.4 | 1,856.8 | 0.0 | 0.3 | 1 | 1 | 1 |
| 03/11/2014 09:00 | 0.1 | 13.2 | 1,859.0 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/11/2014 10:00 | 0.1 | 13.3 | 1,857.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/11/2014 11:00 | 0.2 | 13.3 | 1,854.3 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/11/2014 12:00 | 0.1 | 13.4 | 1,739.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/11/2014 13:00 | 0.0 | 13.9 | 1,335.9 | 0.1 | 0.0 | 1 | 1 | 0 |
| 03/11/2014 14:00 | 0.0 | 13.9 | 1,276.5 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/11/2014 15:00 | 0.0 | 13.9 | 1,303.3 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/11/2014 16:00 | 0.0 | 13.9 | 1,378.4 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/11/2014 17:00 | 0.0 | 13.9 | 1,387.2 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/11/2014 18:00 | 0.1 | 13.6 | 1,569.9 | 0.0 | 0.3 | 1 | 1 | 1 |
| 03/11/2014 19:00 | 0.2 | 12.4 | 2,086.0 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/11/2014 20:00 | 0.2 | 12.1 | 2,179.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/11/2014 21:00 | 0.2 | 12.4 | 2,129.2 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/11/2014 22:00 | 0.2 | 12.1 | 2,197.0 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/11/2014 23:00 | 0.2 | 13.2 | 1,762.9 | 0.1 | 0.6 | 1 | 1 | 1 |
| **Average/Sum#:** | 1.9 | 13.6 | 1,623.3 | 0.1 | 62.2 # | 19 # | 17 # | 11 # |
| **Minimum:** | 0.0 | 12.1 | 414.7 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 24.0 | 18.0 | 2,197.0 | 0.1 | 50.1 | 1 | 1 | 1 |
| **%SI** | 20.8 | 20.8 | 20.8 | 37.5 | 20.8 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/12/2014 00:00 | 0.0 | 13.9 | 1,280.3 | 0.1 | 0.0 | 1 | 1 | 0 |
| 03/12/2014 01:00 | 0.0 | 13.9 | 1,263.7 | 0.1 | 0.0 | 1 | 1 | 0 |
| 03/12/2014 02:00 | 0.0 | 13.9 | 1,242.0 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/12/2014 03:00 | 0.0 | 13.9 | 1,233.2 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/12/2014 04:00 | 0.0 | 13.9 | 1,237.6 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/12/2014 05:00 | 0.2 | 13.4 | 1,731.8 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/12/2014 06:00 | 0.3 | 12.9 | 1,989.9 | 0.1 | 1.0 | 1 | 1 | 1 |
| 03/12/2014 07:00 | 0.2 | 12.1 | 2,199.2 | 0.2 | 0.7 | 1 | 1 | 1 |
| 03/12/2014 08:00 | 0.2 | 12.9 | 2,014.0 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/12/2014 09:00 | 0.1 | 13.3 | 1,866.7 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/12/2014 10:00 | 0.1 | 13.3 | 1,854.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/12/2014 11:00 | 0.1 | 13.3 | 1,854.1 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/12/2014 12:00 | 0.0 | 13.8 | 1,361.4 | 0.1 | 0.0 | 1 | 1 | 1 |
| 03/12/2014 13:00 | 0.0 | 13.9 | 1,378.0 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/12/2014 14:00 | 0.0 | 13.9 | 1,253.4 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/12/2014 15:00 | 0.0 | 13.9 | 1,253.0 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/12/2014 16:00 | 0.0 | 13.9 | 1,252.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/12/2014 17:00 | 0.0 | 13.6 | 1,546.0 | 0.0 | 0.0 | 1 | 1 | 1 |
| 03/12/2014 18:00 | 0.2 | 13.2 | 1,915.5 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/12/2014 19:00 | 0.2 | 12.1 | 2,176.1 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/12/2014 20:00 | 0.2 | 12.0 | 2,202.9 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/12/2014 21:00 | 0.1 | 11.7 | 2,269.6 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/12/2014 22:00 | 0.1 | 11.7 | 2,273.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/12/2014 23:00 | 0.1 | 12.1 | 2,181.9 | 0.1 | 0.3 | 1 | 1 | 1 |
| **Average/Sum#:** | 0.1 | 13.2 | 1,701.3 | 0.1 | 6.9 # | 24 # | 24 # | 15 # |
| **Minimum:** | 0.0 | 11.7 | 1,233.2 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Maximum:** | 0.3 | 13.9 | 2,273.9 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/13/2014 00:00 | 0.0 | 13.6 | 1,675.7 | 0.1 | 0.0 | 1 | 1 | 1 |
| 03/13/2014 01:00 | 0.0 | 13.8 | 1,773.5 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/13/2014 02:00 | 0.0 | 13.9 | 1,392.7 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/13/2014 03:00 | 0.0 | 13.9 | 1,377.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/13/2014 04:00 | 0.0 | 13.9 | 1,379.6 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/13/2014 05:00 | 0.2 | 13.2 | 1,875.1 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/13/2014 06:00 | 0.3 | 12.9 | 1,996.7 | 0.1 | 1.0 | 1 | 1 | 1 |
| 03/13/2014 07:00 | 0.1 | 11.8 | 2,257.9 | 0.2 | 0.3 | 1 | 1 | 1 |
| 03/13/2014 08:00 | 0.2 | 12.2 | 2,169.2 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/13/2014 09:00 | 0.2 | 12.7 | 2,024.3 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/13/2014 10:00 | 0.1 | 13.1 | 1,916.2 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/13/2014 11:00 | 0.1 | 13.4 | 1,856.5 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/13/2014 12:00 | 0.2 | 13.2 | 1,918.8 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/13/2014 13:00 | 0.2 | 13.0 | 1,970.4 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/13/2014 14:00 | 0.2 | 12.9 | 1,972.8 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/13/2014 15:00 | 0.2 | 12.9 | 1,971.5 | 0.1 | 0.7 | 1 | 1 | 1 |
| 03/13/2014 16:00 | 0.2 | 13.1 | 1,918.6 | 0.1 | 0.6 | 1 | 1 | 1 |
| 03/13/2014 17:00 | 0.2 | 13.3 | 1,859.8 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/13/2014 18:00 | 0.2 | 13.2 | 1,882.8 | 0.2 | 0.6 | 1 | 1 | 1 |
| 03/13/2014 19:00 | 0.2 | 13.0 | 1,954.6 | 0.2 | 0.7 | 1 | 1 | 1 |
| 03/13/2014 20:00 | 0.2 | 13.2 | 1,896.5 | 0.2 | 0.7 | 1 | 1 | 1 |
| 03/13/2014 21:00 | 0.1 | 13.3 | 1,771.4 | 0.1 | 0.3 | 1 | 1 | 1 |
| 03/13/2014 22:00 | 0.0 | 13.9 | 1,499.3 | 0.1 | 0.0 | 1 | 1 | 0 |
| 03/13/2014 23:00 | 0.0 | 13.9 | 1,753.4 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Average/Sum#:** | 0.1 | 13.2 | 1,836.0 | 0.1 | 10.2 # | 24 # | 24 # | 18 # |
| **Minimum:** | 0.0 | 11.8 | 1,377.1 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Maximum:** | 0.3 | 13.9 | 2,257.9 | 0.2 | 1.0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/14/2014 00:00 | 0.0 | 13.9 | 1,753.3 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/14/2014 01:00 | 2.4 | 14.4 | 1,429.9 | 0.0 | 5.8 | 1 | 0 | 0 |
| 03/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/14/2014 06:00 | 1.6 | 19.8 | 150.0 | 0.0 | 0.3 | 1 | 0 | 0 |
| 03/14/2014 07:00 | 21.4 | 15.9 | 825.8 | 0.0 | 46.7 | 1 | 0 | 0 |
| 03/14/2014 08:00 | 0.0 | 13.8 | 1,790.3 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/14/2014 09:00 | 0.0 | 13.7 | 1,802.4 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/14/2014 10:00 | 0.0 | 13.7 | 1,795.9 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/14/2014 11:00 | 0.0 | 13.7 | 1,785.4 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/14/2014 12:00 | 0.0 | 13.7 | 1,776.7 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/14/2014 13:00 | 0.0 | 13.7 | 1,767.6 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/14/2014 14:00 | 0.0 | 13.7 | 1,761.3 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/14/2014 15:00 | 0.0 | 13.7 | 1,758.4 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/14/2014 16:00 | 0.0 | 13.7 | 1,748.3 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/14/2014 17:00 | 0.0 | 13.8 | 1,745.2 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/14/2014 18:00 | 0.0 | 13.8 | 1,745.6 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/14/2014 19:00 | 0.0 | 13.7 | 1,759.6 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/14/2014 20:00 | 0.0 | 13.7 | 1,766.4 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/14/2014 21:00 | 0.0 | 13.7 | 1,773.2 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/14/2014 22:00 | 0.0 | 13.7 | 1,781.2 | 0.0 | 0.0 | 1 | 1 | 0 |
| 03/14/2014 23:00 | 0.0 | 13.7 | 1,787.2 | 0.0 | 0.0 | 1 | 1 | 0 |
| **Average/Sum#:** | 1.3 | 14.2 | 1,625.2 | 0.0 | 52.8 # | 20 # | 17 # | 0 # |
| **Minimum:** | 0.0 | 13.7 | 150.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 21.4 | 19.8 | 1,802.4 | 0.0 | 46.7 | 1 | 1 | 0 |
| **%SI** | 16.7 | 16.7 | 16.7 | 37.5 | 16.7 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/15/2014 00:00 | 11.5 | 15.6 | 664.5 | 0.0 | 4.8 | 1 | 0 | 0 |
| 03/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 11.5 | 15.6 | 664.5 | 0.0 | 4.8 # | 1 # | 0 # | 0 # |
| **Minimum:** | 11.5 | 15.6 | 664.5 | 0.0 | 4.8 | 0 | 0 | 0 |
| **Maximum:** | 11.5 | 15.6 | 664.5 | 0.0 | 4.8 | 1 | 0 | 0 |
| **%SI** | 95.8 | 95.8 | 95.8 | 100.0 | 95.8 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/29/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/30/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/30/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# Daily Summary Report
## CT2 - CO

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | > Limit | > Limit | | | |
|---|---|---|---|---|---|---|---|---|
| | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 | Unit CT2 |
| | CO, Ppm | O2, Dry, Pct | HI, MBtuPerHr | CO, _3Hr, Ppmvdc | CO, Lb | UnitOn, TF | NormalOp, TF | DBOn, TF |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 03/31/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 03/31/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 0 | 0 | 0 |

# ATTACHMENT 8
## Hourly Emissions $NH_3$ (AQ-18)

# AQ-18

Pursuant to the CEC conditions of certification, AQ-18 requires that a calculation be developed to determine the ammonia slip emissions, using source test data, based on NOx concentration and Ammonia Injection Rate. AQ-18 reads as follows:

**AQ-18** Ammonia slip shall be limited to 5.0 ppmvd @ 15% $O_2$ over one hour. Formaldehyde emissions will be limited to 0.917 lbs per million standard cubic feet (MMscf) of natural gas. Maximum hourly steady state emission limits for each CTG are:

Pounds $NH_3$ with Duct Firing Pounds: 19.2

$NH_3$ without Duct Firing: 14.2

**Verification:** The project owner shall submit to the CPM and APCO CTG emissions data demonstrating compliance with this condition as part of the Quarterly Operation Reports (AQ-22). The project owner shall provide approval of the CPM and APCO a calculation method to determine the ammonia slip emissions, using source test data, based on the $NO_x$ concentration and the ammonia injection rate; and this calculation shall be revised for approval as necessary after each source test performed under AQ-9.

<u>Calculation</u>

The Calculation used is the standard calculation for determining slip. The constant was updated using 2013 Source Test Data. The correction calculations is attached.

(((NH3Inj_LbPerHr_1H/MoleWtNH3_constant)/(ExhaustFlow_LbPerHr_1H/MoleWtExhaustGas const*1000000)-(NOxInlet_Ppmvdc_1H-NOx_Ppmvdc_1J))*NH3 Correction Constant

Correction Constant

CT1 - .0190

CT2 - .0192

**Ammonia Correction Constant Calculations** Yellow cells are user input values. **Page 1**

Site ID: PG&E Colusa GS

| | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Unit ID: | | 1 | 1 | 1 | 2 | 2 | 2 | 1 | 1 | 1 | 2 | 2 | 2 |
| Load Condition: | | Min Load | Min Load | Min Load | Min Load | Min Load | Min Load | Mid Load | Mid Load | Mid Load | Mid Load | Mid Load | Mid Load |
| Test Date: | | 10/29/2013 | 10/29/2013 | 10/29/2013 | 11/1/2013 | 11/1/2013 | 11/1/2013 | 10/29/2013 | 10/29/2013 | 10/29/2013 | 11/1/2013 | 11/1/2013 | 11/1/2013 |
| Test Duration, minutes: | | 36 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 |
| NH3 Conc, ppm volume dry: | | 1.54 | 1.52 | 1.47 | 0.96 | 0.81 | 0.78 | 1.63 | 1.47 | 1.42 | 1.32 | 1.29 | 1.27 |
| Stack flow rate, dscfm: | | 559798 | 553601 | 551494 | 533159 | 534379 | 532958 | 622349 | 618408 | 618456 | 617746 | 619924 | 620534 |
| NH3 MW: | | 17.01 | 17.01 | 17.01 | 17.01 | 17.01 | 17.01 | 17.01 | 17.01 | 17.01 | 17.01 | 17.01 | 17.01 |
| Agency STP ft^3/lb-mol (see Tab): | | 385.3 | 385.3 | 385.3 | 385.3 | 385.3 | 385.3 | 385.3 | 385.3 | 385.3 | 385.3 | 385.3 | 385.3 |
| NH3 Conc, ppm at 15% O2: | | 1.31 | 1.27 | 1.24 | 0.82 | 0.69 | 0.67 | 1.37 | 1.23 | 1.19 | 1.12 | 1.1 | 1.09 |
| *Calculated NH3 slip, lbs/hr:* | | *2.28* | *2.23* | *2.15* | *1.36* | *1.15* | *1.10* | *2.69* | *2.41* | *2.33* | *2.16* | *2.12* | *2.09* |
| Fuel Flow, scf/hr: | | 1249960 | 1257590 | 1251020 | 1192200 | 1194930 | 1190030 | 1413760 | 1402810 | 1402920 | 1385340 | 1382210 | 1383570 |
| Btu/scf: (avg all tests) | | 1020 | 1020 | 1020 | 1020 | 1020 | 1020 | 1020 | 1020 | 1020 | 1020 | 1020 | 1020 |
| Calculated MMBTU/Hr: | | 1274.96 | 1282.74 | 1276.04 | 1216.04 | 1218.83 | 1213.83 | 1442.04 | 1430.87 | 1430.98 | 1413.05 | 1409.85 | 1411.24 |
| Calculated MMSCF/Hr: | | 1.23 | 1.23 | 1.23 | 1.17 | 1.17 | 1.17 | 1.39 | 1.38 | 1.38 | 1.36 | 1.36 | 1.36 |
| | | | | | | | | | | | | | |
| NH3 Injection Rate, lbs/hr: | | 98.6 | 101.8 | 102.8 | 77.5 | 79.5 | 80.4 | 102.2 | 101.7 | 102.2 | 84.8 | 84.2 | 84.2 |
| Stack Temp, deg F: | | 196 | 196 | 196 | 196 | 196 | 196 | 196 | 196 | 196 | 196 | 196 | 196 |
| Approx Exhaust Density, lb/ft3: (see Tab): | | 0.062 | 0.062 | 0.062 | 0.062 | 0.062 | 0.062 | 0.062 | 0.062 | 0.062 | 0.062 | 0.062 | 0.062 |
| Exhaust flow rate dry, lbs/hr: | | 2082448.6 | 2059395.7 | 2051557.7 | 1983351.5 | 1987889.9 | 1982603.8 | 2315138.3 | 2300477.8 | 2300656.3 | 2298015.1 | 2306117.3 | 2308386.5 |
| Inlet Nox, ppm at 15% O2: | | 9.6 | 9.5 | 9.5 | 8.4 | 8.4 | 8.3 | 8.8 | 8.7 | 8.7 | 7.1 | 7.4 | 8.7 |
| Outlet Nox, ppm at 15% O2: | | 1.1 | 1.1 | 1.1 | 0.8 | 0.8 | 0.7 | 1.1 | 1.1 | 1.1 | 0.6 | 0.7 | 1.1 |
| calc 1 | a = (NH3 Inj/NH3 MW) | 5.80 | 5.98 | 6.04 | 4.56 | 4.67 | 4.72 | 6.01 | 5.98 | 6.01 | 4.98 | 4.95 | 4.95 |
| calc 2 | b = (Exhaust Flow Rate/29) | 71808.57 | 71013.65 | 70743.37 | 68391.43 | 68547.93 | 68365.65 | 79832.35 | 79326.82 | 79332.98 | 79241.90 | 79521.29 | 79599.53 |
| calc 3 | c = (Nox Inlet - Nox Outlet)\ | 8.54 | 8.47 | 8.43 | 7.56 | 7.63 | 7.59 | 7.70 | 7.65 | 7.66 | 6.47 | 6.68 | 7.66 |
| Calculated NH3 slip, ppm @ 15% O2: | (((a/b)*1000000)-c) | 72.17 | 75.76 | 77.02 | 59.09 | 60.51 | 61.51 | 67.54 | 67.75 | 68.06 | 56.43 | 55.56 | 54.49 |
| | | | | | | | | | | | | | |
| Correction Constant, d: | NH3 Conc/Calculated NH3 | 0.0182 | 0.0168 | 0.0161 | 0.0139 | 0.0114 | 0.0109 | 0.0203 | 0.0182 | 0.0175 | 0.0198 | 0.0198 | 0.0200 |

**Avg Correction Constant:**

| | |
|---|---|
| Unit 1-Min | **0.0170** |
| Unit 1-Mid | **0.0186** |
| Unit 1-Base | **0.0245** |
| Unit 1-Max | **0.0159** |
| Unit 2-Min | **0.0121** |
| Unit 2-Mid | **0.0199** |
| Unit 2-Base | **0.0311** |
| Unit 2-Max | **0.0138** |

**Correction Constants (all loads-tested)**

| | |
|---|---|
| Unit 1 | **0.0190** |
| Unit 2 | **0.0192** |

The equations for all values in **RED** must be revised each year depending upon the number of loads tested and number of tests per load.

1/27/2014 16:18

| | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | 1 | 1 | 2 | 2 | 2 | 1 | 1 | 1 | 2 | 2 | 2 |
| Base wo DB | Base wo DB | Base wo DB | Base wo DB | Base wo DB | Base wo DB | Max w DB | Max w DB | Max w DB | Max w DB | Max w DB | Max w DB |
| 10/29/2013 | 10/29/2013 | 10/29/2013 | 11/1/2013 | 11/1/2013 | 11/12013 | 10/30/2013 | 10/30/2013 | 10/30/2013 | 11/1/2013 | 11/1/2013 | 11/1/2013 |
| 32 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 |
| 2.05 | 1.98 | 2 | 2.57 | 2.18 | 1.77 | 2.39 | 2.91 | 3.2 | 1.88 | 1.88 | 1.9 |
| 779044 | 755972 | 752689 | 759979 | 758400 | 756272 | 730310 | 724782 | 721431 | 753523 | 753227 | 756446 |
| 17.01 | 17.01 | 17.01 | 17.01 | 17.01 | 17.01 | 17.01 | 17.01 | 17.01 | 17.01 | 17.01 | 17.01 |
| 385.3 | 385.3 | 385.3 | 385.3 | 385.3 | 385.3 | 385.3 | 385.3 | 385.3 | 385.3 | 385.3 | 385.3 |
| 1.72 | 1.62 | 1.64 | 2.12 | 1.8 | 1.46 | 1.52 | 1.85 | 2.04 | 1.24 | 1.24 | 1.26 |
| *4.23* | *3.96* | *3.99* | *5.17* | *4.38* | *3.55* | *4.62* | *5.59* | *6.12* | *3.75* | *3.75* | *3.81* |
| 1767200 | 1763720 | 1756060 | 1760790 | 1757130 | 1752200 | 2182910 | 2171070 | 2158700 | 2176810 | 2178390 | 2170590 |
| 1020 | 1020 | 1020 | 1020 | 1020 | 1020 | 1020 | 1020 | 1020 | 1020 | 1020 | 1020 |
| 1802.54 | 1798.99 | 1791.18 | 1796.01 | 1792.27 | 1787.24 | 2226.57 | 2214.49 | 2201.87 | 2220.35 | 2221.96 | 2214.00 |
| 1.73 | 1.73 | 1.72 | 1.73 | 1.72 | 1.72 | 2.14 | 2.13 | 2.12 | 2.13 | 2.14 | 2.13 |
| | | | | | | | | | | | |
| 124.6 | 124.4 | 123.9 | 106.9 | 105.9 | 105.6 | 189.0 | 188.6 | 193.5 | 164.6 | 162.8 | 155.7 |
| 196 | 196 | 196 | 196 | 196 | 196 | 170 | 170 | 170 | 170 | 170 | 170 |
| 0.062 | 0.062 | 0.062 | 0.062 | 0.062 | 0.062 | 0.062 | 0.062 | 0.062 | 0.062 | 0.062 | 0.062 |
| 2898043.7 | 2812215.8 | 2800003.1 | 2827121.9 | 2821248.0 | 2813331.8 | 2716753.2 | 2696189.0 | 2683723.3 | 2803105.6 | 2802004.4 | 2813979.1 |
| 8.0 | 7.9 | 7.9 | 7.4 | 7.4 | 7.4 | 8.1 | 8.1 | 8.2 | 8.3 | 8.3 | 8.1 |
| 1.1 | 1.1 | 1.1 | 0.9 | 0.9 | 1.0 | 1.0 | 1.0 | 1.0 | 1.1 | 1.1 | 1.1 |
| 7.33 | 7.32 | 7.29 | 6.28 | 6.23 | 6.21 | 11.11 | 11.09 | 11.38 | 9.68 | 9.57 | 9.15 |
| 99932.54 | 96972.96 | 96551.83 | 97486.96 | 97284.41 | 97011.44 | 93681.14 | 92972.04 | 92542.18 | 96658.81 | 96620.84 | 97033.76 |
| 6.91 | 6.84 | 6.81 | 6.50 | 6.47 | 6.38 | 7.08 | 7.05 | 7.18 | 7.16 | 7.17 | 6.99 |
| 66.40 | 68.60 | 68.64 | 57.94 | 57.54 | 57.59 | 111.56 | 112.22 | 115.76 | 92.95 | 91.90 | 87.33 |
| | | | | | | | | | | | |
| 0.0259 | 0.0236 | 0.0239 | 0.0366 | 0.0313 | 0.0254 | 0.0136 | 0.0165 | 0.0176 | 0.0133 | 0.0135 | 0.0144 |

Reference: all input data derived from "Colusa Generating Station-2012 Source Test Report, December 10, 2012", Avogadro.
Supplemental data derived from CEMS data for the specified test dates and times for each unit tested.

# Excess Emission Report

## CT1 - NH3 Ppmvdc 1-Hour Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT1_NH3Slip_Ppmvdc_1H
**Total Operating Time:** 1,178.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 982.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,178.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT1 - NH3 LbPerHr 1-Hour Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT1_NH3slip_LbPerHr_1H
**Total Operating Time:** 1,178.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 982.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,178.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT2 - NH3 Ppmvdc 1-Hour Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT2_NH3Slip_Ppmvdc_1H
**Total Operating Time:** 1,193.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 967.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,193.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT2 - NH3 LbPerHr 1-Hour Block Average

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** CT2_NH3slip_LbPerHr_1H
**Total Operating Time:** 1,193.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 967.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,193.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/01/2014 00:00 | 10.3 | 13.8 | 8.6 | 115.3 | 3,181,955.4 | 1,626.5 | 1.0 | 0.7 |
| 01/01/2014 01:00 | 10.2 | 13.7 | 8.4 | 124.3 | 3,498,782.9 | 1,814.0 | 1.0 | 0.7 |
| 01/01/2014 02:00 | 10.1 | 13.7 | 8.3 | 118.1 | 3,262,123.2 | 1,691.3 | 1.0 | 0.7 |
| 01/01/2014 03:00 | 20.8 | 14.8 | 20.1 | 161.0 | 2,429,403.0 | 1,099.9 | 1.8 | 0.8 |
| 01/01/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 16:00 | 45.3 | 17.3 | 74.2 | 0.0 | 2,009,831.7 | 499.0 | 0.0 | 0.0 |
| 01/01/2014 17:00 | 51.5 | 14.8 | 49.8 | 243.4 | 2,407,219.8 | 1,054.7 | 2.7 | 1.1 |
| 01/01/2014 18:00 | 10.4 | 13.6 | 8.4 | 126.2 | 3,362,887.9 | 1,768.1 | 1.1 | 0.7 |
| 01/01/2014 19:00 | 10.7 | 13.4 | 8.4 | 135.8 | 3,427,903.0 | 2,052.6 | 1.1 | 0.8 |
| 01/01/2014 20:00 | 10.9 | 13.3 | 8.5 | 144.1 | 3,355,562.0 | 2,131.8 | 1.2 | 1.1 |
| 01/01/2014 21:00 | 10.9 | 13.3 | 8.5 | 145.0 | 3,389,246.6 | 2,153.2 | 1.2 | 1.1 |
| 01/01/2014 22:00 | 10.7 | 13.4 | 8.4 | 137.4 | 3,404,752.0 | 2,063.6 | 1.2 | 1.0 |
| 01/01/2014 23:00 | 10.7 | 13.3 | 8.3 | 137.1 | 3,409,701.7 | 2,066.6 | 1.2 | 1.0 |
| **Average/Sum#:** | 17.7 | 14.0 | 18.3 | 132.3 | 3,094,947.4 | 1,668.4 | 1.2 | 0.8 |
| **Minimum:** | 10.1 | 13.3 | 8.3 | 0.0 | 2,009,831.7 | 499.0 | 0.0 | 0.0 |
| **Maximum:** | 51.5 | 17.3 | 74.2 | 243.4 | 3,498,782.9 | 2,153.2 | 2.7 | 1.1 |
| **%SI** | 50.0 | 50.0 | 50.0 | 50.0 | 50.0 | 50.0 | 50.0 | 50.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/02/2014 00:00 | 10.6 | 13.4 | 8.3 | 135.2 | 3,412,872.8 | 2,043.6 | 1.1 | 0.8 |
| 01/02/2014 01:00 | 10.1 | 13.7 | 8.3 | 121.6 | 3,402,834.5 | 1,838.8 | 1.0 | 0.7 |
| 01/02/2014 02:00 | 10.1 | 13.7 | 8.3 | 112.4 | 3,061,531.4 | 1,587.3 | 1.0 | 0.6 |
| 01/02/2014 03:00 | 10.1 | 13.7 | 8.3 | 119.2 | 3,303,591.7 | 1,712.8 | 1.0 | 0.7 |
| 01/02/2014 04:00 | 10.1 | 13.7 | 8.3 | 113.1 | 3,070,596.6 | 1,592.0 | 1.0 | 0.6 |
| 01/02/2014 05:00 | 10.2 | 13.6 | 8.2 | 120.0 | 3,332,142.6 | 1,800.6 | 1.0 | 0.7 |
| 01/02/2014 06:00 | 10.4 | 13.5 | 8.3 | 128.5 | 3,433,615.0 | 1,980.8 | 1.1 | 0.8 |
| 01/02/2014 07:00 | 10.4 | 13.5 | 8.3 | 131.4 | 3,420,787.4 | 1,973.4 | 1.1 | 0.8 |
| 01/02/2014 08:00 | 10.5 | 13.4 | 8.3 | 132.0 | 3,438,453.4 | 2,008.7 | 1.1 | 0.8 |
| 01/02/2014 09:00 | 10.5 | 13.4 | 8.3 | 132.5 | 3,458,310.1 | 2,020.3 | 1.1 | 0.8 |
| 01/02/2014 10:00 | 10.5 | 13.4 | 8.3 | 132.5 | 3,445,814.1 | 2,013.0 | 1.1 | 0.8 |
| 01/02/2014 11:00 | 10.7 | 13.4 | 8.4 | 132.8 | 3,401,751.6 | 2,012.1 | 1.1 | 0.8 |
| 01/02/2014 12:00 | 10.8 | 13.4 | 8.5 | 132.1 | 3,382,985.4 | 2,001.0 | 1.1 | 0.8 |
| 01/02/2014 13:00 | 10.8 | 13.4 | 8.5 | 131.7 | 3,366,078.9 | 1,991.0 | 1.1 | 0.8 |
| 01/02/2014 14:00 | 10.9 | 13.5 | 8.7 | 128.7 | 3,391,492.2 | 1,956.5 | 1.1 | 0.8 |
| 01/02/2014 15:00 | 10.9 | 13.4 | 8.6 | 131.4 | 3,363,543.0 | 1,989.5 | 1.1 | 0.8 |
| 01/02/2014 16:00 | 11.0 | 13.4 | 8.7 | 133.3 | 3,351,415.7 | 2,006.8 | 1.1 | 0.8 |
| 01/02/2014 17:00 | 10.9 | 13.4 | 8.6 | 134.6 | 3,326,546.3 | 2,016.2 | 1.2 | 1.0 |
| 01/02/2014 18:00 | 11.0 | 13.3 | 8.5 | 142.7 | 3,327,543.8 | 2,114.0 | 1.2 | 1.1 |
| 01/02/2014 19:00 | 11.1 | 13.3 | 8.6 | 147.2 | 3,325,833.9 | 2,137.2 | 1.3 | 1.1 |
| 01/02/2014 20:00 | 11.0 | 13.3 | 8.5 | 143.5 | 3,332,266.0 | 2,117.0 | 1.3 | 1.1 |
| 01/02/2014 21:00 | 10.9 | 13.3 | 8.5 | 142.4 | 3,354,134.3 | 2,106.4 | 1.2 | 1.1 |
| 01/02/2014 22:00 | 10.6 | 13.4 | 8.3 | 136.6 | 3,391,882.7 | 2,055.8 | 1.2 | 1.0 |
| 01/02/2014 23:00 | 10.8 | 13.3 | 8.4 | 142.8 | 3,370,854.0 | 2,116.9 | 1.2 | 1.1 |
| **Average/Sum#:** | 10.6 | 13.5 | 8.4 | 131.6 | 3,352,786.6 | 1,966.3 | 1.1 | 0.9 |
| **Minimum:** | 10.1 | 13.3 | 8.2 | 112.4 | 3,061,531.4 | 1,587.3 | 1.0 | 0.6 |
| **Maximum:** | 11.1 | 13.7 | 8.7 | 147.2 | 3,458,310.1 | 2,137.2 | 1.3 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/03/2014 00:00 | 10.6 | 13.4 | 8.3 | 132.1 | 3,394,989.0 | 2,008.1 | 1.1 | 0.8 |
| 01/03/2014 01:00 | 10.0 | 13.7 | 8.2 | 117.3 | 3,277,614.1 | 1,747.2 | 1.0 | 0.7 |
| 01/03/2014 02:00 | 10.5 | 13.8 | 8.7 | 95.8 | 2,579,604.3 | 1,318.6 | 1.0 | 0.5 |
| 01/03/2014 03:00 | 10.7 | 13.9 | 9.0 | 93.6 | 2,432,489.0 | 1,243.4 | 1.1 | 0.5 |
| 01/03/2014 04:00 | 10.6 | 13.9 | 8.9 | 93.4 | 2,433,662.8 | 1,244.0 | 1.1 | 0.5 |
| 01/03/2014 05:00 | 10.7 | 13.9 | 9.0 | 93.4 | 2,438,749.2 | 1,246.6 | 1.1 | 0.5 |
| 01/03/2014 06:00 | 10.5 | 13.7 | 8.6 | 107.1 | 2,905,618.4 | 1,548.9 | 1.0 | 0.6 |
| 01/03/2014 07:00 | 10.3 | 13.5 | 8.2 | 121.2 | 3,373,585.9 | 1,896.9 | 1.0 | 0.8 |
| 01/03/2014 08:00 | 10.3 | 13.4 | 8.1 | 127.5 | 3,475,528.9 | 1,979.6 | 1.1 | 0.8 |
| 01/03/2014 09:00 | 10.4 | 13.4 | 8.2 | 131.3 | 3,470,634.9 | 2,027.5 | 1.1 | 0.8 |
| 01/03/2014 10:00 | 10.5 | 13.4 | 8.3 | 133.7 | 3,427,111.3 | 2,027.1 | 1.1 | 0.8 |
| 01/03/2014 11:00 | 10.6 | 13.4 | 8.3 | 133.4 | 3,408,683.3 | 2,016.2 | 1.1 | 0.8 |
| 01/03/2014 12:00 | 10.6 | 13.4 | 8.3 | 130.7 | 3,403,533.1 | 1,988.3 | 1.1 | 0.8 |
| 01/03/2014 13:00 | 10.7 | 13.4 | 8.4 | 130.1 | 3,381,964.7 | 1,975.7 | 1.1 | 0.8 |
| 01/03/2014 14:00 | 10.8 | 13.4 | 8.5 | 129.4 | 3,405,186.4 | 1,964.4 | 1.1 | 0.8 |
| 01/03/2014 15:00 | 10.6 | 13.5 | 8.5 | 125.9 | 3,396,523.6 | 1,934.6 | 1.1 | 0.8 |
| 01/03/2014 16:00 | 10.9 | 13.4 | 8.6 | 130.9 | 3,397,884.3 | 1,985.0 | 1.1 | 0.8 |
| 01/03/2014 17:00 | 11.0 | 13.4 | 8.7 | 137.3 | 3,338,461.0 | 2,047.8 | 1.2 | 1.0 |
| 01/03/2014 18:00 | 11.0 | 13.3 | 8.5 | 145.4 | 3,354,932.3 | 2,131.4 | 1.3 | 1.1 |
| 01/03/2014 19:00 | 10.9 | 13.3 | 8.5 | 142.7 | 3,325,949.7 | 2,088.7 | 1.2 | 1.0 |
| 01/03/2014 20:00 | 10.9 | 13.3 | 8.5 | 140.7 | 3,364,111.8 | 2,088.1 | 1.2 | 1.0 |
| 01/03/2014 21:00 | 11.3 | 13.2 | 8.7 | 159.7 | 3,303,736.3 | 2,219.5 | 1.4 | 1.1 |
| 01/03/2014 22:00 | 11.2 | 13.3 | 8.7 | 152.9 | 3,319,332.5 | 2,181.5 | 1.3 | 1.1 |
| 01/03/2014 23:00 | 11.0 | 13.3 | 8.5 | 145.5 | 3,361,543.3 | 2,135.6 | 1.3 | 1.1 |
| **Average/Sum#:** | 10.7 | 13.5 | 8.5 | 127.1 | 3,207,142.9 | 1,876.9 | 1.1 | 0.8 |
| **Minimum:** | 10.0 | 13.2 | 8.1 | 93.4 | 2,432,489.0 | 1,243.4 | 1.0 | 0.5 |
| **Maximum:** | 11.3 | 13.9 | 9.0 | 159.7 | 3,475,528.9 | 2,219.5 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/04/2014 00:00 | 10.6 | 13.4 | 8.3 | 135.3 | 3,413,373.8 | 2,043.9 | 1.1 | 0.8 |
| 01/04/2014 01:00 | 10.6 | 13.4 | 8.3 | 138.4 | 3,407,886.8 | 2,065.5 | 1.2 | 1.0 |
| 01/04/2014 02:00 | 10.1 | 13.8 | 8.4 | 114.8 | 3,131,545.7 | 1,623.6 | 1.0 | 0.6 |
| 01/04/2014 03:00 | 10.2 | 13.8 | 8.5 | 112.3 | 3,078,311.7 | 1,596.0 | 1.0 | 0.6 |
| 01/04/2014 04:00 | 9.7 | 13.8 | 8.1 | 99.3 | 2,785,996.1 | 1,424.1 | 1.0 | 0.6 |
| 01/04/2014 05:00 | 10.2 | 13.7 | 8.4 | 114.9 | 3,190,565.9 | 1,654.2 | 1.0 | 0.7 |
| 01/04/2014 06:00 | 10.1 | 13.7 | 8.3 | 116.4 | 3,226,055.2 | 1,672.6 | 1.0 | 0.7 |
| 01/04/2014 07:00 | 10.1 | 13.6 | 8.2 | 126.5 | 3,472,251.6 | 1,825.6 | 1.0 | 0.7 |
| 01/04/2014 08:00 | 10.3 | 13.5 | 8.2 | 128.0 | 3,387,991.5 | 1,905.0 | 1.1 | 0.8 |
| 01/04/2014 09:00 | 10.9 | 13.3 | 8.5 | 141.5 | 3,388,922.6 | 2,103.5 | 1.2 | 1.1 |
| 01/04/2014 10:00 | 10.9 | 13.4 | 8.6 | 136.1 | 3,395,838.5 | 2,033.4 | 1.2 | 1.0 |
| 01/04/2014 11:00 | 10.9 | 13.5 | 8.7 | 130.9 | 3,377,000.5 | 1,972.8 | 1.1 | 0.8 |
| 01/04/2014 12:00 | 10.6 | 13.6 | 8.6 | 124.0 | 3,426,984.5 | 1,901.9 | 1.0 | 0.8 |
| 01/04/2014 13:00 | 10.0 | 13.8 | 8.3 | 120.8 | 3,435,774.7 | 1,856.6 | 1.0 | 0.7 |
| 01/04/2014 14:00 | 11.1 | 13.5 | 8.9 | 131.1 | 3,425,294.4 | 1,976.0 | 1.1 | 0.8 |
| 01/04/2014 15:00 | 11.4 | 13.5 | 9.1 | 134.9 | 3,368,617.0 | 2,017.1 | 1.1 | 0.8 |
| 01/04/2014 16:00 | 11.5 | 13.4 | 9.0 | 138.0 | 3,364,494.2 | 2,039.2 | 1.2 | 1.0 |
| 01/04/2014 17:00 | 11.5 | 13.4 | 9.0 | 141.6 | 3,393,075.0 | 2,081.3 | 1.2 | 1.0 |
| 01/04/2014 18:00 | 11.6 | 13.3 | 9.0 | 151.0 | 3,363,274.8 | 2,136.7 | 1.3 | 1.1 |
| 01/04/2014 19:00 | 11.6 | 13.3 | 9.0 | 153.7 | 3,366,895.1 | 2,139.0 | 1.3 | 1.1 |
| 01/04/2014 20:00 | 11.3 | 13.4 | 8.9 | 136.7 | 3,418,383.9 | 2,046.9 | 1.1 | 0.8 |
| 01/04/2014 21:00 | 11.8 | 13.2 | 9.0 | 161.8 | 3,345,808.1 | 2,198.9 | 1.4 | 1.1 |
| 01/04/2014 22:00 | 11.9 | 13.2 | 9.1 | 168.6 | 3,337,482.9 | 2,217.8 | 1.5 | 1.3 |
| 01/04/2014 23:00 | 11.3 | 13.4 | 8.9 | 139.2 | 3,372,083.8 | 2,043.8 | 1.2 | 1.0 |
| **Average/Sum#:** | 10.8 | 13.5 | 8.6 | 133.2 | 3,328,079.5 | 1,940.6 | 1.1 | 0.9 |
| **Minimum:** | 9.7 | 13.2 | 8.1 | 99.3 | 2,785,996.1 | 1,424.1 | 1.0 | 0.6 |
| **Maximum:** | 11.9 | 13.8 | 9.1 | 168.6 | 3,472,251.6 | 2,217.8 | 1.5 | 1.3 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/05/2014 00:00 | 11.2 | 13.4 | 8.8 | 135.7 | 3,426,773.2 | 2,026.9 | 1.1 | 0.8 |
| 01/05/2014 01:00 | 11.3 | 13.4 | 8.9 | 140.0 | 3,369,436.1 | 2,066.8 | 1.2 | 1.0 |
| 01/05/2014 02:00 | 10.6 | 13.8 | 8.8 | 115.2 | 3,117,079.9 | 1,616.1 | 1.0 | 0.6 |
| 01/05/2014 03:00 | 10.5 | 13.8 | 8.7 | 113.2 | 3,123,852.7 | 1,596.8 | 1.0 | 0.6 |
| 01/05/2014 04:00 | 10.5 | 13.8 | 8.7 | 118.7 | 3,325,549.3 | 1,699.9 | 1.0 | 0.7 |
| 01/05/2014 05:00 | 10.5 | 13.7 | 8.6 | 126.0 | 3,524,242.6 | 1,827.2 | 1.0 | 0.7 |
| 01/05/2014 06:00 | 10.7 | 13.6 | 8.6 | 128.8 | 3,413,110.1 | 1,894.2 | 1.1 | 0.8 |
| 01/05/2014 07:00 | 11.1 | 13.4 | 8.7 | 140.4 | 3,366,689.6 | 2,089.7 | 1.2 | 1.0 |
| 01/05/2014 08:00 | 11.6 | 13.2 | 8.9 | 166.4 | 3,366,978.2 | 2,237.4 | 1.5 | 1.3 |
| 01/05/2014 09:00 | 11.5 | 13.3 | 8.9 | 158.2 | 3,372,784.6 | 2,192.0 | 1.4 | 1.1 |
| 01/05/2014 10:00 | 11.2 | 13.4 | 8.8 | 138.9 | 3,392,047.7 | 2,055.9 | 1.2 | 1.0 |
| 01/05/2014 11:00 | 11.1 | 13.5 | 8.9 | 131.9 | 3,392,235.4 | 1,981.7 | 1.1 | 0.8 |
| 01/05/2014 12:00 | 10.5 | 13.6 | 8.5 | 123.7 | 3,434,552.4 | 1,906.1 | 1.0 | 0.8 |
| 01/05/2014 13:00 | 11.0 | 13.5 | 8.8 | 126.5 | 3,454,328.5 | 1,942.3 | 1.0 | 0.8 |
| 01/05/2014 14:00 | 11.3 | 13.5 | 9.0 | 133.5 | 3,392,284.0 | 2,006.5 | 1.1 | 0.8 |
| 01/05/2014 15:00 | 10.5 | 13.8 | 8.7 | 115.6 | 3,195,454.0 | 1,633.4 | 1.0 | 0.7 |
| 01/05/2014 16:00 | 11.2 | 13.6 | 9.1 | 127.9 | 3,343,351.8 | 1,879.9 | 1.1 | 0.8 |
| 01/05/2014 17:00 | 11.8 | 13.3 | 9.2 | 160.8 | 3,339,856.8 | 2,170.6 | 1.4 | 1.1 |
| 01/05/2014 18:00 | 11.9 | 13.3 | 9.2 | 170.0 | 3,330,711.0 | 2,213.3 | 1.5 | 1.3 |
| 01/05/2014 19:00 | 11.8 | 13.3 | 9.2 | 170.9 | 3,331,764.4 | 2,214.0 | 1.5 | 1.3 |
| 01/05/2014 20:00 | 11.7 | 13.2 | 9.0 | 170.6 | 3,311,030.0 | 2,224.4 | 1.5 | 1.3 |
| 01/05/2014 21:00 | 11.6 | 13.2 | 8.9 | 166.6 | 3,337,031.4 | 2,217.5 | 1.5 | 1.3 |
| 01/05/2014 22:00 | 11.5 | 13.2 | 8.8 | 164.0 | 3,352,381.0 | 2,227.7 | 1.4 | 1.1 |
| 01/05/2014 23:00 | 11.2 | 13.3 | 8.7 | 152.3 | 3,379,365.9 | 2,171.6 | 1.3 | 1.1 |
| **Average/Sum#:** | 11.2 | 13.5 | 8.9 | 141.5 | 3,349,703.8 | 2,003.8 | 1.2 | 1.0 |
| **Minimum:** | 10.5 | 13.2 | 8.5 | 113.2 | 3,117,079.9 | 1,596.8 | 1.0 | 0.6 |
| **Maximum:** | 11.9 | 13.8 | 9.2 | 170.9 | 3,524,242.6 | 2,237.4 | 1.5 | 1.3 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/06/2014 00:00 | 11.2 | 13.3 | 8.7 | 151.0 | 3,403,885.3 | 2,162.5 | 1.3 | 1.1 |
| 01/06/2014 01:00 | 11.0 | 13.4 | 8.7 | 140.5 | 3,404,649.9 | 2,088.4 | 1.2 | 1.0 |
| 01/06/2014 02:00 | 11.1 | 13.3 | 8.6 | 147.8 | 3,383,274.4 | 2,124.7 | 1.3 | 1.1 |
| 01/06/2014 03:00 | 10.7 | 13.4 | 8.4 | 132.7 | 3,439,651.7 | 2,009.4 | 1.1 | 0.8 |
| 01/06/2014 04:00 | 10.7 | 13.4 | 8.4 | 130.9 | 3,465,857.1 | 1,999.4 | 1.1 | 0.8 |
| 01/06/2014 05:00 | 11.1 | 13.3 | 8.6 | 148.3 | 3,396,015.1 | 2,157.5 | 1.3 | 1.1 |
| 01/06/2014 06:00 | 10.9 | 13.4 | 8.6 | 138.1 | 3,404,422.0 | 2,063.4 | 1.2 | 1.0 |
| 01/06/2014 07:00 | 10.9 | 13.4 | 8.6 | 133.7 | 3,395,003.5 | 2,032.9 | 1.1 | 0.8 |
| 01/06/2014 08:00 | 11.2 | 13.3 | 8.7 | 146.4 | 3,419,898.5 | 2,147.7 | 1.2 | 1.1 |
| 01/06/2014 09:00 | 10.7 | 13.3 | 8.3 | 140.1 | 3,449,808.3 | 2,116.1 | 1.2 | 1.1 |
| 01/06/2014 10:00 | 10.9 | 13.3 | 8.5 | 144.6 | 3,421,968.6 | 2,149.0 | 1.2 | 1.1 |
| 01/06/2014 11:00 | 11.2 | 13.3 | 8.7 | 151.6 | 3,372,630.7 | 2,191.9 | 1.3 | 1.1 |
| 01/06/2014 12:00 | 11.2 | 13.3 | 8.7 | 155.2 | 3,389,094.5 | 2,202.6 | 1.3 | 1.1 |
| 01/06/2014 13:00 | 11.4 | 13.3 | 8.9 | 160.8 | 3,370,457.7 | 2,215.1 | 1.4 | 1.1 |
| 01/06/2014 14:00 | 11.1 | 13.3 | 8.6 | 145.6 | 3,373,401.8 | 2,118.5 | 1.3 | 1.1 |
| 01/06/2014 15:00 | 10.9 | 13.4 | 8.6 | 132.0 | 3,427,155.7 | 2,002.1 | 1.1 | 0.8 |
| 01/06/2014 16:00 | 10.9 | 13.4 | 8.6 | 133.2 | 3,407,499.8 | 2,015.5 | 1.1 | 0.8 |
| 01/06/2014 17:00 | 10.9 | 13.4 | 8.6 | 138.9 | 3,419,766.2 | 2,072.7 | 1.2 | 1.0 |
| 01/06/2014 18:00 | 10.9 | 13.4 | 8.6 | 139.6 | 3,406,443.2 | 2,089.5 | 1.2 | 1.0 |
| 01/06/2014 19:00 | 11.2 | 13.2 | 8.6 | 156.7 | 3,377,304.8 | 2,219.6 | 1.4 | 1.1 |
| 01/06/2014 20:00 | 11.0 | 13.3 | 8.5 | 143.6 | 3,393,594.7 | 2,106.4 | 1.2 | 1.1 |
| 01/06/2014 21:00 | 11.2 | 13.2 | 8.6 | 159.9 | 3,402,867.4 | 2,236.4 | 1.4 | 1.1 |
| 01/06/2014 22:00 | 11.3 | 13.2 | 8.7 | 163.0 | 3,380,973.4 | 2,246.7 | 1.4 | 1.1 |
| 01/06/2014 23:00 | 10.9 | 13.3 | 8.5 | 144.6 | 3,395,205.8 | 2,107.4 | 1.2 | 1.1 |
| **Average/Sum#:** | 11.0 | 13.3 | 8.6 | 145.0 | 3,404,201.3 | 2,119.8 | 1.2 | 1.0 |
| **Minimum:** | 10.7 | 13.2 | 8.3 | 130.9 | 3,370,457.7 | 1,999.4 | 1.1 | 0.8 |
| **Maximum:** | 11.4 | 13.4 | 8.9 | 163.0 | 3,465,857.1 | 2,246.7 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/07/2014 00:00 | 10.5 | 13.5 | 8.4 | 128.7 | 3,435,148.4 | 1,956.6 | 1.1 | 0.8 |
| 01/07/2014 01:00 | 10.4 | 13.7 | 8.5 | 118.0 | 3,188,385.1 | 1,746.2 | 1.1 | 0.7 |
| 01/07/2014 02:00 | 10.2 | 13.8 | 8.5 | 105.5 | 2,910,418.1 | 1,487.7 | 1.0 | 0.6 |
| 01/07/2014 03:00 | 10.4 | 13.7 | 8.5 | 113.1 | 3,070,789.5 | 1,592.1 | 1.0 | 0.6 |
| 01/07/2014 04:00 | 10.4 | 13.8 | 8.6 | 111.8 | 3,089,225.8 | 1,579.1 | 1.0 | 0.6 |
| 01/07/2014 05:00 | 10.4 | 13.8 | 8.6 | 113.0 | 3,121,700.7 | 1,595.7 | 1.0 | 0.6 |
| 01/07/2014 06:00 | 10.4 | 13.6 | 8.4 | 121.4 | 3,309,195.5 | 1,788.2 | 1.0 | 0.7 |
| 01/07/2014 07:00 | 10.5 | 13.5 | 8.4 | 132.2 | 3,420,993.3 | 1,998.5 | 1.1 | 0.8 |
| 01/07/2014 08:00 | 10.8 | 13.3 | 8.4 | 144.3 | 3,445,794.0 | 2,138.8 | 1.2 | 1.1 |
| 01/07/2014 09:00 | 10.8 | 13.3 | 8.4 | 143.6 | 3,431,294.2 | 2,129.8 | 1.2 | 1.1 |
| 01/07/2014 10:00 | 10.7 | 13.4 | 8.4 | 137.6 | 3,449,112.4 | 2,065.3 | 1.2 | 1.0 |
| 01/07/2014 11:00 | 10.7 | 13.4 | 8.4 | 135.6 | 3,448,751.6 | 2,039.9 | 1.1 | 0.8 |
| 01/07/2014 12:00 | 11.1 | 13.2 | 8.5 | 154.0 | 3,406,020.0 | 2,213.6 | 1.3 | 1.1 |
| 01/07/2014 13:00 | 11.2 | 13.3 | 8.7 | 156.4 | 3,359,350.2 | 2,207.8 | 1.4 | 1.1 |
| 01/07/2014 14:00 | 10.8 | 13.4 | 8.5 | 139.1 | 3,400,462.2 | 2,061.0 | 1.2 | 1.0 |
| 01/07/2014 15:00 | 10.9 | 13.4 | 8.6 | 139.4 | 3,381,337.0 | 2,074.1 | 1.2 | 1.0 |
| 01/07/2014 16:00 | 10.7 | 13.5 | 8.5 | 130.6 | 3,433,961.7 | 1,981.0 | 1.1 | 0.8 |
| 01/07/2014 17:00 | 10.7 | 13.5 | 8.5 | 130.5 | 3,436,735.2 | 1,982.6 | 1.1 | 0.8 |
| 01/07/2014 18:00 | 10.7 | 13.4 | 8.4 | 135.0 | 3,399,178.5 | 2,035.4 | 1.1 | 0.8 |
| 01/07/2014 19:00 | 11.0 | 13.3 | 8.5 | 149.2 | 3,380,299.6 | 2,172.2 | 1.3 | 1.1 |
| 01/07/2014 20:00 | 11.1 | 13.2 | 8.5 | 157.6 | 3,342,298.4 | 2,221.0 | 1.4 | 1.1 |
| 01/07/2014 21:00 | 10.7 | 13.4 | 8.4 | 137.5 | 3,400,957.2 | 2,061.3 | 1.2 | 1.0 |
| 01/07/2014 22:00 | 10.6 | 13.4 | 8.3 | 134.2 | 3,442,834.3 | 2,036.4 | 1.1 | 0.8 |
| 01/07/2014 23:00 | 10.4 | 13.6 | 8.4 | 126.2 | 3,335,348.7 | 1,875.4 | 1.1 | 0.8 |
| **Average/Sum#:** | 10.7 | 13.5 | 8.5 | 133.1 | 3,334,983.0 | 1,960.0 | 1.1 | 0.9 |
| **Minimum:** | 10.2 | 13.2 | 8.3 | 105.5 | 2,910,418.1 | 1,487.7 | 1.0 | 0.6 |
| **Maximum:** | 11.2 | 13.8 | 8.7 | 157.6 | 3,449,112.4 | 2,221.0 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/08/2014 00:00 | 10.6 | 13.8 | 8.8 | 99.2 | 2,660,987.2 | 1,360.2 | 1.1 | 0.5 |
| 01/08/2014 01:00 | 10.8 | 13.8 | 9.0 | 97.5 | 2,563,562.4 | 1,310.4 | 1.1 | 0.5 |
| 01/08/2014 02:00 | 10.8 | 13.8 | 9.0 | 96.3 | 2,512,502.5 | 1,284.3 | 1.1 | 0.5 |
| 01/08/2014 03:00 | 10.8 | 13.8 | 9.0 | 96.2 | 2,465,159.5 | 1,260.1 | 1.1 | 0.5 |
| 01/08/2014 04:00 | 10.9 | 13.8 | 9.1 | 96.6 | 2,529,913.7 | 1,293.2 | 1.1 | 0.5 |
| 01/08/2014 05:00 | 10.3 | 13.7 | 8.4 | 112.8 | 3,148,518.8 | 1,632.4 | 1.0 | 0.7 |
| 01/08/2014 06:00 | 10.2 | 13.6 | 8.2 | 115.5 | 3,190,571.2 | 1,700.8 | 1.0 | 0.7 |
| 01/08/2014 07:00 | 10.2 | 13.6 | 8.2 | 120.5 | 3,458,156.9 | 1,919.2 | 1.0 | 0.8 |
| 01/08/2014 08:00 | 10.4 | 13.4 | 8.2 | 129.0 | 3,456,843.2 | 1,994.2 | 1.1 | 0.8 |
| 01/08/2014 09:00 | 10.0 | 13.7 | 8.2 | 119.8 | 3,305,190.2 | 1,761.9 | 1.0 | 0.7 |
| 01/08/2014 10:00 | 10.7 | 13.9 | 9.0 | 98.4 | 2,420,946.7 | 1,237.5 | 1.2 | 0.6 |
| 01/08/2014 11:00 | 10.6 | 13.8 | 8.8 | 103.6 | 2,696,787.9 | 1,378.5 | 1.1 | 0.6 |
| 01/08/2014 12:00 | 10.3 | 13.7 | 8.4 | 120.8 | 3,240,210.3 | 1,703.6 | 1.1 | 0.7 |
| 01/08/2014 13:00 | 10.1 | 13.8 | 8.4 | 105.2 | 2,895,941.3 | 1,480.3 | 1.0 | 0.6 |
| 01/08/2014 14:00 | 10.7 | 13.8 | 8.9 | 97.5 | 2,454,008.5 | 1,254.4 | 1.1 | 0.5 |
| 01/08/2014 15:00 | 10.5 | 13.8 | 8.7 | 101.5 | 2,740,022.6 | 1,400.6 | 1.0 | 0.6 |
| 01/08/2014 16:00 | 10.3 | 13.8 | 8.6 | 108.0 | 2,984,953.9 | 1,525.8 | 1.0 | 0.6 |
| 01/08/2014 17:00 | 10.4 | 13.6 | 8.4 | 122.6 | 3,299,399.8 | 1,807.0 | 1.1 | 0.7 |
| 01/08/2014 18:00 | 9.7 | 13.8 | 8.1 | 100.9 | 2,801,646.7 | 1,432.1 | 1.0 | 0.6 |
| 01/08/2014 19:00 | 9.9 | 13.7 | 8.1 | 106.8 | 2,951,206.0 | 1,530.1 | 1.0 | 0.6 |
| 01/08/2014 20:00 | 9.7 | 13.8 | 8.1 | 103.8 | 2,906,114.2 | 1,485.5 | 1.0 | 0.6 |
| 01/08/2014 21:00 | 9.8 | 13.8 | 8.1 | 103.7 | 2,911,983.1 | 1,488.5 | 1.0 | 0.6 |
| 01/08/2014 22:00 | 29.1 | 15.6 | 32.4 | 202.0 | 1,808,387.1 | 726.3 | 3.1 | 0.9 |
| 01/08/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 11.2 | 13.8 | 9.6 | 111.2 | 2,843,609.3 | 1,476.8 | 1.1 | 0.6 |
| **Minimum:** | 9.7 | 13.4 | 8.1 | 96.2 | 1,808,387.1 | 726.3 | 1.0 | 0.5 |
| **Maximum:** | 29.1 | 15.6 | 32.4 | 202.0 | 3,458,156.9 | 1,994.2 | 3.1 | 0.9 |
| **%SI** | 4.2 | 4.2 | 4.2 | 4.2 | 4.2 | 4.2 | 4.2 | 4.2 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/09/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/10/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/12/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/13/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/14/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/15/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 14:00 | 44.3 | 17.2 | 70.6 | 0.0 | 2,070,178.4 | 529.1 | 0.0 | 0.0 |
| 01/29/2014 15:00 | 62.5 | 15.7 | 70.9 | 233.1 | 2,043,127.5 | 760.9 | 2.9 | 0.8 |
| 01/29/2014 16:00 | 9.8 | 13.8 | 8.1 | 131.1 | 2,589,581.5 | 1,323.7 | 1.5 | 0.8 |
| 01/29/2014 17:00 | 9.7 | 13.7 | 7.9 | 105.7 | 2,973,772.6 | 1,541.8 | 1.0 | 0.6 |
| 01/29/2014 18:00 | 9.7 | 13.6 | 7.8 | 123.9 | 3,460,459.3 | 1,819.4 | 1.0 | 0.7 |
| 01/29/2014 19:00 | 9.8 | 13.6 | 7.9 | 123.5 | 3,460,269.1 | 1,819.3 | 1.0 | 0.7 |
| 01/29/2014 20:00 | 9.7 | 13.7 | 7.9 | 119.4 | 3,379,970.8 | 1,752.4 | 1.0 | 0.7 |
| 01/29/2014 21:00 | 9.3 | 13.7 | 7.6 | 120.6 | 3,484,317.1 | 1,806.5 | 1.0 | 0.7 |
| 01/29/2014 22:00 | 9.6 | 13.7 | 7.9 | 116.5 | 3,216,411.4 | 1,667.6 | 1.0 | 0.7 |
| 01/29/2014 23:00 | 10.2 | 13.8 | 8.5 | 96.1 | 2,527,370.5 | 1,291.9 | 1.1 | 0.5 |
| **Average/Sum#:** | 18.5 | 14.3 | 20.5 | 117.0 | 2,920,545.8 | 1,431.3 | 1.2 | 0.6 |
| **Minimum:** | 9.3 | 13.6 | 7.6 | 0.0 | 2,043,127.5 | 529.1 | 0.0 | 0.0 |
| **Maximum:** | 62.5 | 17.2 | 70.9 | 233.1 | 3,484,317.1 | 1,819.4 | 2.9 | 0.8 |
| **%SI** | 58.3 | 58.3 | 58.3 | 58.3 | 58.3 | 58.3 | 58.3 | 58.3 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/30/2014 00:00 | 10.0 | 13.8 | 8.3 | 108.0 | 2,863,662.0 | 1,463.8 | 1.1 | 0.6 |
| 01/30/2014 01:00 | 10.0 | 13.6 | 8.1 | 114.9 | 3,380,935.2 | 1,752.9 | 1.0 | 0.7 |
| 01/30/2014 02:00 | 10.2 | 13.8 | 8.5 | 96.0 | 2,597,211.2 | 1,327.6 | 1.0 | 0.5 |
| 01/30/2014 03:00 | 10.5 | 13.8 | 8.7 | 95.8 | 2,459,290.6 | 1,257.1 | 1.1 | 0.5 |
| 01/30/2014 04:00 | 10.6 | 13.8 | 8.8 | 95.8 | 2,508,785.5 | 1,282.4 | 1.1 | 0.5 |
| 01/30/2014 05:00 | 10.5 | 13.9 | 8.9 | 95.4 | 2,488,780.0 | 1,254.0 | 1.1 | 0.5 |
| 01/30/2014 06:00 | 10.3 | 13.8 | 8.6 | 104.4 | 2,832,556.5 | 1,447.9 | 1.0 | 0.6 |
| 01/30/2014 07:00 | 10.1 | 13.8 | 8.4 | 111.7 | 3,061,953.5 | 1,542.8 | 1.0 | 0.6 |
| 01/30/2014 08:00 | 10.1 | 13.8 | 8.4 | 112.9 | 3,039,339.6 | 1,553.6 | 1.1 | 0.6 |
| 01/30/2014 09:00 | 10.4 | 13.9 | 8.8 | 95.6 | 2,466,154.7 | 1,242.6 | 1.1 | 0.5 |
| 01/30/2014 10:00 | 10.4 | 13.7 | 8.5 | 107.0 | 2,924,010.4 | 1,516.0 | 1.0 | 0.6 |
| 01/30/2014 11:00 | 10.2 | 13.6 | 8.2 | 124.2 | 3,481,038.2 | 1,804.8 | 1.0 | 0.7 |
| 01/30/2014 12:00 | 10.6 | 13.5 | 8.5 | 128.0 | 3,391,192.7 | 1,906.8 | 1.1 | 0.8 |
| 01/30/2014 13:00 | 11.1 | 13.3 | 8.6 | 140.4 | 3,327,379.0 | 2,065.3 | 1.2 | 1.0 |
| 01/30/2014 14:00 | 11.3 | 13.3 | 8.8 | 152.3 | 3,337,087.2 | 2,168.8 | 1.3 | 1.1 |
| 01/30/2014 15:00 | 11.5 | 13.2 | 8.8 | 165.5 | 3,311,298.3 | 2,200.4 | 1.5 | 1.3 |
| 01/30/2014 16:00 | 10.8 | 13.5 | 8.6 | 134.1 | 3,219,687.9 | 1,880.9 | 1.2 | 0.9 |
| 01/30/2014 17:00 | 10.3 | 13.8 | 8.6 | 110.9 | 3,073,379.6 | 1,571.0 | 1.0 | 0.6 |
| 01/30/2014 18:00 | 10.3 | 13.8 | 8.6 | 114.7 | 3,212,278.3 | 1,642.0 | 1.0 | 0.7 |
| 01/30/2014 19:00 | 10.8 | 13.5 | 8.6 | 129.5 | 3,372,646.5 | 1,921.0 | 1.1 | 0.8 |
| 01/30/2014 20:00 | 10.9 | 13.4 | 8.6 | 138.1 | 3,335,037.5 | 2,045.7 | 1.2 | 1.0 |
| 01/30/2014 21:00 | 10.9 | 13.4 | 8.6 | 136.5 | 3,344,695.3 | 2,027.2 | 1.2 | 1.0 |
| 01/30/2014 22:00 | 10.6 | 13.5 | 8.5 | 129.7 | 3,377,971.3 | 1,948.7 | 1.1 | 0.8 |
| 01/30/2014 23:00 | 10.5 | 13.6 | 8.5 | 127.5 | 3,355,454.9 | 1,837.7 | 1.1 | 0.7 |
| **Average/Sum#:** | 10.5 | 13.6 | 8.6 | 119.5 | 3,073,409.4 | 1,694.2 | 1.1 | 0.7 |
| **Minimum:** | 10.0 | 13.2 | 8.1 | 95.4 | 2,459,290.6 | 1,242.6 | 1.0 | 0.5 |
| **Maximum:** | 11.5 | 13.9 | 8.9 | 165.5 | 3,481,038.2 | 2,200.4 | 1.5 | 1.3 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/31/2014 00:00 | 10.4 | 13.8 | 8.6 | 110.5 | 2,998,452.5 | 1,532.7 | 1.0 | 0.6 |
| 01/31/2014 01:00 | 10.2 | 13.8 | 8.5 | 104.6 | 2,913,548.2 | 1,489.3 | 1.0 | 0.6 |
| 01/31/2014 02:00 | 10.4 | 13.8 | 8.6 | 114.9 | 3,169,434.9 | 1,620.1 | 1.0 | 0.6 |
| 01/31/2014 03:00 | 10.7 | 13.9 | 9.0 | 103.5 | 2,791,641.1 | 1,406.6 | 1.0 | 0.6 |
| 01/31/2014 04:00 | 10.9 | 13.9 | 9.2 | 98.6 | 2,628,699.4 | 1,324.5 | 1.1 | 0.5 |
| 01/31/2014 05:00 | 10.5 | 13.7 | 8.6 | 121.9 | 3,381,706.7 | 1,753.3 | 1.0 | 0.7 |
| 01/31/2014 06:00 | 10.1 | 13.7 | 8.3 | 125.6 | 3,443,341.5 | 1,810.4 | 1.0 | 0.7 |
| 01/31/2014 07:00 | 10.1 | 13.7 | 8.3 | 122.8 | 3,516,141.8 | 1,823.0 | 1.0 | 0.7 |
| 01/31/2014 08:00 | 10.0 | 13.7 | 8.2 | 126.3 | 3,527,328.6 | 1,828.8 | 1.0 | 0.7 |
| 01/31/2014 09:00 | 9.9 | 13.8 | 8.2 | 124.5 | 3,521,181.4 | 1,799.9 | 1.0 | 0.7 |
| 01/31/2014 10:00 | 10.1 | 13.7 | 8.3 | 124.3 | 3,497,818.5 | 1,813.5 | 1.0 | 0.7 |
| 01/31/2014 11:00 | 10.4 | 13.6 | 8.4 | 124.5 | 3,467,565.1 | 1,899.1 | 1.0 | 0.8 |
| 01/31/2014 12:00 | 10.8 | 13.5 | 8.6 | 130.2 | 3,420,787.4 | 1,973.4 | 1.1 | 0.8 |
| 01/31/2014 13:00 | 10.9 | 13.5 | 8.7 | 131.1 | 3,426,854.5 | 1,976.9 | 1.1 | 0.8 |
| 01/31/2014 14:00 | 10.6 | 13.5 | 8.5 | 125.7 | 3,423,916.7 | 1,925.2 | 1.0 | 0.8 |
| 01/31/2014 15:00 | 10.3 | 13.6 | 8.3 | 123.3 | 3,481,076.8 | 1,906.5 | 1.0 | 0.8 |
| 01/31/2014 16:00 | 10.5 | 13.7 | 8.6 | 122.8 | 3,476,694.6 | 1,904.1 | 1.0 | 0.8 |
| 01/31/2014 17:00 | 10.0 | 13.6 | 8.1 | 122.7 | 3,465,905.0 | 1,923.5 | 1.0 | 0.8 |
| 01/31/2014 18:00 | 10.1 | 13.7 | 8.3 | 123.2 | 3,469,391.0 | 1,900.1 | 1.0 | 0.8 |
| 01/31/2014 19:00 | 11.0 | 13.4 | 8.7 | 137.3 | 3,431,243.1 | 2,054.6 | 1.1 | 0.8 |
| 01/31/2014 20:00 | 10.9 | 13.4 | 8.6 | 132.8 | 3,416,371.5 | 1,995.8 | 1.1 | 0.8 |
| 01/31/2014 21:00 | 11.0 | 13.4 | 8.7 | 136.6 | 3,415,377.8 | 2,045.1 | 1.1 | 0.8 |
| 01/31/2014 22:00 | 11.1 | 13.3 | 8.6 | 143.8 | 3,405,839.0 | 2,114.0 | 1.2 | 1.1 |
| 01/31/2014 23:00 | 11.0 | 13.3 | 8.5 | 142.9 | 3,414,431.5 | 2,094.4 | 1.2 | 1.0 |
| **Average/Sum#:** | 10.5 | 13.6 | 8.5 | 123.9 | 3,337,697.9 | 1,829.8 | 1.0 | 0.8 |
| **Minimum:** | 9.9 | 13.3 | 8.1 | 98.6 | 2,628,699.4 | 1,324.5 | 1.0 | 0.5 |
| **Maximum:** | 11.1 | 13.9 | 9.2 | 143.8 | 3,527,328.6 | 2,114.0 | 1.2 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/01/2014 00:00 | 10.3 | 13.7 | 8.4 | 120.8 | 3,257,404.1 | 1,784.0 | 1.1 | 0.7 |
| 02/01/2014 01:00 | 10.3 | 13.8 | 8.6 | 114.5 | 3,171,586.9 | 1,621.2 | 1.0 | 0.6 |
| 02/01/2014 02:00 | 10.3 | 13.8 | 8.6 | 116.4 | 3,234,384.8 | 1,653.3 | 1.0 | 0.7 |
| 02/01/2014 03:00 | 10.3 | 13.7 | 8.4 | 124.9 | 3,433,783.4 | 1,780.3 | 1.0 | 0.7 |
| 02/01/2014 04:00 | 9.9 | 13.8 | 8.2 | 103.2 | 2,861,314.4 | 1,462.6 | 1.0 | 0.6 |
| 02/01/2014 05:00 | 10.5 | 13.5 | 8.4 | 126.6 | 3,343,918.1 | 1,855.8 | 1.1 | 0.7 |
| 02/01/2014 06:00 | 11.2 | 13.2 | 8.6 | 152.0 | 3,400,634.6 | 2,210.1 | 1.3 | 1.1 |
| 02/01/2014 07:00 | 11.1 | 13.2 | 8.5 | 150.0 | 3,400,942.4 | 2,210.3 | 1.3 | 1.1 |
| 02/01/2014 08:00 | 10.8 | 13.3 | 8.4 | 145.6 | 3,435,344.4 | 2,157.4 | 1.2 | 1.1 |
| 02/01/2014 09:00 | 10.7 | 13.4 | 8.4 | 140.1 | 3,461,838.8 | 2,098.2 | 1.2 | 1.0 |
| 02/01/2014 10:00 | 10.3 | 13.6 | 8.3 | 126.6 | 3,386,179.4 | 1,829.8 | 1.1 | 0.7 |
| 02/01/2014 11:00 | 10.3 | 13.8 | 8.6 | 111.7 | 3,055,381.4 | 1,561.8 | 1.0 | 0.6 |
| 02/01/2014 12:00 | 10.3 | 13.8 | 8.6 | 108.4 | 3,010,777.3 | 1,539.0 | 1.0 | 0.6 |
| 02/01/2014 13:00 | 10.6 | 13.8 | 8.8 | 112.6 | 3,107,028.3 | 1,588.2 | 1.0 | 0.6 |
| 02/01/2014 14:00 | 10.5 | 13.9 | 8.9 | 104.0 | 2,861,104.6 | 1,441.6 | 1.0 | 0.6 |
| 02/01/2014 15:00 | 11.0 | 13.9 | 9.3 | 96.6 | 2,492,947.8 | 1,256.1 | 1.1 | 0.5 |
| 02/01/2014 16:00 | 10.7 | 13.9 | 9.0 | 97.6 | 2,592,578.4 | 1,306.3 | 1.1 | 0.5 |
| 02/01/2014 17:00 | 10.7 | 13.7 | 8.8 | 116.3 | 3,159,430.9 | 1,684.2 | 1.0 | 0.7 |
| 02/01/2014 18:00 | 11.0 | 13.4 | 8.7 | 132.3 | 3,413,119.1 | 1,993.9 | 1.1 | 0.8 |
| 02/01/2014 19:00 | 11.3 | 13.2 | 8.7 | 152.8 | 3,358,167.1 | 2,182.5 | 1.3 | 1.1 |
| 02/01/2014 20:00 | 11.4 | 13.2 | 8.7 | 159.1 | 3,358,250.0 | 2,231.6 | 1.4 | 1.1 |
| 02/01/2014 21:00 | 11.1 | 13.2 | 8.5 | 157.7 | 3,360,958.7 | 2,233.4 | 1.4 | 1.1 |
| 02/01/2014 22:00 | 11.0 | 13.2 | 8.4 | 153.9 | 3,392,368.5 | 2,229.5 | 1.3 | 1.1 |
| 02/01/2014 23:00 | 10.8 | 13.2 | 8.3 | 149.7 | 3,441,612.5 | 2,211.6 | 1.3 | 1.1 |
| **Average/Sum#:** | 10.7 | 13.6 | 8.6 | 128.1 | 3,207,960.7 | 1,838.4 | 1.1 | 0.8 |
| **Minimum:** | 9.9 | 13.2 | 8.2 | 96.6 | 2,492,947.8 | 1,256.1 | 1.0 | 0.5 |
| **Maximum:** | 11.4 | 13.9 | 9.3 | 159.1 | 3,461,838.8 | 2,233.4 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/02/2014 00:00 | 10.8 | 13.3 | 8.4 | 144.8 | 3,419,261.6 | 2,147.3 | 1.2 | 1.1 |
| 02/02/2014 01:00 | 10.5 | 13.4 | 8.3 | 135.4 | 3,457,295.6 | 2,070.2 | 1.1 | 0.8 |
| 02/02/2014 02:00 | 10.4 | 13.4 | 8.2 | 134.5 | 3,448,277.4 | 2,064.8 | 1.1 | 0.8 |
| 02/02/2014 03:00 | 10.5 | 13.4 | 8.3 | 135.2 | 3,466,981.7 | 2,076.0 | 1.1 | 0.8 |
| 02/02/2014 04:00 | 10.4 | 13.4 | 8.2 | 130.2 | 3,517,340.5 | 2,029.1 | 1.1 | 0.8 |
| 02/02/2014 05:00 | 10.3 | 13.4 | 8.1 | 130.2 | 3,516,993.8 | 2,028.9 | 1.1 | 0.8 |
| 02/02/2014 06:00 | 10.4 | 13.4 | 8.2 | 131.2 | 3,499,906.4 | 2,044.6 | 1.1 | 0.8 |
| 02/02/2014 07:00 | 10.7 | 13.3 | 8.3 | 144.7 | 3,412,823.4 | 2,193.1 | 1.2 | 1.1 |
| 02/02/2014 08:00 | 10.8 | 13.2 | 8.3 | 150.1 | 3,442,332.8 | 2,237.2 | 1.3 | 1.1 |
| 02/02/2014 09:00 | 10.9 | 13.2 | 8.4 | 150.6 | 3,441,255.8 | 2,236.5 | 1.3 | 1.1 |
| 02/02/2014 10:00 | 10.9 | 13.2 | 8.4 | 151.6 | 3,392,368.5 | 2,229.5 | 1.3 | 1.1 |
| 02/02/2014 11:00 | 10.9 | 13.2 | 8.4 | 152.9 | 3,391,455.6 | 2,228.9 | 1.3 | 1.1 |
| 02/02/2014 12:00 | 11.0 | 13.2 | 8.4 | 152.5 | 3,372,892.3 | 2,216.7 | 1.3 | 1.1 |
| 02/02/2014 13:00 | 11.1 | 13.2 | 8.5 | 151.6 | 3,378,169.9 | 2,195.5 | 1.3 | 1.1 |
| 02/02/2014 14:00 | 10.7 | 13.4 | 8.4 | 138.4 | 3,400,957.2 | 2,061.3 | 1.2 | 1.0 |
| 02/02/2014 15:00 | 11.1 | 13.2 | 8.5 | 152.4 | 3,359,198.0 | 2,207.7 | 1.3 | 1.1 |
| 02/02/2014 16:00 | 11.1 | 13.2 | 8.5 | 155.7 | 3,372,245.2 | 2,240.9 | 1.4 | 1.1 |
| 02/02/2014 17:00 | 10.7 | 13.3 | 8.3 | 144.2 | 3,385,981.4 | 2,126.4 | 1.2 | 1.1 |
| 02/02/2014 18:00 | 10.1 | 13.5 | 8.1 | 126.6 | 3,426,545.6 | 1,951.7 | 1.1 | 0.8 |
| 02/02/2014 19:00 | 10.6 | 13.3 | 8.2 | 140.3 | 3,419,811.3 | 2,097.7 | 1.2 | 1.0 |
| 02/02/2014 20:00 | 11.0 | 13.2 | 8.4 | 151.4 | 3,357,067.8 | 2,206.3 | 1.3 | 1.1 |
| 02/02/2014 21:00 | 11.0 | 13.2 | 8.4 | 154.5 | 3,361,410.2 | 2,233.7 | 1.3 | 1.1 |
| 02/02/2014 22:00 | 10.8 | 13.3 | 8.4 | 146.7 | 3,376,654.2 | 2,145.2 | 1.3 | 1.1 |
| 02/02/2014 23:00 | 11.0 | 13.2 | 8.4 | 151.6 | 3,370,001.3 | 2,214.8 | 1.3 | 1.1 |
| **Average/Sum#:** | 10.7 | 13.3 | 8.3 | 144.1 | 3,416,134.5 | 2,145.2 | 1.2 | 1.0 |
| **Minimum:** | 10.1 | 13.2 | 8.1 | 126.6 | 3,357,067.8 | 1,951.7 | 1.1 | 0.8 |
| **Maximum:** | 11.1 | 13.5 | 8.5 | 155.7 | 3,517,340.5 | 2,240.9 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report
## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/03/2014 00:00 | 10.9 | 13.2 | 8.4 | 150.3 | 3,370,014.9 | 2,190.2 | 1.3 | 1.1 |
| 02/03/2014 01:00 | 10.6 | 13.3 | 8.2 | 139.0 | 3,386,553.9 | 2,077.3 | 1.2 | 1.0 |
| 02/03/2014 02:00 | 10.5 | 13.4 | 8.3 | 130.5 | 3,447,135.9 | 1,988.6 | 1.1 | 0.8 |
| 02/03/2014 03:00 | 10.3 | 13.5 | 8.2 | 128.5 | 3,436,904.1 | 1,957.6 | 1.1 | 0.8 |
| 02/03/2014 04:00 | 10.2 | 13.5 | 8.1 | 127.8 | 3,513,978.1 | 2,001.5 | 1.0 | 0.8 |
| 02/03/2014 05:00 | 10.4 | 13.3 | 8.1 | 136.5 | 3,461,673.9 | 2,098.1 | 1.1 | 0.8 |
| 02/03/2014 06:00 | 10.3 | 13.4 | 8.1 | 132.4 | 3,440,467.4 | 2,035.0 | 1.1 | 0.8 |
| 02/03/2014 07:00 | 10.4 | 13.4 | 8.2 | 131.2 | 3,418,383.9 | 2,046.9 | 1.1 | 0.8 |
| 02/03/2014 08:00 | 10.8 | 13.2 | 8.3 | 147.8 | 3,425,428.4 | 2,201.2 | 1.3 | 1.1 |
| 02/03/2014 09:00 | 10.7 | 13.3 | 8.3 | 144.5 | 3,432,796.6 | 2,155.8 | 1.2 | 1.1 |
| 02/03/2014 10:00 | 10.5 | 13.4 | 8.3 | 135.6 | 3,441,764.3 | 2,060.9 | 1.1 | 0.8 |
| 02/03/2014 11:00 | 10.1 | 13.6 | 8.2 | 123.9 | 3,391,848.0 | 1,882.4 | 1.0 | 0.8 |
| 02/03/2014 12:00 | 10.3 | 13.6 | 8.3 | 124.3 | 3,404,887.0 | 1,914.5 | 1.0 | 0.8 |
| 02/03/2014 13:00 | 10.4 | 13.4 | 8.2 | 128.8 | 3,414,547.0 | 1,969.8 | 1.1 | 0.8 |
| 02/03/2014 14:00 | 10.6 | 13.4 | 8.3 | 130.1 | 3,444,882.4 | 1,987.3 | 1.1 | 0.8 |
| 02/03/2014 15:00 | 10.5 | 13.5 | 8.4 | 126.6 | 3,413,378.1 | 1,944.2 | 1.1 | 0.8 |
| 02/03/2014 16:00 | 10.7 | 13.5 | 8.5 | 129.5 | 3,416,107.1 | 1,970.7 | 1.1 | 0.8 |
| 02/03/2014 17:00 | 10.8 | 13.4 | 8.5 | 137.8 | 3,394,522.6 | 2,057.4 | 1.2 | 1.0 |
| 02/03/2014 18:00 | 11.2 | 13.3 | 8.7 | 156.9 | 3,352,959.5 | 2,203.6 | 1.4 | 1.1 |
| 02/03/2014 19:00 | 11.2 | 13.2 | 8.6 | 162.2 | 3,336,632.3 | 2,241.6 | 1.4 | 1.1 |
| 02/03/2014 20:00 | 11.3 | 13.2 | 8.7 | 161.7 | 3,334,697.2 | 2,240.3 | 1.4 | 1.1 |
| 02/03/2014 21:00 | 11.3 | 13.2 | 8.7 | 159.8 | 3,349,521.8 | 2,225.8 | 1.4 | 1.1 |
| 02/03/2014 22:00 | 11.2 | 13.2 | 8.6 | 153.6 | 3,372,476.8 | 2,191.8 | 1.3 | 1.1 |
| 02/03/2014 23:00 | 10.9 | 13.3 | 8.5 | 142.8 | 3,385,056.0 | 2,101.1 | 1.2 | 1.1 |
| **Average/Sum#:** | 10.7 | 13.4 | 8.4 | 139.3 | 3,407,775.7 | 2,072.7 | 1.2 | 0.9 |
| **Minimum:** | 10.1 | 13.2 | 8.1 | 123.9 | 3,334,697.2 | 1,882.4 | 1.0 | 0.8 |
| **Maximum:** | 11.3 | 13.6 | 8.7 | 162.2 | 3,513,978.1 | 2,241.6 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/04/2014 00:00 | 10.4 | 13.4 | 8.2 | 133.8 | 3,487,974.6 | 2,063.1 | 1.1 | 0.8 |
| 02/04/2014 01:00 | 10.3 | 13.4 | 8.1 | 128.7 | 3,480,938.1 | 2,008.1 | 1.1 | 0.8 |
| 02/04/2014 02:00 | 10.2 | 13.6 | 8.2 | 124.2 | 3,411,467.3 | 1,918.2 | 1.0 | 0.8 |
| 02/04/2014 03:00 | 10.2 | 13.6 | 8.2 | 129.3 | 3,477,448.7 | 1,955.3 | 1.1 | 0.8 |
| 02/04/2014 04:00 | 10.1 | 13.6 | 8.2 | 125.0 | 3,339,413.4 | 1,853.3 | 1.1 | 0.7 |
| 02/04/2014 05:00 | 10.4 | 13.6 | 8.4 | 120.1 | 3,238,244.0 | 1,820.8 | 1.1 | 0.7 |
| 02/04/2014 06:00 | 10.4 | 13.5 | 8.3 | 130.3 | 3,438,642.0 | 1,983.7 | 1.1 | 0.8 |
| 02/04/2014 07:00 | 10.3 | 13.4 | 8.1 | 136.2 | 3,494,805.7 | 2,016.1 | 1.1 | 0.8 |
| 02/04/2014 08:00 | 10.3 | 13.4 | 8.1 | 130.3 | 3,501,046.1 | 2,019.7 | 1.1 | 0.8 |
| 02/04/2014 09:00 | 10.1 | 13.6 | 8.2 | 126.1 | 3,485,274.0 | 1,959.7 | 1.0 | 0.8 |
| 02/04/2014 10:00 | 10.4 | 13.4 | 8.2 | 128.6 | 3,508,008.8 | 1,998.1 | 1.0 | 0.8 |
| 02/04/2014 11:00 | 10.6 | 13.4 | 8.3 | 131.1 | 3,472,097.5 | 2,003.0 | 1.1 | 0.8 |
| 02/04/2014 12:00 | 10.6 | 13.5 | 8.5 | 128.5 | 3,446,735.8 | 1,963.2 | 1.1 | 0.8 |
| 02/04/2014 13:00 | 10.3 | 13.6 | 8.3 | 123.9 | 3,425,723.2 | 1,901.2 | 1.0 | 0.8 |
| 02/04/2014 14:00 | 10.8 | 13.4 | 8.5 | 131.8 | 3,429,894.5 | 2,003.7 | 1.1 | 0.8 |
| 02/04/2014 15:00 | 10.9 | 13.4 | 8.6 | 136.6 | 3,421,890.9 | 2,049.0 | 1.1 | 0.8 |
| 02/04/2014 16:00 | 10.9 | 13.4 | 8.6 | 133.3 | 3,399,215.6 | 2,010.6 | 1.1 | 0.8 |
| 02/04/2014 17:00 | 10.8 | 13.4 | 8.5 | 133.3 | 3,450,093.6 | 2,015.5 | 1.1 | 0.8 |
| 02/04/2014 18:00 | 10.9 | 13.3 | 8.5 | 141.0 | 3,420,137.4 | 2,097.9 | 1.2 | 1.0 |
| 02/04/2014 19:00 | 11.1 | 13.3 | 8.6 | 151.0 | 3,375,246.4 | 2,193.6 | 1.3 | 1.1 |
| 02/04/2014 20:00 | 11.0 | 13.3 | 8.5 | 147.8 | 3,364,893.6 | 2,162.3 | 1.3 | 1.1 |
| 02/04/2014 21:00 | 11.1 | 13.2 | 8.5 | 155.7 | 3,350,725.6 | 2,226.6 | 1.4 | 1.1 |
| 02/04/2014 22:00 | 11.0 | 13.2 | 8.4 | 153.0 | 3,382,324.4 | 2,198.2 | 1.3 | 1.1 |
| 02/04/2014 23:00 | 10.6 | 13.4 | 8.3 | 138.6 | 3,424,550.9 | 2,075.6 | 1.2 | 1.0 |
| **Average/Sum#:** | 10.6 | 13.4 | 8.3 | 134.1 | 3,426,116.3 | 2,020.7 | 1.1 | 0.9 |
| **Minimum:** | 10.1 | 13.2 | 8.1 | 120.1 | 3,238,244.0 | 1,820.8 | 1.0 | 0.7 |
| **Maximum:** | 11.1 | 13.6 | 8.6 | 155.7 | 3,508,008.8 | 2,226.6 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/05/2014 00:00 | 10.5 | 13.4 | 8.3 | 133.2 | 3,420,855.9 | 2,023.4 | 1.1 | 0.8 |
| 02/05/2014 01:00 | 10.1 | 13.6 | 8.2 | 121.6 | 3,350,224.7 | 1,859.3 | 1.0 | 0.7 |
| 02/05/2014 02:00 | 10.3 | 13.6 | 8.3 | 120.0 | 3,298,150.5 | 1,830.4 | 1.0 | 0.7 |
| 02/05/2014 03:00 | 10.4 | 13.6 | 8.4 | 120.3 | 3,313,286.3 | 1,838.8 | 1.0 | 0.7 |
| 02/05/2014 04:00 | 10.4 | 13.6 | 8.4 | 120.4 | 3,318,331.5 | 1,841.6 | 1.0 | 0.7 |
| 02/05/2014 05:00 | 10.3 | 13.6 | 8.3 | 123.7 | 3,377,613.2 | 1,874.5 | 1.0 | 0.7 |
| 02/05/2014 06:00 | 10.4 | 13.5 | 8.3 | 124.6 | 3,437,966.6 | 1,933.1 | 1.0 | 0.8 |
| 02/05/2014 07:00 | 10.5 | 13.4 | 8.3 | 134.9 | 3,344,102.5 | 2,100.1 | 1.2 | 1.1 |
| 02/05/2014 08:00 | 10.8 | 13.2 | 8.3 | 149.2 | 3,410,636.1 | 2,216.6 | 1.3 | 1.1 |
| 02/05/2014 09:00 | 10.5 | 13.4 | 8.3 | 134.3 | 3,506,068.8 | 2,048.2 | 1.1 | 0.8 |
| 02/05/2014 10:00 | 10.5 | 13.8 | 8.7 | 103.4 | 2,591,298.1 | 1,343.5 | 1.1 | 0.5 |
| 02/05/2014 11:00 | 10.7 | 13.7 | 8.8 | 112.9 | 2,871,164.8 | 1,551.5 | 1.1 | 0.6 |
| 02/05/2014 12:00 | 11.1 | 13.2 | 8.5 | 155.0 | 3,397,541.9 | 2,232.9 | 1.3 | 1.1 |
| 02/05/2014 13:00 | 11.0 | 13.2 | 8.4 | 149.4 | 3,385,311.5 | 2,150.7 | 1.3 | 1.1 |
| 02/05/2014 14:00 | 10.2 | 13.6 | 8.2 | 121.7 | 3,352,927.5 | 1,860.8 | 1.0 | 0.7 |
| 02/05/2014 15:00 | 10.2 | 13.6 | 8.2 | 119.8 | 3,297,429.8 | 1,830.0 | 1.0 | 0.7 |
| 02/05/2014 16:00 | 10.2 | 13.6 | 8.2 | 123.1 | 3,336,710.6 | 1,851.8 | 1.1 | 0.7 |
| 02/05/2014 17:00 | 10.6 | 13.4 | 8.3 | 131.8 | 3,431,606.3 | 2,004.7 | 1.1 | 0.8 |
| 02/05/2014 18:00 | 10.7 | 13.3 | 8.3 | 136.9 | 3,391,387.7 | 2,055.5 | 1.2 | 1.0 |
| 02/05/2014 19:00 | 11.0 | 13.2 | 8.4 | 155.2 | 3,353,283.9 | 2,228.3 | 1.4 | 1.1 |
| 02/05/2014 20:00 | 11.1 | 13.2 | 8.5 | 158.8 | 3,346,903.0 | 2,248.5 | 1.4 | 1.1 |
| 02/05/2014 21:00 | 11.1 | 13.2 | 8.5 | 156.4 | 3,336,334.6 | 2,241.4 | 1.4 | 1.1 |
| 02/05/2014 22:00 | 11.0 | 13.1 | 8.3 | 155.0 | 3,333,655.3 | 2,239.6 | 1.4 | 1.1 |
| 02/05/2014 23:00 | 10.9 | 13.1 | 8.2 | 154.1 | 3,333,804.1 | 2,239.7 | 1.4 | 1.1 |
| **Average/Sum#:** | 10.6 | 13.4 | 8.4 | 134.0 | 3,314,024.8 | 1,985.2 | 1.2 | 0.9 |
| **Minimum:** | 10.1 | 13.1 | 8.2 | 103.4 | 2,591,298.1 | 1,343.5 | 1.0 | 0.5 |
| **Maximum:** | 11.1 | 13.8 | 8.8 | 158.8 | 3,506,068.8 | 2,248.5 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/06/2014 00:00 | 10.9 | 13.2 | 8.4 | 150.2 | 3,377,554.5 | 2,195.1 | 1.3 | 1.1 |
| 02/06/2014 01:00 | 10.2 | 13.5 | 8.1 | 126.6 | 3,387,043.0 | 1,929.2 | 1.1 | 0.8 |
| 02/06/2014 02:00 | 10.1 | 13.6 | 8.2 | 119.1 | 3,232,375.1 | 1,817.5 | 1.1 | 0.7 |
| 02/06/2014 03:00 | 10.1 | 13.6 | 8.2 | 119.3 | 3,235,220.6 | 1,819.1 | 1.1 | 0.7 |
| 02/06/2014 04:00 | 10.1 | 13.6 | 8.2 | 119.2 | 3,238,777.6 | 1,821.1 | 1.1 | 0.7 |
| 02/06/2014 05:00 | 10.0 | 13.6 | 8.1 | 120.0 | 3,241,089.6 | 1,822.4 | 1.1 | 0.7 |
| 02/06/2014 06:00 | 10.1 | 13.6 | 8.2 | 119.8 | 3,258,518.6 | 1,832.2 | 1.0 | 0.7 |
| 02/06/2014 07:00 | 10.0 | 13.6 | 8.1 | 120.1 | 3,340,494.6 | 1,853.9 | 1.0 | 0.7 |
| 02/06/2014 08:00 | 10.1 | 13.5 | 8.1 | 124.1 | 3,410,222.4 | 1,917.5 | 1.0 | 0.8 |
| 02/06/2014 09:00 | 10.0 | 13.6 | 8.1 | 122.9 | 3,395,812.1 | 1,884.6 | 1.0 | 0.8 |
| 02/06/2014 10:00 | 10.0 | 13.6 | 8.1 | 121.7 | 3,318,691.9 | 1,841.8 | 1.0 | 0.7 |
| 02/06/2014 11:00 | 10.1 | 13.6 | 8.2 | 120.0 | 3,252,294.0 | 1,828.7 | 1.1 | 0.7 |
| 02/06/2014 12:00 | 10.2 | 13.6 | 8.2 | 119.2 | 3,241,267.5 | 1,822.5 | 1.0 | 0.7 |
| 02/06/2014 13:00 | 10.1 | 13.6 | 8.2 | 119.2 | 3,271,857.2 | 1,839.7 | 1.0 | 0.7 |
| 02/06/2014 14:00 | 10.1 | 13.6 | 8.2 | 119.2 | 3,312,205.1 | 1,838.2 | 1.0 | 0.7 |
| 02/06/2014 15:00 | 9.9 | 13.6 | 8.0 | 120.2 | 3,364,279.3 | 1,867.1 | 1.0 | 0.7 |
| 02/06/2014 16:00 | 9.9 | 13.6 | 8.0 | 118.6 | 3,302,114.6 | 1,832.6 | 1.0 | 0.7 |
| 02/06/2014 17:00 | 9.9 | 13.6 | 8.0 | 116.9 | 3,378,514.1 | 1,875.0 | 1.0 | 0.8 |
| 02/06/2014 18:00 | 9.8 | 13.7 | 8.0 | 119.6 | 3,332,926.7 | 1,849.7 | 1.0 | 0.7 |
| 02/06/2014 19:00 | 9.8 | 13.6 | 7.9 | 121.8 | 3,438,516.5 | 1,908.3 | 1.0 | 0.8 |
| 02/06/2014 20:00 | 9.9 | 13.6 | 8.0 | 119.5 | 3,341,936.1 | 1,854.7 | 1.0 | 0.7 |
| 02/06/2014 21:00 | 9.9 | 13.6 | 8.0 | 118.9 | 3,314,727.8 | 1,839.6 | 1.0 | 0.7 |
| 02/06/2014 22:00 | 9.9 | 13.6 | 8.0 | 118.1 | 3,317,971.1 | 1,841.4 | 1.0 | 0.7 |
| 02/06/2014 23:00 | 10.0 | 13.6 | 8.1 | 118.9 | 3,321,394.7 | 1,843.3 | 1.0 | 0.7 |
| **Average/Sum#:** | 10.0 | 13.6 | 8.1 | 121.4 | 3,317,741.9 | 1,865.6 | 1.0 | 0.7 |
| **Minimum:** | 9.8 | 13.2 | 7.9 | 116.9 | 3,232,375.1 | 1,817.5 | 1.0 | 0.7 |
| **Maximum:** | 10.9 | 13.7 | 8.4 | 150.2 | 3,438,516.5 | 2,195.1 | 1.3 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/07/2014 00:00 | 10.0 | 13.6 | 8.1 | 118.9 | 3,317,971.1 | 1,841.4 | 1.0 | 0.7 |
| 02/07/2014 01:00 | 10.3 | 13.4 | 8.1 | 128.7 | 3,396,857.2 | 1,984.4 | 1.1 | 0.8 |
| 02/07/2014 02:00 | 10.5 | 13.3 | 8.2 | 134.7 | 3,362,019.4 | 2,037.7 | 1.2 | 1.0 |
| 02/07/2014 03:00 | 10.5 | 13.3 | 8.2 | 134.9 | 3,408,697.7 | 2,041.1 | 1.1 | 0.8 |
| 02/07/2014 04:00 | 10.9 | 13.2 | 8.4 | 149.8 | 3,328,309.9 | 2,187.4 | 1.3 | 1.1 |
| 02/07/2014 05:00 | 10.8 | 13.2 | 8.3 | 150.2 | 3,341,243.3 | 2,195.9 | 1.3 | 1.1 |
| 02/07/2014 06:00 | 11.1 | 13.1 | 8.4 | 154.6 | 3,335,590.3 | 2,240.9 | 1.4 | 1.1 |
| 02/07/2014 07:00 | 11.0 | 13.1 | 8.3 | 155.6 | 3,320,486.0 | 2,255.0 | 1.4 | 1.1 |
| 02/07/2014 08:00 | 11.0 | 13.1 | 8.3 | 156.1 | 3,326,376.0 | 2,259.0 | 1.4 | 1.1 |
| 02/07/2014 09:00 | 10.8 | 13.2 | 8.3 | 145.4 | 3,373,820.9 | 2,143.4 | 1.3 | 1.1 |
| 02/07/2014 10:00 | 10.4 | 13.3 | 8.1 | 132.5 | 3,415,784.0 | 2,020.4 | 1.1 | 0.8 |
| 02/07/2014 11:00 | 10.4 | 13.3 | 8.1 | 132.6 | 3,414,093.3 | 2,019.4 | 1.1 | 0.8 |
| 02/07/2014 12:00 | 10.3 | 13.3 | 8.0 | 134.9 | 3,373,733.7 | 2,044.8 | 1.2 | 1.0 |
| 02/07/2014 13:00 | 10.3 | 13.3 | 8.0 | 131.0 | 3,377,913.5 | 1,998.0 | 1.1 | 0.8 |
| 02/07/2014 14:00 | 10.0 | 13.5 | 8.0 | 125.4 | 3,331,514.8 | 1,921.9 | 1.1 | 0.8 |
| 02/07/2014 15:00 | 9.7 | 13.6 | 7.8 | 118.2 | 3,303,916.5 | 1,833.6 | 1.0 | 0.7 |
| 02/07/2014 16:00 | 10.3 | 13.3 | 8.0 | 130.9 | 3,388,564.6 | 2,004.3 | 1.1 | 0.8 |
| 02/07/2014 17:00 | 10.3 | 13.3 | 8.0 | 131.8 | 3,353,753.7 | 2,008.2 | 1.1 | 0.8 |
| 02/07/2014 18:00 | 10.5 | 13.3 | 8.2 | 137.3 | 3,366,827.7 | 2,065.2 | 1.2 | 1.0 |
| 02/07/2014 19:00 | 10.9 | 13.1 | 8.2 | 152.5 | 3,298,377.7 | 2,215.9 | 1.4 | 1.1 |
| 02/07/2014 20:00 | 10.5 | 13.3 | 8.2 | 138.0 | 3,350,525.0 | 2,055.2 | 1.2 | 1.0 |
| 02/07/2014 21:00 | 10.3 | 13.3 | 8.0 | 132.7 | 3,358,429.8 | 2,011.0 | 1.1 | 0.8 |
| 02/07/2014 22:00 | 10.4 | 13.3 | 8.1 | 133.0 | 3,359,097.8 | 2,011.4 | 1.1 | 0.8 |
| 02/07/2014 23:00 | 10.5 | 13.3 | 8.2 | 134.1 | 3,329,021.2 | 2,017.7 | 1.2 | 1.0 |
| **Average/Sum#:** | 10.5 | 13.3 | 8.1 | 137.2 | 3,355,538.5 | 2,058.9 | 1.2 | 0.9 |
| **Minimum:** | 9.7 | 13.1 | 7.8 | 118.2 | 3,298,377.7 | 1,833.6 | 1.0 | 0.7 |
| **Maximum:** | 11.1 | 13.6 | 8.4 | 156.1 | 3,415,784.0 | 2,259.0 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/08/2014 00:00 | 10.0 | 13.4 | 7.9 | 123.7 | 3,367,555.0 | 1,918.1 | 1.1 | 0.8 |
| 02/08/2014 01:00 | 9.8 | 13.5 | 7.8 | 120.5 | 3,371,451.7 | 1,895.7 | 1.0 | 0.8 |
| 02/08/2014 02:00 | 9.7 | 13.5 | 7.7 | 117.8 | 3,363,558.5 | 1,866.7 | 1.0 | 0.7 |
| 02/08/2014 03:00 | 9.4 | 13.5 | 7.5 | 115.4 | 3,391,060.0 | 1,857.2 | 1.0 | 0.7 |
| 02/08/2014 04:00 | 9.4 | 13.5 | 7.5 | 115.4 | 3,401,650.2 | 1,863.0 | 1.0 | 0.7 |
| 02/08/2014 05:00 | 9.5 | 13.5 | 7.6 | 115.7 | 3,400,737.2 | 1,862.5 | 1.0 | 0.7 |
| 02/08/2014 06:00 | 9.5 | 13.6 | 7.7 | 115.8 | 3,368,418.8 | 1,844.8 | 1.0 | 0.7 |
| 02/08/2014 07:00 | 9.8 | 13.5 | 7.8 | 121.6 | 3,340,506.3 | 1,878.3 | 1.0 | 0.8 |
| 02/08/2014 08:00 | 9.7 | 13.6 | 7.8 | 118.3 | 3,255,139.5 | 1,830.3 | 1.0 | 0.7 |
| 02/08/2014 09:00 | 9.9 | 13.6 | 8.0 | 118.9 | 3,251,049.1 | 1,828.0 | 1.0 | 0.7 |
| 02/08/2014 10:00 | 9.9 | 13.6 | 8.0 | 117.9 | 3,237,532.7 | 1,820.4 | 1.0 | 0.7 |
| 02/08/2014 11:00 | 9.7 | 13.6 | 7.8 | 117.7 | 3,235,042.8 | 1,819.0 | 1.0 | 0.7 |
| 02/08/2014 12:00 | 9.6 | 13.6 | 7.8 | 117.5 | 3,233,975.7 | 1,818.4 | 1.0 | 0.7 |
| 02/08/2014 13:00 | 9.5 | 13.6 | 7.7 | 118.8 | 3,293,021.0 | 1,851.6 | 1.0 | 0.7 |
| 02/08/2014 14:00 | 9.6 | 13.6 | 7.8 | 117.0 | 3,224,727.7 | 1,813.2 | 1.0 | 0.7 |
| 02/08/2014 15:00 | 9.6 | 13.6 | 7.8 | 117.3 | 3,228,996.0 | 1,815.6 | 1.0 | 0.7 |
| 02/08/2014 16:00 | 9.6 | 13.6 | 7.8 | 117.4 | 3,228,106.8 | 1,815.1 | 1.0 | 0.7 |
| 02/08/2014 17:00 | 9.6 | 13.6 | 7.8 | 117.7 | 3,286,258.1 | 1,823.8 | 1.0 | 0.7 |
| 02/08/2014 18:00 | 10.2 | 13.4 | 8.0 | 125.2 | 3,334,461.7 | 1,923.6 | 1.1 | 0.8 |
| 02/08/2014 19:00 | 10.9 | 13.2 | 8.4 | 144.1 | 3,284,439.9 | 2,110.6 | 1.3 | 1.1 |
| 02/08/2014 20:00 | 10.6 | 13.3 | 8.2 | 135.7 | 3,300,312.8 | 2,024.4 | 1.2 | 1.0 |
| 02/08/2014 21:00 | 10.8 | 13.2 | 8.3 | 138.5 | 3,296,285.0 | 2,046.0 | 1.2 | 1.0 |
| 02/08/2014 22:00 | 10.0 | 13.5 | 8.0 | 123.0 | 3,314,533.7 | 1,887.9 | 1.1 | 0.8 |
| 02/08/2014 23:00 | 9.7 | 13.6 | 7.8 | 113.9 | 3,352,498.9 | 1,811.6 | 1.0 | 0.7 |
| **Average/Sum#:** | 9.8 | 13.5 | 7.9 | 121.0 | 3,306,721.6 | 1,876.1 | 1.0 | 0.8 |
| **Minimum:** | 9.4 | 13.2 | 7.5 | 113.9 | 3,224,727.7 | 1,811.6 | 1.0 | 0.7 |
| **Maximum:** | 10.9 | 13.6 | 8.4 | 144.1 | 3,401,650.2 | 2,110.6 | 1.3 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/09/2014 00:00 | 9.4 | 13.7 | 7.7 | 112.9 | 3,380,789.9 | 1,802.2 | 0.9 | 0.5 |
| 02/09/2014 01:00 | 10.4 | 13.4 | 8.2 | 123.7 | 3,359,127.8 | 1,913.3 | 1.1 | 0.8 |
| 02/09/2014 02:00 | 9.5 | 13.6 | 7.7 | 114.1 | 3,361,381.7 | 1,816.4 | 1.0 | 0.7 |
| 02/09/2014 03:00 | 9.4 | 13.7 | 7.7 | 112.6 | 3,379,101.6 | 1,801.3 | 0.9 | 0.5 |
| 02/09/2014 04:00 | 9.4 | 13.7 | 7.7 | 112.6 | 3,377,413.2 | 1,800.4 | 0.9 | 0.5 |
| 02/09/2014 05:00 | 9.4 | 13.7 | 7.7 | 112.3 | 3,373,661.4 | 1,798.4 | 0.9 | 0.5 |
| 02/09/2014 06:00 | 9.5 | 13.7 | 7.8 | 113.9 | 3,352,498.9 | 1,811.6 | 1.0 | 0.7 |
| 02/09/2014 07:00 | 9.6 | 13.6 | 7.8 | 117.4 | 3,237,888.4 | 1,820.6 | 1.0 | 0.7 |
| 02/09/2014 08:00 | 9.7 | 13.6 | 7.8 | 117.4 | 3,237,354.8 | 1,820.3 | 1.0 | 0.7 |
| 02/09/2014 09:00 | 9.7 | 13.6 | 7.8 | 117.6 | 3,237,888.4 | 1,820.6 | 1.0 | 0.7 |
| 02/09/2014 10:00 | 9.7 | 13.6 | 7.8 | 117.5 | 3,245,002.2 | 1,824.6 | 1.0 | 0.7 |
| 02/09/2014 11:00 | 9.7 | 13.6 | 7.8 | 117.2 | 3,274,726.2 | 1,817.4 | 1.0 | 0.7 |
| 02/09/2014 12:00 | 9.6 | 13.6 | 7.8 | 116.7 | 3,265,356.4 | 1,812.2 | 1.0 | 0.7 |
| 02/09/2014 13:00 | 9.4 | 13.6 | 7.6 | 116.3 | 3,270,762.0 | 1,815.2 | 1.0 | 0.7 |
| 02/09/2014 14:00 | 9.3 | 13.6 | 7.5 | 116.2 | 3,279,230.8 | 1,819.9 | 1.0 | 0.7 |
| 02/09/2014 15:00 | 9.3 | 13.6 | 7.5 | 116.1 | 3,281,933.6 | 1,821.4 | 1.0 | 0.7 |
| 02/09/2014 16:00 | 9.5 | 13.5 | 7.6 | 118.1 | 3,289,108.4 | 1,849.4 | 1.0 | 0.7 |
| 02/09/2014 17:00 | 9.5 | 13.5 | 7.6 | 118.5 | 3,291,420.4 | 1,850.7 | 1.0 | 0.7 |
| 02/09/2014 18:00 | 10.0 | 13.4 | 7.9 | 126.4 | 3,319,655.9 | 1,939.3 | 1.1 | 0.8 |
| 02/09/2014 19:00 | 11.0 | 13.0 | 8.2 | 153.3 | 3,234,492.0 | 2,196.6 | 1.4 | 1.1 |
| 02/09/2014 20:00 | 11.1 | 13.0 | 8.3 | 155.5 | 3,216,981.8 | 2,208.2 | 1.4 | 1.1 |
| 02/09/2014 21:00 | 11.0 | 13.0 | 8.2 | 155.3 | 3,218,438.7 | 2,209.2 | 1.4 | 1.1 |
| 02/09/2014 22:00 | 10.7 | 13.2 | 8.2 | 144.6 | 3,234,149.6 | 2,101.9 | 1.3 | 1.1 |
| 02/09/2014 23:00 | 10.5 | 13.2 | 8.0 | 137.9 | 3,256,363.8 | 2,045.0 | 1.2 | 1.0 |
| **Average/Sum#:** | 9.8 | 13.5 | 7.8 | 123.5 | 3,290,613.7 | 1,896.5 | 1.1 | 0.8 |
| **Minimum:** | 9.3 | 13.0 | 7.5 | 112.3 | 3,216,981.8 | 1,798.4 | 0.9 | 0.5 |
| **Maximum:** | 11.1 | 13.7 | 8.3 | 155.5 | 3,380,789.9 | 2,209.2 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/10/2014 00:00 | 9.5 | 13.7 | 7.8 | 104.1 | 2,811,504.3 | 1,478.2 | 1.1 | 0.6 |
| 02/10/2014 01:00 | 9.9 | 13.8 | 8.2 | 96.4 | 2,575,482.2 | 1,335.3 | 1.1 | 0.5 |
| 02/10/2014 02:00 | 9.9 | 13.8 | 8.2 | 99.4 | 2,631,609.3 | 1,364.4 | 1.1 | 0.5 |
| 02/10/2014 03:00 | 10.1 | 13.8 | 8.4 | 91.8 | 2,430,337.0 | 1,242.3 | 1.1 | 0.5 |
| 02/10/2014 04:00 | 10.2 | 13.8 | 8.5 | 94.9 | 2,430,337.0 | 1,242.3 | 1.1 | 0.5 |
| 02/10/2014 05:00 | 10.1 | 13.7 | 8.3 | 101.4 | 2,744,056.4 | 1,422.7 | 1.0 | 0.6 |
| 02/10/2014 06:00 | 9.8 | 13.6 | 7.9 | 117.1 | 3,378,643.8 | 1,850.4 | 1.0 | 0.7 |
| 02/10/2014 07:00 | 10.0 | 13.6 | 8.1 | 125.0 | 3,351,177.1 | 1,884.3 | 1.1 | 0.8 |
| 02/10/2014 08:00 | 10.2 | 13.4 | 8.0 | 127.6 | 3,393,052.3 | 1,957.4 | 1.1 | 0.8 |
| 02/10/2014 09:00 | 9.9 | 13.6 | 8.0 | 121.6 | 3,356,351.1 | 1,862.7 | 1.0 | 0.7 |
| 02/10/2014 10:00 | 9.9 | 13.6 | 8.0 | 119.9 | 3,340,134.2 | 1,853.7 | 1.0 | 0.7 |
| 02/10/2014 11:00 | 9.9 | 13.6 | 8.0 | 118.7 | 3,303,376.0 | 1,833.3 | 1.0 | 0.7 |
| 02/10/2014 12:00 | 9.8 | 13.6 | 7.9 | 118.5 | 3,312,745.7 | 1,838.5 | 1.0 | 0.7 |
| 02/10/2014 13:00 | 9.8 | 13.6 | 7.9 | 118.3 | 3,318,331.5 | 1,841.6 | 1.0 | 0.7 |
| 02/10/2014 14:00 | 9.6 | 13.6 | 7.8 | 118.1 | 3,324,638.1 | 1,845.1 | 1.0 | 0.7 |
| 02/10/2014 15:00 | 9.6 | 13.6 | 7.8 | 117.5 | 3,308,601.4 | 1,836.2 | 1.0 | 0.7 |
| 02/10/2014 16:00 | 9.7 | 13.6 | 7.8 | 117.8 | 3,306,439.1 | 1,835.0 | 1.0 | 0.7 |
| 02/10/2014 17:00 | 9.7 | 13.6 | 7.8 | 117.9 | 3,304,276.9 | 1,833.8 | 1.0 | 0.7 |
| 02/10/2014 18:00 | 9.9 | 13.5 | 7.9 | 120.3 | 3,339,261.3 | 1,877.6 | 1.0 | 0.8 |
| 02/10/2014 19:00 | 10.6 | 13.3 | 8.2 | 131.7 | 3,350,580.7 | 2,006.3 | 1.1 | 0.8 |
| 02/10/2014 20:00 | 10.6 | 13.3 | 8.2 | 133.0 | 3,372,959.1 | 2,019.7 | 1.1 | 0.8 |
| 02/10/2014 21:00 | 10.7 | 13.3 | 8.3 | 140.7 | 3,343,624.8 | 2,099.8 | 1.2 | 1.0 |
| 02/10/2014 22:00 | 10.0 | 13.4 | 7.9 | 128.1 | 3,379,225.8 | 1,974.1 | 1.1 | 0.8 |
| 02/10/2014 23:00 | 9.6 | 13.6 | 7.8 | 115.2 | 3,394,877.1 | 1,834.5 | 1.0 | 0.7 |
| **Average/Sum#:** | 10.0 | 13.6 | 8.0 | 116.5 | 3,158,400.9 | 1,757.1 | 1.1 | 0.7 |
| **Minimum:** | 9.5 | 13.3 | 7.8 | 91.8 | 2,430,337.0 | 1,242.3 | 1.0 | 0.5 |
| **Maximum:** | 10.7 | 13.8 | 8.5 | 140.7 | 3,394,877.1 | 2,099.8 | 1.2 | 1.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/11/2014 00:00 | 9.7 | 13.7 | 7.9 | 113.5 | 3,330,292.1 | 1,799.6 | 1.0 | 0.7 |
| 02/11/2014 01:00 | 9.9 | 13.6 | 8.0 | 117.1 | 3,285,177.0 | 1,823.2 | 1.0 | 0.7 |
| 02/11/2014 02:00 | 9.9 | 13.5 | 7.9 | 116.3 | 3,261,392.3 | 1,810.0 | 1.0 | 0.7 |
| 02/11/2014 03:00 | 9.9 | 13.7 | 8.1 | 109.7 | 2,931,863.6 | 1,584.3 | 1.1 | 0.6 |
| 02/11/2014 04:00 | 10.2 | 13.8 | 8.5 | 95.2 | 2,437,966.7 | 1,246.2 | 1.1 | 0.5 |
| 02/11/2014 05:00 | 10.1 | 13.7 | 8.3 | 107.0 | 2,907,615.9 | 1,507.5 | 1.0 | 0.6 |
| 02/11/2014 06:00 | 10.1 | 13.6 | 8.2 | 118.7 | 3,233,975.7 | 1,818.4 | 1.0 | 0.7 |
| 02/11/2014 07:00 | 10.0 | 13.6 | 8.1 | 116.8 | 3,260,475.0 | 1,833.3 | 1.0 | 0.7 |
| 02/11/2014 08:00 | 10.6 | 13.3 | 8.2 | 132.8 | 3,417,305.6 | 2,021.3 | 1.1 | 0.8 |
| 02/11/2014 09:00 | 10.3 | 13.4 | 8.1 | 129.7 | 3,404,731.4 | 1,989.0 | 1.1 | 0.8 |
| 02/11/2014 10:00 | 9.8 | 13.6 | 7.9 | 120.6 | 3,366,801.9 | 1,868.5 | 1.0 | 0.7 |
| 02/11/2014 11:00 | 10.1 | 13.6 | 8.2 | 119.4 | 3,306,259.0 | 1,834.9 | 1.0 | 0.7 |
| 02/11/2014 12:00 | 10.1 | 13.6 | 8.2 | 119.2 | 3,318,331.5 | 1,841.6 | 1.0 | 0.7 |
| 02/11/2014 13:00 | 9.9 | 13.7 | 8.1 | 119.6 | 3,321,755.1 | 1,843.5 | 1.0 | 0.7 |
| 02/11/2014 14:00 | 9.8 | 13.7 | 8.0 | 119.0 | 3,324,277.7 | 1,844.9 | 1.0 | 0.7 |
| 02/11/2014 15:00 | 9.9 | 13.7 | 8.1 | 119.1 | 3,320,854.1 | 1,843.0 | 1.0 | 0.7 |
| 02/11/2014 16:00 | 9.9 | 13.7 | 8.1 | 119.5 | 3,302,655.2 | 1,832.9 | 1.0 | 0.7 |
| 02/11/2014 17:00 | 9.9 | 13.6 | 8.0 | 119.0 | 3,320,493.8 | 1,842.8 | 1.0 | 0.7 |
| 02/11/2014 18:00 | 9.9 | 13.6 | 8.0 | 120.6 | 3,329,657.6 | 1,872.2 | 1.0 | 0.7 |
| 02/11/2014 19:00 | 10.8 | 13.3 | 8.4 | 133.5 | 3,369,619.0 | 2,017.7 | 1.1 | 0.8 |
| 02/11/2014 20:00 | 10.8 | 13.4 | 8.5 | 134.5 | 3,384,482.3 | 2,026.6 | 1.1 | 0.8 |
| 02/11/2014 21:00 | 10.9 | 13.3 | 8.5 | 142.2 | 3,349,835.0 | 2,103.7 | 1.2 | 1.1 |
| 02/11/2014 22:00 | 10.4 | 13.4 | 8.2 | 131.2 | 3,373,348.7 | 1,995.3 | 1.1 | 0.8 |
| 02/11/2014 23:00 | 10.0 | 13.5 | 8.0 | 123.9 | 3,373,699.9 | 1,921.6 | 1.1 | 0.8 |
| **Average/Sum#:** | 10.1 | 13.6 | 8.1 | 120.8 | 3,259,702.8 | 1,838.4 | 1.0 | 0.7 |
| **Minimum:** | 9.7 | 13.3 | 7.9 | 95.2 | 2,437,966.7 | 1,246.2 | 1.0 | 0.5 |
| **Maximum:** | 10.9 | 13.8 | 8.5 | 142.2 | 3,417,305.6 | 2,103.7 | 1.2 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/12/2014 00:00 | 9.8 | 13.6 | 7.9 | 119.5 | 3,298,178.6 | 1,854.5 | 1.0 | 0.7 |
| 02/12/2014 01:00 | 10.1 | 13.4 | 7.9 | 127.3 | 3,381,622.3 | 1,975.5 | 1.1 | 0.8 |
| 02/12/2014 02:00 | 10.2 | 13.3 | 7.9 | 128.6 | 3,393,776.0 | 1,982.6 | 1.1 | 0.8 |
| 02/12/2014 03:00 | 10.2 | 13.3 | 7.9 | 129.2 | 3,412,263.2 | 1,993.4 | 1.1 | 0.8 |
| 02/12/2014 04:00 | 10.4 | 13.3 | 8.1 | 130.9 | 3,388,564.6 | 2,004.3 | 1.1 | 0.8 |
| 02/12/2014 05:00 | 10.3 | 13.3 | 8.0 | 130.4 | 3,377,406.3 | 1,997.7 | 1.1 | 0.8 |
| 02/12/2014 06:00 | 10.0 | 13.4 | 7.9 | 125.8 | 3,379,878.1 | 1,949.8 | 1.1 | 0.8 |
| 02/12/2014 07:00 | 10.4 | 13.3 | 8.1 | 131.8 | 3,328,516.4 | 2,041.7 | 1.1 | 0.8 |
| 02/12/2014 08:00 | 10.5 | 13.3 | 8.2 | 133.7 | 3,376,132.1 | 2,021.6 | 1.1 | 0.8 |
| 02/12/2014 09:00 | 9.9 | 13.6 | 8.0 | 121.8 | 3,327,167.7 | 1,870.8 | 1.0 | 0.7 |
| 02/12/2014 10:00 | 9.8 | 13.6 | 7.9 | 110.6 | 3,244,290.9 | 1,824.2 | 1.0 | 0.7 |
| 02/12/2014 11:00 | 9.9 | 13.6 | 8.0 | 118.7 | 3,243,935.2 | 1,824.0 | 1.0 | 0.7 |
| 02/12/2014 12:00 | 9.9 | 13.6 | 8.0 | 118.6 | 3,250,159.8 | 1,827.5 | 1.0 | 0.7 |
| 02/12/2014 13:00 | 9.8 | 13.6 | 7.9 | 118.3 | 3,245,891.5 | 1,825.1 | 1.0 | 0.7 |
| 02/12/2014 14:00 | 9.6 | 13.6 | 7.8 | 117.6 | 3,294,907.1 | 1,828.6 | 1.0 | 0.7 |
| 02/12/2014 15:00 | 9.6 | 13.6 | 7.8 | 117.5 | 3,297,790.1 | 1,830.2 | 1.0 | 0.7 |
| 02/12/2014 16:00 | 9.6 | 13.6 | 7.8 | 117.4 | 3,295,988.3 | 1,829.2 | 1.0 | 0.7 |
| 02/12/2014 17:00 | 9.7 | 13.6 | 7.8 | 118.3 | 3,332,386.1 | 1,849.4 | 1.0 | 0.7 |
| 02/12/2014 18:00 | 10.8 | 13.3 | 8.4 | 135.8 | 3,325,744.9 | 2,040.0 | 1.2 | 1.0 |
| 02/12/2014 19:00 | 11.2 | 13.1 | 8.5 | 156.4 | 3,278,667.0 | 2,226.6 | 1.4 | 1.1 |
| 02/12/2014 20:00 | 11.3 | 13.1 | 8.5 | 157.3 | 3,258,493.8 | 2,212.9 | 1.4 | 1.1 |
| 02/12/2014 21:00 | 11.1 | 13.1 | 8.4 | 151.2 | 3,267,055.3 | 2,171.0 | 1.4 | 1.1 |
| 02/12/2014 22:00 | 10.7 | 13.2 | 8.2 | 139.2 | 3,343,328.8 | 2,075.2 | 1.2 | 1.0 |
| 02/12/2014 23:00 | 10.1 | 13.4 | 7.9 | 126.3 | 3,377,104.5 | 1,948.2 | 1.1 | 0.8 |
| **Average/Sum#:** | 10.2 | 13.4 | 8.0 | 128.4 | 3,321,635.4 | 1,958.5 | 1.1 | 0.8 |
| **Minimum:** | 9.6 | 13.1 | 7.8 | 110.6 | 3,243,935.2 | 1,824.0 | 1.0 | 0.7 |
| **Maximum:** | 11.3 | 13.6 | 8.5 | 157.3 | 3,412,263.2 | 2,226.6 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/13/2014 00:00 | 9.8 | 13.6 | 7.9 | 120.1 | 3,317,030.4 | 1,865.1 | 1.0 | 0.7 |
| 02/13/2014 01:00 | 9.8 | 13.6 | 7.9 | 118.1 | 3,250,515.5 | 1,827.7 | 1.0 | 0.7 |
| 02/13/2014 02:00 | 9.9 | 13.6 | 8.0 | 117.8 | 3,241,267.5 | 1,822.5 | 1.0 | 0.7 |
| 02/13/2014 03:00 | 9.9 | 13.6 | 8.0 | 118.0 | 3,241,089.6 | 1,822.4 | 1.0 | 0.7 |
| 02/13/2014 04:00 | 9.8 | 13.6 | 7.9 | 117.6 | 3,228,462.4 | 1,815.3 | 1.0 | 0.7 |
| 02/13/2014 05:00 | 9.7 | 13.6 | 7.8 | 118.3 | 3,266,343.9 | 1,836.6 | 1.0 | 0.7 |
| 02/13/2014 06:00 | 9.9 | 13.5 | 7.9 | 122.0 | 3,327,525.7 | 1,895.3 | 1.1 | 0.8 |
| 02/13/2014 07:00 | 10.5 | 13.2 | 8.0 | 137.7 | 3,253,005.4 | 2,090.4 | 1.2 | 1.0 |
| 02/13/2014 08:00 | 10.9 | 13.1 | 8.2 | 154.1 | 3,295,400.7 | 2,213.9 | 1.4 | 1.1 |
| 02/13/2014 09:00 | 10.6 | 13.2 | 8.1 | 143.5 | 3,330,219.7 | 2,115.7 | 1.3 | 1.1 |
| 02/13/2014 10:00 | 10.6 | 13.2 | 8.1 | 141.3 | 3,336,300.0 | 2,095.2 | 1.2 | 1.0 |
| 02/13/2014 11:00 | 10.8 | 13.2 | 8.3 | 141.6 | 3,338,210.8 | 2,096.4 | 1.2 | 1.0 |
| 02/13/2014 12:00 | 10.7 | 13.2 | 8.2 | 141.6 | 3,343,624.8 | 2,099.8 | 1.2 | 1.0 |
| 02/13/2014 13:00 | 10.6 | 13.2 | 8.1 | 141.6 | 3,303,460.9 | 2,098.7 | 1.3 | 1.0 |
| 02/13/2014 14:00 | 10.7 | 13.2 | 8.2 | 142.0 | 3,306,923.8 | 2,100.9 | 1.3 | 1.1 |
| 02/13/2014 15:00 | 10.7 | 13.2 | 8.2 | 142.4 | 3,302,044.2 | 2,097.8 | 1.3 | 1.0 |
| 02/13/2014 16:00 | 10.7 | 13.2 | 8.2 | 142.7 | 3,308,183.0 | 2,101.7 | 1.3 | 1.1 |
| 02/13/2014 17:00 | 10.8 | 13.2 | 8.3 | 144.1 | 3,298,601.0 | 2,119.7 | 1.3 | 1.1 |
| 02/13/2014 18:00 | 10.9 | 13.2 | 8.4 | 143.7 | 3,280,549.5 | 2,108.1 | 1.3 | 1.1 |
| 02/13/2014 19:00 | 11.1 | 13.1 | 8.4 | 151.7 | 3,284,361.2 | 2,182.5 | 1.4 | 1.1 |
| 02/13/2014 20:00 | 11.2 | 13.0 | 8.4 | 159.4 | 3,248,012.4 | 2,229.5 | 1.5 | 1.3 |
| 02/13/2014 21:00 | 11.2 | 13.0 | 8.4 | 159.1 | 3,249,469.2 | 2,230.5 | 1.4 | 1.1 |
| 02/13/2014 22:00 | 11.0 | 13.1 | 8.3 | 149.4 | 3,267,142.3 | 2,147.2 | 1.3 | 1.1 |
| 02/13/2014 23:00 | 10.8 | 13.2 | 8.3 | 141.9 | 3,301,886.8 | 2,097.7 | 1.3 | 1.0 |
| **Average/Sum#:** | 10.5 | 13.3 | 8.1 | 137.9 | 3,288,317.9 | 2,046.3 | 1.2 | 1.0 |
| **Minimum:** | 9.7 | 13.0 | 7.8 | 117.6 | 3,228,462.4 | 1,815.3 | 1.0 | 0.7 |
| **Maximum:** | 11.2 | 13.6 | 8.4 | 159.4 | 3,343,624.8 | 2,230.5 | 1.5 | 1.3 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/14/2014 00:00 | 10.4 | 13.3 | 8.1 | 132.3 | 3,334,381.4 | 1,996.6 | 1.1 | 0.8 |
| 02/14/2014 01:00 | 9.7 | 13.6 | 7.8 | 117.4 | 3,223,660.6 | 1,812.6 | 1.0 | 0.7 |
| 02/14/2014 02:00 | 9.7 | 13.6 | 7.8 | 118.4 | 3,264,743.3 | 1,835.7 | 1.0 | 0.7 |
| 02/14/2014 03:00 | 9.8 | 13.6 | 7.9 | 117.9 | 3,228,996.0 | 1,815.6 | 1.0 | 0.7 |
| 02/14/2014 04:00 | 9.7 | 13.6 | 7.8 | 117.2 | 3,228,106.8 | 1,815.1 | 1.0 | 0.7 |
| 02/14/2014 05:00 | 9.6 | 13.6 | 7.8 | 116.9 | 3,279,411.0 | 1,820.0 | 1.0 | 0.7 |
| 02/14/2014 06:00 | 9.7 | 13.6 | 7.8 | 118.1 | 3,306,439.1 | 1,835.0 | 1.0 | 0.7 |
| 02/14/2014 07:00 | 9.9 | 13.5 | 7.9 | 125.9 | 3,298,381.5 | 1,878.7 | 1.1 | 0.8 |
| 02/14/2014 08:00 | 10.3 | 13.4 | 8.1 | 129.5 | 3,325,503.4 | 1,967.0 | 1.1 | 0.8 |
| 02/14/2014 09:00 | 10.7 | 13.2 | 8.2 | 140.5 | 3,315,280.9 | 2,082.0 | 1.2 | 1.0 |
| 02/14/2014 10:00 | 10.9 | 13.2 | 8.4 | 144.7 | 3,250,305.7 | 2,112.4 | 1.3 | 1.1 |
| 02/14/2014 11:00 | 11.0 | 13.2 | 8.4 | 145.6 | 3,259,383.9 | 2,118.3 | 1.3 | 1.1 |
| 02/14/2014 12:00 | 11.2 | 13.2 | 8.6 | 147.6 | 3,226,972.5 | 2,120.8 | 1.3 | 1.1 |
| 02/14/2014 13:00 | 11.0 | 13.1 | 8.3 | 147.0 | 3,238,536.5 | 2,128.4 | 1.3 | 1.1 |
| 02/14/2014 14:00 | 11.0 | 13.1 | 8.3 | 146.5 | 3,207,161.8 | 2,131.2 | 1.3 | 1.1 |
| 02/14/2014 15:00 | 11.1 | 13.1 | 8.4 | 147.3 | 3,209,569.6 | 2,132.8 | 1.3 | 1.1 |
| 02/14/2014 16:00 | 10.6 | 13.3 | 8.2 | 139.2 | 3,179,803.4 | 1,973.7 | 1.3 | 1.0 |
| 02/14/2014 17:00 | 11.1 | 13.2 | 8.5 | 145.1 | 3,221,646.9 | 2,117.3 | 1.3 | 1.1 |
| 02/14/2014 18:00 | 11.1 | 13.2 | 8.5 | 145.8 | 3,220,277.5 | 2,116.4 | 1.3 | 1.1 |
| 02/14/2014 19:00 | 10.8 | 13.2 | 8.3 | 138.5 | 3,253,975.3 | 2,043.5 | 1.2 | 1.0 |
| 02/14/2014 20:00 | 10.8 | 13.3 | 8.4 | 136.6 | 3,320,365.1 | 2,036.7 | 1.2 | 1.0 |
| 02/14/2014 21:00 | 10.8 | 13.2 | 8.3 | 142.1 | 3,297,322.1 | 2,094.8 | 1.3 | 1.0 |
| 02/14/2014 22:00 | 10.8 | 13.2 | 8.3 | 143.4 | 3,279,304.6 | 2,107.3 | 1.3 | 1.1 |
| 02/14/2014 23:00 | 10.5 | 13.3 | 8.2 | 134.9 | 3,295,095.9 | 2,021.2 | 1.2 | 1.0 |
| **Average/Sum#:** | 10.5 | 13.3 | 8.2 | 134.9 | 3,261,026.0 | 2,004.7 | 1.2 | 0.9 |
| **Minimum:** | 9.6 | 13.1 | 7.8 | 116.9 | 3,179,803.4 | 1,812.6 | 1.0 | 0.7 |
| **Maximum:** | 11.2 | 13.6 | 8.6 | 147.6 | 3,334,381.4 | 2,132.8 | 1.3 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/15/2014 00:00 | 10.6 | 13.3 | 8.2 | 132.5 | 3,306,087.4 | 2,003.8 | 1.2 | 1.0 |
| 02/15/2014 01:00 | 10.8 | 13.2 | 8.3 | 139.6 | 3,293,624.9 | 2,068.4 | 1.2 | 1.0 |
| 02/15/2014 02:00 | 11.0 | 13.1 | 8.3 | 151.2 | 3,279,846.6 | 2,179.5 | 1.4 | 1.1 |
| 02/15/2014 03:00 | 11.0 | 13.1 | 8.3 | 153.3 | 3,269,351.9 | 2,196.4 | 1.4 | 1.1 |
| 02/15/2014 04:00 | 10.6 | 13.2 | 8.1 | 137.7 | 3,291,451.8 | 2,043.0 | 1.2 | 1.0 |
| 02/15/2014 05:00 | 10.4 | 13.3 | 8.1 | 131.8 | 3,340,393.5 | 2,000.2 | 1.1 | 0.8 |
| 02/15/2014 06:00 | 10.6 | 13.3 | 8.2 | 136.3 | 3,313,028.8 | 2,032.2 | 1.2 | 1.0 |
| 02/15/2014 07:00 | 10.3 | 13.4 | 8.1 | 129.6 | 3,289,290.6 | 1,969.6 | 1.1 | 0.8 |
| 02/15/2014 08:00 | 10.3 | 13.3 | 8.0 | 131.0 | 3,317,848.1 | 1,986.7 | 1.1 | 0.8 |
| 02/15/2014 09:00 | 10.4 | 13.3 | 8.1 | 135.1 | 3,311,887.7 | 2,031.5 | 1.2 | 1.0 |
| 02/15/2014 10:00 | 10.6 | 13.2 | 8.1 | 143.4 | 3,287,707.8 | 2,112.7 | 1.3 | 1.1 |
| 02/15/2014 11:00 | 11.0 | 13.0 | 8.2 | 157.2 | 3,259,377.3 | 2,213.5 | 1.4 | 1.1 |
| 02/15/2014 12:00 | 11.2 | 13.0 | 8.4 | 157.9 | 3,215,233.6 | 2,207.0 | 1.5 | 1.3 |
| 02/15/2014 13:00 | 11.0 | 13.1 | 8.3 | 150.5 | 3,242,375.6 | 2,154.6 | 1.4 | 1.1 |
| 02/15/2014 14:00 | 10.8 | 13.3 | 8.4 | 136.0 | 3,287,759.7 | 2,016.7 | 1.2 | 1.0 |
| 02/15/2014 15:00 | 10.8 | 13.3 | 8.4 | 133.2 | 3,292,063.2 | 1,995.3 | 1.2 | 1.0 |
| 02/15/2014 16:00 | 10.7 | 13.4 | 8.4 | 130.4 | 3,321,953.1 | 1,964.9 | 1.1 | 0.8 |
| 02/15/2014 17:00 | 10.8 | 13.3 | 8.4 | 132.7 | 3,289,423.4 | 1,993.7 | 1.2 | 1.0 |
| 02/15/2014 18:00 | 10.9 | 13.3 | 8.5 | 140.0 | 3,282,478.4 | 2,061.4 | 1.2 | 1.0 |
| 02/15/2014 19:00 | 11.2 | 13.1 | 8.5 | 160.4 | 3,234,786.5 | 2,196.8 | 1.5 | 1.3 |
| 02/15/2014 20:00 | 11.0 | 13.1 | 8.3 | 153.1 | 3,272,322.3 | 2,174.5 | 1.4 | 1.1 |
| 02/15/2014 21:00 | 11.0 | 13.1 | 8.3 | 154.3 | 3,256,550.7 | 2,187.8 | 1.4 | 1.1 |
| 02/15/2014 22:00 | 10.7 | 13.2 | 8.2 | 144.0 | 3,263,587.3 | 2,097.2 | 1.3 | 1.0 |
| 02/15/2014 23:00 | 9.7 | 13.5 | 7.7 | 123.3 | 3,287,658.6 | 1,896.6 | 1.1 | 0.8 |
| **Average/Sum#:** | 10.7 | 13.2 | 8.2 | 141.4 | 3,283,587.0 | 2,074.3 | 1.3 | 1.0 |
| **Minimum:** | 9.7 | 13.0 | 7.7 | 123.3 | 3,215,233.6 | 1,896.6 | 1.1 | 0.8 |
| **Maximum:** | 11.2 | 13.5 | 8.5 | 160.4 | 3,340,393.5 | 2,213.5 | 1.5 | 1.3 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/16/2014 00:00 | 9.5 | 13.6 | 7.7 | 117.8 | 3,303,556.1 | 1,833.4 | 1.0 | 0.7 |
| 02/16/2014 01:00 | 9.9 | 13.7 | 8.1 | 119.4 | 3,330,764.4 | 1,848.5 | 1.0 | 0.7 |
| 02/16/2014 02:00 | 10.3 | 13.6 | 8.3 | 122.8 | 3,344,774.6 | 1,880.7 | 1.0 | 0.8 |
| 02/16/2014 03:00 | 10.2 | 13.7 | 8.4 | 116.2 | 3,148,750.8 | 1,701.5 | 1.1 | 0.7 |
| 02/16/2014 04:00 | 10.8 | 13.8 | 9.0 | 96.9 | 2,492,352.4 | 1,274.0 | 1.1 | 0.5 |
| 02/16/2014 05:00 | 10.5 | 13.8 | 8.7 | 106.0 | 2,840,109.0 | 1,472.5 | 1.1 | 0.6 |
| 02/16/2014 06:00 | 10.5 | 13.7 | 8.6 | 113.8 | 3,082,893.2 | 1,643.4 | 1.0 | 0.7 |
| 02/16/2014 07:00 | 10.7 | 13.4 | 8.4 | 124.9 | 3,424,789.9 | 1,950.7 | 1.0 | 0.8 |
| 02/16/2014 08:00 | 10.3 | 13.6 | 8.3 | 120.2 | 3,413,153.3 | 1,869.3 | 1.0 | 0.7 |
| 02/16/2014 09:00 | 10.0 | 13.8 | 8.3 | 117.4 | 3,473,773.2 | 1,826.4 | 1.0 | 0.7 |
| 02/16/2014 10:00 | 9.9 | 13.8 | 8.2 | 119.0 | 3,452,851.4 | 1,815.4 | 1.0 | 0.7 |
| 02/16/2014 11:00 | 9.9 | 13.8 | 8.2 | 115.0 | 3,451,329.8 | 1,814.6 | 0.9 | 0.5 |
| 02/16/2014 12:00 | 9.9 | 13.8 | 8.2 | 114.5 | 3,452,851.4 | 1,815.4 | 0.9 | 0.5 |
| 02/16/2014 13:00 | 9.9 | 13.8 | 8.2 | 114.3 | 3,446,194.5 | 1,811.9 | 0.9 | 0.5 |
| 02/16/2014 14:00 | 9.9 | 13.8 | 8.2 | 114.1 | 3,453,612.2 | 1,815.8 | 0.9 | 0.5 |
| 02/16/2014 15:00 | 10.2 | 13.7 | 8.4 | 115.5 | 3,437,630.4 | 1,832.5 | 0.9 | 0.5 |
| 02/16/2014 16:00 | 10.0 | 13.8 | 8.3 | 115.9 | 3,464,643.7 | 1,821.6 | 0.9 | 0.5 |
| 02/16/2014 17:00 | 10.1 | 13.8 | 8.4 | 115.1 | 3,477,386.9 | 1,828.3 | 0.9 | 0.5 |
| 02/16/2014 18:00 | 10.4 | 13.6 | 8.4 | 127.3 | 3,375,982.2 | 1,922.9 | 1.1 | 0.8 |
| 02/16/2014 19:00 | 11.3 | 13.2 | 8.7 | 158.8 | 3,325,266.7 | 2,185.4 | 1.4 | 1.1 |
| 02/16/2014 20:00 | 11.6 | 13.2 | 8.9 | 167.9 | 3,315,361.4 | 2,203.1 | 1.5 | 1.3 |
| 02/16/2014 21:00 | 11.6 | 13.2 | 8.9 | 166.5 | 3,314,157.5 | 2,202.3 | 1.5 | 1.3 |
| 02/16/2014 22:00 | 11.5 | 13.2 | 8.8 | 164.5 | 3,316,414.8 | 2,203.8 | 1.5 | 1.3 |
| 02/16/2014 23:00 | 10.8 | 13.4 | 8.5 | 135.3 | 3,346,572.6 | 2,003.9 | 1.2 | 1.0 |
| **Average/Sum#:** | 10.4 | 13.6 | 8.4 | 125.0 | 3,311,882.2 | 1,857.4 | 1.1 | 0.7 |
| **Minimum:** | 9.5 | 13.2 | 7.7 | 96.9 | 2,492,352.4 | 1,274.0 | 0.9 | 0.5 |
| **Maximum:** | 11.6 | 13.8 | 9.0 | 167.9 | 3,477,386.9 | 2,203.8 | 1.5 | 1.3 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/17/2014 00:00 | 10.3 | 13.6 | 8.3 | 120.6 | 3,320,133.4 | 1,842.6 | 1.0 | 0.7 |
| 02/17/2014 01:00 | 10.3 | 13.6 | 8.3 | 120.0 | 3,295,447.7 | 1,828.9 | 1.0 | 0.7 |
| 02/17/2014 02:00 | 10.2 | 13.6 | 8.2 | 118.6 | 3,220,553.0 | 1,740.3 | 1.1 | 0.7 |
| 02/17/2014 03:00 | 10.7 | 13.8 | 8.9 | 97.9 | 2,535,195.8 | 1,295.9 | 1.1 | 0.5 |
| 02/17/2014 04:00 | 10.5 | 13.8 | 8.7 | 99.3 | 2,679,963.5 | 1,369.9 | 1.0 | 0.5 |
| 02/17/2014 05:00 | 10.4 | 13.7 | 8.5 | 110.6 | 2,954,392.4 | 1,574.9 | 1.1 | 0.6 |
| 02/17/2014 06:00 | 10.4 | 13.5 | 8.3 | 126.8 | 3,428,301.3 | 1,952.7 | 1.1 | 0.8 |
| 02/17/2014 07:00 | 10.4 | 13.4 | 8.2 | 139.6 | 3,409,353.2 | 1,991.7 | 1.2 | 1.0 |
| 02/17/2014 08:00 | 10.4 | 13.5 | 8.3 | 128.0 | 3,383,691.6 | 1,952.0 | 1.1 | 0.8 |
| 02/17/2014 09:00 | 10.1 | 13.7 | 8.3 | 122.4 | 3,398,514.9 | 1,886.1 | 1.0 | 0.8 |
| 02/17/2014 10:00 | 10.3 | 13.6 | 8.3 | 119.9 | 3,282,294.0 | 1,821.6 | 1.0 | 0.7 |
| 02/17/2014 11:00 | 10.3 | 13.6 | 8.3 | 119.6 | 3,282,113.8 | 1,821.5 | 1.0 | 0.7 |
| 02/17/2014 12:00 | 10.2 | 13.6 | 8.2 | 119.5 | 3,291,123.2 | 1,826.5 | 1.0 | 0.7 |
| 02/17/2014 13:00 | 10.2 | 13.6 | 8.2 | 119.1 | 3,291,663.8 | 1,826.8 | 1.0 | 0.7 |
| 02/17/2014 14:00 | 10.2 | 13.7 | 8.4 | 119.1 | 3,293,826.0 | 1,828.0 | 1.0 | 0.7 |
| 02/17/2014 15:00 | 10.1 | 13.7 | 8.3 | 119.0 | 3,294,366.6 | 1,828.3 | 1.0 | 0.7 |
| 02/17/2014 16:00 | 10.2 | 13.7 | 8.4 | 118.9 | 3,291,483.6 | 1,826.7 | 1.0 | 0.7 |
| 02/17/2014 17:00 | 10.2 | 13.7 | 8.4 | 119.0 | 3,290,762.8 | 1,826.3 | 1.0 | 0.7 |
| 02/17/2014 18:00 | 10.1 | 13.7 | 8.3 | 120.6 | 3,374,261.7 | 1,848.0 | 1.0 | 0.7 |
| 02/17/2014 19:00 | 10.2 | 13.6 | 8.2 | 123.2 | 3,403,199.8 | 1,888.7 | 1.0 | 0.8 |
| 02/17/2014 20:00 | 10.9 | 13.4 | 8.6 | 136.2 | 3,371,588.8 | 2,043.5 | 1.2 | 1.0 |
| 02/17/2014 21:00 | 11.2 | 13.2 | 8.6 | 155.5 | 3,333,240.5 | 2,166.3 | 1.4 | 1.1 |
| 02/17/2014 22:00 | 10.6 | 13.4 | 8.3 | 133.9 | 3,360,266.8 | 2,012.1 | 1.2 | 1.0 |
| 02/17/2014 23:00 | 10.2 | 13.6 | 8.2 | 123.9 | 3,340,862.0 | 1,878.5 | 1.1 | 0.8 |
| **Average/Sum#:** | 10.4 | 13.6 | 8.4 | 122.1 | 3,255,275.0 | 1,828.2 | 1.1 | 0.8 |
| **Minimum:** | 10.1 | 13.2 | 8.2 | 97.9 | 2,535,195.8 | 1,295.9 | 1.0 | 0.5 |
| **Maximum:** | 11.2 | 13.8 | 8.9 | 155.5 | 3,428,301.3 | 2,166.3 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/18/2014 00:00 | 10.3 | 13.6 | 8.3 | 119.9 | 3,301,934.5 | 1,832.5 | 1.0 | 0.7 |
| 02/18/2014 01:00 | 10.4 | 13.6 | 8.4 | 119.9 | 3,289,321.3 | 1,825.5 | 1.0 | 0.7 |
| 02/18/2014 02:00 | 10.2 | 13.6 | 8.2 | 119.2 | 3,243,579.5 | 1,823.8 | 1.1 | 0.7 |
| 02/18/2014 03:00 | 10.2 | 13.6 | 8.2 | 119.1 | 3,284,996.8 | 1,823.1 | 1.0 | 0.7 |
| 02/18/2014 04:00 | 10.2 | 13.6 | 8.2 | 119.2 | 3,279,411.0 | 1,820.0 | 1.0 | 0.7 |
| 02/18/2014 05:00 | 10.2 | 13.6 | 8.2 | 119.2 | 3,237,888.4 | 1,820.6 | 1.1 | 0.7 |
| 02/18/2014 06:00 | 10.2 | 13.6 | 8.2 | 121.3 | 3,313,117.8 | 1,862.9 | 1.0 | 0.7 |
| 02/18/2014 07:00 | 10.5 | 13.4 | 8.3 | 137.5 | 3,290,042.1 | 2,018.1 | 1.2 | 1.0 |
| 02/18/2014 08:00 | 10.9 | 13.3 | 8.5 | 144.6 | 3,356,539.7 | 2,083.4 | 1.3 | 1.0 |
| 02/18/2014 09:00 | 10.4 | 13.4 | 8.2 | 128.9 | 3,385,251.7 | 1,952.9 | 1.1 | 0.8 |
| 02/18/2014 10:00 | 10.4 | 13.4 | 8.2 | 128.4 | 3,376,064.5 | 1,947.6 | 1.1 | 0.8 |
| 02/18/2014 11:00 | 10.6 | 13.4 | 8.3 | 130.6 | 3,330,874.3 | 1,994.5 | 1.1 | 0.8 |
| 02/18/2014 12:00 | 11.0 | 13.3 | 8.5 | 141.9 | 3,315,474.2 | 2,033.7 | 1.2 | 1.0 |
| 02/18/2014 13:00 | 10.8 | 13.4 | 8.5 | 130.6 | 3,330,268.9 | 1,945.5 | 1.1 | 0.8 |
| 02/18/2014 14:00 | 10.1 | 13.7 | 8.3 | 122.0 | 3,289,141.1 | 1,825.4 | 1.1 | 0.7 |
| 02/18/2014 15:00 | 10.1 | 13.6 | 8.2 | 120.5 | 3,308,961.8 | 1,836.4 | 1.0 | 0.7 |
| 02/18/2014 16:00 | 10.1 | 13.7 | 8.3 | 118.5 | 3,241,571.7 | 1,799.0 | 1.0 | 0.7 |
| 02/18/2014 17:00 | 10.7 | 13.5 | 8.5 | 128.3 | 3,293,636.8 | 1,924.1 | 1.1 | 0.8 |
| 02/18/2014 18:00 | 11.5 | 13.2 | 8.8 | 158.5 | 3,256,947.7 | 2,140.5 | 1.4 | 1.1 |
| 02/18/2014 19:00 | 11.6 | 13.1 | 8.8 | 167.8 | 3,230,958.0 | 2,194.2 | 1.5 | 1.3 |
| 02/18/2014 20:00 | 11.0 | 13.3 | 8.5 | 137.8 | 3,313,517.9 | 2,032.5 | 1.2 | 1.0 |
| 02/18/2014 21:00 | 11.4 | 13.2 | 8.7 | 159.3 | 3,256,220.3 | 2,163.8 | 1.4 | 1.1 |
| 02/18/2014 22:00 | 10.2 | 13.5 | 8.1 | 122.4 | 3,347,442.3 | 1,882.2 | 1.0 | 0.8 |
| 02/18/2014 23:00 | 10.0 | 13.8 | 8.3 | 106.7 | 3,000,196.7 | 1,555.5 | 1.0 | 0.6 |
| **Average/Sum#:** | 10.5 | 13.5 | 8.4 | 130.1 | 3,286,390.0 | 1,922.4 | 1.1 | 0.8 |
| **Minimum:** | 10.0 | 13.1 | 8.1 | 106.7 | 3,000,196.7 | 1,555.5 | 1.0 | 0.6 |
| **Maximum:** | 11.6 | 13.8 | 8.8 | 167.8 | 3,385,251.7 | 2,194.2 | 1.5 | 1.3 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/19/2014 00:00 | 10.5 | 13.8 | 8.7 | 95.5 | 2,415,664.6 | 1,234.8 | 1.1 | 0.5 |
| 02/19/2014 01:00 | 10.5 | 13.8 | 8.7 | 102.5 | 2,730,632.2 | 1,395.8 | 1.1 | 0.6 |
| 02/19/2014 02:00 | 41.0 | 15.3 | 43.2 | 215.2 | 1,741,257.9 | 750.2 | 3.3 | 1.0 |
| 02/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 12:00 | 48.6 | 17.2 | 77.5 | 7.9 | 2,034,803.5 | 505.2 | 0.0 | 0.0 |
| 02/19/2014 13:00 | 63.5 | 16.8 | 91.4 | 292.4 | 1,946,979.1 | 568.7 | 3.5 | 0.7 |
| 02/19/2014 14:00 | 57.4 | 15.2 | 59.4 | 275.1 | 2,188,633.6 | 895.0 | 3.3 | 1.2 |
| 02/19/2014 15:00 | 11.2 | 13.9 | 9.4 | 105.9 | 2,511,133.1 | 1,283.6 | 1.2 | 0.6 |
| 02/19/2014 16:00 | 10.8 | 13.8 | 9.0 | 111.1 | 3,106,245.8 | 1,587.8 | 1.0 | 0.6 |
| 02/19/2014 17:00 | 10.4 | 13.8 | 8.6 | 124.3 | 3,371,718.5 | 1,723.5 | 1.0 | 0.7 |
| 02/19/2014 18:00 | 10.3 | 13.8 | 8.6 | 109.7 | 3,078,311.7 | 1,596.0 | 1.0 | 0.6 |
| 02/19/2014 19:00 | 10.2 | 13.7 | 8.4 | 119.5 | 3,428,372.5 | 1,852.6 | 1.0 | 0.7 |
| 02/19/2014 20:00 | 11.5 | 13.2 | 8.8 | 161.7 | 3,340,933.9 | 2,171.3 | 1.4 | 1.1 |
| 02/19/2014 21:00 | 11.7 | 13.1 | 8.9 | 176.2 | 3,309,094.9 | 2,223.1 | 1.6 | 1.3 |
| 02/19/2014 22:00 | 11.3 | 13.3 | 8.8 | 155.0 | 3,348,478.7 | 2,127.3 | 1.4 | 1.1 |
| 02/19/2014 23:00 | 10.2 | 13.7 | 8.4 | 119.6 | 3,426,521.9 | 1,851.6 | 1.0 | 0.7 |
| **Average/Sum#:** | 21.9 | 14.3 | 24.5 | 144.8 | 2,798,585.5 | 1,451.1 | 1.5 | 0.8 |
| **Minimum:** | 10.2 | 13.1 | 8.4 | 7.9 | 1,741,257.9 | 505.2 | 0.0 | 0.0 |
| **Maximum:** | 63.5 | 17.2 | 91.4 | 292.4 | 3,428,372.5 | 2,223.1 | 3.5 | 1.3 |
| **%SI** | 37.5 | 37.5 | 37.5 | 37.5 | 37.5 | 37.5 | 37.5 | 37.5 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/20/2014 00:00 | 9.9 | 13.8 | 8.2 | 118.5 | 3,423,941.4 | 1,800.2 | 1.0 | 0.7 |
| 02/20/2014 01:00 | 10.7 | 13.9 | 9.0 | 97.6 | 2,471,028.5 | 1,263.1 | 1.1 | 0.5 |
| 02/20/2014 02:00 | 10.8 | 13.9 | 9.1 | 96.1 | 2,422,120.5 | 1,238.1 | 1.1 | 0.5 |
| 02/20/2014 03:00 | 10.8 | 13.9 | 9.1 | 96.3 | 2,420,751.0 | 1,237.4 | 1.1 | 0.5 |
| 02/20/2014 04:00 | 10.9 | 13.8 | 9.1 | 96.5 | 2,453,421.6 | 1,254.1 | 1.1 | 0.5 |
| 02/20/2014 05:00 | 10.7 | 13.8 | 8.9 | 97.2 | 2,554,954.6 | 1,306.0 | 1.1 | 0.5 |
| 02/20/2014 06:00 | 10.7 | 13.5 | 8.5 | 127.2 | 3,296,801.4 | 1,877.8 | 1.1 | 0.8 |
| 02/20/2014 07:00 | 10.9 | 13.3 | 8.5 | 128.0 | 3,458,895.5 | 2,045.9 | 1.1 | 0.8 |
| 02/20/2014 08:00 | 11.1 | 13.3 | 8.6 | 152.8 | 3,377,860.4 | 2,121.3 | 1.3 | 1.1 |
| 02/20/2014 09:00 | 10.3 | 13.6 | 8.3 | 122.5 | 3,296,755.8 | 1,853.7 | 1.1 | 0.7 |
| 02/20/2014 10:00 | 10.3 | 13.6 | 8.3 | 119.4 | 3,265,356.4 | 1,812.2 | 1.0 | 0.7 |
| 02/20/2014 11:00 | 10.2 | 13.7 | 8.4 | 119.1 | 3,272,744.1 | 1,816.3 | 1.0 | 0.7 |
| 02/20/2014 12:00 | 10.1 | 13.7 | 8.3 | 118.7 | 3,284,996.8 | 1,823.1 | 1.0 | 0.7 |
| 02/20/2014 13:00 | 10.8 | 13.5 | 8.6 | 127.6 | 3,394,265.7 | 1,958.1 | 1.1 | 0.8 |
| 02/20/2014 14:00 | 10.1 | 13.7 | 8.3 | 120.9 | 3,370,244.7 | 1,845.8 | 1.0 | 0.7 |
| 02/20/2014 15:00 | 10.7 | 13.5 | 8.5 | 127.5 | 3,369,304.0 | 1,943.7 | 1.1 | 0.8 |
| 02/20/2014 16:00 | 11.6 | 13.3 | 9.0 | 155.5 | 3,316,368.1 | 2,106.9 | 1.4 | 1.1 |
| 02/20/2014 17:00 | 12.1 | 13.1 | 9.2 | 187.4 | 3,260,978.2 | 2,238.4 | 1.7 | 1.6 |
| 02/20/2014 18:00 | 11.7 | 13.2 | 9.0 | 164.3 | 3,275,358.8 | 2,152.6 | 1.5 | 1.3 |
| 02/20/2014 19:00 | 11.9 | 13.1 | 9.0 | 184.2 | 3,267,242.6 | 2,242.7 | 1.7 | 1.6 |
| 02/20/2014 20:00 | 11.9 | 13.1 | 9.0 | 191.8 | 3,247,409.7 | 2,252.8 | 1.8 | 1.6 |
| 02/20/2014 21:00 | 11.8 | 13.1 | 8.9 | 182.2 | 3,247,866.7 | 2,229.4 | 1.7 | 1.6 |
| 02/20/2014 22:00 | 11.8 | 13.1 | 8.9 | 182.1 | 3,259,667.1 | 2,237.5 | 1.7 | 1.6 |
| 02/20/2014 23:00 | 11.6 | 13.2 | 8.9 | 165.7 | 3,267,657.3 | 2,171.4 | 1.5 | 1.3 |
| **Average/Sum#:** | 11.0 | 13.5 | 8.7 | 136.6 | 3,136,499.6 | 1,867.9 | 1.3 | 0.9 |
| **Minimum:** | 9.9 | 13.1 | 8.2 | 96.1 | 2,420,751.0 | 1,237.4 | 1.0 | 0.5 |
| **Maximum:** | 12.1 | 13.9 | 9.2 | 191.8 | 3,458,895.5 | 2,252.8 | 1.8 | 1.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/21/2014 00:00 | 11.1 | 13.3 | 8.6 | 139.1 | 3,320,365.1 | 2,036.7 | 1.2 | 1.0 |
| 02/21/2014 01:00 | 10.0 | 13.7 | 8.2 | 118.3 | 3,412,642.6 | 1,844.1 | 1.0 | 0.7 |
| 02/21/2014 02:00 | 9.8 | 13.8 | 8.1 | 114.4 | 3,380,977.5 | 1,802.3 | 1.0 | 0.7 |
| 02/21/2014 03:00 | 9.8 | 13.8 | 8.1 | 114.4 | 3,381,540.3 | 1,802.6 | 1.0 | 0.7 |
| 02/21/2014 04:00 | 9.8 | 13.8 | 8.1 | 114.1 | 3,430,027.7 | 1,803.4 | 0.9 | 0.5 |
| 02/21/2014 05:00 | 9.8 | 13.8 | 8.1 | 114.0 | 3,431,929.7 | 1,804.4 | 0.9 | 0.5 |
| 02/21/2014 06:00 | 9.9 | 13.7 | 8.1 | 115.0 | 3,425,624.5 | 1,826.1 | 1.0 | 0.7 |
| 02/21/2014 07:00 | 10.6 | 13.4 | 8.3 | 127.9 | 3,314,675.0 | 1,984.8 | 1.1 | 0.8 |
| 02/21/2014 08:00 | 11.3 | 13.2 | 8.7 | 162.0 | 3,306,551.3 | 2,173.1 | 1.4 | 1.1 |
| 02/21/2014 09:00 | 10.7 | 13.4 | 8.4 | 125.6 | 3,368,959.6 | 1,918.9 | 1.1 | 0.8 |
| 02/21/2014 10:00 | 9.8 | 13.7 | 8.0 | 114.4 | 3,409,491.5 | 1,817.5 | 1.0 | 0.7 |
| 02/21/2014 11:00 | 10.2 | 13.6 | 8.2 | 116.6 | 3,404,685.1 | 1,839.8 | 1.0 | 0.7 |
| 02/21/2014 12:00 | 9.5 | 13.7 | 7.8 | 113.5 | 3,415,494.5 | 1,820.7 | 0.9 | 0.5 |
| 02/21/2014 13:00 | 10.1 | 13.6 | 8.2 | 115.2 | 3,375,816.2 | 1,824.2 | 1.0 | 0.7 |
| 02/21/2014 14:00 | 10.9 | 13.6 | 8.8 | 117.3 | 3,394,321.9 | 1,834.2 | 1.0 | 0.7 |
| 02/21/2014 15:00 | 10.9 | 13.6 | 8.8 | 117.4 | 3,388,955.2 | 1,831.3 | 1.0 | 0.7 |
| 02/21/2014 16:00 | 11.0 | 13.6 | 8.9 | 117.4 | 3,382,848.3 | 1,828.0 | 1.0 | 0.7 |
| 02/21/2014 17:00 | 11.0 | 13.6 | 8.9 | 118.6 | 3,360,202.3 | 1,840.3 | 1.0 | 0.7 |
| 02/21/2014 18:00 | 11.2 | 13.4 | 8.8 | 133.9 | 3,344,401.6 | 2,002.6 | 1.2 | 1.0 |
| 02/21/2014 19:00 | 11.4 | 13.3 | 8.9 | 158.6 | 3,284,751.1 | 2,110.8 | 1.4 | 1.1 |
| 02/21/2014 20:00 | 11.5 | 13.2 | 8.8 | 161.8 | 3,300,928.2 | 2,145.3 | 1.4 | 1.1 |
| 02/21/2014 21:00 | 11.6 | 13.1 | 8.8 | 175.4 | 3,291,530.6 | 2,211.3 | 1.6 | 1.3 |
| 02/21/2014 22:00 | 11.4 | 13.2 | 8.7 | 160.5 | 3,283,848.9 | 2,134.2 | 1.4 | 1.1 |
| 02/21/2014 23:00 | 11.2 | 13.3 | 8.7 | 141.5 | 3,330,279.0 | 2,067.1 | 1.2 | 1.0 |
| **Average/Sum#:** | 10.6 | 13.5 | 8.5 | 129.5 | 3,364,202.0 | 1,929.3 | 1.1 | 0.8 |
| **Minimum:** | 9.5 | 13.1 | 7.8 | 113.5 | 3,283,848.9 | 1,802.3 | 0.9 | 0.5 |
| **Maximum:** | 11.6 | 13.8 | 8.9 | 175.4 | 3,431,929.7 | 2,211.3 | 1.6 | 1.3 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/22/2014 00:00 | 11.1 | 13.3 | 8.6 | 140.5 | 3,334,874.4 | 2,045.6 | 1.2 | 1.0 |
| 02/22/2014 01:00 | 10.8 | 13.4 | 8.5 | 132.4 | 3,373,517.8 | 1,995.4 | 1.1 | 0.8 |
| 02/22/2014 02:00 | 9.9 | 13.7 | 8.1 | 116.1 | 3,308,601.4 | 1,836.2 | 1.0 | 0.7 |
| 02/22/2014 03:00 | 10.6 | 13.5 | 8.5 | 129.7 | 3,359,711.5 | 1,962.7 | 1.1 | 0.8 |
| 02/22/2014 04:00 | 10.8 | 13.4 | 8.5 | 132.7 | 3,338,014.2 | 1,974.4 | 1.1 | 0.8 |
| 02/22/2014 05:00 | 10.3 | 13.6 | 8.3 | 124.0 | 3,373,763.7 | 1,897.0 | 1.0 | 0.8 |
| 02/22/2014 06:00 | 10.7 | 13.4 | 8.4 | 132.6 | 3,389,917.1 | 2,005.1 | 1.1 | 0.8 |
| 02/22/2014 07:00 | 10.7 | 13.4 | 8.4 | 130.0 | 3,393,129.3 | 2,007.0 | 1.1 | 0.8 |
| 02/22/2014 08:00 | 10.8 | 13.4 | 8.5 | 131.7 | 3,359,992.6 | 1,987.4 | 1.1 | 0.8 |
| 02/22/2014 09:00 | 10.1 | 13.7 | 8.3 | 121.1 | 3,342,656.8 | 1,855.1 | 1.0 | 0.7 |
| 02/22/2014 10:00 | 9.9 | 13.7 | 8.1 | 119.2 | 3,350,890.2 | 1,835.2 | 1.0 | 0.7 |
| 02/22/2014 11:00 | 10.0 | 13.7 | 8.2 | 118.0 | 3,364,767.0 | 1,842.8 | 1.0 | 0.7 |
| 02/22/2014 12:00 | 10.1 | 13.7 | 8.3 | 119.5 | 3,385,217.1 | 1,854.0 | 1.0 | 0.7 |
| 02/22/2014 13:00 | 9.9 | 13.8 | 8.2 | 121.4 | 3,358,741.5 | 1,839.5 | 1.0 | 0.7 |
| 02/22/2014 14:00 | 10.6 | 13.5 | 8.5 | 125.5 | 3,323,541.0 | 1,917.3 | 1.1 | 0.8 |
| 02/22/2014 15:00 | 11.3 | 13.4 | 8.9 | 133.9 | 3,298,809.7 | 1,975.3 | 1.2 | 1.0 |
| 02/22/2014 16:00 | 11.0 | 13.5 | 8.8 | 125.2 | 3,304,701.9 | 1,882.3 | 1.1 | 0.8 |
| 02/22/2014 17:00 | 10.0 | 13.7 | 8.2 | 119.3 | 3,315,088.1 | 1,839.8 | 1.0 | 0.7 |
| 02/22/2014 18:00 | 11.2 | 13.4 | 8.8 | 153.0 | 3,238,688.7 | 2,033.9 | 1.4 | 1.0 |
| 02/22/2014 19:00 | 11.4 | 13.3 | 8.9 | 148.4 | 3,239,711.8 | 2,058.2 | 1.3 | 1.0 |
| 02/22/2014 20:00 | 11.9 | 13.1 | 9.0 | 183.2 | 3,199,354.1 | 2,196.1 | 1.7 | 1.5 |
| 02/22/2014 21:00 | 11.9 | 13.1 | 9.0 | 192.0 | 3,196,236.5 | 2,217.3 | 1.8 | 1.6 |
| 02/22/2014 22:00 | 12.0 | 13.1 | 9.1 | 192.8 | 3,205,750.4 | 2,223.9 | 1.8 | 1.6 |
| 02/22/2014 23:00 | 11.9 | 13.1 | 9.0 | 187.2 | 3,215,408.5 | 2,230.6 | 1.7 | 1.6 |
| **Average/Sum#:** | 10.8 | 13.5 | 8.5 | 138.7 | 3,315,461.9 | 1,979.7 | 1.2 | 0.9 |
| **Minimum:** | 9.9 | 13.1 | 8.1 | 116.1 | 3,196,236.5 | 1,835.2 | 1.0 | 0.7 |
| **Maximum:** | 12.0 | 13.8 | 9.1 | 192.8 | 3,393,129.3 | 2,230.6 | 1.8 | 1.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/23/2014 00:00 | 11.3 | 13.2 | 8.7 | 168.3 | 3,295,647.7 | 2,190.0 | 1.5 | 1.3 |
| 02/23/2014 01:00 | 11.2 | 13.3 | 8.7 | 152.5 | 3,301,246.5 | 2,121.4 | 1.4 | 1.1 |
| 02/23/2014 02:00 | 11.6 | 13.1 | 8.8 | 179.2 | 3,295,400.7 | 2,213.9 | 1.6 | 1.3 |
| 02/23/2014 03:00 | 11.5 | 13.1 | 8.7 | 175.0 | 3,275,574.8 | 2,224.5 | 1.6 | 1.3 |
| 02/23/2014 04:00 | 11.0 | 13.3 | 8.5 | 149.3 | 3,300,942.4 | 2,097.1 | 1.3 | 1.0 |
| 02/23/2014 05:00 | 10.6 | 13.4 | 8.3 | 132.7 | 3,374,025.0 | 1,995.7 | 1.1 | 0.8 |
| 02/23/2014 06:00 | 10.7 | 13.4 | 8.4 | 134.0 | 3,359,097.8 | 2,011.4 | 1.2 | 1.0 |
| 02/23/2014 07:00 | 10.6 | 13.4 | 8.3 | 138.2 | 3,423,214.3 | 1,974.8 | 1.2 | 1.0 |
| 02/23/2014 08:00 | 10.5 | 13.4 | 8.3 | 129.1 | 3,394,612.4 | 1,958.3 | 1.1 | 0.8 |
| 02/23/2014 09:00 | 10.4 | 13.5 | 8.3 | 127.6 | 3,366,703.8 | 1,942.2 | 1.1 | 0.8 |
| 02/23/2014 10:00 | 10.0 | 13.7 | 8.2 | 117.5 | 3,365,453.0 | 1,818.6 | 1.0 | 0.7 |
| 02/23/2014 11:00 | 10.4 | 13.6 | 8.4 | 121.2 | 3,360,675.6 | 1,865.1 | 1.0 | 0.7 |
| 02/23/2014 12:00 | 10.7 | 13.5 | 8.5 | 124.4 | 3,368,961.8 | 1,894.3 | 1.1 | 0.8 |
| 02/23/2014 13:00 | 9.8 | 13.7 | 8.0 | 117.0 | 3,379,147.2 | 1,826.0 | 1.0 | 0.7 |
| 02/23/2014 14:00 | 9.9 | 13.7 | 8.1 | 116.8 | 3,337,561.1 | 1,827.9 | 1.0 | 0.7 |
| 02/23/2014 15:00 | 10.1 | 13.6 | 8.2 | 117.6 | 3,338,656.6 | 1,828.5 | 1.0 | 0.7 |
| 02/23/2014 16:00 | 10.8 | 13.5 | 8.6 | 123.2 | 3,278,015.7 | 1,867.1 | 1.1 | 0.7 |
| 02/23/2014 17:00 | 10.5 | 13.5 | 8.4 | 125.6 | 3,297,712.6 | 1,902.4 | 1.1 | 0.8 |
| 02/23/2014 18:00 | 11.5 | 13.3 | 8.9 | 155.3 | 3,241,801.0 | 2,083.2 | 1.4 | 1.0 |
| 02/23/2014 19:00 | 11.7 | 13.2 | 9.0 | 177.5 | 3,215,938.6 | 2,184.0 | 1.6 | 1.3 |
| 02/23/2014 20:00 | 11.6 | 13.2 | 8.9 | 169.2 | 3,227,524.9 | 2,168.3 | 1.5 | 1.3 |
| 02/23/2014 21:00 | 11.5 | 13.2 | 8.8 | 167.3 | 3,229,311.1 | 2,169.5 | 1.5 | 1.3 |
| 02/23/2014 22:00 | 11.5 | 13.2 | 8.8 | 166.2 | 3,263,293.2 | 2,168.5 | 1.5 | 1.3 |
| 02/23/2014 23:00 | 11.3 | 13.2 | 8.7 | 159.2 | 3,267,446.6 | 2,147.4 | 1.4 | 1.1 |
| **Average/Sum#:** | 10.9 | 13.4 | 8.5 | 143.5 | 3,314,915.2 | 2,020.0 | 1.3 | 1.0 |
| **Minimum:** | 9.8 | 13.1 | 8.0 | 116.8 | 3,215,938.6 | 1,818.6 | 1.0 | 0.7 |
| **Maximum:** | 11.7 | 13.7 | 9.0 | 179.2 | 3,423,214.3 | 2,224.5 | 1.6 | 1.3 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/24/2014 00:00 | 10.6 | 13.4 | 8.3 | 131.1 | 3,333,956.6 | 1,972.0 | 1.1 | 0.8 |
| 02/24/2014 01:00 | 9.9 | 13.7 | 8.1 | 116.9 | 3,348,982.8 | 1,809.7 | 1.0 | 0.7 |
| 02/24/2014 02:00 | 9.8 | 13.7 | 8.0 | 115.7 | 3,302,563.9 | 1,760.5 | 1.0 | 0.7 |
| 02/24/2014 03:00 | 10.5 | 13.9 | 8.9 | 94.5 | 2,439,140.5 | 1,246.8 | 1.1 | 0.5 |
| 02/24/2014 04:00 | 10.8 | 13.9 | 9.1 | 94.3 | 2,388,080.5 | 1,220.7 | 1.1 | 0.5 |
| 02/24/2014 05:00 | 10.5 | 13.8 | 8.7 | 107.1 | 2,867,042.1 | 1,507.4 | 1.1 | 0.6 |
| 02/24/2014 06:00 | 10.2 | 13.6 | 8.2 | 121.1 | 3,342,296.4 | 1,854.9 | 1.0 | 0.7 |
| 02/24/2014 07:00 | 10.4 | 13.4 | 8.2 | 121.7 | 3,371,066.4 | 1,920.1 | 1.0 | 0.8 |
| 02/24/2014 08:00 | 10.6 | 13.3 | 8.2 | 136.7 | 3,368,289.0 | 2,041.5 | 1.2 | 1.0 |
| 02/24/2014 09:00 | 10.2 | 13.5 | 8.1 | 124.5 | 3,392,615.5 | 1,907.6 | 1.1 | 0.8 |
| 02/24/2014 10:00 | 9.8 | 13.8 | 8.1 | 114.2 | 3,431,359.1 | 1,804.1 | 0.9 | 0.5 |
| 02/24/2014 11:00 | 10.3 | 13.6 | 8.3 | 117.2 | 3,396,912.7 | 1,835.6 | 1.0 | 0.7 |
| 02/24/2014 12:00 | 9.8 | 13.7 | 8.0 | 113.7 | 3,381,540.3 | 1,802.6 | 1.0 | 0.7 |
| 02/24/2014 13:00 | 9.5 | 13.7 | 7.8 | 112.8 | 3,374,599.3 | 1,798.9 | 0.9 | 0.5 |
| 02/24/2014 14:00 | 10.2 | 13.6 | 8.2 | 114.5 | 3,341,950.7 | 1,805.9 | 1.0 | 0.7 |
| 02/24/2014 15:00 | 11.1 | 13.4 | 8.7 | 130.5 | 3,249,042.9 | 1,945.5 | 1.2 | 1.0 |
| 02/24/2014 16:00 | 11.3 | 13.4 | 8.9 | 131.2 | 3,279,517.8 | 1,939.8 | 1.1 | 0.8 |
| 02/24/2014 17:00 | 11.5 | 13.3 | 8.9 | 146.1 | 3,248,596.9 | 2,016.4 | 1.3 | 1.0 |
| 02/24/2014 18:00 | 11.7 | 13.3 | 9.1 | 164.0 | 3,202,779.3 | 2,104.9 | 1.5 | 1.3 |
| 02/24/2014 19:00 | 11.9 | 13.1 | 9.0 | 180.8 | 3,184,057.4 | 2,185.6 | 1.7 | 1.5 |
| 02/24/2014 20:00 | 11.8 | 13.2 | 9.0 | 174.8 | 3,219,338.1 | 2,162.8 | 1.6 | 1.3 |
| 02/24/2014 21:00 | 11.7 | 13.2 | 9.0 | 166.3 | 3,222,360.9 | 2,141.3 | 1.5 | 1.3 |
| 02/24/2014 22:00 | 11.5 | 13.2 | 8.8 | 161.9 | 3,253,904.5 | 2,138.5 | 1.5 | 1.3 |
| 02/24/2014 23:00 | 11.4 | 13.2 | 8.7 | 160.8 | 3,262,729.7 | 2,144.3 | 1.5 | 1.3 |
| **Average/Sum#:** | 10.7 | 13.5 | 8.5 | 131.4 | 3,216,780.1 | 1,877.8 | 1.2 | 0.9 |
| **Minimum:** | 9.5 | 13.1 | 7.8 | 94.3 | 2,388,080.5 | 1,220.7 | 0.9 | 0.5 |
| **Maximum:** | 11.9 | 13.9 | 9.1 | 180.8 | 3,431,359.1 | 2,185.6 | 1.7 | 1.5 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/25/2014 00:00 | 10.8 | 13.4 | 8.5 | 135.9 | 3,355,256.7 | 2,009.1 | 1.2 | 1.0 |
| 02/25/2014 01:00 | 10.5 | 13.4 | 8.3 | 127.8 | 3,360,636.8 | 1,938.7 | 1.1 | 0.8 |
| 02/25/2014 02:00 | 9.9 | 13.7 | 8.1 | 119.0 | 3,305,060.1 | 1,810.1 | 1.0 | 0.7 |
| 02/25/2014 03:00 | 9.9 | 13.7 | 8.1 | 120.5 | 3,293,556.9 | 1,803.8 | 1.0 | 0.7 |
| 02/25/2014 04:00 | 10.0 | 13.7 | 8.2 | 118.0 | 3,289,357.4 | 1,801.5 | 1.0 | 0.7 |
| 02/25/2014 05:00 | 10.7 | 13.4 | 8.4 | 130.3 | 3,325,334.3 | 1,966.9 | 1.1 | 0.8 |
| 02/25/2014 06:00 | 10.9 | 13.4 | 8.6 | 133.8 | 3,331,709.3 | 1,995.0 | 1.2 | 1.0 |
| 02/25/2014 07:00 | 10.5 | 13.5 | 8.4 | 137.3 | 3,369,486.3 | 1,919.2 | 1.2 | 1.0 |
| 02/25/2014 08:00 | 10.6 | 13.4 | 8.3 | 137.6 | 3,331,589.7 | 1,970.6 | 1.2 | 1.0 |
| 02/25/2014 09:00 | 10.0 | 13.7 | 8.2 | 119.4 | 3,295,748.0 | 1,805.0 | 1.0 | 0.7 |
| 02/25/2014 10:00 | 9.9 | 13.7 | 8.1 | 122.9 | 1,180,260.4 | 1,801.3 | 3.2 | 2.2 |
| 02/25/2014 11:00 | 9.7 | 13.7 | 7.9 | 125.4 | 1,178,425.7 | 1,798.5 | 3.3 | 2.3 |
| 02/25/2014 12:00 | 9.7 | 13.7 | 7.9 | 124.3 | 1,184,846.9 | 1,808.3 | 3.3 | 2.4 |
| 02/25/2014 13:00 | 10.2 | 13.6 | 8.2 | 126.8 | 1,194,806.4 | 1,823.5 | 3.3 | 2.4 |
| 02/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 126.9 | 3,379,476.8 | 1,801.5 | 1.2 | 0.9 |
| 02/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 126.8 | 3,379,101.6 | 1,801.3 | 1.2 | 0.9 |
| 02/25/2014 16:00 | 9.6 | 13.6 | 7.8 | 118.1 | 3,324,638.1 | 1,845.1 | 1.0 | 0.7 |
| 02/25/2014 17:00 | 9.3 | 13.7 | 7.6 | 115.3 | 3,321,675.8 | 1,819.2 | 1.0 | 0.7 |
| 02/25/2014 18:00 | 10.1 | 13.4 | 7.9 | 126.6 | 3,317,259.4 | 1,937.9 | 1.1 | 0.8 |
| 02/25/2014 19:00 | 10.8 | 13.2 | 8.3 | 143.3 | 3,255,184.0 | 2,091.8 | 1.3 | 1.0 |
| 02/25/2014 20:00 | 10.9 | 13.2 | 8.4 | 150.9 | 3,239,449.5 | 2,129.0 | 1.4 | 1.1 |
| 02/25/2014 21:00 | 10.7 | 13.3 | 8.3 | 137.7 | 3,286,779.6 | 2,040.1 | 1.2 | 1.0 |
| 02/25/2014 22:00 | 10.2 | 13.4 | 8.0 | 126.3 | 3,343,128.9 | 1,928.6 | 1.1 | 0.8 |
| 02/25/2014 23:00 | 10.8 | 13.2 | 8.3 | 146.8 | 3,289,419.6 | 2,113.8 | 1.3 | 1.1 |
| **Average/Sum#:** | 10.3 | 13.5 | 8.2 | 129.1 | 3,319,692.4 | 1,906.7 | 1.1 | 0.9 |
| **Minimum:** | 9.3 | 13.2 | 7.6 | 115.3 | 3,239,449.5 | 1,798.5 | 1.0 | 0.7 |
| **Maximum:** | 10.9 | 13.7 | 8.6 | 150.9 | 3,379,476.8 | 2,129.0 | 1.4 | 1.1 |
| **%SI** | 8.3 | 8.3 | 8.3 | 0.0 | 16.7 | 0.0 | 25.0 | 25.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/26/2014 00:00 | 10.1 | 13.5 | 8.1 | 126.1 | 3,314,873.7 | 1,912.3 | 1.1 | 0.8 |
| 02/26/2014 01:00 | 10.0 | 13.6 | 8.1 | 120.7 | 3,335,629.5 | 1,851.2 | 1.0 | 0.7 |
| 02/26/2014 02:00 | 9.9 | 13.6 | 8.0 | 120.5 | 3,294,006.2 | 1,828.1 | 1.1 | 0.7 |
| 02/26/2014 03:00 | 9.9 | 13.6 | 8.0 | 120.3 | 3,285,357.2 | 1,823.3 | 1.1 | 0.7 |
| 02/26/2014 04:00 | 9.8 | 13.6 | 7.9 | 118.9 | 3,272,563.9 | 1,816.2 | 1.0 | 0.7 |
| 02/26/2014 05:00 | 9.8 | 13.6 | 7.9 | 119.9 | 3,298,356.4 | 1,854.6 | 1.0 | 0.7 |
| 02/26/2014 06:00 | 10.7 | 13.3 | 8.3 | 139.2 | 3,309,818.2 | 2,054.4 | 1.2 | 1.0 |
| 02/26/2014 07:00 | 10.8 | 13.2 | 8.3 | 157.9 | 3,303,851.7 | 2,147.2 | 1.4 | 1.1 |
| 02/26/2014 08:00 | 11.1 | 13.1 | 8.4 | 168.6 | 3,270,010.6 | 2,244.6 | 1.5 | 1.3 |
| 02/26/2014 09:00 | 11.0 | 13.1 | 8.3 | 164.5 | 3,272,924.3 | 2,246.6 | 1.5 | 1.3 |
| 02/26/2014 10:00 | 11.0 | 13.0 | 8.2 | 167.9 | 3,289,969.2 | 2,258.3 | 1.5 | 1.4 |
| 02/26/2014 11:00 | 11.0 | 13.1 | 8.3 | 166.6 | 3,256,753.4 | 2,235.5 | 1.5 | 1.3 |
| 02/26/2014 12:00 | 10.6 | 13.2 | 8.1 | 147.8 | 3,280,771.5 | 2,132.2 | 1.3 | 1.1 |
| 02/26/2014 13:00 | 10.7 | 13.2 | 8.2 | 149.8 | 3,270,641.9 | 2,149.5 | 1.3 | 1.1 |
| 02/26/2014 14:00 | 10.5 | 13.3 | 8.2 | 138.9 | 3,293,147.2 | 2,068.1 | 1.2 | 1.0 |
| 02/26/2014 15:00 | 10.4 | 13.3 | 8.1 | 137.3 | 3,297,573.9 | 2,046.8 | 1.2 | 1.0 |
| 02/26/2014 16:00 | 10.2 | 13.3 | 7.9 | 131.1 | 3,332,544.3 | 1,995.5 | 1.1 | 0.8 |
| 02/26/2014 17:00 | 10.5 | 13.2 | 8.0 | 143.5 | 3,288,019.1 | 2,112.9 | 1.3 | 1.1 |
| 02/26/2014 18:00 | 10.5 | 13.2 | 8.0 | 147.1 | 3,261,208.1 | 2,143.3 | 1.3 | 1.1 |
| 02/26/2014 19:00 | 10.8 | 13.0 | 8.1 | 163.8 | 3,234,724.5 | 2,244.0 | 1.5 | 1.3 |
| 02/26/2014 20:00 | 10.8 | 13.1 | 8.2 | 159.4 | 3,243,787.6 | 2,226.6 | 1.5 | 1.3 |
| 02/26/2014 21:00 | 10.7 | 13.1 | 8.1 | 153.7 | 3,232,577.8 | 2,195.3 | 1.4 | 1.1 |
| 02/26/2014 22:00 | 10.6 | 13.1 | 8.0 | 150.6 | 3,230,055.3 | 2,170.0 | 1.4 | 1.1 |
| 02/26/2014 23:00 | 10.5 | 13.2 | 8.0 | 145.6 | 3,264,923.1 | 2,121.9 | 1.3 | 1.1 |
| **Average/Sum#:** | 10.5 | 13.3 | 8.1 | 144.2 | 3,280,587.0 | 2,078.3 | 1.3 | 1.0 |
| **Minimum:** | 9.8 | 13.0 | 7.9 | 118.9 | 3,230,055.3 | 1,816.2 | 1.0 | 0.7 |
| **Maximum:** | 11.1 | 13.6 | 8.4 | 168.6 | 3,335,629.5 | 2,258.3 | 1.5 | 1.4 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/27/2014 00:00 | 10.1 | 13.3 | 7.8 | 130.6 | 3,288,622.6 | 1,969.2 | 1.2 | 1.0 |
| 02/27/2014 01:00 | 9.3 | 13.7 | 7.6 | 117.9 | 3,304,637.3 | 1,834.0 | 1.0 | 0.7 |
| 02/27/2014 02:00 | 9.7 | 13.8 | 8.1 | 110.0 | 2,909,745.4 | 1,551.1 | 1.1 | 0.6 |
| 02/27/2014 03:00 | 10.2 | 13.8 | 8.5 | 95.2 | 2,498,612.6 | 1,277.2 | 1.1 | 0.5 |
| 02/27/2014 04:00 | 9.9 | 13.7 | 8.1 | 109.5 | 3,018,905.7 | 1,565.2 | 1.0 | 0.6 |
| 02/27/2014 05:00 | 10.0 | 13.6 | 8.1 | 117.2 | 3,135,434.1 | 1,717.2 | 1.1 | 0.7 |
| 02/27/2014 06:00 | 9.6 | 13.6 | 7.8 | 120.1 | 3,367,522.7 | 1,868.9 | 1.0 | 0.7 |
| 02/27/2014 07:00 | 9.7 | 13.6 | 7.8 | 119.4 | 3,335,629.5 | 1,851.2 | 1.0 | 0.7 |
| 02/27/2014 08:00 | 10.3 | 13.3 | 8.0 | 131.7 | 3,344,234.5 | 2,002.5 | 1.1 | 0.8 |
| 02/27/2014 09:00 | 9.3 | 13.6 | 7.5 | 109.9 | 3,391,546.0 | 1,832.7 | 0.9 | 0.5 |
| 02/27/2014 10:00 | 9.2 | 13.7 | 7.5 | 112.4 | 3,390,919.9 | 1,807.6 | 0.9 | 0.5 |
| 02/27/2014 11:00 | 9.3 | 13.7 | 7.6 | 112.4 | 3,384,354.2 | 1,804.1 | 0.9 | 0.5 |
| 02/27/2014 12:00 | 9.3 | 13.7 | 7.6 | 112.7 | 3,390,732.3 | 1,807.5 | 0.9 | 0.5 |
| 02/27/2014 13:00 | 9.3 | 13.7 | 7.6 | 113.3 | 3,362,121.9 | 1,816.8 | 1.0 | 0.7 |
| 02/27/2014 14:00 | 9.4 | 13.7 | 7.7 | 113.5 | 3,359,346.1 | 1,815.3 | 1.0 | 0.7 |
| 02/27/2014 15:00 | 9.5 | 13.7 | 7.8 | 113.4 | 3,364,342.6 | 1,818.0 | 1.0 | 0.7 |
| 02/27/2014 16:00 | 9.5 | 13.7 | 7.8 | 113.7 | 3,376,741.5 | 1,824.7 | 1.0 | 0.7 |
| 02/27/2014 17:00 | 9.9 | 13.6 | 8.0 | 119.2 | 3,388,604.6 | 1,880.6 | 1.0 | 0.8 |
| 02/27/2014 18:00 | 9.6 | 13.6 | 7.8 | 120.0 | 3,365,901.0 | 1,868.0 | 1.0 | 0.7 |
| 02/27/2014 19:00 | 10.7 | 13.4 | 8.4 | 136.3 | 3,317,430.6 | 2,034.9 | 1.2 | 1.0 |
| 02/27/2014 20:00 | 10.6 | 13.4 | 8.3 | 135.0 | 3,335,620.8 | 2,021.7 | 1.2 | 1.0 |
| 02/27/2014 21:00 | 10.4 | 13.3 | 8.1 | 135.1 | 3,353,274.8 | 2,032.4 | 1.2 | 1.0 |
| 02/27/2014 22:00 | 10.4 | 13.4 | 8.2 | 133.1 | 3,314,172.0 | 2,008.7 | 1.2 | 1.0 |
| 02/27/2014 23:00 | 10.4 | 13.4 | 8.2 | 135.2 | 3,306,996.9 | 2,028.5 | 1.2 | 1.0 |
| **Average/Sum#:** | 9.8 | 13.6 | 7.9 | 119.5 | 3,275,227.1 | 1,834.9 | 1.1 | 0.7 |
| **Minimum:** | 9.2 | 13.3 | 7.5 | 95.2 | 2,498,612.6 | 1,277.2 | 0.9 | 0.5 |
| **Maximum:** | 10.7 | 13.8 | 8.5 | 136.3 | 3,391,546.0 | 2,034.9 | 1.2 | 1.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/28/2014 00:00 | 9.8 | 13.6 | 7.9 | 122.7 | 3,303,999.7 | 1,881.9 | 1.1 | 0.8 |
| 02/28/2014 01:00 | 9.5 | 13.7 | 7.8 | 117.9 | 3,337,195.9 | 1,827.7 | 1.0 | 0.7 |
| 02/28/2014 02:00 | 10.0 | 13.5 | 8.0 | 123.5 | 3,336,128.5 | 1,900.2 | 1.1 | 0.8 |
| 02/28/2014 03:00 | 9.6 | 13.7 | 7.9 | 118.0 | 3,341,030.3 | 1,829.8 | 1.0 | 0.7 |
| 02/28/2014 04:00 | 9.6 | 13.7 | 7.9 | 118.0 | 3,341,760.7 | 1,830.2 | 1.0 | 0.7 |
| 02/28/2014 05:00 | 9.5 | 13.7 | 7.8 | 118.4 | 3,367,505.9 | 1,844.3 | 1.0 | 0.7 |
| 02/28/2014 06:00 | 9.4 | 13.7 | 7.7 | 118.2 | 3,370,792.5 | 1,846.1 | 1.0 | 0.7 |
| 02/28/2014 07:00 | 9.6 | 13.6 | 7.8 | 116.0 | 3,307,604.5 | 1,859.8 | 1.0 | 0.7 |
| 02/28/2014 08:00 | 10.2 | 13.4 | 8.0 | 131.9 | 3,350,580.7 | 2,006.3 | 1.1 | 0.8 |
| 02/28/2014 09:00 | 10.5 | 13.2 | 8.0 | 143.8 | 3,309,182.9 | 2,126.5 | 1.3 | 1.1 |
| 02/28/2014 10:00 | 10.6 | 13.2 | 8.1 | 147.9 | 3,300,312.8 | 2,169.0 | 1.3 | 1.1 |
| 02/28/2014 11:00 | 10.5 | 13.2 | 8.0 | 146.0 | 3,273,228.6 | 2,151.2 | 1.3 | 1.1 |
| 02/28/2014 12:00 | 10.4 | 13.3 | 8.1 | 142.9 | 3,288,019.1 | 2,112.9 | 1.3 | 1.1 |
| 02/28/2014 13:00 | 10.2 | 13.3 | 7.9 | 133.4 | 3,308,727.3 | 2,005.4 | 1.2 | 1.0 |
| 02/28/2014 14:00 | 9.4 | 13.6 | 7.6 | 118.9 | 3,346,080.4 | 1,857.0 | 1.0 | 0.7 |
| 02/28/2014 15:00 | 9.7 | 13.5 | 7.7 | 125.5 | 3,337,581.9 | 1,925.4 | 1.1 | 0.8 |
| 02/28/2014 16:00 | 10.4 | 13.3 | 8.1 | 141.2 | 3,304,247.9 | 2,099.2 | 1.2 | 1.0 |
| 02/28/2014 17:00 | 10.3 | 13.3 | 8.0 | 137.7 | 3,313,845.9 | 2,056.9 | 1.2 | 1.0 |
| 02/28/2014 18:00 | 9.7 | 13.4 | 7.6 | 124.1 | 3,385,287.3 | 1,928.2 | 1.1 | 0.8 |
| 02/28/2014 19:00 | 10.1 | 13.4 | 7.9 | 131.8 | 3,332,711.3 | 1,995.6 | 1.1 | 0.8 |
| 02/28/2014 20:00 | 9.4 | 13.7 | 7.7 | 117.9 | 3,307,340.1 | 1,835.5 | 1.0 | 0.7 |
| 02/28/2014 21:00 | 10.0 | 13.4 | 7.9 | 127.5 | 3,382,131.5 | 1,951.1 | 1.1 | 0.8 |
| 02/28/2014 22:00 | 10.1 | 13.4 | 7.9 | 130.6 | 3,357,625.7 | 1,986.0 | 1.1 | 0.8 |
| 02/28/2014 23:00 | 10.2 | 13.4 | 8.0 | 133.7 | 3,342,385.4 | 2,025.8 | 1.2 | 1.0 |
| **Average/Sum#:** | 9.9 | 13.5 | 7.9 | 128.6 | 3,331,054.5 | 1,960.5 | 1.1 | 0.9 |
| **Minimum:** | 9.4 | 13.2 | 7.6 | 116.0 | 3,273,228.6 | 1,827.7 | 1.0 | 0.7 |
| **Maximum:** | 10.6 | 13.7 | 8.1 | 147.9 | 3,385,287.3 | 2,169.0 | 1.3 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/01/2014 00:00 | 9.9 | 13.5 | 7.9 | 126.0 | 3,346,075.8 | 1,930.3 | 1.1 | 0.8 |
| 03/01/2014 01:00 | 9.6 | 13.6 | 7.8 | 119.0 | 3,331,305.0 | 1,848.8 | 1.0 | 0.7 |
| 03/01/2014 02:00 | 9.5 | 13.7 | 7.8 | 117.1 | 3,277,789.3 | 1,819.1 | 1.0 | 0.7 |
| 03/01/2014 03:00 | 9.4 | 13.7 | 7.7 | 117.0 | 3,279,050.6 | 1,819.8 | 1.0 | 0.7 |
| 03/01/2014 04:00 | 9.5 | 13.7 | 7.8 | 117.2 | 3,277,068.6 | 1,818.7 | 1.0 | 0.7 |
| 03/01/2014 05:00 | 9.4 | 13.7 | 7.7 | 117.1 | 3,304,997.6 | 1,834.2 | 1.0 | 0.7 |
| 03/01/2014 06:00 | 9.6 | 13.7 | 7.9 | 117.4 | 3,281,933.6 | 1,821.4 | 1.0 | 0.7 |
| 03/01/2014 07:00 | 9.6 | 13.6 | 7.8 | 117.7 | 3,280,492.1 | 1,820.6 | 1.0 | 0.7 |
| 03/01/2014 08:00 | 9.5 | 13.6 | 7.7 | 117.4 | 3,303,556.1 | 1,833.4 | 1.0 | 0.7 |
| 03/01/2014 09:00 | 9.6 | 13.7 | 7.9 | 117.5 | 3,280,852.5 | 1,820.8 | 1.0 | 0.7 |
| 03/01/2014 10:00 | 9.5 | 13.7 | 7.8 | 117.6 | 3,290,582.6 | 1,826.2 | 1.0 | 0.7 |
| 03/01/2014 11:00 | 9.5 | 13.7 | 7.8 | 117.4 | 3,294,546.8 | 1,828.4 | 1.0 | 0.7 |
| 03/01/2014 12:00 | 9.5 | 13.7 | 7.8 | 117.3 | 3,301,033.5 | 1,832.0 | 1.0 | 0.7 |
| 03/01/2014 13:00 | 9.7 | 13.7 | 7.9 | 118.8 | 3,348,242.6 | 1,858.2 | 1.0 | 0.7 |
| 03/01/2014 14:00 | 10.3 | 13.4 | 8.1 | 129.0 | 3,369,629.3 | 1,993.1 | 1.1 | 0.8 |
| 03/01/2014 15:00 | 10.3 | 13.4 | 8.1 | 130.2 | 3,376,222.8 | 1,997.0 | 1.1 | 0.8 |
| 03/01/2014 16:00 | 9.3 | 13.7 | 7.6 | 117.1 | 3,400,737.2 | 1,862.5 | 1.0 | 0.7 |
| 03/01/2014 17:00 | 9.5 | 13.7 | 7.8 | 117.1 | 3,344,499.5 | 1,831.7 | 1.0 | 0.7 |
| 03/01/2014 18:00 | 9.5 | 13.7 | 7.8 | 117.1 | 3,298,691.1 | 1,830.7 | 1.0 | 0.7 |
| 03/01/2014 19:00 | 10.0 | 13.5 | 8.0 | 125.3 | 3,359,076.7 | 1,937.8 | 1.1 | 0.8 |
| 03/01/2014 20:00 | 10.0 | 13.5 | 8.0 | 124.6 | 3,373,699.9 | 1,921.6 | 1.1 | 0.8 |
| 03/01/2014 21:00 | 10.4 | 13.4 | 8.2 | 130.0 | 3,350,694.1 | 1,981.9 | 1.1 | 0.8 |
| 03/01/2014 22:00 | 10.0 | 13.4 | 7.9 | 128.0 | 3,385,388.3 | 1,977.7 | 1.1 | 0.8 |
| 03/01/2014 23:00 | 10.3 | 13.3 | 8.0 | 132.5 | 3,323,081.5 | 2,014.1 | 1.2 | 1.0 |
| **Average/Sum#:** | 9.7 | 13.6 | 7.9 | 121.1 | 3,324,135.3 | 1,877.5 | 1.0 | 0.7 |
| **Minimum:** | 9.3 | 13.3 | 7.6 | 117.0 | 3,277,068.6 | 1,818.7 | 1.0 | 0.7 |
| **Maximum:** | 10.4 | 13.7 | 8.2 | 132.5 | 3,400,737.2 | 2,014.1 | 1.2 | 1.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/02/2014 00:00 | 9.8 | 13.5 | 7.8 | 122.5 | 3,390,837.1 | 1,906.6 | 1.0 | 0.8 |
| 03/02/2014 01:00 | 9.9 | 13.4 | 7.8 | 130.4 | 3,392,622.1 | 2,006.7 | 1.1 | 0.8 |
| 03/02/2014 02:00 | 9.8 | 13.4 | 7.7 | 127.4 | 3,442,628.9 | 1,986.0 | 1.1 | 0.8 |
| 03/02/2014 03:00 | 9.4 | 13.6 | 7.6 | 116.9 | 3,333,287.1 | 1,849.9 | 1.0 | 0.7 |
| 03/02/2014 04:00 | 9.6 | 13.6 | 7.8 | 117.1 | 3,295,087.3 | 1,828.7 | 1.0 | 0.7 |
| 03/02/2014 05:00 | 9.4 | 13.6 | 7.6 | 117.8 | 3,370,946.2 | 1,870.8 | 1.0 | 0.7 |
| 03/02/2014 06:00 | 9.7 | 13.5 | 7.7 | 125.5 | 3,417,667.2 | 1,971.6 | 1.1 | 0.8 |
| 03/02/2014 07:00 | 10.1 | 13.3 | 7.8 | 125.4 | 3,410,534.7 | 2,042.2 | 1.1 | 0.8 |
| 03/02/2014 08:00 | 10.1 | 13.3 | 7.8 | 131.0 | 3,398,844.5 | 2,035.2 | 1.1 | 0.8 |
| 03/02/2014 09:00 | 9.6 | 13.5 | 7.7 | 121.9 | 3,431,386.2 | 1,929.4 | 1.0 | 0.8 |
| 03/02/2014 10:00 | 10.0 | 13.4 | 7.9 | 133.0 | 3,412,571.8 | 2,018.5 | 1.1 | 0.8 |
| 03/02/2014 11:00 | 10.5 | 13.2 | 8.0 | 147.5 | 3,326,331.8 | 2,186.1 | 1.3 | 1.1 |
| 03/02/2014 12:00 | 10.5 | 13.2 | 8.0 | 145.3 | 3,320,315.6 | 2,157.9 | 1.3 | 1.1 |
| 03/02/2014 13:00 | 10.7 | 13.2 | 8.2 | 152.7 | 3,286,320.8 | 2,207.8 | 1.4 | 1.1 |
| 03/02/2014 14:00 | 10.7 | 13.2 | 8.2 | 151.8 | 3,269,351.9 | 2,196.4 | 1.4 | 1.1 |
| 03/02/2014 15:00 | 10.7 | 13.2 | 8.2 | 150.3 | 3,261,909.3 | 2,191.4 | 1.4 | 1.1 |
| 03/02/2014 16:00 | 10.7 | 13.2 | 8.2 | 149.9 | 3,254,913.4 | 2,186.7 | 1.4 | 1.1 |
| 03/02/2014 17:00 | 10.7 | 13.2 | 8.2 | 146.2 | 3,271,402.7 | 2,150.0 | 1.3 | 1.1 |
| 03/02/2014 18:00 | 10.5 | 13.3 | 8.2 | 139.6 | 3,266,155.9 | 2,075.0 | 1.2 | 1.0 |
| 03/02/2014 19:00 | 10.5 | 13.3 | 8.2 | 139.6 | 3,324,675.8 | 2,087.9 | 1.2 | 1.0 |
| 03/02/2014 20:00 | 10.4 | 13.3 | 8.1 | 133.8 | 3,337,765.7 | 2,023.0 | 1.2 | 1.0 |
| 03/02/2014 21:00 | 10.5 | 13.3 | 8.2 | 141.1 | 3,329,590.1 | 2,115.3 | 1.2 | 1.1 |
| 03/02/2014 22:00 | 10.1 | 13.3 | 7.8 | 131.2 | 3,390,494.4 | 2,030.2 | 1.1 | 0.8 |
| 03/02/2014 23:00 | 9.8 | 13.4 | 7.7 | 126.3 | 3,369,468.7 | 1,968.4 | 1.1 | 0.8 |
| **Average/Sum#:** | 10.2 | 13.4 | 7.9 | 134.3 | 3,346,046.2 | 2,042.6 | 1.2 | 0.9 |
| **Minimum:** | 9.4 | 13.2 | 7.6 | 116.9 | 3,254,913.4 | 1,828.7 | 1.0 | 0.7 |
| **Maximum:** | 10.7 | 13.6 | 8.2 | 152.7 | 3,442,628.9 | 2,207.8 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/03/2014 00:00 | 9.6 | 13.7 | 7.9 | 108.6 | 2,944,817.6 | 1,591.3 | 1.1 | 0.6 |
| 03/03/2014 01:00 | 9.9 | 13.8 | 8.2 | 100.4 | 2,759,293.7 | 1,430.6 | 1.0 | 0.6 |
| 03/03/2014 02:00 | 10.2 | 13.8 | 8.5 | 95.1 | 2,483,865.8 | 1,287.8 | 1.1 | 0.5 |
| 03/03/2014 03:00 | 10.2 | 13.8 | 8.5 | 95.0 | 2,479,043.9 | 1,285.3 | 1.1 | 0.5 |
| 03/03/2014 04:00 | 10.2 | 13.8 | 8.5 | 95.0 | 2,489,845.0 | 1,290.9 | 1.1 | 0.5 |
| 03/03/2014 05:00 | 9.8 | 13.7 | 8.0 | 106.9 | 2,927,237.1 | 1,581.8 | 1.0 | 0.6 |
| 03/03/2014 06:00 | 9.5 | 13.6 | 7.7 | 117.6 | 3,312,584.2 | 1,862.6 | 1.0 | 0.7 |
| 03/03/2014 07:00 | 9.7 | 13.5 | 7.7 | 124.0 | 3,351,370.3 | 1,982.3 | 1.1 | 0.8 |
| 03/03/2014 08:00 | 10.7 | 13.2 | 8.2 | 152.0 | 3,322,133.3 | 2,207.6 | 1.3 | 1.1 |
| 03/03/2014 09:00 | 10.6 | 13.2 | 8.1 | 145.1 | 3,327,078.8 | 2,138.0 | 1.3 | 1.1 |
| 03/03/2014 10:00 | 10.2 | 13.4 | 8.0 | 129.2 | 3,385,730.6 | 1,977.9 | 1.1 | 0.8 |
| 03/03/2014 11:00 | 9.8 | 13.5 | 7.8 | 122.5 | 3,344,906.8 | 1,905.2 | 1.1 | 0.8 |
| 03/03/2014 12:00 | 9.5 | 13.6 | 7.7 | 114.8 | 3,308,849.4 | 1,860.5 | 1.0 | 0.7 |
| 03/03/2014 13:00 | 9.4 | 13.6 | 7.6 | 117.1 | 3,316,169.3 | 1,840.4 | 1.0 | 0.7 |
| 03/03/2014 14:00 | 9.4 | 13.6 | 7.6 | 118.3 | 3,350,585.1 | 1,859.5 | 1.0 | 0.7 |
| 03/03/2014 15:00 | 9.3 | 13.6 | 7.5 | 119.7 | 3,379,099.1 | 1,900.0 | 1.0 | 0.8 |
| 03/03/2014 16:00 | 9.6 | 13.4 | 7.6 | 125.5 | 3,408,839.6 | 1,991.4 | 1.1 | 0.8 |
| 03/03/2014 17:00 | 10.4 | 13.2 | 8.0 | 147.4 | 3,351,133.6 | 2,202.4 | 1.3 | 1.1 |
| 03/03/2014 18:00 | 10.4 | 13.3 | 8.1 | 137.4 | 3,314,973.7 | 2,057.6 | 1.2 | 1.0 |
| 03/03/2014 19:00 | 10.6 | 13.2 | 8.1 | 149.8 | 3,301,065.2 | 2,193.6 | 1.3 | 1.1 |
| 03/03/2014 20:00 | 10.7 | 13.1 | 8.1 | 154.9 | 3,288,827.3 | 2,233.5 | 1.4 | 1.1 |
| 03/03/2014 21:00 | 10.6 | 13.2 | 8.1 | 150.4 | 3,304,827.4 | 2,196.1 | 1.3 | 1.1 |
| 03/03/2014 22:00 | 9.9 | 13.4 | 7.8 | 127.6 | 3,323,593.0 | 1,941.6 | 1.1 | 0.8 |
| 03/03/2014 23:00 | 9.6 | 13.6 | 7.8 | 117.2 | 3,232,019.4 | 1,817.3 | 1.0 | 0.7 |
| **Average/Sum#:** | 10.0 | 13.5 | 8.0 | 123.8 | 3,166,995.4 | 1,859.8 | 1.1 | 0.8 |
| **Minimum:** | 9.3 | 13.1 | 7.5 | 95.0 | 2,479,043.9 | 1,285.3 | 1.0 | 0.5 |
| **Maximum:** | 10.7 | 13.8 | 8.5 | 154.9 | 3,408,839.6 | 2,233.5 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/04/2014 00:00 | 9.8 | 13.7 | 8.0 | 108.9 | 2,887,079.7 | 1,560.1 | 1.1 | 0.6 |
| 03/04/2014 01:00 | 10.1 | 13.8 | 8.4 | 94.9 | 2,421,180.9 | 1,255.3 | 1.1 | 0.5 |
| 03/04/2014 02:00 | 10.2 | 13.8 | 8.5 | 94.9 | 2,441,625.8 | 1,265.9 | 1.1 | 0.5 |
| 03/04/2014 03:00 | 9.8 | 13.8 | 8.1 | 94.7 | 2,564,681.1 | 1,329.7 | 1.1 | 0.5 |
| 03/04/2014 04:00 | 10.0 | 13.8 | 8.3 | 93.9 | 2,461,106.4 | 1,276.0 | 1.1 | 0.5 |
| 03/04/2014 05:00 | 10.1 | 13.8 | 8.4 | 94.4 | 2,492,159.5 | 1,292.1 | 1.1 | 0.5 |
| 03/04/2014 06:00 | 9.7 | 13.7 | 7.9 | 105.9 | 2,970,525.4 | 1,583.5 | 1.0 | 0.6 |
| 03/04/2014 07:00 | 9.5 | 13.6 | 7.7 | 110.6 | 3,356,550.5 | 1,838.3 | 0.9 | 0.6 |
| 03/04/2014 08:00 | 9.5 | 13.7 | 7.8 | 115.8 | 3,339,934.8 | 1,829.2 | 1.0 | 0.7 |
| 03/04/2014 09:00 | 10.0 | 13.8 | 8.3 | 103.1 | 2,758,715.1 | 1,430.3 | 1.1 | 0.6 |
| 03/04/2014 10:00 | 10.3 | 13.8 | 8.6 | 95.0 | 2,406,274.3 | 1,230.0 | 1.1 | 0.5 |
| 03/04/2014 11:00 | 10.1 | 13.8 | 8.4 | 94.7 | 2,407,643.7 | 1,230.7 | 1.1 | 0.5 |
| 03/04/2014 12:00 | 10.3 | 13.8 | 8.6 | 93.1 | 2,437,382.5 | 1,263.7 | 1.1 | 0.5 |
| 03/04/2014 13:00 | 10.1 | 13.8 | 8.4 | 98.9 | 2,737,112.9 | 1,419.1 | 1.0 | 0.6 |
| 03/04/2014 14:00 | 9.7 | 13.7 | 7.9 | 117.2 | 3,362,210.7 | 1,841.4 | 1.0 | 0.7 |
| 03/04/2014 15:00 | 9.5 | 13.7 | 7.8 | 116.1 | 3,366,958.1 | 1,844.0 | 1.0 | 0.7 |
| 03/04/2014 16:00 | 9.4 | 13.7 | 7.7 | 116.0 | 3,367,505.9 | 1,844.3 | 1.0 | 0.7 |
| 03/04/2014 17:00 | 9.3 | 13.7 | 7.6 | 115.7 | 3,369,696.9 | 1,845.5 | 1.0 | 0.7 |
| 03/04/2014 18:00 | 9.4 | 13.6 | 7.6 | 117.7 | 3,391,307.4 | 1,882.1 | 1.0 | 0.8 |
| 03/04/2014 19:00 | 10.5 | 13.2 | 8.0 | 142.6 | 3,353,673.1 | 2,130.6 | 1.2 | 1.1 |
| 03/04/2014 20:00 | 10.5 | 13.3 | 8.2 | 139.7 | 3,325,472.0 | 2,088.4 | 1.2 | 1.0 |
| 03/04/2014 21:00 | 10.4 | 13.4 | 8.2 | 130.0 | 3,375,884.7 | 1,996.8 | 1.1 | 0.8 |
| 03/04/2014 22:00 | 10.0 | 13.5 | 8.0 | 124.2 | 3,344,689.0 | 1,929.5 | 1.1 | 0.8 |
| 03/04/2014 23:00 | 9.4 | 13.7 | 7.7 | 115.5 | 3,352,350.9 | 1,836.0 | 1.0 | 0.7 |
| **Average/Sum#:** | 9.9 | 13.7 | 8.1 | 109.7 | 2,970,488.4 | 1,626.8 | 1.1 | 0.7 |
| **Minimum:** | 9.3 | 13.2 | 7.6 | 93.1 | 2,406,274.3 | 1,230.0 | 0.9 | 0.5 |
| **Maximum:** | 10.5 | 13.8 | 8.6 | 142.6 | 3,391,307.4 | 2,130.6 | 1.2 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/05/2014 00:00 | 9.4 | 13.6 | 7.6 | 116.4 | 3,391,607.7 | 1,857.5 | 1.0 | 0.7 |
| 03/05/2014 01:00 | 10.2 | 13.4 | 8.0 | 127.3 | 3,389,325.4 | 1,980.0 | 1.1 | 0.8 |
| 03/05/2014 02:00 | 10.2 | 13.3 | 7.9 | 128.6 | 3,362,359.5 | 1,988.8 | 1.1 | 0.8 |
| 03/05/2014 03:00 | 9.5 | 13.5 | 7.6 | 118.3 | 3,320,053.8 | 1,866.8 | 1.0 | 0.7 |
| 03/05/2014 04:00 | 9.3 | 13.6 | 7.5 | 115.2 | 3,290,042.1 | 1,825.9 | 1.0 | 0.7 |
| 03/05/2014 05:00 | 9.9 | 13.4 | 7.8 | 124.2 | 3,368,090.6 | 1,943.0 | 1.1 | 0.8 |
| 03/05/2014 06:00 | 9.7 | 13.5 | 7.7 | 121.5 | 3,358,776.7 | 1,913.1 | 1.0 | 0.8 |
| 03/05/2014 07:00 | 9.6 | 13.4 | 7.6 | 125.7 | 3,392,310.0 | 1,932.2 | 1.1 | 0.8 |
| 03/05/2014 08:00 | 9.9 | 13.4 | 7.8 | 124.7 | 3,363,236.9 | 1,940.2 | 1.1 | 0.8 |
| 03/05/2014 09:00 | 9.4 | 13.6 | 7.6 | 117.3 | 3,328,962.6 | 1,847.5 | 1.0 | 0.7 |
| 03/05/2014 10:00 | 9.4 | 13.6 | 7.6 | 117.1 | 3,331,845.6 | 1,849.1 | 1.0 | 0.7 |
| 03/05/2014 11:00 | 9.3 | 13.6 | 7.5 | 116.8 | 3,337,251.2 | 1,852.1 | 1.0 | 0.7 |
| 03/05/2014 12:00 | 9.1 | 13.6 | 7.4 | 116.5 | 3,337,791.7 | 1,852.4 | 1.0 | 0.7 |
| 03/05/2014 13:00 | 9.1 | 13.6 | 7.4 | 116.4 | 3,337,611.6 | 1,852.3 | 1.0 | 0.7 |
| 03/05/2014 14:00 | 9.1 | 13.6 | 7.4 | 116.2 | 3,338,512.5 | 1,852.8 | 1.0 | 0.7 |
| 03/05/2014 15:00 | 8.9 | 13.6 | 7.2 | 115.8 | 3,347,341.7 | 1,857.7 | 1.0 | 0.7 |
| 03/05/2014 16:00 | 9.4 | 13.5 | 7.5 | 120.6 | 3,329,105.8 | 1,896.2 | 1.0 | 0.8 |
| 03/05/2014 17:00 | 9.9 | 13.4 | 7.8 | 124.9 | 3,320,683.0 | 1,939.9 | 1.1 | 0.8 |
| 03/05/2014 18:00 | 10.0 | 13.4 | 7.9 | 125.2 | 3,329,413.0 | 1,945.0 | 1.1 | 0.8 |
| 03/05/2014 19:00 | 10.4 | 13.3 | 8.1 | 134.8 | 3,323,951.6 | 2,038.9 | 1.2 | 1.0 |
| 03/05/2014 20:00 | 10.1 | 13.3 | 7.8 | 130.3 | 3,322,023.2 | 1,989.2 | 1.1 | 0.8 |
| 03/05/2014 21:00 | 9.8 | 13.4 | 7.7 | 126.3 | 3,360,396.3 | 1,963.1 | 1.1 | 0.8 |
| 03/05/2014 22:00 | 9.8 | 13.4 | 7.7 | 125.9 | 3,343,620.8 | 1,953.3 | 1.1 | 0.8 |
| 03/05/2014 23:00 | 9.2 | 13.6 | 7.4 | 115.8 | 3,294,727.0 | 1,828.5 | 1.0 | 0.7 |
| **Average/Sum#:** | 9.6 | 13.5 | 7.6 | 121.7 | 3,342,460.0 | 1,906.9 | 1.1 | 0.8 |
| **Minimum:** | 8.9 | 13.3 | 7.2 | 115.2 | 3,290,042.1 | 1,825.9 | 1.0 | 0.7 |
| **Maximum:** | 10.4 | 13.6 | 8.1 | 134.8 | 3,392,310.0 | 2,038.9 | 1.2 | 1.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/06/2014 00:00 | 9.2 | 13.6 | 7.4 | 115.9 | 3,291,483.6 | 1,826.7 | 1.0 | 0.7 |
| 03/06/2014 01:00 | 9.4 | 13.6 | 7.6 | 115.7 | 3,213,102.1 | 1,783.2 | 1.0 | 0.7 |
| 03/06/2014 02:00 | 10.2 | 13.8 | 8.5 | 96.0 | 2,487,265.9 | 1,271.4 | 1.1 | 0.5 |
| 03/06/2014 03:00 | 29.7 | 16.1 | 36.5 | 227.6 | 1,566,245.6 | 583.3 | 4.1 | 0.9 |
| 03/06/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 14.6 | 14.3 | 15.0 | 138.8 | 2,639,524.3 | 1,366.2 | 1.8 | 0.7 |
| **Minimum:** | 9.2 | 13.6 | 7.4 | 96.0 | 1,566,245.6 | 583.3 | 1.0 | 0.5 |
| **Maximum:** | 29.7 | 16.1 | 36.5 | 227.6 | 3,291,483.6 | 1,826.7 | 4.1 | 0.9 |
| **%SI** | 83.3 | 83.3 | 83.3 | 83.3 | 83.3 | 83.3 | 83.3 | 83.3 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/07/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/07/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/07/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/07/2014 03:00 | 43.5 | 17.3 | 71.3 | 0.0 | 2,014,664.9 | 500.2 | 0.0 | 0.0 |
| 03/07/2014 04:00 | 57.2 | 16.5 | 76.7 | 218.1 | 1,980,569.8 | 621.9 | 2.6 | 0.6 |
| 03/07/2014 05:00 | 52.4 | 14.9 | 51.5 | 263.8 | 2,201,806.2 | 964.7 | 3.2 | 1.2 |
| 03/07/2014 06:00 | 10.0 | 13.8 | 8.3 | 114.6 | 2,836,077.9 | 1,449.7 | 1.2 | 0.7 |
| 03/07/2014 07:00 | 9.6 | 13.7 | 7.9 | 122.1 | 3,470,622.9 | 1,799.4 | 1.0 | 0.7 |
| 03/07/2014 08:00 | 9.6 | 13.8 | 8.0 | 108.2 | 3,017,624.4 | 1,542.5 | 1.0 | 0.6 |
| 03/07/2014 09:00 | 10.3 | 13.8 | 8.6 | 97.5 | 2,607,188.4 | 1,332.7 | 1.1 | 0.5 |
| 03/07/2014 10:00 | 9.7 | 13.6 | 7.8 | 117.0 | 3,276,210.9 | 1,794.3 | 1.0 | 0.7 |
| 03/07/2014 11:00 | 9.6 | 13.7 | 7.9 | 117.7 | 3,295,627.9 | 1,829.0 | 1.0 | 0.7 |
| 03/07/2014 12:00 | 9.5 | 13.7 | 7.8 | 117.6 | 3,310,403.3 | 1,837.2 | 1.0 | 0.7 |
| 03/07/2014 13:00 | 9.5 | 13.7 | 7.8 | 117.4 | 3,353,811.6 | 1,836.8 | 1.0 | 0.7 |
| 03/07/2014 14:00 | 9.5 | 13.7 | 7.8 | 117.3 | 3,347,968.7 | 1,833.6 | 1.0 | 0.7 |
| 03/07/2014 15:00 | 9.5 | 13.8 | 7.9 | 117.2 | 3,347,238.4 | 1,833.2 | 1.0 | 0.7 |
| 03/07/2014 16:00 | 9.6 | 13.7 | 7.9 | 118.6 | 3,347,521.9 | 1,857.8 | 1.0 | 0.7 |
| 03/07/2014 17:00 | 9.9 | 13.4 | 7.8 | 130.7 | 3,399,384.7 | 2,010.7 | 1.1 | 0.8 |
| 03/07/2014 18:00 | 10.0 | 13.4 | 7.9 | 130.8 | 3,404,794.8 | 2,013.9 | 1.1 | 0.8 |
| 03/07/2014 19:00 | 10.3 | 13.3 | 8.0 | 143.6 | 3,368,161.5 | 2,164.4 | 1.2 | 1.1 |
| 03/07/2014 20:00 | 10.5 | 13.2 | 8.0 | 153.6 | 3,299,723.8 | 2,240.9 | 1.4 | 1.1 |
| 03/07/2014 21:00 | 10.5 | 13.2 | 8.0 | 151.7 | 3,341,245.0 | 2,220.3 | 1.3 | 1.1 |
| 03/07/2014 22:00 | 10.5 | 13.2 | 8.0 | 151.5 | 3,339,890.6 | 2,219.4 | 1.3 | 1.1 |
| 03/07/2014 23:00 | 10.4 | 13.3 | 8.1 | 144.8 | 3,331,902.9 | 2,141.1 | 1.3 | 1.1 |
| **Average/Sum#:** | 15.8 | 13.9 | 16.3 | 131.1 | 3,090,116.2 | 1,716.4 | 1.2 | 0.8 |
| **Minimum:** | 9.5 | 13.2 | 7.8 | 0.0 | 1,980,569.8 | 500.2 | 0.0 | 0.0 |
| **Maximum:** | 57.2 | 17.3 | 76.7 | 263.8 | 3,470,622.9 | 2,240.9 | 3.2 | 1.2 |
| **%SI** | 12.5 | 12.5 | 12.5 | 12.5 | 12.5 | 12.5 | 12.5 | 12.5 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/08/2014 00:00 | 9.8 | 13.5 | 7.8 | 126.6 | 3,424,805.9 | 1,925.7 | 1.1 | 0.8 |
| 03/08/2014 01:00 | 9.8 | 13.5 | 7.8 | 124.7 | 3,417,065.0 | 1,946.3 | 1.0 | 0.8 |
| 03/08/2014 02:00 | 9.8 | 13.5 | 7.8 | 123.3 | 3,387,991.5 | 1,905.0 | 1.0 | 0.8 |
| 03/08/2014 03:00 | 9.8 | 13.6 | 7.9 | 121.7 | 3,355,801.1 | 1,886.9 | 1.0 | 0.8 |
| 03/08/2014 04:00 | 10.1 | 13.5 | 8.1 | 126.7 | 3,421,980.9 | 1,949.1 | 1.1 | 0.8 |
| 03/08/2014 05:00 | 10.2 | 13.4 | 8.0 | 131.2 | 3,411,578.5 | 1,993.0 | 1.1 | 0.8 |
| 03/08/2014 06:00 | 10.2 | 13.4 | 8.0 | 133.2 | 3,384,148.3 | 2,026.4 | 1.1 | 0.8 |
| 03/08/2014 07:00 | 10.3 | 13.4 | 8.1 | 130.6 | 3,473,657.6 | 2,003.9 | 1.1 | 0.8 |
| 03/08/2014 08:00 | 9.6 | 13.6 | 7.8 | 120.0 | 3,350,224.7 | 1,859.3 | 1.0 | 0.7 |
| 03/08/2014 09:00 | 9.8 | 13.6 | 7.9 | 117.6 | 3,262,293.2 | 1,810.5 | 1.0 | 0.7 |
| 03/08/2014 10:00 | 9.7 | 13.7 | 7.9 | 117.3 | 3,263,194.2 | 1,811.0 | 1.0 | 0.7 |
| 03/08/2014 11:00 | 9.7 | 13.7 | 7.9 | 117.3 | 3,269,680.9 | 1,814.6 | 1.0 | 0.7 |
| 03/08/2014 12:00 | 9.6 | 13.7 | 7.9 | 117.0 | 3,272,924.3 | 1,816.4 | 1.0 | 0.7 |
| 03/08/2014 13:00 | 9.5 | 13.7 | 7.8 | 116.8 | 3,315,467.7 | 1,815.8 | 1.0 | 0.7 |
| 03/08/2014 14:00 | 9.4 | 13.7 | 7.7 | 116.3 | 3,312,546.3 | 1,814.2 | 1.0 | 0.7 |
| 03/08/2014 15:00 | 9.3 | 13.7 | 7.6 | 115.8 | 3,308,164.1 | 1,811.8 | 1.0 | 0.7 |
| 03/08/2014 16:00 | 9.3 | 13.7 | 7.6 | 116.2 | 3,328,614.2 | 1,823.0 | 1.0 | 0.7 |
| 03/08/2014 17:00 | 9.6 | 13.6 | 7.8 | 118.8 | 3,336,350.2 | 1,851.6 | 1.0 | 0.7 |
| 03/08/2014 18:00 | 10.3 | 13.3 | 8.0 | 139.5 | 3,334,229.9 | 2,093.9 | 1.2 | 1.0 |
| 03/08/2014 19:00 | 10.4 | 13.2 | 8.0 | 147.1 | 3,317,354.5 | 2,180.2 | 1.3 | 1.1 |
| 03/08/2014 20:00 | 10.5 | 13.2 | 8.0 | 151.5 | 3,263,205.8 | 2,216.1 | 1.4 | 1.1 |
| 03/08/2014 21:00 | 10.4 | 13.2 | 8.0 | 151.4 | 3,256,432.3 | 2,211.5 | 1.4 | 1.1 |
| 03/08/2014 22:00 | 10.4 | 13.2 | 8.0 | 150.9 | 3,261,733.3 | 2,215.1 | 1.4 | 1.1 |
| 03/08/2014 23:00 | 10.4 | 13.2 | 8.0 | 147.3 | 3,300,921.4 | 2,169.4 | 1.3 | 1.1 |
| **Average/Sum#:** | 9.9 | 13.5 | 7.9 | 128.3 | 3,334,598.6 | 1,956.3 | 1.1 | 0.8 |
| **Minimum:** | 9.3 | 13.2 | 7.6 | 115.8 | 3,256,432.3 | 1,810.5 | 1.0 | 0.7 |
| **Maximum:** | 10.5 | 13.7 | 8.1 | 151.5 | 3,473,657.6 | 2,216.1 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/09/2014 00:00 | 9.6 | 13.5 | 7.7 | 121.2 | 3,165,126.0 | 1,802.8 | 1.1 | 0.7 |
| 03/09/2014 01:00 | 9.6 | 13.8 | 8.0 | 99.2 | 2,652,825.8 | 1,375.4 | 1.1 | 0.6 |
| 03/09/2014 02:00 | 29.2 | 16.0 | 35.2 | 233.6 | 1,622,767.9 | 616.2 | 4.1 | 1.0 |
| 03/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 11:00 | 46.2 | 16.6 | 63.4 | 114.0 | 1,976,764.1 | 577.4 | 0.0 | 0.0 |
| 03/09/2014 12:00 | 54.2 | 15.0 | 54.2 | 284.4 | 2,102,538.6 | 890.5 | 3.6 | 1.2 |
| 03/09/2014 13:00 | 9.6 | 13.8 | 8.0 | 108.2 | 2,640,445.8 | 1,349.7 | 1.2 | 0.7 |
| 03/09/2014 14:00 | 9.7 | 13.6 | 7.8 | 119.5 | 3,358,132.9 | 1,765.6 | 1.0 | 0.7 |
| 03/09/2014 15:00 | 9.3 | 13.6 | 7.5 | 118.2 | 3,345,009.3 | 1,758.7 | 1.0 | 0.7 |
| 03/09/2014 16:00 | 9.2 | 13.7 | 7.5 | 105.6 | 2,917,645.4 | 1,512.7 | 1.0 | 0.6 |
| 03/09/2014 17:00 | 10.0 | 13.3 | 7.8 | 139.0 | 3,392,707.7 | 2,056.3 | 1.2 | 1.0 |
| 03/09/2014 18:00 | 10.3 | 13.2 | 7.9 | 148.2 | 3,310,696.3 | 2,200.0 | 1.3 | 1.1 |
| 03/09/2014 19:00 | 10.4 | 13.2 | 8.0 | 151.0 | 3,283,231.8 | 2,229.7 | 1.4 | 1.1 |
| 03/09/2014 20:00 | 10.4 | 13.2 | 8.0 | 151.4 | 3,270,126.5 | 2,220.8 | 1.4 | 1.1 |
| 03/09/2014 21:00 | 10.4 | 13.2 | 8.0 | 151.3 | 3,271,451.8 | 2,221.7 | 1.4 | 1.1 |
| 03/09/2014 22:00 | 10.1 | 13.3 | 7.8 | 139.9 | 3,333,501.2 | 2,069.1 | 1.2 | 1.0 |
| 03/09/2014 23:00 | 10.4 | 13.2 | 8.0 | 150.6 | 3,270,691.5 | 2,197.3 | 1.4 | 1.1 |
| **Average/Sum#:** | 16.2 | 13.9 | 15.9 | 146.0 | 2,932,103.9 | 1,677.7 | 1.5 | 0.9 |
| **Minimum:** | 9.2 | 13.2 | 7.5 | 99.2 | 1,622,767.9 | 577.4 | 0.0 | 0.0 |
| **Maximum:** | 54.2 | 16.6 | 63.4 | 284.4 | 3,392,707.7 | 2,229.7 | 4.1 | 1.2 |
| **%SI** | 33.3 | 33.3 | 33.3 | 33.3 | 33.3 | 33.3 | 33.3 | 33.3 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/10/2014 00:00 | 10.2 | 13.3 | 7.9 | 139.1 | 3,271,507.6 | 2,078.4 | 1.2 | 1.0 |
| 03/10/2014 01:00 | 9.7 | 13.8 | 8.1 | 98.5 | 2,523,791.3 | 1,308.5 | 1.1 | 0.5 |
| 03/10/2014 02:00 | 9.9 | 13.8 | 8.2 | 94.3 | 2,412,143.2 | 1,233.0 | 1.1 | 0.5 |
| 03/10/2014 03:00 | 10.0 | 13.8 | 8.3 | 94.2 | 2,419,381.6 | 1,236.7 | 1.1 | 0.5 |
| 03/10/2014 04:00 | 10.0 | 13.8 | 8.3 | 94.0 | 2,430,923.9 | 1,242.6 | 1.1 | 0.5 |
| 03/10/2014 05:00 | 9.7 | 13.7 | 7.9 | 106.8 | 2,939,507.5 | 1,545.5 | 1.0 | 0.6 |
| 03/10/2014 06:00 | 9.8 | 13.5 | 7.8 | 126.8 | 3,409,346.7 | 1,966.8 | 1.1 | 0.8 |
| 03/10/2014 07:00 | 10.4 | 13.3 | 8.1 | 146.3 | 3,349,331.9 | 2,152.3 | 1.3 | 1.1 |
| 03/10/2014 08:00 | 10.4 | 13.3 | 8.1 | 142.3 | 3,351,108.9 | 2,104.5 | 1.2 | 1.1 |
| 03/10/2014 09:00 | 9.4 | 13.6 | 7.6 | 119.3 | 3,299,601.4 | 1,855.3 | 1.0 | 0.7 |
| 03/10/2014 10:00 | 9.7 | 13.7 | 7.9 | 117.5 | 3,271,302.6 | 1,815.5 | 1.0 | 0.7 |
| 03/10/2014 11:00 | 9.7 | 13.7 | 7.9 | 117.7 | 3,280,672.3 | 1,820.7 | 1.0 | 0.7 |
| 03/10/2014 12:00 | 9.6 | 13.7 | 7.9 | 117.4 | 3,281,573.3 | 1,821.2 | 1.0 | 0.7 |
| 03/10/2014 13:00 | 9.7 | 13.7 | 7.9 | 117.6 | 3,328,431.6 | 1,822.9 | 1.0 | 0.7 |
| 03/10/2014 14:00 | 9.7 | 13.7 | 7.9 | 117.5 | 3,334,639.7 | 1,826.3 | 1.0 | 0.7 |
| 03/10/2014 15:00 | 9.7 | 13.7 | 7.9 | 117.7 | 3,341,578.1 | 1,830.1 | 1.0 | 0.7 |
| 03/10/2014 16:00 | 9.8 | 13.7 | 8.0 | 117.6 | 3,336,648.2 | 1,827.4 | 1.0 | 0.7 |
| 03/10/2014 17:00 | 9.7 | 13.7 | 7.9 | 117.2 | 3,335,004.8 | 1,826.5 | 1.0 | 0.7 |
| 03/10/2014 18:00 | 9.7 | 13.7 | 7.9 | 116.5 | 3,421,340.3 | 1,848.8 | 1.0 | 0.7 |
| 03/10/2014 19:00 | 10.6 | 13.3 | 8.2 | 143.2 | 3,375,080.2 | 2,144.2 | 1.2 | 1.1 |
| 03/10/2014 20:00 | 10.2 | 13.3 | 7.9 | 139.1 | 3,354,767.5 | 2,082.3 | 1.2 | 1.0 |
| 03/10/2014 21:00 | 9.9 | 13.7 | 8.1 | 115.0 | 3,166,146.2 | 1,710.9 | 1.0 | 0.7 |
| 03/10/2014 22:00 | 10.0 | 13.8 | 8.3 | 98.8 | 2,718,111.8 | 1,389.4 | 1.0 | 0.6 |
| 03/10/2014 23:00 | 31.0 | 16.2 | 38.9 | 234.8 | 1,572,920.8 | 574.3 | 4.2 | 0.9 |
| **Average/Sum#:** | 10.8 | 13.7 | 9.3 | 122.9 | 3,063,535.9 | 1,711.0 | 1.2 | 0.7 |
| **Minimum:** | 9.4 | 13.3 | 7.6 | 94.0 | 1,572,920.8 | 574.3 | 1.0 | 0.5 |
| **Maximum:** | 31.0 | 16.2 | 38.9 | 234.8 | 3,421,340.3 | 2,152.3 | 4.2 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/11/2014 02:00 | 46.0 | 17.3 | 75.4 | 280.4 | 1,947,402.0 | 483.5 | 3.3 | 0.6 |
| 03/11/2014 03:00 | 46.8 | 15.3 | 49.3 | 243.1 | 2,308,351.5 | 927.1 | 2.7 | 0.9 |
| 03/11/2014 04:00 | 10.2 | 13.9 | 8.6 | 100.6 | 2,605,036.4 | 1,331.6 | 1.1 | 0.5 |
| 03/11/2014 05:00 | 10.3 | 13.8 | 8.6 | 110.8 | 3,047,451.4 | 1,580.0 | 1.0 | 0.6 |
| 03/11/2014 06:00 | 9.9 | 13.9 | 8.3 | 108.1 | 2,981,628.1 | 1,524.1 | 1.0 | 0.6 |
| 03/11/2014 07:00 | 10.2 | 13.7 | 8.4 | 131.9 | 3,352,427.0 | 1,762.6 | 1.1 | 0.7 |
| 03/11/2014 08:00 | 10.1 | 13.6 | 8.2 | 124.6 | 3,386,746.6 | 1,904.3 | 1.1 | 0.8 |
| 03/11/2014 09:00 | 10.1 | 13.7 | 8.3 | 119.0 | 3,264,996.0 | 1,812.0 | 1.0 | 0.7 |
| 03/11/2014 10:00 | 10.0 | 13.7 | 8.2 | 118.8 | 3,267,698.8 | 1,813.5 | 1.0 | 0.7 |
| 03/11/2014 11:00 | 9.9 | 13.7 | 8.1 | 118.2 | 3,314,554.8 | 1,815.3 | 1.0 | 0.7 |
| 03/11/2014 12:00 | 9.9 | 13.7 | 8.1 | 115.0 | 3,178,174.9 | 1,717.4 | 1.0 | 0.7 |
| 03/11/2014 13:00 | 10.4 | 13.9 | 8.8 | 98.4 | 2,600,536.9 | 1,329.3 | 1.1 | 0.5 |
| 03/11/2014 14:00 | 10.7 | 13.9 | 9.0 | 96.8 | 2,518,947.0 | 1,269.2 | 1.1 | 0.5 |
| 03/11/2014 15:00 | 10.7 | 13.9 | 9.0 | 97.6 | 2,570,350.0 | 1,295.1 | 1.1 | 0.5 |
| 03/11/2014 16:00 | 10.6 | 13.9 | 8.9 | 100.8 | 2,719,597.4 | 1,370.3 | 1.0 | 0.5 |
| 03/11/2014 17:00 | 10.4 | 13.9 | 8.8 | 101.4 | 2,743,612.0 | 1,382.4 | 1.0 | 0.6 |
| 03/11/2014 18:00 | 10.2 | 13.8 | 8.5 | 109.3 | 2,976,405.9 | 1,564.9 | 1.0 | 0.6 |
| 03/11/2014 19:00 | 10.8 | 13.4 | 8.5 | 139.5 | 3,373,185.7 | 2,069.1 | 1.2 | 1.0 |
| 03/11/2014 20:00 | 10.5 | 13.3 | 8.2 | 147.1 | 3,368,469.2 | 2,140.0 | 1.3 | 1.1 |
| 03/11/2014 21:00 | 10.2 | 13.3 | 7.9 | 137.5 | 3,392,748.9 | 2,081.1 | 1.2 | 1.0 |
| 03/11/2014 22:00 | 10.4 | 13.3 | 8.1 | 144.7 | 3,369,413.6 | 2,140.6 | 1.3 | 1.1 |
| 03/11/2014 23:00 | 10.1 | 13.7 | 8.3 | 117.8 | 3,155,336.4 | 1,728.1 | 1.1 | 0.7 |
| **Average/Sum#:** | 13.6 | 13.9 | 13.3 | 130.1 | 2,974,685.0 | 1,592.8 | 1.3 | 0.7 |
| **Minimum:** | 9.9 | 13.3 | 7.9 | 96.8 | 1,947,402.0 | 483.5 | 1.0 | 0.5 |
| **Maximum:** | 46.8 | 17.3 | 75.4 | 280.4 | 3,392,748.9 | 2,140.6 | 3.3 | 1.1 |
| **%SI** | 8.3 | 8.3 | 8.3 | 8.3 | 8.3 | 8.3 | 8.3 | 8.3 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/12/2014 00:00 | 10.5 | 13.9 | 8.9 | 97.1 | 2,486,679.0 | 1,271.1 | 1.1 | 0.5 |
| 03/12/2014 01:00 | 10.6 | 13.9 | 8.9 | 97.9 | 2,459,486.2 | 1,257.2 | 1.1 | 0.5 |
| 03/12/2014 02:00 | 10.7 | 13.9 | 9.0 | 97.6 | 2,415,664.6 | 1,234.8 | 1.1 | 0.5 |
| 03/12/2014 03:00 | 10.7 | 13.9 | 9.0 | 97.9 | 2,398,840.3 | 1,226.2 | 1.2 | 0.6 |
| 03/12/2014 04:00 | 10.8 | 13.9 | 9.1 | 97.9 | 2,408,230.6 | 1,231.0 | 1.2 | 0.6 |
| 03/12/2014 05:00 | 10.2 | 13.7 | 8.4 | 114.4 | 3,148,935.9 | 1,701.6 | 1.0 | 0.7 |
| 03/12/2014 06:00 | 10.3 | 13.5 | 8.2 | 126.4 | 3,429,881.4 | 1,953.6 | 1.1 | 0.8 |
| 03/12/2014 07:00 | 10.8 | 13.3 | 8.4 | 157.8 | 3,312,006.7 | 2,152.5 | 1.4 | 1.1 |
| 03/12/2014 08:00 | 10.0 | 13.5 | 8.0 | 128.0 | 3,389,412.0 | 1,955.3 | 1.1 | 0.8 |
| 03/12/2014 09:00 | 9.6 | 13.6 | 7.8 | 117.7 | 3,299,051.5 | 1,830.9 | 1.0 | 0.7 |
| 03/12/2014 10:00 | 9.6 | 13.6 | 7.8 | 117.2 | 3,301,033.5 | 1,832.0 | 1.0 | 0.7 |
| 03/12/2014 11:00 | 9.6 | 13.7 | 7.9 | 117.1 | 3,349,064.3 | 1,834.2 | 1.0 | 0.7 |
| 03/12/2014 12:00 | 10.4 | 13.8 | 8.6 | 99.9 | 2,616,179.2 | 1,356.4 | 1.1 | 0.5 |
| 03/12/2014 13:00 | 10.6 | 13.9 | 8.9 | 100.3 | 2,723,169.9 | 1,372.1 | 1.0 | 0.5 |
| 03/12/2014 14:00 | 11.0 | 13.9 | 9.3 | 95.6 | 2,470,521.0 | 1,244.8 | 1.1 | 0.5 |
| 03/12/2014 15:00 | 11.0 | 13.9 | 9.3 | 95.4 | 2,468,536.3 | 1,243.8 | 1.1 | 0.5 |
| 03/12/2014 16:00 | 11.0 | 13.9 | 9.3 | 95.5 | 2,468,734.8 | 1,243.9 | 1.1 | 0.5 |
| 03/12/2014 17:00 | 10.6 | 13.8 | 8.8 | 107.5 | 2,935,893.7 | 1,543.6 | 1.0 | 0.6 |
| 03/12/2014 18:00 | 9.6 | 13.6 | 7.8 | 121.1 | 3,383,189.6 | 1,902.3 | 1.0 | 0.8 |
| 03/12/2014 19:00 | 10.4 | 13.3 | 8.1 | 145.4 | 3,382,011.4 | 2,173.3 | 1.3 | 1.1 |
| 03/12/2014 20:00 | 10.5 | 13.3 | 8.2 | 148.5 | 3,372,476.8 | 2,191.8 | 1.3 | 1.1 |
| 03/12/2014 21:00 | 10.6 | 13.2 | 8.1 | 156.7 | 3,324,609.0 | 2,257.8 | 1.4 | 1.1 |
| 03/12/2014 22:00 | 10.6 | 13.2 | 8.1 | 157.1 | 3,320,191.5 | 2,254.8 | 1.4 | 1.1 |
| 03/12/2014 23:00 | 10.4 | 13.3 | 8.1 | 146.4 | 3,343,729.7 | 2,148.7 | 1.3 | 1.1 |
| **Average/Sum#:** | 10.4 | 13.6 | 8.5 | 118.2 | 2,966,980.4 | 1,683.9 | 1.1 | 0.7 |
| **Minimum:** | 9.6 | 13.2 | 7.8 | 95.4 | 2,398,840.3 | 1,226.2 | 1.0 | 0.5 |
| **Maximum:** | 11.0 | 13.9 | 9.3 | 157.8 | 3,429,881.4 | 2,257.8 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/13/2014 00:00 | 9.7 | 13.7 | 7.9 | 117.6 | 3,141,797.2 | 1,674.8 | 1.1 | 0.7 |
| 03/13/2014 01:00 | 10.4 | 13.7 | 8.5 | 121.4 | 3,455,385.6 | 1,791.5 | 1.0 | 0.7 |
| 03/13/2014 02:00 | 9.9 | 13.8 | 8.2 | 96.4 | 2,719,481.2 | 1,390.1 | 1.0 | 0.6 |
| 03/13/2014 03:00 | 9.9 | 13.8 | 8.2 | 93.5 | 2,687,201.9 | 1,373.6 | 1.0 | 0.5 |
| 03/13/2014 04:00 | 10.0 | 13.8 | 8.3 | 94.9 | 2,692,679.6 | 1,376.4 | 1.0 | 0.6 |
| 03/13/2014 05:00 | 10.3 | 13.5 | 8.2 | 127.3 | 3,293,376.7 | 1,851.8 | 1.1 | 0.7 |
| 03/13/2014 06:00 | 10.2 | 13.5 | 8.1 | 128.3 | 3,441,468.8 | 1,960.2 | 1.1 | 0.8 |
| 03/13/2014 07:00 | 10.9 | 13.2 | 8.4 | 162.5 | 3,320,477.9 | 2,206.5 | 1.4 | 1.1 |
| 03/13/2014 08:00 | 10.4 | 13.3 | 8.1 | 141.1 | 3,410,681.8 | 2,092.1 | 1.2 | 1.0 |
| 03/13/2014 09:00 | 10.4 | 13.4 | 8.2 | 130.1 | 3,382,649.4 | 1,976.1 | 1.1 | 0.8 |
| 03/13/2014 10:00 | 10.0 | 13.6 | 8.1 | 121.8 | 3,391,667.8 | 1,882.3 | 1.0 | 0.8 |
| 03/13/2014 11:00 | 9.5 | 13.8 | 7.9 | 116.0 | 3,370,264.4 | 1,821.2 | 1.0 | 0.7 |
| 03/13/2014 12:00 | 9.7 | 13.6 | 7.8 | 120.1 | 3,401,217.7 | 1,887.6 | 1.0 | 0.8 |
| 03/13/2014 13:00 | 10.1 | 13.4 | 7.9 | 125.1 | 3,410,217.9 | 1,942.4 | 1.1 | 0.8 |
| 03/13/2014 14:00 | 10.1 | 13.4 | 7.9 | 129.3 | 3,418,820.6 | 1,947.3 | 1.1 | 0.8 |
| 03/13/2014 15:00 | 10.1 | 13.4 | 7.9 | 125.9 | 3,418,469.5 | 1,947.1 | 1.1 | 0.8 |
| 03/13/2014 16:00 | 9.7 | 13.5 | 7.7 | 120.4 | 3,366,649.8 | 1,893.0 | 1.0 | 0.8 |
| 03/13/2014 17:00 | 9.2 | 13.7 | 7.5 | 115.4 | 3,386,734.5 | 1,830.1 | 1.0 | 0.7 |
| 03/13/2014 18:00 | 9.4 | 13.6 | 7.6 | 117.0 | 3,387,408.2 | 1,855.2 | 1.0 | 0.7 |
| 03/13/2014 19:00 | 9.8 | 13.5 | 7.8 | 123.7 | 3,375,982.2 | 1,922.9 | 1.1 | 0.8 |
| 03/13/2014 20:00 | 9.4 | 13.6 | 7.6 | 119.9 | 3,407,127.9 | 1,866.0 | 1.0 | 0.7 |
| 03/13/2014 21:00 | 9.7 | 13.6 | 7.8 | 110.2 | 3,196,784.3 | 1,750.8 | 1.0 | 0.7 |
| 03/13/2014 22:00 | 10.7 | 13.9 | 9.0 | 79.0 | 2,031,247.6 | 1,038.3 | 1.1 | 0.4 |
| 03/13/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 10.0 | 13.6 | 8.0 | 119.0 | 3,222,077.9 | 1,794.7 | 1.1 | 0.7 |
| **Minimum:** | 9.2 | 13.2 | 7.5 | 79.0 | 2,031,247.6 | 1,038.3 | 1.0 | 0.4 |
| **Maximum:** | 10.9 | 13.9 | 9.0 | 162.5 | 3,455,385.6 | 2,206.5 | 1.4 | 1.1 |
| **%SI** | 4.2 | 4.2 | 4.2 | 4.2 | 4.2 | 4.2 | 4.2 | 4.2 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/14/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/15/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/30/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT1 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx, Inlet, Ppm 1 Hour(s) | Unit CT1 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT1 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/31/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/01/2014 00:00 | 10.1 | 13.9 | 8.5 | 101.3 | 3,209,343.9 | 1,640.5 | 0.9 | 0.5 |
| 01/01/2014 01:00 | 10.1 | 13.7 | 8.3 | 109.0 | 3,506,497.9 | 1,818.0 | 0.9 | 0.5 |
| 01/01/2014 02:00 | 10.1 | 13.8 | 8.4 | 103.6 | 3,277,360.4 | 1,699.2 | 0.9 | 0.5 |
| 01/01/2014 03:00 | 19.6 | 14.7 | 18.7 | 137.6 | 2,493,439.2 | 1,147.1 | 1.5 | 0.7 |
| 01/01/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 13:00 | 42.0 | 17.5 | 72.9 | 0.1 | 1,981,385.9 | 463.0 | -0.3 | 0.0 |
| 01/01/2014 14:00 | 52.5 | 15.1 | 53.4 | 240.6 | 2,234,324.0 | 930.0 | 2.9 | 1.0 |
| 01/01/2014 15:00 | 10.2 | 13.8 | 8.5 | 102.6 | 3,185,936.9 | 1,651.8 | 0.9 | 0.5 |
| 01/01/2014 16:00 | 9.7 | 13.8 | 8.1 | 106.7 | 3,387,564.7 | 1,731.6 | 0.9 | 0.5 |
| 01/01/2014 17:00 | 10.0 | 13.9 | 8.4 | 89.3 | 2,935,263.4 | 1,500.4 | 0.9 | 0.5 |
| 01/01/2014 18:00 | 10.1 | 13.7 | 8.3 | 106.2 | 3,353,568.2 | 1,763.2 | 0.9 | 0.5 |
| 01/01/2014 19:00 | 10.9 | 13.4 | 8.6 | 131.7 | 3,448,144.6 | 2,089.9 | 1.1 | 0.8 |
| 01/01/2014 20:00 | 11.1 | 13.3 | 8.6 | 145.5 | 3,422,144.3 | 2,174.1 | 1.3 | 1.1 |
| 01/01/2014 21:00 | 11.0 | 13.2 | 8.4 | 148.9 | 3,412,979.0 | 2,193.2 | 1.3 | 1.1 |
| 01/01/2014 22:00 | 10.8 | 13.3 | 8.4 | 130.4 | 3,430,245.1 | 2,104.1 | 1.1 | 0.8 |
| 01/01/2014 23:00 | 10.8 | 13.3 | 8.4 | 131.5 | 3,435,461.9 | 2,107.3 | 1.1 | 0.8 |
| **Average/Sum#:** | 15.9 | 14.0 | 16.4 | 119.0 | 3,114,244.0 | 1,667.6 | 1.1 | 0.7 |
| **Minimum:** | 9.7 | 13.2 | 8.1 | 0.1 | 1,981,385.9 | 463.0 | -0.3 | 0.0 |
| **Maximum:** | 52.5 | 17.5 | 72.9 | 240.6 | 3,506,497.9 | 2,193.2 | 2.9 | 1.1 |
| **%SI** | 37.5 | 37.5 | 37.5 | 37.5 | 37.5 | 37.5 | 37.5 | 37.5 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/02/2014 00:00 | 10.7 | 13.4 | 8.4 | 129.8 | 3,440,720.0 | 2,085.4 | 1.1 | 0.8 |
| 01/02/2014 01:00 | 9.9 | 13.6 | 8.0 | 109.2 | 3,408,953.8 | 1,867.0 | 0.9 | 0.6 |
| 01/02/2014 02:00 | 10.2 | 13.8 | 8.5 | 95.6 | 3,082,555.0 | 1,598.2 | 0.9 | 0.5 |
| 01/02/2014 03:00 | 10.0 | 13.8 | 8.3 | 103.2 | 3,316,900.2 | 1,719.7 | 0.9 | 0.5 |
| 01/02/2014 04:00 | 10.2 | 13.8 | 8.5 | 96.8 | 3,082,555.0 | 1,598.2 | 0.9 | 0.5 |
| 01/02/2014 05:00 | 10.2 | 13.7 | 8.4 | 108.7 | 3,308,711.9 | 1,812.1 | 0.9 | 0.5 |
| 01/02/2014 06:00 | 10.3 | 13.5 | 8.2 | 139.7 | 3,422,715.6 | 2,024.5 | 1.2 | 1.0 |
| 01/02/2014 07:00 | 10.4 | 13.5 | 8.3 | 119.8 | 3,456,598.3 | 2,019.3 | 1.0 | 0.8 |
| 01/02/2014 08:00 | 10.6 | 13.4 | 8.3 | 123.5 | 3,482,057.4 | 2,059.6 | 1.0 | 0.8 |
| 01/02/2014 09:00 | 10.6 | 13.4 | 8.3 | 124.5 | 3,498,794.8 | 2,069.5 | 1.0 | 0.8 |
| 01/02/2014 10:00 | 10.6 | 13.4 | 8.3 | 125.1 | 3,482,226.4 | 2,059.7 | 1.0 | 0.8 |
| 01/02/2014 11:00 | 10.8 | 13.4 | 8.5 | 125.5 | 3,421,723.9 | 2,048.9 | 1.1 | 0.8 |
| 01/02/2014 12:00 | 10.8 | 13.4 | 8.5 | 126.3 | 3,394,168.4 | 2,032.4 | 1.1 | 0.8 |
| 01/02/2014 13:00 | 10.9 | 13.4 | 8.6 | 127.5 | 3,373,627.1 | 2,020.1 | 1.1 | 0.8 |
| 01/02/2014 14:00 | 10.9 | 13.4 | 8.6 | 123.4 | 3,351,708.4 | 1,982.5 | 1.1 | 0.8 |
| 01/02/2014 15:00 | 11.0 | 13.4 | 8.7 | 127.5 | 3,355,423.7 | 2,009.2 | 1.1 | 0.8 |
| 01/02/2014 16:00 | 11.0 | 13.4 | 8.7 | 131.0 | 3,351,295.0 | 2,031.2 | 1.1 | 0.8 |
| 01/02/2014 17:00 | 11.0 | 13.4 | 8.7 | 130.5 | 3,340,743.4 | 2,049.2 | 1.1 | 0.8 |
| 01/02/2014 18:00 | 11.2 | 13.3 | 8.7 | 145.9 | 3,372,561.7 | 2,142.6 | 1.3 | 1.1 |
| 01/02/2014 19:00 | 11.2 | 13.2 | 8.6 | 150.7 | 3,340,780.0 | 2,171.2 | 1.3 | 1.1 |
| 01/02/2014 20:00 | 11.2 | 13.3 | 8.7 | 147.6 | 3,347,931.4 | 2,151.4 | 1.3 | 1.1 |
| 01/02/2014 21:00 | 11.1 | 13.3 | 8.6 | 143.7 | 3,373,191.3 | 2,143.0 | 1.3 | 1.1 |
| 01/02/2014 22:00 | 10.7 | 13.4 | 8.4 | 129.6 | 3,458,539.0 | 2,096.2 | 1.1 | 0.8 |
| 01/02/2014 23:00 | 11.0 | 13.3 | 8.5 | 143.6 | 3,434,866.7 | 2,157.1 | 1.2 | 1.1 |
| **Average/Sum#:** | 10.7 | 13.5 | 8.5 | 126.2 | 3,370,806.2 | 1,997.8 | 1.1 | 0.8 |
| **Minimum:** | 9.9 | 13.2 | 8.0 | 95.6 | 3,082,555.0 | 1,598.2 | 0.9 | 0.5 |
| **Maximum:** | 11.2 | 13.8 | 8.7 | 150.7 | 3,498,794.8 | 2,171.2 | 1.3 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/03/2014 00:00 | 10.6 | 13.4 | 8.3 | 123.0 | 3,418,550.9 | 2,047.0 | 1.0 | 0.8 |
| 01/03/2014 01:00 | 9.9 | 13.7 | 8.1 | 106.0 | 3,261,080.6 | 1,762.2 | 0.9 | 0.5 |
| 01/03/2014 02:00 | 10.6 | 13.9 | 8.9 | 84.6 | 2,590,559.7 | 1,324.2 | 0.9 | 0.4 |
| 01/03/2014 03:00 | 11.0 | 13.9 | 9.3 | 82.9 | 2,443,835.6 | 1,249.2 | 1.0 | 0.5 |
| 01/03/2014 04:00 | 11.0 | 13.9 | 9.3 | 82.9 | 2,445,791.9 | 1,250.2 | 1.0 | 0.5 |
| 01/03/2014 05:00 | 11.1 | 13.9 | 9.4 | 82.9 | 2,451,074.0 | 1,252.9 | 0.9 | 0.4 |
| 01/03/2014 06:00 | 10.8 | 13.8 | 9.0 | 104.0 | 2,850,593.8 | 1,561.2 | 1.0 | 0.6 |
| 01/03/2014 07:00 | 10.4 | 13.6 | 8.4 | 114.6 | 3,411,973.5 | 1,943.4 | 1.0 | 0.8 |
| 01/03/2014 08:00 | 10.3 | 13.5 | 8.2 | 116.8 | 3,509,540.0 | 2,024.6 | 1.0 | 0.8 |
| 01/03/2014 09:00 | 10.4 | 13.4 | 8.2 | 120.8 | 3,489,158.1 | 2,063.8 | 1.0 | 0.8 |
| 01/03/2014 10:00 | 10.5 | 13.4 | 8.3 | 123.0 | 3,467,983.8 | 2,076.6 | 1.0 | 0.8 |
| 01/03/2014 11:00 | 10.5 | 13.4 | 8.3 | 122.8 | 3,440,595.3 | 2,060.2 | 1.0 | 0.8 |
| 01/03/2014 12:00 | 10.5 | 13.4 | 8.3 | 121.2 | 3,419,503.4 | 2,022.6 | 1.0 | 0.8 |
| 01/03/2014 13:00 | 10.6 | 13.4 | 8.3 | 119.6 | 3,391,776.8 | 2,006.2 | 1.0 | 0.8 |
| 01/03/2014 14:00 | 10.7 | 13.4 | 8.4 | 120.7 | 3,369,122.1 | 1,992.8 | 1.0 | 0.8 |
| 01/03/2014 15:00 | 10.4 | 13.5 | 8.3 | 120.2 | 3,391,838.9 | 1,956.7 | 1.0 | 0.8 |
| 01/03/2014 16:00 | 10.8 | 13.4 | 8.5 | 124.5 | 3,342,731.5 | 2,001.6 | 1.1 | 0.8 |
| 01/03/2014 17:00 | 11.0 | 13.4 | 8.7 | 134.4 | 3,337,690.0 | 2,071.7 | 1.2 | 1.0 |
| 01/03/2014 18:00 | 11.1 | 13.3 | 8.6 | 147.3 | 3,352,444.3 | 2,154.3 | 1.3 | 1.1 |
| 01/03/2014 19:00 | 10.9 | 13.3 | 8.5 | 137.2 | 3,376,268.0 | 2,120.3 | 1.2 | 1.1 |
| 01/03/2014 20:00 | 11.0 | 13.3 | 8.5 | 139.3 | 3,379,771.2 | 2,122.5 | 1.2 | 1.1 |
| 01/03/2014 21:00 | 11.4 | 13.2 | 8.7 | 165.3 | 3,363,366.5 | 2,235.0 | 1.5 | 1.3 |
| 01/03/2014 22:00 | 11.2 | 13.2 | 8.6 | 157.9 | 3,361,632.5 | 2,209.3 | 1.4 | 1.1 |
| 01/03/2014 23:00 | 11.1 | 13.2 | 8.5 | 145.8 | 3,374,541.8 | 2,168.5 | 1.3 | 1.1 |
| **Average/Sum#:** | 10.7 | 13.5 | 8.6 | 120.7 | 3,218,392.7 | 1,903.2 | 1.1 | 0.8 |
| **Minimum:** | 9.9 | 13.2 | 8.1 | 82.9 | 2,443,835.6 | 1,249.2 | 0.9 | 0.4 |
| **Maximum:** | 11.4 | 13.9 | 9.4 | 165.3 | 3,509,540.0 | 2,235.0 | 1.5 | 1.3 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/04/2014 00:00 | 10.6 | 13.4 | 8.3 | 123.2 | 3,433,955.4 | 2,081.3 | 1.0 | 0.8 |
| 01/04/2014 01:00 | 10.6 | 13.3 | 8.2 | 130.3 | 3,447,688.9 | 2,114.8 | 1.1 | 0.8 |
| 01/04/2014 02:00 | 10.0 | 13.9 | 8.4 | 99.7 | 3,141,768.1 | 1,628.9 | 0.9 | 0.5 |
| 01/04/2014 03:00 | 10.1 | 13.9 | 8.5 | 94.7 | 3,123,265.8 | 1,596.5 | 0.9 | 0.5 |
| 01/04/2014 04:00 | 9.5 | 13.9 | 8.0 | 85.9 | 2,794,799.5 | 1,428.6 | 0.9 | 0.4 |
| 01/04/2014 05:00 | 10.1 | 13.8 | 8.4 | 98.3 | 3,197,702.4 | 1,657.9 | 0.9 | 0.5 |
| 01/04/2014 06:00 | 10.0 | 13.8 | 8.3 | 108.8 | 3,243,607.0 | 1,681.7 | 1.0 | 0.7 |
| 01/04/2014 07:00 | 9.9 | 13.7 | 8.1 | 107.9 | 3,493,173.4 | 1,836.6 | 0.9 | 0.6 |
| 01/04/2014 08:00 | 10.3 | 13.5 | 8.2 | 115.3 | 3,424,628.0 | 1,925.6 | 1.0 | 0.8 |
| 01/04/2014 09:00 | 10.9 | 13.3 | 8.5 | 138.7 | 3,452,399.4 | 2,142.9 | 1.2 | 1.1 |
| 01/04/2014 10:00 | 11.0 | 13.4 | 8.7 | 133.1 | 3,419,271.2 | 2,072.4 | 1.1 | 0.8 |
| 01/04/2014 11:00 | 11.0 | 13.4 | 8.7 | 126.3 | 3,392,622.1 | 2,006.7 | 1.1 | 0.8 |
| 01/04/2014 12:00 | 10.8 | 13.5 | 8.6 | 122.1 | 3,394,241.2 | 1,933.3 | 1.0 | 0.8 |
| 01/04/2014 13:00 | 9.9 | 13.7 | 8.1 | 107.1 | 3,394,550.8 | 1,883.9 | 0.9 | 0.6 |
| 01/04/2014 14:00 | 11.2 | 13.5 | 8.9 | 131.3 | 3,366,586.1 | 1,991.3 | 1.1 | 0.8 |
| 01/04/2014 15:00 | 11.6 | 13.4 | 9.1 | 138.8 | 3,353,274.8 | 2,032.4 | 1.2 | 1.0 |
| 01/04/2014 16:00 | 11.7 | 13.4 | 9.2 | 142.8 | 3,348,568.7 | 2,054.0 | 1.2 | 1.0 |
| 01/04/2014 17:00 | 11.7 | 13.4 | 9.2 | 148.5 | 3,377,483.9 | 2,096.4 | 1.3 | 1.0 |
| 01/04/2014 18:00 | 11.7 | 13.3 | 9.1 | 158.1 | 3,376,496.8 | 2,145.1 | 1.4 | 1.1 |
| 01/04/2014 19:00 | 11.8 | 13.3 | 9.2 | 157.0 | 3,382,006.0 | 2,148.6 | 1.4 | 1.1 |
| 01/04/2014 20:00 | 11.5 | 13.4 | 9.0 | 136.5 | 3,401,452.2 | 2,061.6 | 1.2 | 1.0 |
| 01/04/2014 21:00 | 12.0 | 13.2 | 9.2 | 169.0 | 3,385,247.9 | 2,200.1 | 1.5 | 1.3 |
| 01/04/2014 22:00 | 12.1 | 13.2 | 9.3 | 173.9 | 3,386,738.7 | 2,225.8 | 1.5 | 1.3 |
| 01/04/2014 23:00 | 11.5 | 13.4 | 9.0 | 136.2 | 3,418,611.2 | 2,072.0 | 1.2 | 1.0 |
| **Average/Sum#:** | 10.9 | 13.5 | 8.7 | 128.5 | 3,339,589.1 | 1,959.1 | 1.1 | 0.8 |
| **Minimum:** | 9.5 | 13.2 | 8.0 | 85.9 | 2,794,799.5 | 1,428.6 | 0.9 | 0.4 |
| **Maximum:** | 12.1 | 13.9 | 9.3 | 173.9 | 3,493,173.4 | 2,225.8 | 1.5 | 1.3 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/05/2014 00:00 | 11.4 | 13.4 | 9.0 | 133.4 | 3,428,070.0 | 2,052.7 | 1.1 | 0.8 |
| 01/05/2014 01:00 | 11.6 | 13.4 | 9.1 | 142.1 | 3,405,954.1 | 2,089.2 | 1.2 | 1.0 |
| 01/05/2014 02:00 | 10.5 | 13.9 | 8.9 | 103.9 | 3,124,023.5 | 1,619.7 | 0.9 | 0.5 |
| 01/05/2014 03:00 | 10.5 | 13.9 | 8.9 | 99.7 | 3,131,091.0 | 1,600.5 | 0.9 | 0.5 |
| 01/05/2014 04:00 | 10.5 | 13.9 | 8.9 | 105.3 | 3,326,723.1 | 1,700.5 | 0.9 | 0.5 |
| 01/05/2014 05:00 | 10.7 | 13.8 | 8.9 | 111.0 | 3,508,426.7 | 1,819.0 | 0.9 | 0.5 |
| 01/05/2014 06:00 | 10.9 | 13.6 | 8.8 | 125.7 | 3,292,685.6 | 1,899.5 | 1.1 | 0.8 |
| 01/05/2014 07:00 | 11.5 | 13.4 | 9.0 | 148.2 | 3,464,643.7 | 2,125.2 | 1.2 | 1.1 |
| 01/05/2014 08:00 | 12.0 | 13.2 | 9.2 | 176.7 | 3,439,385.4 | 2,260.4 | 1.5 | 1.4 |
| 01/05/2014 09:00 | 11.9 | 13.2 | 9.1 | 166.7 | 3,422,176.1 | 2,224.1 | 1.4 | 1.1 |
| 01/05/2014 10:00 | 11.6 | 13.4 | 9.1 | 140.7 | 3,452,929.3 | 2,092.8 | 1.2 | 1.0 |
| 01/05/2014 11:00 | 11.4 | 13.5 | 9.1 | 131.4 | 3,447,183.5 | 2,013.8 | 1.1 | 0.8 |
| 01/05/2014 12:00 | 10.7 | 13.6 | 8.6 | 122.2 | 3,440,990.0 | 1,934.8 | 1.0 | 0.8 |
| 01/05/2014 13:00 | 11.1 | 13.5 | 8.9 | 136.1 | 3,385,425.1 | 1,953.0 | 1.2 | 1.0 |
| 01/05/2014 14:00 | 11.6 | 13.4 | 9.1 | 133.2 | 3,376,299.1 | 2,021.7 | 1.1 | 0.8 |
| 01/05/2014 15:00 | 10.0 | 13.9 | 8.4 | 102.5 | 3,195,454.0 | 1,633.4 | 0.9 | 0.5 |
| 01/05/2014 16:00 | 11.3 | 13.6 | 9.1 | 126.7 | 3,305,404.2 | 1,882.7 | 1.1 | 0.8 |
| 01/05/2014 17:00 | 12.1 | 13.2 | 9.3 | 172.3 | 3,365,706.6 | 2,187.4 | 1.5 | 1.3 |
| 01/05/2014 18:00 | 12.3 | 13.2 | 9.4 | 179.7 | 3,349,521.8 | 2,225.8 | 1.6 | 1.3 |
| 01/05/2014 19:00 | 12.2 | 13.2 | 9.3 | 183.8 | 3,365,623.8 | 2,236.5 | 1.6 | 1.3 |
| 01/05/2014 20:00 | 12.2 | 13.2 | 9.3 | 179.9 | 3,382,478.2 | 2,247.7 | 1.6 | 1.3 |
| 01/05/2014 21:00 | 12.0 | 13.2 | 9.2 | 179.4 | 3,382,327.7 | 2,247.6 | 1.6 | 1.3 |
| 01/05/2014 22:00 | 11.9 | 13.2 | 9.1 | 178.3 | 3,396,172.5 | 2,256.8 | 1.6 | 1.4 |
| 01/05/2014 23:00 | 11.7 | 13.2 | 9.0 | 159.2 | 3,452,350.0 | 2,218.5 | 1.4 | 1.1 |
| **Average/Sum#:** | 11.4 | 13.5 | 9.0 | 143.3 | 3,368,376.9 | 2,022.6 | 1.2 | 1.0 |
| **Minimum:** | 10.0 | 13.2 | 8.4 | 99.7 | 3,124,023.5 | 1,600.5 | 0.9 | 0.5 |
| **Maximum:** | 12.3 | 13.9 | 9.4 | 183.8 | 3,508,426.7 | 2,260.4 | 1.6 | 1.4 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/06/2014 00:00 | 11.7 | 13.2 | 9.0 | 159.1 | 3,436,321.5 | 2,208.2 | 1.4 | 1.1 |
| 01/06/2014 01:00 | 11.4 | 13.3 | 8.9 | 144.0 | 3,442,410.7 | 2,136.7 | 1.2 | 1.1 |
| 01/06/2014 02:00 | 11.5 | 13.3 | 8.9 | 152.1 | 3,457,955.8 | 2,171.6 | 1.3 | 1.1 |
| 01/06/2014 03:00 | 11.0 | 13.4 | 8.7 | 129.6 | 3,483,917.1 | 2,060.7 | 1.1 | 0.8 |
| 01/06/2014 04:00 | 11.0 | 13.4 | 8.7 | 130.6 | 3,492,203.4 | 2,040.1 | 1.1 | 0.8 |
| 01/06/2014 05:00 | 11.5 | 13.3 | 8.9 | 156.2 | 3,479,282.4 | 2,210.4 | 1.3 | 1.1 |
| 01/06/2014 06:00 | 11.2 | 13.4 | 8.8 | 148.9 | 3,520,923.7 | 2,108.3 | 1.2 | 1.1 |
| 01/06/2014 07:00 | 11.2 | 13.4 | 8.8 | 136.0 | 3,467,983.8 | 2,076.6 | 1.1 | 0.8 |
| 01/06/2014 08:00 | 11.5 | 13.3 | 8.9 | 156.9 | 3,456,143.8 | 2,195.7 | 1.3 | 1.1 |
| 01/06/2014 09:00 | 11.0 | 13.3 | 8.5 | 140.3 | 3,495,415.5 | 2,169.6 | 1.2 | 1.1 |
| 01/06/2014 10:00 | 11.3 | 13.3 | 8.8 | 150.4 | 3,512,892.0 | 2,206.1 | 1.3 | 1.1 |
| 01/06/2014 11:00 | 11.7 | 13.2 | 9.0 | 167.0 | 3,439,255.5 | 2,235.2 | 1.4 | 1.1 |
| 01/06/2014 12:00 | 11.8 | 13.2 | 9.0 | 167.1 | 3,444,179.3 | 2,238.4 | 1.4 | 1.1 |
| 01/06/2014 13:00 | 11.8 | 13.2 | 9.0 | 170.0 | 3,419,300.5 | 2,247.2 | 1.5 | 1.3 |
| 01/06/2014 14:00 | 11.6 | 13.3 | 9.0 | 149.6 | 3,394,913.2 | 2,156.8 | 1.3 | 1.1 |
| 01/06/2014 15:00 | 11.1 | 13.4 | 8.7 | 128.1 | 3,444,017.8 | 2,037.1 | 1.1 | 0.8 |
| 01/06/2014 16:00 | 11.1 | 13.4 | 8.7 | 133.0 | 3,420,220.9 | 2,048.0 | 1.1 | 0.8 |
| 01/06/2014 17:00 | 11.3 | 13.3 | 8.8 | 140.7 | 3,439,374.6 | 2,109.7 | 1.2 | 1.1 |
| 01/06/2014 18:00 | 11.2 | 13.3 | 8.7 | 145.3 | 3,428,877.5 | 2,128.3 | 1.2 | 1.1 |
| 01/06/2014 19:00 | 11.7 | 13.2 | 9.0 | 169.8 | 3,424,017.4 | 2,250.3 | 1.5 | 1.4 |
| 01/06/2014 20:00 | 11.3 | 13.3 | 8.8 | 146.6 | 3,420,217.0 | 2,147.9 | 1.3 | 1.1 |
| 01/06/2014 21:00 | 11.7 | 13.2 | 9.0 | 174.9 | 3,405,352.1 | 2,262.9 | 1.5 | 1.4 |
| 01/06/2014 22:00 | 11.7 | 13.2 | 9.0 | 176.6 | 3,426,570.7 | 2,277.0 | 1.5 | 1.4 |
| 01/06/2014 23:00 | 11.2 | 13.3 | 8.7 | 142.0 | 3,424,834.8 | 2,150.8 | 1.2 | 1.1 |
| **Average/Sum#:** | 11.4 | 13.3 | 8.8 | 150.6 | 3,449,024.2 | 2,161.4 | 1.3 | 1.1 |
| **Minimum:** | 11.0 | 13.2 | 8.5 | 128.1 | 3,394,913.2 | 2,037.1 | 1.1 | 0.8 |
| **Maximum:** | 11.8 | 13.4 | 9.0 | 176.6 | 3,520,923.7 | 2,277.0 | 1.5 | 1.4 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/07/2014 00:00 | 10.7 | 13.5 | 8.5 | 123.1 | 3,419,623.9 | 1,997.7 | 1.0 | 0.8 |
| 01/07/2014 01:00 | 10.6 | 13.7 | 8.7 | 114.7 | 3,189,857.9 | 1,770.3 | 1.0 | 0.7 |
| 01/07/2014 02:00 | 10.5 | 13.9 | 8.9 | 93.7 | 2,921,764.7 | 1,493.5 | 0.9 | 0.4 |
| 01/07/2014 03:00 | 10.8 | 13.8 | 9.0 | 100.5 | 3,127,960.9 | 1,598.9 | 0.9 | 0.5 |
| 01/07/2014 04:00 | 10.7 | 13.8 | 8.9 | 99.3 | 3,093,529.7 | 1,581.3 | 0.9 | 0.5 |
| 01/07/2014 05:00 | 10.7 | 13.9 | 9.0 | 100.3 | 3,124,439.5 | 1,597.1 | 0.9 | 0.5 |
| 01/07/2014 06:00 | 10.7 | 13.7 | 8.8 | 115.2 | 3,236,287.7 | 1,819.7 | 1.0 | 0.7 |
| 01/07/2014 07:00 | 10.7 | 13.5 | 8.5 | 125.6 | 3,552,182.8 | 2,049.2 | 1.0 | 0.8 |
| 01/07/2014 08:00 | 11.2 | 13.2 | 8.6 | 151.0 | 3,509,866.5 | 2,204.2 | 1.3 | 1.1 |
| 01/07/2014 09:00 | 11.2 | 13.3 | 8.7 | 147.8 | 3,495,535.4 | 2,195.2 | 1.2 | 1.1 |
| 01/07/2014 10:00 | 11.0 | 13.4 | 8.7 | 133.8 | 3,501,766.6 | 2,122.4 | 1.1 | 0.8 |
| 01/07/2014 11:00 | 11.0 | 13.4 | 8.7 | 134.6 | 3,488,191.1 | 2,088.7 | 1.1 | 0.8 |
| 01/07/2014 12:00 | 11.6 | 13.2 | 8.9 | 168.7 | 3,419,909.2 | 2,247.6 | 1.5 | 1.3 |
| 01/07/2014 13:00 | 11.7 | 13.2 | 9.0 | 165.3 | 3,412,757.7 | 2,242.9 | 1.4 | 1.1 |
| 01/07/2014 14:00 | 11.3 | 13.3 | 8.8 | 141.7 | 3,421,930.7 | 2,099.0 | 1.2 | 1.0 |
| 01/07/2014 15:00 | 11.3 | 13.3 | 8.8 | 143.8 | 3,401,972.4 | 2,111.6 | 1.2 | 1.1 |
| 01/07/2014 16:00 | 11.0 | 13.4 | 8.7 | 128.3 | 3,411,050.2 | 2,017.6 | 1.1 | 0.8 |
| 01/07/2014 17:00 | 10.9 | 13.4 | 8.6 | 130.1 | 3,415,107.7 | 2,020.0 | 1.1 | 0.8 |
| 01/07/2014 18:00 | 11.1 | 13.4 | 8.7 | 133.5 | 3,418,281.3 | 2,071.8 | 1.1 | 0.8 |
| 01/07/2014 19:00 | 11.5 | 13.2 | 8.8 | 160.6 | 3,394,018.3 | 2,205.8 | 1.4 | 1.1 |
| 01/07/2014 20:00 | 11.6 | 13.1 | 8.8 | 172.2 | 3,387,143.3 | 2,250.8 | 1.5 | 1.4 |
| 01/07/2014 21:00 | 11.1 | 13.4 | 8.7 | 137.1 | 3,425,680.3 | 2,101.3 | 1.2 | 1.1 |
| 01/07/2014 22:00 | 10.9 | 13.4 | 8.6 | 129.1 | 3,467,315.7 | 2,076.2 | 1.1 | 0.8 |
| 01/07/2014 23:00 | 10.5 | 13.6 | 8.5 | 121.1 | 3,346,311.4 | 1,906.0 | 1.0 | 0.8 |
| **Average/Sum#:** | 11.0 | 13.5 | 8.7 | 132.1 | 3,357,603.5 | 1,994.5 | 1.1 | 0.9 |
| **Minimum:** | 10.5 | 13.1 | 8.5 | 93.7 | 2,921,764.7 | 1,493.5 | 0.9 | 0.4 |
| **Maximum:** | 11.7 | 13.9 | 9.0 | 172.2 | 3,552,182.8 | 2,250.8 | 1.5 | 1.4 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/08/2014 00:00 | 10.8 | 13.9 | 9.1 | 92.3 | 2,671,747.0 | 1,365.7 | 1.0 | 0.5 |
| 01/08/2014 01:00 | 11.0 | 13.9 | 9.3 | 87.5 | 2,574,126.6 | 1,315.8 | 1.0 | 0.5 |
| 01/08/2014 02:00 | 11.2 | 13.9 | 9.4 | 88.9 | 2,524,436.0 | 1,290.4 | 1.0 | 0.5 |
| 01/08/2014 03:00 | 11.5 | 13.9 | 9.7 | 86.4 | 2,476,114.9 | 1,265.7 | 1.0 | 0.5 |
| 01/08/2014 04:00 | 11.4 | 13.9 | 9.6 | 86.9 | 2,539,499.7 | 1,298.1 | 1.0 | 0.5 |
| 01/08/2014 05:00 | 10.4 | 13.8 | 8.6 | 106.6 | 3,161,248.7 | 1,639.0 | 1.0 | 0.7 |
| 01/08/2014 06:00 | 10.2 | 13.8 | 8.5 | 108.1 | 3,147,119.8 | 1,723.6 | 1.0 | 0.7 |
| 01/08/2014 07:00 | 10.4 | 13.6 | 8.4 | 117.6 | 3,544,827.1 | 1,967.3 | 0.9 | 0.6 |
| 01/08/2014 08:00 | 10.7 | 13.4 | 8.4 | 125.1 | 3,495,113.4 | 2,041.8 | 1.0 | 0.8 |
| 01/08/2014 09:00 | 10.2 | 13.7 | 8.4 | 117.5 | 3,307,900.1 | 1,787.5 | 1.0 | 0.7 |
| 01/08/2014 10:00 | 11.1 | 13.9 | 9.4 | 84.2 | 2,431,510.8 | 1,242.9 | 1.0 | 0.5 |
| 01/08/2014 11:00 | 10.9 | 13.9 | 9.2 | 94.3 | 2,705,591.3 | 1,383.0 | 1.0 | 0.6 |
| 01/08/2014 12:00 | 10.6 | 13.7 | 8.7 | 107.7 | 3,251,051.5 | 1,709.3 | 0.9 | 0.5 |
| 01/08/2014 13:00 | 10.2 | 13.9 | 8.6 | 91.0 | 2,906,114.2 | 1,485.5 | 0.9 | 0.4 |
| 01/08/2014 14:00 | 11.0 | 13.9 | 9.3 | 85.3 | 2,464,768.3 | 1,259.9 | 1.0 | 0.5 |
| 01/08/2014 15:00 | 10.7 | 13.9 | 9.0 | 89.7 | 2,749,804.2 | 1,405.6 | 0.9 | 0.4 |
| 01/08/2014 16:00 | 10.2 | 13.8 | 8.5 | 93.7 | 2,994,344.2 | 1,530.6 | 0.9 | 0.5 |
| 01/08/2014 17:00 | 10.5 | 13.6 | 8.5 | 111.3 | 3,298,121.7 | 1,806.3 | 1.0 | 0.7 |
| 01/08/2014 18:00 | 9.7 | 13.9 | 8.2 | 89.7 | 2,814,754.0 | 1,438.8 | 0.9 | 0.4 |
| 01/08/2014 19:00 | 10.2 | 13.8 | 8.5 | 94.7 | 3,008,234.1 | 1,537.7 | 0.9 | 0.5 |
| 01/08/2014 20:00 | 10.1 | 13.9 | 8.5 | 88.3 | 2,925,677.4 | 1,495.5 | 0.8 | 0.4 |
| 01/08/2014 21:00 | 10.2 | 13.9 | 8.6 | 91.8 | 2,911,983.1 | 1,488.5 | 0.9 | 0.4 |
| 01/08/2014 22:00 | 28.0 | 15.6 | 31.2 | 173.3 | 1,858,184.4 | 746.3 | 2.6 | 0.7 |
| 01/08/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 11.4 | 13.9 | 9.8 | 100.5 | 2,859,229.2 | 1,488.0 | 1.0 | 0.5 |
| **Minimum:** | 9.7 | 13.4 | 8.2 | 84.2 | 1,858,184.4 | 746.3 | 0.8 | 0.4 |
| **Maximum:** | 28.0 | 15.6 | 31.2 | 173.3 | 3,544,827.1 | 2,041.8 | 2.6 | 0.8 |
| **%SI** | 4.2 | 4.2 | 4.2 | 4.2 | 4.2 | 4.2 | 4.2 | 4.2 |

# Daily Summary Report
## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/09/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/10/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report
## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/12/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/13/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/14/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/15/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 08:00 | 42.6 | 17.3 | 69.8 | 0.1 | 2,091,484.5 | 504.0 | -0.2 | -0.1 |
| 01/29/2014 09:00 | 49.0 | 17.1 | 76.1 | 130.0 | 2,197,205.4 | 609.7 | 1.5 | 0.4 |
| 01/29/2014 10:00 | 38.9 | 17.9 | 76.5 | 257.7 | 2,875,791.2 | 630.0 | 1.8 | 0.4 |
| 01/29/2014 11:00 | 46.5 | 17.5 | 80.7 | 256.0 | 2,659,173.2 | 640.8 | 2.0 | 0.5 |
| 01/29/2014 12:00 | 34.0 | 14.5 | 31.3 | 190.7 | 2,927,874.2 | 1,304.2 | 1.8 | 0.9 |
| 01/29/2014 13:00 | 9.4 | 13.7 | 7.7 | 108.4 | 3,465,024.1 | 1,821.8 | 0.9 | 0.5 |
| 01/29/2014 14:00 | 9.4 | 13.7 | 7.7 | 106.3 | 3,445,814.1 | 1,811.7 | 0.9 | 0.5 |
| 01/29/2014 15:00 | 8.9 | 13.8 | 7.4 | 98.2 | 3,196,159.4 | 1,657.1 | 0.9 | 0.5 |
| 01/29/2014 16:00 | 9.6 | 13.9 | 8.1 | 82.5 | 2,511,720.0 | 1,283.9 | 0.9 | 0.4 |
| 01/29/2014 17:00 | 9.4 | 13.8 | 7.8 | 91.7 | 2,973,772.6 | 1,541.8 | 0.9 | 0.5 |
| 01/29/2014 18:00 | 9.4 | 13.7 | 7.7 | 106.4 | 3,455,704.4 | 1,816.9 | 0.9 | 0.5 |
| 01/29/2014 19:00 | 9.4 | 13.7 | 7.7 | 106.4 | 3,453,992.6 | 1,816.0 | 0.9 | 0.5 |
| 01/29/2014 20:00 | 9.3 | 13.7 | 7.6 | 103.6 | 3,390,964.8 | 1,758.1 | 0.9 | 0.5 |
| 01/29/2014 21:00 | 9.4 | 13.7 | 7.7 | 106.3 | 3,497,239.8 | 1,813.2 | 0.9 | 0.5 |
| 01/29/2014 22:00 | 9.4 | 13.8 | 7.8 | 100.3 | 3,218,725.9 | 1,668.8 | 0.9 | 0.5 |
| 01/29/2014 23:00 | 9.9 | 13.9 | 8.3 | 83.0 | 2,533,630.7 | 1,295.1 | 0.9 | 0.4 |
| **Average/Sum#:** | 19.7 | 14.7 | 26.2 | 120.5 | 2,993,392.3 | 1,373.3 | 1.1 | 0.5 |
| **Minimum:** | 8.9 | 13.7 | 7.4 | 0.1 | 2,091,484.5 | 504.0 | -0.2 | -0.1 |
| **Maximum:** | 49.0 | 17.9 | 80.7 | 257.7 | 3,497,239.8 | 1,821.8 | 2.0 | 0.9 |
| **%SI** | 33.3 | 33.3 | 33.3 | 33.3 | 33.3 | 33.3 | 33.3 | 33.3 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/30/2014 00:00 | 9.5 | 13.8 | 7.9 | 90.0 | 2,868,748.5 | 1,466.4 | 0.9 | 0.4 |
| 01/30/2014 01:00 | 9.6 | 13.7 | 7.9 | 103.5 | 3,376,884.8 | 1,750.8 | 0.9 | 0.5 |
| 01/30/2014 02:00 | 9.6 | 13.9 | 8.1 | 83.0 | 2,601,906.3 | 1,330.0 | 0.9 | 0.4 |
| 01/30/2014 03:00 | 10.3 | 13.9 | 8.7 | 83.3 | 2,467,898.4 | 1,261.5 | 1.0 | 0.5 |
| 01/30/2014 04:00 | 10.2 | 13.9 | 8.6 | 83.7 | 2,514,067.5 | 1,285.1 | 0.9 | 0.4 |
| 01/30/2014 05:00 | 10.5 | 13.9 | 8.9 | 84.0 | 2,464,181.4 | 1,259.6 | 1.0 | 0.5 |
| 01/30/2014 06:00 | 10.2 | 13.9 | 8.6 | 89.4 | 2,840,773.1 | 1,452.1 | 0.9 | 0.4 |
| 01/30/2014 07:00 | 9.6 | 13.9 | 8.1 | 95.1 | 3,029,362.4 | 1,548.5 | 0.9 | 0.5 |
| 01/30/2014 08:00 | 9.7 | 13.9 | 8.2 | 96.9 | 3,053,229.5 | 1,560.7 | 0.9 | 0.5 |
| 01/30/2014 09:00 | 10.5 | 13.9 | 8.9 | 84.3 | 2,441,096.8 | 1,247.8 | 1.0 | 0.5 |
| 01/30/2014 10:00 | 10.0 | 13.8 | 8.3 | 91.6 | 2,930,568.2 | 1,519.4 | 0.9 | 0.5 |
| 01/30/2014 11:00 | 9.9 | 13.7 | 8.1 | 116.1 | 3,424,965.5 | 1,950.8 | 1.0 | 0.8 |
| 01/30/2014 12:00 | 9.8 | 13.7 | 8.0 | 116.9 | 3,391,550.7 | 1,981.3 | 1.0 | 0.8 |
| 01/30/2014 13:00 | 9.9 | 13.7 | 8.1 | 131.1 | 3,388,922.6 | 2,103.5 | 1.1 | 0.8 |
| 01/30/2014 14:00 | 9.9 | 13.7 | 8.1 | 158.3 | 3,339,417.4 | 2,194.7 | 1.4 | 1.1 |
| 01/30/2014 15:00 | 9.9 | 13.7 | 8.1 | 162.6 | 3,344,104.2 | 2,222.2 | 1.5 | 1.3 |
| 01/30/2014 16:00 | 9.9 | 13.7 | 8.1 | 129.1 | 3,181,967.4 | 1,882.1 | 1.2 | 0.9 |
| 01/30/2014 17:00 | 9.8 | 13.8 | 8.1 | 96.2 | 3,071,814.5 | 1,570.2 | 0.9 | 0.5 |
| 01/30/2014 18:00 | 9.8 | 13.8 | 8.1 | 98.3 | 3,209,539.5 | 1,640.6 | 0.9 | 0.5 |
| 01/30/2014 19:00 | 10.0 | 13.7 | 8.2 | 112.8 | 3,343,995.7 | 1,929.1 | 1.0 | 0.8 |
| 01/30/2014 20:00 | 10.0 | 13.7 | 8.2 | 131.3 | 3,400,248.1 | 2,085.7 | 1.1 | 0.8 |
| 01/30/2014 21:00 | 10.0 | 13.7 | 8.2 | 134.5 | 3,408,876.8 | 2,066.1 | 1.2 | 1.0 |
| 01/30/2014 22:00 | 9.9 | 13.7 | 8.1 | 126.3 | 3,426,471.0 | 2,001.7 | 1.1 | 0.8 |
| 01/30/2014 23:00 | 10.1 | 13.7 | 8.3 | 120.5 | 3,429,209.8 | 2,003.3 | 1.0 | 0.8 |
| **Average/Sum#:** | 9.9 | 13.8 | 8.2 | 109.1 | 3,081,241.7 | 1,721.4 | 1.0 | 0.7 |
| **Minimum:** | 9.5 | 13.7 | 7.9 | 83.0 | 2,441,096.8 | 1,247.8 | 0.9 | 0.4 |
| **Maximum:** | 10.5 | 13.9 | 8.9 | 162.6 | 3,429,209.8 | 2,222.2 | 1.5 | 1.3 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/31/2014 00:00 | 10.1 | 13.8 | 8.4 | 102.0 | 2,917,624.3 | 1,555.3 | 1.0 | 0.6 |
| 01/31/2014 01:00 | 9.8 | 13.9 | 8.3 | 91.1 | 2,917,656.5 | 1,491.4 | 0.9 | 0.4 |
| 01/31/2014 02:00 | 10.0 | 13.9 | 8.4 | 97.6 | 3,476,840.1 | 1,624.9 | 0.8 | 0.5 |
| 01/31/2014 03:00 | 10.4 | 13.9 | 8.8 | 88.9 | 2,761,346.5 | 1,411.5 | 0.9 | 0.4 |
| 01/31/2014 04:00 | 10.7 | 13.9 | 9.0 | 86.5 | 2,600,732.5 | 1,329.4 | 0.9 | 0.4 |
| 01/31/2014 05:00 | 10.2 | 13.8 | 8.5 | 106.5 | 3,412,567.0 | 1,769.3 | 0.9 | 0.5 |
| 01/31/2014 06:00 | 10.1 | 13.7 | 8.3 | 117.4 | 3,447,392.5 | 1,938.4 | 1.0 | 0.8 |
| 01/31/2014 07:00 | 10.0 | 13.7 | 8.2 | 121.1 | 3,446,444.8 | 1,912.7 | 1.0 | 0.8 |
| 01/31/2014 08:00 | 10.1 | 13.7 | 8.3 | 119.1 | 3,515,558.2 | 2,002.4 | 1.0 | 0.8 |
| 01/31/2014 09:00 | 9.9 | 13.8 | 8.2 | 115.8 | 3,510,172.6 | 1,973.7 | 0.9 | 0.6 |
| 01/31/2014 10:00 | 9.9 | 13.8 | 8.2 | 117.6 | 3,503,947.9 | 1,970.2 | 1.0 | 0.8 |
| 01/31/2014 11:00 | 9.6 | 13.8 | 8.0 | 111.7 | 3,483,851.2 | 1,958.9 | 0.9 | 0.6 |
| 01/31/2014 12:00 | 10.2 | 13.7 | 8.4 | 125.1 | 3,436,228.1 | 2,007.4 | 1.1 | 0.8 |
| 01/31/2014 13:00 | 10.3 | 13.7 | 8.4 | 124.6 | 3,392,791.2 | 2,006.8 | 1.1 | 0.8 |
| 01/31/2014 14:00 | 10.3 | 13.7 | 8.4 | 123.0 | 3,441,644.4 | 1,960.3 | 1.0 | 0.8 |
| 01/31/2014 15:00 | 9.9 | 13.8 | 8.2 | 114.4 | 3,450,771.6 | 1,940.3 | 0.9 | 0.6 |
| 01/31/2014 16:00 | 9.9 | 13.8 | 8.2 | 116.2 | 3,422,493.9 | 1,924.4 | 1.0 | 0.8 |
| 01/31/2014 17:00 | 10.4 | 13.7 | 8.5 | 119.5 | 3,428,652.4 | 1,952.9 | 1.0 | 0.8 |
| 01/31/2014 18:00 | 9.9 | 13.8 | 8.2 | 118.9 | 3,444,013.4 | 1,936.5 | 1.0 | 0.8 |
| 01/31/2014 19:00 | 10.3 | 13.7 | 8.4 | 139.6 | 3,445,009.8 | 2,088.0 | 1.2 | 1.0 |
| 01/31/2014 20:00 | 10.3 | 13.7 | 8.4 | 124.4 | 3,432,859.5 | 2,030.5 | 1.0 | 0.8 |
| 01/31/2014 21:00 | 10.3 | 13.7 | 8.4 | 135.3 | 3,430,985.5 | 2,079.5 | 1.2 | 1.0 |
| 01/31/2014 22:00 | 10.3 | 13.7 | 8.4 | 147.3 | 3,414,643.8 | 2,144.4 | 1.3 | 1.1 |
| 01/31/2014 23:00 | 10.2 | 13.7 | 8.4 | 142.7 | 3,429,683.1 | 2,128.8 | 1.2 | 1.1 |
| **Average/Sum#:** | 10.1 | 13.8 | 8.4 | 116.9 | 3,340,163.0 | 1,880.7 | 1.0 | 0.7 |
| **Minimum:** | 9.6 | 13.7 | 8.0 | 86.5 | 2,600,732.5 | 1,329.4 | 0.8 | 0.4 |
| **Maximum:** | 10.7 | 13.9 | 9.0 | 147.3 | 3,515,558.2 | 2,144.4 | 1.3 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/01/2014 00:00 | 10.0 | 13.9 | 8.4 | 109.2 | 3,263,014.0 | 1,810.9 | 1.0 | 0.7 |
| 02/01/2014 01:00 | 10.2 | 13.9 | 8.6 | 100.7 | 3,176,477.7 | 1,623.7 | 0.9 | 0.5 |
| 02/01/2014 02:00 | 10.2 | 13.9 | 8.6 | 102.2 | 3,244,753.3 | 1,658.6 | 0.9 | 0.5 |
| 02/01/2014 03:00 | 10.2 | 13.8 | 8.5 | 107.9 | 3,444,777.4 | 1,786.0 | 0.9 | 0.5 |
| 02/01/2014 04:00 | 9.9 | 13.9 | 8.3 | 91.1 | 2,872,465.5 | 1,468.3 | 0.9 | 0.4 |
| 02/01/2014 05:00 | 10.5 | 13.6 | 8.5 | 113.9 | 3,370,766.0 | 1,870.7 | 1.0 | 0.7 |
| 02/01/2014 06:00 | 11.3 | 13.2 | 8.7 | 155.3 | 3,427,973.5 | 2,252.9 | 1.3 | 1.1 |
| 02/01/2014 07:00 | 11.2 | 13.2 | 8.6 | 155.1 | 3,468,952.0 | 2,254.5 | 1.3 | 1.1 |
| 02/01/2014 08:00 | 11.1 | 13.2 | 8.5 | 142.5 | 3,473,458.4 | 2,206.7 | 1.2 | 1.1 |
| 02/01/2014 09:00 | 10.9 | 13.3 | 8.5 | 131.6 | 3,499,857.5 | 2,146.8 | 1.1 | 0.9 |
| 02/01/2014 10:00 | 10.1 | 13.7 | 8.3 | 111.7 | 3,385,764.8 | 1,854.3 | 0.9 | 0.6 |
| 02/01/2014 11:00 | 10.2 | 13.8 | 8.5 | 98.2 | 3,073,183.9 | 1,570.9 | 0.9 | 0.5 |
| 02/01/2014 12:00 | 10.1 | 13.8 | 8.4 | 94.8 | 3,012,342.4 | 1,539.8 | 0.9 | 0.5 |
| 02/01/2014 13:00 | 10.1 | 13.9 | 8.5 | 98.3 | 3,111,919.1 | 1,590.7 | 0.9 | 0.5 |
| 02/01/2014 14:00 | 10.0 | 13.9 | 8.4 | 90.7 | 2,823,166.2 | 1,443.1 | 0.9 | 0.4 |
| 02/01/2014 15:00 | 11.1 | 13.9 | 9.4 | 85.3 | 2,468,876.5 | 1,262.0 | 1.0 | 0.5 |
| 02/01/2014 16:00 | 10.8 | 13.9 | 9.1 | 86.0 | 2,568,062.0 | 1,312.7 | 0.9 | 0.4 |
| 02/01/2014 17:00 | 10.4 | 13.7 | 8.5 | 103.6 | 3,169,560.9 | 1,689.6 | 0.9 | 0.5 |
| 02/01/2014 18:00 | 10.8 | 13.4 | 8.5 | 122.9 | 3,435,057.4 | 2,031.8 | 1.0 | 0.8 |
| 02/01/2014 19:00 | 11.4 | 13.2 | 8.7 | 158.5 | 3,408,789.6 | 2,215.4 | 1.4 | 1.1 |
| 02/01/2014 20:00 | 11.4 | 13.1 | 8.6 | 166.0 | 3,403,847.3 | 2,261.9 | 1.5 | 1.4 |
| 02/01/2014 21:00 | 11.3 | 13.1 | 8.5 | 161.1 | 3,414,381.3 | 2,268.9 | 1.4 | 1.1 |
| 02/01/2014 22:00 | 11.2 | 13.1 | 8.5 | 157.9 | 3,451,405.9 | 2,268.3 | 1.4 | 1.1 |
| 02/01/2014 23:00 | 11.0 | 13.1 | 8.3 | 149.7 | 3,469,875.2 | 2,255.1 | 1.3 | 1.1 |
| **Average/Sum#:** | 10.6 | 13.6 | 8.6 | 120.6 | 3,226,613.7 | 1,860.2 | 1.1 | 0.8 |
| **Minimum:** | 9.9 | 13.1 | 8.3 | 85.3 | 2,468,876.5 | 1,262.0 | 0.9 | 0.4 |
| **Maximum:** | 11.4 | 13.9 | 9.4 | 166.0 | 3,499,857.5 | 2,268.9 | 1.5 | 1.4 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/02/2014 00:00 | 10.8 | 13.2 | 8.3 | 138.4 | 3,493,624.5 | 2,194.0 | 1.2 | 1.1 |
| 02/02/2014 01:00 | 10.4 | 13.3 | 8.1 | 121.6 | 3,471,903.3 | 2,104.3 | 1.0 | 0.8 |
| 02/02/2014 02:00 | 10.4 | 13.3 | 8.1 | 122.4 | 3,513,575.6 | 2,103.9 | 1.0 | 0.8 |
| 02/02/2014 03:00 | 10.4 | 13.3 | 8.1 | 122.8 | 3,518,752.7 | 2,107.0 | 1.0 | 0.8 |
| 02/02/2014 04:00 | 10.2 | 13.4 | 8.0 | 116.1 | 3,523,871.3 | 2,058.6 | 0.9 | 0.6 |
| 02/02/2014 05:00 | 10.2 | 13.4 | 8.0 | 116.3 | 3,527,808.4 | 2,060.9 | 0.9 | 0.6 |
| 02/02/2014 06:00 | 10.2 | 13.4 | 8.0 | 122.6 | 3,508,262.4 | 2,075.1 | 1.0 | 0.8 |
| 02/02/2014 07:00 | 10.6 | 13.2 | 8.1 | 143.2 | 3,506,041.2 | 2,227.4 | 1.2 | 1.1 |
| 02/02/2014 08:00 | 10.8 | 13.1 | 8.2 | 147.0 | 3,488,339.3 | 2,267.1 | 1.2 | 1.1 |
| 02/02/2014 09:00 | 10.8 | 13.1 | 8.2 | 150.0 | 3,490,647.4 | 2,268.6 | 1.3 | 1.1 |
| 02/02/2014 10:00 | 10.9 | 13.1 | 8.2 | 152.0 | 3,452,623.2 | 2,269.1 | 1.3 | 1.1 |
| 02/02/2014 11:00 | 11.0 | 13.1 | 8.3 | 154.2 | 3,453,688.3 | 2,269.8 | 1.3 | 1.1 |
| 02/02/2014 12:00 | 11.0 | 13.1 | 8.3 | 154.4 | 3,438,472.5 | 2,259.8 | 1.3 | 1.1 |
| 02/02/2014 13:00 | 11.0 | 13.2 | 8.4 | 152.7 | 3,448,179.8 | 2,241.0 | 1.3 | 1.1 |
| 02/02/2014 14:00 | 10.6 | 13.3 | 8.2 | 124.9 | 3,438,722.4 | 2,109.3 | 1.1 | 0.8 |
| 02/02/2014 15:00 | 11.1 | 13.1 | 8.4 | 156.1 | 3,413,975.0 | 2,243.7 | 1.4 | 1.1 |
| 02/02/2014 16:00 | 11.1 | 13.1 | 8.4 | 163.0 | 3,423,260.0 | 2,274.8 | 1.4 | 1.1 |
| 02/02/2014 17:00 | 10.7 | 13.2 | 8.2 | 134.0 | 3,422,931.3 | 2,174.6 | 1.1 | 0.9 |
| 02/02/2014 18:00 | 10.1 | 13.5 | 8.1 | 112.0 | 3,501,688.4 | 1,994.5 | 0.9 | 0.6 |
| 02/02/2014 19:00 | 10.6 | 13.3 | 8.2 | 132.1 | 3,452,882.8 | 2,143.2 | 1.1 | 0.9 |
| 02/02/2014 20:00 | 11.0 | 13.1 | 8.3 | 150.1 | 3,420,061.3 | 2,247.7 | 1.3 | 1.1 |
| 02/02/2014 21:00 | 11.0 | 13.1 | 8.3 | 154.8 | 3,420,099.8 | 2,272.7 | 1.3 | 1.1 |
| 02/02/2014 22:00 | 10.8 | 13.2 | 8.3 | 141.7 | 3,417,803.2 | 2,196.3 | 1.2 | 1.1 |
| 02/02/2014 23:00 | 10.9 | 13.1 | 8.2 | 152.9 | 3,426,452.0 | 2,251.9 | 1.3 | 1.1 |
| **Average/Sum#:** | 10.7 | 13.2 | 8.2 | 139.0 | 3,465,569.4 | 2,184.0 | 1.2 | 1.0 |
| **Minimum:** | 10.1 | 13.1 | 8.0 | 112.0 | 3,413,975.0 | 1,994.5 | 0.9 | 0.6 |
| **Maximum:** | 11.1 | 13.5 | 8.4 | 163.0 | 3,527,808.4 | 2,274.8 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/03/2014 00:00 | 10.9 | 13.1 | 8.2 | 145.4 | 3,444,179.3 | 2,238.4 | 1.2 | 1.1 |
| 02/03/2014 01:00 | 10.5 | 13.3 | 8.2 | 126.2 | 3,470,349.6 | 2,128.7 | 1.1 | 0.9 |
| 02/03/2014 02:00 | 10.2 | 13.4 | 8.0 | 114.7 | 3,482,788.6 | 2,034.6 | 0.9 | 0.6 |
| 02/03/2014 03:00 | 10.2 | 13.5 | 8.1 | 115.5 | 3,466,723.8 | 1,999.9 | 1.0 | 0.8 |
| 02/03/2014 04:00 | 10.1 | 13.5 | 8.1 | 127.9 | 3,550,449.4 | 2,048.2 | 1.0 | 0.8 |
| 02/03/2014 05:00 | 10.3 | 13.3 | 8.0 | 122.8 | 3,528,330.2 | 2,138.5 | 1.0 | 0.9 |
| 02/03/2014 06:00 | 10.2 | 13.3 | 7.9 | 128.9 | 3,569,404.7 | 2,085.2 | 1.1 | 0.8 |
| 02/03/2014 07:00 | 10.2 | 13.3 | 7.9 | 118.8 | 3,505,058.4 | 2,098.8 | 1.0 | 0.8 |
| 02/03/2014 08:00 | 10.7 | 13.1 | 8.1 | 144.5 | 3,504,481.5 | 2,252.0 | 1.2 | 1.1 |
| 02/03/2014 09:00 | 10.6 | 13.2 | 8.1 | 138.4 | 3,478,023.1 | 2,209.6 | 1.2 | 1.1 |
| 02/03/2014 10:00 | 10.3 | 13.3 | 8.0 | 124.0 | 3,484,772.6 | 2,112.1 | 1.0 | 0.8 |
| 02/03/2014 11:00 | 10.2 | 13.6 | 8.2 | 115.0 | 3,431,386.2 | 1,929.4 | 1.0 | 0.8 |
| 02/03/2014 12:00 | 10.1 | 13.5 | 8.1 | 111.3 | 3,472,646.8 | 1,952.6 | 0.9 | 0.6 |
| 02/03/2014 13:00 | 10.4 | 13.4 | 8.2 | 118.9 | 3,450,264.7 | 2,015.6 | 1.0 | 0.8 |
| 02/03/2014 14:00 | 10.4 | 13.4 | 8.2 | 118.9 | 3,457,967.7 | 2,020.1 | 1.0 | 0.8 |
| 02/03/2014 15:00 | 10.2 | 13.5 | 8.1 | 118.3 | 3,430,494.8 | 1,979.0 | 1.0 | 0.8 |
| 02/03/2014 16:00 | 10.5 | 13.4 | 8.3 | 118.3 | 3,432,462.2 | 2,005.2 | 1.0 | 0.8 |
| 02/03/2014 17:00 | 10.7 | 13.3 | 8.3 | 137.7 | 3,445,669.7 | 2,088.4 | 1.2 | 1.0 |
| 02/03/2014 18:00 | 11.3 | 13.2 | 8.7 | 162.7 | 3,396,324.6 | 2,232.1 | 1.4 | 1.1 |
| 02/03/2014 19:00 | 11.3 | 13.1 | 8.5 | 163.4 | 3,414,080.3 | 2,268.7 | 1.4 | 1.1 |
| 02/03/2014 20:00 | 11.3 | 13.1 | 8.5 | 162.9 | 3,418,594.9 | 2,271.7 | 1.4 | 1.1 |
| 02/03/2014 21:00 | 11.3 | 13.1 | 8.5 | 160.1 | 3,413,327.9 | 2,268.2 | 1.4 | 1.1 |
| 02/03/2014 22:00 | 11.2 | 13.1 | 8.5 | 154.0 | 3,451,103.3 | 2,242.9 | 1.3 | 1.1 |
| 02/03/2014 23:00 | 10.8 | 13.3 | 8.4 | 136.7 | 3,427,541.8 | 2,152.5 | 1.2 | 1.1 |
| **Average/Sum#:** | 10.6 | 13.3 | 8.2 | 132.7 | 3,463,601.1 | 2,115.5 | 1.1 | 0.9 |
| **Minimum:** | 10.1 | 13.1 | 7.9 | 111.3 | 3,396,324.6 | 1,929.4 | 0.9 | 0.6 |
| **Maximum:** | 11.3 | 13.6 | 8.7 | 163.4 | 3,569,404.7 | 2,271.7 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/04/2014 00:00 | 10.3 | 13.3 | 8.0 | 120.0 | 3,505,893.4 | 2,099.3 | 1.0 | 0.8 |
| 02/04/2014 01:00 | 10.2 | 13.4 | 8.0 | 117.0 | 3,532,768.2 | 2,038.0 | 1.0 | 0.8 |
| 02/04/2014 02:00 | 10.2 | 13.6 | 8.2 | 114.8 | 3,431,637.1 | 1,954.6 | 1.0 | 0.8 |
| 02/04/2014 03:00 | 10.3 | 13.5 | 8.2 | 117.9 | 3,530,305.8 | 2,010.8 | 1.0 | 0.8 |
| 02/04/2014 04:00 | 10.4 | 13.6 | 8.4 | 114.4 | 3,381,411.1 | 1,901.3 | 1.0 | 0.8 |
| 02/04/2014 05:00 | 10.5 | 13.6 | 8.5 | 114.0 | 3,328,590.5 | 1,871.6 | 1.0 | 0.7 |
| 02/04/2014 06:00 | 10.5 | 13.5 | 8.4 | 134.6 | 3,392,999.4 | 2,031.7 | 1.2 | 1.0 |
| 02/04/2014 07:00 | 10.4 | 13.4 | 8.2 | 119.5 | 3,488,143.7 | 2,063.2 | 1.0 | 0.8 |
| 02/04/2014 08:00 | 10.3 | 13.4 | 8.1 | 118.5 | 3,536,196.1 | 2,065.8 | 1.0 | 0.8 |
| 02/04/2014 09:00 | 10.3 | 13.5 | 8.2 | 123.6 | 3,531,183.7 | 2,011.3 | 1.0 | 0.8 |
| 02/04/2014 10:00 | 10.3 | 13.4 | 8.1 | 116.3 | 3,548,022.6 | 2,046.8 | 0.9 | 0.6 |
| 02/04/2014 11:00 | 10.4 | 13.4 | 8.2 | 119.9 | 3,504,699.4 | 2,047.4 | 1.0 | 0.8 |
| 02/04/2014 12:00 | 10.4 | 13.5 | 8.3 | 118.4 | 3,478,858.0 | 2,006.9 | 1.0 | 0.8 |
| 02/04/2014 13:00 | 10.2 | 13.6 | 8.2 | 117.1 | 3,465,355.1 | 1,948.5 | 1.0 | 0.8 |
| 02/04/2014 14:00 | 10.7 | 13.4 | 8.4 | 123.9 | 3,440,636.5 | 2,035.1 | 1.0 | 0.8 |
| 02/04/2014 15:00 | 10.8 | 13.4 | 8.5 | 128.8 | 3,433,625.4 | 2,081.1 | 1.1 | 0.8 |
| 02/04/2014 16:00 | 10.7 | 13.4 | 8.4 | 125.3 | 3,412,872.8 | 2,043.6 | 1.1 | 0.8 |
| 02/04/2014 17:00 | 10.7 | 13.4 | 8.4 | 128.8 | 3,467,348.7 | 2,050.9 | 1.1 | 0.8 |
| 02/04/2014 18:00 | 10.9 | 13.3 | 8.5 | 139.9 | 3,439,349.6 | 2,134.8 | 1.2 | 1.1 |
| 02/04/2014 19:00 | 11.2 | 13.2 | 8.6 | 153.2 | 3,424,484.2 | 2,225.6 | 1.3 | 1.1 |
| 02/04/2014 20:00 | 11.1 | 13.2 | 8.5 | 148.7 | 3,424,027.8 | 2,200.3 | 1.3 | 1.1 |
| 02/04/2014 21:00 | 11.3 | 13.2 | 8.7 | 164.4 | 3,429,038.7 | 2,253.6 | 1.4 | 1.1 |
| 02/04/2014 22:00 | 11.1 | 13.2 | 8.5 | 153.8 | 3,444,640.9 | 2,238.7 | 1.3 | 1.1 |
| 02/04/2014 23:00 | 10.7 | 13.3 | 8.3 | 130.9 | 3,466,110.9 | 2,126.1 | 1.1 | 0.9 |
| **Average/Sum#:** | 10.6 | 13.4 | 8.3 | 127.7 | 3,459,925.0 | 2,062.0 | 1.1 | 0.9 |
| **Minimum:** | 10.2 | 13.2 | 8.0 | 114.0 | 3,328,590.5 | 1,871.6 | 0.9 | 0.6 |
| **Maximum:** | 11.3 | 13.6 | 8.7 | 164.4 | 3,548,022.6 | 2,253.6 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/05/2014 00:00 | 10.6 | 13.4 | 8.3 | 122.6 | 3,497,780.4 | 2,068.9 | 1.0 | 0.8 |
| 02/05/2014 01:00 | 10.3 | 13.6 | 8.3 | 113.9 | 3,387,991.5 | 1,905.0 | 1.0 | 0.8 |
| 02/05/2014 02:00 | 10.4 | 13.6 | 8.4 | 113.2 | 3,333,214.5 | 1,874.2 | 1.0 | 0.7 |
| 02/05/2014 03:00 | 10.5 | 13.6 | 8.5 | 112.7 | 3,333,392.4 | 1,874.3 | 1.0 | 0.7 |
| 02/05/2014 04:00 | 10.6 | 13.6 | 8.6 | 114.2 | 3,335,704.4 | 1,875.6 | 1.0 | 0.8 |
| 02/05/2014 05:00 | 10.5 | 13.6 | 8.5 | 118.0 | 3,405,954.1 | 1,915.1 | 1.0 | 0.8 |
| 02/05/2014 06:00 | 10.5 | 13.5 | 8.4 | 139.6 | 3,426,507.8 | 1,976.7 | 1.2 | 1.0 |
| 02/05/2014 07:00 | 10.6 | 13.3 | 8.2 | 129.9 | 3,498,553.2 | 2,146.0 | 1.1 | 0.9 |
| 02/05/2014 08:00 | 10.9 | 13.2 | 8.4 | 150.7 | 3,480,338.2 | 2,261.9 | 1.3 | 1.1 |
| 02/05/2014 09:00 | 10.5 | 13.4 | 8.3 | 126.0 | 3,548,668.9 | 2,099.0 | 1.0 | 0.8 |
| 02/05/2014 10:00 | 10.7 | 13.9 | 9.0 | 90.1 | 2,607,114.0 | 1,351.7 | 1.0 | 0.5 |
| 02/05/2014 11:00 | 10.8 | 13.7 | 8.9 | 101.3 | 2,889,485.5 | 1,561.4 | 1.0 | 0.6 |
| 02/05/2014 12:00 | 11.2 | 13.1 | 8.5 | 157.6 | 3,464,339.4 | 2,276.8 | 1.3 | 1.1 |
| 02/05/2014 13:00 | 11.0 | 13.2 | 8.4 | 144.3 | 3,413,445.9 | 2,193.5 | 1.2 | 1.1 |
| 02/05/2014 14:00 | 10.1 | 13.6 | 8.2 | 109.7 | 3,394,927.5 | 1,908.9 | 0.9 | 0.6 |
| 02/05/2014 15:00 | 10.1 | 13.6 | 8.2 | 108.9 | 3,348,509.4 | 1,882.8 | 0.9 | 0.6 |
| 02/05/2014 16:00 | 10.1 | 13.6 | 8.2 | 112.3 | 3,386,035.2 | 1,903.9 | 0.9 | 0.6 |
| 02/05/2014 17:00 | 10.5 | 13.4 | 8.3 | 122.0 | 3,453,485.4 | 2,042.7 | 1.0 | 0.8 |
| 02/05/2014 18:00 | 10.6 | 13.3 | 8.2 | 126.7 | 3,444,349.8 | 2,087.6 | 1.1 | 0.8 |
| 02/05/2014 19:00 | 11.0 | 13.1 | 8.3 | 152.9 | 3,403,932.5 | 2,237.1 | 1.3 | 1.1 |
| 02/05/2014 20:00 | 11.1 | 13.1 | 8.4 | 155.1 | 3,434,059.9 | 2,256.9 | 1.3 | 1.1 |
| 02/05/2014 21:00 | 11.0 | 13.1 | 8.3 | 154.6 | 3,436,494.4 | 2,258.5 | 1.3 | 1.1 |
| 02/05/2014 22:00 | 10.9 | 13.1 | 8.2 | 150.0 | 3,439,537.6 | 2,260.5 | 1.3 | 1.1 |
| 02/05/2014 23:00 | 10.8 | 13.1 | 8.2 | 147.5 | 3,439,537.6 | 2,260.5 | 1.3 | 1.1 |
| **Average/Sum#:** | 10.6 | 13.4 | 8.4 | 128.1 | 3,366,806.6 | 2,020.0 | 1.1 | 0.9 |
| **Minimum:** | 10.1 | 13.1 | 8.2 | 90.1 | 2,607,114.0 | 1,351.7 | 0.9 | 0.5 |
| **Maximum:** | 11.2 | 13.9 | 9.0 | 157.6 | 3,548,668.9 | 2,276.8 | 1.3 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/06/2014 00:00 | 10.7 | 13.1 | 8.1 | 140.8 | 3,418,637.2 | 2,221.8 | 1.2 | 1.1 |
| 02/06/2014 01:00 | 10.0 | 13.5 | 8.0 | 111.0 | 3,425,467.8 | 1,976.1 | 0.9 | 0.6 |
| 02/06/2014 02:00 | 10.1 | 13.6 | 8.2 | 105.4 | 3,281,000.4 | 1,868.8 | 0.9 | 0.6 |
| 02/06/2014 03:00 | 10.2 | 13.6 | 8.2 | 107.0 | 3,281,878.2 | 1,869.3 | 0.9 | 0.6 |
| 02/06/2014 04:00 | 10.1 | 13.6 | 8.2 | 106.3 | 3,289,603.2 | 1,873.7 | 0.9 | 0.6 |
| 02/06/2014 05:00 | 10.1 | 13.6 | 8.2 | 106.6 | 3,289,954.3 | 1,873.9 | 0.9 | 0.6 |
| 02/06/2014 06:00 | 10.1 | 13.6 | 8.2 | 108.4 | 3,305,404.2 | 1,882.7 | 0.9 | 0.6 |
| 02/06/2014 07:00 | 10.1 | 13.6 | 8.2 | 109.4 | 3,387,813.6 | 1,904.9 | 0.9 | 0.6 |
| 02/06/2014 08:00 | 10.0 | 13.5 | 8.0 | 122.1 | 3,440,942.1 | 1,959.9 | 1.0 | 0.8 |
| 02/06/2014 09:00 | 9.9 | 13.6 | 8.0 | 107.7 | 3,431,208.4 | 1,929.3 | 0.9 | 0.6 |
| 02/06/2014 10:00 | 10.0 | 13.6 | 8.1 | 106.2 | 3,356,334.7 | 1,887.2 | 0.9 | 0.6 |
| 02/06/2014 11:00 | 10.0 | 13.6 | 8.1 | 108.8 | 3,335,170.8 | 1,875.3 | 0.9 | 0.6 |
| 02/06/2014 12:00 | 10.1 | 13.6 | 8.2 | 105.3 | 3,313,117.8 | 1,862.9 | 0.9 | 0.6 |
| 02/06/2014 13:00 | 10.0 | 13.6 | 8.1 | 113.7 | 3,325,033.5 | 1,869.6 | 1.0 | 0.7 |
| 02/06/2014 14:00 | 9.9 | 13.6 | 8.0 | 114.9 | 3,322,010.1 | 1,867.9 | 1.0 | 0.7 |
| 02/06/2014 15:00 | 9.8 | 13.6 | 7.9 | 105.6 | 3,383,367.5 | 1,902.4 | 0.9 | 0.6 |
| 02/06/2014 16:00 | 9.8 | 13.6 | 7.9 | 104.0 | 3,323,432.9 | 1,868.7 | 0.9 | 0.6 |
| 02/06/2014 17:00 | 9.7 | 13.6 | 7.8 | 105.6 | 3,409,155.3 | 1,916.9 | 0.9 | 0.6 |
| 02/06/2014 18:00 | 9.7 | 13.7 | 7.9 | 103.9 | 3,424,461.9 | 1,900.5 | 0.9 | 0.6 |
| 02/06/2014 19:00 | 9.4 | 13.6 | 7.6 | 108.2 | 3,460,019.7 | 1,945.5 | 0.9 | 0.6 |
| 02/06/2014 20:00 | 9.6 | 13.6 | 7.8 | 104.4 | 3,370,384.6 | 1,895.1 | 0.9 | 0.6 |
| 02/06/2014 21:00 | 9.7 | 13.6 | 7.8 | 104.0 | 3,346,197.4 | 1,881.5 | 0.9 | 0.6 |
| 02/06/2014 22:00 | 9.7 | 13.6 | 7.8 | 104.1 | 3,347,620.2 | 1,882.3 | 0.9 | 0.6 |
| 02/06/2014 23:00 | 9.7 | 13.6 | 7.8 | 104.1 | 3,348,509.4 | 1,882.8 | 0.9 | 0.6 |
| **Average/Sum#:** | 9.9 | 13.6 | 8.0 | 109.1 | 3,359,030.2 | 1,908.3 | 0.9 | 0.6 |
| **Minimum:** | 9.4 | 13.1 | 7.6 | 103.9 | 3,281,000.4 | 1,862.9 | 0.9 | 0.6 |
| **Maximum:** | 10.7 | 13.7 | 8.2 | 140.8 | 3,460,019.7 | 2,221.8 | 1.2 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/07/2014 00:00 | 9.7 | 13.6 | 7.8 | 104.1 | 3,347,975.8 | 1,882.5 | 0.9 | 0.6 |
| 02/07/2014 01:00 | 9.9 | 13.4 | 7.8 | 112.2 | 3,464,814.9 | 2,024.1 | 0.9 | 0.6 |
| 02/07/2014 02:00 | 10.1 | 13.3 | 7.8 | 116.5 | 3,433,955.4 | 2,081.3 | 1.0 | 0.8 |
| 02/07/2014 03:00 | 10.2 | 13.3 | 7.9 | 120.2 | 3,469,486.8 | 2,077.5 | 1.0 | 0.8 |
| 02/07/2014 04:00 | 10.7 | 13.2 | 8.2 | 140.2 | 3,401,250.1 | 2,210.5 | 1.2 | 1.1 |
| 02/07/2014 05:00 | 10.7 | 13.1 | 8.1 | 139.7 | 3,411,867.0 | 2,217.4 | 1.2 | 1.1 |
| 02/07/2014 06:00 | 10.8 | 13.1 | 8.2 | 145.3 | 3,387,143.3 | 2,250.8 | 1.3 | 1.1 |
| 02/07/2014 07:00 | 10.8 | 13.1 | 8.2 | 147.4 | 3,409,114.3 | 2,265.4 | 1.3 | 1.1 |
| 02/07/2014 08:00 | 10.7 | 13.1 | 8.1 | 146.0 | 3,423,711.4 | 2,275.1 | 1.3 | 1.1 |
| 02/07/2014 09:00 | 10.4 | 13.2 | 8.0 | 130.6 | 3,422,301.7 | 2,174.2 | 1.1 | 0.9 |
| 02/07/2014 10:00 | 10.0 | 13.3 | 7.8 | 114.0 | 3,434,917.2 | 2,056.8 | 1.0 | 0.8 |
| 02/07/2014 11:00 | 10.0 | 13.3 | 7.8 | 117.8 | 3,434,917.2 | 2,056.8 | 1.0 | 0.8 |
| 02/07/2014 12:00 | 10.0 | 13.3 | 7.8 | 119.3 | 3,433,130.4 | 2,080.8 | 1.0 | 0.8 |
| 02/07/2014 13:00 | 10.0 | 13.3 | 7.8 | 114.0 | 3,399,512.5 | 2,035.6 | 1.0 | 0.8 |
| 02/07/2014 14:00 | 9.6 | 13.4 | 7.6 | 106.9 | 3,363,819.8 | 1,965.1 | 0.9 | 0.6 |
| 02/07/2014 15:00 | 9.4 | 13.6 | 7.6 | 103.1 | 3,345,308.1 | 1,881.0 | 0.9 | 0.6 |
| 02/07/2014 16:00 | 10.0 | 13.3 | 7.8 | 113.6 | 3,436,917.1 | 2,032.9 | 1.0 | 0.8 |
| 02/07/2014 17:00 | 9.9 | 13.3 | 7.7 | 113.6 | 3,402,184.6 | 2,037.2 | 1.0 | 0.8 |
| 02/07/2014 18:00 | 10.1 | 13.3 | 7.8 | 120.7 | 3,407,910.4 | 2,090.4 | 1.0 | 0.8 |
| 02/07/2014 19:00 | 10.6 | 13.1 | 8.0 | 139.3 | 3,391,455.6 | 2,228.9 | 1.2 | 1.1 |
| 02/07/2014 20:00 | 10.1 | 13.3 | 7.8 | 119.0 | 3,371,555.4 | 2,068.1 | 1.0 | 0.8 |
| 02/07/2014 21:00 | 10.0 | 13.3 | 7.8 | 121.1 | 3,403,432.1 | 2,062.8 | 1.0 | 0.8 |
| 02/07/2014 22:00 | 10.0 | 13.3 | 7.8 | 118.3 | 3,405,741.9 | 2,064.2 | 1.0 | 0.8 |
| 02/07/2014 23:00 | 10.1 | 13.3 | 7.8 | 117.7 | 3,415,146.4 | 2,069.9 | 1.0 | 0.8 |
| **Average/Sum#:** | 10.2 | 13.3 | 7.9 | 122.5 | 3,409,065.4 | 2,091.2 | 1.1 | 0.8 |
| **Minimum:** | 9.4 | 13.1 | 7.6 | 103.1 | 3,345,308.1 | 1,881.0 | 0.9 | 0.6 |
| **Maximum:** | 10.8 | 13.6 | 8.2 | 147.4 | 3,469,486.8 | 2,275.1 | 1.3 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/08/2014 00:00 | 9.8 | 13.4 | 7.7 | 107.5 | 3,405,186.4 | 1,964.4 | 0.9 | 0.6 |
| 02/08/2014 01:00 | 9.9 | 13.5 | 7.9 | 107.1 | 3,419,347.3 | 1,947.6 | 0.9 | 0.6 |
| 02/08/2014 02:00 | 9.8 | 13.5 | 7.8 | 106.4 | 3,435,453.3 | 1,906.6 | 0.9 | 0.6 |
| 02/08/2014 03:00 | 9.8 | 13.5 | 7.8 | 103.2 | 3,418,515.7 | 1,897.2 | 0.9 | 0.6 |
| 02/08/2014 04:00 | 9.8 | 13.5 | 7.8 | 105.1 | 3,725,421.2 | 1,904.3 | 0.8 | 0.6 |
| 02/08/2014 05:00 | 9.8 | 13.5 | 7.8 | 103.1 | 3,430,408.1 | 1,903.8 | 0.9 | 0.6 |
| 02/08/2014 06:00 | 9.7 | 13.5 | 7.7 | 103.0 | 3,445,289.2 | 1,886.9 | 0.9 | 0.6 |
| 02/08/2014 07:00 | 9.4 | 13.6 | 7.6 | 105.1 | 3,418,047.7 | 1,921.9 | 0.9 | 0.6 |
| 02/08/2014 08:00 | 9.5 | 13.6 | 7.7 | 103.4 | 3,331,969.6 | 1,873.5 | 0.9 | 0.6 |
| 02/08/2014 09:00 | 9.5 | 13.6 | 7.7 | 103.1 | 3,319,773.0 | 1,842.4 | 0.9 | 0.6 |
| 02/08/2014 10:00 | 9.5 | 13.6 | 7.7 | 102.9 | 3,275,031.1 | 1,865.4 | 0.9 | 0.6 |
| 02/08/2014 11:00 | 9.5 | 13.6 | 7.7 | 102.9 | 3,323,966.5 | 1,869.0 | 0.9 | 0.6 |
| 02/08/2014 12:00 | 9.3 | 13.6 | 7.5 | 102.5 | 3,330,369.0 | 1,872.6 | 0.9 | 0.6 |
| 02/08/2014 13:00 | 9.4 | 13.6 | 7.6 | 104.1 | 3,343,151.2 | 1,904.2 | 0.9 | 0.6 |
| 02/08/2014 14:00 | 9.3 | 13.6 | 7.5 | 102.1 | 3,313,651.3 | 1,863.2 | 0.9 | 0.6 |
| 02/08/2014 15:00 | 9.2 | 13.6 | 7.4 | 102.1 | 3,317,208.3 | 1,865.2 | 0.9 | 0.6 |
| 02/08/2014 16:00 | 9.2 | 13.6 | 7.4 | 102.0 | 3,318,986.7 | 1,866.2 | 0.9 | 0.6 |
| 02/08/2014 17:00 | 9.2 | 13.6 | 7.4 | 102.4 | 3,334,815.1 | 1,875.1 | 0.9 | 0.6 |
| 02/08/2014 18:00 | 9.7 | 13.4 | 7.6 | 113.6 | 3,380,424.1 | 1,974.8 | 1.0 | 0.8 |
| 02/08/2014 19:00 | 10.4 | 13.2 | 8.0 | 133.2 | 3,320,777.2 | 2,158.2 | 1.2 | 1.1 |
| 02/08/2014 20:00 | 10.1 | 13.3 | 7.8 | 120.0 | 3,370,740.3 | 2,067.6 | 1.0 | 0.8 |
| 02/08/2014 21:00 | 10.2 | 13.2 | 7.8 | 121.1 | 3,335,822.3 | 2,094.9 | 1.1 | 0.8 |
| 02/08/2014 22:00 | 9.4 | 13.5 | 7.5 | 114.6 | 3,344,689.0 | 1,929.5 | 1.0 | 0.8 |
| 02/08/2014 23:00 | 9.0 | 13.6 | 7.3 | 98.4 | 3,368,966.6 | 1,845.1 | 0.8 | 0.6 |
| **Average/Sum#:** | 9.6 | 13.5 | 7.7 | 107.0 | 3,376,167.1 | 1,920.8 | 0.9 | 0.7 |
| **Minimum:** | 9.0 | 13.2 | 7.3 | 98.4 | 3,275,031.1 | 1,842.4 | 0.8 | 0.6 |
| **Maximum:** | 10.4 | 13.6 | 8.0 | 133.2 | 3,725,421.2 | 2,158.2 | 1.2 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report
## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/09/2014 00:00 | 8.8 | 13.7 | 7.2 | 97.4 | 3,403,389.7 | 1,839.1 | 0.8 | 0.6 |
| 02/09/2014 01:00 | 9.8 | 13.4 | 7.7 | 106.7 | 3,364,103.7 | 1,940.7 | 0.9 | 0.6 |
| 02/09/2014 02:00 | 8.9 | 13.6 | 7.2 | 98.9 | 3,384,304.1 | 1,853.5 | 0.8 | 0.6 |
| 02/09/2014 03:00 | 8.8 | 13.7 | 7.2 | 97.4 | 3,405,795.5 | 1,840.4 | 0.8 | 0.6 |
| 02/09/2014 04:00 | 8.8 | 13.7 | 7.2 | 97.3 | 3,404,870.2 | 1,839.9 | 0.8 | 0.6 |
| 02/09/2014 05:00 | 8.7 | 13.7 | 7.1 | 96.9 | 3,396,912.7 | 1,835.6 | 0.8 | 0.6 |
| 02/09/2014 06:00 | 8.9 | 13.7 | 7.3 | 97.8 | 3,376,270.2 | 1,849.1 | 0.8 | 0.6 |
| 02/09/2014 07:00 | 9.2 | 13.6 | 7.4 | 102.0 | 3,310,094.4 | 1,861.2 | 0.9 | 0.6 |
| 02/09/2014 08:00 | 9.3 | 13.6 | 7.5 | 102.1 | 3,305,470.3 | 1,858.6 | 0.9 | 0.6 |
| 02/09/2014 09:00 | 9.3 | 13.6 | 7.5 | 102.1 | 3,312,406.4 | 1,862.5 | 0.9 | 0.6 |
| 02/09/2014 10:00 | 9.2 | 13.6 | 7.4 | 102.0 | 3,312,228.5 | 1,862.4 | 0.9 | 0.6 |
| 02/09/2014 11:00 | 9.1 | 13.6 | 7.4 | 101.5 | 3,297,111.5 | 1,853.9 | 0.9 | 0.6 |
| 02/09/2014 12:00 | 9.1 | 13.6 | 7.4 | 101.0 | 3,296,044.4 | 1,853.3 | 0.9 | 0.6 |
| 02/09/2014 13:00 | 8.9 | 13.6 | 7.2 | 98.5 | 3,296,400.1 | 1,853.5 | 0.9 | 0.6 |
| 02/09/2014 14:00 | 8.9 | 13.6 | 7.2 | 100.6 | 3,301,735.5 | 1,856.5 | 0.9 | 0.6 |
| 02/09/2014 15:00 | 8.8 | 13.7 | 7.2 | 100.5 | 3,303,336.2 | 1,857.4 | 0.9 | 0.6 |
| 02/09/2014 16:00 | 9.1 | 13.6 | 7.4 | 102.3 | 3,352,066.3 | 1,884.8 | 0.9 | 0.6 |
| 02/09/2014 17:00 | 9.1 | 13.5 | 7.3 | 103.1 | 3,316,640.5 | 1,889.1 | 0.9 | 0.6 |
| 02/09/2014 18:00 | 9.6 | 13.4 | 7.6 | 110.4 | 3,343,931.5 | 1,977.9 | 1.0 | 0.8 |
| 02/09/2014 19:00 | 10.7 | 13.0 | 8.0 | 151.7 | 3,295,600.8 | 2,238.1 | 1.4 | 1.1 |
| 02/09/2014 20:00 | 10.8 | 13.0 | 8.1 | 151.3 | 3,315,037.8 | 2,251.3 | 1.4 | 1.1 |
| 02/09/2014 21:00 | 10.8 | 13.0 | 8.1 | 151.5 | 3,319,455.3 | 2,254.3 | 1.4 | 1.1 |
| 02/09/2014 22:00 | 10.4 | 13.1 | 7.9 | 130.1 | 3,306,467.5 | 2,148.9 | 1.2 | 1.1 |
| 02/09/2014 23:00 | 10.2 | 13.2 | 7.8 | 123.3 | 3,321,331.8 | 2,085.8 | 1.1 | 0.8 |
| **Average/Sum#:** | 9.4 | 13.5 | 7.5 | 109.4 | 3,335,041.9 | 1,935.3 | 1.0 | 0.7 |
| **Minimum:** | 8.7 | 13.0 | 7.1 | 96.9 | 3,295,600.8 | 1,835.6 | 0.8 | 0.6 |
| **Maximum:** | 10.8 | 13.7 | 8.1 | 151.7 | 3,405,795.5 | 2,254.3 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/10/2014 00:00 | 9.1 | 13.8 | 7.6 | 88.3 | 2,829,192.7 | 1,487.5 | 0.9 | 0.4 |
| 02/10/2014 01:00 | 9.5 | 13.8 | 7.9 | 83.3 | 2,580,304.1 | 1,337.8 | 0.9 | 0.4 |
| 02/10/2014 02:00 | 9.8 | 13.8 | 8.1 | 87.0 | 2,640,867.4 | 1,369.2 | 0.9 | 0.4 |
| 02/10/2014 03:00 | 10.0 | 13.9 | 8.4 | 82.4 | 2,407,679.5 | 1,248.3 | 1.0 | 0.5 |
| 02/10/2014 04:00 | 10.1 | 13.9 | 8.5 | 80.2 | 2,407,872.4 | 1,248.4 | 0.9 | 0.4 |
| 02/10/2014 05:00 | 9.9 | 13.8 | 8.2 | 88.5 | 2,718,687.8 | 1,429.4 | 0.9 | 0.4 |
| 02/10/2014 06:00 | 9.4 | 13.7 | 7.7 | 101.5 | 3,402,659.2 | 1,888.4 | 0.9 | 0.6 |
| 02/10/2014 07:00 | 9.7 | 13.6 | 7.8 | 106.2 | 3,388,974.2 | 1,930.3 | 0.9 | 0.6 |
| 02/10/2014 08:00 | 10.0 | 13.4 | 7.9 | 111.8 | 3,434,345.2 | 2,006.3 | 0.9 | 0.6 |
| 02/10/2014 09:00 | 9.6 | 13.6 | 7.8 | 105.3 | 3,393,682.6 | 1,908.2 | 0.9 | 0.6 |
| 02/10/2014 10:00 | 9.6 | 13.6 | 7.8 | 105.5 | 3,342,097.8 | 1,903.6 | 0.9 | 0.6 |
| 02/10/2014 11:00 | 9.6 | 13.6 | 7.8 | 103.7 | 3,338,905.6 | 1,877.4 | 0.9 | 0.6 |
| 02/10/2014 12:00 | 9.5 | 13.6 | 7.7 | 103.3 | 3,335,526.5 | 1,875.5 | 0.9 | 0.6 |
| 02/10/2014 13:00 | 9.4 | 13.6 | 7.6 | 103.0 | 3,337,660.7 | 1,876.7 | 0.9 | 0.6 |
| 02/10/2014 14:00 | 9.2 | 13.6 | 7.4 | 102.7 | 3,324,144.3 | 1,869.1 | 0.9 | 0.6 |
| 02/10/2014 15:00 | 9.2 | 13.6 | 7.4 | 102.1 | 3,330,546.8 | 1,872.7 | 0.9 | 0.6 |
| 02/10/2014 16:00 | 9.2 | 13.7 | 7.5 | 101.9 | 3,332,147.4 | 1,873.6 | 0.9 | 0.6 |
| 02/10/2014 17:00 | 9.2 | 13.7 | 7.5 | 102.1 | 3,330,724.7 | 1,872.8 | 0.9 | 0.6 |
| 02/10/2014 18:00 | 9.5 | 13.6 | 7.7 | 104.7 | 3,364,745.9 | 1,916.5 | 0.9 | 0.6 |
| 02/10/2014 19:00 | 10.1 | 13.3 | 7.8 | 116.5 | 3,363,834.3 | 2,038.8 | 1.0 | 0.8 |
| 02/10/2014 20:00 | 10.2 | 13.3 | 7.9 | 115.9 | 3,384,293.1 | 2,051.2 | 1.0 | 0.8 |
| 02/10/2014 21:00 | 10.4 | 13.3 | 8.1 | 127.8 | 3,365,006.3 | 2,137.8 | 1.1 | 0.9 |
| 02/10/2014 22:00 | 10.0 | 13.4 | 7.9 | 113.5 | 3,396,679.7 | 2,009.1 | 1.0 | 0.8 |
| 02/10/2014 23:00 | 9.4 | 13.7 | 7.7 | 104.0 | 3,402,380.5 | 1,863.4 | 0.9 | 0.6 |
| **Average/Sum#:** | 9.7 | 13.6 | 7.8 | 101.7 | 3,173,039.9 | 1,787.2 | 0.9 | 0.6 |
| **Minimum:** | 9.1 | 13.3 | 7.4 | 80.2 | 2,407,679.5 | 1,248.3 | 0.9 | 0.4 |
| **Maximum:** | 10.4 | 13.9 | 8.5 | 127.8 | 3,434,345.2 | 2,137.8 | 1.1 | 0.9 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/11/2014 00:00 | 9.4 | 13.6 | 7.6 | 101.7 | 3,369,684.9 | 1,870.1 | 0.9 | 0.6 |
| 02/11/2014 01:00 | 9.4 | 13.6 | 7.6 | 101.9 | 3,302,624.8 | 1,857.0 | 0.9 | 0.6 |
| 02/11/2014 02:00 | 9.5 | 13.6 | 7.7 | 102.4 | 3,335,526.5 | 1,875.5 | 0.9 | 0.6 |
| 02/11/2014 03:00 | 9.5 | 13.7 | 7.8 | 95.7 | 2,926,916.4 | 1,603.0 | 0.9 | 0.5 |
| 02/11/2014 04:00 | 10.1 | 13.9 | 8.5 | 79.5 | 2,447,161.4 | 1,250.9 | 0.9 | 0.4 |
| 02/11/2014 05:00 | 9.7 | 13.8 | 8.1 | 92.5 | 2,918,995.6 | 1,513.4 | 0.9 | 0.5 |
| 02/11/2014 06:00 | 9.8 | 13.6 | 7.9 | 104.3 | 3,269,939.6 | 1,862.5 | 0.9 | 0.6 |
| 02/11/2014 07:00 | 10.0 | 13.6 | 8.1 | 110.6 | 3,294,870.2 | 1,876.7 | 1.0 | 0.8 |
| 02/11/2014 08:00 | 10.4 | 13.3 | 8.1 | 122.3 | 3,447,442.4 | 2,064.3 | 1.0 | 0.8 |
| 02/11/2014 09:00 | 10.2 | 13.3 | 7.9 | 115.2 | 3,429,140.1 | 2,028.3 | 1.0 | 0.8 |
| 02/11/2014 10:00 | 9.9 | 13.5 | 7.9 | 107.8 | 3,364,570.4 | 1,916.4 | 0.9 | 0.6 |
| 02/11/2014 11:00 | 9.8 | 13.7 | 8.0 | 104.2 | 3,336,593.6 | 1,876.1 | 0.9 | 0.6 |
| 02/11/2014 12:00 | 9.7 | 13.7 | 7.9 | 104.0 | 3,336,771.5 | 1,876.2 | 0.9 | 0.6 |
| 02/11/2014 13:00 | 9.6 | 13.7 | 7.9 | 103.9 | 3,379,054.7 | 1,875.3 | 0.9 | 0.6 |
| 02/11/2014 14:00 | 9.5 | 13.7 | 7.8 | 103.5 | 3,381,216.9 | 1,876.5 | 0.9 | 0.6 |
| 02/11/2014 15:00 | 9.5 | 13.7 | 7.8 | 103.3 | 3,383,018.8 | 1,877.5 | 0.9 | 0.6 |
| 02/11/2014 16:00 | 9.5 | 13.7 | 7.8 | 103.0 | 3,365,180.2 | 1,867.6 | 0.9 | 0.6 |
| 02/11/2014 17:00 | 9.5 | 13.7 | 7.8 | 105.1 | 3,379,054.7 | 1,875.3 | 0.9 | 0.6 |
| 02/11/2014 18:00 | 9.8 | 13.6 | 7.9 | 107.1 | 3,396,883.9 | 1,910.0 | 0.9 | 0.6 |
| 02/11/2014 19:00 | 10.4 | 13.4 | 8.2 | 118.5 | 3,364,329.2 | 2,039.1 | 1.0 | 0.8 |
| 02/11/2014 20:00 | 10.5 | 13.4 | 8.3 | 120.1 | 3,418,884.9 | 2,047.2 | 1.0 | 0.8 |
| 02/11/2014 21:00 | 10.7 | 13.3 | 8.3 | 130.4 | 3,387,255.3 | 2,127.2 | 1.1 | 0.9 |
| 02/11/2014 22:00 | 10.3 | 13.4 | 8.1 | 116.7 | 3,376,466.1 | 2,021.8 | 1.0 | 0.8 |
| 02/11/2014 23:00 | 9.7 | 13.5 | 7.7 | 106.6 | 3,386,811.8 | 1,953.8 | 0.9 | 0.6 |
| **Average/Sum#:** | 9.9 | 13.6 | 7.9 | 106.7 | 3,291,599.7 | 1,872.6 | 0.9 | 0.6 |
| **Minimum:** | 9.4 | 13.3 | 7.6 | 79.5 | 2,447,161.4 | 1,250.9 | 0.9 | 0.4 |
| **Maximum:** | 10.7 | 13.9 | 8.5 | 130.4 | 3,447,442.4 | 2,127.2 | 1.1 | 0.9 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/12/2014 00:00 | 9.5 | 13.6 | 7.7 | 103.7 | 3,367,183.4 | 1,893.3 | 0.9 | 0.6 |
| 02/12/2014 01:00 | 9.9 | 13.4 | 7.8 | 111.2 | 3,435,543.4 | 2,007.0 | 0.9 | 0.6 |
| 02/12/2014 02:00 | 9.9 | 13.4 | 7.8 | 111.7 | 3,440,336.4 | 2,009.8 | 0.9 | 0.6 |
| 02/12/2014 03:00 | 10.0 | 13.4 | 7.9 | 112.6 | 3,450,949.4 | 2,016.0 | 0.9 | 0.6 |
| 02/12/2014 04:00 | 10.0 | 13.4 | 7.9 | 114.9 | 3,427,280.4 | 2,027.2 | 1.0 | 0.8 |
| 02/12/2014 05:00 | 10.0 | 13.4 | 7.9 | 113.5 | 3,422,208.4 | 2,024.2 | 1.0 | 0.8 |
| 02/12/2014 06:00 | 9.6 | 13.5 | 7.7 | 119.2 | 3,400,794.3 | 1,986.7 | 1.0 | 0.8 |
| 02/12/2014 07:00 | 10.1 | 13.3 | 7.8 | 117.4 | 3,422,736.0 | 2,074.5 | 1.0 | 0.8 |
| 02/12/2014 08:00 | 10.1 | 13.3 | 7.8 | 119.1 | 3,440,428.3 | 2,060.1 | 1.0 | 0.8 |
| 02/12/2014 09:00 | 9.7 | 13.6 | 7.8 | 106.7 | 3,364,745.9 | 1,916.5 | 0.9 | 0.6 |
| 02/12/2014 10:00 | 9.8 | 13.6 | 7.9 | 103.9 | 3,281,000.4 | 1,868.8 | 0.9 | 0.6 |
| 02/12/2014 11:00 | 9.7 | 13.6 | 7.8 | 103.8 | 3,286,618.5 | 1,872.0 | 0.9 | 0.6 |
| 02/12/2014 12:00 | 9.7 | 13.6 | 7.8 | 103.7 | 3,333,392.4 | 1,874.3 | 0.9 | 0.6 |
| 02/12/2014 13:00 | 9.5 | 13.6 | 7.7 | 103.3 | 3,330,191.1 | 1,872.5 | 0.9 | 0.6 |
| 02/12/2014 14:00 | 9.3 | 13.6 | 7.5 | 102.7 | 3,327,345.6 | 1,870.9 | 0.9 | 0.6 |
| 02/12/2014 15:00 | 9.3 | 13.6 | 7.5 | 102.4 | 3,327,345.6 | 1,870.9 | 0.9 | 0.6 |
| 02/12/2014 16:00 | 9.1 | 13.7 | 7.5 | 101.7 | 3,326,278.5 | 1,870.3 | 0.9 | 0.6 |
| 02/12/2014 17:00 | 9.2 | 13.6 | 7.4 | 102.6 | 3,355,979.0 | 1,887.0 | 0.9 | 0.6 |
| 02/12/2014 18:00 | 10.3 | 13.3 | 8.0 | 119.9 | 3,371,718.5 | 2,068.2 | 1.0 | 0.8 |
| 02/12/2014 19:00 | 10.8 | 13.1 | 8.2 | 155.7 | 3,359,949.0 | 2,281.8 | 1.4 | 1.1 |
| 02/12/2014 20:00 | 10.8 | 13.1 | 8.2 | 160.6 | 3,356,400.9 | 2,303.9 | 1.4 | 1.2 |
| 02/12/2014 21:00 | 10.7 | 13.1 | 8.1 | 150.8 | 3,339,775.7 | 2,268.1 | 1.3 | 1.1 |
| 02/12/2014 22:00 | 10.4 | 13.2 | 8.0 | 132.7 | 3,386,368.6 | 2,176.1 | 1.2 | 1.1 |
| 02/12/2014 23:00 | 9.8 | 13.4 | 7.7 | 123.6 | 3,381,309.2 | 2,024.7 | 1.1 | 0.8 |
| **Average/Sum#:** | 9.9 | 13.4 | 7.8 | 116.6 | 3,372,328.3 | 2,005.2 | 1.0 | 0.7 |
| **Minimum:** | 9.1 | 13.1 | 7.4 | 101.7 | 3,281,000.4 | 1,868.8 | 0.9 | 0.6 |
| **Maximum:** | 10.8 | 13.7 | 8.2 | 160.6 | 3,450,949.4 | 2,303.9 | 1.4 | 1.2 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report
## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/13/2014 00:00 | 9.4 | 13.6 | 7.6 | 111.2 | 3,344,555.7 | 1,905.0 | 1.0 | 0.8 |
| 02/13/2014 01:00 | 9.4 | 13.6 | 7.6 | 109.2 | 3,330,191.1 | 1,872.5 | 0.9 | 0.6 |
| 02/13/2014 02:00 | 9.5 | 13.6 | 7.7 | 109.4 | 3,274,504.4 | 1,865.1 | 1.0 | 0.7 |
| 02/13/2014 03:00 | 9.5 | 13.6 | 7.7 | 110.2 | 3,274,855.5 | 1,865.3 | 1.0 | 0.7 |
| 02/13/2014 04:00 | 9.5 | 13.6 | 7.7 | 111.3 | 3,271,695.3 | 1,863.5 | 1.0 | 0.7 |
| 02/13/2014 05:00 | 9.4 | 13.6 | 7.6 | 104.5 | 3,303,999.7 | 1,881.9 | 0.9 | 0.6 |
| 02/13/2014 06:00 | 9.6 | 13.5 | 7.7 | 109.5 | 3,350,062.7 | 1,932.6 | 0.9 | 0.6 |
| 02/13/2014 07:00 | 10.3 | 13.2 | 7.9 | 135.6 | 3,405,194.6 | 2,113.6 | 1.2 | 1.1 |
| 02/13/2014 08:00 | 10.7 | 13.0 | 8.0 | 147.1 | 3,365,473.3 | 2,236.4 | 1.3 | 1.1 |
| 02/13/2014 09:00 | 10.4 | 13.2 | 8.0 | 130.5 | 3,379,172.7 | 2,146.8 | 1.1 | 0.9 |
| 02/13/2014 10:00 | 10.4 | 13.2 | 8.0 | 127.4 | 3,384,070.6 | 2,125.2 | 1.1 | 0.9 |
| 02/13/2014 11:00 | 10.4 | 13.2 | 8.0 | 127.1 | 3,383,115.2 | 2,124.6 | 1.1 | 0.8 |
| 02/13/2014 12:00 | 10.4 | 13.2 | 8.0 | 128.8 | 3,385,344.5 | 2,126.0 | 1.1 | 0.9 |
| 02/13/2014 13:00 | 10.4 | 13.2 | 8.0 | 129.1 | 3,344,071.4 | 2,124.5 | 1.1 | 0.8 |
| 02/13/2014 14:00 | 10.4 | 13.2 | 8.0 | 129.8 | 3,346,904.7 | 2,126.3 | 1.1 | 0.9 |
| 02/13/2014 15:00 | 10.4 | 13.2 | 8.0 | 130.4 | 3,346,432.5 | 2,126.0 | 1.1 | 0.9 |
| 02/13/2014 16:00 | 10.5 | 13.2 | 8.0 | 131.5 | 3,349,423.2 | 2,127.9 | 1.2 | 1.1 |
| 02/13/2014 17:00 | 10.5 | 13.2 | 8.0 | 132.9 | 3,334,859.6 | 2,143.0 | 1.2 | 1.1 |
| 02/13/2014 18:00 | 10.5 | 13.2 | 8.0 | 132.0 | 3,321,943.4 | 2,134.7 | 1.2 | 1.1 |
| 02/13/2014 19:00 | 10.7 | 13.1 | 8.1 | 149.8 | 3,342,599.4 | 2,221.2 | 1.3 | 1.1 |
| 02/13/2014 20:00 | 10.9 | 13.0 | 8.1 | 162.3 | 3,312,550.2 | 2,273.8 | 1.5 | 1.4 |
| 02/13/2014 21:00 | 10.9 | 13.0 | 8.1 | 161.7 | 3,318,814.6 | 2,278.1 | 1.5 | 1.4 |
| 02/13/2014 22:00 | 10.7 | 13.0 | 8.0 | 147.7 | 3,310,732.3 | 2,224.2 | 1.3 | 1.1 |
| 02/13/2014 23:00 | 10.6 | 13.1 | 8.0 | 140.0 | 3,328,766.4 | 2,187.7 | 1.2 | 1.1 |
| **Average/Sum#:** | 10.2 | 13.3 | 7.9 | 129.5 | 3,337,888.9 | 2,084.4 | 1.1 | 0.9 |
| **Minimum:** | 9.4 | 13.0 | 7.6 | 104.5 | 3,271,695.3 | 1,863.5 | 0.9 | 0.6 |
| **Maximum:** | 10.9 | 13.6 | 8.1 | 162.3 | 3,405,194.6 | 2,278.1 | 1.5 | 1.4 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/14/2014 00:00 | 10.0 | 13.3 | 7.8 | 121.9 | 3,329,331.5 | 2,042.2 | 1.1 | 0.8 |
| 02/14/2014 01:00 | 9.3 | 13.6 | 7.5 | 102.2 | 3,302,269.1 | 1,856.8 | 0.9 | 0.6 |
| 02/14/2014 02:00 | 9.3 | 13.6 | 7.5 | 103.3 | 3,342,818.3 | 1,879.6 | 0.9 | 0.6 |
| 02/14/2014 03:00 | 9.4 | 13.6 | 7.6 | 102.5 | 3,315,074.1 | 1,864.0 | 0.9 | 0.6 |
| 02/14/2014 04:00 | 9.4 | 13.6 | 7.6 | 102.2 | 3,307,426.7 | 1,859.7 | 0.9 | 0.6 |
| 02/14/2014 05:00 | 9.2 | 13.6 | 7.4 | 101.7 | 3,310,272.2 | 1,861.3 | 0.9 | 0.6 |
| 02/14/2014 06:00 | 9.3 | 13.6 | 7.5 | 105.8 | 3,336,949.3 | 1,876.3 | 0.9 | 0.6 |
| 02/14/2014 07:00 | 9.5 | 13.5 | 7.6 | 106.5 | 3,360,181.2 | 1,913.9 | 0.9 | 0.6 |
| 02/14/2014 08:00 | 10.0 | 13.4 | 7.9 | 116.8 | 3,382,309.2 | 2,000.6 | 1.0 | 0.8 |
| 02/14/2014 09:00 | 10.5 | 13.2 | 8.0 | 129.0 | 3,360,026.0 | 2,110.1 | 1.1 | 0.8 |
| 02/14/2014 10:00 | 10.7 | 13.1 | 8.1 | 136.1 | 3,326,923.2 | 2,137.9 | 1.2 | 1.1 |
| 02/14/2014 11:00 | 10.8 | 13.1 | 8.2 | 139.6 | 3,292,927.1 | 2,140.1 | 1.3 | 1.1 |
| 02/14/2014 12:00 | 11.0 | 13.1 | 8.3 | 141.2 | 3,296,312.2 | 2,142.3 | 1.3 | 1.1 |
| 02/14/2014 13:00 | 10.8 | 13.1 | 8.2 | 138.7 | 3,270,185.4 | 2,149.2 | 1.3 | 1.1 |
| 02/14/2014 14:00 | 10.8 | 13.1 | 8.2 | 140.6 | 3,271,554.9 | 2,150.1 | 1.3 | 1.1 |
| 02/14/2014 15:00 | 10.8 | 13.1 | 8.2 | 138.5 | 3,279,771.4 | 2,155.5 | 1.2 | 1.1 |
| 02/14/2014 16:00 | 10.7 | 13.1 | 8.1 | 137.3 | 3,272,001.1 | 2,126.5 | 1.2 | 1.1 |
| 02/14/2014 17:00 | 10.8 | 13.1 | 8.2 | 140.2 | 3,301,851.4 | 2,145.9 | 1.3 | 1.1 |
| 02/14/2014 18:00 | 10.7 | 13.1 | 8.1 | 135.5 | 3,310,314.2 | 2,151.4 | 1.2 | 1.1 |
| 02/14/2014 19:00 | 10.4 | 13.2 | 8.0 | 123.7 | 3,312,096.2 | 2,080.0 | 1.1 | 0.8 |
| 02/14/2014 20:00 | 10.3 | 13.3 | 8.0 | 121.0 | 3,318,518.1 | 2,059.8 | 1.1 | 0.8 |
| 02/14/2014 21:00 | 10.5 | 13.2 | 8.0 | 131.1 | 3,336,043.7 | 2,119.4 | 1.2 | 1.1 |
| 02/14/2014 22:00 | 10.5 | 13.2 | 8.0 | 131.5 | 3,324,900.2 | 2,136.6 | 1.2 | 1.1 |
| 02/14/2014 23:00 | 10.2 | 13.3 | 7.9 | 121.0 | 3,336,830.7 | 2,046.8 | 1.1 | 0.8 |
| **Average/Sum#:** | 10.2 | 13.3 | 7.9 | 123.7 | 3,316,537.0 | 2,041.9 | 1.1 | 0.9 |
| **Minimum:** | 9.2 | 13.1 | 7.4 | 101.7 | 3,270,185.4 | 1,856.8 | 0.9 | 0.6 |
| **Maximum:** | 11.0 | 13.6 | 8.3 | 141.2 | 3,382,309.2 | 2,155.5 | 1.3 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/15/2014 00:00 | 10.1 | 13.3 | 7.8 | 122.3 | 3,341,065.5 | 2,025.0 | 1.1 | 0.8 |
| 02/15/2014 01:00 | 10.3 | 13.2 | 7.9 | 125.6 | 3,370,717.3 | 2,092.2 | 1.1 | 0.8 |
| 02/15/2014 02:00 | 10.6 | 13.1 | 8.0 | 145.8 | 3,349,764.2 | 2,201.5 | 1.3 | 1.1 |
| 02/15/2014 03:00 | 10.7 | 13.1 | 8.1 | 148.3 | 3,341,094.5 | 2,220.2 | 1.3 | 1.1 |
| 02/15/2014 04:00 | 10.2 | 13.2 | 7.8 | 124.1 | 3,344,295.5 | 2,075.8 | 1.1 | 0.8 |
| 02/15/2014 05:00 | 10.1 | 13.3 | 7.8 | 115.5 | 3,387,989.3 | 2,028.7 | 1.0 | 0.8 |
| 02/15/2014 06:00 | 10.3 | 13.2 | 7.9 | 126.6 | 3,456,961.6 | 2,070.0 | 1.1 | 0.8 |
| 02/15/2014 07:00 | 9.9 | 13.3 | 7.7 | 116.6 | 3,388,733.6 | 2,004.4 | 1.0 | 0.8 |
| 02/15/2014 08:00 | 10.0 | 13.3 | 7.8 | 116.0 | 3,374,796.1 | 2,020.8 | 1.0 | 0.8 |
| 02/15/2014 09:00 | 10.2 | 13.3 | 7.9 | 120.4 | 3,396,337.5 | 2,058.5 | 1.0 | 0.8 |
| 02/15/2014 10:00 | 10.4 | 13.2 | 8.0 | 131.8 | 3,373,506.1 | 2,143.2 | 1.1 | 0.9 |
| 02/15/2014 11:00 | 10.8 | 13.0 | 8.1 | 152.2 | 3,336,632.3 | 2,241.6 | 1.4 | 1.1 |
| 02/15/2014 12:00 | 10.8 | 13.0 | 8.1 | 151.5 | 3,306,644.5 | 2,245.6 | 1.4 | 1.1 |
| 02/15/2014 13:00 | 10.7 | 13.1 | 8.1 | 143.4 | 3,298,356.4 | 2,191.8 | 1.3 | 1.1 |
| 02/15/2014 14:00 | 10.5 | 13.3 | 8.2 | 124.3 | 3,329,331.5 | 2,042.2 | 1.1 | 0.8 |
| 02/15/2014 15:00 | 10.5 | 13.3 | 8.2 | 121.1 | 3,324,731.4 | 2,015.1 | 1.1 | 0.8 |
| 02/15/2014 16:00 | 10.4 | 13.4 | 8.2 | 119.0 | 3,309,664.9 | 1,981.8 | 1.0 | 0.8 |
| 02/15/2014 17:00 | 10.5 | 13.3 | 8.2 | 124.7 | 3,313,182.1 | 2,008.1 | 1.1 | 0.8 |
| 02/15/2014 18:00 | 10.6 | 13.2 | 8.1 | 131.4 | 3,319,421.0 | 2,084.6 | 1.2 | 1.0 |
| 02/15/2014 19:00 | 11.0 | 13.1 | 8.3 | 153.4 | 3,308,946.1 | 2,223.0 | 1.4 | 1.1 |
| 02/15/2014 20:00 | 10.9 | 13.1 | 8.2 | 149.5 | 3,319,424.5 | 2,205.8 | 1.3 | 1.1 |
| 02/15/2014 21:00 | 10.8 | 13.1 | 8.2 | 147.3 | 3,338,536.3 | 2,218.5 | 1.3 | 1.1 |
| 02/15/2014 22:00 | 10.5 | 13.2 | 8.0 | 132.9 | 3,321,632.2 | 2,134.5 | 1.2 | 1.1 |
| 02/15/2014 23:00 | 9.6 | 13.5 | 7.7 | 108.8 | 3,365,837.1 | 1,941.7 | 0.9 | 0.6 |
| **Average/Sum#:** | 10.4 | 13.2 | 8.0 | 131.4 | 3,346,566.7 | 2,103.1 | 1.2 | 0.9 |
| **Minimum:** | 9.6 | 13.0 | 7.7 | 108.8 | 3,298,356.4 | 1,941.7 | 0.9 | 0.6 |
| **Maximum:** | 11.0 | 13.5 | 8.3 | 153.4 | 3,456,961.6 | 2,245.6 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/16/2014 00:00 | 9.3 | 13.7 | 7.6 | 102.9 | 3,393,289.5 | 1,883.2 | 0.9 | 0.6 |
| 02/16/2014 01:00 | 9.5 | 13.7 | 7.8 | 108.0 | 3,407,704.5 | 1,891.2 | 0.9 | 0.6 |
| 02/16/2014 02:00 | 9.9 | 13.6 | 8.0 | 110.9 | 3,407,910.4 | 1,916.2 | 0.9 | 0.6 |
| 02/16/2014 03:00 | 9.8 | 13.7 | 8.0 | 105.1 | 3,158,805.6 | 1,730.0 | 1.0 | 0.7 |
| 02/16/2014 04:00 | 10.6 | 13.9 | 8.9 | 84.7 | 2,499,395.1 | 1,277.6 | 1.0 | 0.5 |
| 02/16/2014 05:00 | 10.1 | 13.8 | 8.4 | 91.4 | 2,852,067.4 | 1,478.7 | 0.9 | 0.4 |
| 02/16/2014 06:00 | 10.0 | 13.8 | 8.3 | 105.4 | 3,026,975.7 | 1,657.8 | 1.0 | 0.7 |
| 02/16/2014 07:00 | 10.3 | 13.4 | 8.1 | 118.4 | 3,440,895.4 | 1,985.0 | 1.0 | 0.8 |
| 02/16/2014 08:00 | 10.0 | 13.6 | 8.1 | 113.9 | 3,461,539.7 | 1,895.8 | 0.9 | 0.6 |
| 02/16/2014 09:00 | 9.7 | 13.8 | 8.1 | 106.1 | 3,482,277.4 | 1,856.3 | 0.9 | 0.6 |
| 02/16/2014 10:00 | 9.7 | 13.8 | 8.1 | 109.1 | 3,473,835.7 | 1,851.8 | 0.9 | 0.6 |
| 02/16/2014 11:00 | 9.6 | 13.8 | 8.0 | 104.5 | 3,470,083.9 | 1,849.8 | 0.9 | 0.6 |
| 02/16/2014 12:00 | 9.4 | 13.7 | 7.7 | 101.2 | 3,466,707.2 | 1,848.0 | 0.8 | 0.6 |
| 02/16/2014 13:00 | 9.4 | 13.8 | 7.8 | 100.6 | 3,445,884.5 | 1,836.9 | 0.8 | 0.6 |
| 02/16/2014 14:00 | 9.4 | 13.7 | 7.7 | 101.9 | 3,405,425.3 | 1,840.2 | 0.9 | 0.6 |
| 02/16/2014 15:00 | 9.8 | 13.7 | 8.0 | 112.5 | 3,435,774.7 | 1,856.6 | 0.9 | 0.6 |
| 02/16/2014 16:00 | 9.5 | 13.7 | 7.8 | 102.3 | 3,407,275.9 | 1,841.2 | 0.9 | 0.6 |
| 02/16/2014 17:00 | 9.6 | 13.7 | 7.9 | 104.3 | 3,412,457.5 | 1,844.0 | 0.9 | 0.6 |
| 02/16/2014 18:00 | 10.3 | 13.5 | 8.2 | 123.8 | 3,375,717.8 | 1,947.4 | 1.1 | 0.8 |
| 02/16/2014 19:00 | 11.3 | 13.1 | 8.5 | 165.4 | 3,380,804.5 | 2,221.9 | 1.5 | 1.3 |
| 02/16/2014 20:00 | 11.5 | 13.1 | 8.7 | 171.2 | 3,353,898.9 | 2,253.2 | 1.5 | 1.4 |
| 02/16/2014 21:00 | 11.4 | 13.1 | 8.6 | 168.2 | 3,357,173.6 | 2,255.4 | 1.5 | 1.4 |
| 02/16/2014 22:00 | 11.4 | 13.1 | 8.6 | 168.2 | 3,357,322.5 | 2,255.5 | 1.5 | 1.4 |
| 02/16/2014 23:00 | 10.5 | 13.4 | 8.3 | 127.9 | 3,384,128.1 | 2,051.1 | 1.1 | 0.8 |
| **Average/Sum#:** | 10.1 | 13.6 | 8.1 | 117.0 | 3,327,389.6 | 1,888.5 | 1.0 | 0.8 |
| **Minimum:** | 9.3 | 13.1 | 7.6 | 84.7 | 2,499,395.1 | 1,277.6 | 0.8 | 0.4 |
| **Maximum:** | 11.5 | 13.9 | 8.9 | 171.2 | 3,482,277.4 | 2,255.5 | 1.5 | 1.4 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/17/2014 00:00 | 10.0 | 13.6 | 8.1 | 110.9 | 3,363,270.7 | 1,891.1 | 0.9 | 0.6 |
| 02/17/2014 01:00 | 10.1 | 13.6 | 8.2 | 111.9 | 3,339,617.0 | 1,877.8 | 1.0 | 0.8 |
| 02/17/2014 02:00 | 10.1 | 13.7 | 8.3 | 110.7 | 3,231,659.0 | 1,769.9 | 1.0 | 0.7 |
| 02/17/2014 03:00 | 10.6 | 13.9 | 8.9 | 83.8 | 2,543,412.3 | 1,300.1 | 0.9 | 0.4 |
| 02/17/2014 04:00 | 10.2 | 13.9 | 8.6 | 86.7 | 2,650,511.3 | 1,374.2 | 0.9 | 0.4 |
| 02/17/2014 05:00 | 10.1 | 13.9 | 8.5 | 100.4 | 3,043,447.9 | 1,555.7 | 0.9 | 0.5 |
| 02/17/2014 06:00 | 9.7 | 13.8 | 8.1 | 108.3 | 3,523,278.2 | 1,826.7 | 0.9 | 0.5 |
| 02/17/2014 07:00 | 9.7 | 13.8 | 8.1 | 109.2 | 3,533,500.7 | 1,832.0 | 0.9 | 0.5 |
| 02/17/2014 08:00 | 9.7 | 13.8 | 8.1 | 108.1 | 3,481,424.0 | 1,805.0 | 0.9 | 0.5 |
| 02/17/2014 09:00 | 9.7 | 13.9 | 8.2 | 106.5 | 3,459,166.0 | 1,768.2 | 0.9 | 0.5 |
| 02/17/2014 10:00 | 10.2 | 13.6 | 8.2 | 109.1 | 3,321,832.3 | 1,867.8 | 0.9 | 0.6 |
| 02/17/2014 11:00 | 10.1 | 13.6 | 8.2 | 114.5 | 3,318,453.2 | 1,865.9 | 1.0 | 0.7 |
| 02/17/2014 12:00 | 10.0 | 13.7 | 8.2 | 108.6 | 3,315,429.8 | 1,864.2 | 0.9 | 0.6 |
| 02/17/2014 13:00 | 9.9 | 13.7 | 8.1 | 111.7 | 3,353,107.7 | 1,860.9 | 1.0 | 0.7 |
| 02/17/2014 14:00 | 9.8 | 13.7 | 8.0 | 108.4 | 3,357,071.8 | 1,863.1 | 0.9 | 0.6 |
| 02/17/2014 15:00 | 9.8 | 13.7 | 8.0 | 108.3 | 3,368,243.4 | 1,869.3 | 0.9 | 0.6 |
| 02/17/2014 16:00 | 9.8 | 13.7 | 8.0 | 108.1 | 3,359,774.6 | 1,864.6 | 0.9 | 0.6 |
| 02/17/2014 17:00 | 9.7 | 13.7 | 7.9 | 108.0 | 3,357,612.4 | 1,863.4 | 0.9 | 0.6 |
| 02/17/2014 18:00 | 9.6 | 13.7 | 7.9 | 106.5 | 3,403,740.3 | 1,889.0 | 0.9 | 0.6 |
| 02/17/2014 19:00 | 9.9 | 13.6 | 8.0 | 119.6 | 3,427,473.6 | 1,927.2 | 1.0 | 0.8 |
| 02/17/2014 20:00 | 10.7 | 13.3 | 8.3 | 132.7 | 3,399,433.0 | 2,085.2 | 1.1 | 0.8 |
| 02/17/2014 21:00 | 11.1 | 13.2 | 8.5 | 159.7 | 3,362,849.8 | 2,210.1 | 1.4 | 1.1 |
| 02/17/2014 22:00 | 10.5 | 13.4 | 8.3 | 126.6 | 3,430,742.1 | 2,054.3 | 1.1 | 0.8 |
| 02/17/2014 23:00 | 10.1 | 13.6 | 8.2 | 115.7 | 3,372,295.3 | 1,920.8 | 1.0 | 0.8 |
| **Average/Sum#:** | 10.0 | 13.7 | 8.2 | 111.4 | 3,304,889.4 | 1,833.6 | 1.0 | 0.6 |
| **Minimum:** | 9.6 | 13.2 | 7.9 | 83.8 | 2,543,412.3 | 1,300.1 | 0.9 | 0.4 |
| **Maximum:** | 11.1 | 13.9 | 8.9 | 159.7 | 3,533,500.7 | 2,210.1 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/18/2014 00:00 | 10.1 | 13.7 | 8.3 | 113.0 | 3,330,546.8 | 1,872.7 | 1.0 | 0.7 |
| 02/18/2014 01:00 | 10.1 | 13.6 | 8.2 | 111.1 | 3,326,456.3 | 1,870.4 | 1.0 | 0.7 |
| 02/18/2014 02:00 | 10.2 | 13.6 | 8.2 | 118.2 | 3,319,698.1 | 1,866.6 | 1.0 | 0.7 |
| 02/18/2014 03:00 | 10.1 | 13.6 | 8.2 | 114.1 | 3,320,587.4 | 1,867.1 | 1.0 | 0.7 |
| 02/18/2014 04:00 | 10.1 | 13.6 | 8.2 | 110.7 | 3,318,986.7 | 1,866.2 | 1.0 | 0.7 |
| 02/18/2014 05:00 | 10.2 | 13.6 | 8.2 | 117.7 | 3,319,698.1 | 1,866.6 | 1.0 | 0.7 |
| 02/18/2014 06:00 | 10.2 | 13.6 | 8.2 | 123.6 | 3,340,868.8 | 1,902.9 | 1.1 | 0.8 |
| 02/18/2014 07:00 | 10.4 | 13.4 | 8.2 | 129.7 | 3,437,923.2 | 2,058.6 | 1.1 | 0.8 |
| 02/18/2014 08:00 | 10.7 | 13.3 | 8.3 | 142.9 | 3,392,191.6 | 2,130.3 | 1.2 | 1.1 |
| 02/18/2014 09:00 | 10.2 | 13.4 | 8.0 | 120.9 | 3,406,956.7 | 1,990.3 | 1.0 | 0.8 |
| 02/18/2014 10:00 | 10.3 | 13.4 | 8.1 | 122.4 | 3,404,046.7 | 1,988.6 | 1.0 | 0.8 |
| 02/18/2014 11:00 | 10.3 | 13.4 | 8.1 | 129.9 | 3,396,339.5 | 2,033.7 | 1.1 | 0.8 |
| 02/18/2014 12:00 | 10.7 | 13.3 | 8.3 | 135.0 | 3,342,039.9 | 2,074.4 | 1.2 | 1.0 |
| 02/18/2014 13:00 | 10.6 | 13.4 | 8.3 | 125.4 | 3,359,485.4 | 1,987.1 | 1.1 | 0.8 |
| 02/18/2014 14:00 | 9.8 | 13.7 | 8.0 | 111.7 | 3,311,872.8 | 1,862.2 | 1.0 | 0.7 |
| 02/18/2014 15:00 | 9.9 | 13.6 | 8.0 | 113.8 | 3,347,264.5 | 1,882.1 | 1.0 | 0.8 |
| 02/18/2014 16:00 | 9.7 | 13.7 | 7.9 | 105.7 | 3,310,403.3 | 1,837.2 | 0.9 | 0.6 |
| 02/18/2014 17:00 | 10.3 | 13.5 | 8.2 | 128.3 | 3,327,870.3 | 1,968.4 | 1.1 | 0.8 |
| 02/18/2014 18:00 | 11.1 | 13.2 | 8.5 | 161.6 | 3,329,983.6 | 2,188.5 | 1.4 | 1.1 |
| 02/18/2014 19:00 | 11.2 | 13.1 | 8.5 | 166.2 | 3,303,405.0 | 2,243.4 | 1.5 | 1.3 |
| 02/18/2014 20:00 | 10.6 | 13.3 | 8.2 | 129.5 | 3,383,456.4 | 2,075.4 | 1.1 | 0.8 |
| 02/18/2014 21:00 | 11.0 | 13.1 | 8.3 | 159.3 | 3,324,390.6 | 2,209.1 | 1.4 | 1.1 |
| 02/18/2014 22:00 | 9.8 | 13.5 | 7.8 | 108.3 | 3,368,432.8 | 1,918.6 | 0.9 | 0.6 |
| 02/18/2014 23:00 | 9.7 | 13.8 | 8.1 | 96.5 | 2,977,166.7 | 1,565.3 | 0.9 | 0.5 |
| **Average/Sum#:** | 10.3 | 13.5 | 8.2 | 124.8 | 3,333,336.3 | 1,963.6 | 1.1 | 0.8 |
| **Minimum:** | 9.7 | 13.1 | 7.8 | 96.5 | 2,977,166.7 | 1,565.3 | 0.9 | 0.5 |
| **Maximum:** | 11.2 | 13.8 | 8.5 | 166.2 | 3,437,923.2 | 2,243.4 | 1.5 | 1.3 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/19/2014 00:00 | 10.4 | 13.9 | 8.8 | 83.6 | 2,428,967.6 | 1,241.6 | 1.0 | 0.5 |
| 02/19/2014 01:00 | 10.1 | 13.9 | 8.5 | 86.3 | 2,742,957.0 | 1,402.1 | 0.9 | 0.4 |
| 02/19/2014 02:00 | 29.3 | 16.1 | 36.0 | 192.5 | 1,611,356.0 | 600.1 | 3.4 | 0.8 |
| 02/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 17:00 | 51.3 | 17.0 | 77.6 | 37.9 | 1,963,828.6 | 530.6 | 0.3 | 0.1 |
| 02/19/2014 18:00 | 31.5 | 14.1 | 27.3 | 175.9 | 2,974,873.1 | 1,477.2 | 1.6 | 0.9 |
| 02/19/2014 19:00 | 10.8 | 13.5 | 8.6 | 129.8 | 3,434,446.1 | 1,956.2 | 1.1 | 0.8 |
| 02/19/2014 20:00 | 11.7 | 13.2 | 9.0 | 180.6 | 3,386,130.0 | 2,225.4 | 1.6 | 1.3 |
| 02/19/2014 21:00 | 11.8 | 13.1 | 8.9 | 184.6 | 3,358,329.2 | 2,280.7 | 1.7 | 1.6 |
| 02/19/2014 22:00 | 11.4 | 13.2 | 8.7 | 161.1 | 3,392,748.9 | 2,180.2 | 1.4 | 1.1 |
| 02/19/2014 23:00 | 10.3 | 13.7 | 8.4 | 117.6 | 3,455,149.0 | 1,892.3 | 1.0 | 0.8 |
| **Average/Sum#:** | 18.9 | 14.2 | 20.2 | 135.0 | 2,874,878.6 | 1,578.6 | 1.4 | 0.8 |
| **Minimum:** | 10.1 | 13.1 | 8.4 | 37.9 | 1,611,356.0 | 530.6 | 0.3 | 0.1 |
| **Maximum:** | 51.3 | 17.0 | 77.6 | 192.5 | 3,455,149.0 | 2,280.7 | 3.4 | 1.6 |
| **%SI** | 58.3 | 58.3 | 58.3 | 58.3 | 58.3 | 58.3 | 58.3 | 58.3 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/20/2014 00:00 | 10.0 | 13.8 | 8.3 | 110.6 | 3,459,203.5 | 1,844.0 | 0.9 | 0.6 |
| 02/20/2014 01:00 | 10.6 | 13.9 | 8.9 | 85.3 | 2,482,179.5 | 1,268.8 | 1.0 | 0.5 |
| 02/20/2014 02:00 | 11.0 | 13.9 | 9.3 | 84.3 | 2,433,271.5 | 1,243.8 | 1.0 | 0.5 |
| 02/20/2014 03:00 | 11.0 | 13.9 | 9.3 | 84.2 | 2,431,706.4 | 1,243.0 | 1.0 | 0.5 |
| 02/20/2014 04:00 | 11.1 | 13.9 | 9.4 | 86.0 | 2,462,225.0 | 1,258.6 | 1.0 | 0.5 |
| 02/20/2014 05:00 | 10.8 | 13.9 | 9.1 | 86.9 | 2,564,345.0 | 1,310.8 | 1.0 | 0.5 |
| 02/20/2014 06:00 | 10.6 | 13.6 | 8.6 | 132.0 | 3,156,523.2 | 1,890.1 | 1.2 | 0.9 |
| 02/20/2014 07:00 | 10.9 | 13.3 | 8.5 | 140.1 | 3,437,750.2 | 2,083.6 | 1.2 | 1.0 |
| 02/20/2014 08:00 | 11.1 | 13.3 | 8.6 | 158.3 | 3,405,194.6 | 2,113.6 | 1.4 | 1.1 |
| 02/20/2014 09:00 | 10.4 | 13.6 | 8.4 | 116.7 | 3,337,708.6 | 1,901.1 | 1.0 | 0.8 |
| 02/20/2014 10:00 | 10.3 | 13.6 | 8.3 | 116.8 | 3,305,114.6 | 1,858.4 | 1.0 | 0.7 |
| 02/20/2014 11:00 | 10.1 | 13.7 | 8.3 | 113.3 | 3,300,490.6 | 1,855.8 | 1.0 | 0.7 |
| 02/20/2014 12:00 | 9.9 | 13.7 | 8.1 | 117.7 | 3,346,080.4 | 1,857.0 | 1.0 | 0.7 |
| 02/20/2014 13:00 | 10.8 | 13.5 | 8.6 | 130.9 | 3,361,423.3 | 1,963.7 | 1.1 | 0.8 |
| 02/20/2014 14:00 | 9.9 | 13.7 | 8.1 | 113.3 | 3,367,522.7 | 1,868.9 | 1.0 | 0.7 |
| 02/20/2014 15:00 | 10.6 | 13.5 | 8.5 | 138.9 | 3,349,783.2 | 1,956.9 | 1.2 | 1.0 |
| 02/20/2014 16:00 | 11.5 | 13.3 | 8.9 | 162.3 | 3,296,849.9 | 2,094.5 | 1.5 | 1.3 |
| 02/20/2014 17:00 | 12.0 | 13.1 | 9.1 | 187.6 | 3,267,416.8 | 2,195.1 | 1.7 | 1.5 |
| 02/20/2014 18:00 | 11.7 | 13.2 | 9.0 | 166.9 | 3,290,773.0 | 2,138.7 | 1.5 | 1.3 |
| 02/20/2014 19:00 | 11.8 | 13.1 | 8.9 | 185.3 | 3,313,706.0 | 2,202.0 | 1.7 | 1.5 |
| 02/20/2014 20:00 | 11.9 | 13.1 | 9.0 | 184.0 | 3,300,908.2 | 2,217.6 | 1.7 | 1.6 |
| 02/20/2014 21:00 | 11.7 | 13.1 | 8.9 | 184.9 | 3,323,939.1 | 2,208.8 | 1.7 | 1.5 |
| 02/20/2014 22:00 | 11.7 | 13.1 | 8.9 | 183.2 | 3,295,996.1 | 2,214.3 | 1.7 | 1.6 |
| 02/20/2014 23:00 | 11.6 | 13.2 | 8.9 | 172.8 | 3,338,164.3 | 2,169.5 | 1.5 | 1.3 |
| **Average/Sum#:** | 11.0 | 13.5 | 8.7 | 135.1 | 3,151,178.2 | 1,873.3 | 1.3 | 1.0 |
| **Minimum:** | 9.9 | 13.1 | 8.1 | 84.2 | 2,431,706.4 | 1,243.0 | 0.9 | 0.5 |
| **Maximum:** | 12.0 | 13.9 | 9.4 | 187.6 | 3,459,203.5 | 2,217.6 | 1.7 | 1.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/21/2014 00:00 | 11.1 | 13.3 | 8.6 | 143.5 | 3,352,481.3 | 2,056.4 | 1.3 | 1.0 |
| 02/21/2014 01:00 | 10.0 | 13.7 | 8.2 | 110.1 | 3,436,524.8 | 1,882.1 | 0.9 | 0.6 |
| 02/21/2014 02:00 | 10.0 | 13.8 | 8.3 | 114.1 | 3,451,699.8 | 1,840.0 | 0.9 | 0.6 |
| 02/21/2014 03:00 | 9.9 | 13.8 | 8.2 | 112.1 | 3,455,451.7 | 1,842.0 | 0.9 | 0.6 |
| 02/21/2014 04:00 | 9.8 | 13.8 | 8.1 | 109.8 | 3,454,326.1 | 1,841.4 | 0.9 | 0.6 |
| 02/21/2014 05:00 | 9.7 | 13.8 | 8.1 | 105.6 | 3,455,076.5 | 1,841.8 | 0.9 | 0.6 |
| 02/21/2014 06:00 | 10.0 | 13.7 | 8.2 | 118.4 | 3,442,066.7 | 1,860.0 | 1.0 | 0.7 |
| 02/21/2014 07:00 | 10.7 | 13.4 | 8.4 | 129.7 | 3,430,408.1 | 2,004.0 | 1.1 | 0.8 |
| 02/21/2014 08:00 | 11.3 | 13.2 | 8.7 | 166.9 | 3,340,626.2 | 2,171.1 | 1.5 | 1.3 |
| 02/21/2014 09:00 | 10.6 | 13.4 | 8.3 | 122.7 | 3,408,111.0 | 1,941.2 | 1.0 | 0.8 |
| 02/21/2014 10:00 | 9.5 | 13.7 | 7.8 | 102.3 | 3,414,493.1 | 1,845.1 | 0.9 | 0.6 |
| 02/21/2014 11:00 | 9.8 | 13.6 | 7.9 | 115.1 | 3,396,720.2 | 1,860.3 | 1.0 | 0.7 |
| 02/21/2014 12:00 | 10.3 | 13.6 | 8.3 | 112.2 | 3,375,722.4 | 1,848.8 | 1.0 | 0.7 |
| 02/21/2014 13:00 | 10.7 | 13.6 | 8.6 | 119.6 | 3,367,871.0 | 1,844.5 | 1.0 | 0.7 |
| 02/21/2014 14:00 | 10.8 | 13.6 | 8.7 | 117.8 | 3,359,837.1 | 1,840.1 | 1.0 | 0.7 |
| 02/21/2014 15:00 | 10.8 | 13.6 | 8.7 | 118.8 | 3,349,429.5 | 1,834.4 | 1.0 | 0.7 |
| 02/21/2014 16:00 | 10.8 | 13.6 | 8.7 | 119.7 | 3,341,395.5 | 1,830.0 | 1.0 | 0.7 |
| 02/21/2014 17:00 | 10.9 | 13.6 | 8.8 | 120.1 | 3,322,295.6 | 1,843.8 | 1.0 | 0.7 |
| 02/21/2014 18:00 | 11.1 | 13.4 | 8.7 | 141.5 | 3,295,033.1 | 1,997.1 | 1.3 | 1.0 |
| 02/21/2014 19:00 | 11.4 | 13.3 | 8.9 | 159.6 | 3,307,396.0 | 2,101.2 | 1.4 | 1.1 |
| 02/21/2014 20:00 | 11.5 | 13.2 | 8.8 | 165.1 | 3,307,782.4 | 2,125.6 | 1.5 | 1.3 |
| 02/21/2014 21:00 | 11.6 | 13.1 | 8.8 | 177.7 | 3,311,572.5 | 2,176.4 | 1.6 | 1.3 |
| 02/21/2014 22:00 | 11.5 | 13.2 | 8.8 | 162.2 | 3,293,621.3 | 2,116.5 | 1.5 | 1.3 |
| 02/21/2014 23:00 | 11.2 | 13.3 | 8.7 | 148.3 | 3,323,673.5 | 2,063.0 | 1.3 | 1.0 |
| **Average/Sum#:** | 10.6 | 13.5 | 8.5 | 129.7 | 3,374,734.0 | 1,942.0 | 1.1 | 0.8 |
| **Minimum:** | 9.5 | 13.1 | 7.8 | 102.3 | 3,293,621.3 | 1,830.0 | 0.9 | 0.6 |
| **Maximum:** | 11.6 | 13.8 | 8.9 | 177.7 | 3,455,451.7 | 2,176.4 | 1.6 | 1.3 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/22/2014 00:00 | 11.1 | 13.3 | 8.6 | 142.1 | 3,331,939.9 | 2,043.8 | 1.3 | 1.0 |
| 02/22/2014 01:00 | 10.8 | 13.4 | 8.5 | 133.8 | 3,339,391.5 | 1,999.6 | 1.2 | 1.0 |
| 02/22/2014 02:00 | 9.8 | 13.7 | 8.0 | 109.5 | 3,318,808.9 | 1,866.1 | 0.9 | 0.6 |
| 02/22/2014 03:00 | 10.7 | 13.5 | 8.5 | 131.4 | 3,348,327.2 | 1,980.5 | 1.1 | 0.8 |
| 02/22/2014 04:00 | 10.8 | 13.4 | 8.5 | 131.6 | 3,342,230.5 | 2,001.3 | 1.1 | 0.8 |
| 02/22/2014 05:00 | 10.3 | 13.6 | 8.3 | 122.1 | 3,395,996.9 | 1,934.3 | 1.0 | 0.8 |
| 02/22/2014 06:00 | 10.7 | 13.4 | 8.4 | 132.1 | 3,385,150.3 | 2,027.0 | 1.1 | 0.8 |
| 02/22/2014 07:00 | 10.6 | 13.4 | 8.3 | 130.9 | 3,396,840.5 | 2,034.0 | 1.1 | 0.8 |
| 02/22/2014 08:00 | 10.7 | 13.4 | 8.4 | 130.2 | 3,403,780.4 | 2,013.3 | 1.1 | 0.8 |
| 02/22/2014 09:00 | 10.0 | 13.7 | 8.2 | 113.2 | 3,374,830.8 | 1,897.6 | 1.0 | 0.8 |
| 02/22/2014 10:00 | 9.9 | 13.7 | 8.1 | 113.6 | 3,375,270.7 | 1,873.2 | 1.0 | 0.7 |
| 02/22/2014 11:00 | 9.8 | 13.7 | 8.0 | 112.2 | 3,373,108.5 | 1,872.0 | 1.0 | 0.7 |
| 02/22/2014 12:00 | 10.0 | 13.6 | 8.1 | 123.6 | 3,339,439.2 | 1,877.7 | 1.1 | 0.8 |
| 02/22/2014 13:00 | 9.8 | 13.7 | 8.0 | 109.9 | 3,319,520.3 | 1,866.5 | 1.0 | 0.7 |
| 02/22/2014 14:00 | 11.0 | 13.5 | 8.8 | 133.1 | 3,330,782.5 | 1,945.8 | 1.2 | 1.0 |
| 02/22/2014 15:00 | 11.4 | 13.4 | 9.0 | 142.5 | 3,268,799.5 | 1,981.2 | 1.3 | 1.0 |
| 02/22/2014 16:00 | 11.0 | 13.5 | 8.8 | 128.1 | 3,286,445.2 | 1,895.9 | 1.1 | 0.8 |
| 02/22/2014 17:00 | 11.2 | 13.4 | 8.8 | 153.0 | 3,251,078.7 | 1,994.2 | 1.4 | 1.0 |
| 02/22/2014 18:00 | 11.5 | 13.3 | 8.9 | 155.8 | 3,249,675.9 | 2,040.8 | 1.4 | 1.0 |
| 02/22/2014 19:00 | 11.5 | 13.3 | 8.9 | 156.6 | 3,248,054.3 | 2,063.5 | 1.4 | 1.0 |
| 02/22/2014 20:00 | 11.7 | 13.1 | 8.9 | 183.2 | 3,258,778.6 | 2,165.5 | 1.7 | 1.5 |
| 02/22/2014 21:00 | 11.8 | 13.1 | 8.9 | 187.2 | 3,251,638.7 | 2,184.5 | 1.7 | 1.5 |
| 02/22/2014 22:00 | 11.8 | 13.1 | 8.9 | 186.7 | 3,259,081.2 | 2,189.5 | 1.7 | 1.5 |
| 02/22/2014 23:00 | 11.8 | 13.1 | 8.9 | 187.4 | 3,274,710.5 | 2,200.0 | 1.7 | 1.5 |
| **Average/Sum#:** | 10.8 | 13.4 | 8.5 | 139.6 | 3,321,820.0 | 1,997.8 | 1.2 | 1.0 |
| **Minimum:** | 9.8 | 13.1 | 8.0 | 109.5 | 3,248,054.3 | 1,866.1 | 0.9 | 0.6 |
| **Maximum:** | 11.8 | 13.7 | 9.0 | 187.4 | 3,403,780.4 | 2,200.0 | 1.7 | 1.5 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/23/2014 00:00 | 11.3 | 13.2 | 8.7 | 167.0 | 3,366,168.2 | 2,187.7 | 1.5 | 1.3 |
| 02/23/2014 01:00 | 11.2 | 13.2 | 8.6 | 160.1 | 3,359,182.3 | 2,134.1 | 1.4 | 1.1 |
| 02/23/2014 02:00 | 11.5 | 13.1 | 8.7 | 179.9 | 3,347,634.0 | 2,200.1 | 1.6 | 1.3 |
| 02/23/2014 03:00 | 11.5 | 13.1 | 8.7 | 178.0 | 3,326,647.8 | 2,210.6 | 1.6 | 1.3 |
| 02/23/2014 04:00 | 11.1 | 13.3 | 8.6 | 149.2 | 3,363,370.0 | 2,112.2 | 1.3 | 1.1 |
| 02/23/2014 05:00 | 10.6 | 13.4 | 8.3 | 129.5 | 3,382,144.2 | 2,025.2 | 1.1 | 0.8 |
| 02/23/2014 06:00 | 10.6 | 13.4 | 8.3 | 138.8 | 3,363,174.3 | 2,038.4 | 1.2 | 1.0 |
| 02/23/2014 07:00 | 10.5 | 13.4 | 8.3 | 126.1 | 3,386,873.9 | 2,003.3 | 1.1 | 0.8 |
| 02/23/2014 08:00 | 10.5 | 13.4 | 8.3 | 124.5 | 3,402,163.7 | 1,987.5 | 1.1 | 0.8 |
| 02/23/2014 09:00 | 10.3 | 13.4 | 8.1 | 120.5 | 3,416,800.5 | 1,971.1 | 1.0 | 0.8 |
| 02/23/2014 10:00 | 9.9 | 13.7 | 8.1 | 117.4 | 3,380,104.6 | 1,851.2 | 1.0 | 0.7 |
| 02/23/2014 11:00 | 10.2 | 13.6 | 8.2 | 119.4 | 3,363,270.7 | 1,891.1 | 1.0 | 0.8 |
| 02/23/2014 12:00 | 10.6 | 13.5 | 8.5 | 128.8 | 3,361,410.2 | 1,914.6 | 1.1 | 0.8 |
| 02/23/2014 13:00 | 10.1 | 13.6 | 8.2 | 120.7 | 3,351,305.8 | 1,859.9 | 1.0 | 0.7 |
| 02/23/2014 14:00 | 10.0 | 13.6 | 8.1 | 118.0 | 3,340,854.9 | 1,854.1 | 1.0 | 0.7 |
| 02/23/2014 15:00 | 10.4 | 13.5 | 8.3 | 123.3 | 3,315,074.1 | 1,864.0 | 1.1 | 0.7 |
| 02/23/2014 16:00 | 10.7 | 13.5 | 8.5 | 124.3 | 3,268,937.3 | 1,885.8 | 1.1 | 0.8 |
| 02/23/2014 17:00 | 10.8 | 13.4 | 8.5 | 131.6 | 3,295,691.0 | 1,925.3 | 1.2 | 1.0 |
| 02/23/2014 18:00 | 11.4 | 13.2 | 8.7 | 159.6 | 3,270,405.8 | 2,077.7 | 1.5 | 1.2 |
| 02/23/2014 19:00 | 11.6 | 13.1 | 8.8 | 176.7 | 3,245,686.3 | 2,156.8 | 1.6 | 1.3 |
| 02/23/2014 20:00 | 11.5 | 13.2 | 8.8 | 172.3 | 3,268,055.2 | 2,147.8 | 1.6 | 1.3 |
| 02/23/2014 21:00 | 11.5 | 13.2 | 8.8 | 171.8 | 3,268,816.0 | 2,148.3 | 1.6 | 1.3 |
| 02/23/2014 22:00 | 11.4 | 13.2 | 8.7 | 171.9 | 3,269,881.1 | 2,149.0 | 1.6 | 1.3 |
| 02/23/2014 23:00 | 11.3 | 13.2 | 8.7 | 161.8 | 3,282,002.5 | 2,133.0 | 1.5 | 1.3 |
| **Average/Sum#:** | 10.9 | 13.4 | 8.5 | 144.6 | 3,333,152.3 | 2,030.4 | 1.3 | 1.0 |
| **Minimum:** | 9.9 | 13.1 | 8.1 | 117.4 | 3,245,686.3 | 1,851.2 | 1.0 | 0.7 |
| **Maximum:** | 11.6 | 13.7 | 8.8 | 179.9 | 3,416,800.5 | 2,210.6 | 1.6 | 1.3 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/24/2014 00:00 | 10.5 | 13.4 | 8.3 | 127.0 | 3,379,942.3 | 1,999.2 | 1.1 | 0.8 |
| 02/24/2014 01:00 | 9.8 | 13.7 | 8.0 | 110.0 | 3,381,017.5 | 1,851.7 | 0.9 | 0.6 |
| 02/24/2014 02:00 | 9.7 | 13.8 | 8.1 | 109.0 | 3,324,925.4 | 1,796.7 | 0.9 | 0.5 |
| 02/24/2014 03:00 | 10.6 | 13.9 | 8.9 | 83.3 | 2,454,399.8 | 1,254.6 | 1.0 | 0.5 |
| 02/24/2014 04:00 | 10.7 | 13.9 | 9.0 | 81.7 | 2,407,839.3 | 1,230.8 | 1.0 | 0.5 |
| 02/24/2014 05:00 | 10.3 | 13.8 | 8.6 | 100.8 | 2,865,286.0 | 1,527.4 | 1.0 | 0.6 |
| 02/24/2014 06:00 | 10.1 | 13.6 | 8.2 | 128.5 | 3,371,273.8 | 1,895.6 | 1.1 | 0.8 |
| 02/24/2014 07:00 | 10.3 | 13.4 | 8.1 | 121.4 | 3,385,078.4 | 1,952.8 | 1.0 | 0.8 |
| 02/24/2014 08:00 | 10.6 | 13.3 | 8.2 | 140.1 | 3,396,172.5 | 2,083.2 | 1.2 | 1.0 |
| 02/24/2014 09:00 | 10.0 | 13.5 | 8.0 | 116.3 | 3,408,286.6 | 1,941.3 | 1.0 | 0.8 |
| 02/24/2014 10:00 | 9.6 | 13.7 | 7.9 | 104.8 | 3,386,549.5 | 1,830.0 | 0.9 | 0.5 |
| 02/24/2014 11:00 | 10.2 | 13.6 | 8.2 | 118.6 | 3,389,051.5 | 1,856.1 | 1.0 | 0.7 |
| 02/24/2014 12:00 | 9.4 | 13.6 | 7.6 | 102.0 | 3,339,204.4 | 1,828.8 | 0.9 | 0.5 |
| 02/24/2014 13:00 | 10.6 | 13.6 | 8.6 | 121.7 | 3,343,221.4 | 1,831.0 | 1.0 | 0.7 |
| 02/24/2014 14:00 | 10.7 | 13.6 | 8.6 | 119.0 | 3,288,780.8 | 1,825.2 | 1.0 | 0.7 |
| 02/24/2014 15:00 | 11.1 | 13.4 | 8.7 | 140.2 | 3,254,445.3 | 1,972.5 | 1.3 | 1.0 |
| 02/24/2014 16:00 | 11.1 | 13.4 | 8.7 | 137.5 | 3,243,555.9 | 1,965.9 | 1.2 | 1.0 |
| 02/24/2014 17:00 | 11.4 | 13.3 | 8.9 | 154.4 | 3,247,605.8 | 2,039.5 | 1.4 | 1.0 |
| 02/24/2014 18:00 | 11.6 | 13.2 | 8.9 | 173.5 | 3,215,408.5 | 2,113.2 | 1.6 | 1.3 |
| 02/24/2014 19:00 | 11.8 | 13.1 | 8.9 | 189.1 | 3,236,158.2 | 2,174.1 | 1.8 | 1.5 |
| 02/24/2014 20:00 | 11.7 | 13.1 | 8.9 | 183.2 | 3,244,632.9 | 2,156.1 | 1.7 | 1.5 |
| 02/24/2014 21:00 | 11.6 | 13.2 | 8.9 | 174.1 | 3,260,447.3 | 2,142.8 | 1.6 | 1.3 |
| 02/24/2014 22:00 | 11.5 | 13.2 | 8.8 | 174.6 | 3,299,081.8 | 2,144.1 | 1.6 | 1.3 |
| 02/24/2014 23:00 | 11.4 | 13.2 | 8.7 | 174.0 | 3,277,032.6 | 2,153.7 | 1.6 | 1.3 |
| **Average/Sum#:** | 10.7 | 13.5 | 8.5 | 132.7 | 3,224,974.9 | 1,898.6 | 1.2 | 0.9 |
| **Minimum:** | 9.4 | 13.1 | 7.6 | 81.7 | 2,407,839.3 | 1,230.8 | 0.9 | 0.5 |
| **Maximum:** | 11.8 | 13.9 | 9.0 | 189.1 | 3,408,286.6 | 2,174.1 | 1.8 | 1.5 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/25/2014 00:00 | 10.7 | 13.3 | 8.3 | 133.8 | 3,365,484.2 | 2,039.8 | 1.2 | 1.0 |
| 02/25/2014 01:00 | 10.5 | 13.4 | 8.3 | 124.4 | 3,374,090.5 | 1,971.1 | 1.1 | 0.8 |
| 02/25/2014 02:00 | 9.8 | 13.7 | 8.0 | 111.7 | 3,336,530.4 | 1,851.7 | 1.0 | 0.7 |
| 02/25/2014 03:00 | 9.8 | 13.7 | 8.0 | 109.5 | 3,322,295.6 | 1,843.8 | 0.9 | 0.6 |
| 02/25/2014 04:00 | 9.9 | 13.7 | 8.1 | 111.3 | 3,326,980.5 | 1,846.4 | 1.0 | 0.7 |
| 02/25/2014 05:00 | 10.5 | 13.4 | 8.3 | 132.0 | 3,375,039.4 | 1,996.3 | 1.1 | 0.8 |
| 02/25/2014 06:00 | 10.8 | 13.4 | 8.5 | 135.3 | 3,377,468.1 | 2,022.4 | 1.2 | 1.0 |
| 02/25/2014 07:00 | 10.3 | 13.5 | 8.2 | 125.1 | 3,385,945.1 | 1,953.3 | 1.1 | 0.8 |
| 02/25/2014 08:00 | 10.5 | 13.4 | 8.3 | 128.7 | 3,347,908.6 | 2,004.7 | 1.1 | 0.8 |
| 02/25/2014 09:00 | 9.9 | 13.7 | 8.1 | 112.2 | 3,330,223.9 | 1,848.2 | 1.0 | 0.7 |
| 02/25/2014 10:00 | 9.7 | 13.7 | 7.9 | 107.3 | 3,351,985.7 | 1,835.8 | 0.9 | 0.6 |
| 02/25/2014 11:00 | 9.3 | 13.7 | 7.6 | 99.4 | 3,331,900.8 | 1,824.8 | 0.9 | 0.5 |
| 02/25/2014 12:00 | 10.3 | 13.6 | 8.3 | 117.4 | 3,337,926.3 | 1,828.1 | 1.0 | 0.7 |
| 02/25/2014 13:00 | 10.1 | 13.6 | 8.2 | 112.7 | 3,362,028.2 | 1,841.3 | 1.0 | 0.7 |
| 02/25/2014 14:00 | 9.2 | 13.6 | 7.4 | 99.8 | 3,332,996.4 | 1,825.4 | 0.9 | 0.5 |
| 02/25/2014 15:00 | 9.1 | 13.6 | 7.4 | 98.5 | 3,338,656.6 | 1,828.5 | 0.8 | 0.5 |
| 02/25/2014 16:00 | 9.4 | 13.6 | 7.6 | 115.0 | 3,331,258.2 | 1,873.1 | 1.0 | 0.7 |
| 02/25/2014 17:00 | 9.2 | 13.6 | 7.4 | 106.8 | 3,343,197.4 | 1,855.4 | 0.9 | 0.6 |
| 02/25/2014 18:00 | 9.9 | 13.4 | 7.8 | 121.3 | 3,313,330.8 | 1,959.8 | 1.1 | 0.8 |
| 02/25/2014 19:00 | 10.7 | 13.2 | 8.2 | 144.3 | 3,305,507.1 | 2,100.0 | 1.3 | 1.1 |
| 02/25/2014 20:00 | 10.8 | 13.1 | 8.2 | 149.7 | 3,277,232.6 | 2,129.9 | 1.4 | 1.1 |
| 02/25/2014 21:00 | 10.5 | 13.3 | 8.2 | 134.7 | 3,308,690.4 | 2,053.7 | 1.2 | 1.0 |
| 02/25/2014 22:00 | 10.0 | 13.4 | 7.9 | 117.9 | 3,337,800.8 | 1,949.9 | 1.0 | 0.8 |
| 02/25/2014 23:00 | 10.7 | 13.2 | 8.2 | 147.1 | 3,295,799.9 | 2,117.9 | 1.3 | 1.1 |
| **Average/Sum#:** | 10.1 | 13.5 | 8.0 | 120.7 | 3,337,928.2 | 1,933.4 | 1.1 | 0.8 |
| **Minimum:** | 9.1 | 13.1 | 7.4 | 98.5 | 3,277,232.6 | 1,824.8 | 0.8 | 0.5 |
| **Maximum:** | 10.8 | 13.7 | 8.5 | 149.7 | 3,385,945.1 | 2,129.9 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/26/2014 00:00 | 10.0 | 13.5 | 8.0 | 115.3 | 3,323,935.3 | 1,941.8 | 1.0 | 0.8 |
| 02/26/2014 01:00 | 9.9 | 13.6 | 8.0 | 114.6 | 3,346,197.4 | 1,881.5 | 1.0 | 0.8 |
| 02/26/2014 02:00 | 9.8 | 13.6 | 7.9 | 113.0 | 3,322,899.4 | 1,868.4 | 1.0 | 0.7 |
| 02/26/2014 03:00 | 9.7 | 13.6 | 7.8 | 110.9 | 3,318,097.5 | 1,865.7 | 1.0 | 0.7 |
| 02/26/2014 04:00 | 9.8 | 13.6 | 7.9 | 110.7 | 3,309,738.7 | 1,861.0 | 1.0 | 0.7 |
| 02/26/2014 05:00 | 9.8 | 13.5 | 7.8 | 114.9 | 3,336,655.2 | 1,900.5 | 1.0 | 0.8 |
| 02/26/2014 06:00 | 10.5 | 13.3 | 8.2 | 144.1 | 3,267,257.7 | 2,075.7 | 1.3 | 1.0 |
| 02/26/2014 07:00 | 10.6 | 13.2 | 8.1 | 151.0 | 3,355,401.0 | 2,156.2 | 1.3 | 1.1 |
| 02/26/2014 08:00 | 10.9 | 13.0 | 8.1 | 166.4 | 3,314,155.9 | 2,226.5 | 1.5 | 1.3 |
| 02/26/2014 09:00 | 10.9 | 13.0 | 8.1 | 164.0 | 3,323,533.4 | 2,232.8 | 1.5 | 1.3 |
| 02/26/2014 10:00 | 10.8 | 13.0 | 8.1 | 143.4 | 1,466,660.1 | 2,238.4 | 3.0 | 2.7 |
| 02/26/2014 11:00 | 10.6 | 13.1 | 8.0 | 153.1 | 1,429,901.8 | 2,182.3 | 3.4 | 2.8 |
| 02/26/2014 12:00 | 10.1 | 13.2 | 7.7 | 153.3 | 1,335,745.7 | 2,038.6 | 3.6 | 2.9 |
| 02/26/2014 13:00 | 10.4 | 13.1 | 7.9 | 153.2 | 1,423,742.7 | 2,172.9 | 3.4 | 2.8 |
| 02/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 154.6 | 3,310,386.7 | 2,103.1 | 1.5 | 1.3 |
| 02/26/2014 15:00 | 10.2 | 13.3 | 7.9 | 141.1 | 3,321,172.6 | 2,085.7 | 1.3 | 1.0 |
| 02/26/2014 16:00 | 10.1 | 13.3 | 7.8 | 121.2 | 3,343,045.4 | 2,026.2 | 1.1 | 0.8 |
| 02/26/2014 17:00 | 10.4 | 13.2 | 8.0 | 142.7 | 3,353,043.5 | 2,130.2 | 1.3 | 1.1 |
| 02/26/2014 18:00 | 10.5 | 13.1 | 7.9 | 144.5 | 3,321,546.5 | 2,158.7 | 1.3 | 1.1 |
| 02/26/2014 19:00 | 10.8 | 13.0 | 8.1 | 159.5 | 3,314,602.4 | 2,226.8 | 1.4 | 1.1 |
| 02/26/2014 20:00 | 10.7 | 13.0 | 8.0 | 160.1 | 3,295,400.7 | 2,213.9 | 1.5 | 1.3 |
| 02/26/2014 21:00 | 10.6 | 13.1 | 8.0 | 152.3 | 3,307,084.6 | 2,197.6 | 1.4 | 1.1 |
| 02/26/2014 22:00 | 10.5 | 13.1 | 7.9 | 149.6 | 3,278,341.8 | 2,178.5 | 1.4 | 1.1 |
| 02/26/2014 23:00 | 10.4 | 13.2 | 8.0 | 141.2 | 3,285,233.7 | 2,135.1 | 1.3 | 1.1 |
| **Average/Sum#:** | 10.3 | 13.2 | 8.0 | 140.6 | 3,317,386.5 | 2,087.4 | 1.2 | 1.0 |
| **Minimum:** | 9.7 | 13.0 | 7.7 | 110.7 | 3,267,257.7 | 1,861.0 | 1.0 | 0.7 |
| **Maximum:** | 10.9 | 13.6 | 8.2 | 166.4 | 3,355,401.0 | 2,238.4 | 1.5 | 1.3 |
| **%SI** | 4.2 | 4.2 | 4.2 | 0.0 | 16.7 | 0.0 | 20.8 | 20.8 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/27/2014 00:00 | 10.0 | 13.3 | 7.8 | 117.4 | 3,342,564.5 | 2,001.5 | 1.0 | 0.8 |
| 02/27/2014 01:00 | 9.2 | 13.7 | 7.5 | 103.6 | 3,349,932.2 | 1,883.6 | 0.9 | 0.6 |
| 02/27/2014 02:00 | 9.7 | 13.8 | 8.1 | 96.9 | 2,940,698.2 | 1,567.6 | 0.9 | 0.5 |
| 02/27/2014 03:00 | 10.0 | 13.9 | 8.4 | 79.9 | 2,511,328.7 | 1,283.7 | 0.9 | 0.4 |
| 02/27/2014 04:00 | 9.5 | 13.8 | 7.9 | 94.7 | 3,022,570.4 | 1,567.1 | 0.9 | 0.5 |
| 02/27/2014 05:00 | 9.7 | 13.6 | 7.8 | 102.2 | 3,148,215.4 | 1,724.2 | 0.9 | 0.5 |
| 02/27/2014 06:00 | 9.5 | 13.6 | 7.7 | 111.2 | 3,362,288.0 | 1,915.1 | 1.0 | 0.8 |
| 02/27/2014 07:00 | 9.5 | 13.6 | 7.7 | 110.4 | 3,402,298.8 | 1,888.2 | 0.9 | 0.6 |
| 02/27/2014 08:00 | 10.2 | 13.3 | 7.9 | 124.7 | 3,334,385.3 | 2,045.3 | 1.1 | 0.8 |
| 02/27/2014 09:00 | 9.1 | 13.6 | 7.4 | 100.3 | 3,399,093.9 | 1,861.6 | 0.8 | 0.6 |
| 02/27/2014 10:00 | 9.0 | 13.7 | 7.4 | 98.1 | 3,419,674.8 | 1,847.9 | 0.8 | 0.6 |
| 02/27/2014 11:00 | 8.8 | 13.7 | 7.2 | 97.7 | 3,413,938.0 | 1,844.8 | 0.8 | 0.6 |
| 02/27/2014 12:00 | 9.0 | 13.7 | 7.4 | 98.2 | 3,415,603.5 | 1,845.7 | 0.8 | 0.6 |
| 02/27/2014 13:00 | 9.0 | 13.7 | 7.4 | 98.6 | 3,374,809.5 | 1,848.3 | 0.8 | 0.6 |
| 02/27/2014 14:00 | 9.1 | 13.6 | 7.4 | 102.8 | 3,368,601.4 | 1,844.9 | 0.9 | 0.6 |
| 02/27/2014 15:00 | 9.7 | 13.6 | 7.8 | 110.6 | 3,372,070.6 | 1,846.8 | 0.9 | 0.6 |
| 02/27/2014 16:00 | 9.2 | 13.6 | 7.4 | 99.4 | 3,373,713.9 | 1,847.7 | 0.8 | 0.6 |
| 02/27/2014 17:00 | 9.4 | 13.5 | 7.5 | 107.3 | 3,394,216.2 | 1,908.5 | 0.9 | 0.6 |
| 02/27/2014 18:00 | 9.5 | 13.6 | 7.7 | 111.7 | 3,358,250.0 | 1,912.8 | 1.0 | 0.8 |
| 02/27/2014 19:00 | 10.4 | 13.4 | 8.2 | 131.7 | 3,354,606.4 | 2,082.2 | 1.1 | 0.8 |
| 02/27/2014 20:00 | 10.3 | 13.4 | 8.1 | 126.1 | 3,362,262.9 | 2,062.4 | 1.1 | 0.8 |
| 02/27/2014 21:00 | 10.2 | 13.3 | 7.9 | 123.9 | 3,374,979.0 | 2,070.2 | 1.1 | 0.8 |
| 02/27/2014 22:00 | 10.2 | 13.4 | 8.0 | 122.0 | 3,379,343.4 | 2,048.2 | 1.0 | 0.8 |
| 02/27/2014 23:00 | 10.2 | 13.4 | 8.0 | 126.2 | 3,338,978.9 | 2,072.5 | 1.1 | 0.8 |
| **Average/Sum#:** | 9.6 | 13.6 | 7.7 | 108.2 | 3,296,434.3 | 1,867.5 | 0.9 | 0.7 |
| **Minimum:** | 8.8 | 13.3 | 7.2 | 79.9 | 2,511,328.7 | 1,283.7 | 0.8 | 0.4 |
| **Maximum:** | 10.4 | 13.9 | 8.4 | 131.7 | 3,419,674.8 | 2,082.2 | 1.1 | 0.8 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/28/2014 00:00 | 9.6 | 13.6 | 7.8 | 109.6 | 3,384,760.6 | 1,927.9 | 0.9 | 0.6 |
| 02/28/2014 01:00 | 9.4 | 13.7 | 7.7 | 104.5 | 3,391,667.8 | 1,882.3 | 0.9 | 0.6 |
| 02/28/2014 02:00 | 9.7 | 13.6 | 7.8 | 112.5 | 3,372,424.2 | 1,945.5 | 1.0 | 0.8 |
| 02/28/2014 03:00 | 9.4 | 13.7 | 7.7 | 104.7 | 3,390,226.3 | 1,881.5 | 0.9 | 0.6 |
| 02/28/2014 04:00 | 9.4 | 13.8 | 7.8 | 105.2 | 3,394,550.8 | 1,883.9 | 0.9 | 0.6 |
| 02/28/2014 05:00 | 9.4 | 13.7 | 7.7 | 106.8 | 3,376,075.7 | 1,898.3 | 0.9 | 0.6 |
| 02/28/2014 06:00 | 9.2 | 13.7 | 7.5 | 104.6 | 3,410,947.8 | 1,893.0 | 0.9 | 0.6 |
| 02/28/2014 07:00 | 9.4 | 13.6 | 7.6 | 106.6 | 3,390,303.5 | 1,906.3 | 0.9 | 0.6 |
| 02/28/2014 08:00 | 9.9 | 13.4 | 7.8 | 117.8 | 3,378,518.4 | 2,047.7 | 1.0 | 0.8 |
| 02/28/2014 09:00 | 10.2 | 13.3 | 7.9 | 137.2 | 3,350,935.3 | 2,177.8 | 1.2 | 1.1 |
| 02/28/2014 10:00 | 10.3 | 13.2 | 7.9 | 144.7 | 3,344,254.7 | 2,222.3 | 1.3 | 1.1 |
| 02/28/2014 11:00 | 10.2 | 13.2 | 7.8 | 139.6 | 3,352,503.1 | 2,203.3 | 1.2 | 1.1 |
| 02/28/2014 12:00 | 10.2 | 13.2 | 7.8 | 131.8 | 3,336,010.1 | 2,168.1 | 1.2 | 1.1 |
| 02/28/2014 13:00 | 9.9 | 13.4 | 7.8 | 121.6 | 3,345,634.2 | 2,052.2 | 1.1 | 0.8 |
| 02/28/2014 14:00 | 9.1 | 13.6 | 7.4 | 103.7 | 3,336,655.2 | 1,900.5 | 0.9 | 0.6 |
| 02/28/2014 15:00 | 9.7 | 13.5 | 7.7 | 110.1 | 3,376,315.8 | 1,972.4 | 0.9 | 0.6 |
| 02/28/2014 16:00 | 10.1 | 13.3 | 7.8 | 133.9 | 3,340,150.6 | 2,146.4 | 1.2 | 1.1 |
| 02/28/2014 17:00 | 10.0 | 13.3 | 7.8 | 127.4 | 3,349,835.0 | 2,103.7 | 1.1 | 0.8 |
| 02/28/2014 18:00 | 9.8 | 13.5 | 7.8 | 113.3 | 3,387,784.7 | 1,979.1 | 1.0 | 0.8 |
| 02/28/2014 19:00 | 9.8 | 13.4 | 7.7 | 116.8 | 3,358,389.6 | 2,035.5 | 1.0 | 0.8 |
| 02/28/2014 20:00 | 9.3 | 13.7 | 7.6 | 103.8 | 3,338,372.1 | 1,877.1 | 0.9 | 0.6 |
| 02/28/2014 21:00 | 9.8 | 13.4 | 7.7 | 114.7 | 3,400,280.7 | 1,986.4 | 1.0 | 0.8 |
| 02/28/2014 22:00 | 9.8 | 13.4 | 7.7 | 116.6 | 3,384,315.3 | 2,026.5 | 1.0 | 0.8 |
| 02/28/2014 23:00 | 10.0 | 13.4 | 7.9 | 123.0 | 3,370,740.3 | 2,067.6 | 1.1 | 0.8 |
| **Average/Sum#:** | 9.7 | 13.5 | 7.7 | 117.1 | 3,369,235.5 | 2,007.7 | 1.0 | 0.8 |
| **Minimum:** | 9.1 | 13.2 | 7.4 | 103.7 | 3,336,010.1 | 1,877.1 | 0.9 | 0.6 |
| **Maximum:** | 10.3 | 13.8 | 7.9 | 144.7 | 3,410,947.8 | 2,222.3 | 1.3 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/01/2014 00:00 | 9.6 | 13.5 | 7.7 | 112.8 | 3,375,459.9 | 1,971.9 | 1.0 | 0.8 |
| 03/01/2014 01:00 | 9.4 | 13.6 | 7.6 | 110.7 | 3,367,005.5 | 1,893.2 | 1.0 | 0.8 |
| 03/01/2014 02:00 | 9.3 | 13.7 | 7.6 | 102.9 | 3,317,919.7 | 1,865.6 | 0.9 | 0.6 |
| 03/01/2014 03:00 | 9.3 | 13.7 | 7.6 | 104.3 | 3,324,144.3 | 1,869.1 | 0.9 | 0.6 |
| 03/01/2014 04:00 | 9.4 | 13.7 | 7.7 | 104.4 | 3,328,768.3 | 1,871.7 | 0.9 | 0.6 |
| 03/01/2014 05:00 | 9.3 | 13.7 | 7.6 | 103.6 | 3,350,643.6 | 1,884.0 | 0.9 | 0.6 |
| 03/01/2014 06:00 | 9.5 | 13.7 | 7.8 | 106.2 | 3,322,188.0 | 1,868.0 | 0.9 | 0.6 |
| 03/01/2014 07:00 | 9.5 | 13.7 | 7.8 | 106.5 | 3,322,188.0 | 1,868.0 | 0.9 | 0.6 |
| 03/01/2014 08:00 | 9.4 | 13.7 | 7.7 | 105.6 | 3,341,217.6 | 1,878.7 | 0.9 | 0.6 |
| 03/01/2014 09:00 | 9.4 | 13.7 | 7.7 | 104.9 | 3,331,613.9 | 1,873.3 | 0.9 | 0.6 |
| 03/01/2014 10:00 | 9.4 | 13.7 | 7.7 | 105.2 | 3,338,549.9 | 1,877.2 | 0.9 | 0.6 |
| 03/01/2014 11:00 | 9.3 | 13.7 | 7.6 | 104.9 | 3,374,009.4 | 1,872.5 | 0.9 | 0.6 |
| 03/01/2014 12:00 | 9.3 | 13.7 | 7.6 | 104.0 | 3,367,342.5 | 1,868.8 | 0.9 | 0.6 |
| 03/01/2014 13:00 | 9.4 | 13.6 | 7.6 | 111.5 | 3,367,005.5 | 1,893.2 | 1.0 | 0.8 |
| 03/01/2014 14:00 | 10.1 | 13.4 | 7.9 | 118.8 | 3,420,855.9 | 2,023.4 | 1.0 | 0.8 |
| 03/01/2014 15:00 | 10.1 | 13.4 | 7.9 | 124.8 | 3,391,496.4 | 2,030.8 | 1.1 | 0.8 |
| 03/01/2014 16:00 | 9.0 | 13.7 | 7.4 | 102.9 | 3,429,507.1 | 1,903.3 | 0.9 | 0.6 |
| 03/01/2014 17:00 | 9.2 | 13.7 | 7.5 | 103.2 | 3,366,801.9 | 1,868.5 | 0.9 | 0.6 |
| 03/01/2014 18:00 | 9.2 | 13.7 | 7.5 | 102.4 | 3,369,504.7 | 1,870.0 | 0.9 | 0.6 |
| 03/01/2014 19:00 | 9.8 | 13.5 | 7.8 | 119.1 | 3,386,244.1 | 1,978.2 | 1.0 | 0.8 |
| 03/01/2014 20:00 | 9.6 | 13.5 | 7.7 | 116.7 | 3,355,089.7 | 1,960.0 | 1.0 | 0.8 |
| 03/01/2014 21:00 | 10.1 | 13.4 | 7.9 | 119.7 | 3,368,951.0 | 2,017.3 | 1.0 | 0.8 |
| 03/01/2014 22:00 | 9.9 | 13.4 | 7.8 | 116.7 | 3,412,233.6 | 2,018.3 | 1.0 | 0.8 |
| 03/01/2014 23:00 | 10.0 | 13.4 | 7.9 | 122.6 | 3,383,798.2 | 2,050.9 | 1.1 | 0.8 |
| **Average/Sum#:** | 9.5 | 13.6 | 7.7 | 109.8 | 3,363,022.4 | 1,919.8 | 1.0 | 0.7 |
| **Minimum:** | 9.0 | 13.4 | 7.4 | 102.4 | 3,317,919.7 | 1,865.6 | 0.9 | 0.6 |
| **Maximum:** | 10.1 | 13.7 | 7.9 | 124.8 | 3,429,507.1 | 2,050.9 | 1.1 | 0.8 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/02/2014 00:00 | 9.5 | 13.5 | 7.6 | 120.3 | 3,405,477.5 | 1,939.7 | 1.0 | 0.8 |
| 03/02/2014 01:00 | 9.7 | 13.4 | 7.6 | 115.6 | 3,452,132.9 | 2,041.9 | 1.0 | 0.8 |
| 03/02/2014 02:00 | 9.7 | 13.4 | 7.6 | 112.0 | 3,462,418.4 | 2,022.7 | 0.9 | 0.6 |
| 03/02/2014 03:00 | 9.2 | 13.7 | 7.5 | 103.3 | 3,361,670.1 | 1,890.2 | 0.9 | 0.6 |
| 03/02/2014 04:00 | 9.4 | 13.7 | 7.7 | 104.6 | 3,319,164.6 | 1,866.3 | 0.9 | 0.6 |
| 03/02/2014 05:00 | 9.3 | 13.7 | 7.6 | 104.8 | 3,403,642.1 | 1,913.8 | 0.9 | 0.6 |
| 03/02/2014 06:00 | 9.4 | 13.6 | 7.6 | 125.1 | 3,395,834.3 | 2,008.6 | 1.1 | 0.8 |
| 03/02/2014 07:00 | 9.8 | 13.4 | 7.7 | 115.9 | 3,488,692.1 | 2,089.0 | 1.0 | 0.8 |
| 03/02/2014 08:00 | 9.8 | 13.4 | 7.7 | 116.9 | 3,477,168.9 | 2,082.1 | 1.0 | 0.8 |
| 03/02/2014 09:00 | 9.3 | 13.5 | 7.4 | 107.2 | 3,467,979.5 | 1,975.3 | 0.9 | 0.6 |
| 03/02/2014 10:00 | 9.7 | 13.4 | 7.6 | 120.1 | 3,448,611.4 | 2,065.0 | 1.0 | 0.8 |
| 03/02/2014 11:00 | 10.4 | 13.2 | 8.0 | 145.2 | 3,398,150.5 | 2,233.3 | 1.3 | 1.1 |
| 03/02/2014 12:00 | 10.3 | 13.2 | 7.9 | 141.4 | 3,398,942.1 | 2,209.0 | 1.2 | 1.1 |
| 03/02/2014 13:00 | 10.5 | 13.1 | 7.9 | 155.7 | 3,363,723.1 | 2,259.8 | 1.4 | 1.1 |
| 03/02/2014 14:00 | 10.5 | 13.1 | 7.9 | 154.2 | 3,350,326.5 | 2,250.8 | 1.4 | 1.1 |
| 03/02/2014 15:00 | 10.5 | 13.1 | 7.9 | 153.1 | 3,337,227.7 | 2,242.0 | 1.4 | 1.1 |
| 03/02/2014 16:00 | 10.5 | 13.1 | 7.9 | 151.3 | 3,333,059.9 | 2,239.2 | 1.4 | 1.1 |
| 03/02/2014 17:00 | 10.4 | 13.2 | 8.0 | 144.5 | 3,351,133.6 | 2,202.4 | 1.3 | 1.1 |
| 03/02/2014 18:00 | 10.2 | 13.3 | 7.9 | 131.9 | 3,345,960.2 | 2,125.7 | 1.2 | 1.1 |
| 03/02/2014 19:00 | 10.2 | 13.3 | 7.9 | 133.2 | 3,354,774.9 | 2,131.3 | 1.2 | 1.1 |
| 03/02/2014 20:00 | 10.0 | 13.3 | 7.8 | 122.7 | 3,368,294.9 | 2,066.1 | 1.1 | 0.8 |
| 03/02/2014 21:00 | 10.2 | 13.2 | 7.8 | 135.3 | 3,404,987.2 | 2,163.2 | 1.2 | 1.1 |
| 03/02/2014 22:00 | 9.8 | 13.3 | 7.6 | 129.0 | 3,467,148.7 | 2,076.1 | 1.1 | 0.8 |
| 03/02/2014 23:00 | 9.5 | 13.5 | 7.6 | 118.5 | 3,469,779.0 | 2,027.0 | 1.0 | 0.8 |
| **Average/Sum#:** | 9.9 | 13.4 | 7.7 | 127.6 | 3,401,095.8 | 2,088.4 | 1.1 | 0.9 |
| **Minimum:** | 9.2 | 13.1 | 7.4 | 103.3 | 3,319,164.6 | 1,866.3 | 0.9 | 0.6 |
| **Maximum:** | 10.5 | 13.7 | 8.0 | 155.7 | 3,488,692.1 | 2,259.8 | 1.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/03/2014 00:00 | 9.4 | 13.7 | 7.7 | 95.6 | 2,986,270.4 | 1,613.7 | 0.9 | 0.5 |
| 03/03/2014 01:00 | 9.5 | 13.8 | 7.9 | 85.7 | 2,770,480.5 | 1,436.4 | 0.9 | 0.4 |
| 03/03/2014 02:00 | 10.2 | 13.8 | 8.5 | 83.6 | 2,490,230.7 | 1,291.1 | 1.0 | 0.5 |
| 03/03/2014 03:00 | 10.2 | 13.8 | 8.5 | 83.5 | 2,485,408.8 | 1,288.6 | 1.0 | 0.5 |
| 03/03/2014 04:00 | 10.1 | 13.8 | 8.4 | 83.6 | 2,496,017.0 | 1,294.1 | 1.0 | 0.5 |
| 03/03/2014 05:00 | 9.7 | 13.7 | 7.9 | 94.0 | 2,954,255.5 | 1,596.4 | 0.9 | 0.5 |
| 03/03/2014 06:00 | 9.5 | 13.6 | 7.7 | 105.8 | 3,355,089.7 | 1,911.0 | 0.9 | 0.6 |
| 03/03/2014 07:00 | 9.7 | 13.4 | 7.6 | 120.7 | 3,433,535.8 | 2,030.9 | 1.0 | 0.8 |
| 03/03/2014 08:00 | 10.8 | 13.0 | 8.1 | 164.4 | 3,381,869.6 | 2,222.6 | 1.5 | 1.3 |
| 03/03/2014 09:00 | 10.7 | 13.1 | 8.1 | 155.6 | 3,334,009.8 | 2,166.8 | 1.4 | 1.1 |
| 03/03/2014 10:00 | 10.2 | 13.3 | 7.9 | 121.4 | 3,379,472.2 | 2,023.6 | 1.0 | 0.8 |
| 03/03/2014 11:00 | 9.8 | 13.5 | 7.8 | 118.0 | 3,377,971.3 | 1,948.7 | 1.0 | 0.8 |
| 03/03/2014 12:00 | 9.5 | 13.5 | 7.6 | 108.6 | 3,344,029.0 | 1,904.7 | 0.9 | 0.6 |
| 03/03/2014 13:00 | 9.4 | 13.6 | 7.6 | 106.3 | 3,347,264.5 | 1,882.1 | 0.9 | 0.6 |
| 03/03/2014 14:00 | 9.5 | 13.6 | 7.7 | 111.3 | 3,346,838.1 | 1,906.3 | 1.0 | 0.8 |
| 03/03/2014 15:00 | 9.4 | 13.5 | 7.5 | 109.1 | 3,419,874.0 | 1,947.9 | 0.9 | 0.6 |
| 03/03/2014 16:00 | 9.6 | 13.4 | 7.6 | 118.0 | 3,442,665.3 | 2,036.3 | 1.0 | 0.8 |
| 03/03/2014 17:00 | 10.7 | 13.0 | 8.0 | 157.8 | 3,374,109.5 | 2,217.5 | 1.4 | 1.1 |
| 03/03/2014 18:00 | 10.5 | 13.2 | 8.0 | 135.3 | 3,340,280.8 | 2,097.7 | 1.2 | 1.0 |
| 03/03/2014 19:00 | 10.8 | 13.0 | 8.1 | 161.1 | 3,356,307.0 | 2,205.8 | 1.4 | 1.1 |
| 03/03/2014 20:00 | 10.9 | 13.0 | 8.1 | 166.5 | 3,330,976.0 | 2,237.8 | 1.5 | 1.3 |
| 03/03/2014 21:00 | 10.9 | 13.0 | 8.1 | 162.6 | 3,338,235.3 | 2,218.3 | 1.5 | 1.3 |
| 03/03/2014 22:00 | 9.9 | 13.4 | 7.8 | 117.9 | 3,323,526.2 | 1,990.1 | 1.0 | 0.8 |
| 03/03/2014 23:00 | 9.6 | 13.6 | 7.8 | 106.3 | 3,276,260.1 | 1,866.1 | 0.9 | 0.6 |
| **Average/Sum#:** | 10.0 | 13.4 | 7.9 | 119.7 | 3,195,207.4 | 1,888.9 | 1.1 | 0.8 |
| **Minimum:** | 9.4 | 13.0 | 7.5 | 83.5 | 2,485,408.8 | 1,288.6 | 0.9 | 0.4 |
| **Maximum:** | 10.9 | 13.8 | 8.5 | 166.5 | 3,442,665.3 | 2,237.8 | 1.5 | 1.3 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/04/2014 00:00 | 9.7 | 13.7 | 7.9 | 97.9 | 2,883,094.8 | 1,579.0 | 1.0 | 0.6 |
| 03/04/2014 01:00 | 10.3 | 13.8 | 8.6 | 84.0 | 2,430,631.8 | 1,260.2 | 1.0 | 0.5 |
| 03/04/2014 02:00 | 10.4 | 13.8 | 8.6 | 84.0 | 2,449,148.0 | 1,269.8 | 1.0 | 0.5 |
| 03/04/2014 03:00 | 9.7 | 13.8 | 8.1 | 83.1 | 2,569,310.2 | 1,332.1 | 0.9 | 0.4 |
| 03/04/2014 04:00 | 10.3 | 13.8 | 8.6 | 83.8 | 2,468,628.5 | 1,279.9 | 1.0 | 0.5 |
| 03/04/2014 05:00 | 10.3 | 13.8 | 8.6 | 83.8 | 2,500,260.3 | 1,296.3 | 0.9 | 0.4 |
| 03/04/2014 06:00 | 9.8 | 13.7 | 8.0 | 103.2 | 2,906,648.9 | 1,591.9 | 1.0 | 0.6 |
| 03/04/2014 07:00 | 9.5 | 13.6 | 7.7 | 104.4 | 3,386,802.7 | 1,879.6 | 0.9 | 0.6 |
| 03/04/2014 08:00 | 9.6 | 13.7 | 7.9 | 107.2 | 3,367,342.5 | 1,868.8 | 0.9 | 0.6 |
| 03/04/2014 09:00 | 9.7 | 13.8 | 8.1 | 90.5 | 2,788,803.8 | 1,445.9 | 0.9 | 0.4 |
| 03/04/2014 10:00 | 10.0 | 13.9 | 8.4 | 76.6 | 2,418,990.4 | 1,236.5 | 0.9 | 0.4 |
| 03/04/2014 11:00 | 10.0 | 13.9 | 8.4 | 78.6 | 2,420,751.0 | 1,237.4 | 0.9 | 0.4 |
| 03/04/2014 12:00 | 10.5 | 13.8 | 8.7 | 81.7 | 2,445,869.1 | 1,268.1 | 0.9 | 0.4 |
| 03/04/2014 13:00 | 10.0 | 13.8 | 8.3 | 87.0 | 2,740,970.4 | 1,421.1 | 0.9 | 0.4 |
| 03/04/2014 14:00 | 9.5 | 13.7 | 7.8 | 105.1 | 3,345,720.0 | 1,856.8 | 0.9 | 0.6 |
| 03/04/2014 15:00 | 9.3 | 13.7 | 7.6 | 104.8 | 3,379,234.9 | 1,875.4 | 0.9 | 0.6 |
| 03/04/2014 16:00 | 9.2 | 13.7 | 7.5 | 103.8 | 3,381,937.7 | 1,876.9 | 0.9 | 0.6 |
| 03/04/2014 17:00 | 9.1 | 13.7 | 7.5 | 102.3 | 3,378,514.1 | 1,875.0 | 0.9 | 0.6 |
| 03/04/2014 18:00 | 9.3 | 13.6 | 7.5 | 110.7 | 3,397,417.4 | 1,910.3 | 0.9 | 0.6 |
| 03/04/2014 19:00 | 10.6 | 13.2 | 8.1 | 146.3 | 3,365,006.3 | 2,137.8 | 1.3 | 1.1 |
| 03/04/2014 20:00 | 10.6 | 13.2 | 8.1 | 143.2 | 3,323,923.5 | 2,111.7 | 1.3 | 1.1 |
| 03/04/2014 21:00 | 10.3 | 13.3 | 8.0 | 126.4 | 3,345,520.3 | 2,027.7 | 1.1 | 0.8 |
| 03/04/2014 22:00 | 9.9 | 13.4 | 7.8 | 117.5 | 3,353,206.8 | 1,958.9 | 1.0 | 0.8 |
| 03/04/2014 23:00 | 9.2 | 13.6 | 7.4 | 101.9 | 3,368,243.4 | 1,869.3 | 0.9 | 0.6 |
| **Average/Sum#:** | 9.9 | 13.7 | 8.1 | 100.3 | 2,975,665.7 | 1,644.4 | 1.0 | 0.6 |
| **Minimum:** | 9.1 | 13.2 | 7.4 | 76.6 | 2,418,990.4 | 1,236.5 | 0.9 | 0.4 |
| **Maximum:** | 10.6 | 13.9 | 8.7 | 146.3 | 3,397,417.4 | 2,137.8 | 1.3 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/05/2014 00:00 | 9.2 | 13.6 | 7.4 | 106.7 | 3,361,670.1 | 1,890.2 | 0.9 | 0.6 |
| 03/05/2014 01:00 | 10.1 | 13.3 | 7.8 | 121.0 | 3,359,264.8 | 2,011.5 | 1.1 | 0.8 |
| 03/05/2014 02:00 | 10.1 | 13.3 | 7.8 | 124.1 | 3,382,144.2 | 2,025.2 | 1.1 | 0.8 |
| 03/05/2014 03:00 | 9.3 | 13.5 | 7.4 | 112.8 | 3,341,219.9 | 1,903.1 | 1.0 | 0.8 |
| 03/05/2014 04:00 | 9.2 | 13.6 | 7.4 | 107.1 | 3,318,097.5 | 1,865.7 | 0.9 | 0.6 |
| 03/05/2014 05:00 | 9.7 | 13.4 | 7.6 | 119.9 | 3,392,406.6 | 1,981.8 | 1.0 | 0.8 |
| 03/05/2014 06:00 | 9.7 | 13.4 | 7.6 | 115.3 | 3,427,423.4 | 1,952.2 | 1.0 | 0.8 |
| 03/05/2014 07:00 | 9.5 | 13.4 | 7.5 | 112.3 | 3,374,261.7 | 1,971.2 | 1.0 | 0.8 |
| 03/05/2014 08:00 | 9.7 | 13.4 | 7.6 | 118.4 | 3,383,505.3 | 1,976.6 | 1.0 | 0.8 |
| 03/05/2014 09:00 | 9.3 | 13.6 | 7.5 | 103.8 | 3,318,220.6 | 1,890.0 | 0.9 | 0.6 |
| 03/05/2014 10:00 | 9.2 | 13.6 | 7.4 | 102.7 | 3,319,976.3 | 1,891.0 | 0.9 | 0.6 |
| 03/05/2014 11:00 | 9.1 | 13.6 | 7.4 | 102.4 | 3,363,982.1 | 1,891.5 | 0.9 | 0.6 |
| 03/05/2014 12:00 | 9.0 | 13.6 | 7.3 | 102.0 | 3,364,871.3 | 1,892.0 | 0.9 | 0.6 |
| 03/05/2014 13:00 | 9.0 | 13.6 | 7.3 | 101.7 | 3,365,760.6 | 1,892.5 | 0.9 | 0.6 |
| 03/05/2014 14:00 | 8.9 | 13.6 | 7.2 | 101.4 | 3,366,472.0 | 1,892.9 | 0.9 | 0.6 |
| 03/05/2014 15:00 | 8.7 | 13.6 | 7.0 | 100.9 | 3,325,945.6 | 1,894.4 | 0.9 | 0.6 |
| 03/05/2014 16:00 | 9.3 | 13.5 | 7.4 | 109.0 | 3,313,664.7 | 1,935.8 | 1.0 | 0.8 |
| 03/05/2014 17:00 | 9.8 | 13.4 | 7.7 | 116.8 | 3,336,154.5 | 1,973.3 | 1.0 | 0.8 |
| 03/05/2014 18:00 | 9.9 | 13.4 | 7.8 | 118.1 | 3,347,650.9 | 1,980.1 | 1.0 | 0.8 |
| 03/05/2014 19:00 | 10.4 | 13.2 | 8.0 | 135.1 | 3,344,617.7 | 2,076.0 | 1.2 | 1.0 |
| 03/05/2014 20:00 | 10.1 | 13.3 | 7.8 | 122.1 | 3,315,800.3 | 2,033.9 | 1.1 | 0.8 |
| 03/05/2014 21:00 | 9.8 | 13.3 | 7.6 | 121.6 | 3,351,081.7 | 2,006.6 | 1.1 | 0.8 |
| 03/05/2014 22:00 | 9.8 | 13.3 | 7.6 | 116.7 | 3,327,033.2 | 1,992.2 | 1.0 | 0.8 |
| 03/05/2014 23:00 | 9.0 | 13.6 | 7.3 | 101.5 | 3,285,214.0 | 1,871.2 | 0.9 | 0.6 |
| **Average/Sum#:** | 9.5 | 13.5 | 7.5 | 112.2 | 3,349,435.0 | 1,945.5 | 1.0 | 0.7 |
| **Minimum:** | 8.7 | 13.2 | 7.0 | 100.9 | 3,285,214.0 | 1,865.7 | 0.9 | 0.6 |
| **Maximum:** | 10.4 | 13.6 | 8.0 | 135.1 | 3,427,423.4 | 2,076.0 | 1.2 | 1.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/06/2014 00:00 | 9.1 | 13.6 | 7.4 | 101.6 | 3,320,409.5 | 1,867.0 | 0.9 | 0.6 |
| 03/06/2014 01:00 | 9.2 | 13.6 | 7.4 | 101.4 | 3,275,627.1 | 1,817.9 | 0.9 | 0.5 |
| 03/06/2014 02:00 | 10.0 | 13.9 | 8.4 | 84.0 | 2,495,873.8 | 1,275.8 | 1.0 | 0.5 |
| 03/06/2014 03:00 | 28.5 | 16.0 | 34.3 | 196.1 | 1,635,816.2 | 633.1 | 3.4 | 0.8 |
| 03/06/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 14.2 | 14.3 | 14.4 | 120.8 | 2,681,931.7 | 1,398.5 | 1.6 | 0.6 |
| **Minimum:** | 9.1 | 13.6 | 7.4 | 84.0 | 1,635,816.2 | 633.1 | 0.9 | 0.5 |
| **Maximum:** | 28.5 | 16.0 | 34.3 | 196.1 | 3,320,409.5 | 1,867.0 | 3.4 | 0.8 |
| **%SI** | 83.3 | 83.3 | 83.3 | 83.3 | 83.3 | 83.3 | 83.3 | 83.3 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/07/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/07/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/07/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/07/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/07/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/07/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/07/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/07/2014 07:00 | 42.7 | 17.3 | 70.0 | 0.1 | 1,986,873.7 | 493.3 | -0.1 | 0.0 |
| 03/07/2014 08:00 | 42.1 | 14.8 | 40.7 | 180.9 | 2,573,376.7 | 1,127.5 | 1.9 | 0.8 |
| 03/07/2014 09:00 | 10.2 | 13.9 | 8.6 | 86.9 | 2,616,187.5 | 1,337.3 | 0.9 | 0.4 |
| 03/07/2014 10:00 | 9.9 | 13.7 | 8.1 | 108.7 | 3,269,861.1 | 1,814.7 | 1.0 | 0.7 |
| 03/07/2014 11:00 | 9.8 | 13.7 | 8.0 | 121.1 | 3,309,205.1 | 1,860.7 | 1.1 | 0.7 |
| 03/07/2014 12:00 | 9.7 | 13.7 | 7.9 | 114.6 | 3,350,945.4 | 1,859.7 | 1.0 | 0.7 |
| 03/07/2014 13:00 | 9.6 | 13.7 | 7.9 | 107.1 | 3,344,638.9 | 1,856.2 | 0.9 | 0.6 |
| 03/07/2014 14:00 | 9.5 | 13.7 | 7.8 | 106.3 | 3,349,864.3 | 1,859.1 | 0.9 | 0.6 |
| 03/07/2014 15:00 | 9.5 | 13.7 | 7.8 | 107.7 | 3,348,963.4 | 1,858.6 | 0.9 | 0.6 |
| 03/07/2014 16:00 | 10.1 | 13.6 | 8.2 | 125.7 | 3,355,267.6 | 1,886.6 | 1.1 | 0.8 |
| 03/07/2014 17:00 | 10.1 | 13.4 | 7.9 | 121.6 | 3,385,150.3 | 2,027.0 | 1.0 | 0.8 |
| 03/07/2014 18:00 | 10.2 | 13.3 | 7.9 | 121.1 | 3,363,504.3 | 2,038.6 | 1.0 | 0.8 |
| 03/07/2014 19:00 | 10.7 | 13.1 | 8.1 | 152.6 | 3,368,327.5 | 2,213.7 | 1.3 | 1.1 |
| 03/07/2014 20:00 | 11.0 | 13.0 | 8.2 | 166.2 | 3,376,146.5 | 2,292.8 | 1.5 | 1.4 |
| 03/07/2014 21:00 | 11.1 | 13.0 | 8.3 | 167.4 | 3,369,373.0 | 2,288.2 | 1.5 | 1.4 |
| 03/07/2014 22:00 | 11.0 | 13.0 | 8.2 | 164.3 | 3,367,311.5 | 2,286.8 | 1.5 | 1.4 |
| 03/07/2014 23:00 | 10.9 | 13.1 | 8.2 | 152.5 | 3,386,130.0 | 2,225.4 | 1.3 | 1.1 |
| **Average/Sum#:** | 14.0 | 13.7 | 13.6 | 123.8 | 3,183,595.7 | 1,842.7 | 1.1 | 0.8 |
| **Minimum:** | 9.5 | 13.0 | 7.8 | 0.1 | 1,986,873.7 | 493.3 | -0.1 | 0.0 |
| **Maximum:** | 42.7 | 17.3 | 70.0 | 180.9 | 3,386,130.0 | 2,292.8 | 1.9 | 1.4 |
| **%SI** | 29.2 | 29.2 | 29.2 | 29.2 | 29.2 | 29.2 | 29.2 | 29.2 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/08/2014 00:00 | 10.0 | 13.4 | 7.9 | 117.6 | 3,412,233.6 | 2,018.3 | 1.0 | 0.8 |
| 03/08/2014 01:00 | 10.0 | 13.4 | 7.9 | 118.2 | 3,424,416.9 | 2,000.5 | 1.0 | 0.8 |
| 03/08/2014 02:00 | 10.0 | 13.5 | 8.0 | 113.1 | 3,381,264.8 | 1,950.6 | 1.0 | 0.8 |
| 03/08/2014 03:00 | 10.2 | 13.6 | 8.2 | 117.4 | 3,383,882.8 | 1,927.4 | 1.0 | 0.8 |
| 03/08/2014 04:00 | 10.4 | 13.5 | 8.3 | 122.4 | 3,436,215.1 | 1,982.3 | 1.0 | 0.8 |
| 03/08/2014 05:00 | 10.5 | 13.4 | 8.3 | 125.2 | 3,427,787.6 | 2,027.5 | 1.1 | 0.8 |
| 03/08/2014 06:00 | 10.6 | 13.3 | 8.2 | 129.5 | 3,408,546.8 | 2,065.9 | 1.1 | 0.8 |
| 03/08/2014 07:00 | 10.6 | 13.4 | 8.3 | 131.4 | 3,413,540.8 | 2,044.0 | 1.1 | 0.8 |
| 03/08/2014 08:00 | 10.1 | 13.6 | 8.2 | 113.1 | 3,348,242.6 | 1,907.1 | 1.0 | 0.8 |
| 03/08/2014 09:00 | 10.0 | 13.6 | 8.1 | 109.3 | 3,297,822.9 | 1,854.3 | 1.0 | 0.7 |
| 03/08/2014 10:00 | 9.9 | 13.6 | 8.0 | 109.0 | 3,298,534.3 | 1,854.7 | 0.9 | 0.6 |
| 03/08/2014 11:00 | 9.8 | 13.7 | 8.0 | 110.9 | 3,293,910.3 | 1,852.1 | 1.0 | 0.7 |
| 03/08/2014 12:00 | 9.7 | 13.7 | 7.9 | 107.3 | 3,294,621.7 | 1,852.5 | 0.9 | 0.6 |
| 03/08/2014 13:00 | 9.6 | 13.7 | 7.9 | 106.5 | 3,343,377.6 | 1,855.5 | 0.9 | 0.6 |
| 03/08/2014 14:00 | 9.5 | 13.7 | 7.8 | 106.2 | 3,338,152.1 | 1,852.6 | 0.9 | 0.6 |
| 03/08/2014 15:00 | 9.4 | 13.7 | 7.7 | 104.7 | 3,338,332.3 | 1,852.7 | 0.9 | 0.6 |
| 03/08/2014 16:00 | 9.4 | 13.7 | 7.7 | 105.1 | 3,356,531.2 | 1,862.8 | 0.9 | 0.6 |
| 03/08/2014 17:00 | 9.7 | 13.6 | 7.8 | 117.1 | 3,357,935.3 | 1,888.1 | 1.0 | 0.8 |
| 03/08/2014 18:00 | 10.6 | 13.2 | 8.1 | 140.1 | 3,363,432.2 | 2,136.8 | 1.2 | 1.1 |
| 03/08/2014 19:00 | 10.9 | 13.0 | 8.1 | 160.8 | 3,312,534.5 | 2,249.6 | 1.5 | 1.3 |
| 03/08/2014 20:00 | 11.0 | 13.0 | 8.2 | 161.9 | 3,306,140.1 | 2,269.4 | 1.5 | 1.4 |
| 03/08/2014 21:00 | 11.0 | 13.0 | 8.2 | 162.0 | 3,295,942.3 | 2,262.4 | 1.5 | 1.4 |
| 03/08/2014 22:00 | 11.0 | 13.0 | 8.2 | 163.4 | 3,298,418.9 | 2,264.1 | 1.5 | 1.4 |
| 03/08/2014 23:00 | 10.9 | 13.0 | 8.1 | 155.0 | 3,313,113.9 | 2,225.8 | 1.4 | 1.1 |
| **Average/Sum#:** | 10.2 | 13.4 | 8.0 | 125.3 | 3,351,872.1 | 2,002.4 | 1.1 | 0.9 |
| **Minimum:** | 9.4 | 13.0 | 7.7 | 104.7 | 3,293,910.3 | 1,852.1 | 0.9 | 0.6 |
| **Maximum:** | 11.0 | 13.7 | 8.3 | 163.4 | 3,436,215.1 | 2,269.4 | 1.5 | 1.4 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/09/2014 00:00 | 9.7 | 13.5 | 7.7 | 109.3 | 3,162,850.3 | 1,824.6 | 1.0 | 0.7 |
| 03/09/2014 01:00 | 9.5 | 13.8 | 7.9 | 86.1 | 2,659,576.5 | 1,378.9 | 0.9 | 0.4 |
| 03/09/2014 02:00 | 28.2 | 15.8 | 32.6 | 196.0 | 1,640,321.4 | 658.8 | 3.4 | 0.9 |
| 03/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 15:00 | 43.1 | 17.0 | 65.2 | 51.6 | 1,937,735.5 | 537.7 | 0.5 | 0.1 |
| 03/09/2014 16:00 | 27.0 | 14.0 | 23.1 | 159.1 | 2,833,902.9 | 1,407.2 | 1.6 | 0.8 |
| 03/09/2014 17:00 | 10.5 | 13.3 | 8.2 | 129.7 | 3,382,641.3 | 2,074.9 | 1.1 | 0.8 |
| 03/09/2014 18:00 | 10.9 | 13.0 | 8.1 | 157.6 | 3,300,610.5 | 2,217.4 | 1.4 | 1.1 |
| 03/09/2014 19:00 | 10.9 | 13.0 | 8.1 | 156.6 | 3,304,435.8 | 2,244.1 | 1.4 | 1.1 |
| 03/09/2014 20:00 | 10.9 | 13.0 | 8.1 | 161.8 | 3,309,147.8 | 2,247.3 | 1.5 | 1.3 |
| 03/09/2014 21:00 | 10.9 | 13.0 | 8.1 | 161.3 | 3,309,736.8 | 2,247.7 | 1.5 | 1.3 |
| 03/09/2014 22:00 | 9.7 | 13.6 | 7.8 | 111.6 | 3,328,996.7 | 1,798.9 | 1.0 | 0.7 |
| 03/09/2014 23:00 | 9.6 | 13.6 | 7.8 | 107.4 | 3,374,786.9 | 1,799.0 | 0.9 | 0.5 |
| **Average/Sum#:** | 15.9 | 13.9 | 16.1 | 132.3 | 2,962,061.9 | 1,703.0 | 1.4 | 0.8 |
| **Minimum:** | 9.5 | 13.0 | 7.7 | 51.6 | 1,640,321.4 | 537.7 | 0.5 | 0.1 |
| **Maximum:** | 43.1 | 17.0 | 65.2 | 196.0 | 3,382,641.3 | 2,247.7 | 3.4 | 1.3 |
| **%SI** | 50.0 | 50.0 | 50.0 | 50.0 | 50.0 | 50.0 | 50.0 | 50.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/10/2014 00:00 | 9.6 | 13.6 | 7.8 | 107.4 | 3,377,038.0 | 1,800.2 | 0.9 | 0.5 |
| 03/10/2014 01:00 | 9.7 | 13.9 | 8.2 | 84.2 | 2,534,592.4 | 1,314.1 | 0.9 | 0.4 |
| 03/10/2014 02:00 | 10.1 | 13.9 | 8.5 | 82.8 | 2,393,213.8 | 1,240.8 | 1.0 | 0.5 |
| 03/10/2014 03:00 | 10.2 | 13.8 | 8.5 | 79.4 | 2,400,157.3 | 1,244.4 | 0.9 | 0.4 |
| 03/10/2014 04:00 | 10.4 | 13.8 | 8.6 | 83.9 | 2,411,537.1 | 1,250.3 | 1.0 | 0.5 |
| 03/10/2014 05:00 | 9.6 | 13.8 | 8.0 | 93.5 | 2,949,084.3 | 1,529.0 | 0.9 | 0.5 |
| 03/10/2014 06:00 | 9.2 | 13.8 | 7.6 | 105.5 | 3,402,068.6 | 1,788.7 | 0.9 | 0.5 |
| 03/10/2014 07:00 | 9.6 | 13.7 | 7.9 | 108.3 | 3,454,563.2 | 1,816.3 | 0.9 | 0.5 |
| 03/10/2014 08:00 | 9.8 | 13.5 | 7.8 | 121.5 | 3,365,404.9 | 1,892.3 | 1.1 | 0.8 |
| 03/10/2014 09:00 | 9.6 | 13.5 | 7.7 | 106.9 | 3,343,853.4 | 1,904.6 | 0.9 | 0.6 |
| 03/10/2014 10:00 | 9.6 | 13.7 | 7.9 | 105.2 | 3,298,712.1 | 1,854.8 | 0.9 | 0.6 |
| 03/10/2014 11:00 | 9.6 | 13.7 | 7.9 | 108.3 | 3,351,305.8 | 1,859.9 | 0.9 | 0.6 |
| 03/10/2014 12:00 | 9.5 | 13.7 | 7.8 | 106.1 | 3,351,125.6 | 1,859.8 | 0.9 | 0.6 |
| 03/10/2014 13:00 | 9.5 | 13.7 | 7.8 | 107.2 | 3,311,517.1 | 1,862.0 | 0.9 | 0.6 |
| 03/10/2014 14:00 | 9.5 | 13.7 | 7.8 | 107.7 | 3,316,674.7 | 1,864.9 | 0.9 | 0.6 |
| 03/10/2014 15:00 | 9.6 | 13.7 | 7.9 | 109.9 | 3,365,360.4 | 1,867.7 | 0.9 | 0.6 |
| 03/10/2014 16:00 | 9.6 | 13.7 | 7.9 | 111.0 | 3,361,396.3 | 1,865.5 | 1.0 | 0.7 |
| 03/10/2014 17:00 | 9.6 | 13.7 | 7.9 | 108.4 | 3,355,990.7 | 1,862.5 | 0.9 | 0.6 |
| 03/10/2014 18:00 | 9.7 | 13.7 | 7.9 | 115.8 | 3,372,027.4 | 1,871.4 | 1.0 | 0.7 |
| 03/10/2014 19:00 | 10.9 | 13.2 | 8.4 | 146.9 | 3,375,475.5 | 2,169.1 | 1.3 | 1.1 |
| 03/10/2014 20:00 | 10.4 | 13.3 | 8.1 | 136.8 | 3,384,070.6 | 2,125.2 | 1.2 | 1.1 |
| 03/10/2014 21:00 | 9.8 | 13.7 | 8.0 | 104.2 | 3,178,342.7 | 1,740.7 | 0.9 | 0.5 |
| 03/10/2014 22:00 | 9.8 | 13.9 | 8.3 | 85.8 | 2,727,502.1 | 1,394.2 | 0.9 | 0.4 |
| 03/10/2014 23:00 | 31.2 | 16.1 | 38.4 | 197.8 | 1,604,860.0 | 609.4 | 3.5 | 0.8 |
| **Average/Sum#:** | 10.7 | 13.8 | 9.3 | 109.4 | 3,082,744.8 | 1,691.2 | 1.1 | 0.6 |
| **Minimum:** | 9.2 | 13.2 | 7.6 | 79.4 | 1,604,860.0 | 609.4 | 0.9 | 0.4 |
| **Maximum:** | 31.2 | 16.1 | 38.4 | 197.8 | 3,454,563.2 | 2,169.1 | 3.5 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/11/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/11/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/11/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/11/2014 05:00 | 36.1 | 17.7 | 66.6 | 0.1 | 1,958,276.9 | 414.7 | -0.4 | -0.1 |
| 03/11/2014 06:00 | 61.0 | 15.6 | 67.9 | 236.7 | 2,165,402.3 | 885.5 | 2.9 | 1.0 |
| 03/11/2014 07:00 | 10.8 | 13.7 | 8.9 | 116.7 | 3,365,931.0 | 1,769.7 | 1.0 | 0.7 |
| 03/11/2014 08:00 | 10.5 | 13.6 | 8.5 | 121.7 | 3,390,329.6 | 1,856.8 | 1.0 | 0.7 |
| 03/11/2014 09:00 | 10.5 | 13.7 | 8.6 | 121.2 | 3,306,181.7 | 1,859.0 | 1.1 | 0.7 |
| 03/11/2014 10:00 | 10.4 | 13.7 | 8.5 | 124.5 | 3,346,440.7 | 1,857.2 | 1.1 | 0.7 |
| 03/11/2014 11:00 | 10.2 | 13.7 | 8.4 | 125.0 | 3,341,215.3 | 1,854.3 | 1.1 | 0.7 |
| 03/11/2014 12:00 | 10.0 | 13.7 | 8.2 | 112.0 | 3,176,516.8 | 1,739.7 | 1.0 | 0.7 |
| 03/11/2014 13:00 | 10.6 | 13.9 | 8.9 | 87.7 | 2,613,448.6 | 1,335.9 | 0.9 | 0.4 |
| 03/11/2014 14:00 | 11.0 | 13.9 | 9.3 | 86.3 | 2,497,243.2 | 1,276.5 | 1.0 | 0.5 |
| 03/11/2014 15:00 | 10.9 | 13.9 | 9.2 | 93.9 | 2,549,672.6 | 1,303.3 | 1.0 | 0.5 |
| 03/11/2014 16:00 | 10.5 | 13.9 | 8.9 | 88.7 | 2,696,592.2 | 1,378.4 | 0.9 | 0.4 |
| 03/11/2014 17:00 | 10.3 | 13.9 | 8.7 | 89.1 | 2,713,807.9 | 1,387.2 | 0.9 | 0.4 |
| 03/11/2014 18:00 | 10.2 | 13.8 | 8.5 | 108.1 | 2,945,012.8 | 1,569.9 | 1.1 | 0.6 |
| 03/11/2014 19:00 | 11.2 | 13.4 | 8.8 | 155.3 | 3,360,728.5 | 2,086.0 | 1.4 | 1.0 |
| 03/11/2014 20:00 | 10.8 | 13.2 | 8.3 | 149.3 | 3,391,348.4 | 2,179.3 | 1.3 | 1.1 |
| 03/11/2014 21:00 | 10.5 | 13.3 | 8.2 | 134.6 | 3,430,327.5 | 2,129.2 | 1.1 | 0.9 |
| 03/11/2014 22:00 | 10.7 | 13.2 | 8.2 | 147.2 | 3,418,892.5 | 2,197.0 | 1.3 | 1.1 |
| 03/11/2014 23:00 | 10.2 | 13.6 | 8.2 | 111.4 | 3,135,270.4 | 1,762.9 | 1.0 | 0.7 |
| **Average/Sum#:** | 14.5 | 14.0 | 14.8 | 116.3 | 2,989,612.6 | 1,623.3 | 1.1 | 0.7 |
| **Minimum:** | 10.0 | 13.2 | 8.2 | 0.1 | 1,958,276.9 | 414.7 | -0.4 | -0.1 |
| **Maximum:** | 61.0 | 17.7 | 67.9 | 236.7 | 3,430,327.5 | 2,197.0 | 2.9 | 1.1 |
| **%SI** | 20.8 | 20.8 | 20.8 | 20.8 | 20.8 | 20.8 | 33.3 | 33.3 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/12/2014 00:00 | 10.4 | 13.9 | 8.8 | 83.6 | 2,504,677.2 | 1,280.3 | 0.9 | 0.4 |
| 03/12/2014 01:00 | 10.6 | 13.9 | 8.9 | 83.3 | 2,472,202.3 | 1,263.7 | 1.0 | 0.5 |
| 03/12/2014 02:00 | 10.8 | 13.9 | 9.1 | 82.8 | 2,429,750.1 | 1,242.0 | 1.0 | 0.5 |
| 03/12/2014 03:00 | 10.8 | 14.0 | 9.2 | 82.5 | 2,412,534.5 | 1,233.2 | 1.0 | 0.5 |
| 03/12/2014 04:00 | 10.9 | 13.9 | 9.2 | 83.0 | 2,421,142.3 | 1,237.6 | 1.0 | 0.5 |
| 03/12/2014 05:00 | 10.5 | 13.8 | 8.7 | 114.5 | 3,162,092.2 | 1,731.8 | 1.0 | 0.7 |
| 03/12/2014 06:00 | 10.6 | 13.5 | 8.5 | 132.9 | 3,406,272.0 | 1,989.9 | 1.1 | 0.8 |
| 03/12/2014 07:00 | 11.4 | 13.2 | 8.7 | 166.5 | 3,422,316.0 | 2,199.2 | 1.4 | 1.1 |
| 03/12/2014 08:00 | 10.4 | 13.5 | 8.3 | 126.7 | 3,447,525.9 | 2,014.0 | 1.1 | 0.8 |
| 03/12/2014 09:00 | 9.9 | 13.6 | 8.0 | 109.9 | 3,363,558.5 | 1,866.7 | 0.9 | 0.6 |
| 03/12/2014 10:00 | 10.0 | 13.6 | 8.1 | 114.3 | 3,340,854.9 | 1,854.1 | 1.0 | 0.7 |
| 03/12/2014 11:00 | 9.9 | 13.6 | 8.0 | 121.5 | 3,340,854.9 | 1,854.1 | 1.1 | 0.7 |
| 03/12/2014 12:00 | 10.6 | 13.8 | 8.8 | 93.3 | 2,625,823.0 | 1,361.4 | 1.0 | 0.5 |
| 03/12/2014 13:00 | 10.6 | 13.9 | 8.9 | 90.8 | 2,695,809.7 | 1,378.0 | 1.0 | 0.6 |
| 03/12/2014 14:00 | 11.2 | 13.9 | 9.4 | 86.4 | 2,452,052.2 | 1,253.4 | 1.0 | 0.5 |
| 03/12/2014 15:00 | 11.2 | 13.9 | 9.4 | 85.7 | 2,451,269.6 | 1,253.0 | 1.0 | 0.5 |
| 03/12/2014 16:00 | 11.1 | 13.9 | 9.4 | 85.7 | 2,449,509.0 | 1,252.1 | 1.0 | 0.5 |
| 03/12/2014 17:00 | 10.5 | 13.8 | 8.7 | 114.3 | 2,900,178.2 | 1,546.0 | 1.1 | 0.6 |
| 03/12/2014 18:00 | 9.7 | 13.6 | 7.8 | 109.9 | 3,406,665.5 | 1,915.5 | 0.9 | 0.6 |
| 03/12/2014 19:00 | 10.7 | 13.2 | 8.2 | 145.9 | 3,386,368.6 | 2,176.1 | 1.3 | 1.1 |
| 03/12/2014 20:00 | 10.8 | 13.2 | 8.3 | 150.8 | 3,389,556.2 | 2,202.9 | 1.3 | 1.1 |
| 03/12/2014 21:00 | 11.0 | 13.1 | 8.3 | 164.0 | 3,378,310.4 | 2,269.6 | 1.5 | 1.4 |
| 03/12/2014 22:00 | 11.0 | 13.1 | 8.3 | 159.8 | 3,384,711.0 | 2,273.9 | 1.4 | 1.1 |
| 03/12/2014 23:00 | 10.8 | 13.2 | 8.3 | 144.0 | 3,395,394.4 | 2,181.9 | 1.3 | 1.1 |
| **Average/Sum#:** | 10.6 | 13.6 | 8.6 | 113.8 | 2,984,976.2 | 1,701.3 | 1.1 | 0.7 |
| **Minimum:** | 9.7 | 13.1 | 7.8 | 82.5 | 2,412,534.5 | 1,233.2 | 0.9 | 0.4 |
| **Maximum:** | 11.4 | 14.0 | 9.4 | 166.5 | 3,447,525.9 | 2,273.9 | 1.5 | 1.4 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/13/2014 00:00 | 9.8 | 13.7 | 8.0 | 102.5 | 3,143,485.5 | 1,675.7 | 0.9 | 0.5 |
| 03/13/2014 01:00 | 10.5 | 13.8 | 8.7 | 112.2 | 3,420,667.8 | 1,773.5 | 0.9 | 0.5 |
| 03/13/2014 02:00 | 9.6 | 13.9 | 8.1 | 85.4 | 2,724,567.6 | 1,392.7 | 0.9 | 0.4 |
| 03/13/2014 03:00 | 9.7 | 13.9 | 8.2 | 82.7 | 2,694,049.0 | 1,377.1 | 0.9 | 0.4 |
| 03/13/2014 04:00 | 9.6 | 13.9 | 8.1 | 82.6 | 2,698,939.8 | 1,379.6 | 0.9 | 0.4 |
| 03/13/2014 05:00 | 10.6 | 13.6 | 8.6 | 123.7 | 3,334,815.1 | 1,875.1 | 1.1 | 0.8 |
| 03/13/2014 06:00 | 10.6 | 13.5 | 8.5 | 130.7 | 3,417,912.1 | 1,996.7 | 1.1 | 0.8 |
| 03/13/2014 07:00 | 11.7 | 13.1 | 8.9 | 181.7 | 3,397,827.8 | 2,257.9 | 1.6 | 1.4 |
| 03/13/2014 08:00 | 10.9 | 13.2 | 8.4 | 146.5 | 3,414,431.5 | 2,169.2 | 1.3 | 1.1 |
| 03/13/2014 09:00 | 10.8 | 13.4 | 8.5 | 129.4 | 3,380,641.2 | 2,024.3 | 1.1 | 0.8 |
| 03/13/2014 10:00 | 10.2 | 13.6 | 8.2 | 119.9 | 3,364,219.2 | 1,916.2 | 1.0 | 0.8 |
| 03/13/2014 11:00 | 9.7 | 13.7 | 7.9 | 114.4 | 3,389,781.8 | 1,856.5 | 1.0 | 0.7 |
| 03/13/2014 12:00 | 9.8 | 13.5 | 7.8 | 111.1 | 3,412,534.4 | 1,918.8 | 0.9 | 0.6 |
| 03/13/2014 13:00 | 10.2 | 13.4 | 8.0 | 116.2 | 3,415,587.1 | 1,970.4 | 1.0 | 0.8 |
| 03/13/2014 14:00 | 10.2 | 13.4 | 8.0 | 116.5 | 3,377,000.5 | 1,972.8 | 1.0 | 0.8 |
| 03/13/2014 15:00 | 10.1 | 13.4 | 7.9 | 115.3 | 3,374,775.2 | 1,971.5 | 1.0 | 0.8 |
| 03/13/2014 16:00 | 9.6 | 13.5 | 7.7 | 108.8 | 3,368,432.8 | 1,918.6 | 0.9 | 0.6 |
| 03/13/2014 17:00 | 9.3 | 13.7 | 7.6 | 101.7 | 3,351,125.6 | 1,859.8 | 0.9 | 0.6 |
| 03/13/2014 18:00 | 9.4 | 13.6 | 7.6 | 106.6 | 3,348,509.4 | 1,882.8 | 0.9 | 0.6 |
| 03/13/2014 19:00 | 9.8 | 13.5 | 7.8 | 111.8 | 3,388,198.6 | 1,954.6 | 1.0 | 0.8 |
| 03/13/2014 20:00 | 9.4 | 13.6 | 7.6 | 107.0 | 3,372,874.5 | 1,896.5 | 0.9 | 0.6 |
| 03/13/2014 21:00 | 9.7 | 13.6 | 7.8 | 106.4 | 3,191,839.9 | 1,771.4 | 1.0 | 0.7 |
| 03/13/2014 22:00 | 9.8 | 13.9 | 8.3 | 95.6 | 2,933,111.4 | 1,499.3 | 0.9 | 0.4 |
| 03/13/2014 23:00 | 9.2 | 13.9 | 7.8 | 103.2 | 3,430,212.4 | 1,753.4 | 0.9 | 0.5 |
| **Average/Sum#:** | 10.0 | 13.6 | 8.1 | 113.0 | 3,264,397.5 | 1,836.0 | 1.0 | 0.7 |
| **Minimum:** | 9.2 | 13.1 | 7.6 | 82.6 | 2,694,049.0 | 1,377.1 | 0.9 | 0.4 |
| **Maximum:** | 11.7 | 13.9 | 8.9 | 181.7 | 3,430,212.4 | 2,257.9 | 1.6 | 1.4 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/14/2014 00:00 | 9.2 | 13.9 | 7.8 | 102.5 | 3,430,016.8 | 1,753.3 | 0.8 | 0.5 |
| 03/14/2014 01:00 | 15.1 | 14.5 | 13.9 | 132.8 | 3,012,523.0 | 1,429.9 | 1.2 | 0.7 |
| 03/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 06:00 | 10.7 | 18.9 | 31.6 | 0.1 | 1,867,396.9 | 150.0 | -0.6 | 0.0 |
| 03/14/2014 07:00 | 50.4 | 15.8 | 58.3 | 160.5 | 2,261,741.3 | 825.8 | 1.8 | 0.6 |
| 03/14/2014 08:00 | 10.1 | 13.8 | 8.4 | 111.0 | 3,453,071.1 | 1,790.3 | 0.9 | 0.5 |
| 03/14/2014 09:00 | 10.2 | 13.7 | 8.4 | 111.7 | 3,428,125.7 | 1,802.4 | 0.9 | 0.5 |
| 03/14/2014 10:00 | 10.2 | 13.7 | 8.4 | 109.8 | 3,415,762.8 | 1,795.9 | 0.9 | 0.5 |
| 03/14/2014 11:00 | 10.3 | 13.7 | 8.4 | 110.6 | 3,395,792.1 | 1,785.4 | 0.9 | 0.5 |
| 03/14/2014 12:00 | 10.4 | 13.7 | 8.5 | 110.7 | 3,379,244.9 | 1,776.7 | 0.9 | 0.5 |
| 03/14/2014 13:00 | 10.5 | 13.7 | 8.6 | 111.5 | 3,361,936.9 | 1,767.6 | 0.9 | 0.5 |
| 03/14/2014 14:00 | 10.4 | 13.7 | 8.5 | 109.5 | 3,349,954.4 | 1,761.3 | 0.9 | 0.5 |
| 03/14/2014 15:00 | 10.4 | 13.7 | 8.5 | 109.7 | 3,344,438.7 | 1,758.4 | 0.9 | 0.5 |
| 03/14/2014 16:00 | 10.5 | 13.7 | 8.6 | 110.3 | 3,325,228.7 | 1,748.3 | 0.9 | 0.5 |
| 03/14/2014 17:00 | 10.6 | 13.7 | 8.7 | 111.3 | 3,366,083.7 | 1,745.2 | 0.9 | 0.5 |
| 03/14/2014 18:00 | 10.6 | 13.7 | 8.7 | 111.5 | 3,366,855.2 | 1,745.6 | 0.9 | 0.5 |
| 03/14/2014 19:00 | 10.5 | 13.7 | 8.6 | 109.4 | 3,346,721.0 | 1,759.6 | 0.9 | 0.5 |
| 03/14/2014 20:00 | 10.5 | 13.7 | 8.6 | 110.0 | 3,359,654.5 | 1,766.4 | 0.9 | 0.5 |
| 03/14/2014 21:00 | 10.4 | 13.7 | 8.5 | 109.2 | 3,372,587.9 | 1,773.2 | 0.9 | 0.5 |
| 03/14/2014 22:00 | 10.3 | 13.7 | 8.4 | 109.4 | 3,387,803.8 | 1,781.2 | 0.9 | 0.5 |
| 03/14/2014 23:00 | 10.1 | 13.7 | 8.3 | 107.0 | 3,399,215.6 | 1,787.2 | 0.9 | 0.5 |
| **Average/Sum#:** | 12.6 | 14.1 | 12.4 | 107.9 | 3,231,207.8 | 1,625.2 | 0.9 | 0.5 |
| **Minimum:** | 9.2 | 13.7 | 7.8 | 0.1 | 1,867,396.9 | 150.0 | -0.6 | 0.0 |
| **Maximum:** | 50.4 | 18.9 | 58.3 | 160.5 | 3,453,071.1 | 1,802.4 | 1.8 | 0.7 |
| **%SI** | 16.7 | 16.7 | 16.7 | 16.7 | 16.7 | 16.7 | 16.7 | 16.7 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/15/2014 00:00 | 28.4 | 15.9 | 33.5 | 207.3 | 1,716,948.1 | 664.5 | 3.4 | 0.9 |
| 03/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 28.4 | 15.9 | 33.5 | 207.3 | 1,716,948.1 | 664.5 | 3.4 | 0.9 |
| **Minimum:** | 28.4 | 15.9 | 33.5 | 207.3 | 1,716,948.1 | 664.5 | 3.4 | 0.9 |
| **Maximum:** | 28.4 | 15.9 | 33.5 | 207.3 | 1,716,948.1 | 664.5 | 3.4 | 0.9 |
| **%SI** | 95.8 | 95.8 | 95.8 | 95.8 | 95.8 | 95.8 | 95.8 | 95.8 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/30/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# Daily Summary Report

## CT2 - NH3 Slip

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx, Inlet, Ppm 1 Hour(s) | Unit CT2 O2Dry, Inlet, Pct 1 Hour(s) | Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s) | Unit CT2 NH3slip, LbPerHr 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/31/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 | 100.0 |

# ATTACHMENT 9

## Quarterly/Annual Emissions (AQ-23, 26)
## (Fuel Use, Hours of Operation and NH3 Injection)

# Emissions Limits Per AQ-26

| Quarterly and Annual Combustion Emissions from CGS Facility | | | | | |
|---|---|---|---|---|---|
| Pollutant | 1st Quarter Emissions (tons) | 2nd Quarter Emissions (tons) | 3rd Quarter Emissions (tons) | 4th Quarter Emissions (tons) | Annual Emissions (tons) |
| $NO_x$ | 45.56 | 43.58 | 51.30 | 44.27 | 184.7 |
| CO | 54.29 | 52.49 | 107.15 | 53.95 | 267.9 |
| VOC's | 12.30 | 11.63 | 11.84 | 11.76 | 47.5 |
| PM10 | 25.54 | 25.78 | 26.02 | 26.02 | 103.4 |
| $SO_2$ | 4.07 | 3.85 | 3.89 | 3.89 | 15.7 |

# Actual Emission from Emission Sources *

| Pollutant | 1st Quarter Emissions (tons) | 2nd Quarter Emissions (tons) | 3rd Quarter Emissions (tons) | 4th Quarter Emissions (tons) | Annual Emissions (tons) |
|---|---|---|---|---|---|
| $NO_x$ | 8.84 | | | | 8.84 |
| CO | 2.43 | | | | 2.43 |
| VOC's** | 1.12 | | | | 1.12 |
| PM10*** | 6.17 | | | | 6.17 |
| $SO_2$ | 1.34 | | | | 1.34 |

* Emissions are based on CT1 and CT2 and the Wet SAC. The Water Bath Heater did not Operate during the 3rd Quarter of 2013.

** VOC Mass Emissions are based on Average Souce Test Results for lbs/MMBtu. CT1 EF = .0009 Prior to 10/30/2013 and .0007 After 10/30/2013. CT2 EF = .0007 Prior to 11/01/2014 and .0003 after 11/01/2014.

*** PM10 is based on 2010 lb/MMBtu Source Test Results. CT1 EF = .0025; CT2 EF = .003

# Quarterly Emissions

# Monthly Summary By Day Report

## CT1 and CT2 - Pounds

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

| Date/Time | Unit CT1 CO, Lb 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 SO2, Lb 1 Hour(s) | Unit CT2 CO, Lb 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/01/2014 | 106.2 | 187.20 | 11.5 | 112.6 | 229.10 | 14.8 |
| 01/02/2014 | 66.9 | 144.60 | 28.5 | 15.4 | 189.70 | 28.7 |
| 01/03/2014 | 60.3 | 138.60 | 26.9 | 14.7 | 182.60 | 27.3 |
| 01/04/2014 | 59.2 | 154.30 | 27.8 | 11.4 | 184.80 | 28.2 |
| 01/05/2014 | 56.9 | 176.40 | 28.6 | 9.0 | 192.50 | 29.1 |
| 01/06/2014 | 76.4 | 191.10 | 30.5 | 13.6 | 207.30 | 31.0 |
| 01/07/2014 | 64.2 | 153.70 | 28.0 | 13.4 | 191.60 | 28.7 |
| 01/08/2014 | 30.0 | 84.52 | 20.2 | 8.0 | 133.37 | 20.2 |
| 01/09/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/10/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/11/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/12/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/13/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/14/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/15/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/16/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/17/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/18/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/19/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/20/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/21/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/22/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/23/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/24/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/25/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/26/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/27/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/28/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 01/29/2014 | 169.3 | 211.45 | 8.7 | 280.7 | 407.93 | 13.3 |
| 01/30/2014 | 44.8 | 110.70 | 24.4 | 7.6 | 147.60 | 24.9 |
| 01/31/2014 | 48.8 | 124.20 | 26.4 | 13.8 | 176.10 | 27.3 |
| **Monthly Avg/Sum*:** | 783.0 * | 1,676.77 * | 261.5 * | 500.2 * | 2,242.60 * | 273.5 * |
| **Daily Min:** | 30.0 | 84.52 | 8.7 | 7.6 | 133.37 | 13.3 |
| **Daily Max:** | 169.3 | 211.45 | 30.5 | 280.7 | 407.93 | 31.0 |
| **Jan 14 - Jan 14** | 783.0 | 1,676.77 | 261.5 | 500.2 | 2,242.60 | 273.5 |
| **QTD:** | 783.0 * | 1,676.77 * | 261.5 * | 500.2 * | 2,242.60 * | 273.5 * |
| **YTD 14:** | 783.0 * | 1,676.77 * | 261.5 * | 500.2 * | 2,242.60 * | 273.5 * |

# Monthly Summary By Day Report

## CT1 and CT2 - Pounds

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

| Date/Time | Unit CT1 CO, Lb 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 SO2, Lb 1 Hour(s) | Unit CT2 CO, Lb 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/01/2014 | 52.0 | 137.30 | 26.5 | 6.5 | 166.60 | 27.1 |
| 02/02/2014 | 81.6 | 183.20 | 30.4 | 15.0 | 209.70 | 31.6 |
| 02/03/2014 | 75.8 | 162.60 | 29.6 | 16.5 | 203.10 | 30.7 |
| 02/04/2014 | 73.1 | 154.30 | 29.0 | 18.8 | 197.90 | 29.4 |
| 02/05/2014 | 68.9 | 158.00 | 28.2 | 15.5 | 190.40 | 29.0 |
| 02/06/2014 | 55.7 | 136.70 | 26.8 | 15.3 | 183.20 | 27.1 |
| 02/07/2014 | 74.9 | 151.20 | 29.5 | 18.8 | 200.70 | 29.7 |
| 02/08/2014 | 65.6 | 114.60 | 27.0 | 16.4 | 180.80 | 27.4 |
| 02/09/2014 | 66.4 | 141.20 | 27.4 | 15.4 | 174.70 | 27.8 |
| 02/10/2014 | 55.1 | 118.50 | 25.2 | 13.2 | 160.40 | 25.3 |
| 02/11/2014 | 58.2 | 128.10 | 26.5 | 15.9 | 175.50 | 26.6 |
| 02/12/2014 | 63.7 | 147.60 | 28.1 | 17.6 | 192.50 | 28.5 |
| 02/13/2014 | 65.4 | 158.40 | 29.8 | 14.1 | 190.70 | 30.1 |
| 02/14/2014 | 60.1 | 159.00 | 29.1 | 12.7 | 196.00 | 29.3 |
| 02/15/2014 | 64.2 | 167.00 | 29.7 | 13.7 | 202.00 | 30.0 |
| 02/16/2014 | 59.1 | 141.30 | 26.8 | 9.6 | 181.20 | 27.1 |
| 02/17/2014 | 55.7 | 131.30 | 26.2 | 10.4 | 176.20 | 26.3 |
| 02/18/2014 | 60.2 | 147.30 | 27.8 | 13.2 | 186.70 | 27.9 |
| 02/19/2014 | 128.0 | 230.71 | 12.5 | 58.2 | 211.50 | 9.0 |
| 02/20/2014 | 48.6 | 151.80 | 26.9 | 4.6 | 180.00 | 26.9 |
| 02/21/2014 | 60.2 | 165.00 | 27.9 | 4.3 | 186.60 | 27.9 |
| 02/22/2014 | 59.3 | 161.40 | 28.3 | 10.3 | 192.00 | 28.5 |
| 02/23/2014 | 56.1 | 169.20 | 29.0 | 7.3 | 194.90 | 29.1 |
| 02/24/2014 | 56.8 | 155.30 | 27.2 | 7.9 | 180.40 | 27.4 |
| 02/25/2014 | 53.7 | 124.00 | 27.9 | 11.5 | 185.60 | 27.9 |
| 02/26/2014 | 64.4 | 176.00 | 29.7 | 8.4 | 163.60 | 29.8 |
| 02/27/2014 | 67.4 | 127.80 | 26.3 | 14.7 | 179.40 | 26.3 |
| 02/28/2014 | 69.5 | 143.50 | 28.3 | 18.1 | 192.60 | 28.6 |
| **Monthly Avg/Sum*:** | 1,819.7 * | 4,242.31 * | 767.6 * | 403.9 * | 5,234.90 * | 772.3 * |
| **Daily Min:** | 48.6 | 114.60 | 12.5 | 4.3 | 160.40 | 9.0 |
| **Daily Max:** | 128.0 | 230.71 | 30.4 | 58.2 | 211.50 | 31.6 |
| **Jan 14 - Feb 14** | 2,602.7 | 5,919.08 | 1,029.1 | 904.1 | 7,477.50 | 1,045.8 |
| **QTD:** | 2,602.7 * | 5,919.08 * | 1,029.1 * | 904.1 * | 7,477.50 * | 1,045.8 * |
| **YTD 14:** | 2,602.7 * | 5,919.08 * | 1,029.1 * | 904.1 * | 7,477.50 * | 1,045.8 * |

# Monthly Summary By Day Report

## CT1 and CT2 - Pounds

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:23 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

| Date/Time | Unit CT1 CO, Lb 1 Hour(s) | Unit CT1 NOx, Lb 1 Hour(s) | Unit CT1 SO2, Lb 1 Hour(s) | Unit CT2 CO, Lb 1 Hour(s) | Unit CT2 NOx, Lb 1 Hour(s) | Unit CT2 SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/01/2014 | 60.3 | 135.40 | 27.2 | 17.4 | 184.50 | 27.2 |
| 03/02/2014 | 71.5 | 160.10 | 29.3 | 16.5 | 198.70 | 29.8 |
| 03/03/2014 | 56.5 | 136.60 | 26.7 | 8.9 | 176.20 | 27.1 |
| 03/04/2014 | 42.2 | 103.10 | 23.7 | 7.7 | 145.80 | 23.7 |
| 03/05/2014 | 61.6 | 135.60 | 27.5 | 14.9 | 186.90 | 27.7 |
| 03/06/2014 | 9.7 | 13.39 | 3.1 | 5.8 | 22.73 | 3.1 |
| 03/07/2014 | 209.6 | 276.13 | 21.5 | 109.0 | 279.83 | 18.6 |
| 03/08/2014 | 56.6 | 147.30 | 28.2 | 9.5 | 192.20 | 28.7 |
| 03/09/2014 | 162.5 | 167.60 | 15.6 | 67.4 | 191.79 | 11.7 |
| 03/10/2014 | 54.4 | 120.45 | 24.2 | 9.3 | 154.98 | 23.8 |
| 03/11/2014 | 80.5 | 138.78 | 20.8 | 62.2 | 218.19 | 18.3 |
| 03/12/2014 | 43.1 | 120.30 | 24.1 | 6.9 | 159.00 | 24.4 |
| 03/13/2014 | 50.7 | 117.35 | 24.2 | 10.2 | 169.90 | 26.5 |
| 03/14/2014 | 0.0 | 0.00 | 0.0 | 52.8 | 216.71 | 19.6 |
| 03/15/2014 | 0.0 | 0.00 | 0.0 | 4.8 | 4.15 | 0.1 |
| 03/16/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 03/17/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 03/18/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 03/19/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 03/20/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 03/21/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 03/22/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 03/23/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 03/24/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 03/25/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 03/26/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 03/27/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 03/28/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 03/29/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 03/30/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| 03/31/2014 | 0.0 | 0.00 | 0.0 | 0.0 | 0.00 | 0.0 |
| **Monthly Avg/Sum*:** | 959.2 * | 1,772.10 * | 296.1 * | 403.3 * | 2,501.58 * | 310.3 * |
| **Daily Min:** | 9.7 | 13.39 | 3.1 | 4.8 | 4.15 | 0.1 |
| **Daily Max:** | 209.6 | 276.13 | 29.3 | 109.0 | 279.83 | 29.8 |
| **Jan 14 - Mar 14** | 3,561.9 | 7,691.18 | 1,325.2 | 1,307.4 | 9,979.08 | 1,356.1 |
| **QTD:** | 3,561.9 * | 7,691.18 * | 1,325.2 * | 1,307.4 * | 9,979.08 * | 1,356.1 * |
| **YTD 14:** | 3,561.9 * | 7,691.18 * | 1,325.2 * | 1,307.4 * | 9,979.08 * | 1,356.1 * |

# Annual Fuel Use, NH3 Injection and Operating Hours

# Monthly Summary By Day Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 10:27 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

| Date/Time | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 GasFlowCT, 100scf 1 Hour(s) | Unit CT1 DBOn, Hr 1 Hour(s) | Unit CT1 GasFlowDB, 100scf 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtu 1 Hour(s) |
|---|---|---|---|---|---|---|---|
| 01/01/2014 | 11.10 | 174,055.7 | 5.18 | 12,950.7 | 187,006.4 | 1,587.7 | 19,259.732 |
| 01/02/2014 | 24.00 | 415,807.6 | 20.40 | 42,405.7 | 458,213.3 | 3,158.2 | 47,191.700 |
| 01/03/2014 | 24.00 | 396,587.0 | 18.92 | 40,781.5 | 437,368.5 | 3,051.0 | 45,044.700 |
| 01/04/2014 | 24.00 | 409,853.6 | 17.83 | 42,377.7 | 452,231.3 | 3,195.8 | 46,575.400 |
| 01/05/2014 | 24.00 | 414,662.5 | 18.57 | 52,295.5 | 466,958.0 | 3,395.8 | 48,091.900 |
| 01/06/2014 | 24.00 | 426,207.7 | 24.00 | 67,776.3 | 493,984.0 | 3,478.8 | 50,875.400 |
| 01/07/2014 | 24.00 | 411,960.4 | 19.15 | 44,780.2 | 456,740.6 | 3,194.5 | 47,039.700 |
| 01/08/2014 | 22.27 | 321,211.3 | 3.57 | 3,448.2 | 324,659.5 | 2,558.2 | 33,436.701 |
| 01/09/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/10/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/11/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/12/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/13/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/14/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/15/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/16/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/17/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/18/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/19/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/20/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/21/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/22/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/23/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/24/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/25/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/26/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/27/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/28/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/29/2014 | 9.83 | 138,098.4 | 0.00 | 0.0 | 138,098.4 | 1,169.9 | 14,222.653 |
| 01/30/2014 | 24.00 | 377,104.0 | 9.04 | 20,526.8 | 397,630.8 | 2,868.9 | 40,661.000 |
| 01/31/2014 | 24.00 | 407,128.2 | 13.66 | 22,323.8 | 429,452.0 | 2,974.4 | 43,914.800 |
| **Monthly Avg/Sum*:** | 235.20 * | 3,892,676.4 * | 150.32 * | 349,666.4 * | 4,242,342.8 * | 30,633.2 * | 436,313.686 * |
| **Daily Min:** | 9.83 | 138,098.4 | 0.00 | 0.0 | 138,098.4 | 1,169.9 | 14,222.653 |
| **Daily Max:** | 24.00 | 426,207.7 | 24.00 | 67,776.3 | 493,984.0 | 3,478.8 | 50,875.400 |
| **Jan 14 - Jan 14** | 235.20 | 3,892,676.4 | 150.32 | 349,666.4 | 4,242,342.8 | 30,633.2 | 436,313.686 |
| **QTD:** | 235.20 * | 3,892,676.4 * | 150.32 * | 349,666.4 * | 4,242,342.8 * | 30,633.2 * | 436,313.686 * |
| **YTD 14:** | 235.20 * | 3,892,676.4 * | 150.32 * | 349,666.4 * | 4,242,342.8 * | 30,633.2 * | 436,313.686 * |

# Monthly Summary By Day Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 10:27 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

| Date/Time | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 GasFlowCT, 100scf 1 Hour(s) | Unit CT1 DBOn, Hr 1 Hour(s) | Unit CT1 GasFlowDB, 100scf 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtu 1 Hour(s) |
|---|---|---|---|---|---|---|---|
| 02/01/2014 | 24.00 | 395,804.6 | 12.41 | 35,682.6 | 431,487.2 | 3,073.4 | 44,122.700 |
| 02/02/2014 | 24.00 | 432,589.2 | 24.00 | 70,883.6 | 503,472.8 | 3,457.3 | 51,484.000 |
| 02/03/2014 | 24.00 | 428,674.5 | 24.00 | 57,774.1 | 486,448.6 | 3,342.1 | 49,743.600 |
| 02/04/2014 | 24.00 | 427,273.7 | 24.00 | 46,984.4 | 474,258.1 | 3,218.2 | 48,496.500 |
| 02/05/2014 | 24.00 | 414,113.8 | 22.45 | 51,814.2 | 465,928.0 | 3,215.7 | 47,644.900 |
| 02/06/2014 | 24.00 | 406,620.3 | 24.00 | 31,243.0 | 437,863.3 | 2,913.1 | 44,775.200 |
| 02/07/2014 | 24.00 | 424,616.7 | 24.00 | 58,604.5 | 483,221.2 | 3,293.8 | 49,413.200 |
| 02/08/2014 | 24.00 | 411,359.0 | 24.00 | 28,957.7 | 440,316.7 | 2,904.8 | 45,025.800 |
| 02/09/2014 | 24.00 | 408,302.2 | 24.00 | 36,805.7 | 445,107.9 | 2,964.1 | 45,516.100 |
| 02/10/2014 | 24.00 | 387,800.4 | 18.53 | 24,581.1 | 412,381.5 | 2,795.0 | 42,169.200 |
| 02/11/2014 | 24.00 | 401,647.1 | 21.58 | 29,829.7 | 431,476.8 | 2,898.1 | 44,122.000 |
| 02/12/2014 | 24.00 | 416,243.9 | 24.00 | 43,415.1 | 459,659.0 | 3,082.2 | 47,004.000 |
| 02/13/2014 | 24.00 | 418,747.4 | 24.00 | 61,514.1 | 480,261.5 | 3,309.7 | 49,110.600 |
| 02/14/2014 | 24.00 | 413,508.4 | 23.83 | 56,999.2 | 470,507.6 | 3,238.4 | 48,113.100 |
| 02/15/2014 | 24.00 | 420,238.0 | 24.00 | 66,609.3 | 486,847.3 | 3,394.5 | 49,784.000 |
| 02/16/2014 | 24.00 | 405,756.8 | 21.13 | 30,172.4 | 435,929.2 | 2,999.1 | 44,577.300 |
| 02/17/2014 | 24.00 | 399,570.8 | 21.14 | 29,518.6 | 429,089.4 | 2,931.2 | 43,877.800 |
| 02/18/2014 | 24.00 | 409,043.2 | 23.52 | 42,144.3 | 451,187.5 | 3,122.1 | 46,137.700 |
| 02/19/2014 | 13.81 | 192,297.1 | 5.18 | 12,294.1 | 204,591.2 | 2,171.6 | 20,964.412 |
| 02/20/2014 | 24.00 | 389,405.2 | 18.78 | 48,073.4 | 437,478.6 | 3,279.1 | 44,828.500 |
| 02/21/2014 | 24.00 | 415,562.2 | 24.00 | 36,309.9 | 451,872.1 | 3,106.9 | 46,303.700 |
| 02/22/2014 | 24.00 | 411,342.3 | 24.00 | 52,324.3 | 463,666.6 | 3,329.4 | 47,512.100 |
| 02/23/2014 | 24.00 | 415,405.0 | 24.00 | 57,709.2 | 473,114.2 | 3,443.9 | 48,480.100 |
| 02/24/2014 | 24.00 | 398,637.0 | 21.16 | 41,172.7 | 439,809.7 | 3,152.4 | 45,067.400 |
| 02/25/2014 | 24.00 | 410,916.1 | 24.00 | 35,651.6 | 446,567.7 | 3,097.7 | 45,759.800 |
| 02/26/2014 | 24.00 | 416,688.0 | 24.00 | 70,074.7 | 486,762.7 | 3,459.7 | 49,878.400 |
| 02/27/2014 | 24.00 | 403,149.6 | 20.87 | 26,614.7 | 429,764.3 | 2,866.8 | 44,038.000 |
| 02/28/2014 | 24.00 | 412,677.4 | 24.00 | 46,501.4 | 459,178.8 | 3,087.5 | 47,052.000 |
| **Monthly Avg/Sum*:** | 661.81 * | 11,287,989.9 * | 614.58 * | 1,230,259.6 * | 12,518,249.5 * | 87,147.8 * | 1,281,002.112 * |
| **Daily Min:** | 13.81 | 192,297.1 | 5.18 | 12,294.1 | 204,591.2 | 2,171.6 | 20,964.412 |
| **Daily Max:** | 24.00 | 432,589.2 | 24.00 | 70,883.6 | 503,472.8 | 3,459.7 | 51,484.000 |
| **Jan 14 - Feb 14** | 897.01 | 15,180,666.3 | 764.90 | 1,579,926.0 | 16,760,592.3 | 117,781.0 | 1,717,315.798 |
| **QTD:** | 897.01 * | 15,180,666.3 * | 764.90 * | 1,579,926.0 * | 16,760,592.3 * | 117,781.0 * | 1,717,315.798 * |
| **YTD 14:** | 897.01 * | 15,180,666.3 * | 764.90 * | 1,579,926.0 * | 16,760,592.3 * | 117,781.0 * | 1,717,315.798 * |

# Monthly Summary By Day Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 10:27 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

| Date/Time | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 GasFlowCT, 100scf 1 Hour(s) | Unit CT1 DBOn, Hr 1 Hour(s) | Unit CT1 GasFlowDB, 100scf 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT1 HI, MBtu 1 Hour(s) |
|---|---|---|---|---|---|---|---|
| 03/01/2014 | 24.00 | 406,720.8 | 24.00 | 33,017.1 | 439,737.9 | 2,905.4 | 45,060.000 |
| 03/02/2014 | 24.00 | 421,261.5 | 24.00 | 57,142.4 | 478,403.9 | 3,224.2 | 49,021.700 |
| 03/03/2014 | 24.00 | 395,241.6 | 19.00 | 40,351.5 | 435,593.1 | 2,971.5 | 44,635.200 |
| 03/04/2014 | 24.00 | 363,654.1 | 12.97 | 17,360.7 | 381,014.8 | 2,633.5 | 39,042.500 |
| 03/05/2014 | 24.00 | 413,412.1 | 24.00 | 33,211.5 | 446,623.6 | 2,921.8 | 45,765.500 |
| 03/06/2014 | 3.23 | 46,860.1 | 1.88 | 2,086.4 | 48,946.5 | 555.2 | 5,015.459 |
| 03/07/2014 | 20.62 | 319,466.6 | 13.87 | 30,427.2 | 349,893.8 | 2,753.8 | 35,853.624 |
| 03/08/2014 | 24.00 | 412,180.2 | 24.00 | 46,008.5 | 458,188.7 | 3,078.8 | 46,950.700 |
| 03/09/2014 | 15.03 | 230,296.0 | 7.79 | 25,914.6 | 256,210.6 | 2,335.3 | 26,253.946 |
| 03/10/2014 | 23.23 | 367,828.5 | 17.16 | 28,599.0 | 396,427.5 | 2,949.2 | 40,621.889 |
| 03/11/2014 | 21.60 | 322,360.0 | 10.05 | 17,720.9 | 340,080.9 | 2,861.4 | 34,848.100 |
| 03/12/2014 | 24.00 | 364,479.3 | 13.33 | 29,917.6 | 394,396.9 | 2,836.4 | 40,413.700 |
| 03/13/2014 | 22.07 | 369,355.3 | 16.81 | 24,044.8 | 393,400.1 | 2,736.9 | 40,311.681 |
| 03/14/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/15/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/16/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/17/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/18/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/19/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/20/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/21/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/22/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/23/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/24/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/25/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/26/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/27/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/28/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/29/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/30/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/31/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| **Monthly Avg/Sum*:** | 273.78 * | 4,433,116.1 * | 208.86 * | 385,802.2 * | 4,818,918.3 * | 34,763.4 * | 493,793.999 * |
| **Daily Min:** | 3.23 | 46,860.1 | 1.88 | 2,086.4 | 48,946.5 | 555.2 | 5,015.459 |
| **Daily Max:** | 24.00 | 421,261.5 | 24.00 | 57,142.4 | 478,403.9 | 3,224.2 | 49,021.700 |
| **Jan 14 - Mar 14** | 1,170.79 | 19,613,782.4 | 973.76 | 1,965,728.2 | 21,579,510.6 | 152,544.4 | 2,211,109.797 |
| **QTD:** | 1,170.79 * | 19,613,782.4 * | 973.76 * | 1,965,728.2 * | 21,579,510.6 * | 152,544.4 * | 2,211,109.797 * |
| **YTD 14:** | 1,170.79 * | 19,613,782.4 * | 973.76 * | 1,965,728.2 * | 21,579,510.6 * | 152,544.4 * | 2,211,109.797 * |

# Monthly Summary By Day Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 10:28 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

| Date/Time | Unit CT2 OperatingTime, Hr | Unit CT2 GasFlowCT, 100scf | Unit CT2 DBOn, Hr | Unit CT2 GasFlowDB, 100scf | Unit CT2 GasFlow, Total, 100scf | Unit CT2 NH3, Inj, LbPerHr | Unit CT2 HI, MBtu |
|---|---|---|---|---|---|---|---|
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 01/01/2014 | 14.22 | 221,296.3 | 5.13 | 15,081.9 | 236,378.2 | 1,785.0 | 24,344.415 |
| 01/02/2014 | 24.00 | 415,191.0 | 20.35 | 50,372.2 | 465,563.2 | 3,028.7 | 47,948.200 |
| 01/03/2014 | 24.00 | 395,947.0 | 18.95 | 47,562.5 | 443,509.5 | 2,897.7 | 45,677.000 |
| 01/04/2014 | 24.00 | 408,226.2 | 17.86 | 48,309.3 | 456,535.5 | 3,083.5 | 47,018.400 |
| 01/05/2014 | 24.00 | 412,859.1 | 18.53 | 58,482.9 | 471,342.0 | 3,438.1 | 48,543.300 |
| 01/06/2014 | 24.00 | 425,801.0 | 24.00 | 77,876.4 | 503,677.4 | 3,614.8 | 51,873.600 |
| 01/07/2014 | 24.00 | 412,142.5 | 19.20 | 52,647.0 | 464,789.5 | 3,171.1 | 47,868.800 |
| 01/08/2014 | 22.28 | 322,737.0 | 3.57 | 4,357.5 | 327,094.5 | 2,311.9 | 33,687.464 |
| 01/09/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/10/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/11/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/12/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/13/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/14/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/15/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/16/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/17/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/18/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/19/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/20/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/21/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/22/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/23/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/24/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/25/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/26/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/27/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/28/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 01/29/2014 | 15.63 | 211,540.6 | 0.00 | 0.0 | 211,540.6 | 1,927.6 | 21,786.620 |
| 01/30/2014 | 24.00 | 376,769.3 | 10.60 | 27,243.0 | 404,012.3 | 2,618.8 | 41,313.200 |
| 01/31/2014 | 24.00 | 408,271.4 | 17.87 | 33,141.6 | 441,413.0 | 2,806.3 | 45,137.900 |
| **Monthly Avg/Sum*:** | 244.13 * | 4,010,781.4 * | 156.06 * | 415,074.3 * | 4,425,855.7 * | 30,683.5 * | 455,198.899 * |
| **Daily Min:** | 14.22 | 211,540.6 | 0.00 | 0.0 | 211,540.6 | 1,785.0 | 21,786.620 |
| **Daily Max:** | 24.00 | 425,801.0 | 24.00 | 77,876.4 | 503,677.4 | 3,614.8 | 51,873.600 |
| **Jan 14 - Jan 14** | 244.13 | 4,010,781.4 | 156.06 | 415,074.3 | 4,425,855.7 | 30,683.5 | 455,198.899 |
| **QTD:** | 244.13 * | 4,010,781.4 * | 156.06 * | 415,074.3 * | 4,425,855.7 * | 30,683.5 * | 455,198.899 * |
| **YTD 14:** | 244.13 * | 4,010,781.4 * | 156.06 * | 415,074.3 * | 4,425,855.7 * | 30,683.5 * | 455,198.899 * |

# Monthly Summary By Day Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 10:28 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

| Date/Time | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 GasFlowCT, 100scf 1 Hour(s) | Unit CT2 DBOn, Hr 1 Hour(s) | Unit CT2 GasFlowDB, 100scf 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtu 1 Hour(s) |
|---|---|---|---|---|---|---|---|
| 02/01/2014 | 24.00 | 396,877.7 | 12.37 | 39,700.2 | 436,577.9 | 2,894.2 | 44,643.600 |
| 02/02/2014 | 24.00 | 432,867.7 | 24.00 | 79,714.2 | 512,581.9 | 3,335.3 | 52,415.300 |
| 02/03/2014 | 24.00 | 430,059.9 | 24.00 | 66,453.8 | 496,513.7 | 3,185.3 | 50,772.400 |
| 02/04/2014 | 24.00 | 428,136.0 | 24.00 | 55,807.5 | 483,943.5 | 3,063.7 | 49,487.000 |
| 02/05/2014 | 24.00 | 415,955.6 | 22.43 | 58,134.2 | 474,089.8 | 3,073.8 | 48,479.500 |
| 02/06/2014 | 24.00 | 409,302.6 | 24.00 | 38,576.1 | 447,878.7 | 2,617.5 | 45,799.000 |
| 02/07/2014 | 24.00 | 426,582.4 | 23.97 | 64,228.8 | 490,811.2 | 2,940.6 | 50,189.300 |
| 02/08/2014 | 24.00 | 414,114.4 | 23.92 | 36,703.0 | 450,817.4 | 2,568.9 | 46,099.600 |
| 02/09/2014 | 24.00 | 409,825.2 | 24.00 | 44,397.2 | 454,222.4 | 2,626.4 | 46,447.800 |
| 02/10/2014 | 24.00 | 388,525.5 | 18.49 | 30,920.8 | 419,446.3 | 2,441.2 | 42,892.000 |
| 02/11/2014 | 24.00 | 402,823.9 | 21.58 | 36,665.5 | 439,489.4 | 2,560.3 | 44,941.700 |
| 02/12/2014 | 24.00 | 417,150.5 | 24.00 | 53,471.4 | 470,621.9 | 2,797.4 | 48,124.800 |
| 02/13/2014 | 24.00 | 418,207.6 | 24.00 | 71,002.6 | 489,210.2 | 3,109.0 | 50,025.900 |
| 02/14/2014 | 24.00 | 413,689.6 | 24.00 | 65,551.7 | 479,241.3 | 2,967.9 | 49,006.000 |
| 02/15/2014 | 24.00 | 420,294.3 | 24.00 | 73,307.5 | 493,601.8 | 3,152.5 | 50,474.600 |
| 02/16/2014 | 24.00 | 405,835.5 | 21.15 | 37,405.7 | 443,241.2 | 2,807.9 | 45,324.800 |
| 02/17/2014 | 24.00 | 400,623.4 | 16.91 | 29,723.9 | 430,347.3 | 2,674.0 | 44,006.500 |
| 02/18/2014 | 24.00 | 409,850.7 | 23.53 | 50,999.9 | 460,850.6 | 2,995.5 | 47,125.700 |
| 02/19/2014 | 9.00 | 133,203.8 | 5.13 | 15,153.8 | 148,357.6 | 1,349.9 | 15,202.285 |
| 02/20/2014 | 24.00 | 388,647.7 | 18.68 | 50,102.1 | 438,749.8 | 3,242.3 | 44,958.600 |
| 02/21/2014 | 24.00 | 413,845.5 | 24.00 | 40,988.8 | 454,834.3 | 3,112.9 | 46,606.800 |
| 02/22/2014 | 24.00 | 409,994.9 | 24.00 | 57,925.9 | 467,920.8 | 3,349.8 | 47,947.800 |
| 02/23/2014 | 24.00 | 414,098.4 | 24.00 | 61,444.2 | 475,542.6 | 3,471.2 | 48,728.800 |
| 02/24/2014 | 24.00 | 397,819.6 | 21.23 | 46,859.9 | 444,679.5 | 3,184.8 | 45,566.300 |
| 02/25/2014 | 24.00 | 411,129.0 | 24.00 | 41,699.7 | 452,828.7 | 2,895.9 | 46,401.300 |
| 02/26/2014 | 24.00 | 417,437.6 | 23.80 | 71,469.0 | 488,906.6 | 3,374.7 | 50,098.100 |
| 02/27/2014 | 24.00 | 404,163.4 | 20.82 | 33,240.5 | 437,403.9 | 2,595.6 | 44,820.800 |
| 02/28/2014 | 24.00 | 413,825.6 | 24.00 | 56,415.0 | 470,240.6 | 2,810.5 | 48,185.300 |
| **Monthly Avg/Sum*:** | 657.00 * | 11,244,888.0 * | 610.01 * | 1,408,062.9 * | 12,652,950.9 * | 81,199.0 * | 1,294,771.585 * |
| **Daily Min:** | 9.00 | 133,203.8 | 5.13 | 15,153.8 | 148,357.6 | 1,349.9 | 15,202.285 |
| **Daily Max:** | 24.00 | 432,867.7 | 24.00 | 79,714.2 | 512,581.9 | 3,471.2 | 52,415.300 |
| **Jan 14 - Feb 14** | 901.13 | 15,255,669.4 | 766.07 | 1,823,137.2 | 17,078,806.6 | 111,882.5 | 1,749,970.484 |
| **QTD:** | 901.13 * | 15,255,669.4 * | 766.07 * | 1,823,137.2 * | 17,078,806.6 * | 111,882.5 * | 1,749,970.484 * |
| **YTD 14:** | 901.13 * | 15,255,669.4 * | 766.07 * | 1,823,137.2 * | 17,078,806.6 * | 111,882.5 * | 1,749,970.484 * |

# Monthly Summary By Day Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 10:28 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

| Date/Time | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 GasFlowCT, 100scf 1 Hour(s) | Unit CT2 DBOn, Hr 1 Hour(s) | Unit CT2 GasFlowDB, 100scf 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 NH3, Inj, LbPerHr 1 Hour(s) | Unit CT2 HI, MBtu 1 Hour(s) |
|---|---|---|---|---|---|---|---|
| 03/01/2014 | 24.00 | 408,036.5 | 24.00 | 41,613.4 | 449,649.9 | 2,634.4 | 46,075.900 |
| 03/02/2014 | 24.00 | 422,022.2 | 24.00 | 67,100.5 | 489,122.7 | 3,061.8 | 50,120.500 |
| 03/03/2014 | 24.00 | 397,230.3 | 18.98 | 45,187.3 | 442,417.6 | 2,872.7 | 45,334.500 |
| 03/04/2014 | 24.00 | 364,266.2 | 12.87 | 20,885.6 | 385,151.8 | 2,407.8 | 39,466.400 |
| 03/05/2014 | 24.00 | 414,081.0 | 24.00 | 41,577.0 | 455,658.0 | 2,693.4 | 46,690.900 |
| 03/06/2014 | 3.25 | 47,257.5 | 1.88 | 2,698.0 | 49,955.5 | 483.1 | 5,118.975 |
| 03/07/2014 | 16.63 | 267,966.4 | 13.83 | 35,961.7 | 303,928.1 | 2,104.8 | 31,143.679 |
| 03/08/2014 | 24.00 | 412,747.7 | 24.00 | 56,237.7 | 468,985.4 | 3,007.2 | 48,057.000 |
| 03/09/2014 | 11.01 | 172,095.2 | 6.00 | 21,238.1 | 193,333.3 | 1,588.1 | 19,810.930 |
| 03/10/2014 | 23.23 | 368,482.3 | 13.48 | 23,033.3 | 391,515.6 | 2,624.5 | 40,118.562 |
| 03/11/2014 | 18.32 | 278,014.6 | 9.78 | 20,223.8 | 298,238.4 | 2,209.5 | 30,560.504 |
| 03/12/2014 | 24.00 | 365,032.6 | 13.33 | 33,427.2 | 398,459.8 | 2,732.1 | 40,830.400 |
| 03/13/2014 | 24.00 | 399,765.6 | 16.83 | 30,257.9 | 430,023.5 | 2,711.9 | 44,064.400 |
| 03/14/2014 | 18.95 | 312,443.6 | 0.00 | 0.0 | 312,443.6 | 2,158.5 | 32,128.617 |
| 03/15/2014 | 0.25 | 1,615.6 | 0.00 | 0.0 | 1,615.6 | 207.3 | 166.125 |
| 03/16/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/17/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/18/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/19/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/20/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/21/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/22/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/23/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/24/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/25/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/26/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/27/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/28/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/29/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/30/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| 03/31/2014 | 0.00 | 0.0 | 0.00 | 0.0 | 0.0 | 0.0 | 0.000 |
| **Monthly Avg/Sum*:** | 283.64 * | 4,631,057.3 * | 202.98 * | 439,441.5 * | 5,070,498.8 * | 33,497.1 * | 519,687.392 * |
| **Daily Min:** | 0.25 | 1,615.6 | 0.00 | 0.0 | 1,615.6 | 207.3 | 166.125 |
| **Daily Max:** | 24.00 | 422,022.2 | 24.00 | 67,100.5 | 489,122.7 | 3,061.8 | 50,120.500 |
| **Jan 14 - Mar 14** | 1,184.77 | 19,886,726.7 | 969.05 | 2,262,578.7 | 22,149,305.4 | 145,379.6 | 2,269,657.876 |
| **QTD:** | 1,184.77 * | 19,886,726.7 * | 969.05 * | 2,262,578.7 * | 22,149,305.4 * | 145,379.6 * | 2,269,657.876 * |
| **YTD 14:** | 1,184.77 * | 19,886,726.7 * | 969.05 * | 2,262,578.7 * | 22,149,305.4 * | 145,379.6 * | 2,269,657.876 * |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/01/2014 00:00 | 15,792.3 | 0.0 | 15,792.3 | 15,792.3 | 102,990.1 | 1,626.5 | 1.00 | 1 |
| 01/01/2014 01:00 | 17,613.1 | 0.0 | 17,613.1 | 17,613.1 | 102,990.1 | 1,814.0 | 1.00 | 1 |
| 01/01/2014 02:00 | 16,422.2 | 0.0 | 16,422.2 | 16,422.2 | 102,990.1 | 1,691.3 | 1.00 | 1 |
| 01/01/2014 03:00 | 10,679.5 | 0.0 | 10,679.5 | 5,126.2 | 102,990.1 | 1,099.9 | 0.48 | 0 |
| 01/01/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 16:00 | 4,845.5 | 0.0 | 4,845.5 | 3,004.2 | 102,990.1 | 499.0 | 0.62 | 0 |
| 01/01/2014 17:00 | 10,241.0 | 0.0 | 10,241.0 | 10,241.0 | 102,990.1 | 1,054.7 | 1.00 | 0 |
| 01/01/2014 18:00 | 17,124.3 | 241.5 | 17,167.8 | 17,167.8 | 102,990.1 | 1,768.1 | 1.00 | 1 |
| 01/01/2014 19:00 | 17,669.8 | 2,260.7 | 19,930.5 | 19,930.5 | 102,990.1 | 2,052.6 | 1.00 | 1 |
| 01/01/2014 20:00 | 17,707.7 | 2,991.5 | 20,699.2 | 20,699.2 | 102,990.1 | 2,131.8 | 1.00 | 1 |
| 01/01/2014 21:00 | 17,782.8 | 3,123.8 | 20,906.6 | 20,906.6 | 102,990.1 | 2,153.2 | 1.00 | 1 |
| 01/01/2014 22:00 | 17,767.8 | 2,269.4 | 20,037.2 | 20,037.2 | 102,990.1 | 2,063.6 | 1.00 | 1 |
| 01/01/2014 23:00 | 17,804.3 | 2,261.8 | 20,066.1 | 20,066.1 | 102,990.1 | 2,066.6 | 1.00 | 1 |
| **Average/Sum#:** | 15,120.9 | 1,095.7 | 16,200.1 | 187,006.4 # | 102,990.1 | 1,668.4 | 11.10 # | 9 # |
| **Minimum:** | 4,845.5 | 0.0 | 4,845.5 | 3,004.2 | 102,990.1 | 499.0 | 0.00 | 0 |
| **Maximum:** | 17,804.3 | 3,123.8 | 20,906.6 | 20,906.6 | 102,990.1 | 2,153.2 | 1.00 | 1 |
| **%SI** | 50.0 | 50.0 | 50.0 | 50.0 | 0.0 | 50.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/02/2014 00:00 | 17,807.5 | 2,035.4 | 19,842.9 | 19,842.9 | 102,990.1 | 2,043.6 | 1.00 | 1 |
| 01/02/2014 01:00 | 17,385.4 | 651.4 | 17,854.4 | 17,854.4 | 102,990.1 | 1,838.8 | 1.00 | 1 |
| 01/02/2014 02:00 | 15,412.5 | 0.0 | 15,412.5 | 15,412.5 | 102,990.1 | 1,587.3 | 1.00 | 1 |
| 01/02/2014 03:00 | 16,630.8 | 0.0 | 16,630.8 | 16,630.8 | 102,990.1 | 1,712.8 | 1.00 | 1 |
| 01/02/2014 04:00 | 15,457.5 | 0.0 | 15,457.5 | 15,457.5 | 102,990.1 | 1,592.0 | 1.00 | 1 |
| 01/02/2014 05:00 | 16,948.1 | 787.7 | 17,483.7 | 17,483.7 | 102,990.1 | 1,800.6 | 1.00 | 1 |
| 01/02/2014 06:00 | 17,679.7 | 1,552.9 | 19,232.6 | 19,232.6 | 102,990.1 | 1,980.8 | 1.00 | 1 |
| 01/02/2014 07:00 | 17,708.9 | 1,451.8 | 19,160.7 | 19,160.7 | 102,990.1 | 1,973.4 | 1.00 | 1 |
| 01/02/2014 08:00 | 17,782.8 | 1,721.0 | 19,503.8 | 19,503.8 | 102,990.1 | 2,008.7 | 1.00 | 1 |
| 01/02/2014 09:00 | 17,849.7 | 1,766.4 | 19,616.1 | 19,616.1 | 102,990.1 | 2,020.3 | 1.00 | 1 |
| 01/02/2014 10:00 | 17,801.9 | 1,743.4 | 19,545.3 | 19,545.3 | 102,990.1 | 2,013.0 | 1.00 | 1 |
| 01/02/2014 11:00 | 17,657.7 | 1,879.0 | 19,536.7 | 19,536.7 | 102,990.1 | 2,012.1 | 1.00 | 1 |
| 01/02/2014 12:00 | 17,535.3 | 1,893.5 | 19,428.8 | 19,428.8 | 102,990.1 | 2,001.0 | 1.00 | 1 |
| 01/02/2014 13:00 | 17,440.2 | 1,891.4 | 19,331.6 | 19,331.6 | 102,990.1 | 1,991.0 | 1.00 | 1 |
| 01/02/2014 14:00 | 17,344.9 | 1,651.8 | 18,996.7 | 18,996.7 | 102,990.1 | 1,956.5 | 1.00 | 1 |
| 01/02/2014 15:00 | 17,358.3 | 1,958.7 | 19,317.0 | 19,317.0 | 102,990.1 | 1,989.5 | 1.00 | 1 |
| 01/02/2014 16:00 | 17,338.9 | 2,146.5 | 19,485.4 | 19,485.4 | 102,990.1 | 2,006.8 | 1.00 | 1 |
| 01/02/2014 17:00 | 17,363.3 | 2,213.7 | 19,577.0 | 19,577.0 | 102,990.1 | 2,016.2 | 1.00 | 1 |
| 01/02/2014 18:00 | 17,433.4 | 3,092.5 | 20,525.9 | 20,525.9 | 102,990.1 | 2,114.0 | 1.00 | 1 |
| 01/02/2014 19:00 | 17,454.6 | 3,297.1 | 20,751.7 | 20,751.7 | 102,990.1 | 2,137.2 | 1.00 | 1 |
| 01/02/2014 20:00 | 17,460.4 | 3,094.5 | 20,554.9 | 20,554.9 | 102,990.1 | 2,117.0 | 1.00 | 1 |
| 01/02/2014 21:00 | 17,545.1 | 2,907.0 | 20,452.1 | 20,452.1 | 102,990.1 | 2,106.4 | 1.00 | 1 |
| 01/02/2014 22:00 | 17,719.1 | 2,241.9 | 19,961.0 | 19,961.0 | 102,990.1 | 2,055.8 | 1.00 | 1 |
| 01/02/2014 23:00 | 17,691.6 | 2,862.6 | 20,554.2 | 20,554.2 | 102,990.1 | 2,116.9 | 1.00 | 1 |
| **Average/Sum#:** | 17,325.3 | 1,785.0 | 19,092.2 | 458,213.3 # | 102,990.1 | 1,966.3 | 24.00 # | 24 # |
| **Minimum:** | 15,412.5 | 0.0 | 15,412.5 | 15,412.5 | 102,990.1 | 1,587.3 | 1.00 | 1 |
| **Maximum:** | 17,849.7 | 3,297.1 | 20,751.7 | 20,751.7 | 102,990.1 | 2,137.2 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/03/2014 00:00 | 17,690.8 | 1,806.9 | 19,497.7 | 19,497.7 | 102,990.1 | 2,008.1 | 1.00 | 1 |
| 01/03/2014 01:00 | 16,770.3 | 432.6 | 16,965.0 | 16,965.0 | 102,990.1 | 1,747.2 | 1.00 | 1 |
| 01/03/2014 02:00 | 12,803.0 | 0.0 | 12,803.0 | 12,803.0 | 102,990.1 | 1,318.6 | 1.00 | 1 |
| 01/03/2014 03:00 | 12,072.7 | 0.0 | 12,072.7 | 12,072.7 | 102,990.1 | 1,243.4 | 1.00 | 1 |
| 01/03/2014 04:00 | 12,079.3 | 0.0 | 12,079.3 | 12,079.3 | 102,990.1 | 1,244.0 | 1.00 | 1 |
| 01/03/2014 05:00 | 12,104.5 | 0.0 | 12,104.5 | 12,104.5 | 102,990.1 | 1,246.6 | 1.00 | 1 |
| 01/03/2014 06:00 | 14,784.7 | 541.3 | 15,039.1 | 15,039.1 | 102,990.1 | 1,548.9 | 1.00 | 1 |
| 01/03/2014 07:00 | 17,186.6 | 1,231.7 | 18,418.3 | 18,418.3 | 102,990.1 | 1,896.9 | 1.00 | 1 |
| 01/03/2014 08:00 | 17,912.6 | 1,308.8 | 19,221.4 | 19,221.4 | 102,990.1 | 1,979.6 | 1.00 | 1 |
| 01/03/2014 09:00 | 18,048.5 | 1,638.0 | 19,686.5 | 19,686.5 | 102,990.1 | 2,027.5 | 1.00 | 1 |
| 01/03/2014 10:00 | 17,801.7 | 1,880.3 | 19,682.0 | 19,682.0 | 102,990.1 | 2,027.1 | 1.00 | 1 |
| 01/03/2014 11:00 | 17,712.4 | 1,864.4 | 19,576.8 | 19,576.8 | 102,990.1 | 2,016.2 | 1.00 | 1 |
| 01/03/2014 12:00 | 17,634.7 | 1,671.1 | 19,305.8 | 19,305.8 | 102,990.1 | 1,988.3 | 1.00 | 1 |
| 01/03/2014 13:00 | 17,511.6 | 1,671.7 | 19,183.3 | 19,183.3 | 102,990.1 | 1,975.7 | 1.00 | 1 |
| 01/03/2014 14:00 | 17,424.1 | 1,649.5 | 19,073.6 | 19,073.6 | 102,990.1 | 1,964.4 | 1.00 | 1 |
| 01/03/2014 15:00 | 17,331.0 | 1,453.4 | 18,784.4 | 18,784.4 | 102,990.1 | 1,934.6 | 1.00 | 1 |
| 01/03/2014 16:00 | 17,391.7 | 1,881.6 | 19,273.3 | 19,273.3 | 102,990.1 | 1,985.0 | 1.00 | 1 |
| 01/03/2014 17:00 | 17,348.7 | 2,535.0 | 19,883.7 | 19,883.7 | 102,990.1 | 2,047.8 | 1.00 | 1 |
| 01/03/2014 18:00 | 17,454.3 | 3,240.6 | 20,694.9 | 20,694.9 | 102,990.1 | 2,131.4 | 1.00 | 1 |
| 01/03/2014 19:00 | 17,464.5 | 2,815.7 | 20,280.2 | 20,280.2 | 102,990.1 | 2,088.7 | 1.00 | 1 |
| 01/03/2014 20:00 | 17,472.5 | 2,802.1 | 20,274.6 | 20,274.6 | 102,990.1 | 2,088.1 | 1.00 | 1 |
| 01/03/2014 21:00 | 17,488.5 | 4,062.2 | 21,550.7 | 21,550.7 | 102,990.1 | 2,219.5 | 1.00 | 1 |
| 01/03/2014 22:00 | 17,541.0 | 3,640.7 | 21,181.7 | 21,181.7 | 102,990.1 | 2,181.5 | 1.00 | 1 |
| 01/03/2014 23:00 | 17,557.3 | 3,178.7 | 20,736.0 | 20,736.0 | 102,990.1 | 2,135.6 | 1.00 | 1 |
| **Average/Sum#:** | 16,524.5 | 1,721.1 | 18,223.7 | 437,368.5 # | 102,990.1 | 1,876.9 | 24.00 # | 24 # |
| **Minimum:** | 12,072.7 | 0.0 | 12,072.7 | 12,072.7 | 102,990.1 | 1,243.4 | 1.00 | 1 |
| **Maximum:** | 18,048.5 | 4,062.2 | 21,550.7 | 21,550.7 | 102,990.1 | 2,219.5 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/04/2014 00:00 | 17,762.5 | 2,083.5 | 19,846.0 | 19,846.0 | 102,990.1 | 2,043.9 | 1.00 | 1 |
| 01/04/2014 01:00 | 17,716.7 | 2,338.9 | 20,055.6 | 20,055.6 | 102,990.1 | 2,065.5 | 1.00 | 1 |
| 01/04/2014 02:00 | 15,754.5 | 103.0 | 15,764.8 | 15,764.8 | 102,990.1 | 1,623.6 | 1.00 | 1 |
| 01/04/2014 03:00 | 15,496.3 | 0.0 | 15,496.3 | 15,496.3 | 102,990.1 | 1,596.0 | 1.00 | 1 |
| 01/04/2014 04:00 | 13,827.3 | 0.0 | 13,827.3 | 13,827.3 | 102,990.1 | 1,424.1 | 1.00 | 1 |
| 01/04/2014 05:00 | 16,061.8 | 0.0 | 16,061.8 | 16,061.8 | 102,990.1 | 1,654.2 | 1.00 | 1 |
| 01/04/2014 06:00 | 16,240.2 | 0.0 | 16,240.2 | 16,240.2 | 102,990.1 | 1,672.6 | 1.00 | 1 |
| 01/04/2014 07:00 | 17,726.1 | 0.0 | 17,726.1 | 17,726.1 | 102,990.1 | 1,825.6 | 1.00 | 1 |
| 01/04/2014 08:00 | 17,623.8 | 1,196.1 | 18,497.0 | 18,497.0 | 102,990.1 | 1,905.0 | 1.00 | 1 |
| 01/04/2014 09:00 | 17,747.6 | 2,676.7 | 20,424.3 | 20,424.3 | 102,990.1 | 2,103.5 | 1.00 | 1 |
| 01/04/2014 10:00 | 17,579.8 | 2,163.6 | 19,743.4 | 19,743.4 | 102,990.1 | 2,033.4 | 1.00 | 1 |
| 01/04/2014 11:00 | 17,486.0 | 1,669.4 | 19,155.4 | 19,155.4 | 102,990.1 | 1,972.8 | 1.00 | 1 |
| 01/04/2014 12:00 | 17,285.4 | 1,181.6 | 18,467.0 | 18,467.0 | 102,990.1 | 1,901.9 | 1.00 | 1 |
| 01/04/2014 13:00 | 16,878.6 | 1,148.4 | 18,027.0 | 18,027.0 | 102,990.1 | 1,856.6 | 1.00 | 1 |
| 01/04/2014 14:00 | 17,355.2 | 1,831.5 | 19,186.7 | 19,186.7 | 102,990.1 | 1,976.0 | 1.00 | 1 |
| 01/04/2014 15:00 | 17,340.1 | 2,244.8 | 19,584.9 | 19,584.9 | 102,990.1 | 2,017.1 | 1.00 | 1 |
| 01/04/2014 16:00 | 17,349.3 | 2,450.5 | 19,799.8 | 19,799.8 | 102,990.1 | 2,039.2 | 1.00 | 1 |
| 01/04/2014 17:00 | 17,457.5 | 2,751.4 | 20,208.9 | 20,208.9 | 102,990.1 | 2,081.3 | 1.00 | 1 |
| 01/04/2014 18:00 | 17,543.8 | 3,203.3 | 20,747.1 | 20,747.1 | 102,990.1 | 2,136.7 | 1.00 | 1 |
| 01/04/2014 19:00 | 17,535.0 | 3,233.7 | 20,768.7 | 20,768.7 | 102,990.1 | 2,139.0 | 1.00 | 1 |
| 01/04/2014 20:00 | 17,578.9 | 2,295.7 | 19,874.6 | 19,874.6 | 102,990.1 | 2,046.9 | 1.00 | 1 |
| 01/04/2014 21:00 | 17,553.2 | 3,797.0 | 21,350.2 | 21,350.2 | 102,990.1 | 2,198.9 | 1.00 | 1 |
| 01/04/2014 22:00 | 17,463.3 | 4,070.5 | 21,533.8 | 21,533.8 | 102,990.1 | 2,217.8 | 1.00 | 1 |
| 01/04/2014 23:00 | 17,490.7 | 2,353.7 | 19,844.4 | 19,844.4 | 102,990.1 | 2,043.8 | 1.00 | 1 |
| **Average/Sum#:** | 17,077.2 | 1,783.1 | 18,843.0 | 452,231.3 # | 102,990.1 | 1,940.6 | 24.00 # | 24 # |
| **Minimum:** | 13,827.3 | 0.0 | 13,827.3 | 13,827.3 | 102,990.1 | 1,424.1 | 1.00 | 1 |
| **Maximum:** | 17,762.5 | 4,070.5 | 21,533.8 | 21,533.8 | 102,990.1 | 2,217.8 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/05/2014 00:00 | 17,554.9 | 2,125.5 | 19,680.4 | 19,680.4 | 102,990.1 | 2,026.9 | 1.00 | 1 |
| 01/05/2014 01:00 | 17,577.2 | 2,490.9 | 20,068.1 | 20,068.1 | 102,990.1 | 2,066.8 | 1.00 | 1 |
| 01/05/2014 02:00 | 15,677.0 | 126.5 | 15,692.2 | 15,692.2 | 102,990.1 | 1,616.1 | 1.00 | 1 |
| 01/05/2014 03:00 | 15,504.6 | 0.0 | 15,504.6 | 15,504.6 | 102,990.1 | 1,596.8 | 1.00 | 1 |
| 01/05/2014 04:00 | 16,505.9 | 0.0 | 16,505.9 | 16,505.9 | 102,990.1 | 1,699.9 | 1.00 | 1 |
| 01/05/2014 05:00 | 17,741.8 | 0.0 | 17,741.8 | 17,741.8 | 102,990.1 | 1,827.2 | 1.00 | 1 |
| 01/05/2014 06:00 | 17,716.7 | 1,038.4 | 18,391.7 | 18,391.7 | 102,990.1 | 1,894.2 | 1.00 | 1 |
| 01/05/2014 07:00 | 17,751.7 | 2,538.8 | 20,290.5 | 20,290.5 | 102,990.1 | 2,089.7 | 1.00 | 1 |
| 01/05/2014 08:00 | 17,730.8 | 3,993.6 | 21,724.4 | 21,724.4 | 102,990.1 | 2,237.4 | 1.00 | 1 |
| 01/05/2014 09:00 | 17,687.4 | 3,596.6 | 21,284.0 | 21,284.0 | 102,990.1 | 2,192.0 | 1.00 | 1 |
| 01/05/2014 10:00 | 17,584.3 | 2,377.8 | 19,962.1 | 19,962.1 | 102,990.1 | 2,055.9 | 1.00 | 1 |
| 01/05/2014 11:00 | 17,530.4 | 1,711.7 | 19,242.1 | 19,242.1 | 102,990.1 | 1,981.7 | 1.00 | 1 |
| 01/05/2014 12:00 | 17,298.0 | 1,209.3 | 18,507.3 | 18,507.3 | 102,990.1 | 1,906.1 | 1.00 | 1 |
| 01/05/2014 13:00 | 17,473.8 | 1,385.6 | 18,859.4 | 18,859.4 | 102,990.1 | 1,942.3 | 1.00 | 1 |
| 01/05/2014 14:00 | 17,445.3 | 2,036.8 | 19,482.1 | 19,482.1 | 102,990.1 | 2,006.5 | 1.00 | 1 |
| 01/05/2014 15:00 | 15,854.8 | 70.7 | 15,859.7 | 15,859.7 | 102,990.1 | 1,633.4 | 1.00 | 1 |
| 01/05/2014 16:00 | 17,248.6 | 1,375.8 | 18,252.9 | 18,252.9 | 102,990.1 | 1,879.9 | 1.00 | 1 |
| 01/05/2014 17:00 | 17,434.8 | 3,641.1 | 21,075.9 | 21,075.9 | 102,990.1 | 2,170.6 | 1.00 | 1 |
| 01/05/2014 18:00 | 17,479.5 | 4,010.8 | 21,490.3 | 21,490.3 | 102,990.1 | 2,213.3 | 1.00 | 1 |
| 01/05/2014 19:00 | 17,403.9 | 4,092.9 | 21,496.8 | 21,496.8 | 102,990.1 | 2,214.0 | 1.00 | 1 |
| 01/05/2014 20:00 | 17,467.9 | 4,130.3 | 21,598.2 | 21,598.2 | 102,990.1 | 2,224.4 | 1.00 | 1 |
| 01/05/2014 21:00 | 17,555.4 | 3,976.0 | 21,531.4 | 21,531.4 | 102,990.1 | 2,217.5 | 1.00 | 1 |
| 01/05/2014 22:00 | 17,675.1 | 3,955.2 | 21,630.3 | 21,630.3 | 102,990.1 | 2,227.7 | 1.00 | 1 |
| 01/05/2014 23:00 | 17,762.7 | 3,323.2 | 21,085.9 | 21,085.9 | 102,990.1 | 2,171.6 | 1.00 | 1 |
| **Average/Sum#:** | 17,277.6 | 2,217.0 | 19,456.6 | 466,958.0 # | 102,990.1 | 2,003.8 | 24.00 # | 24 # |
| **Minimum:** | 15,504.6 | 0.0 | 15,504.6 | 15,504.6 | 102,990.1 | 1,596.8 | 1.00 | 1 |
| **Maximum:** | 17,762.7 | 4,130.3 | 21,724.4 | 21,724.4 | 102,990.1 | 2,237.4 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/06/2014 00:00 | 17,710.3 | 3,286.4 | 20,996.7 | 20,996.7 | 102,990.1 | 2,162.5 | 1.00 | 1 |
| 01/06/2014 01:00 | 17,785.9 | 2,492.2 | 20,278.1 | 20,278.1 | 102,990.1 | 2,088.4 | 1.00 | 1 |
| 01/06/2014 02:00 | 17,761.9 | 2,867.9 | 20,629.8 | 20,629.8 | 102,990.1 | 2,124.7 | 1.00 | 1 |
| 01/06/2014 03:00 | 17,792.4 | 1,718.2 | 19,510.6 | 19,510.6 | 102,990.1 | 2,009.4 | 1.00 | 1 |
| 01/06/2014 04:00 | 17,818.3 | 1,595.4 | 19,413.7 | 19,413.7 | 102,990.1 | 1,999.4 | 1.00 | 1 |
| 01/06/2014 05:00 | 17,787.0 | 3,161.7 | 20,948.7 | 20,948.7 | 102,990.1 | 2,157.5 | 1.00 | 1 |
| 01/06/2014 06:00 | 17,817.8 | 2,217.4 | 20,035.2 | 20,035.2 | 102,990.1 | 2,063.4 | 1.00 | 1 |
| 01/06/2014 07:00 | 17,757.8 | 1,980.6 | 19,738.4 | 19,738.4 | 102,990.1 | 2,032.9 | 1.00 | 1 |
| 01/06/2014 08:00 | 17,802.2 | 3,051.5 | 20,853.7 | 20,853.7 | 102,990.1 | 2,147.7 | 1.00 | 1 |
| 01/06/2014 09:00 | 18,077.4 | 2,469.7 | 20,547.1 | 20,547.1 | 102,990.1 | 2,116.1 | 1.00 | 1 |
| 01/06/2014 10:00 | 17,942.6 | 2,923.9 | 20,866.5 | 20,866.5 | 102,990.1 | 2,149.0 | 1.00 | 1 |
| 01/06/2014 11:00 | 17,780.6 | 3,502.2 | 21,282.8 | 21,282.8 | 102,990.1 | 2,191.9 | 1.00 | 1 |
| 01/06/2014 12:00 | 17,752.9 | 3,633.2 | 21,386.1 | 21,386.1 | 102,990.1 | 2,202.6 | 1.00 | 1 |
| 01/06/2014 13:00 | 17,681.3 | 3,826.3 | 21,507.6 | 21,507.6 | 102,990.1 | 2,215.1 | 1.00 | 1 |
| 01/06/2014 14:00 | 17,681.9 | 2,888.3 | 20,570.2 | 20,570.2 | 102,990.1 | 2,118.5 | 1.00 | 1 |
| 01/06/2014 15:00 | 17,650.0 | 1,790.1 | 19,440.1 | 19,440.1 | 102,990.1 | 2,002.1 | 1.00 | 1 |
| 01/06/2014 16:00 | 17,634.9 | 1,934.5 | 19,569.4 | 19,569.4 | 102,990.1 | 2,015.5 | 1.00 | 1 |
| 01/06/2014 17:00 | 17,664.9 | 2,460.1 | 20,125.0 | 20,125.0 | 102,990.1 | 2,072.7 | 1.00 | 1 |
| 01/06/2014 18:00 | 17,690.7 | 2,597.9 | 20,288.6 | 20,288.6 | 102,990.1 | 2,089.5 | 1.00 | 1 |
| 01/06/2014 19:00 | 17,699.8 | 3,851.8 | 21,551.6 | 21,551.6 | 102,990.1 | 2,219.6 | 1.00 | 1 |
| 01/06/2014 20:00 | 17,708.5 | 2,744.0 | 20,452.5 | 20,452.5 | 102,990.1 | 2,106.4 | 1.00 | 1 |
| 01/06/2014 21:00 | 17,738.0 | 3,976.9 | 21,714.9 | 21,714.9 | 102,990.1 | 2,236.4 | 1.00 | 1 |
| 01/06/2014 22:00 | 17,722.2 | 4,092.1 | 21,814.3 | 21,814.3 | 102,990.1 | 2,246.7 | 1.00 | 1 |
| 01/06/2014 23:00 | 17,748.4 | 2,714.0 | 20,462.4 | 20,462.4 | 102,990.1 | 2,107.4 | 1.00 | 1 |
| **Average/Sum#:** | 17,758.7 | 2,824.0 | 20,582.7 | 493,984.0 # | 102,990.1 | 2,119.8 | 24.00 # | 24 # |
| **Minimum:** | 17,634.9 | 1,595.4 | 19,413.7 | 19,413.7 | 102,990.1 | 1,999.4 | 1.00 | 1 |
| **Maximum:** | 18,077.4 | 4,092.1 | 21,814.3 | 21,814.3 | 102,990.1 | 2,246.7 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/07/2014 00:00 | 17,418.0 | 1,579.5 | 18,997.5 | 18,997.5 | 102,990.1 | 1,956.6 | 1.00 | 1 |
| 01/07/2014 01:00 | 16,257.8 | 905.7 | 16,955.2 | 16,955.2 | 102,990.1 | 1,746.2 | 1.00 | 1 |
| 01/07/2014 02:00 | 14,445.2 | 0.0 | 14,445.2 | 14,445.2 | 102,990.1 | 1,487.7 | 1.00 | 1 |
| 01/07/2014 03:00 | 15,458.7 | 0.0 | 15,458.7 | 15,458.7 | 102,990.1 | 1,592.1 | 1.00 | 1 |
| 01/07/2014 04:00 | 15,333.0 | 0.0 | 15,333.0 | 15,333.0 | 102,990.1 | 1,579.1 | 1.00 | 1 |
| 01/07/2014 05:00 | 15,493.5 | 0.0 | 15,493.5 | 15,493.5 | 102,990.1 | 1,595.7 | 1.00 | 1 |
| 01/07/2014 06:00 | 16,963.9 | 687.2 | 17,362.5 | 17,362.5 | 102,990.1 | 1,788.2 | 1.00 | 1 |
| 01/07/2014 07:00 | 17,863.9 | 1,540.4 | 19,404.3 | 19,404.3 | 102,990.1 | 1,998.5 | 1.00 | 1 |
| 01/07/2014 08:00 | 17,927.7 | 2,839.4 | 20,767.1 | 20,767.1 | 102,990.1 | 2,138.8 | 1.00 | 1 |
| 01/07/2014 09:00 | 17,915.3 | 2,764.2 | 20,679.5 | 20,679.5 | 102,990.1 | 2,129.8 | 1.00 | 1 |
| 01/07/2014 10:00 | 17,871.6 | 2,181.3 | 20,052.9 | 20,052.9 | 102,990.1 | 2,065.3 | 1.00 | 1 |
| 01/07/2014 11:00 | 17,788.5 | 2,018.1 | 19,806.6 | 19,806.6 | 102,990.1 | 2,039.9 | 1.00 | 1 |
| 01/07/2014 12:00 | 17,753.3 | 3,740.0 | 21,493.3 | 21,493.3 | 102,990.1 | 2,213.6 | 1.00 | 1 |
| 01/07/2014 13:00 | 17,639.3 | 3,798.0 | 21,437.3 | 21,437.3 | 102,990.1 | 2,207.8 | 1.00 | 1 |
| 01/07/2014 14:00 | 17,584.7 | 2,427.4 | 20,012.1 | 20,012.1 | 102,990.1 | 2,061.0 | 1.00 | 1 |
| 01/07/2014 15:00 | 17,544.3 | 2,594.6 | 20,138.9 | 20,138.9 | 102,990.1 | 2,074.1 | 1.00 | 1 |
| 01/07/2014 16:00 | 17,530.2 | 1,704.7 | 19,234.9 | 19,234.9 | 102,990.1 | 1,981.0 | 1.00 | 1 |
| 01/07/2014 17:00 | 17,532.3 | 1,718.5 | 19,250.8 | 19,250.8 | 102,990.1 | 1,982.6 | 1.00 | 1 |
| 01/07/2014 18:00 | 17,570.3 | 2,192.7 | 19,763.0 | 19,763.0 | 102,990.1 | 2,035.4 | 1.00 | 1 |
| 01/07/2014 19:00 | 17,630.9 | 3,460.5 | 21,091.4 | 21,091.4 | 102,990.1 | 2,172.2 | 1.00 | 1 |
| 01/07/2014 20:00 | 17,676.0 | 3,889.6 | 21,565.6 | 21,565.6 | 102,990.1 | 2,221.0 | 1.00 | 1 |
| 01/07/2014 21:00 | 17,699.5 | 2,315.1 | 20,014.6 | 20,014.6 | 102,990.1 | 2,061.3 | 1.00 | 1 |
| 01/07/2014 22:00 | 17,781.1 | 1,991.6 | 19,772.7 | 19,772.7 | 102,990.1 | 2,036.4 | 1.00 | 1 |
| 01/07/2014 23:00 | 17,281.4 | 1,160.7 | 18,210.0 | 18,210.0 | 102,990.1 | 1,875.4 | 1.00 | 1 |
| **Average/Sum#:** | 17,165.0 | 1,896.2 | 19,030.9 | 456,740.6 # | 102,990.1 | 1,960.0 | 24.00 # | 24 # |
| **Minimum:** | 14,445.2 | 0.0 | 14,445.2 | 14,445.2 | 102,990.1 | 1,487.7 | 1.00 | 1 |
| **Maximum:** | 17,927.7 | 3,889.6 | 21,565.6 | 21,565.6 | 102,990.1 | 2,221.0 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/08/2014 00:00 | 13,207.5 | 0.0 | 13,207.5 | 13,207.5 | 102,990.1 | 1,360.2 | 1.00 | 1 |
| 01/08/2014 01:00 | 12,723.6 | 0.0 | 12,723.6 | 12,723.6 | 102,990.1 | 1,310.4 | 1.00 | 1 |
| 01/08/2014 02:00 | 12,470.1 | 0.0 | 12,470.1 | 12,470.1 | 102,990.1 | 1,284.3 | 1.00 | 1 |
| 01/08/2014 03:00 | 12,235.2 | 0.0 | 12,235.2 | 12,235.2 | 102,990.1 | 1,260.1 | 1.00 | 1 |
| 01/08/2014 04:00 | 12,556.3 | 0.0 | 12,556.3 | 12,556.3 | 102,990.1 | 1,293.2 | 1.00 | 1 |
| 01/08/2014 05:00 | 15,849.7 | 0.0 | 15,849.7 | 15,849.7 | 102,990.1 | 1,632.4 | 1.00 | 1 |
| 01/08/2014 06:00 | 16,340.1 | 405.7 | 16,514.6 | 16,514.6 | 102,990.1 | 1,700.8 | 1.00 | 1 |
| 01/08/2014 07:00 | 17,634.6 | 1,000.2 | 18,634.8 | 18,634.8 | 102,990.1 | 1,919.2 | 1.00 | 1 |
| 01/08/2014 08:00 | 17,895.6 | 1,467.4 | 19,363.0 | 19,363.0 | 102,990.1 | 1,994.2 | 1.00 | 1 |
| 01/08/2014 09:00 | 16,847.0 | 500.8 | 17,107.4 | 17,107.4 | 102,990.1 | 1,761.9 | 1.00 | 1 |
| 01/08/2014 10:00 | 12,015.3 | 0.0 | 12,015.3 | 12,015.3 | 102,990.1 | 1,237.5 | 1.00 | 1 |
| 01/08/2014 11:00 | 13,384.5 | 0.0 | 13,384.5 | 13,384.5 | 102,990.1 | 1,378.5 | 1.00 | 1 |
| 01/08/2014 12:00 | 16,541.3 | 0.0 | 16,541.3 | 16,541.3 | 102,990.1 | 1,703.6 | 1.00 | 1 |
| 01/08/2014 13:00 | 14,373.4 | 0.0 | 14,373.4 | 14,373.4 | 102,990.1 | 1,480.3 | 1.00 | 1 |
| 01/08/2014 14:00 | 12,180.1 | 0.0 | 12,180.1 | 12,180.1 | 102,990.1 | 1,254.4 | 1.00 | 1 |
| 01/08/2014 15:00 | 13,599.1 | 0.0 | 13,599.1 | 13,599.1 | 102,990.1 | 1,400.6 | 1.00 | 1 |
| 01/08/2014 16:00 | 14,815.1 | 0.0 | 14,815.1 | 14,815.1 | 102,990.1 | 1,525.8 | 1.00 | 1 |
| 01/08/2014 17:00 | 16,999.8 | 880.1 | 17,545.5 | 17,545.5 | 102,990.1 | 1,807.0 | 1.00 | 1 |
| 01/08/2014 18:00 | 13,905.5 | 0.0 | 13,905.5 | 13,905.5 | 102,990.1 | 1,432.1 | 1.00 | 1 |
| 01/08/2014 19:00 | 14,857.2 | 0.0 | 14,857.2 | 14,857.2 | 102,990.1 | 1,530.1 | 1.00 | 1 |
| 01/08/2014 20:00 | 14,423.6 | 0.0 | 14,423.6 | 14,423.6 | 102,990.1 | 1,485.5 | 1.00 | 1 |
| 01/08/2014 21:00 | 14,452.7 | 0.0 | 14,452.7 | 14,452.7 | 102,990.1 | 1,488.5 | 1.00 | 1 |
| 01/08/2014 22:00 | 7,052.0 | 0.0 | 7,052.0 | 1,904.0 | 102,990.1 | 726.3 | 0.27 | 0 |
| 01/08/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 14,189.5 | 185.0 | 14,339.5 | 324,659.5 # | 102,990.1 | 1,476.8 | 22.27 # | 22 # |
| **Minimum:** | 7,052.0 | 0.0 | 7,052.0 | 1,904.0 | 102,990.1 | 726.3 | 0.00 | 0 |
| **Maximum:** | 17,895.6 | 1,467.4 | 19,363.0 | 19,363.0 | 102,990.1 | 1,994.2 | 1.00 | 1 |
| **%SI** | 4.2 | 4.2 | 4.2 | 4.2 | 0.0 | 4.2 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/09/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/10/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/12/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/13/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/14/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/15/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 14:00 | 5,137.8 | 0.0 | 5,137.8 | 4,264.4 | 102,990.1 | 529.1 | 0.83 | 0 |
| 01/29/2014 15:00 | 7,388.5 | 0.0 | 7,388.5 | 7,388.5 | 102,990.1 | 760.9 | 1.00 | 0 |
| 01/29/2014 16:00 | 12,852.8 | 0.0 | 12,852.8 | 12,852.8 | 102,990.1 | 1,323.7 | 1.00 | 0 |
| 01/29/2014 17:00 | 14,970.5 | 0.0 | 14,970.5 | 14,970.5 | 102,990.1 | 1,541.8 | 1.00 | 1 |
| 01/29/2014 18:00 | 17,665.8 | 0.0 | 17,665.8 | 17,665.8 | 102,990.1 | 1,819.4 | 1.00 | 1 |
| 01/29/2014 19:00 | 17,664.8 | 0.0 | 17,664.8 | 17,664.8 | 102,990.1 | 1,819.3 | 1.00 | 1 |
| 01/29/2014 20:00 | 17,015.0 | 0.0 | 17,015.0 | 17,015.0 | 102,990.1 | 1,752.4 | 1.00 | 1 |
| 01/29/2014 21:00 | 17,540.5 | 0.0 | 17,540.5 | 17,540.5 | 102,990.1 | 1,806.5 | 1.00 | 1 |
| 01/29/2014 22:00 | 16,192.2 | 0.0 | 16,192.2 | 16,192.2 | 102,990.1 | 1,667.6 | 1.00 | 1 |
| 01/29/2014 23:00 | 12,543.9 | 0.0 | 12,543.9 | 12,543.9 | 102,990.1 | 1,291.9 | 1.00 | 1 |
| **Average/Sum#:** | 13,897.2 | 0.0 | 13,897.2 | 138,098.4 # | 102,990.1 | 1,431.3 | 9.83 # | 7 # |
| **Minimum:** | 5,137.8 | 0.0 | 5,137.8 | 4,264.4 | 102,990.1 | 529.1 | 0.00 | 0 |
| **Maximum:** | 17,665.8 | 0.0 | 17,665.8 | 17,665.8 | 102,990.1 | 1,819.4 | 1.00 | 1 |
| **%SI** | 58.3 | 58.3 | 58.3 | 58.3 | 0.0 | 58.3 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/30/2014 00:00 | 14,314.7 | 0.0 | 14,314.7 | 14,314.7 | 102,258.0 | 1,463.8 | 1.00 | 1 |
| 01/30/2014 01:00 | 17,141.7 | 0.0 | 17,141.7 | 17,141.7 | 102,258.0 | 1,752.9 | 1.00 | 1 |
| 01/30/2014 02:00 | 12,983.3 | 0.0 | 12,983.3 | 12,983.3 | 102,258.0 | 1,327.6 | 1.00 | 1 |
| 01/30/2014 03:00 | 12,293.9 | 0.0 | 12,293.9 | 12,293.9 | 102,258.0 | 1,257.1 | 1.00 | 1 |
| 01/30/2014 04:00 | 12,540.8 | 0.0 | 12,540.8 | 12,540.8 | 102,258.0 | 1,282.4 | 1.00 | 1 |
| 01/30/2014 05:00 | 12,262.9 | 0.0 | 12,262.9 | 12,262.9 | 102,258.0 | 1,254.0 | 1.00 | 1 |
| 01/30/2014 06:00 | 14,159.3 | 0.0 | 14,159.3 | 14,159.3 | 102,258.0 | 1,447.9 | 1.00 | 1 |
| 01/30/2014 07:00 | 15,087.0 | 0.0 | 15,087.0 | 15,087.0 | 102,258.0 | 1,542.8 | 1.00 | 1 |
| 01/30/2014 08:00 | 15,192.6 | 0.0 | 15,192.6 | 15,192.6 | 102,258.0 | 1,553.6 | 1.00 | 1 |
| 01/30/2014 09:00 | 12,151.5 | 0.0 | 12,151.5 | 12,151.5 | 102,258.0 | 1,242.6 | 1.00 | 1 |
| 01/30/2014 10:00 | 14,822.2 | 43.6 | 14,825.3 | 14,825.3 | 102,258.0 | 1,516.0 | 1.00 | 1 |
| 01/30/2014 11:00 | 17,644.2 | 29.5 | 17,649.2 | 17,649.2 | 102,258.0 | 1,804.8 | 1.00 | 1 |
| 01/30/2014 12:00 | 17,560.1 | 1,308.9 | 18,646.5 | 18,646.5 | 102,258.0 | 1,906.8 | 1.00 | 1 |
| 01/30/2014 13:00 | 17,510.5 | 2,686.8 | 20,197.3 | 20,197.3 | 102,258.0 | 2,065.3 | 1.00 | 1 |
| 01/30/2014 14:00 | 17,502.1 | 3,707.2 | 21,209.3 | 21,209.3 | 102,258.0 | 2,168.8 | 1.00 | 1 |
| 01/30/2014 15:00 | 17,481.8 | 4,036.3 | 21,518.1 | 21,518.1 | 102,258.0 | 2,200.4 | 1.00 | 1 |
| 01/30/2014 16:00 | 17,187.0 | 1,724.4 | 18,394.1 | 18,394.1 | 102,258.0 | 1,880.9 | 1.00 | 1 |
| 01/30/2014 17:00 | 15,362.6 | 6.0 | 15,362.7 | 15,362.7 | 102,258.0 | 1,571.0 | 1.00 | 1 |
| 01/30/2014 18:00 | 16,057.1 | 0.0 | 16,057.1 | 16,057.1 | 102,258.0 | 1,642.0 | 1.00 | 1 |
| 01/30/2014 19:00 | 17,531.7 | 1,475.3 | 18,785.7 | 18,785.7 | 102,258.0 | 1,921.0 | 1.00 | 1 |
| 01/30/2014 20:00 | 17,542.2 | 2,462.8 | 20,005.0 | 20,005.0 | 102,258.0 | 2,045.7 | 1.00 | 1 |
| 01/30/2014 21:00 | 17,551.2 | 2,273.0 | 19,824.2 | 19,824.2 | 102,258.0 | 2,027.2 | 1.00 | 1 |
| 01/30/2014 22:00 | 17,575.0 | 1,560.1 | 19,057.1 | 19,057.1 | 102,258.0 | 1,948.7 | 1.00 | 1 |
| 01/30/2014 23:00 | 17,648.6 | 717.5 | 17,971.5 | 17,971.5 | 102,258.0 | 1,837.7 | 1.00 | 1 |
| **Average/Sum#:** | 15,712.7 | 918.0 | 16,568.0 | 397,630.8 # | 102,258.0 | 1,694.2 | 24.00 # | 24 # |
| **Minimum:** | 12,151.5 | 0.0 | 12,151.5 | 12,151.5 | 102,258.0 | 1,242.6 | 1.00 | 1 |
| **Maximum:** | 17,648.6 | 4,036.3 | 21,518.1 | 21,518.1 | 102,258.0 | 2,200.4 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/31/2014 00:00 | 14,988.4 | 0.0 | 14,988.4 | 14,988.4 | 102,258.0 | 1,532.7 | 1.00 | 1 |
| 01/31/2014 01:00 | 14,564.2 | 0.0 | 14,564.2 | 14,564.2 | 102,258.0 | 1,489.3 | 1.00 | 1 |
| 01/31/2014 02:00 | 15,843.6 | 0.0 | 15,843.6 | 15,843.6 | 102,258.0 | 1,620.1 | 1.00 | 1 |
| 01/31/2014 03:00 | 13,755.6 | 0.0 | 13,755.6 | 13,755.6 | 102,258.0 | 1,406.6 | 1.00 | 1 |
| 01/31/2014 04:00 | 12,952.6 | 0.0 | 12,952.6 | 12,952.6 | 102,258.0 | 1,324.5 | 1.00 | 1 |
| 01/31/2014 05:00 | 17,146.1 | 0.0 | 17,146.1 | 17,146.1 | 102,258.0 | 1,753.3 | 1.00 | 1 |
| 01/31/2014 06:00 | 17,570.9 | 381.5 | 17,704.4 | 17,704.4 | 102,258.0 | 1,810.4 | 1.00 | 1 |
| 01/31/2014 07:00 | 17,827.8 | 0.0 | 17,827.8 | 17,827.8 | 102,258.0 | 1,823.0 | 1.00 | 1 |
| 01/31/2014 08:00 | 17,883.9 | 0.0 | 17,883.9 | 17,883.9 | 102,258.0 | 1,828.8 | 1.00 | 1 |
| 01/31/2014 09:00 | 17,591.1 | 108.5 | 17,602.0 | 17,602.0 | 102,258.0 | 1,799.9 | 1.00 | 1 |
| 01/31/2014 10:00 | 17,650.1 | 302.4 | 17,734.8 | 17,734.8 | 102,258.0 | 1,813.5 | 1.00 | 1 |
| 01/31/2014 11:00 | 17,573.1 | 1,073.8 | 18,571.7 | 18,571.7 | 102,258.0 | 1,899.1 | 1.00 | 1 |
| 01/31/2014 12:00 | 17,703.1 | 1,595.5 | 19,298.6 | 19,298.6 | 102,258.0 | 1,973.4 | 1.00 | 1 |
| 01/31/2014 13:00 | 17,679.0 | 1,653.5 | 19,332.5 | 19,332.5 | 102,258.0 | 1,976.9 | 1.00 | 1 |
| 01/31/2014 14:00 | 17,579.6 | 1,246.9 | 18,826.5 | 18,826.5 | 102,258.0 | 1,925.2 | 1.00 | 1 |
| 01/31/2014 15:00 | 17,459.3 | 1,184.4 | 18,643.7 | 18,643.7 | 102,258.0 | 1,906.5 | 1.00 | 1 |
| 01/31/2014 16:00 | 17,436.9 | 1,183.6 | 18,620.5 | 18,620.5 | 102,258.0 | 1,904.1 | 1.00 | 1 |
| 01/31/2014 17:00 | 17,625.8 | 1,184.5 | 18,810.3 | 18,810.3 | 102,258.0 | 1,923.5 | 1.00 | 1 |
| 01/31/2014 18:00 | 17,389.3 | 1,192.4 | 18,581.7 | 18,581.7 | 102,258.0 | 1,900.1 | 1.00 | 1 |
| 01/31/2014 19:00 | 17,711.7 | 2,380.9 | 20,092.6 | 20,092.6 | 102,258.0 | 2,054.6 | 1.00 | 1 |
| 01/31/2014 20:00 | 17,801.1 | 1,716.1 | 19,517.2 | 19,517.2 | 102,258.0 | 1,995.8 | 1.00 | 1 |
| 01/31/2014 21:00 | 17,794.0 | 2,205.0 | 19,999.0 | 19,999.0 | 102,258.0 | 2,045.1 | 1.00 | 1 |
| 01/31/2014 22:00 | 17,820.5 | 2,852.6 | 20,673.1 | 20,673.1 | 102,258.0 | 2,114.0 | 1.00 | 1 |
| 01/31/2014 23:00 | 17,780.5 | 2,700.7 | 20,481.2 | 20,481.2 | 102,258.0 | 2,094.4 | 1.00 | 1 |
| **Average/Sum#:** | 16,963.7 | 956.8 | 17,893.8 | 429,452.0 # | 102,258.0 | 1,829.8 | 24.00 # | 24 # |
| **Minimum:** | 12,952.6 | 0.0 | 12,952.6 | 12,952.6 | 102,258.0 | 1,324.5 | 1.00 | 1 |
| **Maximum:** | 17,883.9 | 2,852.6 | 20,673.1 | 20,673.1 | 102,258.0 | 2,114.0 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/01/2014 00:00 | 16,732.9 | 926.6 | 17,446.4 | 17,446.4 | 102,258.0 | 1,784.0 | 1.00 | 1 |
| 02/01/2014 01:00 | 15,854.3 | 0.0 | 15,854.3 | 15,854.3 | 102,258.0 | 1,621.2 | 1.00 | 1 |
| 02/01/2014 02:00 | 16,168.1 | 0.0 | 16,168.1 | 16,168.1 | 102,258.0 | 1,653.3 | 1.00 | 1 |
| 02/01/2014 03:00 | 17,410.2 | 0.0 | 17,410.2 | 17,410.2 | 102,258.0 | 1,780.3 | 1.00 | 1 |
| 02/01/2014 04:00 | 14,303.5 | 0.0 | 14,303.5 | 14,303.5 | 102,258.0 | 1,462.6 | 1.00 | 1 |
| 02/01/2014 05:00 | 17,459.9 | 1,147.9 | 18,148.6 | 18,148.6 | 102,258.0 | 1,855.8 | 1.00 | 1 |
| 02/01/2014 06:00 | 17,926.7 | 3,686.2 | 21,612.9 | 21,612.9 | 102,258.0 | 2,210.1 | 1.00 | 1 |
| 02/01/2014 07:00 | 17,992.7 | 3,622.1 | 21,614.8 | 21,614.8 | 102,258.0 | 2,210.3 | 1.00 | 1 |
| 02/01/2014 08:00 | 18,091.8 | 3,005.4 | 21,097.2 | 21,097.2 | 102,258.0 | 2,157.4 | 1.00 | 1 |
| 02/01/2014 09:00 | 18,090.3 | 2,428.8 | 20,519.1 | 20,519.1 | 102,258.0 | 2,098.2 | 1.00 | 1 |
| 02/01/2014 10:00 | 17,474.5 | 735.7 | 17,893.8 | 17,893.8 | 102,258.0 | 1,829.8 | 1.00 | 1 |
| 02/01/2014 11:00 | 15,273.0 | 0.0 | 15,273.0 | 15,273.0 | 102,258.0 | 1,561.8 | 1.00 | 1 |
| 02/01/2014 12:00 | 15,050.3 | 0.0 | 15,050.3 | 15,050.3 | 102,258.0 | 1,539.0 | 1.00 | 1 |
| 02/01/2014 13:00 | 15,530.9 | 0.0 | 15,530.9 | 15,530.9 | 102,258.0 | 1,588.2 | 1.00 | 1 |
| 02/01/2014 14:00 | 14,097.8 | 0.0 | 14,097.8 | 14,097.8 | 102,258.0 | 1,441.6 | 1.00 | 1 |
| 02/01/2014 15:00 | 12,284.1 | 0.0 | 12,284.1 | 12,284.1 | 102,258.0 | 1,256.1 | 1.00 | 1 |
| 02/01/2014 16:00 | 12,774.2 | 0.0 | 12,774.2 | 12,774.2 | 102,258.0 | 1,306.3 | 1.00 | 1 |
| 02/01/2014 17:00 | 16,179.7 | 617.9 | 16,470.1 | 16,470.1 | 102,258.0 | 1,684.2 | 1.00 | 1 |
| 02/01/2014 18:00 | 17,651.3 | 1,847.4 | 19,498.7 | 19,498.7 | 102,258.0 | 1,993.9 | 1.00 | 1 |
| 02/01/2014 19:00 | 17,714.9 | 3,628.4 | 21,343.3 | 21,343.3 | 102,258.0 | 2,182.5 | 1.00 | 1 |
| 02/01/2014 20:00 | 17,790.6 | 4,033.1 | 21,823.7 | 21,823.7 | 102,258.0 | 2,231.6 | 1.00 | 1 |
| 02/01/2014 21:00 | 17,848.4 | 3,992.8 | 21,841.2 | 21,841.2 | 102,258.0 | 2,233.4 | 1.00 | 1 |
| 02/01/2014 22:00 | 17,998.0 | 3,805.0 | 21,803.0 | 21,803.0 | 102,258.0 | 2,229.5 | 1.00 | 1 |
| 02/01/2014 23:00 | 18,106.5 | 3,521.5 | 21,628.0 | 21,628.0 | 102,258.0 | 2,211.6 | 1.00 | 1 |
| **Average/Sum#:** | 16,491.9 | 1,541.6 | 17,978.6 | 431,487.2 # | 102,258.0 | 1,838.4 | 24.00 # | 24 # |
| **Minimum:** | 12,284.1 | 0.0 | 12,284.1 | 12,284.1 | 102,258.0 | 1,256.1 | 1.00 | 1 |
| **Maximum:** | 18,106.5 | 4,033.1 | 21,841.2 | 21,841.2 | 102,258.0 | 2,233.4 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/02/2014 00:00 | 18,063.0 | 2,935.5 | 20,998.5 | 20,998.5 | 102,258.0 | 2,147.3 | 1.00 | 1 |
| 02/02/2014 01:00 | 18,190.3 | 2,054.1 | 20,244.4 | 20,244.4 | 102,258.0 | 2,070.2 | 1.00 | 1 |
| 02/02/2014 02:00 | 18,182.3 | 2,009.7 | 20,192.0 | 20,192.0 | 102,258.0 | 2,064.8 | 1.00 | 1 |
| 02/02/2014 03:00 | 18,281.6 | 2,020.3 | 20,301.9 | 20,301.9 | 102,258.0 | 2,076.0 | 1.00 | 1 |
| 02/02/2014 04:00 | 18,292.4 | 1,550.4 | 19,842.8 | 19,842.8 | 102,258.0 | 2,029.1 | 1.00 | 1 |
| 02/02/2014 05:00 | 18,280.7 | 1,560.4 | 19,841.1 | 19,841.1 | 102,258.0 | 2,028.9 | 1.00 | 1 |
| 02/02/2014 06:00 | 18,309.1 | 1,685.9 | 19,995.0 | 19,995.0 | 102,258.0 | 2,044.6 | 1.00 | 1 |
| 02/02/2014 07:00 | 18,261.3 | 3,185.1 | 21,446.4 | 21,446.4 | 102,258.0 | 2,193.1 | 1.00 | 1 |
| 02/02/2014 08:00 | 18,308.9 | 3,569.5 | 21,878.4 | 21,878.4 | 102,258.0 | 2,237.2 | 1.00 | 1 |
| 02/02/2014 09:00 | 18,268.4 | 3,603.1 | 21,871.5 | 21,871.5 | 102,258.0 | 2,236.5 | 1.00 | 1 |
| 02/02/2014 10:00 | 18,081.7 | 3,721.3 | 21,803.0 | 21,803.0 | 102,258.0 | 2,229.5 | 1.00 | 1 |
| 02/02/2014 11:00 | 17,948.3 | 3,848.4 | 21,796.7 | 21,796.7 | 102,258.0 | 2,228.9 | 1.00 | 1 |
| 02/02/2014 12:00 | 17,882.8 | 3,794.8 | 21,677.6 | 21,677.6 | 102,258.0 | 2,216.7 | 1.00 | 1 |
| 02/02/2014 13:00 | 17,843.4 | 3,626.6 | 21,470.0 | 21,470.0 | 102,258.0 | 2,195.5 | 1.00 | 1 |
| 02/02/2014 14:00 | 17,799.2 | 2,358.6 | 20,157.8 | 20,157.8 | 102,258.0 | 2,061.3 | 1.00 | 1 |
| 02/02/2014 15:00 | 17,771.5 | 3,817.7 | 21,589.2 | 21,589.2 | 102,258.0 | 2,207.7 | 1.00 | 1 |
| 02/02/2014 16:00 | 17,832.3 | 4,082.1 | 21,914.4 | 21,914.4 | 102,258.0 | 2,240.9 | 1.00 | 1 |
| 02/02/2014 17:00 | 17,879.0 | 2,915.2 | 20,794.2 | 20,794.2 | 102,258.0 | 2,126.4 | 1.00 | 1 |
| 02/02/2014 18:00 | 17,701.9 | 1,384.6 | 19,086.5 | 19,086.5 | 102,258.0 | 1,951.7 | 1.00 | 1 |
| 02/02/2014 19:00 | 17,939.1 | 2,574.8 | 20,513.9 | 20,513.9 | 102,258.0 | 2,097.7 | 1.00 | 1 |
| 02/02/2014 20:00 | 17,861.8 | 3,714.2 | 21,576.0 | 21,576.0 | 102,258.0 | 2,206.3 | 1.00 | 1 |
| 02/02/2014 21:00 | 17,853.5 | 3,990.6 | 21,844.1 | 21,844.1 | 102,258.0 | 2,233.7 | 1.00 | 1 |
| 02/02/2014 22:00 | 17,842.1 | 3,136.3 | 20,978.4 | 20,978.4 | 102,258.0 | 2,145.2 | 1.00 | 1 |
| 02/02/2014 23:00 | 17,914.6 | 3,744.4 | 21,659.0 | 21,659.0 | 102,258.0 | 2,214.8 | 1.00 | 1 |
| **Average/Sum#:** | 18,024.6 | 2,953.5 | 20,978.0 | 503,472.8 # | 102,258.0 | 2,145.2 | 24.00 # | 24 # |
| **Minimum:** | 17,701.9 | 1,384.6 | 19,086.5 | 19,086.5 | 102,258.0 | 1,951.7 | 1.00 | 1 |
| **Maximum:** | 18,309.1 | 4,082.1 | 21,914.4 | 21,914.4 | 102,258.0 | 2,240.9 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/03/2014 00:00 | 17,892.2 | 3,526.3 | 21,418.5 | 21,418.5 | 102,258.0 | 2,190.2 | 1.00 | 1 |
| 02/03/2014 01:00 | 17,908.7 | 2,405.2 | 20,313.9 | 20,313.9 | 102,258.0 | 2,077.3 | 1.00 | 1 |
| 02/03/2014 02:00 | 17,916.3 | 1,530.2 | 19,446.5 | 19,446.5 | 102,258.0 | 1,988.6 | 1.00 | 1 |
| 02/03/2014 03:00 | 17,724.8 | 1,419.1 | 19,143.9 | 19,143.9 | 102,258.0 | 1,957.6 | 1.00 | 1 |
| 02/03/2014 04:00 | 18,158.3 | 1,415.2 | 19,573.5 | 19,573.5 | 102,258.0 | 2,001.5 | 1.00 | 1 |
| 02/03/2014 05:00 | 18,241.4 | 2,275.9 | 20,517.3 | 20,517.3 | 102,258.0 | 2,098.1 | 1.00 | 1 |
| 02/03/2014 06:00 | 18,160.9 | 1,739.3 | 19,900.2 | 19,900.2 | 102,258.0 | 2,035.0 | 1.00 | 1 |
| 02/03/2014 07:00 | 18,146.1 | 1,871.1 | 20,017.2 | 20,017.2 | 102,258.0 | 2,046.9 | 1.00 | 1 |
| 02/03/2014 08:00 | 18,158.4 | 3,367.1 | 21,525.5 | 21,525.5 | 102,258.0 | 2,201.2 | 1.00 | 1 |
| 02/03/2014 09:00 | 18,158.7 | 2,922.8 | 21,081.5 | 21,081.5 | 102,258.0 | 2,155.8 | 1.00 | 1 |
| 02/03/2014 10:00 | 18,111.1 | 2,042.4 | 20,153.5 | 20,153.5 | 102,258.0 | 2,060.9 | 1.00 | 1 |
| 02/03/2014 11:00 | 17,200.5 | 1,207.7 | 18,408.2 | 18,408.2 | 102,258.0 | 1,882.4 | 1.00 | 1 |
| 02/03/2014 12:00 | 17,500.6 | 1,221.7 | 18,722.3 | 18,722.3 | 102,258.0 | 1,914.5 | 1.00 | 1 |
| 02/03/2014 13:00 | 17,792.9 | 1,469.8 | 19,262.7 | 19,262.7 | 102,258.0 | 1,969.8 | 1.00 | 1 |
| 02/03/2014 14:00 | 17,820.6 | 1,613.2 | 19,433.8 | 19,433.8 | 102,258.0 | 1,987.3 | 1.00 | 1 |
| 02/03/2014 15:00 | 17,644.9 | 1,367.5 | 19,012.4 | 19,012.4 | 102,258.0 | 1,944.2 | 1.00 | 1 |
| 02/03/2014 16:00 | 17,675.9 | 1,595.9 | 19,271.8 | 19,271.8 | 102,258.0 | 1,970.7 | 1.00 | 1 |
| 02/03/2014 17:00 | 17,687.6 | 2,432.0 | 20,119.6 | 20,119.6 | 102,258.0 | 2,057.4 | 1.00 | 1 |
| 02/03/2014 18:00 | 17,735.3 | 3,814.5 | 21,549.8 | 21,549.8 | 102,258.0 | 2,203.6 | 1.00 | 1 |
| 02/03/2014 19:00 | 17,784.8 | 4,136.1 | 21,920.9 | 21,920.9 | 102,258.0 | 2,241.6 | 1.00 | 1 |
| 02/03/2014 20:00 | 17,788.5 | 4,120.0 | 21,908.5 | 21,908.5 | 102,258.0 | 2,240.3 | 1.00 | 1 |
| 02/03/2014 21:00 | 17,786.7 | 3,979.9 | 21,766.6 | 21,766.6 | 102,258.0 | 2,225.8 | 1.00 | 1 |
| 02/03/2014 22:00 | 17,824.2 | 3,609.4 | 21,433.6 | 21,433.6 | 102,258.0 | 2,191.8 | 1.00 | 1 |
| 02/03/2014 23:00 | 17,855.1 | 2,691.8 | 20,546.9 | 20,546.9 | 102,258.0 | 2,101.1 | 1.00 | 1 |
| **Average/Sum#:** | 17,861.4 | 2,407.3 | 20,268.7 | 486,448.6 # | 102,258.0 | 2,072.7 | 24.00 # | 24 # |
| **Minimum:** | 17,200.5 | 1,207.7 | 18,408.2 | 18,408.2 | 102,258.0 | 1,882.4 | 1.00 | 1 |
| **Maximum:** | 18,241.4 | 4,136.1 | 21,920.9 | 21,920.9 | 102,258.0 | 2,241.6 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/04/2014 00:00 | 18,246.8 | 1,928.8 | 20,175.6 | 20,175.6 | 102,258.0 | 2,063.1 | 1.00 | 1 |
| 02/04/2014 01:00 | 18,221.8 | 1,415.9 | 19,637.7 | 19,637.7 | 102,258.0 | 2,008.1 | 1.00 | 1 |
| 02/04/2014 02:00 | 17,503.5 | 1,255.4 | 18,758.9 | 18,758.9 | 102,258.0 | 1,918.2 | 1.00 | 1 |
| 02/04/2014 03:00 | 17,844.6 | 1,276.6 | 19,121.2 | 19,121.2 | 102,258.0 | 1,955.3 | 1.00 | 1 |
| 02/04/2014 04:00 | 16,910.9 | 1,213.3 | 18,124.2 | 18,124.2 | 102,258.0 | 1,853.3 | 1.00 | 1 |
| 02/04/2014 05:00 | 16,591.1 | 1,215.1 | 17,806.2 | 17,806.2 | 102,258.0 | 1,820.8 | 1.00 | 1 |
| 02/04/2014 06:00 | 17,697.9 | 1,701.5 | 19,399.4 | 19,399.4 | 102,258.0 | 1,983.7 | 1.00 | 1 |
| 02/04/2014 07:00 | 18,137.8 | 1,577.9 | 19,715.7 | 19,715.7 | 102,258.0 | 2,016.1 | 1.00 | 1 |
| 02/04/2014 08:00 | 18,160.4 | 1,590.7 | 19,751.1 | 19,751.1 | 102,258.0 | 2,019.7 | 1.00 | 1 |
| 02/04/2014 09:00 | 17,915.0 | 1,249.2 | 19,164.2 | 19,164.2 | 102,258.0 | 1,959.7 | 1.00 | 1 |
| 02/04/2014 10:00 | 18,152.1 | 1,388.1 | 19,540.2 | 19,540.2 | 102,258.0 | 1,998.1 | 1.00 | 1 |
| 02/04/2014 11:00 | 18,024.8 | 1,563.1 | 19,587.9 | 19,587.9 | 102,258.0 | 2,003.0 | 1.00 | 1 |
| 02/04/2014 12:00 | 17,850.3 | 1,347.8 | 19,198.1 | 19,198.1 | 102,258.0 | 1,963.2 | 1.00 | 1 |
| 02/04/2014 13:00 | 17,399.4 | 1,193.0 | 18,592.4 | 18,592.4 | 102,258.0 | 1,901.2 | 1.00 | 1 |
| 02/04/2014 14:00 | 17,871.4 | 1,723.4 | 19,594.8 | 19,594.8 | 102,258.0 | 2,003.7 | 1.00 | 1 |
| 02/04/2014 15:00 | 17,837.1 | 2,200.5 | 20,037.6 | 20,037.6 | 102,258.0 | 2,049.0 | 1.00 | 1 |
| 02/04/2014 16:00 | 17,818.3 | 1,843.9 | 19,662.2 | 19,662.2 | 102,258.0 | 2,010.6 | 1.00 | 1 |
| 02/04/2014 17:00 | 17,795.6 | 1,914.3 | 19,709.9 | 19,709.9 | 102,258.0 | 2,015.5 | 1.00 | 1 |
| 02/04/2014 18:00 | 17,840.7 | 2,675.1 | 20,515.8 | 20,515.8 | 102,258.0 | 2,097.9 | 1.00 | 1 |
| 02/04/2014 19:00 | 17,845.3 | 3,606.5 | 21,451.8 | 21,451.8 | 102,258.0 | 2,193.6 | 1.00 | 1 |
| 02/04/2014 20:00 | 17,866.5 | 3,278.7 | 21,145.2 | 21,145.2 | 102,258.0 | 2,162.3 | 1.00 | 1 |
| 02/04/2014 21:00 | 17,879.0 | 3,895.1 | 21,774.1 | 21,774.1 | 102,258.0 | 2,226.6 | 1.00 | 1 |
| 02/04/2014 22:00 | 17,878.3 | 3,618.4 | 21,496.7 | 21,496.7 | 102,258.0 | 2,198.2 | 1.00 | 1 |
| 02/04/2014 23:00 | 17,985.1 | 2,312.1 | 20,297.2 | 20,297.2 | 102,258.0 | 2,075.6 | 1.00 | 1 |
| **Average/Sum#:** | 17,803.1 | 1,957.7 | 19,760.8 | 474,258.1 # | 102,258.0 | 2,020.7 | 24.00 # | 24 # |
| **Minimum:** | 16,591.1 | 1,193.0 | 17,806.2 | 17,806.2 | 102,258.0 | 1,820.8 | 1.00 | 1 |
| **Maximum:** | 18,246.8 | 3,895.1 | 21,774.1 | 21,774.1 | 102,258.0 | 2,226.6 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/05/2014 00:00 | 17,971.4 | 1,815.4 | 19,786.8 | 19,786.8 | 102,258.0 | 2,023.4 | 1.00 | 1 |
| 02/05/2014 01:00 | 16,976.5 | 1,205.8 | 18,182.3 | 18,182.3 | 102,258.0 | 1,859.3 | 1.00 | 1 |
| 02/05/2014 02:00 | 16,690.6 | 1,209.5 | 17,900.1 | 17,900.1 | 102,258.0 | 1,830.4 | 1.00 | 1 |
| 02/05/2014 03:00 | 16,770.1 | 1,212.0 | 17,982.1 | 17,982.1 | 102,258.0 | 1,838.8 | 1.00 | 1 |
| 02/05/2014 04:00 | 16,793.9 | 1,215.9 | 18,009.8 | 18,009.8 | 102,258.0 | 1,841.6 | 1.00 | 1 |
| 02/05/2014 05:00 | 17,119.4 | 1,211.7 | 18,331.1 | 18,331.1 | 102,258.0 | 1,874.5 | 1.00 | 1 |
| 02/05/2014 06:00 | 17,622.6 | 1,281.2 | 18,903.8 | 18,903.8 | 102,258.0 | 1,933.1 | 1.00 | 1 |
| 02/05/2014 07:00 | 18,130.6 | 2,407.0 | 20,537.6 | 20,537.6 | 102,258.0 | 2,100.1 | 1.00 | 1 |
| 02/05/2014 08:00 | 18,202.1 | 3,474.9 | 21,677.0 | 21,677.0 | 102,258.0 | 2,216.6 | 1.00 | 1 |
| 02/05/2014 09:00 | 18,229.0 | 1,800.7 | 20,029.7 | 20,029.7 | 102,258.0 | 2,048.2 | 1.00 | 1 |
| 02/05/2014 10:00 | 13,122.9 | 131.6 | 13,138.7 | 13,138.7 | 102,258.0 | 1,343.5 | 1.00 | 1 |
| 02/05/2014 11:00 | 14,932.7 | 725.3 | 15,172.0 | 15,172.0 | 102,258.0 | 1,551.5 | 1.00 | 1 |
| 02/05/2014 12:00 | 18,015.7 | 3,820.2 | 21,835.9 | 21,835.9 | 102,258.0 | 2,232.9 | 1.00 | 1 |
| 02/05/2014 13:00 | 17,918.6 | 3,113.6 | 21,032.2 | 21,032.2 | 102,258.0 | 2,150.7 | 1.00 | 1 |
| 02/05/2014 14:00 | 16,999.8 | 1,197.2 | 18,197.0 | 18,197.0 | 102,258.0 | 1,860.8 | 1.00 | 1 |
| 02/05/2014 15:00 | 16,702.2 | 1,193.7 | 17,895.9 | 17,895.9 | 102,258.0 | 1,830.0 | 1.00 | 1 |
| 02/05/2014 16:00 | 16,916.2 | 1,192.8 | 18,109.0 | 18,109.0 | 102,258.0 | 1,851.8 | 1.00 | 1 |
| 02/05/2014 17:00 | 17,747.7 | 1,856.8 | 19,604.5 | 19,604.5 | 102,258.0 | 2,004.7 | 1.00 | 1 |
| 02/05/2014 18:00 | 17,813.3 | 2,287.5 | 20,100.8 | 20,100.8 | 102,258.0 | 2,055.5 | 1.00 | 1 |
| 02/05/2014 19:00 | 17,858.6 | 3,932.1 | 21,790.7 | 21,790.7 | 102,258.0 | 2,228.3 | 1.00 | 1 |
| 02/05/2014 20:00 | 17,886.2 | 4,102.0 | 21,988.2 | 21,988.2 | 102,258.0 | 2,248.5 | 1.00 | 1 |
| 02/05/2014 21:00 | 17,896.2 | 4,023.1 | 21,919.3 | 21,919.3 | 102,258.0 | 2,241.4 | 1.00 | 1 |
| 02/05/2014 22:00 | 17,886.1 | 4,015.1 | 21,901.2 | 21,901.2 | 102,258.0 | 2,239.6 | 1.00 | 1 |
| 02/05/2014 23:00 | 17,911.4 | 3,990.9 | 21,902.3 | 21,902.3 | 102,258.0 | 2,239.7 | 1.00 | 1 |
| **Average/Sum#:** | 17,254.7 | 2,184.0 | 19,413.7 | 465,928.0 # | 102,258.0 | 1,985.2 | 24.00 # | 24 # |
| **Minimum:** | 13,122.9 | 131.6 | 13,138.7 | 13,138.7 | 102,258.0 | 1,343.5 | 1.00 | 1 |
| **Maximum:** | 18,229.0 | 4,102.0 | 21,988.2 | 21,988.2 | 102,258.0 | 2,248.5 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/06/2014 00:00 | 17,953.4 | 3,512.9 | 21,466.3 | 21,466.3 | 102,258.0 | 2,195.1 | 1.00 | 1 |
| 02/06/2014 01:00 | 17,445.9 | 1,420.5 | 18,866.4 | 18,866.4 | 102,258.0 | 1,929.2 | 1.00 | 1 |
| 02/06/2014 02:00 | 16,567.3 | 1,205.9 | 17,773.2 | 17,773.2 | 102,258.0 | 1,817.5 | 1.00 | 1 |
| 02/06/2014 03:00 | 16,580.7 | 1,208.5 | 17,789.2 | 17,789.2 | 102,258.0 | 1,819.1 | 1.00 | 1 |
| 02/06/2014 04:00 | 16,599.5 | 1,209.1 | 17,808.6 | 17,808.6 | 102,258.0 | 1,821.1 | 1.00 | 1 |
| 02/06/2014 05:00 | 16,612.5 | 1,208.7 | 17,821.2 | 17,821.2 | 102,258.0 | 1,822.4 | 1.00 | 1 |
| 02/06/2014 06:00 | 16,708.2 | 1,209.3 | 17,917.5 | 17,917.5 | 102,258.0 | 1,832.2 | 1.00 | 1 |
| 02/06/2014 07:00 | 16,921.3 | 1,208.1 | 18,129.4 | 18,129.4 | 102,258.0 | 1,853.9 | 1.00 | 1 |
| 02/06/2014 08:00 | 17,478.4 | 1,273.5 | 18,751.9 | 18,751.9 | 102,258.0 | 1,917.5 | 1.00 | 1 |
| 02/06/2014 09:00 | 17,218.3 | 1,211.1 | 18,429.4 | 18,429.4 | 102,258.0 | 1,884.6 | 1.00 | 1 |
| 02/06/2014 10:00 | 16,818.1 | 1,193.4 | 18,011.5 | 18,011.5 | 102,258.0 | 1,841.8 | 1.00 | 1 |
| 02/06/2014 11:00 | 16,690.9 | 1,192.5 | 17,883.4 | 17,883.4 | 102,258.0 | 1,828.7 | 1.00 | 1 |
| 02/06/2014 12:00 | 16,631.1 | 1,191.5 | 17,822.6 | 17,822.6 | 102,258.0 | 1,822.5 | 1.00 | 1 |
| 02/06/2014 13:00 | 16,799.6 | 1,191.1 | 17,990.7 | 17,990.7 | 102,258.0 | 1,839.7 | 1.00 | 1 |
| 02/06/2014 14:00 | 16,791.2 | 1,185.0 | 17,976.2 | 17,976.2 | 102,258.0 | 1,838.2 | 1.00 | 1 |
| 02/06/2014 15:00 | 17,073.6 | 1,185.2 | 18,258.8 | 18,258.8 | 102,258.0 | 1,867.1 | 1.00 | 1 |
| 02/06/2014 16:00 | 16,735.4 | 1,185.5 | 17,920.9 | 17,920.9 | 102,258.0 | 1,832.6 | 1.00 | 1 |
| 02/06/2014 17:00 | 17,150.0 | 1,185.6 | 18,335.6 | 18,335.6 | 102,258.0 | 1,875.0 | 1.00 | 1 |
| 02/06/2014 18:00 | 16,908.4 | 1,180.0 | 18,088.4 | 18,088.4 | 102,258.0 | 1,849.7 | 1.00 | 1 |
| 02/06/2014 19:00 | 17,483.8 | 1,178.3 | 18,662.1 | 18,662.1 | 102,258.0 | 1,908.3 | 1.00 | 1 |
| 02/06/2014 20:00 | 16,960.6 | 1,177.1 | 18,137.7 | 18,137.7 | 102,258.0 | 1,854.7 | 1.00 | 1 |
| 02/06/2014 21:00 | 16,811.7 | 1,177.9 | 17,989.6 | 17,989.6 | 102,258.0 | 1,839.6 | 1.00 | 1 |
| 02/06/2014 22:00 | 16,829.8 | 1,177.2 | 18,007.0 | 18,007.0 | 102,258.0 | 1,841.4 | 1.00 | 1 |
| 02/06/2014 23:00 | 16,850.6 | 1,175.1 | 18,025.7 | 18,025.7 | 102,258.0 | 1,843.3 | 1.00 | 1 |
| **Average/Sum#:** | 16,942.5 | 1,301.8 | 18,244.3 | 437,863.3 # | 102,258.0 | 1,865.6 | 24.00 # | 24 # |
| **Minimum:** | 16,567.3 | 1,175.1 | 17,773.2 | 17,773.2 | 102,258.0 | 1,817.5 | 1.00 | 1 |
| **Maximum:** | 17,953.4 | 3,512.9 | 21,466.3 | 21,466.3 | 102,258.0 | 2,195.1 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/07/2014 00:00 | 16,831.3 | 1,176.4 | 18,007.7 | 18,007.7 | 102,258.0 | 1,841.4 | 1.00 | 1 |
| 02/07/2014 01:00 | 17,757.8 | 1,647.7 | 19,405.5 | 19,405.5 | 102,258.0 | 1,984.4 | 1.00 | 1 |
| 02/07/2014 02:00 | 17,880.5 | 2,046.8 | 19,927.3 | 19,927.3 | 102,258.0 | 2,037.7 | 1.00 | 1 |
| 02/07/2014 03:00 | 17,860.4 | 2,100.0 | 19,960.4 | 19,960.4 | 102,258.0 | 2,041.1 | 1.00 | 1 |
| 02/07/2014 04:00 | 17,797.6 | 3,593.6 | 21,391.2 | 21,391.2 | 102,258.0 | 2,187.4 | 1.00 | 1 |
| 02/07/2014 05:00 | 17,797.4 | 3,676.5 | 21,473.9 | 21,473.9 | 102,258.0 | 2,195.9 | 1.00 | 1 |
| 02/07/2014 06:00 | 17,809.9 | 4,104.5 | 21,914.4 | 21,914.4 | 102,258.0 | 2,240.9 | 1.00 | 1 |
| 02/07/2014 07:00 | 17,853.0 | 4,199.0 | 22,052.0 | 22,052.0 | 102,258.0 | 2,255.0 | 1.00 | 1 |
| 02/07/2014 08:00 | 17,857.7 | 4,233.6 | 22,091.3 | 22,091.3 | 102,258.0 | 2,259.0 | 1.00 | 1 |
| 02/07/2014 09:00 | 17,939.5 | 3,021.6 | 20,961.1 | 20,961.1 | 102,258.0 | 2,143.4 | 1.00 | 1 |
| 02/07/2014 10:00 | 17,942.2 | 1,815.9 | 19,758.1 | 19,758.1 | 102,258.0 | 2,020.4 | 1.00 | 1 |
| 02/07/2014 11:00 | 17,878.0 | 1,870.1 | 19,748.1 | 19,748.1 | 102,258.0 | 2,019.4 | 1.00 | 1 |
| 02/07/2014 12:00 | 17,822.5 | 2,174.2 | 19,996.7 | 19,996.7 | 102,258.0 | 2,044.8 | 1.00 | 1 |
| 02/07/2014 13:00 | 17,742.7 | 1,796.4 | 19,539.1 | 19,539.1 | 102,258.0 | 1,998.0 | 1.00 | 1 |
| 02/07/2014 14:00 | 17,343.9 | 1,450.4 | 18,794.3 | 18,794.3 | 102,258.0 | 1,921.9 | 1.00 | 1 |
| 02/07/2014 15:00 | 16,746.6 | 1,184.2 | 17,930.8 | 17,930.8 | 102,258.0 | 1,833.6 | 1.00 | 1 |
| 02/07/2014 16:00 | 17,738.7 | 1,861.4 | 19,600.1 | 19,600.1 | 102,258.0 | 2,004.3 | 1.00 | 1 |
| 02/07/2014 17:00 | 17,735.3 | 1,903.1 | 19,638.4 | 19,638.4 | 102,258.0 | 2,008.2 | 1.00 | 1 |
| 02/07/2014 18:00 | 17,742.7 | 2,453.5 | 20,196.2 | 20,196.2 | 102,258.0 | 2,065.2 | 1.00 | 1 |
| 02/07/2014 19:00 | 17,735.1 | 3,934.4 | 21,669.5 | 21,669.5 | 102,258.0 | 2,215.9 | 1.00 | 1 |
| 02/07/2014 20:00 | 17,689.3 | 2,408.8 | 20,098.1 | 20,098.1 | 102,258.0 | 2,055.2 | 1.00 | 1 |
| 02/07/2014 21:00 | 17,706.7 | 1,958.9 | 19,665.6 | 19,665.6 | 102,258.0 | 2,011.0 | 1.00 | 1 |
| 02/07/2014 22:00 | 17,703.8 | 1,966.2 | 19,670.0 | 19,670.0 | 102,258.0 | 2,011.4 | 1.00 | 1 |
| 02/07/2014 23:00 | 17,704.1 | 2,027.3 | 19,731.4 | 19,731.4 | 102,258.0 | 2,017.7 | 1.00 | 1 |
| **Average/Sum#:** | 17,692.4 | 2,441.9 | 20,134.2 | 483,221.2 # | 102,258.0 | 2,058.9 | 24.00 # | 24 # |
| **Minimum:** | 16,746.6 | 1,176.4 | 17,930.8 | 17,930.8 | 102,258.0 | 1,833.6 | 1.00 | 1 |
| **Maximum:** | 17,942.2 | 4,233.6 | 22,091.3 | 22,091.3 | 102,258.0 | 2,259.0 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/08/2014 00:00 | 17,658.0 | 1,099.3 | 18,757.3 | 18,757.3 | 102,258.0 | 1,918.1 | 1.00 | 1 |
| 02/08/2014 01:00 | 17,578.7 | 959.8 | 18,538.5 | 18,538.5 | 102,258.0 | 1,895.7 | 1.00 | 1 |
| 02/08/2014 02:00 | 17,601.2 | 653.7 | 18,254.9 | 18,254.9 | 102,258.0 | 1,866.7 | 1.00 | 1 |
| 02/08/2014 03:00 | 17,598.7 | 562.9 | 18,161.6 | 18,161.6 | 102,258.0 | 1,857.2 | 1.00 | 1 |
| 02/08/2014 04:00 | 17,656.8 | 562.2 | 18,219.0 | 18,219.0 | 102,258.0 | 1,863.0 | 1.00 | 1 |
| 02/08/2014 05:00 | 17,651.5 | 562.5 | 18,214.0 | 18,214.0 | 102,258.0 | 1,862.5 | 1.00 | 1 |
| 02/08/2014 06:00 | 17,346.6 | 693.9 | 18,040.5 | 18,040.5 | 102,258.0 | 1,844.8 | 1.00 | 1 |
| 02/08/2014 07:00 | 17,196.5 | 1,172.1 | 18,368.6 | 18,368.6 | 102,258.0 | 1,878.3 | 1.00 | 1 |
| 02/08/2014 08:00 | 16,721.1 | 1,178.1 | 17,899.2 | 17,899.2 | 102,258.0 | 1,830.3 | 1.00 | 1 |
| 02/08/2014 09:00 | 16,697.1 | 1,178.8 | 17,875.9 | 17,875.9 | 102,258.0 | 1,828.0 | 1.00 | 1 |
| 02/08/2014 10:00 | 16,623.7 | 1,178.5 | 17,802.2 | 17,802.2 | 102,258.0 | 1,820.4 | 1.00 | 1 |
| 02/08/2014 11:00 | 16,612.6 | 1,176.2 | 17,788.8 | 17,788.8 | 102,258.0 | 1,819.0 | 1.00 | 1 |
| 02/08/2014 12:00 | 16,611.5 | 1,171.0 | 17,782.5 | 17,782.5 | 102,258.0 | 1,818.4 | 1.00 | 1 |
| 02/08/2014 13:00 | 16,921.7 | 1,185.7 | 18,107.4 | 18,107.4 | 102,258.0 | 1,851.6 | 1.00 | 1 |
| 02/08/2014 14:00 | 16,551.6 | 1,179.7 | 17,731.3 | 17,731.3 | 102,258.0 | 1,813.2 | 1.00 | 1 |
| 02/08/2014 15:00 | 16,576.9 | 1,177.9 | 17,754.8 | 17,754.8 | 102,258.0 | 1,815.6 | 1.00 | 1 |
| 02/08/2014 16:00 | 16,573.9 | 1,176.7 | 17,750.6 | 17,750.6 | 102,258.0 | 1,815.1 | 1.00 | 1 |
| 02/08/2014 17:00 | 16,660.2 | 1,175.4 | 17,835.6 | 17,835.6 | 102,258.0 | 1,823.8 | 1.00 | 1 |
| 02/08/2014 18:00 | 17,425.8 | 1,385.9 | 18,811.7 | 18,811.7 | 102,258.0 | 1,923.6 | 1.00 | 1 |
| 02/08/2014 19:00 | 17,550.7 | 3,089.1 | 20,639.8 | 20,639.8 | 102,258.0 | 2,110.6 | 1.00 | 1 |
| 02/08/2014 20:00 | 17,567.6 | 2,229.3 | 19,796.9 | 19,796.9 | 102,258.0 | 2,024.4 | 1.00 | 1 |
| 02/08/2014 21:00 | 17,546.6 | 2,461.4 | 20,008.0 | 20,008.0 | 102,258.0 | 2,046.0 | 1.00 | 1 |
| 02/08/2014 22:00 | 17,260.9 | 1,200.8 | 18,461.7 | 18,461.7 | 102,258.0 | 1,887.9 | 1.00 | 1 |
| 02/08/2014 23:00 | 17,169.1 | 546.8 | 17,715.9 | 17,715.9 | 102,258.0 | 1,811.6 | 1.00 | 1 |
| **Average/Sum#:** | 17,140.0 | 1,206.6 | 18,346.5 | 440,316.7 # | 102,258.0 | 1,876.1 | 24.00 # | 24 # |
| **Minimum:** | 16,551.6 | 546.8 | 17,715.9 | 17,715.9 | 102,258.0 | 1,811.6 | 1.00 | 1 |
| **Maximum:** | 17,658.0 | 3,089.1 | 20,639.8 | 20,639.8 | 102,258.0 | 2,110.6 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/09/2014 00:00 | 17,050.0 | 573.6 | 17,623.6 | 17,623.6 | 102,258.0 | 1,802.2 | 1.00 | 1 |
| 02/09/2014 01:00 | 17,586.9 | 1,123.5 | 18,710.4 | 18,710.4 | 102,258.0 | 1,913.3 | 1.00 | 1 |
| 02/09/2014 02:00 | 17,229.1 | 533.5 | 17,762.6 | 17,762.6 | 102,258.0 | 1,816.4 | 1.00 | 1 |
| 02/09/2014 03:00 | 17,085.5 | 529.9 | 17,615.4 | 17,615.4 | 102,258.0 | 1,801.3 | 1.00 | 1 |
| 02/09/2014 04:00 | 17,076.5 | 530.0 | 17,606.5 | 17,606.5 | 102,258.0 | 1,800.4 | 1.00 | 1 |
| 02/09/2014 05:00 | 17,053.7 | 532.9 | 17,586.6 | 17,586.6 | 102,258.0 | 1,798.4 | 1.00 | 1 |
| 02/09/2014 06:00 | 17,009.5 | 706.1 | 17,715.6 | 17,715.6 | 102,258.0 | 1,811.6 | 1.00 | 1 |
| 02/09/2014 07:00 | 16,656.6 | 1,147.6 | 17,804.2 | 17,804.2 | 102,258.0 | 1,820.6 | 1.00 | 1 |
| 02/09/2014 08:00 | 16,651.0 | 1,150.3 | 17,801.3 | 17,801.3 | 102,258.0 | 1,820.3 | 1.00 | 1 |
| 02/09/2014 09:00 | 16,656.1 | 1,147.6 | 17,803.7 | 17,803.7 | 102,258.0 | 1,820.6 | 1.00 | 1 |
| 02/09/2014 10:00 | 16,699.7 | 1,143.8 | 17,843.5 | 17,843.5 | 102,258.0 | 1,824.6 | 1.00 | 1 |
| 02/09/2014 11:00 | 16,632.7 | 1,139.8 | 17,772.5 | 17,772.5 | 102,258.0 | 1,817.4 | 1.00 | 1 |
| 02/09/2014 12:00 | 16,582.6 | 1,139.1 | 17,721.7 | 17,721.7 | 102,258.0 | 1,812.2 | 1.00 | 1 |
| 02/09/2014 13:00 | 16,617.8 | 1,132.9 | 17,750.7 | 17,750.7 | 102,258.0 | 1,815.2 | 1.00 | 1 |
| 02/09/2014 14:00 | 16,667.8 | 1,129.7 | 17,797.5 | 17,797.5 | 102,258.0 | 1,819.9 | 1.00 | 1 |
| 02/09/2014 15:00 | 16,685.1 | 1,126.6 | 17,811.7 | 17,811.7 | 102,258.0 | 1,821.4 | 1.00 | 1 |
| 02/09/2014 16:00 | 16,903.1 | 1,182.7 | 18,085.8 | 18,085.8 | 102,258.0 | 1,849.4 | 1.00 | 1 |
| 02/09/2014 17:00 | 16,902.6 | 1,195.6 | 18,098.2 | 18,098.2 | 102,258.0 | 1,850.7 | 1.00 | 1 |
| 02/09/2014 18:00 | 17,183.5 | 1,780.9 | 18,964.4 | 18,964.4 | 102,258.0 | 1,939.3 | 1.00 | 1 |
| 02/09/2014 19:00 | 17,442.8 | 4,038.1 | 21,480.9 | 21,480.9 | 102,258.0 | 2,196.6 | 1.00 | 1 |
| 02/09/2014 20:00 | 17,469.2 | 4,124.9 | 21,594.1 | 21,594.1 | 102,258.0 | 2,208.2 | 1.00 | 1 |
| 02/09/2014 21:00 | 17,467.4 | 4,136.6 | 21,604.0 | 21,604.0 | 102,258.0 | 2,209.2 | 1.00 | 1 |
| 02/09/2014 22:00 | 17,477.3 | 3,077.2 | 20,554.5 | 20,554.5 | 102,258.0 | 2,101.9 | 1.00 | 1 |
| 02/09/2014 23:00 | 17,515.7 | 2,482.8 | 19,998.5 | 19,998.5 | 102,258.0 | 2,045.0 | 1.00 | 1 |
| **Average/Sum#:** | 17,012.6 | 1,533.6 | 18,546.2 | 445,107.9 # | 102,258.0 | 1,896.5 | 24.00 # | 24 # |
| **Minimum:** | 16,582.6 | 529.9 | 17,586.6 | 17,586.6 | 102,258.0 | 1,798.4 | 1.00 | 1 |
| **Maximum:** | 17,586.9 | 4,136.6 | 21,604.0 | 21,604.0 | 102,258.0 | 2,209.2 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/10/2014 00:00 | 14,385.1 | 234.9 | 14,455.6 | 14,455.6 | 102,258.0 | 1,478.2 | 1.00 | 1 |
| 02/10/2014 01:00 | 13,058.5 | 0.0 | 13,058.5 | 13,058.5 | 102,258.0 | 1,335.3 | 1.00 | 1 |
| 02/10/2014 02:00 | 13,342.3 | 0.0 | 13,342.3 | 13,342.3 | 102,258.0 | 1,364.4 | 1.00 | 1 |
| 02/10/2014 03:00 | 12,148.2 | 0.0 | 12,148.2 | 12,148.2 | 102,258.0 | 1,242.3 | 1.00 | 1 |
| 02/10/2014 04:00 | 12,148.7 | 0.0 | 12,148.7 | 12,148.7 | 102,258.0 | 1,242.3 | 1.00 | 1 |
| 02/10/2014 05:00 | 13,878.1 | 153.0 | 13,913.3 | 13,913.3 | 102,258.0 | 1,422.7 | 1.00 | 1 |
| 02/10/2014 06:00 | 17,229.7 | 866.0 | 18,095.7 | 18,095.7 | 102,258.0 | 1,850.4 | 1.00 | 1 |
| 02/10/2014 07:00 | 17,197.0 | 1,230.1 | 18,427.1 | 18,427.1 | 102,258.0 | 1,884.3 | 1.00 | 1 |
| 02/10/2014 08:00 | 17,752.2 | 1,389.2 | 19,141.4 | 19,141.4 | 102,258.0 | 1,957.4 | 1.00 | 1 |
| 02/10/2014 09:00 | 17,019.7 | 1,196.3 | 18,216.0 | 18,216.0 | 102,258.0 | 1,862.7 | 1.00 | 1 |
| 02/10/2014 10:00 | 16,944.5 | 1,183.1 | 18,127.6 | 18,127.6 | 102,258.0 | 1,853.7 | 1.00 | 1 |
| 02/10/2014 11:00 | 16,748.2 | 1,179.5 | 17,927.7 | 17,927.7 | 102,258.0 | 1,833.3 | 1.00 | 1 |
| 02/10/2014 12:00 | 16,798.4 | 1,180.9 | 17,979.3 | 17,979.3 | 102,258.0 | 1,838.5 | 1.00 | 1 |
| 02/10/2014 13:00 | 16,824.7 | 1,185.0 | 18,009.7 | 18,009.7 | 102,258.0 | 1,841.6 | 1.00 | 1 |
| 02/10/2014 14:00 | 16,856.1 | 1,187.7 | 18,043.8 | 18,043.8 | 102,258.0 | 1,845.1 | 1.00 | 1 |
| 02/10/2014 15:00 | 16,766.9 | 1,189.7 | 17,956.6 | 17,956.6 | 102,258.0 | 1,836.2 | 1.00 | 1 |
| 02/10/2014 16:00 | 16,754.6 | 1,190.5 | 17,945.1 | 17,945.1 | 102,258.0 | 1,835.0 | 1.00 | 1 |
| 02/10/2014 17:00 | 16,741.4 | 1,191.9 | 17,933.3 | 17,933.3 | 102,258.0 | 1,833.8 | 1.00 | 1 |
| 02/10/2014 18:00 | 17,119.8 | 1,241.2 | 18,361.0 | 18,361.0 | 102,258.0 | 1,877.6 | 1.00 | 1 |
| 02/10/2014 19:00 | 17,691.1 | 1,929.1 | 19,620.2 | 19,620.2 | 102,258.0 | 2,006.3 | 1.00 | 1 |
| 02/10/2014 20:00 | 17,699.0 | 2,051.8 | 19,750.8 | 19,750.8 | 102,258.0 | 2,019.7 | 1.00 | 1 |
| 02/10/2014 21:00 | 17,721.2 | 2,813.2 | 20,534.4 | 20,534.4 | 102,258.0 | 2,099.8 | 1.00 | 1 |
| 02/10/2014 22:00 | 17,684.7 | 1,620.8 | 19,305.5 | 19,305.5 | 102,258.0 | 1,974.1 | 1.00 | 1 |
| 02/10/2014 23:00 | 17,290.3 | 649.4 | 17,939.7 | 17,939.7 | 102,258.0 | 1,834.5 | 1.00 | 1 |
| **Average/Sum#:** | 16,158.4 | 1,036.0 | 17,182.6 | 412,381.5 # | 102,258.0 | 1,757.1 | 24.00 # | 24 # |
| **Minimum:** | 12,148.2 | 0.0 | 12,148.2 | 12,148.2 | 102,258.0 | 1,242.3 | 1.00 | 1 |
| **Maximum:** | 17,752.2 | 2,813.2 | 20,534.4 | 20,534.4 | 102,258.0 | 2,099.8 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/11/2014 00:00 | 16,847.4 | 751.1 | 17,598.5 | 17,598.5 | 102,258.0 | 1,799.6 | 1.00 | 1 |
| 02/11/2014 01:00 | 16,719.0 | 1,110.3 | 17,829.3 | 17,829.3 | 102,258.0 | 1,823.2 | 1.00 | 1 |
| 02/11/2014 02:00 | 16,714.1 | 985.8 | 17,699.9 | 17,699.9 | 102,258.0 | 1,810.0 | 1.00 | 1 |
| 02/11/2014 03:00 | 15,137.6 | 647.1 | 15,493.5 | 15,493.5 | 102,258.0 | 1,584.3 | 1.00 | 1 |
| 02/11/2014 04:00 | 12,186.5 | 0.0 | 12,186.5 | 12,186.5 | 102,258.0 | 1,246.2 | 1.00 | 1 |
| 02/11/2014 05:00 | 14,741.4 | 22.9 | 14,742.1 | 14,742.1 | 102,258.0 | 1,507.5 | 1.00 | 1 |
| 02/11/2014 06:00 | 16,580.1 | 1,201.9 | 17,782.0 | 17,782.0 | 102,258.0 | 1,818.4 | 1.00 | 1 |
| 02/11/2014 07:00 | 16,717.9 | 1,210.2 | 17,928.1 | 17,928.1 | 102,258.0 | 1,833.3 | 1.00 | 1 |
| 02/11/2014 08:00 | 17,873.5 | 1,893.5 | 19,767.0 | 19,767.0 | 102,258.0 | 2,021.3 | 1.00 | 1 |
| 02/11/2014 09:00 | 17,951.3 | 1,499.5 | 19,450.8 | 19,450.8 | 102,258.0 | 1,989.0 | 1.00 | 1 |
| 02/11/2014 10:00 | 17,090.1 | 1,182.3 | 18,272.4 | 18,272.4 | 102,258.0 | 1,868.5 | 1.00 | 1 |
| 02/11/2014 11:00 | 16,769.1 | 1,174.5 | 17,943.6 | 17,943.6 | 102,258.0 | 1,834.9 | 1.00 | 1 |
| 02/11/2014 12:00 | 16,836.4 | 1,173.1 | 18,009.5 | 18,009.5 | 102,258.0 | 1,841.6 | 1.00 | 1 |
| 02/11/2014 13:00 | 16,860.4 | 1,168.0 | 18,028.4 | 18,028.4 | 102,258.0 | 1,843.5 | 1.00 | 1 |
| 02/11/2014 14:00 | 16,866.6 | 1,174.6 | 18,041.2 | 18,041.2 | 102,258.0 | 1,844.9 | 1.00 | 1 |
| 02/11/2014 15:00 | 16,845.9 | 1,177.1 | 18,023.0 | 18,023.0 | 102,258.0 | 1,843.0 | 1.00 | 1 |
| 02/11/2014 16:00 | 16,747.0 | 1,177.4 | 17,924.4 | 17,924.4 | 102,258.0 | 1,832.9 | 1.00 | 1 |
| 02/11/2014 17:00 | 16,845.7 | 1,175.2 | 18,020.9 | 18,020.9 | 102,258.0 | 1,842.8 | 1.00 | 1 |
| 02/11/2014 18:00 | 17,129.7 | 1,179.2 | 18,308.9 | 18,308.9 | 102,258.0 | 1,872.2 | 1.00 | 1 |
| 02/11/2014 19:00 | 17,631.5 | 2,100.3 | 19,731.8 | 19,731.8 | 102,258.0 | 2,017.7 | 1.00 | 1 |
| 02/11/2014 20:00 | 17,677.8 | 2,140.5 | 19,818.3 | 19,818.3 | 102,258.0 | 2,026.6 | 1.00 | 1 |
| 02/11/2014 21:00 | 17,688.3 | 2,884.5 | 20,572.8 | 20,572.8 | 102,258.0 | 2,103.7 | 1.00 | 1 |
| 02/11/2014 22:00 | 17,692.3 | 1,819.8 | 19,512.1 | 19,512.1 | 102,258.0 | 1,995.3 | 1.00 | 1 |
| 02/11/2014 23:00 | 17,497.5 | 1,294.3 | 18,791.8 | 18,791.8 | 102,258.0 | 1,921.6 | 1.00 | 1 |
| **Average/Sum#:** | 16,735.3 | 1,256.0 | 17,978.2 | 431,476.8 # | 102,258.0 | 1,838.4 | 24.00 # | 24 # |
| **Minimum:** | 12,186.5 | 0.0 | 12,186.5 | 12,186.5 | 102,258.0 | 1,246.2 | 1.00 | 1 |
| **Maximum:** | 17,951.3 | 2,884.5 | 20,572.8 | 20,572.8 | 102,258.0 | 2,103.7 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/12/2014 00:00 | 16,931.9 | 1,203.5 | 18,135.4 | 18,135.4 | 102,258.0 | 1,854.5 | 1.00 | 1 |
| 02/12/2014 01:00 | 17,805.1 | 1,513.4 | 19,318.5 | 19,318.5 | 102,258.0 | 1,975.5 | 1.00 | 1 |
| 02/12/2014 02:00 | 17,880.8 | 1,507.9 | 19,388.7 | 19,388.7 | 102,258.0 | 1,982.6 | 1.00 | 1 |
| 02/12/2014 03:00 | 17,871.3 | 1,623.0 | 19,494.3 | 19,494.3 | 102,258.0 | 1,993.4 | 1.00 | 1 |
| 02/12/2014 04:00 | 17,859.9 | 1,740.1 | 19,600.0 | 19,600.0 | 102,258.0 | 2,004.3 | 1.00 | 1 |
| 02/12/2014 05:00 | 17,873.1 | 1,663.2 | 19,536.3 | 19,536.3 | 102,258.0 | 1,997.7 | 1.00 | 1 |
| 02/12/2014 06:00 | 17,695.8 | 1,371.5 | 19,067.3 | 19,067.3 | 102,258.0 | 1,949.8 | 1.00 | 1 |
| 02/12/2014 07:00 | 17,876.6 | 2,089.1 | 19,965.7 | 19,965.7 | 102,258.0 | 2,041.7 | 1.00 | 1 |
| 02/12/2014 08:00 | 17,868.1 | 1,901.2 | 19,769.3 | 19,769.3 | 102,258.0 | 2,021.6 | 1.00 | 1 |
| 02/12/2014 09:00 | 17,066.3 | 1,228.6 | 18,294.9 | 18,294.9 | 102,258.0 | 1,870.8 | 1.00 | 1 |
| 02/12/2014 10:00 | 16,643.9 | 1,195.1 | 17,839.0 | 17,839.0 | 102,258.0 | 1,824.2 | 1.00 | 1 |
| 02/12/2014 11:00 | 16,643.5 | 1,193.4 | 17,836.9 | 17,836.9 | 102,258.0 | 1,824.0 | 1.00 | 1 |
| 02/12/2014 12:00 | 16,681.6 | 1,189.8 | 17,871.4 | 17,871.4 | 102,258.0 | 1,827.5 | 1.00 | 1 |
| 02/12/2014 13:00 | 16,668.1 | 1,180.2 | 17,848.3 | 17,848.3 | 102,258.0 | 1,825.1 | 1.00 | 1 |
| 02/12/2014 14:00 | 16,704.7 | 1,177.2 | 17,881.9 | 17,881.9 | 102,258.0 | 1,828.6 | 1.00 | 1 |
| 02/12/2014 15:00 | 16,721.8 | 1,175.6 | 17,897.4 | 17,897.4 | 102,258.0 | 1,830.2 | 1.00 | 1 |
| 02/12/2014 16:00 | 16,715.6 | 1,172.4 | 17,888.0 | 17,888.0 | 102,258.0 | 1,829.2 | 1.00 | 1 |
| 02/12/2014 17:00 | 16,917.0 | 1,168.3 | 18,085.3 | 18,085.3 | 102,258.0 | 1,849.4 | 1.00 | 1 |
| 02/12/2014 18:00 | 17,460.9 | 2,488.6 | 19,949.5 | 19,949.5 | 102,258.0 | 2,040.0 | 1.00 | 1 |
| 02/12/2014 19:00 | 17,584.9 | 4,189.3 | 21,774.2 | 21,774.2 | 102,258.0 | 2,226.6 | 1.00 | 1 |
| 02/12/2014 20:00 | 17,647.4 | 3,993.2 | 21,640.6 | 21,640.6 | 102,258.0 | 2,212.9 | 1.00 | 1 |
| 02/12/2014 21:00 | 17,709.9 | 3,520.5 | 21,230.4 | 21,230.4 | 102,258.0 | 2,171.0 | 1.00 | 1 |
| 02/12/2014 22:00 | 17,759.4 | 2,534.8 | 20,294.2 | 20,294.2 | 102,258.0 | 2,075.2 | 1.00 | 1 |
| 02/12/2014 23:00 | 17,656.3 | 1,395.2 | 19,051.5 | 19,051.5 | 102,258.0 | 1,948.2 | 1.00 | 1 |
| **Average/Sum#:** | 17,343.5 | 1,809.0 | 19,152.5 | 459,659.0 # | 102,258.0 | 1,958.5 | 24.00 # | 24 # |
| **Minimum:** | 16,643.5 | 1,168.3 | 17,836.9 | 17,836.9 | 102,258.0 | 1,824.0 | 1.00 | 1 |
| **Maximum:** | 17,880.8 | 4,189.3 | 21,774.2 | 21,774.2 | 102,258.0 | 2,226.6 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/13/2014 00:00 | 17,038.0 | 1,201.4 | 18,239.4 | 18,239.4 | 102,258.0 | 1,865.1 | 1.00 | 1 |
| 02/13/2014 01:00 | 16,670.2 | 1,203.7 | 17,873.9 | 17,873.9 | 102,258.0 | 1,827.7 | 1.00 | 1 |
| 02/13/2014 02:00 | 16,618.6 | 1,203.6 | 17,822.2 | 17,822.2 | 102,258.0 | 1,822.5 | 1.00 | 1 |
| 02/13/2014 03:00 | 16,618.7 | 1,203.0 | 17,821.7 | 17,821.7 | 102,258.0 | 1,822.4 | 1.00 | 1 |
| 02/13/2014 04:00 | 16,553.9 | 1,198.4 | 17,752.3 | 17,752.3 | 102,258.0 | 1,815.3 | 1.00 | 1 |
| 02/13/2014 05:00 | 16,764.9 | 1,195.9 | 17,960.8 | 17,960.8 | 102,258.0 | 1,836.6 | 1.00 | 1 |
| 02/13/2014 06:00 | 17,246.0 | 1,288.9 | 18,534.9 | 18,534.9 | 102,258.0 | 1,895.3 | 1.00 | 1 |
| 02/13/2014 07:00 | 17,811.1 | 2,631.4 | 20,442.5 | 20,442.5 | 102,258.0 | 2,090.4 | 1.00 | 1 |
| 02/13/2014 08:00 | 17,823.1 | 3,826.7 | 21,649.8 | 21,649.8 | 102,258.0 | 2,213.9 | 1.00 | 1 |
| 02/13/2014 09:00 | 17,804.5 | 2,885.8 | 20,690.3 | 20,690.3 | 102,258.0 | 2,115.7 | 1.00 | 1 |
| 02/13/2014 10:00 | 17,795.7 | 2,694.1 | 20,489.8 | 20,489.8 | 102,258.0 | 2,095.2 | 1.00 | 1 |
| 02/13/2014 11:00 | 17,802.9 | 2,698.3 | 20,501.2 | 20,501.2 | 102,258.0 | 2,096.4 | 1.00 | 1 |
| 02/13/2014 12:00 | 17,793.7 | 2,740.6 | 20,534.3 | 20,534.3 | 102,258.0 | 2,099.8 | 1.00 | 1 |
| 02/13/2014 13:00 | 17,760.9 | 2,762.5 | 20,523.4 | 20,523.4 | 102,258.0 | 2,098.7 | 1.00 | 1 |
| 02/13/2014 14:00 | 17,724.4 | 2,820.4 | 20,544.8 | 20,544.8 | 102,258.0 | 2,100.9 | 1.00 | 1 |
| 02/13/2014 15:00 | 17,635.5 | 2,878.9 | 20,514.4 | 20,514.4 | 102,258.0 | 2,097.8 | 1.00 | 1 |
| 02/13/2014 16:00 | 17,627.6 | 2,925.3 | 20,552.9 | 20,552.9 | 102,258.0 | 2,101.7 | 1.00 | 1 |
| 02/13/2014 17:00 | 17,645.5 | 3,083.1 | 20,728.6 | 20,728.6 | 102,258.0 | 2,119.7 | 1.00 | 1 |
| 02/13/2014 18:00 | 17,654.8 | 2,960.3 | 20,615.1 | 20,615.1 | 102,258.0 | 2,108.1 | 1.00 | 1 |
| 02/13/2014 19:00 | 17,657.2 | 3,685.8 | 21,343.0 | 21,343.0 | 102,258.0 | 2,182.5 | 1.00 | 1 |
| 02/13/2014 20:00 | 17,637.9 | 4,164.8 | 21,802.7 | 21,802.7 | 102,258.0 | 2,229.5 | 1.00 | 1 |
| 02/13/2014 21:00 | 17,660.2 | 4,152.0 | 21,812.2 | 21,812.2 | 102,258.0 | 2,230.5 | 1.00 | 1 |
| 02/13/2014 22:00 | 17,682.4 | 3,315.2 | 20,997.6 | 20,997.6 | 102,258.0 | 2,147.2 | 1.00 | 1 |
| 02/13/2014 23:00 | 17,719.7 | 2,794.0 | 20,513.7 | 20,513.7 | 102,258.0 | 2,097.7 | 1.00 | 1 |
| **Average/Sum#:** | 17,447.8 | 2,563.1 | 20,010.9 | 480,261.5 # | 102,258.0 | 2,046.3 | 24.00 # | 24 # |
| **Minimum:** | 16,553.9 | 1,195.9 | 17,752.3 | 17,752.3 | 102,258.0 | 1,815.3 | 1.00 | 1 |
| **Maximum:** | 17,823.1 | 4,164.8 | 21,812.2 | 21,812.2 | 102,258.0 | 2,230.5 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/14/2014 00:00 | 17,579.6 | 1,945.7 | 19,525.3 | 19,525.3 | 102,258.0 | 1,996.6 | 1.00 | 1 |
| 02/14/2014 01:00 | 16,546.5 | 1,179.4 | 17,725.9 | 17,725.9 | 102,258.0 | 1,812.6 | 1.00 | 1 |
| 02/14/2014 02:00 | 16,771.7 | 1,179.6 | 17,951.3 | 17,951.3 | 102,258.0 | 1,835.7 | 1.00 | 1 |
| 02/14/2014 03:00 | 16,574.2 | 1,180.8 | 17,755.0 | 17,755.0 | 102,258.0 | 1,815.6 | 1.00 | 1 |
| 02/14/2014 04:00 | 16,568.1 | 1,181.7 | 17,749.8 | 17,749.8 | 102,258.0 | 1,815.1 | 1.00 | 1 |
| 02/14/2014 05:00 | 16,625.8 | 1,172.6 | 17,798.4 | 17,798.4 | 102,258.0 | 1,820.0 | 1.00 | 1 |
| 02/14/2014 06:00 | 16,773.5 | 1,171.5 | 17,945.0 | 17,945.0 | 102,258.0 | 1,835.0 | 1.00 | 1 |
| 02/14/2014 07:00 | 17,227.7 | 1,144.0 | 18,371.7 | 18,371.7 | 102,258.0 | 1,878.7 | 1.00 | 1 |
| 02/14/2014 08:00 | 17,517.5 | 1,717.9 | 19,235.4 | 19,235.4 | 102,258.0 | 1,967.0 | 1.00 | 1 |
| 02/14/2014 09:00 | 17,572.8 | 2,787.8 | 20,360.6 | 20,360.6 | 102,258.0 | 2,082.0 | 1.00 | 1 |
| 02/14/2014 10:00 | 17,478.5 | 3,179.1 | 20,657.6 | 20,657.6 | 102,258.0 | 2,112.4 | 1.00 | 1 |
| 02/14/2014 11:00 | 17,421.5 | 3,293.4 | 20,714.9 | 20,714.9 | 102,258.0 | 2,118.3 | 1.00 | 1 |
| 02/14/2014 12:00 | 17,328.2 | 3,411.9 | 20,740.1 | 20,740.1 | 102,258.0 | 2,120.8 | 1.00 | 1 |
| 02/14/2014 13:00 | 17,308.3 | 3,506.0 | 20,814.3 | 20,814.3 | 102,258.0 | 2,128.4 | 1.00 | 1 |
| 02/14/2014 14:00 | 17,321.3 | 3,520.5 | 20,841.8 | 20,841.8 | 102,258.0 | 2,131.2 | 1.00 | 1 |
| 02/14/2014 15:00 | 17,264.1 | 3,593.2 | 20,857.3 | 20,857.3 | 102,258.0 | 2,132.8 | 1.00 | 1 |
| 02/14/2014 16:00 | 17,283.3 | 2,431.4 | 19,301.4 | 19,301.4 | 102,258.0 | 1,973.7 | 1.00 | 1 |
| 02/14/2014 17:00 | 17,290.9 | 3,414.7 | 20,705.6 | 20,705.6 | 102,258.0 | 2,117.3 | 1.00 | 1 |
| 02/14/2014 18:00 | 17,328.6 | 3,367.6 | 20,696.2 | 20,696.2 | 102,258.0 | 2,116.4 | 1.00 | 1 |
| 02/14/2014 19:00 | 17,403.0 | 2,581.2 | 19,984.2 | 19,984.2 | 102,258.0 | 2,043.5 | 1.00 | 1 |
| 02/14/2014 20:00 | 17,514.5 | 2,402.9 | 19,917.4 | 19,917.4 | 102,258.0 | 2,036.7 | 1.00 | 1 |
| 02/14/2014 21:00 | 17,568.4 | 2,916.9 | 20,485.3 | 20,485.3 | 102,258.0 | 2,094.8 | 1.00 | 1 |
| 02/14/2014 22:00 | 17,613.1 | 2,994.7 | 20,607.8 | 20,607.8 | 102,258.0 | 2,107.3 | 1.00 | 1 |
| 02/14/2014 23:00 | 17,627.3 | 2,138.0 | 19,765.3 | 19,765.3 | 102,258.0 | 2,021.2 | 1.00 | 1 |
| **Average/Sum#:** | 17,229.5 | 2,392.2 | 19,604.5 | 470,507.6 # | 102,258.0 | 2,004.7 | 24.00 # | 24 # |
| **Minimum:** | 16,546.5 | 1,144.0 | 17,725.9 | 17,725.9 | 102,258.0 | 1,812.6 | 1.00 | 1 |
| **Maximum:** | 17,627.3 | 3,593.2 | 20,857.3 | 20,857.3 | 102,258.0 | 2,132.8 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/15/2014 00:00 | 17,634.5 | 1,961.4 | 19,595.9 | 19,595.9 | 102,258.0 | 2,003.8 | 1.00 | 1 |
| 02/15/2014 01:00 | 17,625.6 | 2,601.5 | 20,227.1 | 20,227.1 | 102,258.0 | 2,068.4 | 1.00 | 1 |
| 02/15/2014 02:00 | 17,630.2 | 3,683.2 | 21,313.4 | 21,313.4 | 102,258.0 | 2,179.5 | 1.00 | 1 |
| 02/15/2014 03:00 | 17,636.5 | 3,842.2 | 21,478.7 | 21,478.7 | 102,258.0 | 2,196.4 | 1.00 | 1 |
| 02/15/2014 04:00 | 17,643.7 | 2,335.1 | 19,978.8 | 19,978.8 | 102,258.0 | 2,043.0 | 1.00 | 1 |
| 02/15/2014 05:00 | 17,642.7 | 1,917.5 | 19,560.2 | 19,560.2 | 102,258.0 | 2,000.2 | 1.00 | 1 |
| 02/15/2014 06:00 | 17,590.6 | 2,282.6 | 19,873.2 | 19,873.2 | 102,258.0 | 2,032.2 | 1.00 | 1 |
| 02/15/2014 07:00 | 17,591.9 | 1,668.8 | 19,260.7 | 19,260.7 | 102,258.0 | 1,969.6 | 1.00 | 1 |
| 02/15/2014 08:00 | 17,632.3 | 1,796.3 | 19,428.6 | 19,428.6 | 102,258.0 | 1,986.7 | 1.00 | 1 |
| 02/15/2014 09:00 | 17,677.4 | 2,189.2 | 19,866.6 | 19,866.6 | 102,258.0 | 2,031.5 | 1.00 | 1 |
| 02/15/2014 10:00 | 17,646.6 | 3,014.1 | 20,660.7 | 20,660.7 | 102,258.0 | 2,112.7 | 1.00 | 1 |
| 02/15/2014 11:00 | 17,583.9 | 4,062.3 | 21,646.2 | 21,646.2 | 102,258.0 | 2,213.5 | 1.00 | 1 |
| 02/15/2014 12:00 | 17,498.2 | 4,084.8 | 21,583.0 | 21,583.0 | 102,258.0 | 2,207.0 | 1.00 | 1 |
| 02/15/2014 13:00 | 17,433.4 | 3,637.1 | 21,070.5 | 21,070.5 | 102,258.0 | 2,154.6 | 1.00 | 1 |
| 02/15/2014 14:00 | 17,367.9 | 2,353.5 | 19,721.4 | 19,721.4 | 102,258.0 | 2,016.7 | 1.00 | 1 |
| 02/15/2014 15:00 | 17,346.3 | 2,165.9 | 19,512.2 | 19,512.2 | 102,258.0 | 1,995.3 | 1.00 | 1 |
| 02/15/2014 16:00 | 17,351.1 | 1,864.5 | 19,215.6 | 19,215.6 | 102,258.0 | 1,964.9 | 1.00 | 1 |
| 02/15/2014 17:00 | 17,344.7 | 2,152.5 | 19,497.2 | 19,497.2 | 102,258.0 | 1,993.7 | 1.00 | 1 |
| 02/15/2014 18:00 | 17,394.7 | 2,764.3 | 20,159.0 | 20,159.0 | 102,258.0 | 2,061.4 | 1.00 | 1 |
| 02/15/2014 19:00 | 17,416.5 | 4,066.0 | 21,482.5 | 21,482.5 | 102,258.0 | 2,196.8 | 1.00 | 1 |
| 02/15/2014 20:00 | 17,452.6 | 3,812.2 | 21,264.8 | 21,264.8 | 102,258.0 | 2,174.5 | 1.00 | 1 |
| 02/15/2014 21:00 | 17,479.0 | 3,915.5 | 21,394.5 | 21,394.5 | 102,258.0 | 2,187.8 | 1.00 | 1 |
| 02/15/2014 22:00 | 17,496.3 | 3,012.9 | 20,509.2 | 20,509.2 | 102,258.0 | 2,097.2 | 1.00 | 1 |
| 02/15/2014 23:00 | 17,121.4 | 1,425.9 | 18,547.3 | 18,547.3 | 102,258.0 | 1,896.6 | 1.00 | 1 |
| **Average/Sum#:** | 17,509.9 | 2,775.4 | 20,285.3 | 486,847.3 # | 102,258.0 | 2,074.3 | 24.00 # | 24 # |
| **Minimum:** | 17,121.4 | 1,425.9 | 18,547.3 | 18,547.3 | 102,258.0 | 1,896.6 | 1.00 | 1 |
| **Maximum:** | 17,677.4 | 4,084.8 | 21,646.2 | 21,646.2 | 102,258.0 | 2,213.5 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/16/2014 00:00 | 16,757.4 | 1,171.5 | 17,928.9 | 17,928.9 | 102,258.0 | 1,833.4 | 1.00 | 1 |
| 02/16/2014 01:00 | 16,903.6 | 1,173.2 | 18,076.8 | 18,076.8 | 102,258.0 | 1,848.5 | 1.00 | 1 |
| 02/16/2014 02:00 | 17,128.9 | 1,263.0 | 18,391.9 | 18,391.9 | 102,258.0 | 1,880.7 | 1.00 | 1 |
| 02/16/2014 03:00 | 16,072.0 | 810.2 | 16,639.1 | 16,639.1 | 102,258.0 | 1,701.5 | 1.00 | 1 |
| 02/16/2014 04:00 | 12,458.8 | 0.0 | 12,458.8 | 12,458.8 | 102,258.0 | 1,274.0 | 1.00 | 1 |
| 02/16/2014 05:00 | 14,399.8 | 0.0 | 14,399.8 | 14,399.8 | 102,258.0 | 1,472.5 | 1.00 | 1 |
| 02/16/2014 06:00 | 15,869.3 | 469.6 | 16,071.2 | 16,071.2 | 102,258.0 | 1,643.4 | 1.00 | 1 |
| 02/16/2014 07:00 | 17,829.0 | 1,246.9 | 19,075.9 | 19,075.9 | 102,258.0 | 1,950.7 | 1.00 | 1 |
| 02/16/2014 08:00 | 17,556.1 | 724.2 | 18,280.3 | 18,280.3 | 102,258.0 | 1,869.3 | 1.00 | 1 |
| 02/16/2014 09:00 | 17,285.4 | 575.6 | 17,861.0 | 17,861.0 | 102,258.0 | 1,826.4 | 1.00 | 1 |
| 02/16/2014 10:00 | 17,181.3 | 572.2 | 17,753.5 | 17,753.5 | 102,258.0 | 1,815.4 | 1.00 | 1 |
| 02/16/2014 11:00 | 17,177.0 | 568.6 | 17,745.6 | 17,745.6 | 102,258.0 | 1,814.6 | 1.00 | 1 |
| 02/16/2014 12:00 | 17,187.6 | 565.5 | 17,753.1 | 17,753.1 | 102,258.0 | 1,815.4 | 1.00 | 1 |
| 02/16/2014 13:00 | 17,160.4 | 558.4 | 17,718.8 | 17,718.8 | 102,258.0 | 1,811.9 | 1.00 | 1 |
| 02/16/2014 14:00 | 17,184.4 | 572.3 | 17,756.7 | 17,756.7 | 102,258.0 | 1,815.8 | 1.00 | 1 |
| 02/16/2014 15:00 | 17,344.2 | 575.7 | 17,919.9 | 17,919.9 | 102,258.0 | 1,832.5 | 1.00 | 1 |
| 02/16/2014 16:00 | 17,232.7 | 581.1 | 17,813.8 | 17,813.8 | 102,258.0 | 1,821.6 | 1.00 | 1 |
| 02/16/2014 17:00 | 17,264.9 | 614.4 | 17,879.3 | 17,879.3 | 102,258.0 | 1,828.3 | 1.00 | 1 |
| 02/16/2014 18:00 | 17,369.3 | 1,435.3 | 18,804.6 | 18,804.6 | 102,258.0 | 1,922.9 | 1.00 | 1 |
| 02/16/2014 19:00 | 17,758.8 | 3,612.3 | 21,371.1 | 21,371.1 | 102,258.0 | 2,185.4 | 1.00 | 1 |
| 02/16/2014 20:00 | 17,644.9 | 3,899.6 | 21,544.5 | 21,544.5 | 102,258.0 | 2,203.1 | 1.00 | 1 |
| 02/16/2014 21:00 | 17,668.3 | 3,868.1 | 21,536.4 | 21,536.4 | 102,258.0 | 2,202.3 | 1.00 | 1 |
| 02/16/2014 22:00 | 17,718.6 | 3,832.9 | 21,551.5 | 21,551.5 | 102,258.0 | 2,203.8 | 1.00 | 1 |
| 02/16/2014 23:00 | 17,604.1 | 1,992.6 | 19,596.7 | 19,596.7 | 102,258.0 | 2,003.9 | 1.00 | 1 |
| **Average/Sum#:** | 16,906.5 | 1,278.5 | 18,163.7 | 435,929.2 # | 102,258.0 | 1,857.4 | 24.00 # | 24 # |
| **Minimum:** | 12,458.8 | 0.0 | 12,458.8 | 12,458.8 | 102,258.0 | 1,274.0 | 1.00 | 1 |
| **Maximum:** | 17,829.0 | 3,899.6 | 21,551.5 | 21,551.5 | 102,258.0 | 2,203.8 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/17/2014 00:00 | 16,829.9 | 1,189.3 | 18,019.2 | 18,019.2 | 102,258.0 | 1,842.6 | 1.00 | 1 |
| 02/17/2014 01:00 | 16,690.5 | 1,194.6 | 17,885.1 | 17,885.1 | 102,258.0 | 1,828.9 | 1.00 | 1 |
| 02/17/2014 02:00 | 16,495.7 | 780.2 | 17,018.4 | 17,018.4 | 102,258.0 | 1,740.3 | 1.00 | 1 |
| 02/17/2014 03:00 | 12,672.5 | 0.0 | 12,672.5 | 12,672.5 | 102,258.0 | 1,295.9 | 1.00 | 1 |
| 02/17/2014 04:00 | 13,396.1 | 0.0 | 13,396.1 | 13,396.1 | 102,258.0 | 1,369.9 | 1.00 | 1 |
| 02/17/2014 05:00 | 15,146.3 | 542.2 | 15,401.1 | 15,401.1 | 102,258.0 | 1,574.9 | 1.00 | 1 |
| 02/17/2014 06:00 | 17,778.3 | 1,317.1 | 19,095.4 | 19,095.4 | 102,258.0 | 1,952.7 | 1.00 | 1 |
| 02/17/2014 07:00 | 17,818.3 | 1,658.5 | 19,476.8 | 19,476.8 | 102,258.0 | 1,991.7 | 1.00 | 1 |
| 02/17/2014 08:00 | 17,597.9 | 1,491.5 | 19,089.4 | 19,089.4 | 102,258.0 | 1,952.0 | 1.00 | 1 |
| 02/17/2014 09:00 | 17,257.5 | 1,186.7 | 18,444.2 | 18,444.2 | 102,258.0 | 1,886.1 | 1.00 | 1 |
| 02/17/2014 10:00 | 16,637.8 | 1,176.4 | 17,814.2 | 17,814.2 | 102,258.0 | 1,821.6 | 1.00 | 1 |
| 02/17/2014 11:00 | 16,639.6 | 1,173.0 | 17,812.6 | 17,812.6 | 102,258.0 | 1,821.5 | 1.00 | 1 |
| 02/17/2014 12:00 | 16,694.3 | 1,167.8 | 17,862.1 | 17,862.1 | 102,258.0 | 1,826.5 | 1.00 | 1 |
| 02/17/2014 13:00 | 16,696.8 | 1,168.2 | 17,865.0 | 17,865.0 | 102,258.0 | 1,826.8 | 1.00 | 1 |
| 02/17/2014 14:00 | 16,698.9 | 1,177.1 | 17,876.0 | 17,876.0 | 102,258.0 | 1,828.0 | 1.00 | 1 |
| 02/17/2014 15:00 | 16,702.0 | 1,177.5 | 17,879.5 | 17,879.5 | 102,258.0 | 1,828.3 | 1.00 | 1 |
| 02/17/2014 16:00 | 16,685.8 | 1,178.3 | 17,864.1 | 17,864.1 | 102,258.0 | 1,826.7 | 1.00 | 1 |
| 02/17/2014 17:00 | 16,679.9 | 1,180.1 | 17,860.0 | 17,860.0 | 102,258.0 | 1,826.3 | 1.00 | 1 |
| 02/17/2014 18:00 | 16,886.3 | 1,186.1 | 18,072.4 | 18,072.4 | 102,258.0 | 1,848.0 | 1.00 | 1 |
| 02/17/2014 19:00 | 17,268.4 | 1,201.5 | 18,469.9 | 18,469.9 | 102,258.0 | 1,888.7 | 1.00 | 1 |
| 02/17/2014 20:00 | 17,696.9 | 2,286.9 | 19,983.8 | 19,983.8 | 102,258.0 | 2,043.5 | 1.00 | 1 |
| 02/17/2014 21:00 | 17,736.5 | 3,448.5 | 21,185.0 | 21,185.0 | 102,258.0 | 2,166.3 | 1.00 | 1 |
| 02/17/2014 22:00 | 17,752.2 | 1,924.1 | 19,676.3 | 19,676.3 | 102,258.0 | 2,012.1 | 1.00 | 1 |
| 02/17/2014 23:00 | 17,112.4 | 1,257.9 | 18,370.3 | 18,370.3 | 102,258.0 | 1,878.5 | 1.00 | 1 |
| **Average/Sum#:** | 16,648.8 | 1,252.6 | 17,878.7 | 429,089.4 # | 102,258.0 | 1,828.2 | 24.00 # | 24 # |
| **Minimum:** | 12,672.5 | 0.0 | 12,672.5 | 12,672.5 | 102,258.0 | 1,295.9 | 1.00 | 1 |
| **Maximum:** | 17,818.3 | 3,448.5 | 21,185.0 | 21,185.0 | 102,258.0 | 2,166.3 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/18/2014 00:00 | 16,722.2 | 1,198.3 | 17,920.5 | 17,920.5 | 102,258.0 | 1,832.5 | 1.00 | 1 |
| 02/18/2014 01:00 | 16,654.6 | 1,197.1 | 17,851.7 | 17,851.7 | 102,258.0 | 1,825.5 | 1.00 | 1 |
| 02/18/2014 02:00 | 16,639.4 | 1,196.0 | 17,835.4 | 17,835.4 | 102,258.0 | 1,823.8 | 1.00 | 1 |
| 02/18/2014 03:00 | 16,637.0 | 1,191.1 | 17,828.1 | 17,828.1 | 102,258.0 | 1,823.1 | 1.00 | 1 |
| 02/18/2014 04:00 | 16,604.1 | 1,194.0 | 17,798.1 | 17,798.1 | 102,258.0 | 1,820.0 | 1.00 | 1 |
| 02/18/2014 05:00 | 16,603.1 | 1,200.8 | 17,803.9 | 17,803.9 | 102,258.0 | 1,820.6 | 1.00 | 1 |
| 02/18/2014 06:00 | 16,982.8 | 1,234.4 | 18,217.2 | 18,217.2 | 102,258.0 | 1,862.9 | 1.00 | 1 |
| 02/18/2014 07:00 | 17,730.8 | 2,004.7 | 19,735.5 | 19,735.5 | 102,258.0 | 2,018.1 | 1.00 | 1 |
| 02/18/2014 08:00 | 17,789.2 | 2,584.6 | 20,373.8 | 20,373.8 | 102,258.0 | 2,083.4 | 1.00 | 1 |
| 02/18/2014 09:00 | 17,643.6 | 1,454.1 | 19,097.7 | 19,097.7 | 102,258.0 | 1,952.9 | 1.00 | 1 |
| 02/18/2014 10:00 | 17,620.2 | 1,426.1 | 19,046.3 | 19,046.3 | 102,258.0 | 1,947.6 | 1.00 | 1 |
| 02/18/2014 11:00 | 17,431.7 | 2,072.5 | 19,504.2 | 19,504.2 | 102,258.0 | 1,994.5 | 1.00 | 1 |
| 02/18/2014 12:00 | 17,526.0 | 2,362.4 | 19,888.4 | 19,888.4 | 102,258.0 | 2,033.7 | 1.00 | 1 |
| 02/18/2014 13:00 | 17,331.4 | 1,694.2 | 19,025.6 | 19,025.6 | 102,258.0 | 1,945.5 | 1.00 | 1 |
| 02/18/2014 14:00 | 16,680.7 | 1,170.6 | 17,851.3 | 17,851.3 | 102,258.0 | 1,825.4 | 1.00 | 1 |
| 02/18/2014 15:00 | 16,787.1 | 1,171.0 | 17,958.1 | 17,958.1 | 102,258.0 | 1,836.4 | 1.00 | 1 |
| 02/18/2014 16:00 | 16,424.3 | 1,168.0 | 17,592.3 | 17,592.3 | 102,258.0 | 1,799.0 | 1.00 | 1 |
| 02/18/2014 17:00 | 17,007.8 | 1,807.9 | 18,815.7 | 18,815.7 | 102,258.0 | 1,924.1 | 1.00 | 1 |
| 02/18/2014 18:00 | 17,356.6 | 3,575.9 | 20,932.5 | 20,932.5 | 102,258.0 | 2,140.5 | 1.00 | 1 |
| 02/18/2014 19:00 | 17,441.1 | 4,016.1 | 21,457.2 | 21,457.2 | 102,258.0 | 2,194.2 | 1.00 | 1 |
| 02/18/2014 20:00 | 17,510.1 | 2,366.5 | 19,876.6 | 19,876.6 | 102,258.0 | 2,032.5 | 1.00 | 1 |
| 02/18/2014 21:00 | 17,503.5 | 3,656.3 | 21,159.8 | 21,159.8 | 102,258.0 | 2,163.8 | 1.00 | 1 |
| 02/18/2014 22:00 | 17,350.0 | 1,056.3 | 18,406.3 | 18,406.3 | 102,258.0 | 1,882.2 | 1.00 | 1 |
| 02/18/2014 23:00 | 15,065.9 | 279.6 | 15,211.3 | 15,211.3 | 102,258.0 | 1,555.5 | 1.00 | 1 |
| **Average/Sum#:** | 17,043.5 | 1,761.6 | 18,799.5 | 451,187.5 # | 102,258.0 | 1,922.4 | 24.00 # | 24 # |
| **Minimum:** | 15,065.9 | 279.6 | 15,211.3 | 15,211.3 | 102,258.0 | 1,555.5 | 1.00 | 1 |
| **Maximum:** | 17,789.2 | 4,016.1 | 21,457.2 | 21,457.2 | 102,258.0 | 2,194.2 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/19/2014 00:00 | 12,050.0 | 0.0 | 12,050.0 | 12,050.0 | 102,470.0 | 1,234.8 | 1.00 | 1 |
| 02/19/2014 01:00 | 13,621.4 | 0.0 | 13,621.4 | 13,621.4 | 102,470.0 | 1,395.8 | 1.00 | 1 |
| 02/19/2014 02:00 | 7,321.6 | 0.0 | 7,321.6 | 1,317.9 | 102,470.0 | 750.2 | 0.18 | 0 |
| 02/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 12:00 | 4,930.3 | 0.0 | 4,930.3 | 3,106.1 | 102,470.0 | 505.2 | 0.63 | 0 |
| 02/19/2014 13:00 | 5,549.7 | 0.0 | 5,549.7 | 5,549.7 | 102,470.0 | 568.7 | 1.00 | 0 |
| 02/19/2014 14:00 | 8,734.0 | 0.0 | 8,734.0 | 8,734.0 | 102,470.0 | 895.0 | 1.00 | 0 |
| 02/19/2014 15:00 | 12,526.9 | 0.0 | 12,526.9 | 12,526.9 | 102,470.0 | 1,283.6 | 1.00 | 1 |
| 02/19/2014 16:00 | 15,495.7 | 0.0 | 15,495.7 | 15,495.7 | 102,470.0 | 1,587.8 | 1.00 | 1 |
| 02/19/2014 17:00 | 16,819.8 | 0.0 | 16,819.8 | 16,819.8 | 102,470.0 | 1,723.5 | 1.00 | 1 |
| 02/19/2014 18:00 | 15,549.3 | 145.7 | 15,575.5 | 15,575.5 | 102,470.0 | 1,596.0 | 1.00 | 1 |
| 02/19/2014 19:00 | 17,330.1 | 749.2 | 18,079.3 | 18,079.3 | 102,470.0 | 1,852.6 | 1.00 | 1 |
| 02/19/2014 20:00 | 17,592.6 | 3,597.1 | 21,189.7 | 21,189.7 | 102,470.0 | 2,171.3 | 1.00 | 1 |
| 02/19/2014 21:00 | 17,617.9 | 4,076.9 | 21,694.8 | 21,694.8 | 102,470.0 | 2,223.1 | 1.00 | 1 |
| 02/19/2014 22:00 | 17,688.6 | 3,072.1 | 20,760.7 | 20,760.7 | 102,470.0 | 2,127.3 | 1.00 | 1 |
| 02/19/2014 23:00 | 17,297.1 | 772.6 | 18,069.7 | 18,069.7 | 102,470.0 | 1,851.6 | 1.00 | 1 |
| **Average/Sum#:** | 13,341.7 | 827.6 | 14,161.3 | 204,591.2 # | 102,470.0 | 1,451.1 | 13.81 # | 11 # |
| **Minimum:** | 4,930.3 | 0.0 | 4,930.3 | 1,317.9 | 102,470.0 | 505.2 | 0.00 | 0 |
| **Maximum:** | 17,688.6 | 4,076.9 | 21,694.8 | 21,694.8 | 102,470.0 | 2,223.1 | 1.00 | 1 |
| **%SI** | 37.5 | 37.5 | 37.5 | 37.5 | 0.0 | 37.5 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/20/2014 00:00 | 17,047.5 | 530.9 | 17,567.8 | 17,567.8 | 102,470.0 | 1,800.2 | 1.00 | 1 |
| 02/20/2014 01:00 | 12,326.5 | 0.0 | 12,326.5 | 12,326.5 | 102,470.0 | 1,263.1 | 1.00 | 1 |
| 02/20/2014 02:00 | 12,083.0 | 0.0 | 12,083.0 | 12,083.0 | 102,470.0 | 1,238.1 | 1.00 | 1 |
| 02/20/2014 03:00 | 12,075.5 | 0.0 | 12,075.5 | 12,075.5 | 102,470.0 | 1,237.4 | 1.00 | 1 |
| 02/20/2014 04:00 | 12,238.5 | 0.0 | 12,238.5 | 12,238.5 | 102,470.0 | 1,254.1 | 1.00 | 1 |
| 02/20/2014 05:00 | 12,745.4 | 0.0 | 12,745.4 | 12,745.4 | 102,470.0 | 1,306.0 | 1.00 | 1 |
| 02/20/2014 06:00 | 17,192.3 | 1,416.1 | 18,325.2 | 18,325.2 | 102,470.0 | 1,877.8 | 1.00 | 1 |
| 02/20/2014 07:00 | 17,908.8 | 2,057.4 | 19,966.2 | 19,966.2 | 102,470.0 | 2,045.9 | 1.00 | 1 |
| 02/20/2014 08:00 | 17,816.6 | 2,885.3 | 20,701.9 | 20,701.9 | 102,470.0 | 2,121.3 | 1.00 | 1 |
| 02/20/2014 09:00 | 16,887.7 | 1,202.6 | 18,090.3 | 18,090.3 | 102,470.0 | 1,853.7 | 1.00 | 1 |
| 02/20/2014 10:00 | 16,520.6 | 1,164.9 | 17,685.5 | 17,685.5 | 102,470.0 | 1,812.2 | 1.00 | 1 |
| 02/20/2014 11:00 | 16,568.9 | 1,155.8 | 17,724.7 | 17,724.7 | 102,470.0 | 1,816.3 | 1.00 | 1 |
| 02/20/2014 12:00 | 16,640.4 | 1,151.5 | 17,791.9 | 17,791.9 | 102,470.0 | 1,823.1 | 1.00 | 1 |
| 02/20/2014 13:00 | 17,604.9 | 1,503.9 | 19,108.8 | 19,108.8 | 102,470.0 | 1,958.1 | 1.00 | 1 |
| 02/20/2014 14:00 | 16,858.5 | 1,154.3 | 18,012.8 | 18,012.8 | 102,470.0 | 1,845.8 | 1.00 | 1 |
| 02/20/2014 15:00 | 17,259.8 | 1,708.3 | 18,968.1 | 18,968.1 | 102,470.0 | 1,943.7 | 1.00 | 1 |
| 02/20/2014 16:00 | 17,431.3 | 3,129.5 | 20,560.8 | 20,560.8 | 102,470.0 | 2,106.9 | 1.00 | 1 |
| 02/20/2014 17:00 | 17,414.1 | 4,430.7 | 21,844.8 | 21,844.8 | 102,470.0 | 2,238.4 | 1.00 | 1 |
| 02/20/2014 18:00 | 17,447.0 | 3,559.9 | 21,006.9 | 21,006.9 | 102,470.0 | 2,152.6 | 1.00 | 1 |
| 02/20/2014 19:00 | 17,516.5 | 4,369.7 | 21,886.2 | 21,886.2 | 102,470.0 | 2,242.7 | 1.00 | 1 |
| 02/20/2014 20:00 | 17,425.2 | 4,559.5 | 21,984.7 | 21,984.7 | 102,470.0 | 2,252.8 | 1.00 | 1 |
| 02/20/2014 21:00 | 17,445.2 | 4,311.7 | 21,756.9 | 21,756.9 | 102,470.0 | 2,229.4 | 1.00 | 1 |
| 02/20/2014 22:00 | 17,467.2 | 4,368.0 | 21,835.2 | 21,835.2 | 102,470.0 | 2,237.5 | 1.00 | 1 |
| 02/20/2014 23:00 | 17,483.8 | 3,707.2 | 21,191.0 | 21,191.0 | 102,470.0 | 2,171.4 | 1.00 | 1 |
| **Average/Sum#:** | 16,225.2 | 2,015.3 | 18,228.3 | 437,478.6 # | 102,470.0 | 1,867.9 | 24.00 # | 24 # |
| **Minimum:** | 12,075.5 | 0.0 | 12,075.5 | 12,075.5 | 102,470.0 | 1,237.4 | 1.00 | 1 |
| **Maximum:** | 17,908.8 | 4,559.5 | 21,984.7 | 21,984.7 | 102,470.0 | 2,252.8 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/21/2014 00:00 | 17,491.7 | 2,384.0 | 19,875.7 | 19,875.7 | 102,470.0 | 2,036.7 | 1.00 | 1 |
| 02/21/2014 01:00 | 17,244.6 | 751.6 | 17,996.2 | 17,996.2 | 102,470.0 | 1,844.1 | 1.00 | 1 |
| 02/21/2014 02:00 | 17,011.9 | 576.2 | 17,588.1 | 17,588.1 | 102,470.0 | 1,802.3 | 1.00 | 1 |
| 02/21/2014 03:00 | 17,014.0 | 577.5 | 17,591.5 | 17,591.5 | 102,470.0 | 1,802.6 | 1.00 | 1 |
| 02/21/2014 04:00 | 17,024.2 | 574.7 | 17,598.9 | 17,598.9 | 102,470.0 | 1,803.4 | 1.00 | 1 |
| 02/21/2014 05:00 | 17,032.6 | 576.2 | 17,608.8 | 17,608.8 | 102,470.0 | 1,804.4 | 1.00 | 1 |
| 02/21/2014 06:00 | 17,243.1 | 577.8 | 17,820.9 | 17,820.9 | 102,470.0 | 1,826.1 | 1.00 | 1 |
| 02/21/2014 07:00 | 17,655.0 | 1,714.4 | 19,369.4 | 19,369.4 | 102,470.0 | 1,984.8 | 1.00 | 1 |
| 02/21/2014 08:00 | 17,660.2 | 3,546.6 | 21,206.8 | 21,206.8 | 102,470.0 | 2,173.1 | 1.00 | 1 |
| 02/21/2014 09:00 | 17,630.0 | 1,096.0 | 18,726.0 | 18,726.0 | 102,470.0 | 1,918.9 | 1.00 | 1 |
| 02/21/2014 10:00 | 17,166.2 | 570.4 | 17,736.6 | 17,736.6 | 102,470.0 | 1,817.5 | 1.00 | 1 |
| 02/21/2014 11:00 | 17,299.6 | 654.5 | 17,954.1 | 17,954.1 | 102,470.0 | 1,839.8 | 1.00 | 1 |
| 02/21/2014 12:00 | 17,206.0 | 562.2 | 17,768.2 | 17,768.2 | 102,470.0 | 1,820.7 | 1.00 | 1 |
| 02/21/2014 13:00 | 17,247.4 | 554.4 | 17,801.8 | 17,801.8 | 102,470.0 | 1,824.2 | 1.00 | 1 |
| 02/21/2014 14:00 | 17,323.5 | 576.4 | 17,899.9 | 17,899.9 | 102,470.0 | 1,834.2 | 1.00 | 1 |
| 02/21/2014 15:00 | 17,270.4 | 601.2 | 17,871.6 | 17,871.6 | 102,470.0 | 1,831.3 | 1.00 | 1 |
| 02/21/2014 16:00 | 17,238.2 | 601.2 | 17,839.4 | 17,839.4 | 102,470.0 | 1,828.0 | 1.00 | 1 |
| 02/21/2014 17:00 | 17,213.7 | 745.4 | 17,959.1 | 17,959.1 | 102,470.0 | 1,840.3 | 1.00 | 1 |
| 02/21/2014 18:00 | 17,299.1 | 2,244.6 | 19,543.7 | 19,543.7 | 102,470.0 | 2,002.6 | 1.00 | 1 |
| 02/21/2014 19:00 | 17,410.7 | 3,188.8 | 20,599.5 | 20,599.5 | 102,470.0 | 2,110.8 | 1.00 | 1 |
| 02/21/2014 20:00 | 17,419.7 | 3,515.8 | 20,935.5 | 20,935.5 | 102,470.0 | 2,145.3 | 1.00 | 1 |
| 02/21/2014 21:00 | 17,495.6 | 4,084.2 | 21,579.8 | 21,579.8 | 102,470.0 | 2,211.3 | 1.00 | 1 |
| 02/21/2014 22:00 | 17,481.0 | 3,346.7 | 20,827.7 | 20,827.7 | 102,470.0 | 2,134.2 | 1.00 | 1 |
| 02/21/2014 23:00 | 17,483.8 | 2,689.1 | 20,172.9 | 20,172.9 | 102,470.0 | 2,067.1 | 1.00 | 1 |
| **Average/Sum#:** | 17,315.1 | 1,512.9 | 18,828.0 | 451,872.1 # | 102,470.0 | 1,929.3 | 24.00 # | 24 # |
| **Minimum:** | 17,011.9 | 554.4 | 17,588.1 | 17,588.1 | 102,470.0 | 1,802.3 | 1.00 | 1 |
| **Maximum:** | 17,660.2 | 4,084.2 | 21,579.8 | 21,579.8 | 102,470.0 | 2,211.3 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/22/2014 00:00 | 17,511.0 | 2,452.2 | 19,963.2 | 19,963.2 | 102,470.0 | 2,045.6 | 1.00 | 1 |
| 02/22/2014 01:00 | 17,488.4 | 1,984.9 | 19,473.3 | 19,473.3 | 102,470.0 | 1,995.4 | 1.00 | 1 |
| 02/22/2014 02:00 | 16,730.6 | 1,188.7 | 17,919.3 | 17,919.3 | 102,470.0 | 1,836.2 | 1.00 | 1 |
| 02/22/2014 03:00 | 17,364.4 | 1,789.5 | 19,153.9 | 19,153.9 | 102,470.0 | 1,962.7 | 1.00 | 1 |
| 02/22/2014 04:00 | 17,435.5 | 1,832.9 | 19,268.4 | 19,268.4 | 102,470.0 | 1,974.4 | 1.00 | 1 |
| 02/22/2014 05:00 | 17,187.4 | 1,325.2 | 18,512.6 | 18,512.6 | 102,470.0 | 1,897.0 | 1.00 | 1 |
| 02/22/2014 06:00 | 17,692.3 | 1,875.2 | 19,567.5 | 19,567.5 | 102,470.0 | 2,005.1 | 1.00 | 1 |
| 02/22/2014 07:00 | 17,728.1 | 1,858.2 | 19,586.3 | 19,586.3 | 102,470.0 | 2,007.0 | 1.00 | 1 |
| 02/22/2014 08:00 | 17,624.4 | 1,770.1 | 19,394.5 | 19,394.5 | 102,470.0 | 1,987.4 | 1.00 | 1 |
| 02/22/2014 09:00 | 16,900.4 | 1,203.3 | 18,103.7 | 18,103.7 | 102,470.0 | 1,855.1 | 1.00 | 1 |
| 02/22/2014 10:00 | 16,739.8 | 1,170.1 | 17,909.9 | 17,909.9 | 102,470.0 | 1,835.2 | 1.00 | 1 |
| 02/22/2014 11:00 | 16,821.9 | 1,162.0 | 17,983.9 | 17,983.9 | 102,470.0 | 1,842.8 | 1.00 | 1 |
| 02/22/2014 12:00 | 16,932.8 | 1,160.1 | 18,092.9 | 18,092.9 | 102,470.0 | 1,854.0 | 1.00 | 1 |
| 02/22/2014 13:00 | 16,798.6 | 1,152.8 | 17,951.4 | 17,951.4 | 102,470.0 | 1,839.5 | 1.00 | 1 |
| 02/22/2014 14:00 | 17,034.8 | 1,675.8 | 18,710.6 | 18,710.6 | 102,470.0 | 1,917.3 | 1.00 | 1 |
| 02/22/2014 15:00 | 17,106.5 | 2,170.6 | 19,277.1 | 19,277.1 | 102,470.0 | 1,975.3 | 1.00 | 1 |
| 02/22/2014 16:00 | 16,961.7 | 1,407.1 | 18,368.8 | 18,368.8 | 102,470.0 | 1,882.3 | 1.00 | 1 |
| 02/22/2014 17:00 | 16,630.5 | 1,323.6 | 17,954.1 | 17,954.1 | 102,470.0 | 1,839.8 | 1.00 | 1 |
| 02/22/2014 18:00 | 16,942.2 | 2,906.7 | 19,848.9 | 19,848.9 | 102,470.0 | 2,033.9 | 1.00 | 1 |
| 02/22/2014 19:00 | 17,063.7 | 3,021.8 | 20,085.5 | 20,085.5 | 102,470.0 | 2,058.2 | 1.00 | 1 |
| 02/22/2014 20:00 | 17,100.9 | 4,330.9 | 21,431.8 | 21,431.8 | 102,470.0 | 2,196.1 | 1.00 | 1 |
| 02/22/2014 21:00 | 17,134.1 | 4,504.3 | 21,638.4 | 21,638.4 | 102,470.0 | 2,217.3 | 1.00 | 1 |
| 02/22/2014 22:00 | 17,155.6 | 4,547.1 | 21,702.7 | 21,702.7 | 102,470.0 | 2,223.9 | 1.00 | 1 |
| 02/22/2014 23:00 | 17,256.7 | 4,511.2 | 21,767.9 | 21,767.9 | 102,470.0 | 2,230.6 | 1.00 | 1 |
| **Average/Sum#:** | 17,139.3 | 2,180.2 | 19,319.4 | 463,666.6 # | 102,470.0 | 1,979.7 | 24.00 # | 24 # |
| **Minimum:** | 16,630.5 | 1,152.8 | 17,909.9 | 17,909.9 | 102,470.0 | 1,835.2 | 1.00 | 1 |
| **Maximum:** | 17,728.1 | 4,547.1 | 21,767.9 | 21,767.9 | 102,470.0 | 2,230.6 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/23/2014 00:00 | 17,632.1 | 3,739.9 | 21,372.0 | 21,372.0 | 102,470.0 | 2,190.0 | 1.00 | 1 |
| 02/23/2014 01:00 | 17,524.7 | 3,177.5 | 20,702.2 | 20,702.2 | 102,470.0 | 2,121.4 | 1.00 | 1 |
| 02/23/2014 02:00 | 17,494.5 | 4,110.5 | 21,605.0 | 21,605.0 | 102,470.0 | 2,213.9 | 1.00 | 1 |
| 02/23/2014 03:00 | 17,555.2 | 4,153.9 | 21,709.1 | 21,709.1 | 102,470.0 | 2,224.5 | 1.00 | 1 |
| 02/23/2014 04:00 | 17,606.6 | 2,859.3 | 20,465.9 | 20,465.9 | 102,470.0 | 2,097.1 | 1.00 | 1 |
| 02/23/2014 05:00 | 17,605.3 | 1,871.0 | 19,476.3 | 19,476.3 | 102,470.0 | 1,995.7 | 1.00 | 1 |
| 02/23/2014 06:00 | 17,615.8 | 2,013.0 | 19,628.8 | 19,628.8 | 102,470.0 | 2,011.4 | 1.00 | 1 |
| 02/23/2014 07:00 | 17,627.3 | 1,644.3 | 19,271.6 | 19,271.6 | 102,470.0 | 1,974.8 | 1.00 | 1 |
| 02/23/2014 08:00 | 17,663.5 | 1,447.5 | 19,111.0 | 19,111.0 | 102,470.0 | 1,958.3 | 1.00 | 1 |
| 02/23/2014 09:00 | 17,564.8 | 1,388.9 | 18,953.7 | 18,953.7 | 102,470.0 | 1,942.2 | 1.00 | 1 |
| 02/23/2014 10:00 | 16,848.3 | 899.3 | 17,747.6 | 17,747.6 | 102,470.0 | 1,818.6 | 1.00 | 1 |
| 02/23/2014 11:00 | 17,159.7 | 1,041.4 | 18,201.1 | 18,201.1 | 102,470.0 | 1,865.1 | 1.00 | 1 |
| 02/23/2014 12:00 | 17,298.3 | 1,188.5 | 18,486.8 | 18,486.8 | 102,470.0 | 1,894.3 | 1.00 | 1 |
| 02/23/2014 13:00 | 16,941.3 | 878.4 | 17,819.7 | 17,819.7 | 102,470.0 | 1,826.0 | 1.00 | 1 |
| 02/23/2014 14:00 | 16,933.4 | 905.4 | 17,838.8 | 17,838.8 | 102,470.0 | 1,827.9 | 1.00 | 1 |
| 02/23/2014 15:00 | 16,877.4 | 966.6 | 17,844.0 | 17,844.0 | 102,470.0 | 1,828.5 | 1.00 | 1 |
| 02/23/2014 16:00 | 16,973.9 | 1,247.5 | 18,221.4 | 18,221.4 | 102,470.0 | 1,867.1 | 1.00 | 1 |
| 02/23/2014 17:00 | 16,917.7 | 1,647.3 | 18,565.0 | 18,565.0 | 102,470.0 | 1,902.4 | 1.00 | 1 |
| 02/23/2014 18:00 | 17,072.3 | 3,257.5 | 20,329.8 | 20,329.8 | 102,470.0 | 2,083.2 | 1.00 | 1 |
| 02/23/2014 19:00 | 17,166.2 | 4,147.3 | 21,313.5 | 21,313.5 | 102,470.0 | 2,184.0 | 1.00 | 1 |
| 02/23/2014 20:00 | 17,245.1 | 3,915.1 | 21,160.2 | 21,160.2 | 102,470.0 | 2,168.3 | 1.00 | 1 |
| 02/23/2014 21:00 | 17,302.1 | 3,869.8 | 21,171.9 | 21,171.9 | 102,470.0 | 2,169.5 | 1.00 | 1 |
| 02/23/2014 22:00 | 17,348.7 | 3,814.0 | 21,162.7 | 21,162.7 | 102,470.0 | 2,168.5 | 1.00 | 1 |
| 02/23/2014 23:00 | 17,430.8 | 3,525.3 | 20,956.1 | 20,956.1 | 102,470.0 | 2,147.4 | 1.00 | 1 |
| **Average/Sum#:** | 17,308.5 | 2,404.6 | 19,713.1 | 473,114.2 # | 102,470.0 | 2,020.0 | 24.00 # | 24 # |
| **Minimum:** | 16,848.3 | 878.4 | 17,747.6 | 17,747.6 | 102,470.0 | 1,818.6 | 1.00 | 1 |
| **Maximum:** | 17,663.5 | 4,153.9 | 21,709.1 | 21,709.1 | 102,470.0 | 2,224.5 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/24/2014 00:00 | 17,576.7 | 1,668.4 | 19,245.1 | 19,245.1 | 102,470.0 | 1,972.0 | 1.00 | 1 |
| 02/24/2014 01:00 | 16,751.1 | 909.6 | 17,660.7 | 17,660.7 | 102,470.0 | 1,809.7 | 1.00 | 1 |
| 02/24/2014 02:00 | 16,565.2 | 741.5 | 17,180.6 | 17,180.6 | 102,470.0 | 1,760.5 | 1.00 | 1 |
| 02/24/2014 03:00 | 12,167.6 | 0.0 | 12,167.6 | 12,167.6 | 102,470.0 | 1,246.8 | 1.00 | 1 |
| 02/24/2014 04:00 | 11,912.3 | 0.0 | 11,912.3 | 11,912.3 | 102,470.0 | 1,220.7 | 1.00 | 1 |
| 02/24/2014 05:00 | 14,598.3 | 341.8 | 14,711.1 | 14,711.1 | 102,470.0 | 1,507.4 | 1.00 | 1 |
| 02/24/2014 06:00 | 16,965.3 | 1,136.5 | 18,101.8 | 18,101.8 | 102,470.0 | 1,854.9 | 1.00 | 1 |
| 02/24/2014 07:00 | 17,596.7 | 1,141.0 | 18,737.7 | 18,737.7 | 102,470.0 | 1,920.1 | 1.00 | 1 |
| 02/24/2014 08:00 | 17,713.3 | 2,209.2 | 19,922.5 | 19,922.5 | 102,470.0 | 2,041.5 | 1.00 | 1 |
| 02/24/2014 09:00 | 17,517.6 | 1,098.8 | 18,616.4 | 18,616.4 | 102,470.0 | 1,907.6 | 1.00 | 1 |
| 02/24/2014 10:00 | 17,035.6 | 570.8 | 17,606.4 | 17,606.4 | 102,470.0 | 1,804.1 | 1.00 | 1 |
| 02/24/2014 11:00 | 17,276.1 | 637.0 | 17,913.1 | 17,913.1 | 102,470.0 | 1,835.6 | 1.00 | 1 |
| 02/24/2014 12:00 | 17,024.6 | 566.6 | 17,591.2 | 17,591.2 | 102,470.0 | 1,802.6 | 1.00 | 1 |
| 02/24/2014 13:00 | 17,001.7 | 553.6 | 17,555.3 | 17,555.3 | 102,470.0 | 1,798.9 | 1.00 | 1 |
| 02/24/2014 14:00 | 17,013.1 | 610.8 | 17,623.9 | 17,623.9 | 102,470.0 | 1,805.9 | 1.00 | 1 |
| 02/24/2014 15:00 | 16,957.4 | 2,029.1 | 18,986.5 | 18,986.5 | 102,470.0 | 1,945.5 | 1.00 | 1 |
| 02/24/2014 16:00 | 16,945.3 | 1,984.7 | 18,930.0 | 18,930.0 | 102,470.0 | 1,939.8 | 1.00 | 1 |
| 02/24/2014 17:00 | 16,930.2 | 2,747.7 | 19,677.9 | 19,677.9 | 102,470.0 | 2,016.4 | 1.00 | 1 |
| 02/24/2014 18:00 | 16,978.9 | 3,562.5 | 20,541.4 | 20,541.4 | 102,470.0 | 2,104.9 | 1.00 | 1 |
| 02/24/2014 19:00 | 17,093.9 | 4,235.5 | 21,329.4 | 21,329.4 | 102,470.0 | 2,185.6 | 1.00 | 1 |
| 02/24/2014 20:00 | 17,174.0 | 3,932.4 | 21,106.4 | 21,106.4 | 102,470.0 | 2,162.8 | 1.00 | 1 |
| 02/24/2014 21:00 | 17,219.7 | 3,677.1 | 20,896.8 | 20,896.8 | 102,470.0 | 2,141.3 | 1.00 | 1 |
| 02/24/2014 22:00 | 17,288.9 | 3,580.8 | 20,869.7 | 20,869.7 | 102,470.0 | 2,138.5 | 1.00 | 1 |
| 02/24/2014 23:00 | 17,333.5 | 3,592.4 | 20,925.9 | 20,925.9 | 102,470.0 | 2,144.3 | 1.00 | 1 |
| **Average/Sum#:** | 16,609.9 | 1,730.3 | 18,325.4 | 439,809.7 # | 102,470.0 | 1,877.8 | 24.00 # | 24 # |
| **Minimum:** | 11,912.3 | 0.0 | 11,912.3 | 11,912.3 | 102,470.0 | 1,220.7 | 1.00 | 1 |
| **Maximum:** | 17,713.3 | 4,235.5 | 21,329.4 | 21,329.4 | 102,470.0 | 2,185.6 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/25/2014 00:00 | 17,560.2 | 2,046.4 | 19,606.6 | 19,606.6 | 102,470.0 | 2,009.1 | 1.00 | 1 |
| 02/25/2014 01:00 | 17,446.0 | 1,473.9 | 18,919.9 | 18,919.9 | 102,470.0 | 1,938.7 | 1.00 | 1 |
| 02/25/2014 02:00 | 16,587.4 | 1,077.3 | 17,664.7 | 17,664.7 | 102,470.0 | 1,810.1 | 1.00 | 1 |
| 02/25/2014 03:00 | 16,526.0 | 1,077.2 | 17,603.2 | 17,603.2 | 102,470.0 | 1,803.8 | 1.00 | 1 |
| 02/25/2014 04:00 | 16,502.0 | 1,078.6 | 17,580.6 | 17,580.6 | 102,470.0 | 1,801.5 | 1.00 | 1 |
| 02/25/2014 05:00 | 17,365.8 | 1,828.8 | 19,194.6 | 19,194.6 | 102,470.0 | 1,966.9 | 1.00 | 1 |
| 02/25/2014 06:00 | 17,439.9 | 2,029.6 | 19,469.5 | 19,469.5 | 102,470.0 | 1,995.0 | 1.00 | 1 |
| 02/25/2014 07:00 | 17,273.4 | 1,456.0 | 18,729.4 | 18,729.4 | 102,470.0 | 1,919.2 | 1.00 | 1 |
| 02/25/2014 08:00 | 17,403.9 | 1,826.7 | 19,230.6 | 19,230.6 | 102,470.0 | 1,970.6 | 1.00 | 1 |
| 02/25/2014 09:00 | 16,590.3 | 1,024.2 | 17,614.5 | 17,614.5 | 102,470.0 | 1,805.0 | 1.00 | 1 |
| 02/25/2014 10:00 | 16,739.1 | 839.9 | 17,579.0 | 17,579.0 | 102,470.0 | 1,801.3 | 1.00 | 1 |
| 02/25/2014 11:00 | 16,984.9 | 566.2 | 17,551.1 | 17,551.1 | 102,470.0 | 1,798.5 | 1.00 | 1 |
| 02/25/2014 12:00 | 17,013.8 | 633.4 | 17,647.2 | 17,647.2 | 102,470.0 | 1,808.3 | 1.00 | 1 |
| 02/25/2014 13:00 | 17,188.7 | 606.6 | 17,795.3 | 17,795.3 | 102,470.0 | 1,823.5 | 1.00 | 1 |
| 02/25/2014 14:00 | 17,013.9 | 566.6 | 17,580.5 | 17,580.5 | 102,470.0 | 1,801.5 | 1.00 | 1 |
| 02/25/2014 15:00 | 17,019.0 | 560.1 | 17,579.1 | 17,579.1 | 102,470.0 | 1,801.3 | 1.00 | 1 |
| 02/25/2014 16:00 | 17,029.0 | 977.7 | 18,006.7 | 18,006.7 | 102,470.0 | 1,845.1 | 1.00 | 1 |
| 02/25/2014 17:00 | 16,866.8 | 887.0 | 17,753.8 | 17,753.8 | 102,470.0 | 1,819.2 | 1.00 | 1 |
| 02/25/2014 18:00 | 17,173.7 | 1,738.4 | 18,912.1 | 18,912.1 | 102,470.0 | 1,937.9 | 1.00 | 1 |
| 02/25/2014 19:00 | 17,383.7 | 3,030.2 | 20,413.9 | 20,413.9 | 102,470.0 | 2,091.8 | 1.00 | 1 |
| 02/25/2014 20:00 | 17,411.2 | 3,365.3 | 20,776.5 | 20,776.5 | 102,470.0 | 2,129.0 | 1.00 | 1 |
| 02/25/2014 21:00 | 17,485.5 | 2,423.8 | 19,909.3 | 19,909.3 | 102,470.0 | 2,040.1 | 1.00 | 1 |
| 02/25/2014 22:00 | 17,383.6 | 1,437.1 | 18,820.7 | 18,820.7 | 102,470.0 | 1,928.6 | 1.00 | 1 |
| 02/25/2014 23:00 | 17,528.3 | 3,100.6 | 20,628.9 | 20,628.9 | 102,470.0 | 2,113.8 | 1.00 | 1 |
| **Average/Sum#:** | 17,121.5 | 1,485.5 | 18,607.0 | 446,567.7 # | 102,470.0 | 1,906.7 | 24.00 # | 24 # |
| **Minimum:** | 16,502.0 | 560.1 | 17,551.1 | 17,551.1 | 102,470.0 | 1,798.5 | 1.00 | 1 |
| **Maximum:** | 17,560.2 | 3,365.3 | 20,776.5 | 20,776.5 | 102,470.0 | 2,129.0 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/26/2014 00:00 | 17,231.9 | 1,429.9 | 18,661.8 | 18,661.8 | 102,470.0 | 1,912.3 | 1.00 | 1 |
| 02/26/2014 01:00 | 16,865.1 | 1,200.7 | 18,065.8 | 18,065.8 | 102,470.0 | 1,851.2 | 1.00 | 1 |
| 02/26/2014 02:00 | 16,645.5 | 1,194.8 | 17,840.3 | 17,840.3 | 102,470.0 | 1,828.1 | 1.00 | 1 |
| 02/26/2014 03:00 | 16,600.6 | 1,193.3 | 17,793.9 | 17,793.9 | 102,470.0 | 1,823.3 | 1.00 | 1 |
| 02/26/2014 04:00 | 16,532.2 | 1,192.4 | 17,724.6 | 17,724.6 | 102,470.0 | 1,816.2 | 1.00 | 1 |
| 02/26/2014 05:00 | 16,860.6 | 1,238.5 | 18,099.1 | 18,099.1 | 102,470.0 | 1,854.6 | 1.00 | 1 |
| 02/26/2014 06:00 | 17,502.0 | 2,546.8 | 20,048.8 | 20,048.8 | 102,470.0 | 2,054.4 | 1.00 | 1 |
| 02/26/2014 07:00 | 17,669.7 | 3,284.7 | 20,954.4 | 20,954.4 | 102,470.0 | 2,147.2 | 1.00 | 1 |
| 02/26/2014 08:00 | 17,689.0 | 4,216.4 | 21,905.4 | 21,905.4 | 102,470.0 | 2,244.6 | 1.00 | 1 |
| 02/26/2014 09:00 | 17,743.9 | 4,180.1 | 21,924.0 | 21,924.0 | 102,470.0 | 2,246.6 | 1.00 | 1 |
| 02/26/2014 10:00 | 17,724.5 | 4,314.2 | 22,038.7 | 22,038.7 | 102,470.0 | 2,258.3 | 1.00 | 1 |
| 02/26/2014 11:00 | 17,647.3 | 4,169.3 | 21,816.6 | 21,816.6 | 102,470.0 | 2,235.5 | 1.00 | 1 |
| 02/26/2014 12:00 | 17,630.9 | 3,177.4 | 20,808.3 | 20,808.3 | 102,470.0 | 2,132.2 | 1.00 | 1 |
| 02/26/2014 13:00 | 17,569.1 | 3,407.3 | 20,976.4 | 20,976.4 | 102,470.0 | 2,149.5 | 1.00 | 1 |
| 02/26/2014 14:00 | 17,470.9 | 2,711.8 | 20,182.7 | 20,182.7 | 102,470.0 | 2,068.1 | 1.00 | 1 |
| 02/26/2014 15:00 | 17,472.6 | 2,502.4 | 19,975.0 | 19,975.0 | 102,470.0 | 2,046.8 | 1.00 | 1 |
| 02/26/2014 16:00 | 17,536.0 | 1,938.4 | 19,474.4 | 19,474.4 | 102,470.0 | 1,995.5 | 1.00 | 1 |
| 02/26/2014 17:00 | 17,498.9 | 3,120.6 | 20,619.5 | 20,619.5 | 102,470.0 | 2,112.9 | 1.00 | 1 |
| 02/26/2014 18:00 | 17,497.8 | 3,418.2 | 20,916.0 | 20,916.0 | 102,470.0 | 2,143.3 | 1.00 | 1 |
| 02/26/2014 19:00 | 17,534.8 | 4,364.5 | 21,899.3 | 21,899.3 | 102,470.0 | 2,244.0 | 1.00 | 1 |
| 02/26/2014 20:00 | 17,498.2 | 4,230.9 | 21,729.1 | 21,729.1 | 102,470.0 | 2,226.6 | 1.00 | 1 |
| 02/26/2014 21:00 | 17,436.0 | 3,987.5 | 21,423.5 | 21,423.5 | 102,470.0 | 2,195.3 | 1.00 | 1 |
| 02/26/2014 22:00 | 17,412.9 | 3,764.3 | 21,177.2 | 21,177.2 | 102,470.0 | 2,170.0 | 1.00 | 1 |
| 02/26/2014 23:00 | 17,417.6 | 3,290.3 | 20,707.9 | 20,707.9 | 102,470.0 | 2,121.9 | 1.00 | 1 |
| **Average/Sum#:** | 17,362.0 | 2,919.8 | 20,281.8 | 486,762.7 # | 102,470.0 | 2,078.3 | 24.00 # | 24 # |
| **Minimum:** | 16,532.2 | 1,192.4 | 17,724.6 | 17,724.6 | 102,470.0 | 1,816.2 | 1.00 | 1 |
| **Maximum:** | 17,743.9 | 4,364.5 | 22,038.7 | 22,038.7 | 102,470.0 | 2,258.3 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/27/2014 00:00 | 17,417.6 | 1,799.7 | 19,217.3 | 19,217.3 | 102,470.0 | 1,969.2 | 1.00 | 1 |
| 02/27/2014 01:00 | 16,721.9 | 1,176.2 | 17,898.1 | 17,898.1 | 102,470.0 | 1,834.0 | 1.00 | 1 |
| 02/27/2014 02:00 | 14,992.9 | 411.6 | 15,137.0 | 15,137.0 | 102,470.0 | 1,551.1 | 1.00 | 1 |
| 02/27/2014 03:00 | 12,463.7 | 0.0 | 12,463.7 | 12,463.7 | 102,470.0 | 1,277.2 | 1.00 | 1 |
| 02/27/2014 04:00 | 15,274.7 | 0.0 | 15,274.7 | 15,274.7 | 102,470.0 | 1,565.2 | 1.00 | 1 |
| 02/27/2014 05:00 | 16,398.3 | 691.4 | 16,757.8 | 16,757.8 | 102,470.0 | 1,717.2 | 1.00 | 1 |
| 02/27/2014 06:00 | 17,046.2 | 1,192.7 | 18,238.9 | 18,238.9 | 102,470.0 | 1,868.9 | 1.00 | 1 |
| 02/27/2014 07:00 | 17,171.6 | 894.6 | 18,066.2 | 18,066.2 | 102,470.0 | 1,851.2 | 1.00 | 1 |
| 02/27/2014 08:00 | 17,553.0 | 1,989.0 | 19,542.0 | 19,542.0 | 102,470.0 | 2,002.5 | 1.00 | 1 |
| 02/27/2014 09:00 | 17,157.8 | 727.1 | 17,884.9 | 17,884.9 | 102,470.0 | 1,832.7 | 1.00 | 1 |
| 02/27/2014 10:00 | 17,085.0 | 555.7 | 17,640.7 | 17,640.7 | 102,470.0 | 1,807.6 | 1.00 | 1 |
| 02/27/2014 11:00 | 17,052.5 | 554.0 | 17,606.5 | 17,606.5 | 102,470.0 | 1,804.1 | 1.00 | 1 |
| 02/27/2014 12:00 | 17,006.5 | 633.1 | 17,639.6 | 17,639.6 | 102,470.0 | 1,807.5 | 1.00 | 1 |
| 02/27/2014 13:00 | 17,041.3 | 688.5 | 17,729.8 | 17,729.8 | 102,470.0 | 1,816.8 | 1.00 | 1 |
| 02/27/2014 14:00 | 17,031.8 | 683.2 | 17,715.0 | 17,715.0 | 102,470.0 | 1,815.3 | 1.00 | 1 |
| 02/27/2014 15:00 | 17,058.7 | 682.7 | 17,741.4 | 17,741.4 | 102,470.0 | 1,818.0 | 1.00 | 1 |
| 02/27/2014 16:00 | 17,123.5 | 683.4 | 17,806.9 | 17,806.9 | 102,470.0 | 1,824.7 | 1.00 | 1 |
| 02/27/2014 17:00 | 17,330.8 | 1,022.2 | 18,353.0 | 18,353.0 | 102,470.0 | 1,880.6 | 1.00 | 1 |
| 02/27/2014 18:00 | 16,978.5 | 1,251.1 | 18,229.6 | 18,229.6 | 102,470.0 | 1,868.0 | 1.00 | 1 |
| 02/27/2014 19:00 | 17,363.1 | 2,495.6 | 19,858.7 | 19,858.7 | 102,470.0 | 2,034.9 | 1.00 | 1 |
| 02/27/2014 20:00 | 17,456.1 | 2,273.3 | 19,729.4 | 19,729.4 | 102,470.0 | 2,021.7 | 1.00 | 1 |
| 02/27/2014 21:00 | 17,500.3 | 2,333.4 | 19,833.7 | 19,833.7 | 102,470.0 | 2,032.4 | 1.00 | 1 |
| 02/27/2014 22:00 | 17,462.6 | 2,140.4 | 19,603.0 | 19,603.0 | 102,470.0 | 2,008.7 | 1.00 | 1 |
| 02/27/2014 23:00 | 17,461.2 | 2,335.2 | 19,796.4 | 19,796.4 | 102,470.0 | 2,028.5 | 1.00 | 1 |
| **Average/Sum#:** | 16,797.9 | 1,133.9 | 17,906.8 | 429,764.3 # | 102,470.0 | 1,834.9 | 24.00 # | 24 # |
| **Minimum:** | 12,463.7 | 0.0 | 12,463.7 | 12,463.7 | 102,470.0 | 1,277.2 | 1.00 | 1 |
| **Maximum:** | 17,553.0 | 2,495.6 | 19,858.7 | 19,858.7 | 102,470.0 | 2,034.9 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/28/2014 00:00 | 16,981.3 | 1,384.5 | 18,365.8 | 18,365.8 | 102,470.0 | 1,881.9 | 1.00 | 1 |
| 02/28/2014 01:00 | 16,656.7 | 1,179.7 | 17,836.4 | 17,836.4 | 102,470.0 | 1,827.7 | 1.00 | 1 |
| 02/28/2014 02:00 | 17,139.9 | 1,404.5 | 18,544.4 | 18,544.4 | 102,470.0 | 1,900.2 | 1.00 | 1 |
| 02/28/2014 03:00 | 16,672.1 | 1,185.1 | 17,857.2 | 17,857.2 | 102,470.0 | 1,829.8 | 1.00 | 1 |
| 02/28/2014 04:00 | 16,675.1 | 1,185.6 | 17,860.7 | 17,860.7 | 102,470.0 | 1,830.2 | 1.00 | 1 |
| 02/28/2014 05:00 | 16,811.4 | 1,186.8 | 17,998.2 | 17,998.2 | 102,470.0 | 1,844.3 | 1.00 | 1 |
| 02/28/2014 06:00 | 16,826.7 | 1,188.9 | 18,015.6 | 18,015.6 | 102,470.0 | 1,846.1 | 1.00 | 1 |
| 02/28/2014 07:00 | 16,915.6 | 1,234.0 | 18,149.6 | 18,149.6 | 102,470.0 | 1,859.8 | 1.00 | 1 |
| 02/28/2014 08:00 | 17,470.0 | 2,109.4 | 19,579.4 | 19,579.4 | 102,470.0 | 2,006.3 | 1.00 | 1 |
| 02/28/2014 09:00 | 17,446.1 | 3,305.9 | 20,752.0 | 20,752.0 | 102,470.0 | 2,126.5 | 1.00 | 1 |
| 02/28/2014 10:00 | 17,461.1 | 3,706.2 | 21,167.3 | 21,167.3 | 102,470.0 | 2,169.0 | 1.00 | 1 |
| 02/28/2014 11:00 | 17,460.5 | 3,532.9 | 20,993.4 | 20,993.4 | 102,470.0 | 2,151.2 | 1.00 | 1 |
| 02/28/2014 12:00 | 17,433.9 | 3,185.8 | 20,619.7 | 20,619.7 | 102,470.0 | 2,112.9 | 1.00 | 1 |
| 02/28/2014 13:00 | 17,402.1 | 2,168.1 | 19,570.2 | 19,570.2 | 102,470.0 | 2,005.4 | 1.00 | 1 |
| 02/28/2014 14:00 | 16,933.2 | 1,189.6 | 18,122.8 | 18,122.8 | 102,470.0 | 1,857.0 | 1.00 | 1 |
| 02/28/2014 15:00 | 17,174.8 | 1,615.0 | 18,789.8 | 18,789.8 | 102,470.0 | 1,925.4 | 1.00 | 1 |
| 02/28/2014 16:00 | 17,403.1 | 3,082.6 | 20,485.7 | 20,485.7 | 102,470.0 | 2,099.2 | 1.00 | 1 |
| 02/28/2014 17:00 | 17,482.8 | 2,590.3 | 20,073.1 | 20,073.1 | 102,470.0 | 2,056.9 | 1.00 | 1 |
| 02/28/2014 18:00 | 17,438.1 | 1,379.6 | 18,817.7 | 18,817.7 | 102,470.0 | 1,928.2 | 1.00 | 1 |
| 02/28/2014 19:00 | 17,522.6 | 1,952.6 | 19,475.2 | 19,475.2 | 102,470.0 | 1,995.6 | 1.00 | 1 |
| 02/28/2014 20:00 | 16,737.9 | 1,175.0 | 17,912.9 | 17,912.9 | 102,470.0 | 1,835.5 | 1.00 | 1 |
| 02/28/2014 21:00 | 17,537.6 | 1,502.7 | 19,040.3 | 19,040.3 | 102,470.0 | 1,951.1 | 1.00 | 1 |
| 02/28/2014 22:00 | 17,572.2 | 1,809.2 | 19,381.4 | 19,381.4 | 102,470.0 | 1,986.0 | 1.00 | 1 |
| 02/28/2014 23:00 | 17,522.6 | 2,247.4 | 19,770.0 | 19,770.0 | 102,470.0 | 2,025.8 | 1.00 | 1 |
| **Average/Sum#:** | 17,194.9 | 1,937.6 | 19,132.5 | 459,178.8 # | 102,470.0 | 1,960.5 | 24.00 # | 24 # |
| **Minimum:** | 16,656.7 | 1,175.0 | 17,836.4 | 17,836.4 | 102,470.0 | 1,827.7 | 1.00 | 1 |
| **Maximum:** | 17,572.2 | 3,706.2 | 21,167.3 | 21,167.3 | 102,470.0 | 2,169.0 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/01/2014 00:00 | 17,273.5 | 1,564.4 | 18,837.9 | 18,837.9 | 102,470.0 | 1,930.3 | 1.00 | 1 |
| 03/01/2014 01:00 | 16,840.0 | 1,201.9 | 18,041.9 | 18,041.9 | 102,470.0 | 1,848.8 | 1.00 | 1 |
| 03/01/2014 02:00 | 16,560.9 | 1,191.3 | 17,752.2 | 17,752.2 | 102,470.0 | 1,819.1 | 1.00 | 1 |
| 03/01/2014 03:00 | 16,567.4 | 1,192.2 | 17,759.6 | 17,759.6 | 102,470.0 | 1,819.8 | 1.00 | 1 |
| 03/01/2014 04:00 | 16,556.0 | 1,192.7 | 17,748.7 | 17,748.7 | 102,470.0 | 1,818.7 | 1.00 | 1 |
| 03/01/2014 05:00 | 16,704.3 | 1,195.2 | 17,899.5 | 17,899.5 | 102,470.0 | 1,834.2 | 1.00 | 1 |
| 03/01/2014 06:00 | 16,580.4 | 1,194.8 | 17,775.2 | 17,775.2 | 102,470.0 | 1,821.4 | 1.00 | 1 |
| 03/01/2014 07:00 | 16,572.1 | 1,194.7 | 17,766.8 | 17,766.8 | 102,470.0 | 1,820.6 | 1.00 | 1 |
| 03/01/2014 08:00 | 16,698.7 | 1,192.9 | 17,891.6 | 17,891.6 | 102,470.0 | 1,833.4 | 1.00 | 1 |
| 03/01/2014 09:00 | 16,577.8 | 1,191.5 | 17,769.3 | 17,769.3 | 102,470.0 | 1,820.8 | 1.00 | 1 |
| 03/01/2014 10:00 | 16,636.7 | 1,184.7 | 17,821.4 | 17,821.4 | 102,470.0 | 1,826.2 | 1.00 | 1 |
| 03/01/2014 11:00 | 16,666.3 | 1,177.3 | 17,843.6 | 17,843.6 | 102,470.0 | 1,828.4 | 1.00 | 1 |
| 03/01/2014 12:00 | 16,703.8 | 1,174.8 | 17,878.6 | 17,878.6 | 102,470.0 | 1,832.0 | 1.00 | 1 |
| 03/01/2014 13:00 | 16,932.9 | 1,201.6 | 18,134.5 | 18,134.5 | 102,470.0 | 1,858.2 | 1.00 | 1 |
| 03/01/2014 14:00 | 17,616.3 | 1,833.9 | 19,450.2 | 19,450.2 | 102,470.0 | 1,993.1 | 1.00 | 1 |
| 03/01/2014 15:00 | 17,566.1 | 1,922.3 | 19,488.4 | 19,488.4 | 102,470.0 | 1,997.0 | 1.00 | 1 |
| 03/01/2014 16:00 | 16,993.9 | 1,182.1 | 18,176.0 | 18,176.0 | 102,470.0 | 1,862.5 | 1.00 | 1 |
| 03/01/2014 17:00 | 16,695.8 | 1,180.0 | 17,875.8 | 17,875.8 | 102,470.0 | 1,831.7 | 1.00 | 1 |
| 03/01/2014 18:00 | 16,683.3 | 1,182.8 | 17,866.1 | 17,866.1 | 102,470.0 | 1,830.7 | 1.00 | 1 |
| 03/01/2014 19:00 | 17,288.9 | 1,622.0 | 18,910.9 | 18,910.9 | 102,470.0 | 1,937.8 | 1.00 | 1 |
| 03/01/2014 20:00 | 17,300.1 | 1,452.5 | 18,752.6 | 18,752.6 | 102,470.0 | 1,921.6 | 1.00 | 1 |
| 03/01/2014 21:00 | 17,506.0 | 1,835.2 | 19,341.2 | 19,341.2 | 102,470.0 | 1,981.9 | 1.00 | 1 |
| 03/01/2014 22:00 | 17,596.2 | 1,703.8 | 19,300.0 | 19,300.0 | 102,470.0 | 1,977.7 | 1.00 | 1 |
| 03/01/2014 23:00 | 17,603.4 | 2,052.5 | 19,655.9 | 19,655.9 | 102,470.0 | 2,014.1 | 1.00 | 1 |
| **Average/Sum#:** | 16,946.7 | 1,375.7 | 18,322.4 | 439,737.9 # | 102,470.0 | 1,877.5 | 24.00 # | 24 # |
| **Minimum:** | 16,556.0 | 1,174.8 | 17,748.7 | 17,748.7 | 102,470.0 | 1,818.7 | 1.00 | 1 |
| **Maximum:** | 17,616.3 | 2,052.5 | 19,655.9 | 19,655.9 | 102,470.0 | 2,014.1 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/02/2014 00:00 | 17,332.9 | 1,273.9 | 18,606.8 | 18,606.8 | 102,470.0 | 1,906.6 | 1.00 | 1 |
| 03/02/2014 01:00 | 17,804.5 | 1,778.9 | 19,583.4 | 19,583.4 | 102,470.0 | 2,006.7 | 1.00 | 1 |
| 03/02/2014 02:00 | 17,887.5 | 1,493.7 | 19,381.2 | 19,381.2 | 102,470.0 | 1,986.0 | 1.00 | 1 |
| 03/02/2014 03:00 | 16,863.0 | 1,190.5 | 18,053.5 | 18,053.5 | 102,470.0 | 1,849.9 | 1.00 | 1 |
| 03/02/2014 04:00 | 16,658.3 | 1,188.2 | 17,846.5 | 17,846.5 | 102,470.0 | 1,828.7 | 1.00 | 1 |
| 03/02/2014 05:00 | 17,066.6 | 1,190.5 | 18,257.1 | 18,257.1 | 102,470.0 | 1,870.8 | 1.00 | 1 |
| 03/02/2014 06:00 | 17,693.2 | 1,547.7 | 19,240.9 | 19,240.9 | 102,470.0 | 1,971.6 | 1.00 | 1 |
| 03/02/2014 07:00 | 17,979.1 | 1,951.1 | 19,930.2 | 19,930.2 | 102,470.0 | 2,042.2 | 1.00 | 1 |
| 03/02/2014 08:00 | 17,930.3 | 1,931.5 | 19,861.8 | 19,861.8 | 102,470.0 | 2,035.2 | 1.00 | 1 |
| 03/02/2014 09:00 | 17,581.7 | 1,246.8 | 18,828.5 | 18,828.5 | 102,470.0 | 1,929.4 | 1.00 | 1 |
| 03/02/2014 10:00 | 17,720.8 | 1,978.0 | 19,698.8 | 19,698.8 | 102,470.0 | 2,018.5 | 1.00 | 1 |
| 03/02/2014 11:00 | 17,745.0 | 3,589.5 | 21,334.5 | 21,334.5 | 102,470.0 | 2,186.1 | 1.00 | 1 |
| 03/02/2014 12:00 | 17,715.9 | 3,343.0 | 21,058.9 | 21,058.9 | 102,470.0 | 2,157.9 | 1.00 | 1 |
| 03/02/2014 13:00 | 17,525.7 | 4,020.6 | 21,546.3 | 21,546.3 | 102,470.0 | 2,207.8 | 1.00 | 1 |
| 03/02/2014 14:00 | 17,497.4 | 3,937.5 | 21,434.9 | 21,434.9 | 102,470.0 | 2,196.4 | 1.00 | 1 |
| 03/02/2014 15:00 | 17,499.9 | 3,886.0 | 21,385.9 | 21,385.9 | 102,470.0 | 2,191.4 | 1.00 | 1 |
| 03/02/2014 16:00 | 17,451.7 | 3,888.2 | 21,339.9 | 21,339.9 | 102,470.0 | 2,186.7 | 1.00 | 1 |
| 03/02/2014 17:00 | 17,456.4 | 3,525.0 | 20,981.4 | 20,981.4 | 102,470.0 | 2,150.0 | 1.00 | 1 |
| 03/02/2014 18:00 | 17,462.7 | 2,787.0 | 20,249.7 | 20,249.7 | 102,470.0 | 2,075.0 | 1.00 | 1 |
| 03/02/2014 19:00 | 17,575.8 | 2,800.0 | 20,375.8 | 20,375.8 | 102,470.0 | 2,087.9 | 1.00 | 1 |
| 03/02/2014 20:00 | 17,606.6 | 2,135.9 | 19,742.5 | 19,742.5 | 102,470.0 | 2,023.0 | 1.00 | 1 |
| 03/02/2014 21:00 | 17,727.4 | 2,916.2 | 20,643.6 | 20,643.6 | 102,470.0 | 2,115.3 | 1.00 | 1 |
| 03/02/2014 22:00 | 17,913.4 | 1,899.2 | 19,812.6 | 19,812.6 | 102,470.0 | 2,030.2 | 1.00 | 1 |
| 03/02/2014 23:00 | 17,565.7 | 1,643.5 | 19,209.2 | 19,209.2 | 102,470.0 | 1,968.4 | 1.00 | 1 |
| **Average/Sum#:** | 17,552.6 | 2,380.9 | 19,933.5 | 478,403.9 # | 102,470.0 | 2,042.6 | 24.00 # | 24 # |
| **Minimum:** | 16,658.3 | 1,188.2 | 17,846.5 | 17,846.5 | 102,470.0 | 1,828.7 | 1.00 | 1 |
| **Maximum:** | 17,979.1 | 4,020.6 | 21,546.3 | 21,546.3 | 102,470.0 | 2,207.8 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/03/2014 00:00 | 15,201.0 | 619.0 | 15,529.1 | 15,529.1 | 102,470.0 | 1,591.3 | 1.00 | 1 |
| 03/03/2014 01:00 | 13,960.9 | 0.0 | 13,960.9 | 13,960.9 | 102,470.0 | 1,430.6 | 1.00 | 1 |
| 03/03/2014 02:00 | 12,567.2 | 0.0 | 12,567.2 | 12,567.2 | 102,470.0 | 1,287.8 | 1.00 | 1 |
| 03/03/2014 03:00 | 12,543.3 | 0.0 | 12,543.3 | 12,543.3 | 102,470.0 | 1,285.3 | 1.00 | 1 |
| 03/03/2014 04:00 | 12,598.3 | 0.0 | 12,598.3 | 12,598.3 | 102,470.0 | 1,290.9 | 1.00 | 1 |
| 03/03/2014 05:00 | 15,185.1 | 535.7 | 15,436.9 | 15,436.9 | 102,470.0 | 1,581.8 | 1.00 | 1 |
| 03/03/2014 06:00 | 16,984.9 | 1,192.2 | 18,177.1 | 18,177.1 | 102,470.0 | 1,862.6 | 1.00 | 1 |
| 03/03/2014 07:00 | 17,693.8 | 1,651.8 | 19,345.6 | 19,345.6 | 102,470.0 | 1,982.3 | 1.00 | 1 |
| 03/03/2014 08:00 | 17,713.4 | 3,830.3 | 21,543.7 | 21,543.7 | 102,470.0 | 2,207.6 | 1.00 | 1 |
| 03/03/2014 09:00 | 17,687.2 | 3,177.3 | 20,864.5 | 20,864.5 | 102,470.0 | 2,138.0 | 1.00 | 1 |
| 03/03/2014 10:00 | 17,669.5 | 1,632.8 | 19,302.3 | 19,302.3 | 102,470.0 | 1,977.9 | 1.00 | 1 |
| 03/03/2014 11:00 | 17,331.0 | 1,262.2 | 18,593.2 | 18,593.2 | 102,470.0 | 1,905.2 | 1.00 | 1 |
| 03/03/2014 12:00 | 16,967.8 | 1,188.5 | 18,156.3 | 18,156.3 | 102,470.0 | 1,860.5 | 1.00 | 1 |
| 03/03/2014 13:00 | 16,783.4 | 1,177.0 | 17,960.4 | 17,960.4 | 102,470.0 | 1,840.4 | 1.00 | 1 |
| 03/03/2014 14:00 | 16,968.9 | 1,178.2 | 18,147.1 | 18,147.1 | 102,470.0 | 1,859.5 | 1.00 | 1 |
| 03/03/2014 15:00 | 17,315.2 | 1,226.4 | 18,541.6 | 18,541.6 | 102,470.0 | 1,900.0 | 1.00 | 1 |
| 03/03/2014 16:00 | 17,804.7 | 1,629.5 | 19,434.2 | 19,434.2 | 102,470.0 | 1,991.4 | 1.00 | 1 |
| 03/03/2014 17:00 | 17,828.1 | 3,665.0 | 21,493.1 | 21,493.1 | 102,470.0 | 2,202.4 | 1.00 | 1 |
| 03/03/2014 18:00 | 17,659.1 | 2,421.1 | 20,080.2 | 20,080.2 | 102,470.0 | 2,057.6 | 1.00 | 1 |
| 03/03/2014 19:00 | 17,681.9 | 3,724.9 | 21,406.8 | 21,406.8 | 102,470.0 | 2,193.6 | 1.00 | 1 |
| 03/03/2014 20:00 | 17,644.6 | 4,152.3 | 21,796.9 | 21,796.9 | 102,470.0 | 2,233.5 | 1.00 | 1 |
| 03/03/2014 21:00 | 17,639.4 | 3,792.1 | 21,431.5 | 21,431.5 | 102,470.0 | 2,196.1 | 1.00 | 1 |
| 03/03/2014 22:00 | 17,266.2 | 1,681.9 | 18,948.1 | 18,948.1 | 102,470.0 | 1,941.6 | 1.00 | 1 |
| 03/03/2014 23:00 | 16,546.7 | 1,188.1 | 17,734.8 | 17,734.8 | 102,470.0 | 1,817.3 | 1.00 | 1 |
| **Average/Sum#:** | 16,468.4 | 1,705.3 | 18,149.7 | 435,593.1 # | 102,470.0 | 1,859.8 | 24.00 # | 24 # |
| **Minimum:** | 12,543.3 | 0.0 | 12,543.3 | 12,543.3 | 102,470.0 | 1,285.3 | 1.00 | 1 |
| **Maximum:** | 17,828.1 | 4,152.3 | 21,796.9 | 21,796.9 | 102,470.0 | 2,233.5 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/04/2014 00:00 | 14,903.7 | 618.5 | 15,225.3 | 15,225.3 | 102,470.0 | 1,560.1 | 1.00 | 1 |
| 03/04/2014 01:00 | 12,250.8 | 0.0 | 12,250.8 | 12,250.8 | 102,470.0 | 1,255.3 | 1.00 | 1 |
| 03/04/2014 02:00 | 12,353.5 | 0.0 | 12,353.5 | 12,353.5 | 102,470.0 | 1,265.9 | 1.00 | 1 |
| 03/04/2014 03:00 | 12,976.3 | 0.0 | 12,976.3 | 12,976.3 | 102,470.0 | 1,329.7 | 1.00 | 1 |
| 03/04/2014 04:00 | 12,452.3 | 0.0 | 12,452.3 | 12,452.3 | 102,470.0 | 1,276.0 | 1.00 | 1 |
| 03/04/2014 05:00 | 12,609.6 | 0.0 | 12,609.6 | 12,609.6 | 102,470.0 | 1,292.1 | 1.00 | 1 |
| 03/04/2014 06:00 | 15,247.4 | 457.7 | 15,453.4 | 15,453.4 | 102,470.0 | 1,583.5 | 1.00 | 1 |
| 03/04/2014 07:00 | 17,040.2 | 899.5 | 17,939.7 | 17,939.7 | 102,470.0 | 1,838.3 | 1.00 | 1 |
| 03/04/2014 08:00 | 16,951.2 | 900.1 | 17,851.3 | 17,851.3 | 102,470.0 | 1,829.2 | 1.00 | 1 |
| 03/04/2014 09:00 | 13,957.5 | 17.5 | 13,958.0 | 13,958.0 | 102,470.0 | 1,430.3 | 1.00 | 1 |
| 03/04/2014 10:00 | 12,003.4 | 0.0 | 12,003.4 | 12,003.4 | 102,470.0 | 1,230.0 | 1.00 | 1 |
| 03/04/2014 11:00 | 12,010.6 | 0.0 | 12,010.6 | 12,010.6 | 102,470.0 | 1,230.7 | 1.00 | 1 |
| 03/04/2014 12:00 | 12,332.1 | 0.0 | 12,332.1 | 12,332.1 | 102,470.0 | 1,263.7 | 1.00 | 1 |
| 03/04/2014 13:00 | 13,848.6 | 0.0 | 13,848.6 | 13,848.6 | 102,470.0 | 1,419.1 | 1.00 | 1 |
| 03/04/2014 14:00 | 17,026.4 | 972.5 | 17,969.7 | 17,969.7 | 102,470.0 | 1,841.4 | 1.00 | 1 |
| 03/04/2014 15:00 | 16,993.1 | 1,002.8 | 17,995.9 | 17,995.9 | 102,470.0 | 1,844.0 | 1.00 | 1 |
| 03/04/2014 16:00 | 16,993.9 | 1,004.9 | 17,998.8 | 17,998.8 | 102,470.0 | 1,844.3 | 1.00 | 1 |
| 03/04/2014 17:00 | 17,004.2 | 1,005.9 | 18,010.1 | 18,010.1 | 102,470.0 | 1,845.5 | 1.00 | 1 |
| 03/04/2014 18:00 | 17,311.3 | 1,055.7 | 18,367.0 | 18,367.0 | 102,470.0 | 1,882.1 | 1.00 | 1 |
| 03/04/2014 19:00 | 17,692.0 | 3,100.7 | 20,792.7 | 20,792.7 | 102,470.0 | 2,130.6 | 1.00 | 1 |
| 03/04/2014 20:00 | 17,696.8 | 2,684.2 | 20,381.0 | 20,381.0 | 102,470.0 | 2,088.4 | 1.00 | 1 |
| 03/04/2014 21:00 | 17,680.9 | 1,806.2 | 19,487.1 | 19,487.1 | 102,470.0 | 1,996.8 | 1.00 | 1 |
| 03/04/2014 22:00 | 17,416.3 | 1,413.7 | 18,830.0 | 18,830.0 | 102,470.0 | 1,929.5 | 1.00 | 1 |
| 03/04/2014 23:00 | 16,902.0 | 1,015.6 | 17,917.6 | 17,917.6 | 102,470.0 | 1,836.0 | 1.00 | 1 |
| **Average/Sum#:** | 15,152.3 | 748.1 | 15,875.6 | 381,014.8 # | 102,470.0 | 1,626.8 | 24.00 # | 24 # |
| **Minimum:** | 12,003.4 | 0.0 | 12,003.4 | 12,003.4 | 102,470.0 | 1,230.0 | 1.00 | 1 |
| **Maximum:** | 17,696.8 | 3,100.7 | 20,792.7 | 20,792.7 | 102,470.0 | 2,130.6 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/05/2014 00:00 | 17,101.2 | 1,025.8 | 18,127.0 | 18,127.0 | 102,470.0 | 1,857.5 | 1.00 | 1 |
| 03/05/2014 01:00 | 17,725.4 | 1,597.4 | 19,322.8 | 19,322.8 | 102,470.0 | 1,980.0 | 1.00 | 1 |
| 03/05/2014 02:00 | 17,733.4 | 1,675.1 | 19,408.5 | 19,408.5 | 102,470.0 | 1,988.8 | 1.00 | 1 |
| 03/05/2014 03:00 | 17,110.9 | 1,106.7 | 18,217.6 | 18,217.6 | 102,470.0 | 1,866.8 | 1.00 | 1 |
| 03/05/2014 04:00 | 16,807.0 | 1,012.1 | 17,819.1 | 17,819.1 | 102,470.0 | 1,825.9 | 1.00 | 1 |
| 03/05/2014 05:00 | 17,465.2 | 1,496.4 | 18,961.6 | 18,961.6 | 102,470.0 | 1,943.0 | 1.00 | 1 |
| 03/05/2014 06:00 | 17,471.6 | 1,198.7 | 18,670.3 | 18,670.3 | 102,470.0 | 1,913.1 | 1.00 | 1 |
| 03/05/2014 07:00 | 17,629.3 | 1,227.2 | 18,856.5 | 18,856.5 | 102,470.0 | 1,932.2 | 1.00 | 1 |
| 03/05/2014 08:00 | 17,493.6 | 1,440.4 | 18,934.0 | 18,934.0 | 102,470.0 | 1,940.2 | 1.00 | 1 |
| 03/05/2014 09:00 | 16,837.4 | 1,192.6 | 18,030.0 | 18,030.0 | 102,470.0 | 1,847.5 | 1.00 | 1 |
| 03/05/2014 10:00 | 16,855.7 | 1,189.1 | 18,044.8 | 18,044.8 | 102,470.0 | 1,849.1 | 1.00 | 1 |
| 03/05/2014 11:00 | 16,890.4 | 1,183.8 | 18,074.2 | 18,074.2 | 102,470.0 | 1,852.1 | 1.00 | 1 |
| 03/05/2014 12:00 | 16,895.8 | 1,181.6 | 18,077.4 | 18,077.4 | 102,470.0 | 1,852.4 | 1.00 | 1 |
| 03/05/2014 13:00 | 16,897.7 | 1,178.7 | 18,076.4 | 18,076.4 | 102,470.0 | 1,852.3 | 1.00 | 1 |
| 03/05/2014 14:00 | 16,906.3 | 1,175.4 | 18,081.7 | 18,081.7 | 102,470.0 | 1,852.8 | 1.00 | 1 |
| 03/05/2014 15:00 | 16,963.8 | 1,165.6 | 18,129.4 | 18,129.4 | 102,470.0 | 1,857.7 | 1.00 | 1 |
| 03/05/2014 16:00 | 17,145.9 | 1,359.3 | 18,505.2 | 18,505.2 | 102,470.0 | 1,896.2 | 1.00 | 1 |
| 03/05/2014 17:00 | 17,378.5 | 1,553.0 | 18,931.5 | 18,931.5 | 102,470.0 | 1,939.9 | 1.00 | 1 |
| 03/05/2014 18:00 | 17,389.7 | 1,591.8 | 18,981.5 | 18,981.5 | 102,470.0 | 1,945.0 | 1.00 | 1 |
| 03/05/2014 19:00 | 17,515.4 | 2,382.2 | 19,897.6 | 19,897.6 | 102,470.0 | 2,038.9 | 1.00 | 1 |
| 03/05/2014 20:00 | 17,561.2 | 1,851.0 | 19,412.2 | 19,412.2 | 102,470.0 | 1,989.2 | 1.00 | 1 |
| 03/05/2014 21:00 | 17,541.9 | 1,615.7 | 19,157.6 | 19,157.6 | 102,470.0 | 1,963.1 | 1.00 | 1 |
| 03/05/2014 22:00 | 17,431.0 | 1,631.0 | 19,062.0 | 19,062.0 | 102,470.0 | 1,953.3 | 1.00 | 1 |
| 03/05/2014 23:00 | 16,663.8 | 1,180.9 | 17,844.7 | 17,844.7 | 102,470.0 | 1,828.5 | 1.00 | 1 |
| **Average/Sum#:** | 17,225.5 | 1,383.8 | 18,609.3 | 446,623.6 # | 102,470.0 | 1,906.9 | 24.00 # | 24 # |
| **Minimum:** | 16,663.8 | 1,012.1 | 17,819.1 | 17,819.1 | 102,470.0 | 1,825.9 | 1.00 | 1 |
| **Maximum:** | 17,733.4 | 2,382.2 | 19,897.6 | 19,897.6 | 102,470.0 | 2,038.9 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/06/2014 00:00 | 16,654.2 | 1,172.9 | 17,827.1 | 17,827.1 | 102,470.0 | 1,826.7 | 1.00 | 1 |
| 03/06/2014 01:00 | 16,489.0 | 1,038.1 | 17,402.5 | 17,402.5 | 102,470.0 | 1,783.2 | 1.00 | 1 |
| 03/06/2014 02:00 | 12,407.7 | 0.0 | 12,407.7 | 12,407.7 | 102,470.0 | 1,271.4 | 1.00 | 1 |
| 03/06/2014 03:00 | 5,692.3 | 0.0 | 5,692.3 | 1,309.2 | 102,470.0 | 583.3 | 0.23 | 0 |
| 03/06/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 12,810.8 | 552.8 | 13,332.4 | 48,946.5 # | 102,470.0 | 1,366.2 | 3.23 # | 3 # |
| **Minimum:** | 5,692.3 | 0.0 | 5,692.3 | 1,309.2 | 102,470.0 | 583.3 | 0.00 | 0 |
| **Maximum:** | 16,654.2 | 1,172.9 | 17,827.1 | 17,827.1 | 102,470.0 | 1,826.7 | 1.00 | 1 |
| **%SI** | 83.3 | 83.3 | 83.3 | 83.3 | 0.0 | 83.3 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/07/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/07/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/07/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/07/2014 03:00 | 4,881.2 | 0.0 | 4,881.2 | 3,026.3 | 102,470.0 | 500.2 | 0.62 | 0 |
| 03/07/2014 04:00 | 6,069.0 | 0.0 | 6,069.0 | 6,069.0 | 102,470.0 | 621.9 | 1.00 | 0 |
| 03/07/2014 05:00 | 9,414.6 | 0.0 | 9,414.6 | 9,414.6 | 102,470.0 | 964.7 | 1.00 | 0 |
| 03/07/2014 06:00 | 14,147.8 | 0.0 | 14,147.8 | 14,147.8 | 102,470.0 | 1,449.7 | 1.00 | 1 |
| 03/07/2014 07:00 | 17,560.0 | 0.0 | 17,560.0 | 17,560.0 | 102,470.0 | 1,799.4 | 1.00 | 1 |
| 03/07/2014 08:00 | 15,053.2 | 0.0 | 15,053.2 | 15,053.2 | 102,470.0 | 1,542.5 | 1.00 | 1 |
| 03/07/2014 09:00 | 13,005.9 | 0.0 | 13,005.9 | 13,005.9 | 102,470.0 | 1,332.7 | 1.00 | 1 |
| 03/07/2014 10:00 | 16,615.1 | 1,029.0 | 17,510.3 | 17,510.3 | 102,470.0 | 1,794.3 | 1.00 | 1 |
| 03/07/2014 11:00 | 16,628.3 | 1,220.5 | 17,848.8 | 17,848.8 | 102,470.0 | 1,829.0 | 1.00 | 1 |
| 03/07/2014 12:00 | 16,711.9 | 1,217.3 | 17,929.2 | 17,929.2 | 102,470.0 | 1,837.2 | 1.00 | 1 |
| 03/07/2014 13:00 | 16,713.3 | 1,211.9 | 17,925.2 | 17,925.2 | 102,470.0 | 1,836.8 | 1.00 | 1 |
| 03/07/2014 14:00 | 16,671.1 | 1,223.3 | 17,894.4 | 17,894.4 | 102,470.0 | 1,833.6 | 1.00 | 1 |
| 03/07/2014 15:00 | 16,668.3 | 1,222.2 | 17,890.5 | 17,890.5 | 102,470.0 | 1,833.2 | 1.00 | 1 |
| 03/07/2014 16:00 | 16,866.5 | 1,263.7 | 18,130.2 | 18,130.2 | 102,470.0 | 1,857.8 | 1.00 | 1 |
| 03/07/2014 17:00 | 17,672.7 | 1,949.6 | 19,622.3 | 19,622.3 | 102,470.0 | 2,010.7 | 1.00 | 1 |
| 03/07/2014 18:00 | 17,827.8 | 1,825.5 | 19,653.3 | 19,653.3 | 102,470.0 | 2,013.9 | 1.00 | 1 |
| 03/07/2014 19:00 | 17,889.6 | 3,232.2 | 21,121.8 | 21,121.8 | 102,470.0 | 2,164.4 | 1.00 | 1 |
| 03/07/2014 20:00 | 17,745.3 | 4,123.5 | 21,868.8 | 21,868.8 | 102,470.0 | 2,240.9 | 1.00 | 1 |
| 03/07/2014 21:00 | 17,731.8 | 3,936.4 | 21,668.2 | 21,668.2 | 102,470.0 | 2,220.3 | 1.00 | 1 |
| 03/07/2014 22:00 | 17,717.7 | 3,941.5 | 21,659.2 | 21,659.2 | 102,470.0 | 2,219.4 | 1.00 | 1 |
| 03/07/2014 23:00 | 17,730.4 | 3,164.4 | 20,894.8 | 20,894.8 | 102,470.0 | 2,141.1 | 1.00 | 1 |
| **Average/Sum#:** | 15,301.0 | 1,455.3 | 16,749.9 | 349,893.8 # | 102,470.0 | 1,716.4 | 20.62 # | 18 # |
| **Minimum:** | 4,881.2 | 0.0 | 4,881.2 | 3,026.3 | 102,470.0 | 500.2 | 0.00 | 0 |
| **Maximum:** | 17,889.6 | 4,123.5 | 21,868.8 | 21,868.8 | 102,470.0 | 2,240.9 | 1.00 | 1 |
| **%SI** | 12.5 | 12.5 | 12.5 | 12.5 | 0.0 | 12.5 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/08/2014 00:00 | 17,588.3 | 1,204.9 | 18,793.2 | 18,793.2 | 102,470.0 | 1,925.7 | 1.00 | 1 |
| 03/08/2014 01:00 | 17,673.5 | 1,320.7 | 18,994.2 | 18,994.2 | 102,470.0 | 1,946.3 | 1.00 | 1 |
| 03/08/2014 02:00 | 17,313.3 | 1,277.5 | 18,590.8 | 18,590.8 | 102,470.0 | 1,905.0 | 1.00 | 1 |
| 03/08/2014 03:00 | 17,154.5 | 1,259.3 | 18,413.8 | 18,413.8 | 102,470.0 | 1,886.9 | 1.00 | 1 |
| 03/08/2014 04:00 | 17,677.3 | 1,343.7 | 19,021.0 | 19,021.0 | 102,470.0 | 1,949.1 | 1.00 | 1 |
| 03/08/2014 05:00 | 17,734.1 | 1,715.5 | 19,449.6 | 19,449.6 | 102,470.0 | 1,993.0 | 1.00 | 1 |
| 03/08/2014 06:00 | 17,722.6 | 2,052.5 | 19,775.1 | 19,775.1 | 102,470.0 | 2,026.4 | 1.00 | 1 |
| 03/08/2014 07:00 | 17,697.7 | 1,858.1 | 19,555.8 | 19,555.8 | 102,470.0 | 2,003.9 | 1.00 | 1 |
| 03/08/2014 08:00 | 16,959.7 | 1,185.1 | 18,144.8 | 18,144.8 | 102,470.0 | 1,859.3 | 1.00 | 1 |
| 03/08/2014 09:00 | 16,496.7 | 1,172.3 | 17,669.0 | 17,669.0 | 102,470.0 | 1,810.5 | 1.00 | 1 |
| 03/08/2014 10:00 | 16,510.1 | 1,162.9 | 17,673.0 | 17,673.0 | 102,470.0 | 1,811.0 | 1.00 | 1 |
| 03/08/2014 11:00 | 16,550.5 | 1,157.7 | 17,708.2 | 17,708.2 | 102,470.0 | 1,814.6 | 1.00 | 1 |
| 03/08/2014 12:00 | 16,573.9 | 1,152.2 | 17,726.1 | 17,726.1 | 102,470.0 | 1,816.4 | 1.00 | 1 |
| 03/08/2014 13:00 | 16,566.5 | 1,153.7 | 17,720.2 | 17,720.2 | 102,470.0 | 1,815.8 | 1.00 | 1 |
| 03/08/2014 14:00 | 16,539.8 | 1,165.0 | 17,704.8 | 17,704.8 | 102,470.0 | 1,814.2 | 1.00 | 1 |
| 03/08/2014 15:00 | 16,521.8 | 1,159.8 | 17,681.6 | 17,681.6 | 102,470.0 | 1,811.8 | 1.00 | 1 |
| 03/08/2014 16:00 | 16,628.2 | 1,162.8 | 17,791.0 | 17,791.0 | 102,470.0 | 1,823.0 | 1.00 | 1 |
| 03/08/2014 17:00 | 16,772.8 | 1,296.4 | 18,069.2 | 18,069.2 | 102,470.0 | 1,851.6 | 1.00 | 1 |
| 03/08/2014 18:00 | 17,521.3 | 2,913.2 | 20,434.5 | 20,434.5 | 102,470.0 | 2,093.9 | 1.00 | 1 |
| 03/08/2014 19:00 | 17,639.8 | 3,636.3 | 21,276.1 | 21,276.1 | 102,470.0 | 2,180.2 | 1.00 | 1 |
| 03/08/2014 20:00 | 17,567.3 | 4,059.5 | 21,626.8 | 21,626.8 | 102,470.0 | 2,216.1 | 1.00 | 1 |
| 03/08/2014 21:00 | 17,535.8 | 4,046.0 | 21,581.8 | 21,581.8 | 102,470.0 | 2,211.5 | 1.00 | 1 |
| 03/08/2014 22:00 | 17,611.1 | 4,006.1 | 21,617.2 | 21,617.2 | 102,470.0 | 2,215.1 | 1.00 | 1 |
| 03/08/2014 23:00 | 17,623.6 | 3,547.3 | 21,170.9 | 21,170.9 | 102,470.0 | 2,169.4 | 1.00 | 1 |
| **Average/Sum#:** | 17,174.2 | 1,917.0 | 19,091.2 | 458,188.7 # | 102,470.0 | 1,956.3 | 24.00 # | 24 # |
| **Minimum:** | 16,496.7 | 1,152.2 | 17,669.0 | 17,669.0 | 102,470.0 | 1,810.5 | 1.00 | 1 |
| **Maximum:** | 17,734.1 | 4,059.5 | 21,626.8 | 21,626.8 | 102,470.0 | 2,216.1 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/09/2014 00:00 | 16,664.6 | 1,206.1 | 17,593.3 | 17,593.3 | 102,470.0 | 1,802.8 | 1.00 | 1 |
| 03/09/2014 01:00 | 13,422.2 | 0.0 | 13,422.2 | 13,422.2 | 102,470.0 | 1,375.4 | 1.00 | 1 |
| 03/09/2014 02:00 | 6,013.0 | 0.0 | 6,013.0 | 1,383.0 | 102,470.0 | 616.2 | 0.23 | 0 |
| 03/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 11:00 | 5,634.5 | 0.0 | 5,634.5 | 4,507.6 | 102,470.0 | 577.4 | 0.80 | 0 |
| 03/09/2014 12:00 | 8,690.5 | 0.0 | 8,690.5 | 8,690.5 | 102,470.0 | 890.5 | 1.00 | 0 |
| 03/09/2014 13:00 | 13,171.9 | 0.0 | 13,171.9 | 13,171.9 | 102,470.0 | 1,349.7 | 1.00 | 1 |
| 03/09/2014 14:00 | 17,230.0 | 0.0 | 17,230.0 | 17,230.0 | 102,470.0 | 1,765.6 | 1.00 | 1 |
| 03/09/2014 15:00 | 17,163.2 | 0.0 | 17,163.2 | 17,163.2 | 102,470.0 | 1,758.7 | 1.00 | 1 |
| 03/09/2014 16:00 | 14,761.9 | 3.2 | 14,762.0 | 14,762.0 | 102,470.0 | 1,512.7 | 1.00 | 1 |
| 03/09/2014 17:00 | 17,690.3 | 2,376.7 | 20,067.0 | 20,067.0 | 102,470.0 | 2,056.3 | 1.00 | 1 |
| 03/09/2014 18:00 | 17,701.5 | 3,768.5 | 21,470.0 | 21,470.0 | 102,470.0 | 2,200.0 | 1.00 | 1 |
| 03/09/2014 19:00 | 17,679.3 | 4,080.3 | 21,759.6 | 21,759.6 | 102,470.0 | 2,229.7 | 1.00 | 1 |
| 03/09/2014 20:00 | 17,569.5 | 4,103.4 | 21,672.9 | 21,672.9 | 102,470.0 | 2,220.8 | 1.00 | 1 |
| 03/09/2014 21:00 | 17,573.6 | 4,107.9 | 21,681.5 | 21,681.5 | 102,470.0 | 2,221.7 | 1.00 | 1 |
| 03/09/2014 22:00 | 17,555.5 | 2,636.6 | 20,192.1 | 20,192.1 | 102,470.0 | 2,069.1 | 1.00 | 1 |
| 03/09/2014 23:00 | 17,531.4 | 3,912.4 | 21,443.8 | 21,443.8 | 102,470.0 | 2,197.3 | 1.00 | 1 |
| **Average/Sum#:** | 14,753.3 | 1,637.2 | 16,373.0 | 256,210.6 # | 102,470.0 | 1,677.7 | 15.03 # | 13 # |
| **Minimum:** | 5,634.5 | 0.0 | 5,634.5 | 1,383.0 | 102,470.0 | 577.4 | 0.00 | 0 |
| **Maximum:** | 17,701.5 | 4,107.9 | 21,759.6 | 21,759.6 | 102,470.0 | 2,229.7 | 1.00 | 1 |
| **%SI** | 33.3 | 33.3 | 33.3 | 33.3 | 0.0 | 33.3 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/10/2014 00:00 | 17,540.4 | 2,742.5 | 20,282.9 | 20,282.9 | 102,470.0 | 2,078.4 | 1.00 | 1 |
| 03/10/2014 01:00 | 12,769.5 | 16.3 | 12,770.0 | 12,770.0 | 102,470.0 | 1,308.5 | 1.00 | 1 |
| 03/10/2014 02:00 | 12,033.0 | 0.0 | 12,033.0 | 12,033.0 | 102,470.0 | 1,233.0 | 1.00 | 1 |
| 03/10/2014 03:00 | 12,068.5 | 0.0 | 12,068.5 | 12,068.5 | 102,470.0 | 1,236.7 | 1.00 | 1 |
| 03/10/2014 04:00 | 12,126.4 | 0.0 | 12,126.4 | 12,126.4 | 102,470.0 | 1,242.6 | 1.00 | 1 |
| 03/10/2014 05:00 | 14,940.2 | 406.8 | 15,082.6 | 15,082.6 | 102,470.0 | 1,545.5 | 1.00 | 1 |
| 03/10/2014 06:00 | 17,439.6 | 1,754.1 | 19,193.7 | 19,193.7 | 102,470.0 | 1,966.8 | 1.00 | 1 |
| 03/10/2014 07:00 | 17,715.8 | 3,288.7 | 21,004.5 | 21,004.5 | 102,470.0 | 2,152.3 | 1.00 | 1 |
| 03/10/2014 08:00 | 17,698.2 | 2,839.4 | 20,537.6 | 20,537.6 | 102,470.0 | 2,104.5 | 1.00 | 1 |
| 03/10/2014 09:00 | 16,926.3 | 1,179.4 | 18,105.7 | 18,105.7 | 102,470.0 | 1,855.3 | 1.00 | 1 |
| 03/10/2014 10:00 | 16,547.6 | 1,169.8 | 17,717.4 | 17,717.4 | 102,470.0 | 1,815.5 | 1.00 | 1 |
| 03/10/2014 11:00 | 16,603.0 | 1,165.1 | 17,768.1 | 17,768.1 | 102,470.0 | 1,820.7 | 1.00 | 1 |
| 03/10/2014 12:00 | 16,604.9 | 1,168.2 | 17,773.1 | 17,773.1 | 102,470.0 | 1,821.2 | 1.00 | 1 |
| 03/10/2014 13:00 | 16,617.4 | 1,171.9 | 17,789.3 | 17,789.3 | 102,470.0 | 1,822.9 | 1.00 | 1 |
| 03/10/2014 14:00 | 16,635.1 | 1,188.0 | 17,823.1 | 17,823.1 | 102,470.0 | 1,826.3 | 1.00 | 1 |
| 03/10/2014 15:00 | 16,675.9 | 1,184.3 | 17,860.2 | 17,860.2 | 102,470.0 | 1,830.1 | 1.00 | 1 |
| 03/10/2014 16:00 | 16,647.4 | 1,186.0 | 17,833.4 | 17,833.4 | 102,470.0 | 1,827.4 | 1.00 | 1 |
| 03/10/2014 17:00 | 16,681.4 | 1,143.8 | 17,825.2 | 17,825.2 | 102,470.0 | 1,826.5 | 1.00 | 1 |
| 03/10/2014 18:00 | 17,099.4 | 943.0 | 18,042.4 | 18,042.4 | 102,470.0 | 1,848.8 | 1.00 | 1 |
| 03/10/2014 19:00 | 17,753.5 | 3,171.7 | 20,925.2 | 20,925.2 | 102,470.0 | 2,144.2 | 1.00 | 1 |
| 03/10/2014 20:00 | 17,813.1 | 2,507.7 | 20,320.8 | 20,320.8 | 102,470.0 | 2,082.3 | 1.00 | 1 |
| 03/10/2014 21:00 | 16,044.1 | 836.6 | 16,696.6 | 16,696.6 | 102,470.0 | 1,710.9 | 1.00 | 1 |
| 03/10/2014 22:00 | 13,558.7 | 0.0 | 13,558.7 | 13,558.7 | 102,470.0 | 1,389.4 | 1.00 | 1 |
| 03/10/2014 23:00 | 5,604.8 | 0.0 | 5,604.8 | 1,289.1 | 102,470.0 | 574.3 | 0.23 | 0 |
| **Average/Sum#:** | 15,506.0 | 1,211.0 | 16,697.6 | 396,427.5 # | 102,470.0 | 1,711.0 | 23.23 # | 23 # |
| **Minimum:** | 5,604.8 | 0.0 | 5,604.8 | 1,289.1 | 102,470.0 | 574.3 | 0.23 | 0 |
| **Maximum:** | 17,813.1 | 3,288.7 | 21,004.5 | 21,004.5 | 102,470.0 | 2,152.3 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/11/2014 02:00 | 4,718.2 | 0.0 | 4,718.2 | 2,830.9 | 102,470.0 | 483.5 | 0.60 | 0 |
| 03/11/2014 03:00 | 9,047.7 | 0.0 | 9,047.7 | 9,047.7 | 102,470.0 | 927.1 | 1.00 | 0 |
| 03/11/2014 04:00 | 12,995.4 | 0.0 | 12,995.4 | 12,995.4 | 102,470.0 | 1,331.6 | 1.00 | 1 |
| 03/11/2014 05:00 | 15,418.7 | 0.0 | 15,418.7 | 15,418.7 | 102,470.0 | 1,580.0 | 1.00 | 1 |
| 03/11/2014 06:00 | 14,873.3 | 0.0 | 14,873.3 | 14,873.3 | 102,470.0 | 1,524.1 | 1.00 | 1 |
| 03/11/2014 07:00 | 17,201.1 | 0.0 | 17,201.1 | 17,201.1 | 102,470.0 | 1,762.6 | 1.00 | 1 |
| 03/11/2014 08:00 | 17,361.8 | 1,222.4 | 18,584.2 | 18,584.2 | 102,470.0 | 1,904.3 | 1.00 | 1 |
| 03/11/2014 09:00 | 16,506.5 | 1,177.0 | 17,683.5 | 17,683.5 | 102,470.0 | 1,812.0 | 1.00 | 1 |
| 03/11/2014 10:00 | 16,532.9 | 1,164.7 | 17,697.6 | 17,697.6 | 102,470.0 | 1,813.5 | 1.00 | 1 |
| 03/11/2014 11:00 | 16,560.4 | 1,155.2 | 17,715.6 | 17,715.6 | 102,470.0 | 1,815.3 | 1.00 | 1 |
| 03/11/2014 12:00 | 16,034.0 | 907.3 | 16,759.8 | 16,759.8 | 102,470.0 | 1,717.4 | 1.00 | 1 |
| 03/11/2014 13:00 | 12,972.9 | 0.0 | 12,972.9 | 12,972.9 | 102,470.0 | 1,329.3 | 1.00 | 1 |
| 03/11/2014 14:00 | 12,386.1 | 0.0 | 12,386.1 | 12,386.1 | 102,470.0 | 1,269.2 | 1.00 | 1 |
| 03/11/2014 15:00 | 12,638.8 | 0.0 | 12,638.8 | 12,638.8 | 102,470.0 | 1,295.1 | 1.00 | 1 |
| 03/11/2014 16:00 | 13,372.9 | 0.0 | 13,372.9 | 13,372.9 | 102,470.0 | 1,370.3 | 1.00 | 1 |
| 03/11/2014 17:00 | 13,491.1 | 0.0 | 13,491.1 | 13,491.1 | 102,470.0 | 1,382.4 | 1.00 | 1 |
| 03/11/2014 18:00 | 15,021.3 | 533.0 | 15,271.8 | 15,271.8 | 102,470.0 | 1,564.9 | 1.00 | 1 |
| 03/11/2014 19:00 | 17,472.5 | 2,719.4 | 20,191.9 | 20,191.9 | 102,470.0 | 2,069.1 | 1.00 | 1 |
| 03/11/2014 20:00 | 17,823.0 | 3,060.7 | 20,883.7 | 20,883.7 | 102,470.0 | 2,140.0 | 1.00 | 1 |
| 03/11/2014 21:00 | 17,873.8 | 2,436.0 | 20,309.8 | 20,309.8 | 102,470.0 | 2,081.1 | 1.00 | 1 |
| 03/11/2014 22:00 | 17,814.8 | 3,074.8 | 20,889.6 | 20,889.6 | 102,470.0 | 2,140.6 | 1.00 | 1 |
| 03/11/2014 23:00 | 16,130.1 | 941.6 | 16,864.5 | 16,864.5 | 102,470.0 | 1,728.1 | 1.00 | 1 |
| **Average/Sum#:** | 14,738.5 | 836.0 | 15,544.0 | 340,080.9 # | 102,470.0 | 1,592.8 | 21.60 # | 20 # |
| **Minimum:** | 4,718.2 | 0.0 | 4,718.2 | 2,830.9 | 102,470.0 | 483.5 | 0.00 | 0 |
| **Maximum:** | 17,873.8 | 3,074.8 | 20,889.6 | 20,889.6 | 102,470.0 | 2,140.6 | 1.00 | 1 |
| **%SI** | 8.3 | 8.3 | 8.3 | 8.3 | 0.0 | 8.3 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/12/2014 00:00 | 12,404.9 | 0.0 | 12,404.9 | 12,404.9 | 102,470.0 | 1,271.1 | 1.00 | 1 |
| 03/12/2014 01:00 | 12,269.2 | 0.0 | 12,269.2 | 12,269.2 | 102,470.0 | 1,257.2 | 1.00 | 1 |
| 03/12/2014 02:00 | 12,050.1 | 0.0 | 12,050.1 | 12,050.1 | 102,470.0 | 1,234.8 | 1.00 | 1 |
| 03/12/2014 03:00 | 11,966.7 | 0.0 | 11,966.7 | 11,966.7 | 102,470.0 | 1,226.2 | 1.00 | 1 |
| 03/12/2014 04:00 | 12,013.4 | 0.0 | 12,013.4 | 12,013.4 | 102,470.0 | 1,231.0 | 1.00 | 1 |
| 03/12/2014 05:00 | 15,982.5 | 854.4 | 16,606.2 | 16,606.2 | 102,470.0 | 1,701.6 | 1.00 | 1 |
| 03/12/2014 06:00 | 17,593.5 | 1,471.7 | 19,065.2 | 19,065.2 | 102,470.0 | 1,953.6 | 1.00 | 1 |
| 03/12/2014 07:00 | 17,763.5 | 3,242.5 | 21,006.0 | 21,006.0 | 102,470.0 | 2,152.5 | 1.00 | 1 |
| 03/12/2014 08:00 | 17,595.9 | 1,486.1 | 19,082.0 | 19,082.0 | 102,470.0 | 1,955.3 | 1.00 | 1 |
| 03/12/2014 09:00 | 16,814.3 | 1,053.0 | 17,867.3 | 17,867.3 | 102,470.0 | 1,830.9 | 1.00 | 1 |
| 03/12/2014 10:00 | 16,833.1 | 1,045.4 | 17,878.5 | 17,878.5 | 102,470.0 | 1,832.0 | 1.00 | 1 |
| 03/12/2014 11:00 | 16,861.2 | 1,038.8 | 17,900.0 | 17,900.0 | 102,470.0 | 1,834.2 | 1.00 | 1 |
| 03/12/2014 12:00 | 13,214.4 | 150.4 | 13,237.0 | 13,237.0 | 102,470.0 | 1,356.4 | 1.00 | 1 |
| 03/12/2014 13:00 | 13,390.6 | 0.0 | 13,390.6 | 13,390.6 | 102,470.0 | 1,372.1 | 1.00 | 1 |
| 03/12/2014 14:00 | 12,147.5 | 0.0 | 12,147.5 | 12,147.5 | 102,470.0 | 1,244.8 | 1.00 | 1 |
| 03/12/2014 15:00 | 12,138.2 | 0.0 | 12,138.2 | 12,138.2 | 102,470.0 | 1,243.8 | 1.00 | 1 |
| 03/12/2014 16:00 | 12,139.1 | 0.0 | 12,139.1 | 12,139.1 | 102,470.0 | 1,243.9 | 1.00 | 1 |
| 03/12/2014 17:00 | 14,856.2 | 462.1 | 15,064.1 | 15,064.1 | 102,470.0 | 1,543.6 | 1.00 | 1 |
| 03/12/2014 18:00 | 17,310.8 | 1,253.4 | 18,564.2 | 18,564.2 | 102,470.0 | 1,902.3 | 1.00 | 1 |
| 03/12/2014 19:00 | 17,850.2 | 3,359.2 | 21,209.4 | 21,209.4 | 102,470.0 | 2,173.3 | 1.00 | 1 |
| 03/12/2014 20:00 | 17,883.5 | 3,506.6 | 21,390.1 | 21,390.1 | 102,470.0 | 2,191.8 | 1.00 | 1 |
| 03/12/2014 21:00 | 17,828.3 | 4,205.0 | 22,033.3 | 22,033.3 | 102,470.0 | 2,257.8 | 1.00 | 1 |
| 03/12/2014 22:00 | 17,788.5 | 4,215.9 | 22,004.4 | 22,004.4 | 102,470.0 | 2,254.8 | 1.00 | 1 |
| 03/12/2014 23:00 | 17,783.7 | 3,185.8 | 20,969.5 | 20,969.5 | 102,470.0 | 2,148.7 | 1.00 | 1 |
| **Average/Sum#:** | 15,186.6 | 1,272.1 | 16,433.2 | 394,396.9 # | 102,470.0 | 1,683.9 | 24.00 # | 24 # |
| **Minimum:** | 11,966.7 | 0.0 | 11,966.7 | 11,966.7 | 102,470.0 | 1,226.2 | 1.00 | 1 |
| **Maximum:** | 17,883.5 | 4,215.9 | 22,033.3 | 22,033.3 | 102,470.0 | 2,257.8 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/13/2014 00:00 | 16,255.7 | 317.3 | 16,344.5 | 16,344.5 | 102,470.0 | 1,674.8 | 1.00 | 1 |
| 03/13/2014 01:00 | 17,482.7 | 0.0 | 17,482.7 | 17,482.7 | 102,470.0 | 1,791.5 | 1.00 | 1 |
| 03/13/2014 02:00 | 13,566.1 | 0.0 | 13,566.1 | 13,566.1 | 102,470.0 | 1,390.1 | 1.00 | 1 |
| 03/13/2014 03:00 | 13,405.0 | 0.0 | 13,405.0 | 13,405.0 | 102,470.0 | 1,373.6 | 1.00 | 1 |
| 03/13/2014 04:00 | 13,432.2 | 0.0 | 13,432.2 | 13,432.2 | 102,470.0 | 1,376.4 | 1.00 | 1 |
| 03/13/2014 05:00 | 17,128.0 | 1,257.7 | 18,071.3 | 18,071.3 | 102,470.0 | 1,851.8 | 1.00 | 1 |
| 03/13/2014 06:00 | 17,542.4 | 1,587.1 | 19,129.5 | 19,129.5 | 102,470.0 | 1,960.2 | 1.00 | 1 |
| 03/13/2014 07:00 | 17,618.9 | 3,913.8 | 21,532.7 | 21,532.7 | 102,470.0 | 2,206.5 | 1.00 | 1 |
| 03/13/2014 08:00 | 17,879.5 | 2,537.2 | 20,416.7 | 20,416.7 | 102,470.0 | 2,092.1 | 1.00 | 1 |
| 03/13/2014 09:00 | 17,564.7 | 1,719.7 | 19,284.4 | 19,284.4 | 102,470.0 | 1,976.1 | 1.00 | 1 |
| 03/13/2014 10:00 | 17,182.1 | 1,187.6 | 18,369.7 | 18,369.7 | 102,470.0 | 1,882.3 | 1.00 | 1 |
| 03/13/2014 11:00 | 16,801.1 | 972.3 | 17,773.4 | 17,773.4 | 102,470.0 | 1,821.2 | 1.00 | 1 |
| 03/13/2014 12:00 | 17,381.7 | 1,039.3 | 18,421.0 | 18,421.0 | 102,470.0 | 1,887.6 | 1.00 | 1 |
| 03/13/2014 13:00 | 17,734.0 | 1,221.5 | 18,955.5 | 18,955.5 | 102,470.0 | 1,942.4 | 1.00 | 1 |
| 03/13/2014 14:00 | 17,693.1 | 1,310.9 | 19,004.0 | 19,004.0 | 102,470.0 | 1,947.3 | 1.00 | 1 |
| 03/13/2014 15:00 | 17,666.7 | 1,335.3 | 19,002.0 | 19,002.0 | 102,470.0 | 1,947.1 | 1.00 | 1 |
| 03/13/2014 16:00 | 17,349.4 | 1,124.2 | 18,473.6 | 18,473.6 | 102,470.0 | 1,893.0 | 1.00 | 1 |
| 03/13/2014 17:00 | 16,876.5 | 983.5 | 17,860.0 | 17,860.0 | 102,470.0 | 1,830.1 | 1.00 | 1 |
| 03/13/2014 18:00 | 17,077.4 | 1,027.7 | 18,105.1 | 18,105.1 | 102,470.0 | 1,855.2 | 1.00 | 1 |
| 03/13/2014 19:00 | 17,406.6 | 1,358.5 | 18,765.1 | 18,765.1 | 102,470.0 | 1,922.9 | 1.00 | 1 |
| 03/13/2014 20:00 | 17,210.0 | 1,000.1 | 18,210.1 | 18,210.1 | 102,470.0 | 1,866.0 | 1.00 | 1 |
| 03/13/2014 21:00 | 16,392.2 | 889.8 | 17,086.2 | 17,086.2 | 102,470.0 | 1,750.8 | 1.00 | 1 |
| 03/13/2014 22:00 | 10,132.8 | 0.0 | 10,132.8 | 709.3 | 102,470.0 | 1,038.3 | 0.07 | 1 |
| 03/13/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 16,468.6 | 1,077.5 | 17,514.1 | 393,400.1 # | 102,470.0 | 1,794.7 | 22.07 # | 23 # |
| **Minimum:** | 10,132.8 | 0.0 | 10,132.8 | 709.3 | 102,470.0 | 1,038.3 | 0.00 | 0 |
| **Maximum:** | 17,879.5 | 3,913.8 | 21,532.7 | 21,532.7 | 102,470.0 | 2,206.5 | 1.00 | 1 |
| **%SI** | 4.2 | 4.2 | 4.2 | 4.2 | 0.0 | 4.2 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/14/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/15/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/30/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT1 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT1 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT1 GasFlow, Total, 100scf 1 Hour(s) | Unit CT1 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT1 HI, MBtuPerHr 1 Hour(s) | Unit CT1 OperatingTime, Hr 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/31/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/01/2014 00:00 | 15,929.1 | 0.0 | 15,929.1 | 15,929.1 | 102,990.1 | 1,640.5 | 1.00 | 1 |
| 01/01/2014 01:00 | 17,652.6 | 0.0 | 17,652.6 | 17,652.6 | 102,990.1 | 1,818.0 | 1.00 | 1 |
| 01/01/2014 02:00 | 16,498.7 | 0.0 | 16,498.7 | 16,498.7 | 102,990.1 | 1,699.2 | 1.00 | 1 |
| 01/01/2014 03:00 | 11,137.5 | 0.0 | 11,137.5 | 6,125.6 | 102,990.1 | 1,147.1 | 0.55 | 0 |
| 01/01/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/01/2014 13:00 | 4,495.8 | 0.0 | 4,495.8 | 3,012.2 | 102,990.1 | 463.0 | 0.67 | 0 |
| 01/01/2014 14:00 | 9,029.8 | 0.0 | 9,029.8 | 9,029.8 | 102,990.1 | 930.0 | 1.00 | 0 |
| 01/01/2014 15:00 | 16,038.1 | 0.0 | 16,038.1 | 16,038.1 | 102,990.1 | 1,651.8 | 1.00 | 1 |
| 01/01/2014 16:00 | 16,813.6 | 0.0 | 16,813.6 | 16,813.6 | 102,990.1 | 1,731.6 | 1.00 | 1 |
| 01/01/2014 17:00 | 14,568.7 | 0.0 | 14,568.7 | 14,568.7 | 102,990.1 | 1,500.4 | 1.00 | 1 |
| 01/01/2014 18:00 | 17,090.1 | 231.9 | 17,120.2 | 17,120.2 | 102,990.1 | 1,763.2 | 1.00 | 1 |
| 01/01/2014 19:00 | 17,625.9 | 2,666.5 | 20,292.4 | 20,292.4 | 102,990.1 | 2,089.9 | 1.00 | 1 |
| 01/01/2014 20:00 | 17,668.2 | 3,441.7 | 21,109.9 | 21,109.9 | 102,990.1 | 2,174.1 | 1.00 | 1 |
| 01/01/2014 21:00 | 17,728.5 | 3,566.9 | 21,295.4 | 21,295.4 | 102,990.1 | 2,193.2 | 1.00 | 1 |
| 01/01/2014 22:00 | 17,734.2 | 2,696.2 | 20,430.4 | 20,430.4 | 102,990.1 | 2,104.1 | 1.00 | 1 |
| 01/01/2014 23:00 | 17,781.0 | 2,680.5 | 20,461.5 | 20,461.5 | 102,990.1 | 2,107.3 | 1.00 | 1 |
| **Average/Sum#:** | 15,186.1 | 1,018.9 | 16,191.6 | 236,378.2 # | 102,990.1 | 1,667.6 | 14.22 # | 12 # |
| **Minimum:** | 4,495.8 | 0.0 | 4,495.8 | 3,012.2 | 102,990.1 | 463.0 | 0.00 | 0 |
| **Maximum:** | 17,781.0 | 3,566.9 | 21,295.4 | 21,295.4 | 102,990.1 | 2,193.2 | 1.00 | 1 |
| **%SI** | 37.5 | 37.5 | 37.5 | 37.5 | 0.0 | 37.5 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/02/2014 00:00 | 17,795.1 | 2,453.5 | 20,248.6 | 20,248.6 | 102,990.1 | 2,085.4 | 1.00 | 1 |
| 01/02/2014 01:00 | 17,486.7 | 890.9 | 18,128.1 | 18,128.1 | 102,990.1 | 1,867.0 | 1.00 | 1 |
| 01/02/2014 02:00 | 15,517.8 | 0.0 | 15,517.8 | 15,517.8 | 102,990.1 | 1,598.2 | 1.00 | 1 |
| 01/02/2014 03:00 | 16,697.9 | 0.0 | 16,697.9 | 16,697.9 | 102,990.1 | 1,719.7 | 1.00 | 1 |
| 01/02/2014 04:00 | 15,518.3 | 0.0 | 15,518.3 | 15,518.3 | 102,990.1 | 1,598.2 | 1.00 | 1 |
| 01/02/2014 05:00 | 16,995.1 | 952.6 | 17,595.2 | 17,595.2 | 102,990.1 | 1,812.1 | 1.00 | 1 |
| 01/02/2014 06:00 | 17,723.6 | 1,934.1 | 19,657.7 | 19,657.7 | 102,990.1 | 2,024.5 | 1.00 | 1 |
| 01/02/2014 07:00 | 17,772.7 | 1,834.0 | 19,606.7 | 19,606.7 | 102,990.1 | 2,019.3 | 1.00 | 1 |
| 01/02/2014 08:00 | 17,871.7 | 2,125.9 | 19,997.6 | 19,997.6 | 102,990.1 | 2,059.6 | 1.00 | 1 |
| 01/02/2014 09:00 | 17,915.1 | 2,179.2 | 20,094.3 | 20,094.3 | 102,990.1 | 2,069.5 | 1.00 | 1 |
| 01/02/2014 10:00 | 17,839.6 | 2,159.3 | 19,998.9 | 19,998.9 | 102,990.1 | 2,059.7 | 1.00 | 1 |
| 01/02/2014 11:00 | 17,609.1 | 2,285.2 | 19,894.3 | 19,894.3 | 102,990.1 | 2,048.9 | 1.00 | 1 |
| 01/02/2014 12:00 | 17,447.8 | 2,286.1 | 19,733.9 | 19,733.9 | 102,990.1 | 2,032.4 | 1.00 | 1 |
| 01/02/2014 13:00 | 17,326.0 | 2,288.3 | 19,614.3 | 19,614.3 | 102,990.1 | 2,020.1 | 1.00 | 1 |
| 01/02/2014 14:00 | 17,222.2 | 2,027.3 | 19,249.5 | 19,249.5 | 102,990.1 | 1,982.5 | 1.00 | 1 |
| 01/02/2014 15:00 | 17,157.8 | 2,351.1 | 19,508.9 | 19,508.9 | 102,990.1 | 2,009.2 | 1.00 | 1 |
| 01/02/2014 16:00 | 17,173.4 | 2,549.1 | 19,722.5 | 19,722.5 | 102,990.1 | 2,031.2 | 1.00 | 1 |
| 01/02/2014 17:00 | 17,261.5 | 2,635.6 | 19,897.1 | 19,897.1 | 102,990.1 | 2,049.2 | 1.00 | 1 |
| 01/02/2014 18:00 | 17,337.7 | 3,466.6 | 20,804.3 | 20,804.3 | 102,990.1 | 2,142.6 | 1.00 | 1 |
| 01/02/2014 19:00 | 17,370.2 | 3,711.2 | 21,081.4 | 21,081.4 | 102,990.1 | 2,171.2 | 1.00 | 1 |
| 01/02/2014 20:00 | 17,364.7 | 3,524.6 | 20,889.3 | 20,889.3 | 102,990.1 | 2,151.4 | 1.00 | 1 |
| 01/02/2014 21:00 | 17,435.7 | 3,372.0 | 20,807.7 | 20,807.7 | 102,990.1 | 2,143.0 | 1.00 | 1 |
| 01/02/2014 22:00 | 17,691.0 | 2,662.7 | 20,353.7 | 20,353.7 | 102,990.1 | 2,096.2 | 1.00 | 1 |
| 01/02/2014 23:00 | 17,660.3 | 3,284.9 | 20,945.2 | 20,945.2 | 102,990.1 | 2,157.1 | 1.00 | 1 |
| **Average/Sum#:** | 17,299.6 | 2,123.9 | 19,398.5 | 465,563.2 # | 102,990.1 | 1,997.8 | 24.00 # | 24 # |
| **Minimum:** | 15,517.8 | 0.0 | 15,517.8 | 15,517.8 | 102,990.1 | 1,598.2 | 1.00 | 1 |
| **Maximum:** | 17,915.1 | 3,711.2 | 21,081.4 | 21,081.4 | 102,990.1 | 2,171.2 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/03/2014 00:00 | 17,656.5 | 2,219.3 | 19,875.8 | 19,875.8 | 102,990.1 | 2,047.0 | 1.00 | 1 |
| 01/03/2014 01:00 | 16,806.5 | 607.9 | 17,110.5 | 17,110.5 | 102,990.1 | 1,762.2 | 1.00 | 1 |
| 01/03/2014 02:00 | 12,857.8 | 0.0 | 12,857.8 | 12,857.8 | 102,990.1 | 1,324.2 | 1.00 | 1 |
| 01/03/2014 03:00 | 12,129.5 | 0.0 | 12,129.5 | 12,129.5 | 102,990.1 | 1,249.2 | 1.00 | 1 |
| 01/03/2014 04:00 | 12,139.2 | 0.0 | 12,139.2 | 12,139.2 | 102,990.1 | 1,250.2 | 1.00 | 1 |
| 01/03/2014 05:00 | 12,165.2 | 0.0 | 12,165.2 | 12,165.2 | 102,990.1 | 1,252.9 | 1.00 | 1 |
| 01/03/2014 06:00 | 14,860.6 | 661.5 | 15,158.3 | 15,158.3 | 102,990.1 | 1,561.2 | 1.00 | 1 |
| 01/03/2014 07:00 | 17,298.8 | 1,571.4 | 18,870.2 | 18,870.2 | 102,990.1 | 1,943.4 | 1.00 | 1 |
| 01/03/2014 08:00 | 18,000.4 | 1,657.8 | 19,658.2 | 19,658.2 | 102,990.1 | 2,024.6 | 1.00 | 1 |
| 01/03/2014 09:00 | 18,017.1 | 2,022.2 | 20,039.3 | 20,039.3 | 102,990.1 | 2,063.8 | 1.00 | 1 |
| 01/03/2014 10:00 | 17,883.4 | 2,279.4 | 20,162.8 | 20,162.8 | 102,990.1 | 2,076.6 | 1.00 | 1 |
| 01/03/2014 11:00 | 17,752.7 | 2,251.2 | 20,003.9 | 20,003.9 | 102,990.1 | 2,060.2 | 1.00 | 1 |
| 01/03/2014 12:00 | 17,593.9 | 2,045.2 | 19,639.1 | 19,639.1 | 102,990.1 | 2,022.6 | 1.00 | 1 |
| 01/03/2014 13:00 | 17,431.0 | 2,048.5 | 19,479.5 | 19,479.5 | 102,990.1 | 2,006.2 | 1.00 | 1 |
| 01/03/2014 14:00 | 17,321.5 | 2,028.4 | 19,349.9 | 19,349.9 | 102,990.1 | 1,992.8 | 1.00 | 1 |
| 01/03/2014 15:00 | 17,185.8 | 1,813.5 | 18,999.3 | 18,999.3 | 102,990.1 | 1,956.7 | 1.00 | 1 |
| 01/03/2014 16:00 | 17,175.4 | 2,259.8 | 19,435.2 | 19,435.2 | 102,990.1 | 2,001.6 | 1.00 | 1 |
| 01/03/2014 17:00 | 17,188.3 | 2,926.8 | 20,115.1 | 20,115.1 | 102,990.1 | 2,071.7 | 1.00 | 1 |
| 01/03/2014 18:00 | 17,335.0 | 3,583.0 | 20,918.0 | 20,918.0 | 102,990.1 | 2,154.3 | 1.00 | 1 |
| 01/03/2014 19:00 | 17,381.5 | 3,205.6 | 20,587.1 | 20,587.1 | 102,990.1 | 2,120.3 | 1.00 | 1 |
| 01/03/2014 20:00 | 17,398.6 | 3,209.8 | 20,608.4 | 20,608.4 | 102,990.1 | 2,122.5 | 1.00 | 1 |
| 01/03/2014 21:00 | 17,397.5 | 4,303.2 | 21,700.7 | 21,700.7 | 102,990.1 | 2,235.0 | 1.00 | 1 |
| 01/03/2014 22:00 | 17,475.4 | 3,976.0 | 21,451.4 | 21,451.4 | 102,990.1 | 2,209.3 | 1.00 | 1 |
| 01/03/2014 23:00 | 17,495.4 | 3,559.7 | 21,055.1 | 21,055.1 | 102,990.1 | 2,168.5 | 1.00 | 1 |
| **Average/Sum#:** | 16,497.8 | 2,009.6 | 18,479.6 | 443,509.5 # | 102,990.1 | 1,903.2 | 24.00 # | 24 # |
| **Minimum:** | 12,129.5 | 0.0 | 12,129.5 | 12,129.5 | 102,990.1 | 1,249.2 | 1.00 | 1 |
| **Maximum:** | 18,017.1 | 4,303.2 | 21,700.7 | 21,700.7 | 102,990.1 | 2,235.0 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/04/2014 00:00 | 17,735.5 | 2,473.7 | 20,209.2 | 20,209.2 | 102,990.1 | 2,081.3 | 1.00 | 1 |
| 01/04/2014 01:00 | 17,802.8 | 2,730.9 | 20,533.7 | 20,533.7 | 102,990.1 | 2,114.8 | 1.00 | 1 |
| 01/04/2014 02:00 | 15,791.6 | 185.9 | 15,815.8 | 15,815.8 | 102,990.1 | 1,628.9 | 1.00 | 1 |
| 01/04/2014 03:00 | 15,501.8 | 0.0 | 15,501.8 | 15,501.8 | 102,990.1 | 1,596.5 | 1.00 | 1 |
| 01/04/2014 04:00 | 13,871.7 | 0.0 | 13,871.7 | 13,871.7 | 102,990.1 | 1,428.6 | 1.00 | 1 |
| 01/04/2014 05:00 | 16,097.4 | 0.0 | 16,097.4 | 16,097.4 | 102,990.1 | 1,657.9 | 1.00 | 1 |
| 01/04/2014 06:00 | 16,329.1 | 0.0 | 16,329.1 | 16,329.1 | 102,990.1 | 1,681.7 | 1.00 | 1 |
| 01/04/2014 07:00 | 17,832.6 | 0.0 | 17,832.6 | 17,832.6 | 102,990.1 | 1,836.6 | 1.00 | 1 |
| 01/04/2014 08:00 | 17,633.9 | 1,456.7 | 18,697.3 | 18,697.3 | 102,990.1 | 1,925.6 | 1.00 | 1 |
| 01/04/2014 09:00 | 17,696.5 | 3,110.6 | 20,807.1 | 20,807.1 | 102,990.1 | 2,142.9 | 1.00 | 1 |
| 01/04/2014 10:00 | 17,552.2 | 2,570.5 | 20,122.7 | 20,122.7 | 102,990.1 | 2,072.4 | 1.00 | 1 |
| 01/04/2014 11:00 | 17,440.3 | 2,043.8 | 19,484.1 | 19,484.1 | 102,990.1 | 2,006.7 | 1.00 | 1 |
| 01/04/2014 12:00 | 17,267.2 | 1,504.8 | 18,772.0 | 18,772.0 | 102,990.1 | 1,933.3 | 1.00 | 1 |
| 01/04/2014 13:00 | 16,818.6 | 1,473.4 | 18,292.0 | 18,292.0 | 102,990.1 | 1,883.9 | 1.00 | 1 |
| 01/04/2014 14:00 | 17,150.6 | 2,184.7 | 19,335.3 | 19,335.3 | 102,990.1 | 1,991.3 | 1.00 | 1 |
| 01/04/2014 15:00 | 17,121.3 | 2,612.3 | 19,733.6 | 19,733.6 | 102,990.1 | 2,032.4 | 1.00 | 1 |
| 01/04/2014 16:00 | 17,114.4 | 2,829.0 | 19,943.4 | 19,943.4 | 102,990.1 | 2,054.0 | 1.00 | 1 |
| 01/04/2014 17:00 | 17,220.6 | 3,135.1 | 20,355.7 | 20,355.7 | 102,990.1 | 2,096.4 | 1.00 | 1 |
| 01/04/2014 18:00 | 17,324.4 | 3,504.3 | 20,828.7 | 20,828.7 | 102,990.1 | 2,145.1 | 1.00 | 1 |
| 01/04/2014 19:00 | 17,323.4 | 3,538.4 | 20,861.8 | 20,861.8 | 102,990.1 | 2,148.6 | 1.00 | 1 |
| 01/04/2014 20:00 | 17,358.6 | 2,659.0 | 20,017.6 | 20,017.6 | 102,990.1 | 2,061.6 | 1.00 | 1 |
| 01/04/2014 21:00 | 17,360.4 | 4,001.9 | 21,362.3 | 21,362.3 | 102,990.1 | 2,200.1 | 1.00 | 1 |
| 01/04/2014 22:00 | 17,400.1 | 4,211.9 | 21,612.0 | 21,612.0 | 102,990.1 | 2,225.8 | 1.00 | 1 |
| 01/04/2014 23:00 | 17,481.2 | 2,637.4 | 20,118.6 | 20,118.6 | 102,990.1 | 2,072.0 | 1.00 | 1 |
| **Average/Sum#:** | 17,009.4 | 2,036.0 | 19,022.3 | 456,535.5 # | 102,990.1 | 1,959.1 | 24.00 # | 24 # |
| **Minimum:** | 13,871.7 | 0.0 | 13,871.7 | 13,871.7 | 102,990.1 | 1,428.6 | 1.00 | 1 |
| **Maximum:** | 17,832.6 | 4,211.9 | 21,612.0 | 21,612.0 | 102,990.1 | 2,225.8 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/05/2014 00:00 | 17,556.1 | 2,375.2 | 19,931.3 | 19,931.3 | 102,990.1 | 2,052.7 | 1.00 | 1 |
| 01/05/2014 01:00 | 17,544.5 | 2,741.4 | 20,285.9 | 20,285.9 | 102,990.1 | 2,089.2 | 1.00 | 1 |
| 01/05/2014 02:00 | 15,712.1 | 151.4 | 15,727.2 | 15,727.2 | 102,990.1 | 1,619.7 | 1.00 | 1 |
| 01/05/2014 03:00 | 15,540.6 | 0.0 | 15,540.6 | 15,540.6 | 102,990.1 | 1,600.5 | 1.00 | 1 |
| 01/05/2014 04:00 | 16,511.3 | 0.0 | 16,511.3 | 16,511.3 | 102,990.1 | 1,700.5 | 1.00 | 1 |
| 01/05/2014 05:00 | 17,662.0 | 0.0 | 17,662.0 | 17,662.0 | 102,990.1 | 1,819.0 | 1.00 | 1 |
| 01/05/2014 06:00 | 17,651.4 | 1,257.9 | 18,443.9 | 18,443.9 | 102,990.1 | 1,899.5 | 1.00 | 1 |
| 01/05/2014 07:00 | 17,689.3 | 2,945.6 | 20,634.9 | 20,634.9 | 102,990.1 | 2,125.2 | 1.00 | 1 |
| 01/05/2014 08:00 | 17,684.6 | 4,263.2 | 21,947.8 | 21,947.8 | 102,990.1 | 2,260.4 | 1.00 | 1 |
| 01/05/2014 09:00 | 17,648.3 | 3,947.4 | 21,595.7 | 21,595.7 | 102,990.1 | 2,224.1 | 1.00 | 1 |
| 01/05/2014 10:00 | 17,531.1 | 2,789.5 | 20,320.6 | 20,320.6 | 102,990.1 | 2,092.8 | 1.00 | 1 |
| 01/05/2014 11:00 | 17,474.6 | 2,079.1 | 19,553.7 | 19,553.7 | 102,990.1 | 2,013.8 | 1.00 | 1 |
| 01/05/2014 12:00 | 17,257.8 | 1,528.2 | 18,786.0 | 18,786.0 | 102,990.1 | 1,934.8 | 1.00 | 1 |
| 01/05/2014 13:00 | 17,246.2 | 1,716.5 | 18,962.7 | 18,962.7 | 102,990.1 | 1,953.0 | 1.00 | 1 |
| 01/05/2014 14:00 | 17,230.4 | 2,399.7 | 19,630.1 | 19,630.1 | 102,990.1 | 2,021.7 | 1.00 | 1 |
| 01/05/2014 15:00 | 15,853.1 | 99.9 | 15,860.1 | 15,860.1 | 102,990.1 | 1,633.4 | 1.00 | 1 |
| 01/05/2014 16:00 | 17,078.5 | 1,645.9 | 18,280.0 | 18,280.0 | 102,990.1 | 1,882.7 | 1.00 | 1 |
| 01/05/2014 17:00 | 17,229.4 | 4,009.5 | 21,238.9 | 21,238.9 | 102,990.1 | 2,187.4 | 1.00 | 1 |
| 01/05/2014 18:00 | 17,252.4 | 4,359.0 | 21,611.4 | 21,611.4 | 102,990.1 | 2,225.8 | 1.00 | 1 |
| 01/05/2014 19:00 | 17,293.6 | 4,422.5 | 21,716.1 | 21,716.1 | 102,990.1 | 2,236.5 | 1.00 | 1 |
| 01/05/2014 20:00 | 17,370.3 | 4,454.6 | 21,824.9 | 21,824.9 | 102,990.1 | 2,247.7 | 1.00 | 1 |
| 01/05/2014 21:00 | 17,486.2 | 4,337.3 | 21,823.5 | 21,823.5 | 102,990.1 | 2,247.6 | 1.00 | 1 |
| 01/05/2014 22:00 | 17,593.1 | 4,319.3 | 21,912.4 | 21,912.4 | 102,990.1 | 2,256.8 | 1.00 | 1 |
| 01/05/2014 23:00 | 17,762.2 | 3,778.8 | 21,541.0 | 21,541.0 | 102,990.1 | 2,218.5 | 1.00 | 1 |
| **Average/Sum#:** | 17,202.5 | 2,484.2 | 19,639.3 | 471,342.0 # | 102,990.1 | 2,022.6 | 24.00 # | 24 # |
| **Minimum:** | 15,540.6 | 0.0 | 15,540.6 | 15,540.6 | 102,990.1 | 1,600.5 | 1.00 | 1 |
| **Maximum:** | 17,762.2 | 4,454.6 | 21,947.8 | 21,947.8 | 102,990.1 | 2,260.4 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/06/2014 00:00 | 17,703.0 | 3,737.8 | 21,440.8 | 21,440.8 | 102,990.1 | 2,208.2 | 1.00 | 1 |
| 01/06/2014 01:00 | 17,798.6 | 2,948.3 | 20,746.9 | 20,746.9 | 102,990.1 | 2,136.7 | 1.00 | 1 |
| 01/06/2014 02:00 | 17,786.9 | 3,299.1 | 21,086.0 | 21,086.0 | 102,990.1 | 2,171.6 | 1.00 | 1 |
| 01/06/2014 03:00 | 17,865.6 | 2,143.4 | 20,009.0 | 20,009.0 | 102,990.1 | 2,060.7 | 1.00 | 1 |
| 01/06/2014 04:00 | 17,815.1 | 1,993.7 | 19,808.8 | 19,808.8 | 102,990.1 | 2,040.1 | 1.00 | 1 |
| 01/06/2014 05:00 | 17,879.8 | 3,582.7 | 21,462.5 | 21,462.5 | 102,990.1 | 2,210.4 | 1.00 | 1 |
| 01/06/2014 06:00 | 17,808.0 | 2,663.1 | 20,471.1 | 20,471.1 | 102,990.1 | 2,108.3 | 1.00 | 1 |
| 01/06/2014 07:00 | 17,762.0 | 2,401.4 | 20,163.4 | 20,163.4 | 102,990.1 | 2,076.6 | 1.00 | 1 |
| 01/06/2014 08:00 | 17,821.4 | 3,497.9 | 21,319.3 | 21,319.3 | 102,990.1 | 2,195.7 | 1.00 | 1 |
| 01/06/2014 09:00 | 18,136.4 | 2,929.3 | 21,065.7 | 21,065.7 | 102,990.1 | 2,169.6 | 1.00 | 1 |
| 01/06/2014 10:00 | 18,022.5 | 3,398.1 | 21,420.6 | 21,420.6 | 102,990.1 | 2,206.1 | 1.00 | 1 |
| 01/06/2014 11:00 | 17,781.4 | 3,921.8 | 21,703.2 | 21,703.2 | 102,990.1 | 2,235.2 | 1.00 | 1 |
| 01/06/2014 12:00 | 17,695.0 | 4,039.1 | 21,734.1 | 21,734.1 | 102,990.1 | 2,238.4 | 1.00 | 1 |
| 01/06/2014 13:00 | 17,617.0 | 4,202.9 | 21,819.9 | 21,819.9 | 102,990.1 | 2,247.2 | 1.00 | 1 |
| 01/06/2014 14:00 | 17,606.7 | 3,335.2 | 20,941.9 | 20,941.9 | 102,990.1 | 2,156.8 | 1.00 | 1 |
| 01/06/2014 15:00 | 17,570.0 | 2,209.3 | 19,779.3 | 19,779.3 | 102,990.1 | 2,037.1 | 1.00 | 1 |
| 01/06/2014 16:00 | 17,537.5 | 2,347.8 | 19,885.3 | 19,885.3 | 102,990.1 | 2,048.0 | 1.00 | 1 |
| 01/06/2014 17:00 | 17,585.6 | 2,898.8 | 20,484.4 | 20,484.4 | 102,990.1 | 2,109.7 | 1.00 | 1 |
| 01/06/2014 18:00 | 17,625.7 | 3,039.2 | 20,664.9 | 20,664.9 | 102,990.1 | 2,128.3 | 1.00 | 1 |
| 01/06/2014 19:00 | 17,638.1 | 4,211.7 | 21,849.8 | 21,849.8 | 102,990.1 | 2,250.3 | 1.00 | 1 |
| 01/06/2014 20:00 | 17,661.4 | 3,194.4 | 20,855.8 | 20,855.8 | 102,990.1 | 2,147.9 | 1.00 | 1 |
| 01/06/2014 21:00 | 17,663.4 | 4,309.1 | 21,972.5 | 21,972.5 | 102,990.1 | 2,262.9 | 1.00 | 1 |
| 01/06/2014 22:00 | 17,685.6 | 4,423.0 | 22,108.6 | 22,108.6 | 102,990.1 | 2,277.0 | 1.00 | 1 |
| 01/06/2014 23:00 | 17,734.3 | 3,149.3 | 20,883.6 | 20,883.6 | 102,990.1 | 2,150.8 | 1.00 | 1 |
| **Average/Sum#:** | 17,741.7 | 3,244.9 | 20,986.6 | 503,677.4 # | 102,990.1 | 2,161.4 | 24.00 # | 24 # |
| **Minimum:** | 17,537.5 | 1,993.7 | 19,779.3 | 19,779.3 | 102,990.1 | 2,037.1 | 1.00 | 1 |
| **Maximum:** | 18,136.4 | 4,423.0 | 22,108.6 | 22,108.6 | 102,990.1 | 2,277.0 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/07/2014 00:00 | 17,418.1 | 1,979.1 | 19,397.2 | 19,397.2 | 102,990.1 | 1,997.7 | 1.00 | 1 |
| 01/07/2014 01:00 | 16,273.7 | 1,188.4 | 17,188.8 | 17,188.8 | 102,990.1 | 1,770.3 | 1.00 | 1 |
| 01/07/2014 02:00 | 14,501.6 | 0.0 | 14,501.6 | 14,501.6 | 102,990.1 | 1,493.5 | 1.00 | 1 |
| 01/07/2014 03:00 | 15,524.7 | 0.0 | 15,524.7 | 15,524.7 | 102,990.1 | 1,598.9 | 1.00 | 1 |
| 01/07/2014 04:00 | 15,353.8 | 0.0 | 15,353.8 | 15,353.8 | 102,990.1 | 1,581.3 | 1.00 | 1 |
| 01/07/2014 05:00 | 15,507.6 | 0.0 | 15,507.6 | 15,507.6 | 102,990.1 | 1,597.1 | 1.00 | 1 |
| 01/07/2014 06:00 | 17,058.2 | 968.4 | 17,668.3 | 17,668.3 | 102,990.1 | 1,819.7 | 1.00 | 1 |
| 01/07/2014 07:00 | 17,972.4 | 1,925.0 | 19,897.4 | 19,897.4 | 102,990.1 | 2,049.2 | 1.00 | 1 |
| 01/07/2014 08:00 | 18,043.2 | 3,358.7 | 21,401.9 | 21,401.9 | 102,990.1 | 2,204.2 | 1.00 | 1 |
| 01/07/2014 09:00 | 18,027.4 | 3,287.1 | 21,314.5 | 21,314.5 | 102,990.1 | 2,195.2 | 1.00 | 1 |
| 01/07/2014 10:00 | 17,962.1 | 2,646.0 | 20,608.1 | 20,608.1 | 102,990.1 | 2,122.4 | 1.00 | 1 |
| 01/07/2014 11:00 | 17,834.6 | 2,445.8 | 20,280.4 | 20,280.4 | 102,990.1 | 2,088.7 | 1.00 | 1 |
| 01/07/2014 12:00 | 17,714.9 | 4,108.7 | 21,823.6 | 21,823.6 | 102,990.1 | 2,247.6 | 1.00 | 1 |
| 01/07/2014 13:00 | 17,600.9 | 4,176.8 | 21,777.7 | 21,777.7 | 102,990.1 | 2,242.9 | 1.00 | 1 |
| 01/07/2014 14:00 | 17,521.0 | 2,859.3 | 20,380.3 | 20,380.3 | 102,990.1 | 2,099.0 | 1.00 | 1 |
| 01/07/2014 15:00 | 17,472.1 | 3,030.6 | 20,502.7 | 20,502.7 | 102,990.1 | 2,111.6 | 1.00 | 1 |
| 01/07/2014 16:00 | 17,480.9 | 2,109.7 | 19,590.6 | 19,590.6 | 102,990.1 | 2,017.6 | 1.00 | 1 |
| 01/07/2014 17:00 | 17,494.5 | 2,118.7 | 19,613.2 | 19,613.2 | 102,990.1 | 2,020.0 | 1.00 | 1 |
| 01/07/2014 18:00 | 17,502.6 | 2,613.9 | 20,116.5 | 20,116.5 | 102,990.1 | 2,071.8 | 1.00 | 1 |
| 01/07/2014 19:00 | 17,559.8 | 3,858.2 | 21,418.0 | 21,418.0 | 102,990.1 | 2,205.8 | 1.00 | 1 |
| 01/07/2014 20:00 | 17,614.7 | 4,240.1 | 21,854.8 | 21,854.8 | 102,990.1 | 2,250.8 | 1.00 | 1 |
| 01/07/2014 21:00 | 17,638.3 | 2,764.4 | 20,402.7 | 20,402.7 | 102,990.1 | 2,101.3 | 1.00 | 1 |
| 01/07/2014 22:00 | 17,742.1 | 2,416.8 | 20,158.9 | 20,158.9 | 102,990.1 | 2,076.2 | 1.00 | 1 |
| 01/07/2014 23:00 | 17,323.3 | 1,478.6 | 18,506.2 | 18,506.2 | 102,990.1 | 1,906.0 | 1.00 | 1 |
| **Average/Sum#:** | 17,172.6 | 2,232.3 | 19,366.2 | 464,789.5 # | 102,990.1 | 1,994.5 | 24.00 # | 24 # |
| **Minimum:** | 14,501.6 | 0.0 | 14,501.6 | 14,501.6 | 102,990.1 | 1,493.5 | 1.00 | 1 |
| **Maximum:** | 18,043.2 | 4,240.1 | 21,854.8 | 21,854.8 | 102,990.1 | 2,250.8 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/08/2014 00:00 | 13,260.4 | 0.0 | 13,260.4 | 13,260.4 | 102,990.1 | 1,365.7 | 1.00 | 1 |
| 01/08/2014 01:00 | 12,775.5 | 0.0 | 12,775.5 | 12,775.5 | 102,990.1 | 1,315.8 | 1.00 | 1 |
| 01/08/2014 02:00 | 12,529.3 | 0.0 | 12,529.3 | 12,529.3 | 102,990.1 | 1,290.4 | 1.00 | 1 |
| 01/08/2014 03:00 | 12,289.7 | 0.0 | 12,289.7 | 12,289.7 | 102,990.1 | 1,265.7 | 1.00 | 1 |
| 01/08/2014 04:00 | 12,603.9 | 0.0 | 12,603.9 | 12,603.9 | 102,990.1 | 1,298.1 | 1.00 | 1 |
| 01/08/2014 05:00 | 15,914.6 | 0.0 | 15,914.6 | 15,914.6 | 102,990.1 | 1,639.0 | 1.00 | 1 |
| 01/08/2014 06:00 | 16,452.7 | 601.1 | 16,735.2 | 16,735.2 | 102,990.1 | 1,723.6 | 1.00 | 1 |
| 01/08/2014 07:00 | 17,781.8 | 1,320.0 | 19,101.8 | 19,101.8 | 102,990.1 | 1,967.3 | 1.00 | 1 |
| 01/08/2014 08:00 | 17,973.7 | 1,851.2 | 19,824.9 | 19,824.9 | 102,990.1 | 2,041.8 | 1.00 | 1 |
| 01/08/2014 09:00 | 16,986.7 | 697.2 | 17,356.2 | 17,356.2 | 102,990.1 | 1,787.5 | 1.00 | 1 |
| 01/08/2014 10:00 | 12,068.3 | 0.0 | 12,068.3 | 12,068.3 | 102,990.1 | 1,242.9 | 1.00 | 1 |
| 01/08/2014 11:00 | 13,428.2 | 0.0 | 13,428.2 | 13,428.2 | 102,990.1 | 1,383.0 | 1.00 | 1 |
| 01/08/2014 12:00 | 16,596.9 | 0.0 | 16,596.9 | 16,596.9 | 102,990.1 | 1,709.3 | 1.00 | 1 |
| 01/08/2014 13:00 | 14,423.5 | 0.0 | 14,423.5 | 14,423.5 | 102,990.1 | 1,485.5 | 1.00 | 1 |
| 01/08/2014 14:00 | 12,233.5 | 0.0 | 12,233.5 | 12,233.5 | 102,990.1 | 1,259.9 | 1.00 | 1 |
| 01/08/2014 15:00 | 13,648.3 | 0.0 | 13,648.3 | 13,648.3 | 102,990.1 | 1,405.6 | 1.00 | 1 |
| 01/08/2014 16:00 | 14,861.4 | 0.0 | 14,861.4 | 14,861.4 | 102,990.1 | 1,530.6 | 1.00 | 1 |
| 01/08/2014 17:00 | 17,004.7 | 937.3 | 17,539.0 | 17,539.0 | 102,990.1 | 1,806.3 | 1.00 | 1 |
| 01/08/2014 18:00 | 13,970.1 | 0.0 | 13,970.1 | 13,970.1 | 102,990.1 | 1,438.8 | 1.00 | 1 |
| 01/08/2014 19:00 | 14,930.4 | 0.0 | 14,930.4 | 14,930.4 | 102,990.1 | 1,537.7 | 1.00 | 1 |
| 01/08/2014 20:00 | 14,521.1 | 0.0 | 14,521.1 | 14,521.1 | 102,990.1 | 1,495.5 | 1.00 | 1 |
| 01/08/2014 21:00 | 14,453.3 | 0.0 | 14,453.3 | 14,453.3 | 102,990.1 | 1,488.5 | 1.00 | 1 |
| 01/08/2014 22:00 | 7,246.5 | 0.0 | 7,246.5 | 2,029.0 | 102,990.1 | 746.3 | 0.28 | 0 |
| 01/08/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 14,258.9 | 235.1 | 14,448.3 | 327,094.5 # | 102,990.1 | 1,488.0 | 22.28 # | 22 # |
| **Minimum:** | 7,246.5 | 0.0 | 7,246.5 | 2,029.0 | 102,990.1 | 746.3 | 0.00 | 0 |
| **Maximum:** | 17,973.7 | 1,851.2 | 19,824.9 | 19,824.9 | 102,990.1 | 2,041.8 | 1.00 | 1 |
| **%SI** | 4.2 | 4.2 | 4.2 | 4.2 | 0.0 | 4.2 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/09/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/09/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/10/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/10/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/11/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/12/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/12/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/13/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/13/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/14/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/14/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/15/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,990.1 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,990.1 | 0.0 | 0.00 | 0 |
| 01/29/2014 08:00 | 4,893.3 | 2.2 | 4,893.3 | 3,082.8 | 102,990.1 | 504.0 | 0.63 | 0 |
| 01/29/2014 09:00 | 5,919.8 | 0.0 | 5,919.8 | 5,919.8 | 102,990.1 | 609.7 | 1.00 | 0 |
| 01/29/2014 10:00 | 6,117.3 | 0.0 | 6,117.3 | 6,117.3 | 102,990.1 | 630.0 | 1.00 | 0 |
| 01/29/2014 11:00 | 6,222.2 | 0.0 | 6,222.2 | 6,222.2 | 102,990.1 | 640.8 | 1.00 | 0 |
| 01/29/2014 12:00 | 12,663.0 | 0.0 | 12,663.0 | 12,663.0 | 102,990.1 | 1,304.2 | 1.00 | 0 |
| 01/29/2014 13:00 | 17,689.0 | 0.0 | 17,689.0 | 17,689.0 | 102,990.1 | 1,821.8 | 1.00 | 1 |
| 01/29/2014 14:00 | 17,591.3 | 0.0 | 17,591.3 | 17,591.3 | 102,990.1 | 1,811.7 | 1.00 | 1 |
| 01/29/2014 15:00 | 16,089.8 | 0.0 | 16,089.8 | 16,089.8 | 102,990.1 | 1,657.1 | 1.00 | 1 |
| 01/29/2014 16:00 | 12,466.6 | 0.0 | 12,466.6 | 12,466.6 | 102,990.1 | 1,283.9 | 1.00 | 1 |
| 01/29/2014 17:00 | 14,970.5 | 0.0 | 14,970.5 | 14,970.5 | 102,990.1 | 1,541.8 | 1.00 | 1 |
| 01/29/2014 18:00 | 17,641.3 | 0.0 | 17,641.3 | 17,641.3 | 102,990.1 | 1,816.9 | 1.00 | 1 |
| 01/29/2014 19:00 | 17,632.3 | 0.0 | 17,632.3 | 17,632.3 | 102,990.1 | 1,816.0 | 1.00 | 1 |
| 01/29/2014 20:00 | 17,070.3 | 0.0 | 17,070.3 | 17,070.3 | 102,990.1 | 1,758.1 | 1.00 | 1 |
| 01/29/2014 21:00 | 17,605.9 | 0.0 | 17,605.9 | 17,605.9 | 102,990.1 | 1,813.2 | 1.00 | 1 |
| 01/29/2014 22:00 | 16,203.9 | 0.0 | 16,203.9 | 16,203.9 | 102,990.1 | 1,668.8 | 1.00 | 1 |
| 01/29/2014 23:00 | 12,574.6 | 0.0 | 12,574.6 | 12,574.6 | 102,990.1 | 1,295.1 | 1.00 | 1 |
| **Average/Sum#:** | 13,334.4 | 0.1 | 13,334.4 | 211,540.6 # | 102,990.1 | 1,373.3 | 15.63 # | 11 # |
| **Minimum:** | 4,893.3 | 0.0 | 4,893.3 | 3,082.8 | 102,990.1 | 504.0 | 0.00 | 0 |
| **Maximum:** | 17,689.0 | 2.2 | 17,689.0 | 17,689.0 | 102,990.1 | 1,821.8 | 1.00 | 1 |
| **%SI** | 33.3 | 33.3 | 33.3 | 33.3 | 0.0 | 33.3 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/30/2014 00:00 | 14,340.4 | 0.0 | 14,340.4 | 14,340.4 | 102,258.0 | 1,466.4 | 1.00 | 1 |
| 01/30/2014 01:00 | 17,121.5 | 0.0 | 17,121.5 | 17,121.5 | 102,258.0 | 1,750.8 | 1.00 | 1 |
| 01/30/2014 02:00 | 13,006.5 | 0.0 | 13,006.5 | 13,006.5 | 102,258.0 | 1,330.0 | 1.00 | 1 |
| 01/30/2014 03:00 | 12,336.7 | 0.0 | 12,336.7 | 12,336.7 | 102,258.0 | 1,261.5 | 1.00 | 1 |
| 01/30/2014 04:00 | 12,567.7 | 0.0 | 12,567.7 | 12,567.7 | 102,258.0 | 1,285.1 | 1.00 | 1 |
| 01/30/2014 05:00 | 12,317.5 | 0.0 | 12,317.5 | 12,317.5 | 102,258.0 | 1,259.6 | 1.00 | 1 |
| 01/30/2014 06:00 | 14,200.1 | 0.0 | 14,200.1 | 14,200.1 | 102,258.0 | 1,452.1 | 1.00 | 1 |
| 01/30/2014 07:00 | 15,143.3 | 0.0 | 15,143.3 | 15,143.3 | 102,258.0 | 1,548.5 | 1.00 | 1 |
| 01/30/2014 08:00 | 15,262.8 | 0.0 | 15,262.8 | 15,262.8 | 102,258.0 | 1,560.7 | 1.00 | 1 |
| 01/30/2014 09:00 | 12,202.6 | 0.0 | 12,202.6 | 12,202.6 | 102,258.0 | 1,247.8 | 1.00 | 1 |
| 01/30/2014 10:00 | 14,827.6 | 206.0 | 14,858.5 | 14,858.5 | 102,258.0 | 1,519.4 | 1.00 | 1 |
| 01/30/2014 11:00 | 17,600.5 | 1,477.1 | 19,077.6 | 19,077.6 | 102,258.0 | 1,950.8 | 1.00 | 1 |
| 01/30/2014 12:00 | 17,496.9 | 1,878.9 | 19,375.8 | 19,375.8 | 102,258.0 | 1,981.3 | 1.00 | 1 |
| 01/30/2014 13:00 | 17,439.3 | 3,131.3 | 20,570.6 | 20,570.6 | 102,258.0 | 2,103.5 | 1.00 | 1 |
| 01/30/2014 14:00 | 17,410.8 | 4,051.8 | 21,462.6 | 21,462.6 | 102,258.0 | 2,194.7 | 1.00 | 1 |
| 01/30/2014 15:00 | 17,390.9 | 4,340.3 | 21,731.2 | 21,731.2 | 102,258.0 | 2,222.2 | 1.00 | 1 |
| 01/30/2014 16:00 | 17,117.7 | 1,981.2 | 18,405.5 | 18,405.5 | 102,258.0 | 1,882.1 | 1.00 | 1 |
| 01/30/2014 17:00 | 15,355.0 | 0.0 | 15,355.0 | 15,355.0 | 102,258.0 | 1,570.2 | 1.00 | 1 |
| 01/30/2014 18:00 | 16,043.7 | 0.0 | 16,043.7 | 16,043.7 | 102,258.0 | 1,640.6 | 1.00 | 1 |
| 01/30/2014 19:00 | 17,473.4 | 1,739.7 | 18,865.2 | 18,865.2 | 102,258.0 | 1,929.1 | 1.00 | 1 |
| 01/30/2014 20:00 | 17,470.5 | 2,926.1 | 20,396.6 | 20,396.6 | 102,258.0 | 2,085.7 | 1.00 | 1 |
| 01/30/2014 21:00 | 17,475.1 | 2,730.1 | 20,205.2 | 20,205.2 | 102,258.0 | 2,066.1 | 1.00 | 1 |
| 01/30/2014 22:00 | 17,538.0 | 2,037.0 | 19,575.0 | 19,575.0 | 102,258.0 | 2,001.7 | 1.00 | 1 |
| 01/30/2014 23:00 | 17,630.8 | 1,959.9 | 19,590.7 | 19,590.7 | 102,258.0 | 2,003.3 | 1.00 | 1 |
| **Average/Sum#:** | 15,698.7 | 1,185.8 | 16,833.8 | 404,012.3 # | 102,258.0 | 1,721.4 | 24.00 # | 24 # |
| **Minimum:** | 12,202.6 | 0.0 | 12,202.6 | 12,202.6 | 102,258.0 | 1,247.8 | 1.00 | 1 |
| **Maximum:** | 17,630.8 | 4,340.3 | 21,731.2 | 21,731.2 | 102,258.0 | 2,222.2 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 01/31/2014 00:00 | 15,023.7 | 562.0 | 15,209.2 | 15,209.2 | 102,258.0 | 1,555.3 | 1.00 | 1 |
| 01/31/2014 01:00 | 14,584.3 | 0.0 | 14,584.3 | 14,584.3 | 102,258.0 | 1,491.4 | 1.00 | 1 |
| 01/31/2014 02:00 | 15,890.5 | 0.0 | 15,890.5 | 15,890.5 | 102,258.0 | 1,624.9 | 1.00 | 1 |
| 01/31/2014 03:00 | 13,803.6 | 0.0 | 13,803.6 | 13,803.6 | 102,258.0 | 1,411.5 | 1.00 | 1 |
| 01/31/2014 04:00 | 13,000.9 | 0.0 | 13,000.9 | 13,000.9 | 102,258.0 | 1,329.4 | 1.00 | 1 |
| 01/31/2014 05:00 | 17,302.3 | 0.0 | 17,302.3 | 17,302.3 | 102,258.0 | 1,769.3 | 1.00 | 1 |
| 01/31/2014 06:00 | 17,813.4 | 1,313.1 | 18,955.8 | 18,955.8 | 102,258.0 | 1,938.4 | 1.00 | 1 |
| 01/31/2014 07:00 | 18,041.8 | 989.0 | 18,704.4 | 18,704.4 | 102,258.0 | 1,912.7 | 1.00 | 1 |
| 01/31/2014 08:00 | 18,052.9 | 1,528.8 | 19,581.7 | 19,581.7 | 102,258.0 | 2,002.4 | 1.00 | 1 |
| 01/31/2014 09:00 | 17,773.3 | 1,528.3 | 19,301.6 | 19,301.6 | 102,258.0 | 1,973.7 | 1.00 | 1 |
| 01/31/2014 10:00 | 17,747.6 | 1,519.2 | 19,266.8 | 19,266.8 | 102,258.0 | 1,970.2 | 1.00 | 1 |
| 01/31/2014 11:00 | 17,657.2 | 1,498.9 | 19,156.1 | 19,156.1 | 102,258.0 | 1,958.9 | 1.00 | 1 |
| 01/31/2014 12:00 | 17,692.2 | 1,938.1 | 19,630.3 | 19,630.3 | 102,258.0 | 2,007.4 | 1.00 | 1 |
| 01/31/2014 13:00 | 17,619.1 | 2,006.2 | 19,625.3 | 19,625.3 | 102,258.0 | 2,006.8 | 1.00 | 1 |
| 01/31/2014 14:00 | 17,576.4 | 1,593.9 | 19,170.3 | 19,170.3 | 102,258.0 | 1,960.3 | 1.00 | 1 |
| 01/31/2014 15:00 | 17,460.5 | 1,513.7 | 18,974.2 | 18,974.2 | 102,258.0 | 1,940.3 | 1.00 | 1 |
| 01/31/2014 16:00 | 17,309.1 | 1,510.1 | 18,819.2 | 18,819.2 | 102,258.0 | 1,924.4 | 1.00 | 1 |
| 01/31/2014 17:00 | 17,583.7 | 1,514.4 | 19,098.1 | 19,098.1 | 102,258.0 | 1,952.9 | 1.00 | 1 |
| 01/31/2014 18:00 | 17,417.3 | 1,520.2 | 18,937.5 | 18,937.5 | 102,258.0 | 1,936.5 | 1.00 | 1 |
| 01/31/2014 19:00 | 17,726.2 | 2,692.8 | 20,419.0 | 20,419.0 | 102,258.0 | 2,088.0 | 1.00 | 1 |
| 01/31/2014 20:00 | 17,777.7 | 2,079.3 | 19,857.0 | 19,857.0 | 102,258.0 | 2,030.5 | 1.00 | 1 |
| 01/31/2014 21:00 | 17,775.6 | 2,560.2 | 20,335.8 | 20,335.8 | 102,258.0 | 2,079.5 | 1.00 | 1 |
| 01/31/2014 22:00 | 17,806.3 | 3,164.4 | 20,970.7 | 20,970.7 | 102,258.0 | 2,144.4 | 1.00 | 1 |
| 01/31/2014 23:00 | 17,835.8 | 2,982.6 | 20,818.4 | 20,818.4 | 102,258.0 | 2,128.8 | 1.00 | 1 |
| **Average/Sum#:** | 17,011.3 | 1,417.3 | 18,392.2 | 441,413.0 # | 102,258.0 | 1,880.7 | 24.00 # | 24 # |
| **Minimum:** | 13,000.9 | 0.0 | 13,000.9 | 13,000.9 | 102,258.0 | 1,329.4 | 1.00 | 1 |
| **Maximum:** | 18,052.9 | 3,164.4 | 20,970.7 | 20,970.7 | 102,258.0 | 2,144.4 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/01/2014 00:00 | 16,778.6 | 1,192.8 | 17,709.0 | 17,709.0 | 102,258.0 | 1,810.9 | 1.00 | 1 |
| 02/01/2014 01:00 | 15,878.2 | 0.0 | 15,878.2 | 15,878.2 | 102,258.0 | 1,623.7 | 1.00 | 1 |
| 02/01/2014 02:00 | 16,219.5 | 0.0 | 16,219.5 | 16,219.5 | 102,258.0 | 1,658.6 | 1.00 | 1 |
| 02/01/2014 03:00 | 17,465.3 | 0.0 | 17,465.3 | 17,465.3 | 102,258.0 | 1,786.0 | 1.00 | 1 |
| 02/01/2014 04:00 | 14,358.6 | 0.0 | 14,358.6 | 14,358.6 | 102,258.0 | 1,468.3 | 1.00 | 1 |
| 02/01/2014 05:00 | 17,534.6 | 1,332.7 | 18,294.2 | 18,294.2 | 102,258.0 | 1,870.7 | 1.00 | 1 |
| 02/01/2014 06:00 | 18,012.5 | 4,019.3 | 22,031.8 | 22,031.8 | 102,258.0 | 2,252.9 | 1.00 | 1 |
| 02/01/2014 07:00 | 18,065.8 | 3,980.9 | 22,046.7 | 22,046.7 | 102,258.0 | 2,254.5 | 1.00 | 1 |
| 02/01/2014 08:00 | 18,140.7 | 3,439.4 | 21,580.1 | 21,580.1 | 102,258.0 | 2,206.7 | 1.00 | 1 |
| 02/01/2014 09:00 | 18,126.0 | 2,868.4 | 20,994.4 | 20,994.4 | 102,258.0 | 2,146.8 | 1.00 | 1 |
| 02/01/2014 10:00 | 17,594.0 | 946.9 | 18,133.7 | 18,133.7 | 102,258.0 | 1,854.3 | 1.00 | 1 |
| 02/01/2014 11:00 | 15,361.7 | 0.0 | 15,361.7 | 15,361.7 | 102,258.0 | 1,570.9 | 1.00 | 1 |
| 02/01/2014 12:00 | 15,058.1 | 0.0 | 15,058.1 | 15,058.1 | 102,258.0 | 1,539.8 | 1.00 | 1 |
| 02/01/2014 13:00 | 15,556.2 | 0.0 | 15,556.2 | 15,556.2 | 102,258.0 | 1,590.7 | 1.00 | 1 |
| 02/01/2014 14:00 | 14,111.9 | 0.0 | 14,111.9 | 14,111.9 | 102,258.0 | 1,443.1 | 1.00 | 1 |
| 02/01/2014 15:00 | 12,341.5 | 0.0 | 12,341.5 | 12,341.5 | 102,258.0 | 1,262.0 | 1.00 | 1 |
| 02/01/2014 16:00 | 12,837.5 | 0.0 | 12,837.5 | 12,837.5 | 102,258.0 | 1,312.7 | 1.00 | 1 |
| 02/01/2014 17:00 | 16,185.4 | 750.4 | 16,523.1 | 16,523.1 | 102,258.0 | 1,689.6 | 1.00 | 1 |
| 02/01/2014 18:00 | 17,659.6 | 2,209.9 | 19,869.5 | 19,869.5 | 102,258.0 | 2,031.8 | 1.00 | 1 |
| 02/01/2014 19:00 | 17,719.0 | 3,945.5 | 21,664.5 | 21,664.5 | 102,258.0 | 2,215.4 | 1.00 | 1 |
| 02/01/2014 20:00 | 17,812.7 | 4,306.4 | 22,119.1 | 22,119.1 | 102,258.0 | 2,261.9 | 1.00 | 1 |
| 02/01/2014 21:00 | 17,896.2 | 4,291.7 | 22,187.9 | 22,187.9 | 102,258.0 | 2,268.9 | 1.00 | 1 |
| 02/01/2014 22:00 | 18,029.5 | 4,152.4 | 22,181.9 | 22,181.9 | 102,258.0 | 2,268.3 | 1.00 | 1 |
| 02/01/2014 23:00 | 18,134.6 | 3,918.9 | 22,053.5 | 22,053.5 | 102,258.0 | 2,255.1 | 1.00 | 1 |
| **Average/Sum#:** | 16,536.6 | 1,723.2 | 18,190.7 | 436,577.9 # | 102,258.0 | 1,860.2 | 24.00 # | 24 # |
| **Minimum:** | 12,341.5 | 0.0 | 12,341.5 | 12,341.5 | 102,258.0 | 1,262.0 | 1.00 | 1 |
| **Maximum:** | 18,140.7 | 4,306.4 | 22,187.9 | 22,187.9 | 102,258.0 | 2,268.9 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/02/2014 00:00 | 18,106.2 | 3,349.2 | 21,455.4 | 21,455.4 | 102,258.0 | 2,194.0 | 1.00 | 1 |
| 02/02/2014 01:00 | 18,123.7 | 2,454.9 | 20,578.6 | 20,578.6 | 102,258.0 | 2,104.3 | 1.00 | 1 |
| 02/02/2014 02:00 | 18,163.6 | 2,411.3 | 20,574.9 | 20,574.9 | 102,258.0 | 2,103.9 | 1.00 | 1 |
| 02/02/2014 03:00 | 18,180.2 | 2,424.7 | 20,604.9 | 20,604.9 | 102,258.0 | 2,107.0 | 1.00 | 1 |
| 02/02/2014 04:00 | 18,191.5 | 1,939.5 | 20,131.0 | 20,131.0 | 102,258.0 | 2,058.6 | 1.00 | 1 |
| 02/02/2014 05:00 | 18,208.2 | 1,945.7 | 20,153.9 | 20,153.9 | 102,258.0 | 2,060.9 | 1.00 | 1 |
| 02/02/2014 06:00 | 18,223.1 | 2,069.9 | 20,293.0 | 20,293.0 | 102,258.0 | 2,075.1 | 1.00 | 1 |
| 02/02/2014 07:00 | 18,216.8 | 3,565.8 | 21,782.6 | 21,782.6 | 102,258.0 | 2,227.4 | 1.00 | 1 |
| 02/02/2014 08:00 | 18,225.2 | 3,945.2 | 22,170.4 | 22,170.4 | 102,258.0 | 2,267.1 | 1.00 | 1 |
| 02/02/2014 09:00 | 18,209.4 | 3,976.0 | 22,185.4 | 22,185.4 | 102,258.0 | 2,268.6 | 1.00 | 1 |
| 02/02/2014 10:00 | 18,117.8 | 4,072.0 | 22,189.8 | 22,189.8 | 102,258.0 | 2,269.1 | 1.00 | 1 |
| 02/02/2014 11:00 | 18,020.1 | 4,177.0 | 22,197.1 | 22,197.1 | 102,258.0 | 2,269.8 | 1.00 | 1 |
| 02/02/2014 12:00 | 17,967.0 | 4,132.3 | 22,099.3 | 22,099.3 | 102,258.0 | 2,259.8 | 1.00 | 1 |
| 02/02/2014 13:00 | 17,920.1 | 3,995.3 | 21,915.4 | 21,915.4 | 102,258.0 | 2,241.0 | 1.00 | 1 |
| 02/02/2014 14:00 | 17,849.3 | 2,778.0 | 20,627.3 | 20,627.3 | 102,258.0 | 2,109.3 | 1.00 | 1 |
| 02/02/2014 15:00 | 17,819.2 | 4,122.5 | 21,941.7 | 21,941.7 | 102,258.0 | 2,243.7 | 1.00 | 1 |
| 02/02/2014 16:00 | 17,888.3 | 4,357.6 | 22,245.9 | 22,245.9 | 102,258.0 | 2,274.8 | 1.00 | 1 |
| 02/02/2014 17:00 | 17,944.6 | 3,321.3 | 21,265.9 | 21,265.9 | 102,258.0 | 2,174.6 | 1.00 | 1 |
| 02/02/2014 18:00 | 17,766.8 | 1,737.7 | 19,504.5 | 19,504.5 | 102,258.0 | 1,994.5 | 1.00 | 1 |
| 02/02/2014 19:00 | 17,960.9 | 2,998.2 | 20,959.1 | 20,959.1 | 102,258.0 | 2,143.2 | 1.00 | 1 |
| 02/02/2014 20:00 | 17,943.6 | 4,036.8 | 21,980.4 | 21,980.4 | 102,258.0 | 2,247.7 | 1.00 | 1 |
| 02/02/2014 21:00 | 17,940.6 | 4,284.2 | 22,224.8 | 22,224.8 | 102,258.0 | 2,272.7 | 1.00 | 1 |
| 02/02/2014 22:00 | 17,934.1 | 3,544.4 | 21,478.5 | 21,478.5 | 102,258.0 | 2,196.3 | 1.00 | 1 |
| 02/02/2014 23:00 | 17,947.4 | 4,074.7 | 22,022.1 | 22,022.1 | 102,258.0 | 2,251.9 | 1.00 | 1 |
| **Average/Sum#:** | 18,036.2 | 3,321.4 | 21,357.6 | 512,581.9 # | 102,258.0 | 2,184.0 | 24.00 # | 24 # |
| **Minimum:** | 17,766.8 | 1,737.7 | 19,504.5 | 19,504.5 | 102,258.0 | 1,994.5 | 1.00 | 1 |
| **Maximum:** | 18,225.2 | 4,357.6 | 22,245.9 | 22,245.9 | 102,258.0 | 2,274.8 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/03/2014 00:00 | 17,980.2 | 3,910.0 | 21,890.2 | 21,890.2 | 102,258.0 | 2,238.4 | 1.00 | 1 |
| 02/03/2014 01:00 | 18,000.6 | 2,816.8 | 20,817.4 | 20,817.4 | 102,258.0 | 2,128.7 | 1.00 | 1 |
| 02/03/2014 02:00 | 17,987.7 | 1,909.1 | 19,896.8 | 19,896.8 | 102,258.0 | 2,034.6 | 1.00 | 1 |
| 02/03/2014 03:00 | 17,772.8 | 1,784.9 | 19,557.7 | 19,557.7 | 102,258.0 | 1,999.9 | 1.00 | 1 |
| 02/03/2014 04:00 | 18,246.7 | 1,783.2 | 20,029.9 | 20,029.9 | 102,258.0 | 2,048.2 | 1.00 | 1 |
| 02/03/2014 05:00 | 18,226.7 | 2,685.9 | 20,912.6 | 20,912.6 | 102,258.0 | 2,138.5 | 1.00 | 1 |
| 02/03/2014 06:00 | 18,255.1 | 2,136.4 | 20,391.5 | 20,391.5 | 102,258.0 | 2,085.2 | 1.00 | 1 |
| 02/03/2014 07:00 | 18,265.3 | 2,259.2 | 20,524.5 | 20,524.5 | 102,258.0 | 2,098.8 | 1.00 | 1 |
| 02/03/2014 08:00 | 18,265.5 | 3,757.1 | 22,022.6 | 22,022.6 | 102,258.0 | 2,252.0 | 1.00 | 1 |
| 02/03/2014 09:00 | 18,267.1 | 3,340.8 | 21,607.9 | 21,607.9 | 102,258.0 | 2,209.6 | 1.00 | 1 |
| 02/03/2014 10:00 | 18,207.7 | 2,446.8 | 20,654.5 | 20,654.5 | 102,258.0 | 2,112.1 | 1.00 | 1 |
| 02/03/2014 11:00 | 17,307.9 | 1,559.8 | 18,867.7 | 18,867.7 | 102,258.0 | 1,929.4 | 1.00 | 1 |
| 02/03/2014 12:00 | 17,532.7 | 1,561.9 | 19,094.6 | 19,094.6 | 102,258.0 | 1,952.6 | 1.00 | 1 |
| 02/03/2014 13:00 | 17,878.9 | 1,832.5 | 19,711.4 | 19,711.4 | 102,258.0 | 2,015.6 | 1.00 | 1 |
| 02/03/2014 14:00 | 17,780.4 | 1,974.6 | 19,755.0 | 19,755.0 | 102,258.0 | 2,020.1 | 1.00 | 1 |
| 02/03/2014 15:00 | 17,632.6 | 1,720.2 | 19,352.8 | 19,352.8 | 102,258.0 | 1,979.0 | 1.00 | 1 |
| 02/03/2014 16:00 | 17,649.7 | 1,959.5 | 19,609.2 | 19,609.2 | 102,258.0 | 2,005.2 | 1.00 | 1 |
| 02/03/2014 17:00 | 17,654.7 | 2,768.6 | 20,423.3 | 20,423.3 | 102,258.0 | 2,088.4 | 1.00 | 1 |
| 02/03/2014 18:00 | 17,705.5 | 4,122.2 | 21,827.7 | 21,827.7 | 102,258.0 | 2,232.1 | 1.00 | 1 |
| 02/03/2014 19:00 | 17,792.7 | 4,393.8 | 22,186.5 | 22,186.5 | 102,258.0 | 2,268.7 | 1.00 | 1 |
| 02/03/2014 20:00 | 17,839.3 | 4,376.2 | 22,215.5 | 22,215.5 | 102,258.0 | 2,271.7 | 1.00 | 1 |
| 02/03/2014 21:00 | 17,901.6 | 4,280.0 | 22,181.6 | 22,181.6 | 102,258.0 | 2,268.2 | 1.00 | 1 |
| 02/03/2014 22:00 | 17,957.5 | 3,975.9 | 21,933.4 | 21,933.4 | 102,258.0 | 2,242.9 | 1.00 | 1 |
| 02/03/2014 23:00 | 17,951.0 | 3,098.4 | 21,049.4 | 21,049.4 | 102,258.0 | 2,152.5 | 1.00 | 1 |
| **Average/Sum#:** | 17,919.2 | 2,768.9 | 20,688.1 | 496,513.7 # | 102,258.0 | 2,115.5 | 24.00 # | 24 # |
| **Minimum:** | 17,307.9 | 1,559.8 | 18,867.7 | 18,867.7 | 102,258.0 | 1,929.4 | 1.00 | 1 |
| **Maximum:** | 18,267.1 | 4,393.8 | 22,215.5 | 22,215.5 | 102,258.0 | 2,271.7 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/04/2014 00:00 | 18,207.7 | 2,322.1 | 20,529.8 | 20,529.8 | 102,258.0 | 2,099.3 | 1.00 | 1 |
| 02/04/2014 01:00 | 18,140.1 | 1,789.9 | 19,930.0 | 19,930.0 | 102,258.0 | 2,038.0 | 1.00 | 1 |
| 02/04/2014 02:00 | 17,495.4 | 1,619.1 | 19,114.5 | 19,114.5 | 102,258.0 | 1,954.6 | 1.00 | 1 |
| 02/04/2014 03:00 | 17,977.8 | 1,686.1 | 19,663.9 | 19,663.9 | 102,258.0 | 2,010.8 | 1.00 | 1 |
| 02/04/2014 04:00 | 17,031.2 | 1,562.3 | 18,593.5 | 18,593.5 | 102,258.0 | 1,901.3 | 1.00 | 1 |
| 02/04/2014 05:00 | 16,745.7 | 1,556.7 | 18,302.4 | 18,302.4 | 102,258.0 | 1,871.6 | 1.00 | 1 |
| 02/04/2014 06:00 | 17,811.5 | 2,056.7 | 19,868.2 | 19,868.2 | 102,258.0 | 2,031.7 | 1.00 | 1 |
| 02/04/2014 07:00 | 18,212.1 | 1,963.9 | 20,176.0 | 20,176.0 | 102,258.0 | 2,063.2 | 1.00 | 1 |
| 02/04/2014 08:00 | 18,232.5 | 1,969.3 | 20,201.8 | 20,201.8 | 102,258.0 | 2,065.8 | 1.00 | 1 |
| 02/04/2014 09:00 | 18,062.6 | 1,606.7 | 19,669.3 | 19,669.3 | 102,258.0 | 2,011.3 | 1.00 | 1 |
| 02/04/2014 10:00 | 18,260.1 | 1,756.0 | 20,016.1 | 20,016.1 | 102,258.0 | 2,046.8 | 1.00 | 1 |
| 02/04/2014 11:00 | 18,090.4 | 1,931.7 | 20,022.1 | 20,022.1 | 102,258.0 | 2,047.4 | 1.00 | 1 |
| 02/04/2014 12:00 | 17,927.9 | 1,697.6 | 19,625.5 | 19,625.5 | 102,258.0 | 2,006.9 | 1.00 | 1 |
| 02/04/2014 13:00 | 17,492.5 | 1,562.7 | 19,055.2 | 19,055.2 | 102,258.0 | 1,948.5 | 1.00 | 1 |
| 02/04/2014 14:00 | 17,818.4 | 2,083.0 | 19,901.4 | 19,901.4 | 102,258.0 | 2,035.1 | 1.00 | 1 |
| 02/04/2014 15:00 | 17,776.7 | 2,575.2 | 20,351.9 | 20,351.9 | 102,258.0 | 2,081.1 | 1.00 | 1 |
| 02/04/2014 16:00 | 17,759.6 | 2,225.5 | 19,985.1 | 19,985.1 | 102,258.0 | 2,043.6 | 1.00 | 1 |
| 02/04/2014 17:00 | 17,765.4 | 2,290.4 | 20,055.8 | 20,055.8 | 102,258.0 | 2,050.9 | 1.00 | 1 |
| 02/04/2014 18:00 | 17,811.0 | 3,065.5 | 20,876.5 | 20,876.5 | 102,258.0 | 2,134.8 | 1.00 | 1 |
| 02/04/2014 19:00 | 17,819.9 | 3,944.9 | 21,764.8 | 21,764.8 | 102,258.0 | 2,225.6 | 1.00 | 1 |
| 02/04/2014 20:00 | 17,835.8 | 3,681.1 | 21,516.9 | 21,516.9 | 102,258.0 | 2,200.3 | 1.00 | 1 |
| 02/04/2014 21:00 | 17,865.4 | 4,172.7 | 22,038.1 | 22,038.1 | 102,258.0 | 2,253.6 | 1.00 | 1 |
| 02/04/2014 22:00 | 17,923.8 | 3,969.2 | 21,893.0 | 21,893.0 | 102,258.0 | 2,238.7 | 1.00 | 1 |
| 02/04/2014 23:00 | 18,072.5 | 2,719.2 | 20,791.7 | 20,791.7 | 102,258.0 | 2,126.1 | 1.00 | 1 |
| **Average/Sum#:** | 17,839.0 | 2,325.3 | 20,164.3 | 483,943.5 # | 102,258.0 | 2,062.0 | 24.00 # | 24 # |
| **Minimum:** | 16,745.7 | 1,556.7 | 18,302.4 | 18,302.4 | 102,258.0 | 1,871.6 | 1.00 | 1 |
| **Maximum:** | 18,260.1 | 4,172.7 | 22,038.1 | 22,038.1 | 102,258.0 | 2,253.6 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/05/2014 00:00 | 18,019.5 | 2,212.4 | 20,231.9 | 20,231.9 | 102,258.0 | 2,068.9 | 1.00 | 1 |
| 02/05/2014 01:00 | 17,075.3 | 1,553.6 | 18,628.9 | 18,628.9 | 102,258.0 | 1,905.0 | 1.00 | 1 |
| 02/05/2014 02:00 | 16,777.3 | 1,550.7 | 18,328.0 | 18,328.0 | 102,258.0 | 1,874.2 | 1.00 | 1 |
| 02/05/2014 03:00 | 16,773.8 | 1,555.8 | 18,329.6 | 18,329.6 | 102,258.0 | 1,874.3 | 1.00 | 1 |
| 02/05/2014 04:00 | 16,783.0 | 1,558.4 | 18,341.4 | 18,341.4 | 102,258.0 | 1,875.6 | 1.00 | 1 |
| 02/05/2014 05:00 | 17,167.1 | 1,560.9 | 18,728.0 | 18,728.0 | 102,258.0 | 1,915.1 | 1.00 | 1 |
| 02/05/2014 06:00 | 17,694.4 | 1,636.4 | 19,330.8 | 19,330.8 | 102,258.0 | 1,976.7 | 1.00 | 1 |
| 02/05/2014 07:00 | 18,217.9 | 2,767.9 | 20,985.8 | 20,985.8 | 102,258.0 | 2,146.0 | 1.00 | 1 |
| 02/05/2014 08:00 | 18,265.1 | 3,854.4 | 22,119.5 | 22,119.5 | 102,258.0 | 2,261.9 | 1.00 | 1 |
| 02/05/2014 09:00 | 18,311.9 | 2,214.3 | 20,526.2 | 20,526.2 | 102,258.0 | 2,099.0 | 1.00 | 1 |
| 02/05/2014 10:00 | 13,194.8 | 186.5 | 13,219.0 | 13,219.0 | 102,258.0 | 1,351.7 | 1.00 | 1 |
| 02/05/2014 11:00 | 15,035.3 | 781.4 | 15,269.7 | 15,269.7 | 102,258.0 | 1,561.4 | 1.00 | 1 |
| 02/05/2014 12:00 | 18,173.9 | 4,091.7 | 22,265.6 | 22,265.6 | 102,258.0 | 2,276.8 | 1.00 | 1 |
| 02/05/2014 13:00 | 18,006.6 | 3,443.9 | 21,450.5 | 21,450.5 | 102,258.0 | 2,193.5 | 1.00 | 1 |
| 02/05/2014 14:00 | 17,130.0 | 1,537.4 | 18,667.4 | 18,667.4 | 102,258.0 | 1,908.9 | 1.00 | 1 |
| 02/05/2014 15:00 | 16,874.1 | 1,538.3 | 18,412.4 | 18,412.4 | 102,258.0 | 1,882.8 | 1.00 | 1 |
| 02/05/2014 16:00 | 17,082.1 | 1,536.5 | 18,618.6 | 18,618.6 | 102,258.0 | 1,903.9 | 1.00 | 1 |
| 02/05/2014 17:00 | 17,831.6 | 2,144.0 | 19,975.6 | 19,975.6 | 102,258.0 | 2,042.7 | 1.00 | 1 |
| 02/05/2014 18:00 | 17,855.0 | 2,559.7 | 20,414.7 | 20,414.7 | 102,258.0 | 2,087.6 | 1.00 | 1 |
| 02/05/2014 19:00 | 17,859.5 | 4,017.7 | 21,877.2 | 21,877.2 | 102,258.0 | 2,237.1 | 1.00 | 1 |
| 02/05/2014 20:00 | 17,894.3 | 4,176.8 | 22,071.1 | 22,071.1 | 102,258.0 | 2,256.9 | 1.00 | 1 |
| 02/05/2014 21:00 | 17,957.7 | 4,128.6 | 22,086.3 | 22,086.3 | 102,258.0 | 2,258.5 | 1.00 | 1 |
| 02/05/2014 22:00 | 17,981.7 | 4,123.7 | 22,105.4 | 22,105.4 | 102,258.0 | 2,260.5 | 1.00 | 1 |
| 02/05/2014 23:00 | 17,993.7 | 4,112.5 | 22,106.2 | 22,106.2 | 102,258.0 | 2,260.5 | 1.00 | 1 |
| **Average/Sum#:** | 17,331.5 | 2,451.8 | 19,753.7 | 474,089.8 # | 102,258.0 | 2,020.0 | 24.00 # | 24 # |
| **Minimum:** | 13,194.8 | 186.5 | 13,219.0 | 13,219.0 | 102,258.0 | 1,351.7 | 1.00 | 1 |
| **Maximum:** | 18,311.9 | 4,176.8 | 22,265.6 | 22,265.6 | 102,258.0 | 2,276.8 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/06/2014 00:00 | 17,994.6 | 3,733.1 | 21,727.7 | 21,727.7 | 102,258.0 | 2,221.8 | 1.00 | 1 |
| 02/06/2014 01:00 | 17,551.3 | 1,773.8 | 19,325.1 | 19,325.1 | 102,258.0 | 1,976.1 | 1.00 | 1 |
| 02/06/2014 02:00 | 16,719.9 | 1,555.5 | 18,275.4 | 18,275.4 | 102,258.0 | 1,868.8 | 1.00 | 1 |
| 02/06/2014 03:00 | 16,723.9 | 1,556.4 | 18,280.3 | 18,280.3 | 102,258.0 | 1,869.3 | 1.00 | 1 |
| 02/06/2014 04:00 | 16,765.9 | 1,557.7 | 18,323.6 | 18,323.6 | 102,258.0 | 1,873.7 | 1.00 | 1 |
| 02/06/2014 05:00 | 16,768.9 | 1,556.4 | 18,325.3 | 18,325.3 | 102,258.0 | 1,873.9 | 1.00 | 1 |
| 02/06/2014 06:00 | 16,857.0 | 1,554.1 | 18,411.1 | 18,411.1 | 102,258.0 | 1,882.7 | 1.00 | 1 |
| 02/06/2014 07:00 | 17,077.3 | 1,551.1 | 18,628.4 | 18,628.4 | 102,258.0 | 1,904.9 | 1.00 | 1 |
| 02/06/2014 08:00 | 17,562.3 | 1,604.3 | 19,166.6 | 19,166.6 | 102,258.0 | 1,959.9 | 1.00 | 1 |
| 02/06/2014 09:00 | 17,358.1 | 1,509.0 | 18,867.1 | 18,867.1 | 102,258.0 | 1,929.3 | 1.00 | 1 |
| 02/06/2014 10:00 | 16,967.0 | 1,488.5 | 18,455.5 | 18,455.5 | 102,258.0 | 1,887.2 | 1.00 | 1 |
| 02/06/2014 11:00 | 16,853.0 | 1,486.1 | 18,339.1 | 18,339.1 | 102,258.0 | 1,875.3 | 1.00 | 1 |
| 02/06/2014 12:00 | 16,733.4 | 1,484.4 | 18,217.8 | 18,217.8 | 102,258.0 | 1,862.9 | 1.00 | 1 |
| 02/06/2014 13:00 | 16,801.0 | 1,482.5 | 18,283.5 | 18,283.5 | 102,258.0 | 1,869.6 | 1.00 | 1 |
| 02/06/2014 14:00 | 16,787.9 | 1,478.7 | 18,266.6 | 18,266.6 | 102,258.0 | 1,867.9 | 1.00 | 1 |
| 02/06/2014 15:00 | 17,129.3 | 1,474.6 | 18,603.9 | 18,603.9 | 102,258.0 | 1,902.4 | 1.00 | 1 |
| 02/06/2014 16:00 | 16,801.9 | 1,472.1 | 18,274.0 | 18,274.0 | 102,258.0 | 1,868.7 | 1.00 | 1 |
| 02/06/2014 17:00 | 17,273.5 | 1,471.9 | 18,745.4 | 18,745.4 | 102,258.0 | 1,916.9 | 1.00 | 1 |
| 02/06/2014 18:00 | 17,117.8 | 1,467.6 | 18,585.4 | 18,585.4 | 102,258.0 | 1,900.5 | 1.00 | 1 |
| 02/06/2014 19:00 | 17,562.0 | 1,463.5 | 19,025.5 | 19,025.5 | 102,258.0 | 1,945.5 | 1.00 | 1 |
| 02/06/2014 20:00 | 17,069.8 | 1,462.5 | 18,532.3 | 18,532.3 | 102,258.0 | 1,895.1 | 1.00 | 1 |
| 02/06/2014 21:00 | 16,935.1 | 1,464.4 | 18,399.5 | 18,399.5 | 102,258.0 | 1,881.5 | 1.00 | 1 |
| 02/06/2014 22:00 | 16,942.0 | 1,465.3 | 18,407.3 | 18,407.3 | 102,258.0 | 1,882.3 | 1.00 | 1 |
| 02/06/2014 23:00 | 16,949.7 | 1,462.6 | 18,412.3 | 18,412.3 | 102,258.0 | 1,882.8 | 1.00 | 1 |
| **Average/Sum#:** | 17,054.3 | 1,607.3 | 18,661.6 | 447,878.7 # | 102,258.0 | 1,908.3 | 24.00 # | 24 # |
| **Minimum:** | 16,719.9 | 1,462.5 | 18,217.8 | 18,217.8 | 102,258.0 | 1,862.9 | 1.00 | 1 |
| **Maximum:** | 17,994.6 | 3,733.1 | 21,727.7 | 21,727.7 | 102,258.0 | 2,221.8 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/07/2014 00:00 | 16,945.7 | 1,463.5 | 18,409.2 | 18,409.2 | 102,258.0 | 1,882.5 | 1.00 | 1 |
| 02/07/2014 01:00 | 17,876.2 | 1,918.3 | 19,794.5 | 19,794.5 | 102,258.0 | 2,024.1 | 1.00 | 1 |
| 02/07/2014 02:00 | 18,017.8 | 2,335.8 | 20,353.6 | 20,353.6 | 102,258.0 | 2,081.3 | 1.00 | 1 |
| 02/07/2014 03:00 | 17,945.5 | 2,370.3 | 20,315.8 | 20,315.8 | 102,258.0 | 2,077.5 | 1.00 | 1 |
| 02/07/2014 04:00 | 17,850.8 | 3,766.5 | 21,617.3 | 21,617.3 | 102,258.0 | 2,210.5 | 1.00 | 1 |
| 02/07/2014 05:00 | 17,862.8 | 3,821.7 | 21,684.5 | 21,684.5 | 102,258.0 | 2,217.4 | 1.00 | 1 |
| 02/07/2014 06:00 | 17,852.3 | 4,159.0 | 22,011.3 | 22,011.3 | 102,258.0 | 2,250.8 | 1.00 | 1 |
| 02/07/2014 07:00 | 17,911.4 | 4,241.9 | 22,153.3 | 22,153.3 | 102,258.0 | 2,265.4 | 1.00 | 1 |
| 02/07/2014 08:00 | 17,968.5 | 4,279.9 | 22,248.4 | 22,248.4 | 102,258.0 | 2,275.1 | 1.00 | 1 |
| 02/07/2014 09:00 | 17,993.5 | 3,268.5 | 21,262.0 | 21,262.0 | 102,258.0 | 2,174.2 | 1.00 | 1 |
| 02/07/2014 10:00 | 17,995.7 | 2,118.1 | 20,113.8 | 20,113.8 | 102,258.0 | 2,056.8 | 1.00 | 1 |
| 02/07/2014 11:00 | 17,959.1 | 2,155.2 | 20,114.3 | 20,114.3 | 102,258.0 | 2,056.8 | 1.00 | 1 |
| 02/07/2014 12:00 | 17,914.9 | 2,433.9 | 20,348.8 | 20,348.8 | 102,258.0 | 2,080.8 | 1.00 | 1 |
| 02/07/2014 13:00 | 17,830.6 | 2,075.7 | 19,906.3 | 19,906.3 | 102,258.0 | 2,035.6 | 1.00 | 1 |
| 02/07/2014 14:00 | 17,451.1 | 1,766.1 | 19,217.2 | 19,217.2 | 102,258.0 | 1,965.1 | 1.00 | 1 |
| 02/07/2014 15:00 | 16,872.6 | 1,522.3 | 18,394.9 | 18,394.9 | 102,258.0 | 1,881.0 | 1.00 | 1 |
| 02/07/2014 16:00 | 17,758.3 | 2,121.6 | 19,879.9 | 19,879.9 | 102,258.0 | 2,032.9 | 1.00 | 1 |
| 02/07/2014 17:00 | 17,754.8 | 2,167.4 | 19,922.2 | 19,922.2 | 102,258.0 | 2,037.2 | 1.00 | 1 |
| 02/07/2014 18:00 | 17,767.9 | 2,674.1 | 20,442.0 | 20,442.0 | 102,258.0 | 2,090.4 | 1.00 | 1 |
| 02/07/2014 19:00 | 17,789.8 | 4,006.9 | 21,796.7 | 21,796.7 | 102,258.0 | 2,228.9 | 1.00 | 1 |
| 02/07/2014 20:00 | 17,801.3 | 2,498.5 | 20,224.8 | 20,224.8 | 102,258.0 | 2,068.1 | 1.00 | 1 |
| 02/07/2014 21:00 | 17,822.6 | 2,350.2 | 20,172.8 | 20,172.8 | 102,258.0 | 2,062.8 | 1.00 | 1 |
| 02/07/2014 22:00 | 17,826.3 | 2,359.6 | 20,185.9 | 20,185.9 | 102,258.0 | 2,064.2 | 1.00 | 1 |
| 02/07/2014 23:00 | 17,812.9 | 2,428.8 | 20,241.7 | 20,241.7 | 102,258.0 | 2,069.9 | 1.00 | 1 |
| **Average/Sum#:** | 17,774.3 | 2,679.3 | 20,450.5 | 490,811.2 # | 102,258.0 | 2,091.2 | 24.00 # | 24 # |
| **Minimum:** | 16,872.6 | 1,463.5 | 18,394.9 | 18,394.9 | 102,258.0 | 1,881.0 | 1.00 | 1 |
| **Maximum:** | 18,017.8 | 4,279.9 | 22,248.4 | 22,248.4 | 102,258.0 | 2,275.1 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/08/2014 00:00 | 17,796.8 | 1,413.4 | 19,210.2 | 19,210.2 | 102,258.0 | 1,964.4 | 1.00 | 1 |
| 02/08/2014 01:00 | 17,778.2 | 1,267.6 | 19,045.8 | 19,045.8 | 102,258.0 | 1,947.6 | 1.00 | 1 |
| 02/08/2014 02:00 | 17,729.4 | 915.4 | 18,644.8 | 18,644.8 | 102,258.0 | 1,906.6 | 1.00 | 1 |
| 02/08/2014 03:00 | 17,741.2 | 811.8 | 18,553.0 | 18,553.0 | 102,258.0 | 1,897.2 | 1.00 | 1 |
| 02/08/2014 04:00 | 17,810.5 | 812.4 | 18,622.9 | 18,622.9 | 102,258.0 | 1,904.3 | 1.00 | 1 |
| 02/08/2014 05:00 | 17,801.7 | 816.2 | 18,617.9 | 18,617.9 | 102,258.0 | 1,903.8 | 1.00 | 1 |
| 02/08/2014 06:00 | 17,485.9 | 966.6 | 18,452.5 | 18,452.5 | 102,258.0 | 1,886.9 | 1.00 | 1 |
| 02/08/2014 07:00 | 17,291.7 | 1,503.1 | 18,794.8 | 18,794.8 | 102,258.0 | 1,921.9 | 1.00 | 1 |
| 02/08/2014 08:00 | 16,813.9 | 1,507.2 | 18,321.1 | 18,321.1 | 102,258.0 | 1,873.5 | 1.00 | 1 |
| 02/08/2014 09:00 | 16,793.2 | 1,330.0 | 18,016.8 | 18,016.8 | 102,258.0 | 1,842.4 | 1.00 | 1 |
| 02/08/2014 10:00 | 16,704.6 | 1,537.5 | 18,242.1 | 18,242.1 | 102,258.0 | 1,865.4 | 1.00 | 1 |
| 02/08/2014 11:00 | 16,745.6 | 1,532.0 | 18,277.6 | 18,277.6 | 102,258.0 | 1,869.0 | 1.00 | 1 |
| 02/08/2014 12:00 | 16,785.9 | 1,526.6 | 18,312.5 | 18,312.5 | 102,258.0 | 1,872.6 | 1.00 | 1 |
| 02/08/2014 13:00 | 17,069.1 | 1,552.6 | 18,621.7 | 18,621.7 | 102,258.0 | 1,904.2 | 1.00 | 1 |
| 02/08/2014 14:00 | 16,697.9 | 1,523.0 | 18,220.9 | 18,220.9 | 102,258.0 | 1,863.2 | 1.00 | 1 |
| 02/08/2014 15:00 | 16,720.0 | 1,520.5 | 18,240.5 | 18,240.5 | 102,258.0 | 1,865.2 | 1.00 | 1 |
| 02/08/2014 16:00 | 16,734.0 | 1,516.2 | 18,250.2 | 18,250.2 | 102,258.0 | 1,866.2 | 1.00 | 1 |
| 02/08/2014 17:00 | 16,822.8 | 1,514.1 | 18,336.9 | 18,336.9 | 102,258.0 | 1,875.1 | 1.00 | 1 |
| 02/08/2014 18:00 | 17,485.8 | 1,825.9 | 19,311.7 | 19,311.7 | 102,258.0 | 1,974.8 | 1.00 | 1 |
| 02/08/2014 19:00 | 17,548.5 | 3,557.1 | 21,105.6 | 21,105.6 | 102,258.0 | 2,158.2 | 1.00 | 1 |
| 02/08/2014 20:00 | 17,574.1 | 2,645.1 | 20,219.2 | 20,219.2 | 102,258.0 | 2,067.6 | 1.00 | 1 |
| 02/08/2014 21:00 | 17,582.5 | 2,903.9 | 20,486.4 | 20,486.4 | 102,258.0 | 2,094.9 | 1.00 | 1 |
| 02/08/2014 22:00 | 17,344.1 | 1,524.6 | 18,868.7 | 18,868.7 | 102,258.0 | 1,929.5 | 1.00 | 1 |
| 02/08/2014 23:00 | 17,257.0 | 786.6 | 18,043.6 | 18,043.6 | 102,258.0 | 1,845.1 | 1.00 | 1 |
| **Average/Sum#:** | 17,254.8 | 1,533.7 | 18,784.1 | 450,817.4 # | 102,258.0 | 1,920.8 | 24.00 # | 24 # |
| **Minimum:** | 16,697.9 | 786.6 | 18,016.8 | 18,016.8 | 102,258.0 | 1,842.4 | 1.00 | 1 |
| **Maximum:** | 17,810.5 | 3,557.1 | 21,105.6 | 21,105.6 | 102,258.0 | 2,158.2 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/09/2014 00:00 | 17,169.1 | 816.1 | 17,985.2 | 17,985.2 | 102,258.0 | 1,839.1 | 1.00 | 1 |
| 02/09/2014 01:00 | 17,544.9 | 1,433.3 | 18,978.2 | 18,978.2 | 102,258.0 | 1,940.7 | 1.00 | 1 |
| 02/09/2014 02:00 | 17,348.8 | 777.3 | 18,126.1 | 18,126.1 | 102,258.0 | 1,853.5 | 1.00 | 1 |
| 02/09/2014 03:00 | 17,225.4 | 771.9 | 17,997.3 | 17,997.3 | 102,258.0 | 1,840.4 | 1.00 | 1 |
| 02/09/2014 04:00 | 17,221.4 | 771.5 | 17,992.9 | 17,992.9 | 102,258.0 | 1,839.9 | 1.00 | 1 |
| 02/09/2014 05:00 | 17,174.5 | 776.5 | 17,951.0 | 17,951.0 | 102,258.0 | 1,835.6 | 1.00 | 1 |
| 02/09/2014 06:00 | 17,117.9 | 964.9 | 18,082.8 | 18,082.8 | 102,258.0 | 1,849.1 | 1.00 | 1 |
| 02/09/2014 07:00 | 16,747.8 | 1,453.7 | 18,201.5 | 18,201.5 | 102,258.0 | 1,861.2 | 1.00 | 1 |
| 02/09/2014 08:00 | 16,714.0 | 1,461.5 | 18,175.5 | 18,175.5 | 102,258.0 | 1,858.6 | 1.00 | 1 |
| 02/09/2014 09:00 | 16,752.8 | 1,460.7 | 18,213.5 | 18,213.5 | 102,258.0 | 1,862.5 | 1.00 | 1 |
| 02/09/2014 10:00 | 16,752.9 | 1,459.5 | 18,212.4 | 18,212.4 | 102,258.0 | 1,862.4 | 1.00 | 1 |
| 02/09/2014 11:00 | 16,677.9 | 1,452.1 | 18,130.0 | 18,130.0 | 102,258.0 | 1,853.9 | 1.00 | 1 |
| 02/09/2014 12:00 | 16,672.5 | 1,451.7 | 18,124.2 | 18,124.2 | 102,258.0 | 1,853.3 | 1.00 | 1 |
| 02/09/2014 13:00 | 16,682.4 | 1,443.1 | 18,125.5 | 18,125.5 | 102,258.0 | 1,853.5 | 1.00 | 1 |
| 02/09/2014 14:00 | 16,717.7 | 1,437.7 | 18,155.4 | 18,155.4 | 102,258.0 | 1,856.5 | 1.00 | 1 |
| 02/09/2014 15:00 | 16,731.6 | 1,432.7 | 18,164.3 | 18,164.3 | 102,258.0 | 1,857.4 | 1.00 | 1 |
| 02/09/2014 16:00 | 16,937.1 | 1,494.4 | 18,431.5 | 18,431.5 | 102,258.0 | 1,884.8 | 1.00 | 1 |
| 02/09/2014 17:00 | 16,968.2 | 1,505.2 | 18,473.4 | 18,473.4 | 102,258.0 | 1,889.1 | 1.00 | 1 |
| 02/09/2014 18:00 | 17,212.4 | 2,129.6 | 19,342.0 | 19,342.0 | 102,258.0 | 1,977.9 | 1.00 | 1 |
| 02/09/2014 19:00 | 17,456.3 | 4,430.6 | 21,886.9 | 21,886.9 | 102,258.0 | 2,238.1 | 1.00 | 1 |
| 02/09/2014 20:00 | 17,481.3 | 4,534.4 | 22,015.7 | 22,015.7 | 102,258.0 | 2,251.3 | 1.00 | 1 |
| 02/09/2014 21:00 | 17,506.5 | 4,538.3 | 22,044.8 | 22,044.8 | 102,258.0 | 2,254.3 | 1.00 | 1 |
| 02/09/2014 22:00 | 17,506.5 | 3,507.9 | 21,014.4 | 21,014.4 | 102,258.0 | 2,148.9 | 1.00 | 1 |
| 02/09/2014 23:00 | 17,505.3 | 2,892.6 | 20,397.9 | 20,397.9 | 102,258.0 | 2,085.8 | 1.00 | 1 |
| **Average/Sum#:** | 17,076.1 | 1,849.9 | 18,925.9 | 454,222.4 # | 102,258.0 | 1,935.3 | 24.00 # | 24 # |
| **Minimum:** | 16,672.5 | 771.5 | 17,951.0 | 17,951.0 | 102,258.0 | 1,835.6 | 1.00 | 1 |
| **Maximum:** | 17,544.9 | 4,538.3 | 22,044.8 | 22,044.8 | 102,258.0 | 2,254.3 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/10/2014 00:00 | 14,451.8 | 315.5 | 14,546.5 | 14,546.5 | 102,258.0 | 1,487.5 | 1.00 | 1 |
| 02/10/2014 01:00 | 13,082.3 | 0.0 | 13,082.3 | 13,082.3 | 102,258.0 | 1,337.8 | 1.00 | 1 |
| 02/10/2014 02:00 | 13,389.7 | 0.0 | 13,389.7 | 13,389.7 | 102,258.0 | 1,369.2 | 1.00 | 1 |
| 02/10/2014 03:00 | 12,207.4 | 0.0 | 12,207.4 | 12,207.4 | 102,258.0 | 1,248.3 | 1.00 | 1 |
| 02/10/2014 04:00 | 12,208.3 | 0.0 | 12,208.3 | 12,208.3 | 102,258.0 | 1,248.4 | 1.00 | 1 |
| 02/10/2014 05:00 | 13,936.9 | 189.2 | 13,978.5 | 13,978.5 | 102,258.0 | 1,429.4 | 1.00 | 1 |
| 02/10/2014 06:00 | 17,314.2 | 1,152.6 | 18,466.8 | 18,466.8 | 102,258.0 | 1,888.4 | 1.00 | 1 |
| 02/10/2014 07:00 | 17,306.0 | 1,570.6 | 18,876.6 | 18,876.6 | 102,258.0 | 1,930.3 | 1.00 | 1 |
| 02/10/2014 08:00 | 17,860.5 | 1,759.2 | 19,619.7 | 19,619.7 | 102,258.0 | 2,006.3 | 1.00 | 1 |
| 02/10/2014 09:00 | 17,109.0 | 1,551.4 | 18,660.4 | 18,660.4 | 102,258.0 | 1,908.2 | 1.00 | 1 |
| 02/10/2014 10:00 | 17,073.7 | 1,542.2 | 18,615.9 | 18,615.9 | 102,258.0 | 1,903.6 | 1.00 | 1 |
| 02/10/2014 11:00 | 16,833.9 | 1,525.3 | 18,359.2 | 18,359.2 | 102,258.0 | 1,877.4 | 1.00 | 1 |
| 02/10/2014 12:00 | 16,825.0 | 1,515.4 | 18,340.4 | 18,340.4 | 102,258.0 | 1,875.5 | 1.00 | 1 |
| 02/10/2014 13:00 | 16,828.1 | 1,524.3 | 18,352.4 | 18,352.4 | 102,258.0 | 1,876.7 | 1.00 | 1 |
| 02/10/2014 14:00 | 16,855.9 | 1,466.1 | 18,278.0 | 18,278.0 | 102,258.0 | 1,869.1 | 1.00 | 1 |
| 02/10/2014 15:00 | 16,777.7 | 1,535.7 | 18,313.4 | 18,313.4 | 102,258.0 | 1,872.7 | 1.00 | 1 |
| 02/10/2014 16:00 | 16,787.3 | 1,535.1 | 18,322.4 | 18,322.4 | 102,258.0 | 1,873.6 | 1.00 | 1 |
| 02/10/2014 17:00 | 16,776.9 | 1,537.5 | 18,314.4 | 18,314.4 | 102,258.0 | 1,872.8 | 1.00 | 1 |
| 02/10/2014 18:00 | 17,137.2 | 1,605.0 | 18,742.2 | 18,742.2 | 102,258.0 | 1,916.5 | 1.00 | 1 |
| 02/10/2014 19:00 | 17,608.6 | 2,328.9 | 19,937.5 | 19,937.5 | 102,258.0 | 2,038.8 | 1.00 | 1 |
| 02/10/2014 20:00 | 17,603.8 | 2,455.4 | 20,059.2 | 20,059.2 | 102,258.0 | 2,051.2 | 1.00 | 1 |
| 02/10/2014 21:00 | 17,608.5 | 3,297.4 | 20,905.9 | 20,905.9 | 102,258.0 | 2,137.8 | 1.00 | 1 |
| 02/10/2014 22:00 | 17,633.5 | 2,013.4 | 19,646.9 | 19,646.9 | 102,258.0 | 2,009.1 | 1.00 | 1 |
| 02/10/2014 23:00 | 17,309.3 | 913.0 | 18,222.3 | 18,222.3 | 102,258.0 | 1,863.4 | 1.00 | 1 |
| **Average/Sum#:** | 16,188.6 | 1,305.6 | 17,476.9 | 419,446.3 # | 102,258.0 | 1,787.2 | 24.00 # | 24 # |
| **Minimum:** | 12,207.4 | 0.0 | 12,207.4 | 12,207.4 | 102,258.0 | 1,248.3 | 1.00 | 1 |
| **Maximum:** | 17,860.5 | 3,297.4 | 20,905.9 | 20,905.9 | 102,258.0 | 2,137.8 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/11/2014 00:00 | 17,154.7 | 1,132.9 | 18,287.6 | 18,287.6 | 102,258.0 | 1,870.1 | 1.00 | 1 |
| 02/11/2014 01:00 | 16,735.3 | 1,424.2 | 18,159.5 | 18,159.5 | 102,258.0 | 1,857.0 | 1.00 | 1 |
| 02/11/2014 02:00 | 17,090.8 | 1,249.7 | 18,340.5 | 18,340.5 | 102,258.0 | 1,875.5 | 1.00 | 1 |
| 02/11/2014 03:00 | 15,213.2 | 841.5 | 15,676.0 | 15,676.0 | 102,258.0 | 1,603.0 | 1.00 | 1 |
| 02/11/2014 04:00 | 12,232.3 | 0.0 | 12,232.3 | 12,232.3 | 102,258.0 | 1,250.9 | 1.00 | 1 |
| 02/11/2014 05:00 | 14,799.2 | 24.2 | 14,799.9 | 14,799.9 | 102,258.0 | 1,513.4 | 1.00 | 1 |
| 02/11/2014 06:00 | 16,684.8 | 1,528.8 | 18,213.6 | 18,213.6 | 102,258.0 | 1,862.5 | 1.00 | 1 |
| 02/11/2014 07:00 | 16,813.9 | 1,538.4 | 18,352.3 | 18,352.3 | 102,258.0 | 1,876.7 | 1.00 | 1 |
| 02/11/2014 08:00 | 17,958.2 | 2,228.7 | 20,186.9 | 20,186.9 | 102,258.0 | 2,064.3 | 1.00 | 1 |
| 02/11/2014 09:00 | 17,969.1 | 1,865.8 | 19,834.9 | 19,834.9 | 102,258.0 | 2,028.3 | 1.00 | 1 |
| 02/11/2014 10:00 | 17,210.3 | 1,530.8 | 18,741.1 | 18,741.1 | 102,258.0 | 1,916.4 | 1.00 | 1 |
| 02/11/2014 11:00 | 16,831.9 | 1,514.5 | 18,346.4 | 18,346.4 | 102,258.0 | 1,876.1 | 1.00 | 1 |
| 02/11/2014 12:00 | 16,844.3 | 1,503.4 | 18,347.7 | 18,347.7 | 102,258.0 | 1,876.2 | 1.00 | 1 |
| 02/11/2014 13:00 | 16,851.3 | 1,487.8 | 18,339.1 | 18,339.1 | 102,258.0 | 1,875.3 | 1.00 | 1 |
| 02/11/2014 14:00 | 16,862.9 | 1,487.6 | 18,350.5 | 18,350.5 | 102,258.0 | 1,876.5 | 1.00 | 1 |
| 02/11/2014 15:00 | 16,871.8 | 1,488.3 | 18,360.1 | 18,360.1 | 102,258.0 | 1,877.5 | 1.00 | 1 |
| 02/11/2014 16:00 | 16,781.5 | 1,482.1 | 18,263.6 | 18,263.6 | 102,258.0 | 1,867.6 | 1.00 | 1 |
| 02/11/2014 17:00 | 16,875.8 | 1,463.5 | 18,339.3 | 18,339.3 | 102,258.0 | 1,875.3 | 1.00 | 1 |
| 02/11/2014 18:00 | 17,156.4 | 1,521.5 | 18,677.9 | 18,677.9 | 102,258.0 | 1,910.0 | 1.00 | 1 |
| 02/11/2014 19:00 | 17,552.2 | 2,388.6 | 19,940.8 | 19,940.8 | 102,258.0 | 2,039.1 | 1.00 | 1 |
| 02/11/2014 20:00 | 17,601.3 | 2,418.2 | 20,019.5 | 20,019.5 | 102,258.0 | 2,047.2 | 1.00 | 1 |
| 02/11/2014 21:00 | 17,618.2 | 3,184.0 | 20,802.2 | 20,802.2 | 102,258.0 | 2,127.2 | 1.00 | 1 |
| 02/11/2014 22:00 | 17,625.3 | 2,146.2 | 19,771.5 | 19,771.5 | 102,258.0 | 2,021.8 | 1.00 | 1 |
| 02/11/2014 23:00 | 17,489.2 | 1,617.0 | 19,106.2 | 19,106.2 | 102,258.0 | 1,953.8 | 1.00 | 1 |
| **Average/Sum#:** | 16,784.3 | 1,544.5 | 18,312.1 | 439,489.4 # | 102,258.0 | 1,872.6 | 24.00 # | 24 # |
| **Minimum:** | 12,232.3 | 0.0 | 12,232.3 | 12,232.3 | 102,258.0 | 1,250.9 | 1.00 | 1 |
| **Maximum:** | 17,969.1 | 3,184.0 | 20,802.2 | 20,802.2 | 102,258.0 | 2,127.2 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/12/2014 00:00 | 16,972.9 | 1,542.4 | 18,515.3 | 18,515.3 | 102,258.0 | 1,893.3 | 1.00 | 1 |
| 02/12/2014 01:00 | 17,805.3 | 1,821.5 | 19,626.8 | 19,626.8 | 102,258.0 | 2,007.0 | 1.00 | 1 |
| 02/12/2014 02:00 | 17,852.5 | 1,801.4 | 19,653.9 | 19,653.9 | 102,258.0 | 2,009.8 | 1.00 | 1 |
| 02/12/2014 03:00 | 17,817.0 | 1,897.7 | 19,714.7 | 19,714.7 | 102,258.0 | 2,016.0 | 1.00 | 1 |
| 02/12/2014 04:00 | 17,819.7 | 2,004.6 | 19,824.3 | 19,824.3 | 102,258.0 | 2,027.2 | 1.00 | 1 |
| 02/12/2014 05:00 | 17,856.7 | 1,938.6 | 19,795.3 | 19,795.3 | 102,258.0 | 2,024.2 | 1.00 | 1 |
| 02/12/2014 06:00 | 17,740.7 | 1,688.0 | 19,428.7 | 19,428.7 | 102,258.0 | 1,986.7 | 1.00 | 1 |
| 02/12/2014 07:00 | 17,934.1 | 2,352.4 | 20,286.5 | 20,286.5 | 102,258.0 | 2,074.5 | 1.00 | 1 |
| 02/12/2014 08:00 | 17,949.6 | 2,196.6 | 20,146.2 | 20,146.2 | 102,258.0 | 2,060.1 | 1.00 | 1 |
| 02/12/2014 09:00 | 17,170.2 | 1,571.4 | 18,741.6 | 18,741.6 | 102,258.0 | 1,916.5 | 1.00 | 1 |
| 02/12/2014 10:00 | 16,740.2 | 1,535.1 | 18,275.3 | 18,275.3 | 102,258.0 | 1,868.8 | 1.00 | 1 |
| 02/12/2014 11:00 | 16,778.6 | 1,527.7 | 18,306.3 | 18,306.3 | 102,258.0 | 1,872.0 | 1.00 | 1 |
| 02/12/2014 12:00 | 16,807.1 | 1,522.1 | 18,329.2 | 18,329.2 | 102,258.0 | 1,874.3 | 1.00 | 1 |
| 02/12/2014 13:00 | 16,802.8 | 1,508.8 | 18,311.6 | 18,311.6 | 102,258.0 | 1,872.5 | 1.00 | 1 |
| 02/12/2014 14:00 | 16,798.5 | 1,497.8 | 18,296.3 | 18,296.3 | 102,258.0 | 1,870.9 | 1.00 | 1 |
| 02/12/2014 15:00 | 16,800.2 | 1,496.1 | 18,296.3 | 18,296.3 | 102,258.0 | 1,870.9 | 1.00 | 1 |
| 02/12/2014 16:00 | 16,797.9 | 1,492.3 | 18,290.2 | 18,290.2 | 102,258.0 | 1,870.3 | 1.00 | 1 |
| 02/12/2014 17:00 | 16,965.4 | 1,487.6 | 18,453.0 | 18,453.0 | 102,258.0 | 1,887.0 | 1.00 | 1 |
| 02/12/2014 18:00 | 17,503.1 | 2,722.3 | 20,225.4 | 20,225.4 | 102,258.0 | 2,068.2 | 1.00 | 1 |
| 02/12/2014 19:00 | 17,603.7 | 4,710.5 | 22,314.2 | 22,314.2 | 102,258.0 | 2,281.8 | 1.00 | 1 |
| 02/12/2014 20:00 | 17,628.2 | 4,901.7 | 22,529.9 | 22,529.9 | 102,258.0 | 2,303.9 | 1.00 | 1 |
| 02/12/2014 21:00 | 17,658.3 | 4,522.3 | 22,180.6 | 22,180.6 | 102,258.0 | 2,268.1 | 1.00 | 1 |
| 02/12/2014 22:00 | 17,705.0 | 3,575.4 | 21,280.4 | 21,280.4 | 102,258.0 | 2,176.1 | 1.00 | 1 |
| 02/12/2014 23:00 | 17,642.8 | 2,157.1 | 19,799.9 | 19,799.9 | 102,258.0 | 2,024.7 | 1.00 | 1 |
| **Average/Sum#:** | 17,381.3 | 2,228.0 | 19,609.2 | 470,621.9 # | 102,258.0 | 2,005.2 | 24.00 # | 24 # |
| **Minimum:** | 16,740.2 | 1,487.6 | 18,275.3 | 18,275.3 | 102,258.0 | 1,868.8 | 1.00 | 1 |
| **Maximum:** | 17,949.6 | 4,901.7 | 22,529.9 | 22,529.9 | 102,258.0 | 2,303.9 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/13/2014 00:00 | 17,090.4 | 1,538.7 | 18,629.1 | 18,629.1 | 102,258.0 | 1,905.0 | 1.00 | 1 |
| 02/13/2014 01:00 | 16,779.6 | 1,531.7 | 18,311.3 | 18,311.3 | 102,258.0 | 1,872.5 | 1.00 | 1 |
| 02/13/2014 02:00 | 16,711.0 | 1,527.7 | 18,238.7 | 18,238.7 | 102,258.0 | 1,865.1 | 1.00 | 1 |
| 02/13/2014 03:00 | 16,718.1 | 1,522.6 | 18,240.7 | 18,240.7 | 102,258.0 | 1,865.3 | 1.00 | 1 |
| 02/13/2014 04:00 | 16,706.5 | 1,516.8 | 18,223.3 | 18,223.3 | 102,258.0 | 1,863.5 | 1.00 | 1 |
| 02/13/2014 05:00 | 16,891.6 | 1,511.7 | 18,403.3 | 18,403.3 | 102,258.0 | 1,881.9 | 1.00 | 1 |
| 02/13/2014 06:00 | 17,304.7 | 1,594.1 | 18,898.8 | 18,898.8 | 102,258.0 | 1,932.6 | 1.00 | 1 |
| 02/13/2014 07:00 | 17,781.7 | 2,888.0 | 20,669.7 | 20,669.7 | 102,258.0 | 2,113.6 | 1.00 | 1 |
| 02/13/2014 08:00 | 17,790.0 | 4,080.0 | 21,870.0 | 21,870.0 | 102,258.0 | 2,236.4 | 1.00 | 1 |
| 02/13/2014 09:00 | 17,763.7 | 3,230.0 | 20,993.7 | 20,993.7 | 102,258.0 | 2,146.8 | 1.00 | 1 |
| 02/13/2014 10:00 | 17,752.0 | 3,030.6 | 20,782.6 | 20,782.6 | 102,258.0 | 2,125.2 | 1.00 | 1 |
| 02/13/2014 11:00 | 17,743.1 | 3,033.4 | 20,776.5 | 20,776.5 | 102,258.0 | 2,124.6 | 1.00 | 1 |
| 02/13/2014 12:00 | 17,715.3 | 3,075.1 | 20,790.4 | 20,790.4 | 102,258.0 | 2,126.0 | 1.00 | 1 |
| 02/13/2014 13:00 | 17,672.9 | 3,102.7 | 20,775.6 | 20,775.6 | 102,258.0 | 2,124.5 | 1.00 | 1 |
| 02/13/2014 14:00 | 17,629.4 | 3,164.3 | 20,793.7 | 20,793.7 | 102,258.0 | 2,126.3 | 1.00 | 1 |
| 02/13/2014 15:00 | 17,564.7 | 3,226.2 | 20,790.9 | 20,790.9 | 102,258.0 | 2,126.0 | 1.00 | 1 |
| 02/13/2014 16:00 | 17,530.8 | 3,278.6 | 20,809.4 | 20,809.4 | 102,258.0 | 2,127.9 | 1.00 | 1 |
| 02/13/2014 17:00 | 17,543.9 | 3,412.6 | 20,956.5 | 20,956.5 | 102,258.0 | 2,143.0 | 1.00 | 1 |
| 02/13/2014 18:00 | 17,561.2 | 3,314.2 | 20,875.4 | 20,875.4 | 102,258.0 | 2,134.7 | 1.00 | 1 |
| 02/13/2014 19:00 | 17,570.9 | 4,150.2 | 21,721.1 | 21,721.1 | 102,258.0 | 2,221.2 | 1.00 | 1 |
| 02/13/2014 20:00 | 17,563.9 | 4,672.3 | 22,236.2 | 22,236.2 | 102,258.0 | 2,273.8 | 1.00 | 1 |
| 02/13/2014 21:00 | 17,591.6 | 4,686.4 | 22,278.0 | 22,278.0 | 102,258.0 | 2,278.1 | 1.00 | 1 |
| 02/13/2014 22:00 | 17,603.8 | 4,147.1 | 21,750.9 | 21,750.9 | 102,258.0 | 2,224.2 | 1.00 | 1 |
| 02/13/2014 23:00 | 17,626.8 | 3,767.6 | 21,394.4 | 21,394.4 | 102,258.0 | 2,187.7 | 1.00 | 1 |
| **Average/Sum#:** | 17,425.3 | 2,958.4 | 20,383.8 | 489,210.2 # | 102,258.0 | 2,084.4 | 24.00 # | 24 # |
| **Minimum:** | 16,706.5 | 1,511.7 | 18,223.3 | 18,223.3 | 102,258.0 | 1,863.5 | 1.00 | 1 |
| **Maximum:** | 17,790.0 | 4,686.4 | 22,278.0 | 22,278.0 | 102,258.0 | 2,278.1 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/14/2014 00:00 | 17,544.7 | 2,426.5 | 19,971.2 | 19,971.2 | 102,258.0 | 2,042.2 | 1.00 | 1 |
| 02/14/2014 01:00 | 16,643.3 | 1,514.7 | 18,158.0 | 18,158.0 | 102,258.0 | 1,856.8 | 1.00 | 1 |
| 02/14/2014 02:00 | 16,876.2 | 1,504.9 | 18,381.1 | 18,381.1 | 102,258.0 | 1,879.6 | 1.00 | 1 |
| 02/14/2014 03:00 | 16,727.4 | 1,501.4 | 18,228.8 | 18,228.8 | 102,258.0 | 1,864.0 | 1.00 | 1 |
| 02/14/2014 04:00 | 16,684.5 | 1,501.9 | 18,186.4 | 18,186.4 | 102,258.0 | 1,859.7 | 1.00 | 1 |
| 02/14/2014 05:00 | 16,713.1 | 1,488.9 | 18,202.0 | 18,202.0 | 102,258.0 | 1,861.3 | 1.00 | 1 |
| 02/14/2014 06:00 | 16,867.3 | 1,481.7 | 18,349.0 | 18,349.0 | 102,258.0 | 1,876.3 | 1.00 | 1 |
| 02/14/2014 07:00 | 17,289.7 | 1,426.3 | 18,716.0 | 18,716.0 | 102,258.0 | 1,913.9 | 1.00 | 1 |
| 02/14/2014 08:00 | 17,582.6 | 1,981.6 | 19,564.2 | 19,564.2 | 102,258.0 | 2,000.6 | 1.00 | 1 |
| 02/14/2014 09:00 | 17,567.3 | 3,068.2 | 20,635.5 | 20,635.5 | 102,258.0 | 2,110.1 | 1.00 | 1 |
| 02/14/2014 10:00 | 17,435.4 | 3,471.4 | 20,906.8 | 20,906.8 | 102,258.0 | 2,137.9 | 1.00 | 1 |
| 02/14/2014 11:00 | 17,351.9 | 3,576.5 | 20,928.4 | 20,928.4 | 102,258.0 | 2,140.1 | 1.00 | 1 |
| 02/14/2014 12:00 | 17,268.3 | 3,682.1 | 20,950.4 | 20,950.4 | 102,258.0 | 2,142.3 | 1.00 | 1 |
| 02/14/2014 13:00 | 17,244.4 | 3,773.3 | 21,017.7 | 21,017.7 | 102,258.0 | 2,149.2 | 1.00 | 1 |
| 02/14/2014 14:00 | 17,231.0 | 3,795.6 | 21,026.6 | 21,026.6 | 102,258.0 | 2,150.1 | 1.00 | 1 |
| 02/14/2014 15:00 | 17,216.4 | 3,862.5 | 21,078.9 | 21,078.9 | 102,258.0 | 2,155.5 | 1.00 | 1 |
| 02/14/2014 16:00 | 17,239.0 | 3,556.0 | 20,795.0 | 20,795.0 | 102,258.0 | 2,126.5 | 1.00 | 1 |
| 02/14/2014 17:00 | 17,289.0 | 3,696.2 | 20,985.2 | 20,985.2 | 102,258.0 | 2,145.9 | 1.00 | 1 |
| 02/14/2014 18:00 | 17,373.8 | 3,665.4 | 21,039.2 | 21,039.2 | 102,258.0 | 2,151.4 | 1.00 | 1 |
| 02/14/2014 19:00 | 17,447.9 | 2,893.0 | 20,340.9 | 20,340.9 | 102,258.0 | 2,080.0 | 1.00 | 1 |
| 02/14/2014 20:00 | 17,447.7 | 2,695.2 | 20,142.9 | 20,142.9 | 102,258.0 | 2,059.8 | 1.00 | 1 |
| 02/14/2014 21:00 | 17,526.6 | 3,199.6 | 20,726.2 | 20,726.2 | 102,258.0 | 2,119.4 | 1.00 | 1 |
| 02/14/2014 22:00 | 17,567.1 | 3,327.3 | 20,894.4 | 20,894.4 | 102,258.0 | 2,136.6 | 1.00 | 1 |
| 02/14/2014 23:00 | 17,555.0 | 2,461.5 | 20,016.5 | 20,016.5 | 102,258.0 | 2,046.8 | 1.00 | 1 |
| **Average/Sum#:** | 17,237.1 | 2,731.3 | 19,968.4 | 479,241.3 # | 102,258.0 | 2,041.9 | 24.00 # | 24 # |
| **Minimum:** | 16,643.3 | 1,426.3 | 18,158.0 | 18,158.0 | 102,258.0 | 1,856.8 | 1.00 | 1 |
| **Maximum:** | 17,582.6 | 3,862.5 | 21,078.9 | 21,078.9 | 102,258.0 | 2,155.5 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/15/2014 00:00 | 17,564.2 | 2,238.7 | 19,802.9 | 19,802.9 | 102,258.0 | 2,025.0 | 1.00 | 1 |
| 02/15/2014 01:00 | 17,588.9 | 2,871.4 | 20,460.3 | 20,460.3 | 102,258.0 | 2,092.2 | 1.00 | 1 |
| 02/15/2014 02:00 | 17,605.5 | 3,923.1 | 21,528.6 | 21,528.6 | 102,258.0 | 2,201.5 | 1.00 | 1 |
| 02/15/2014 03:00 | 17,620.6 | 4,091.5 | 21,712.1 | 21,712.1 | 102,258.0 | 2,220.2 | 1.00 | 1 |
| 02/15/2014 04:00 | 17,654.9 | 2,644.6 | 20,299.5 | 20,299.5 | 102,258.0 | 2,075.8 | 1.00 | 1 |
| 02/15/2014 05:00 | 17,644.3 | 2,194.4 | 19,838.7 | 19,838.7 | 102,258.0 | 2,028.7 | 1.00 | 1 |
| 02/15/2014 06:00 | 17,660.4 | 2,582.8 | 20,243.2 | 20,243.2 | 102,258.0 | 2,070.0 | 1.00 | 1 |
| 02/15/2014 07:00 | 17,652.6 | 1,949.1 | 19,601.7 | 19,601.7 | 102,258.0 | 2,004.4 | 1.00 | 1 |
| 02/15/2014 08:00 | 17,673.2 | 2,088.9 | 19,762.1 | 19,762.1 | 102,258.0 | 2,020.8 | 1.00 | 1 |
| 02/15/2014 09:00 | 17,685.7 | 2,445.2 | 20,130.9 | 20,130.9 | 102,258.0 | 2,058.5 | 1.00 | 1 |
| 02/15/2014 10:00 | 17,679.1 | 3,279.3 | 20,958.4 | 20,958.4 | 102,258.0 | 2,143.2 | 1.00 | 1 |
| 02/15/2014 11:00 | 17,605.0 | 4,315.7 | 21,920.7 | 21,920.7 | 102,258.0 | 2,241.6 | 1.00 | 1 |
| 02/15/2014 12:00 | 17,546.4 | 4,414.1 | 21,960.5 | 21,960.5 | 102,258.0 | 2,245.6 | 1.00 | 1 |
| 02/15/2014 13:00 | 17,472.6 | 3,961.4 | 21,434.0 | 21,434.0 | 102,258.0 | 2,191.8 | 1.00 | 1 |
| 02/15/2014 14:00 | 17,302.7 | 2,668.3 | 19,971.0 | 19,971.0 | 102,258.0 | 2,042.2 | 1.00 | 1 |
| 02/15/2014 15:00 | 17,257.0 | 2,449.1 | 19,706.1 | 19,706.1 | 102,258.0 | 2,015.1 | 1.00 | 1 |
| 02/15/2014 16:00 | 17,240.4 | 2,140.3 | 19,380.7 | 19,380.7 | 102,258.0 | 1,981.8 | 1.00 | 1 |
| 02/15/2014 17:00 | 17,215.5 | 2,422.4 | 19,637.9 | 19,637.9 | 102,258.0 | 2,008.1 | 1.00 | 1 |
| 02/15/2014 18:00 | 17,366.5 | 3,019.0 | 20,385.5 | 20,385.5 | 102,258.0 | 2,084.6 | 1.00 | 1 |
| 02/15/2014 19:00 | 17,445.3 | 4,294.3 | 21,739.6 | 21,739.6 | 102,258.0 | 2,223.0 | 1.00 | 1 |
| 02/15/2014 20:00 | 17,489.2 | 4,081.8 | 21,571.0 | 21,571.0 | 102,258.0 | 2,205.8 | 1.00 | 1 |
| 02/15/2014 21:00 | 17,524.7 | 4,170.6 | 21,695.3 | 21,695.3 | 102,258.0 | 2,218.5 | 1.00 | 1 |
| 02/15/2014 22:00 | 17,566.2 | 3,307.1 | 20,873.3 | 20,873.3 | 102,258.0 | 2,134.5 | 1.00 | 1 |
| 02/15/2014 23:00 | 17,233.4 | 1,754.4 | 18,987.8 | 18,987.8 | 102,258.0 | 1,941.7 | 1.00 | 1 |
| **Average/Sum#:** | 17,512.3 | 3,054.5 | 20,566.7 | 493,601.8 # | 102,258.0 | 2,103.1 | 24.00 # | 24 # |
| **Minimum:** | 17,215.5 | 1,754.4 | 18,987.8 | 18,987.8 | 102,258.0 | 1,941.7 | 1.00 | 1 |
| **Maximum:** | 17,685.7 | 4,414.1 | 21,960.5 | 21,960.5 | 102,258.0 | 2,245.6 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/16/2014 00:00 | 16,923.0 | 1,493.4 | 18,416.4 | 18,416.4 | 102,258.0 | 1,883.2 | 1.00 | 1 |
| 02/16/2014 01:00 | 17,010.2 | 1,483.9 | 18,494.1 | 18,494.1 | 102,258.0 | 1,891.2 | 1.00 | 1 |
| 02/16/2014 02:00 | 17,166.8 | 1,572.2 | 18,739.0 | 18,739.0 | 102,258.0 | 1,916.2 | 1.00 | 1 |
| 02/16/2014 03:00 | 16,155.1 | 1,060.1 | 16,918.4 | 16,918.4 | 102,258.0 | 1,730.0 | 1.00 | 1 |
| 02/16/2014 04:00 | 12,494.3 | 0.0 | 12,494.3 | 12,494.3 | 102,258.0 | 1,277.6 | 1.00 | 1 |
| 02/16/2014 05:00 | 14,460.1 | 0.0 | 14,460.1 | 14,460.1 | 102,258.0 | 1,478.7 | 1.00 | 1 |
| 02/16/2014 06:00 | 15,932.1 | 651.9 | 16,212.4 | 16,212.4 | 102,258.0 | 1,657.8 | 1.00 | 1 |
| 02/16/2014 07:00 | 17,805.5 | 1,606.3 | 19,411.8 | 19,411.8 | 102,258.0 | 1,985.0 | 1.00 | 1 |
| 02/16/2014 08:00 | 17,524.9 | 1,014.9 | 18,539.8 | 18,539.8 | 102,258.0 | 1,895.8 | 1.00 | 1 |
| 02/16/2014 09:00 | 17,311.2 | 842.3 | 18,153.5 | 18,153.5 | 102,258.0 | 1,856.3 | 1.00 | 1 |
| 02/16/2014 10:00 | 17,271.8 | 837.7 | 18,109.5 | 18,109.5 | 102,258.0 | 1,851.8 | 1.00 | 1 |
| 02/16/2014 11:00 | 17,265.5 | 824.0 | 18,089.5 | 18,089.5 | 102,258.0 | 1,849.8 | 1.00 | 1 |
| 02/16/2014 12:00 | 17,260.4 | 811.1 | 18,071.5 | 18,071.5 | 102,258.0 | 1,848.0 | 1.00 | 1 |
| 02/16/2014 13:00 | 17,151.6 | 811.6 | 17,963.2 | 17,963.2 | 102,258.0 | 1,836.9 | 1.00 | 1 |
| 02/16/2014 14:00 | 17,161.2 | 834.2 | 17,995.4 | 17,995.4 | 102,258.0 | 1,840.2 | 1.00 | 1 |
| 02/16/2014 15:00 | 17,312.2 | 843.9 | 18,156.1 | 18,156.1 | 102,258.0 | 1,856.6 | 1.00 | 1 |
| 02/16/2014 16:00 | 17,155.8 | 849.4 | 18,005.2 | 18,005.2 | 102,258.0 | 1,841.2 | 1.00 | 1 |
| 02/16/2014 17:00 | 17,143.5 | 889.0 | 18,032.5 | 18,032.5 | 102,258.0 | 1,844.0 | 1.00 | 1 |
| 02/16/2014 18:00 | 17,241.0 | 1,802.6 | 19,043.6 | 19,043.6 | 102,258.0 | 1,947.4 | 1.00 | 1 |
| 02/16/2014 19:00 | 17,586.6 | 4,142.2 | 21,728.8 | 21,728.8 | 102,258.0 | 2,221.9 | 1.00 | 1 |
| 02/16/2014 20:00 | 17,582.2 | 4,452.6 | 22,034.8 | 22,034.8 | 102,258.0 | 2,253.2 | 1.00 | 1 |
| 02/16/2014 21:00 | 17,632.7 | 4,423.4 | 22,056.1 | 22,056.1 | 102,258.0 | 2,255.4 | 1.00 | 1 |
| 02/16/2014 22:00 | 17,672.2 | 4,384.8 | 22,057.0 | 22,057.0 | 102,258.0 | 2,255.5 | 1.00 | 1 |
| 02/16/2014 23:00 | 17,615.6 | 2,442.6 | 20,058.2 | 20,058.2 | 102,258.0 | 2,051.1 | 1.00 | 1 |
| **Average/Sum#:** | 16,909.8 | 1,586.4 | 18,468.4 | 443,241.2 # | 102,258.0 | 1,888.5 | 24.00 # | 24 # |
| **Minimum:** | 12,494.3 | 0.0 | 12,494.3 | 12,494.3 | 102,258.0 | 1,277.6 | 1.00 | 1 |
| **Maximum:** | 17,805.5 | 4,452.6 | 22,057.0 | 22,057.0 | 102,258.0 | 2,255.5 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/17/2014 00:00 | 16,941.8 | 1,551.8 | 18,493.6 | 18,493.6 | 102,258.0 | 1,891.1 | 1.00 | 1 |
| 02/17/2014 01:00 | 16,812.1 | 1,550.8 | 18,362.9 | 18,362.9 | 102,258.0 | 1,877.8 | 1.00 | 1 |
| 02/17/2014 02:00 | 16,618.9 | 1,029.0 | 17,308.3 | 17,308.3 | 102,258.0 | 1,769.9 | 1.00 | 1 |
| 02/17/2014 03:00 | 12,713.8 | 0.0 | 12,713.8 | 12,713.8 | 102,258.0 | 1,300.1 | 1.00 | 1 |
| 02/17/2014 04:00 | 13,438.7 | 0.0 | 13,438.7 | 13,438.7 | 102,258.0 | 1,374.2 | 1.00 | 1 |
| 02/17/2014 05:00 | 15,212.9 | 1.4 | 15,213.0 | 15,213.0 | 102,258.0 | 1,555.7 | 1.00 | 1 |
| 02/17/2014 06:00 | 17,864.0 | 0.0 | 17,864.0 | 17,864.0 | 102,258.0 | 1,826.7 | 1.00 | 1 |
| 02/17/2014 07:00 | 17,915.4 | 0.0 | 17,915.4 | 17,915.4 | 102,258.0 | 1,832.0 | 1.00 | 1 |
| 02/17/2014 08:00 | 17,651.8 | 0.5 | 17,651.8 | 17,651.8 | 102,258.0 | 1,805.0 | 1.00 | 1 |
| 02/17/2014 09:00 | 17,275.1 | 139.9 | 17,291.9 | 17,291.9 | 102,258.0 | 1,768.2 | 1.00 | 1 |
| 02/17/2014 10:00 | 16,736.2 | 1,529.0 | 18,265.2 | 18,265.2 | 102,258.0 | 1,867.8 | 1.00 | 1 |
| 02/17/2014 11:00 | 16,731.3 | 1,515.6 | 18,246.9 | 18,246.9 | 102,258.0 | 1,865.9 | 1.00 | 1 |
| 02/17/2014 12:00 | 16,733.9 | 1,496.5 | 18,230.4 | 18,230.4 | 102,258.0 | 1,864.2 | 1.00 | 1 |
| 02/17/2014 13:00 | 16,700.2 | 1,498.0 | 18,198.2 | 18,198.2 | 102,258.0 | 1,860.9 | 1.00 | 1 |
| 02/17/2014 14:00 | 16,699.3 | 1,520.2 | 18,219.5 | 18,219.5 | 102,258.0 | 1,863.1 | 1.00 | 1 |
| 02/17/2014 15:00 | 16,754.4 | 1,525.5 | 18,279.9 | 18,279.9 | 102,258.0 | 1,869.3 | 1.00 | 1 |
| 02/17/2014 16:00 | 16,705.4 | 1,528.6 | 18,234.0 | 18,234.0 | 102,258.0 | 1,864.6 | 1.00 | 1 |
| 02/17/2014 17:00 | 16,693.4 | 1,529.2 | 18,222.6 | 18,222.6 | 102,258.0 | 1,863.4 | 1.00 | 1 |
| 02/17/2014 18:00 | 16,938.2 | 1,535.0 | 18,473.2 | 18,473.2 | 102,258.0 | 1,889.0 | 1.00 | 1 |
| 02/17/2014 19:00 | 17,281.1 | 1,565.8 | 18,846.9 | 18,846.9 | 102,258.0 | 1,927.2 | 1.00 | 1 |
| 02/17/2014 20:00 | 17,629.9 | 2,761.2 | 20,391.1 | 20,391.1 | 102,258.0 | 2,085.2 | 1.00 | 1 |
| 02/17/2014 21:00 | 17,671.1 | 3,942.2 | 21,613.3 | 21,613.3 | 102,258.0 | 2,210.1 | 1.00 | 1 |
| 02/17/2014 22:00 | 17,740.2 | 2,348.8 | 20,089.0 | 20,089.0 | 102,258.0 | 2,054.3 | 1.00 | 1 |
| 02/17/2014 23:00 | 17,164.3 | 1,619.4 | 18,783.7 | 18,783.7 | 102,258.0 | 1,920.8 | 1.00 | 1 |
| **Average/Sum#:** | 16,692.6 | 1,257.9 | 17,931.1 | 430,347.3 # | 102,258.0 | 1,833.6 | 24.00 # | 24 # |
| **Minimum:** | 12,713.8 | 0.0 | 12,713.8 | 12,713.8 | 102,258.0 | 1,300.1 | 1.00 | 1 |
| **Maximum:** | 17,915.4 | 3,942.2 | 21,613.3 | 21,613.3 | 102,258.0 | 2,210.1 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/18/2014 00:00 | 16,781.1 | 1,532.5 | 18,313.6 | 18,313.6 | 102,258.0 | 1,872.7 | 1.00 | 1 |
| 02/18/2014 01:00 | 16,758.3 | 1,532.4 | 18,290.7 | 18,290.7 | 102,258.0 | 1,870.4 | 1.00 | 1 |
| 02/18/2014 02:00 | 16,721.1 | 1,533.1 | 18,254.2 | 18,254.2 | 102,258.0 | 1,866.6 | 1.00 | 1 |
| 02/18/2014 03:00 | 16,725.5 | 1,533.0 | 18,258.5 | 18,258.5 | 102,258.0 | 1,867.1 | 1.00 | 1 |
| 02/18/2014 04:00 | 16,719.5 | 1,530.6 | 18,250.1 | 18,250.1 | 102,258.0 | 1,866.2 | 1.00 | 1 |
| 02/18/2014 05:00 | 16,718.9 | 1,534.7 | 18,253.6 | 18,253.6 | 102,258.0 | 1,866.6 | 1.00 | 1 |
| 02/18/2014 06:00 | 17,034.2 | 1,574.7 | 18,608.9 | 18,608.9 | 102,258.0 | 1,902.9 | 1.00 | 1 |
| 02/18/2014 07:00 | 17,715.5 | 2,415.9 | 20,131.4 | 20,131.4 | 102,258.0 | 2,058.6 | 1.00 | 1 |
| 02/18/2014 08:00 | 17,737.1 | 3,095.9 | 20,833.0 | 20,833.0 | 102,258.0 | 2,130.3 | 1.00 | 1 |
| 02/18/2014 09:00 | 17,635.8 | 1,827.4 | 19,463.2 | 19,463.2 | 102,258.0 | 1,990.3 | 1.00 | 1 |
| 02/18/2014 10:00 | 17,633.3 | 1,813.4 | 19,446.7 | 19,446.7 | 102,258.0 | 1,988.6 | 1.00 | 1 |
| 02/18/2014 11:00 | 17,436.6 | 2,451.2 | 19,887.8 | 19,887.8 | 102,258.0 | 2,033.7 | 1.00 | 1 |
| 02/18/2014 12:00 | 17,494.8 | 2,791.0 | 20,285.8 | 20,285.8 | 102,258.0 | 2,074.4 | 1.00 | 1 |
| 02/18/2014 13:00 | 17,359.9 | 2,072.7 | 19,432.6 | 19,432.6 | 102,258.0 | 1,987.1 | 1.00 | 1 |
| 02/18/2014 14:00 | 16,705.9 | 1,504.7 | 18,210.6 | 18,210.6 | 102,258.0 | 1,862.2 | 1.00 | 1 |
| 02/18/2014 15:00 | 16,862.1 | 1,543.5 | 18,405.6 | 18,405.6 | 102,258.0 | 1,882.1 | 1.00 | 1 |
| 02/18/2014 16:00 | 16,458.7 | 1,507.7 | 17,966.4 | 17,966.4 | 102,258.0 | 1,837.2 | 1.00 | 1 |
| 02/18/2014 17:00 | 17,070.6 | 2,178.9 | 19,249.5 | 19,249.5 | 102,258.0 | 1,968.4 | 1.00 | 1 |
| 02/18/2014 18:00 | 17,396.9 | 4,005.2 | 21,402.1 | 21,402.1 | 102,258.0 | 2,188.5 | 1.00 | 1 |
| 02/18/2014 19:00 | 17,448.1 | 4,491.0 | 21,939.1 | 21,939.1 | 102,258.0 | 2,243.4 | 1.00 | 1 |
| 02/18/2014 20:00 | 17,494.0 | 2,801.3 | 20,295.3 | 20,295.3 | 102,258.0 | 2,075.4 | 1.00 | 1 |
| 02/18/2014 21:00 | 17,463.5 | 4,139.3 | 21,602.8 | 21,602.8 | 102,258.0 | 2,209.1 | 1.00 | 1 |
| 02/18/2014 22:00 | 17,391.8 | 1,370.2 | 18,762.0 | 18,762.0 | 102,258.0 | 1,918.6 | 1.00 | 1 |
| 02/18/2014 23:00 | 15,087.5 | 414.4 | 15,307.1 | 15,307.1 | 102,258.0 | 1,565.3 | 1.00 | 1 |
| **Average/Sum#:** | 17,077.1 | 2,133.1 | 19,202.1 | 460,850.6 # | 102,258.0 | 1,963.6 | 24.00 # | 24 # |
| **Minimum:** | 15,087.5 | 414.4 | 15,307.1 | 15,307.1 | 102,258.0 | 1,565.3 | 1.00 | 1 |
| **Maximum:** | 17,737.1 | 4,491.0 | 21,939.1 | 21,939.1 | 102,258.0 | 2,243.4 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/19/2014 00:00 | 12,116.5 | 0.0 | 12,116.5 | 12,116.5 | 102,470.0 | 1,241.6 | 1.00 | 1 |
| 02/19/2014 01:00 | 13,683.4 | 0.0 | 13,683.4 | 13,683.4 | 102,470.0 | 1,402.1 | 1.00 | 1 |
| 02/19/2014 02:00 | 5,856.2 | 0.0 | 5,856.2 | 1,346.9 | 102,470.0 | 600.1 | 0.23 | 0 |
| 02/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 02/19/2014 17:00 | 5,177.7 | 0.0 | 5,177.7 | 3,986.8 | 102,470.0 | 530.6 | 0.77 | 0 |
| 02/19/2014 18:00 | 14,398.7 | 134.2 | 14,416.1 | 14,416.1 | 102,470.0 | 1,477.2 | 1.00 | 0 |
| 02/19/2014 19:00 | 17,454.3 | 1,635.7 | 19,090.0 | 19,090.0 | 102,470.0 | 1,956.2 | 1.00 | 1 |
| 02/19/2014 20:00 | 17,570.8 | 4,146.5 | 21,717.3 | 21,717.3 | 102,470.0 | 2,225.4 | 1.00 | 1 |
| 02/19/2014 21:00 | 17,595.1 | 4,662.1 | 22,257.2 | 22,257.2 | 102,470.0 | 2,280.7 | 1.00 | 1 |
| 02/19/2014 22:00 | 17,656.4 | 3,620.3 | 21,276.7 | 21,276.7 | 102,470.0 | 2,180.2 | 1.00 | 1 |
| 02/19/2014 23:00 | 17,394.9 | 1,071.8 | 18,466.7 | 18,466.7 | 102,470.0 | 1,892.3 | 1.00 | 1 |
| **Average/Sum#:** | 13,890.4 | 1,527.1 | 15,405.8 | 148,357.6 # | 102,470.0 | 1,578.6 | 9.00 # | 7 # |
| **Minimum:** | 5,177.7 | 0.0 | 5,177.7 | 1,346.9 | 102,470.0 | 530.6 | 0.00 | 0 |
| **Maximum:** | 17,656.4 | 4,662.1 | 22,257.2 | 22,257.2 | 102,470.0 | 2,280.7 | 1.00 | 1 |
| **%SI** | 58.3 | 58.3 | 58.3 | 58.3 | 0.0 | 58.3 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/20/2014 00:00 | 17,225.1 | 785.7 | 17,995.1 | 17,995.1 | 102,470.0 | 1,844.0 | 1.00 | 1 |
| 02/20/2014 01:00 | 12,382.1 | 0.0 | 12,382.1 | 12,382.1 | 102,470.0 | 1,268.8 | 1.00 | 1 |
| 02/20/2014 02:00 | 12,138.2 | 0.0 | 12,138.2 | 12,138.2 | 102,470.0 | 1,243.8 | 1.00 | 1 |
| 02/20/2014 03:00 | 12,130.5 | 0.0 | 12,130.5 | 12,130.5 | 102,470.0 | 1,243.0 | 1.00 | 1 |
| 02/20/2014 04:00 | 12,283.1 | 0.0 | 12,283.1 | 12,283.1 | 102,470.0 | 1,258.6 | 1.00 | 1 |
| 02/20/2014 05:00 | 12,792.1 | 0.0 | 12,792.1 | 12,792.1 | 102,470.0 | 1,310.8 | 1.00 | 1 |
| 02/20/2014 06:00 | 17,207.9 | 1,650.2 | 18,445.6 | 18,445.6 | 102,470.0 | 1,890.1 | 1.00 | 1 |
| 02/20/2014 07:00 | 17,857.9 | 2,475.7 | 20,333.6 | 20,333.6 | 102,470.0 | 2,083.6 | 1.00 | 1 |
| 02/20/2014 08:00 | 17,859.7 | 2,912.8 | 20,626.9 | 20,626.9 | 102,470.0 | 2,113.6 | 1.00 | 1 |
| 02/20/2014 09:00 | 17,009.7 | 1,542.8 | 18,552.5 | 18,552.5 | 102,470.0 | 1,901.1 | 1.00 | 1 |
| 02/20/2014 10:00 | 16,641.4 | 1,495.1 | 18,136.5 | 18,136.5 | 102,470.0 | 1,858.4 | 1.00 | 1 |
| 02/20/2014 11:00 | 16,638.7 | 1,472.4 | 18,111.1 | 18,111.1 | 102,470.0 | 1,855.8 | 1.00 | 1 |
| 02/20/2014 12:00 | 16,667.8 | 1,454.2 | 18,122.0 | 18,122.0 | 102,470.0 | 1,857.0 | 1.00 | 1 |
| 02/20/2014 13:00 | 17,387.5 | 1,776.5 | 19,164.0 | 19,164.0 | 102,470.0 | 1,963.7 | 1.00 | 1 |
| 02/20/2014 14:00 | 16,769.5 | 1,469.0 | 18,238.5 | 18,238.5 | 102,470.0 | 1,868.9 | 1.00 | 1 |
| 02/20/2014 15:00 | 17,138.6 | 1,958.3 | 19,096.9 | 19,096.9 | 102,470.0 | 1,956.9 | 1.00 | 1 |
| 02/20/2014 16:00 | 17,220.9 | 3,218.8 | 20,439.7 | 20,439.7 | 102,470.0 | 2,094.5 | 1.00 | 1 |
| 02/20/2014 17:00 | 17,220.3 | 4,201.4 | 21,421.7 | 21,421.7 | 102,470.0 | 2,195.1 | 1.00 | 1 |
| 02/20/2014 18:00 | 17,241.2 | 3,630.6 | 20,871.8 | 20,871.8 | 102,470.0 | 2,138.7 | 1.00 | 1 |
| 02/20/2014 19:00 | 17,309.8 | 4,179.4 | 21,489.2 | 21,489.2 | 102,470.0 | 2,202.0 | 1.00 | 1 |
| 02/20/2014 20:00 | 17,341.4 | 4,299.8 | 21,641.2 | 21,641.2 | 102,470.0 | 2,217.6 | 1.00 | 1 |
| 02/20/2014 21:00 | 17,377.5 | 4,178.1 | 21,555.6 | 21,555.6 | 102,470.0 | 2,208.8 | 1.00 | 1 |
| 02/20/2014 22:00 | 17,403.2 | 4,206.3 | 21,609.5 | 21,609.5 | 102,470.0 | 2,214.3 | 1.00 | 1 |
| 02/20/2014 23:00 | 17,403.6 | 3,768.8 | 21,172.4 | 21,172.4 | 102,470.0 | 2,169.5 | 1.00 | 1 |
| **Average/Sum#:** | 16,193.7 | 2,111.5 | 18,281.2 | 438,749.8 # | 102,470.0 | 1,873.3 | 24.00 # | 24 # |
| **Minimum:** | 12,130.5 | 0.0 | 12,130.5 | 12,130.5 | 102,470.0 | 1,243.0 | 1.00 | 1 |
| **Maximum:** | 17,859.7 | 4,299.8 | 21,641.2 | 21,641.2 | 102,470.0 | 2,217.6 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/21/2014 00:00 | 17,422.6 | 2,645.7 | 20,068.3 | 20,068.3 | 102,470.0 | 2,056.4 | 1.00 | 1 |
| 02/21/2014 01:00 | 17,333.9 | 1,033.8 | 18,367.7 | 18,367.7 | 102,470.0 | 1,882.1 | 1.00 | 1 |
| 02/21/2014 02:00 | 17,127.1 | 829.3 | 17,956.4 | 17,956.4 | 102,470.0 | 1,840.0 | 1.00 | 1 |
| 02/21/2014 03:00 | 17,144.1 | 831.8 | 17,975.9 | 17,975.9 | 102,470.0 | 1,842.0 | 1.00 | 1 |
| 02/21/2014 04:00 | 17,140.2 | 830.1 | 17,970.3 | 17,970.3 | 102,470.0 | 1,841.4 | 1.00 | 1 |
| 02/21/2014 05:00 | 17,148.9 | 825.2 | 17,974.1 | 17,974.1 | 102,470.0 | 1,841.8 | 1.00 | 1 |
| 02/21/2014 06:00 | 17,322.2 | 829.8 | 18,152.0 | 18,152.0 | 102,470.0 | 1,860.0 | 1.00 | 1 |
| 02/21/2014 07:00 | 17,628.0 | 1,928.8 | 19,556.8 | 19,556.8 | 102,470.0 | 2,004.0 | 1.00 | 1 |
| 02/21/2014 08:00 | 17,605.2 | 3,582.7 | 21,187.9 | 21,187.9 | 102,470.0 | 2,171.1 | 1.00 | 1 |
| 02/21/2014 09:00 | 17,555.9 | 1,388.0 | 18,943.9 | 18,943.9 | 102,470.0 | 1,941.2 | 1.00 | 1 |
| 02/21/2014 10:00 | 17,178.5 | 828.1 | 18,006.6 | 18,006.6 | 102,470.0 | 1,845.1 | 1.00 | 1 |
| 02/21/2014 11:00 | 17,255.9 | 898.5 | 18,154.4 | 18,154.4 | 102,470.0 | 1,860.3 | 1.00 | 1 |
| 02/21/2014 12:00 | 17,246.8 | 796.0 | 18,042.8 | 18,042.8 | 102,470.0 | 1,848.8 | 1.00 | 1 |
| 02/21/2014 13:00 | 17,219.3 | 780.7 | 18,000.0 | 18,000.0 | 102,470.0 | 1,844.5 | 1.00 | 1 |
| 02/21/2014 14:00 | 17,160.3 | 796.8 | 17,957.1 | 17,957.1 | 102,470.0 | 1,840.1 | 1.00 | 1 |
| 02/21/2014 15:00 | 17,075.8 | 825.8 | 17,901.6 | 17,901.6 | 102,470.0 | 1,834.4 | 1.00 | 1 |
| 02/21/2014 16:00 | 17,032.3 | 826.8 | 17,859.1 | 17,859.1 | 102,470.0 | 1,830.0 | 1.00 | 1 |
| 02/21/2014 17:00 | 17,023.9 | 969.6 | 17,993.5 | 17,993.5 | 102,470.0 | 1,843.8 | 1.00 | 1 |
| 02/21/2014 18:00 | 17,089.9 | 2,399.6 | 19,489.5 | 19,489.5 | 102,470.0 | 1,997.1 | 1.00 | 1 |
| 02/21/2014 19:00 | 17,190.9 | 3,314.4 | 20,505.3 | 20,505.3 | 102,470.0 | 2,101.2 | 1.00 | 1 |
| 02/21/2014 20:00 | 17,195.3 | 3,548.8 | 20,744.1 | 20,744.1 | 102,470.0 | 2,125.6 | 1.00 | 1 |
| 02/21/2014 21:00 | 17,266.1 | 3,973.4 | 21,239.5 | 21,239.5 | 102,470.0 | 2,176.4 | 1.00 | 1 |
| 02/21/2014 22:00 | 17,236.5 | 3,418.0 | 20,654.5 | 20,654.5 | 102,470.0 | 2,116.5 | 1.00 | 1 |
| 02/21/2014 23:00 | 17,245.9 | 2,887.1 | 20,133.0 | 20,133.0 | 102,470.0 | 2,063.0 | 1.00 | 1 |
| **Average/Sum#:** | 17,243.6 | 1,707.9 | 18,951.4 | 454,834.3 # | 102,470.0 | 1,942.0 | 24.00 # | 24 # |
| **Minimum:** | 17,023.9 | 780.7 | 17,859.1 | 17,859.1 | 102,470.0 | 1,830.0 | 1.00 | 1 |
| **Maximum:** | 17,628.0 | 3,973.4 | 21,239.5 | 21,239.5 | 102,470.0 | 2,176.4 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/22/2014 00:00 | 17,263.1 | 2,682.4 | 19,945.5 | 19,945.5 | 102,470.0 | 2,043.8 | 1.00 | 1 |
| 02/22/2014 01:00 | 17,270.0 | 2,244.2 | 19,514.2 | 19,514.2 | 102,470.0 | 1,999.6 | 1.00 | 1 |
| 02/22/2014 02:00 | 16,677.1 | 1,533.9 | 18,211.0 | 18,211.0 | 102,470.0 | 1,866.1 | 1.00 | 1 |
| 02/22/2014 03:00 | 17,266.0 | 2,061.3 | 19,327.3 | 19,327.3 | 102,470.0 | 1,980.5 | 1.00 | 1 |
| 02/22/2014 04:00 | 17,417.0 | 2,113.3 | 19,530.3 | 19,530.3 | 102,470.0 | 2,001.3 | 1.00 | 1 |
| 02/22/2014 05:00 | 17,232.2 | 1,644.5 | 18,876.7 | 18,876.7 | 102,470.0 | 1,934.3 | 1.00 | 1 |
| 02/22/2014 06:00 | 17,672.1 | 2,109.1 | 19,781.2 | 19,781.2 | 102,470.0 | 2,027.0 | 1.00 | 1 |
| 02/22/2014 07:00 | 17,727.7 | 2,121.8 | 19,849.5 | 19,849.5 | 102,470.0 | 2,034.0 | 1.00 | 1 |
| 02/22/2014 08:00 | 17,598.1 | 2,049.9 | 19,648.0 | 19,648.0 | 102,470.0 | 2,013.3 | 1.00 | 1 |
| 02/22/2014 09:00 | 16,961.8 | 1,556.6 | 18,518.4 | 18,518.4 | 102,470.0 | 1,897.6 | 1.00 | 1 |
| 02/22/2014 10:00 | 16,762.9 | 1,517.5 | 18,280.4 | 18,280.4 | 102,470.0 | 1,873.2 | 1.00 | 1 |
| 02/22/2014 11:00 | 16,776.6 | 1,492.3 | 18,268.9 | 18,268.9 | 102,470.0 | 1,872.0 | 1.00 | 1 |
| 02/22/2014 12:00 | 16,864.3 | 1,459.8 | 18,324.1 | 18,324.1 | 102,470.0 | 1,877.7 | 1.00 | 1 |
| 02/22/2014 13:00 | 16,767.8 | 1,447.1 | 18,214.9 | 18,214.9 | 102,470.0 | 1,866.5 | 1.00 | 1 |
| 02/22/2014 14:00 | 16,982.6 | 2,006.5 | 18,989.1 | 18,989.1 | 102,470.0 | 1,945.8 | 1.00 | 1 |
| 02/22/2014 15:00 | 16,929.7 | 2,404.9 | 19,334.6 | 19,334.6 | 102,470.0 | 1,981.2 | 1.00 | 1 |
| 02/22/2014 16:00 | 16,789.9 | 1,712.4 | 18,502.3 | 18,502.3 | 102,470.0 | 1,895.9 | 1.00 | 1 |
| 02/22/2014 17:00 | 16,788.4 | 2,672.7 | 19,461.1 | 19,461.1 | 102,470.0 | 1,994.2 | 1.00 | 1 |
| 02/22/2014 18:00 | 16,877.4 | 3,038.8 | 19,916.2 | 19,916.2 | 102,470.0 | 2,040.8 | 1.00 | 1 |
| 02/22/2014 19:00 | 16,971.0 | 3,166.9 | 20,137.9 | 20,137.9 | 102,470.0 | 2,063.5 | 1.00 | 1 |
| 02/22/2014 20:00 | 17,028.5 | 4,104.8 | 21,133.3 | 21,133.3 | 102,470.0 | 2,165.5 | 1.00 | 1 |
| 02/22/2014 21:00 | 17,073.2 | 4,245.7 | 21,318.9 | 21,318.9 | 102,470.0 | 2,184.5 | 1.00 | 1 |
| 02/22/2014 22:00 | 17,093.8 | 4,273.9 | 21,367.7 | 21,367.7 | 102,470.0 | 2,189.5 | 1.00 | 1 |
| 02/22/2014 23:00 | 17,203.7 | 4,265.6 | 21,469.3 | 21,469.3 | 102,470.0 | 2,200.0 | 1.00 | 1 |
| **Average/Sum#:** | 17,083.1 | 2,413.6 | 19,496.7 | 467,920.8 # | 102,470.0 | 1,997.8 | 24.00 # | 24 # |
| **Minimum:** | 16,677.1 | 1,447.1 | 18,211.0 | 18,211.0 | 102,470.0 | 1,866.1 | 1.00 | 1 |
| **Maximum:** | 17,727.7 | 4,273.9 | 21,469.3 | 21,469.3 | 102,470.0 | 2,200.0 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/23/2014 00:00 | 17,597.7 | 3,751.7 | 21,349.4 | 21,349.4 | 102,470.0 | 2,187.7 | 1.00 | 1 |
| 02/23/2014 01:00 | 17,516.8 | 3,309.9 | 20,826.7 | 20,826.7 | 102,470.0 | 2,134.1 | 1.00 | 1 |
| 02/23/2014 02:00 | 17,481.9 | 3,988.8 | 21,470.7 | 21,470.7 | 102,470.0 | 2,200.1 | 1.00 | 1 |
| 02/23/2014 03:00 | 17,528.2 | 4,045.1 | 21,573.3 | 21,573.3 | 102,470.0 | 2,210.6 | 1.00 | 1 |
| 02/23/2014 04:00 | 17,578.6 | 3,034.0 | 20,612.6 | 20,612.6 | 102,470.0 | 2,112.2 | 1.00 | 1 |
| 02/23/2014 05:00 | 17,600.9 | 2,162.9 | 19,763.8 | 19,763.8 | 102,470.0 | 2,025.2 | 1.00 | 1 |
| 02/23/2014 06:00 | 17,608.2 | 2,284.7 | 19,892.9 | 19,892.9 | 102,470.0 | 2,038.4 | 1.00 | 1 |
| 02/23/2014 07:00 | 17,615.0 | 1,935.2 | 19,550.2 | 19,550.2 | 102,470.0 | 2,003.3 | 1.00 | 1 |
| 02/23/2014 08:00 | 17,661.7 | 1,734.5 | 19,396.2 | 19,396.2 | 102,470.0 | 1,987.5 | 1.00 | 1 |
| 02/23/2014 09:00 | 17,562.2 | 1,673.6 | 19,235.8 | 19,235.8 | 102,470.0 | 1,971.1 | 1.00 | 1 |
| 02/23/2014 10:00 | 16,856.2 | 1,209.7 | 18,065.9 | 18,065.9 | 102,470.0 | 1,851.2 | 1.00 | 1 |
| 02/23/2014 11:00 | 17,121.9 | 1,333.7 | 18,455.6 | 18,455.6 | 102,470.0 | 1,891.1 | 1.00 | 1 |
| 02/23/2014 12:00 | 17,217.4 | 1,467.2 | 18,684.6 | 18,684.6 | 102,470.0 | 1,914.6 | 1.00 | 1 |
| 02/23/2014 13:00 | 16,990.2 | 1,160.2 | 18,150.4 | 18,150.4 | 102,470.0 | 1,859.9 | 1.00 | 1 |
| 02/23/2014 14:00 | 16,906.6 | 1,187.9 | 18,094.5 | 18,094.5 | 102,470.0 | 1,854.1 | 1.00 | 1 |
| 02/23/2014 15:00 | 16,906.8 | 1,284.0 | 18,190.8 | 18,190.8 | 102,470.0 | 1,864.0 | 1.00 | 1 |
| 02/23/2014 16:00 | 16,884.3 | 1,519.5 | 18,403.8 | 18,403.8 | 102,470.0 | 1,885.8 | 1.00 | 1 |
| 02/23/2014 17:00 | 16,892.5 | 1,896.7 | 18,789.2 | 18,789.2 | 102,470.0 | 1,925.3 | 1.00 | 1 |
| 02/23/2014 18:00 | 16,951.6 | 3,324.3 | 20,275.9 | 20,275.9 | 102,470.0 | 2,077.7 | 1.00 | 1 |
| 02/23/2014 19:00 | 17,031.3 | 4,016.4 | 21,047.7 | 21,047.7 | 102,470.0 | 2,156.8 | 1.00 | 1 |
| 02/23/2014 20:00 | 17,078.4 | 3,882.3 | 20,960.7 | 20,960.7 | 102,470.0 | 2,147.8 | 1.00 | 1 |
| 02/23/2014 21:00 | 17,114.1 | 3,850.6 | 20,964.7 | 20,964.7 | 102,470.0 | 2,148.3 | 1.00 | 1 |
| 02/23/2014 22:00 | 17,161.2 | 3,810.4 | 20,971.6 | 20,971.6 | 102,470.0 | 2,149.0 | 1.00 | 1 |
| 02/23/2014 23:00 | 17,234.7 | 3,580.9 | 20,815.6 | 20,815.6 | 102,470.0 | 2,133.0 | 1.00 | 1 |
| **Average/Sum#:** | 17,254.1 | 2,560.2 | 19,814.3 | 475,542.6 # | 102,470.0 | 2,030.4 | 24.00 # | 24 # |
| **Minimum:** | 16,856.2 | 1,160.2 | 18,065.9 | 18,065.9 | 102,470.0 | 1,851.2 | 1.00 | 1 |
| **Maximum:** | 17,661.7 | 4,045.1 | 21,573.3 | 21,573.3 | 102,470.0 | 2,210.6 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/24/2014 00:00 | 17,541.5 | 1,968.7 | 19,510.2 | 19,510.2 | 102,470.0 | 1,999.2 | 1.00 | 1 |
| 02/24/2014 01:00 | 16,854.0 | 1,216.8 | 18,070.8 | 18,070.8 | 102,470.0 | 1,851.7 | 1.00 | 1 |
| 02/24/2014 02:00 | 16,697.4 | 1,007.8 | 17,533.9 | 17,533.9 | 102,470.0 | 1,796.7 | 1.00 | 1 |
| 02/24/2014 03:00 | 12,243.8 | 0.0 | 12,243.8 | 12,243.8 | 102,470.0 | 1,254.6 | 1.00 | 1 |
| 02/24/2014 04:00 | 12,010.9 | 0.0 | 12,010.9 | 12,010.9 | 102,470.0 | 1,230.8 | 1.00 | 1 |
| 02/24/2014 05:00 | 14,674.3 | 578.9 | 14,905.9 | 14,905.9 | 102,470.0 | 1,527.4 | 1.00 | 1 |
| 02/24/2014 06:00 | 17,029.9 | 1,469.2 | 18,499.1 | 18,499.1 | 102,470.0 | 1,895.6 | 1.00 | 1 |
| 02/24/2014 07:00 | 17,577.2 | 1,480.2 | 19,057.4 | 19,057.4 | 102,470.0 | 1,952.8 | 1.00 | 1 |
| 02/24/2014 08:00 | 17,728.7 | 2,601.5 | 20,330.2 | 20,330.2 | 102,470.0 | 2,083.2 | 1.00 | 1 |
| 02/24/2014 09:00 | 17,519.5 | 1,425.6 | 18,945.1 | 18,945.1 | 102,470.0 | 1,941.3 | 1.00 | 1 |
| 02/24/2014 10:00 | 17,035.1 | 823.5 | 17,858.6 | 17,858.6 | 102,470.0 | 1,830.0 | 1.00 | 1 |
| 02/24/2014 11:00 | 17,212.9 | 901.1 | 18,114.0 | 18,114.0 | 102,470.0 | 1,856.1 | 1.00 | 1 |
| 02/24/2014 12:00 | 17,041.0 | 806.2 | 17,847.2 | 17,847.2 | 102,470.0 | 1,828.8 | 1.00 | 1 |
| 02/24/2014 13:00 | 17,066.3 | 802.2 | 17,868.5 | 17,868.5 | 102,470.0 | 1,831.0 | 1.00 | 1 |
| 02/24/2014 14:00 | 16,917.0 | 895.2 | 17,812.2 | 17,812.2 | 102,470.0 | 1,825.2 | 1.00 | 1 |
| 02/24/2014 15:00 | 16,849.3 | 2,400.5 | 19,249.8 | 19,249.8 | 102,470.0 | 1,972.5 | 1.00 | 1 |
| 02/24/2014 16:00 | 16,828.3 | 2,356.5 | 19,184.8 | 19,184.8 | 102,470.0 | 1,965.9 | 1.00 | 1 |
| 02/24/2014 17:00 | 16,816.8 | 3,086.4 | 19,903.2 | 19,903.2 | 102,470.0 | 2,039.5 | 1.00 | 1 |
| 02/24/2014 18:00 | 16,846.1 | 3,776.2 | 20,622.3 | 20,622.3 | 102,470.0 | 2,113.2 | 1.00 | 1 |
| 02/24/2014 19:00 | 16,951.0 | 4,266.2 | 21,217.2 | 21,217.2 | 102,470.0 | 2,174.1 | 1.00 | 1 |
| 02/24/2014 20:00 | 16,983.4 | 4,057.9 | 21,041.3 | 21,041.3 | 102,470.0 | 2,156.1 | 1.00 | 1 |
| 02/24/2014 21:00 | 17,043.8 | 3,867.4 | 20,911.2 | 20,911.2 | 102,470.0 | 2,142.8 | 1.00 | 1 |
| 02/24/2014 22:00 | 17,138.8 | 3,785.4 | 20,924.2 | 20,924.2 | 102,470.0 | 2,144.1 | 1.00 | 1 |
| 02/24/2014 23:00 | 17,212.6 | 3,805.1 | 21,017.7 | 21,017.7 | 102,470.0 | 2,153.7 | 1.00 | 1 |
| **Average/Sum#:** | 16,575.8 | 1,974.1 | 18,528.3 | 444,679.5 # | 102,470.0 | 1,898.6 | 24.00 # | 24 # |
| **Minimum:** | 12,010.9 | 0.0 | 12,010.9 | 12,010.9 | 102,470.0 | 1,230.8 | 1.00 | 1 |
| **Maximum:** | 17,728.7 | 4,266.2 | 21,217.2 | 21,217.2 | 102,470.0 | 2,174.1 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/25/2014 00:00 | 17,506.3 | 2,400.5 | 19,906.8 | 19,906.8 | 102,470.0 | 2,039.8 | 1.00 | 1 |
| 02/25/2014 01:00 | 17,439.9 | 1,795.7 | 19,235.6 | 19,235.6 | 102,470.0 | 1,971.1 | 1.00 | 1 |
| 02/25/2014 02:00 | 16,693.6 | 1,377.2 | 18,070.8 | 18,070.8 | 102,470.0 | 1,851.7 | 1.00 | 1 |
| 02/25/2014 03:00 | 16,618.3 | 1,374.9 | 17,993.2 | 17,993.2 | 102,470.0 | 1,843.8 | 1.00 | 1 |
| 02/25/2014 04:00 | 16,646.7 | 1,372.2 | 18,018.9 | 18,018.9 | 102,470.0 | 1,846.4 | 1.00 | 1 |
| 02/25/2014 05:00 | 17,372.2 | 2,109.6 | 19,481.8 | 19,481.8 | 102,470.0 | 1,996.3 | 1.00 | 1 |
| 02/25/2014 06:00 | 17,406.6 | 2,330.2 | 19,736.8 | 19,736.8 | 102,470.0 | 2,022.4 | 1.00 | 1 |
| 02/25/2014 07:00 | 17,302.9 | 1,759.6 | 19,062.5 | 19,062.5 | 102,470.0 | 1,953.3 | 1.00 | 1 |
| 02/25/2014 08:00 | 17,426.9 | 2,136.8 | 19,563.7 | 19,563.7 | 102,470.0 | 2,004.7 | 1.00 | 1 |
| 02/25/2014 09:00 | 16,703.5 | 1,333.1 | 18,036.6 | 18,036.6 | 102,470.0 | 1,848.2 | 1.00 | 1 |
| 02/25/2014 10:00 | 16,786.0 | 1,129.2 | 17,915.2 | 17,915.2 | 102,470.0 | 1,835.8 | 1.00 | 1 |
| 02/25/2014 11:00 | 16,993.2 | 814.5 | 17,807.7 | 17,807.7 | 102,470.0 | 1,824.8 | 1.00 | 1 |
| 02/25/2014 12:00 | 17,039.9 | 800.7 | 17,840.6 | 17,840.6 | 102,470.0 | 1,828.1 | 1.00 | 1 |
| 02/25/2014 13:00 | 17,123.1 | 846.5 | 17,969.6 | 17,969.6 | 102,470.0 | 1,841.3 | 1.00 | 1 |
| 02/25/2014 14:00 | 17,025.3 | 788.7 | 17,814.0 | 17,814.0 | 102,470.0 | 1,825.4 | 1.00 | 1 |
| 02/25/2014 15:00 | 17,062.0 | 782.4 | 17,844.4 | 17,844.4 | 102,470.0 | 1,828.5 | 1.00 | 1 |
| 02/25/2014 16:00 | 17,056.2 | 1,223.7 | 18,279.9 | 18,279.9 | 102,470.0 | 1,873.1 | 1.00 | 1 |
| 02/25/2014 17:00 | 16,939.4 | 1,167.4 | 18,106.8 | 18,106.8 | 102,470.0 | 1,855.4 | 1.00 | 1 |
| 02/25/2014 18:00 | 17,169.4 | 1,956.6 | 19,126.0 | 19,126.0 | 102,470.0 | 1,959.8 | 1.00 | 1 |
| 02/25/2014 19:00 | 17,328.3 | 3,165.4 | 20,493.7 | 20,493.7 | 102,470.0 | 2,100.0 | 1.00 | 1 |
| 02/25/2014 20:00 | 17,346.1 | 3,439.3 | 20,785.4 | 20,785.4 | 102,470.0 | 2,129.9 | 1.00 | 1 |
| 02/25/2014 21:00 | 17,384.0 | 2,657.6 | 20,041.6 | 20,041.6 | 102,470.0 | 2,053.7 | 1.00 | 1 |
| 02/25/2014 22:00 | 17,307.6 | 1,721.1 | 19,028.7 | 19,028.7 | 102,470.0 | 1,949.9 | 1.00 | 1 |
| 02/25/2014 23:00 | 17,451.6 | 3,216.8 | 20,668.4 | 20,668.4 | 102,470.0 | 2,117.9 | 1.00 | 1 |
| **Average/Sum#:** | 17,130.4 | 1,737.5 | 18,867.9 | 452,828.7 # | 102,470.0 | 1,933.4 | 24.00 # | 24 # |
| **Minimum:** | 16,618.3 | 782.4 | 17,807.7 | 17,807.7 | 102,470.0 | 1,824.8 | 1.00 | 1 |
| **Maximum:** | 17,506.3 | 3,439.3 | 20,785.4 | 20,785.4 | 102,470.0 | 2,129.9 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/26/2014 00:00 | 17,223.6 | 1,726.6 | 18,950.2 | 18,950.2 | 102,470.0 | 1,941.8 | 1.00 | 1 |
| 02/26/2014 01:00 | 16,869.4 | 1,491.8 | 18,361.2 | 18,361.2 | 102,470.0 | 1,881.5 | 1.00 | 1 |
| 02/26/2014 02:00 | 16,752.9 | 1,480.8 | 18,233.7 | 18,233.7 | 102,470.0 | 1,868.4 | 1.00 | 1 |
| 02/26/2014 03:00 | 16,729.5 | 1,477.7 | 18,207.2 | 18,207.2 | 102,470.0 | 1,865.7 | 1.00 | 1 |
| 02/26/2014 04:00 | 16,680.0 | 1,481.5 | 18,161.5 | 18,161.5 | 102,470.0 | 1,861.0 | 1.00 | 1 |
| 02/26/2014 05:00 | 16,976.7 | 1,570.3 | 18,547.0 | 18,547.0 | 102,470.0 | 1,900.5 | 1.00 | 1 |
| 02/26/2014 06:00 | 17,551.0 | 2,706.1 | 20,257.1 | 20,257.1 | 102,470.0 | 2,075.7 | 1.00 | 1 |
| 02/26/2014 07:00 | 17,677.4 | 3,364.9 | 21,042.3 | 21,042.3 | 102,470.0 | 2,156.2 | 1.00 | 1 |
| 02/26/2014 08:00 | 17,645.6 | 4,082.8 | 21,728.4 | 21,728.4 | 102,470.0 | 2,226.5 | 1.00 | 1 |
| 02/26/2014 09:00 | 17,719.8 | 4,070.3 | 21,790.1 | 21,790.1 | 102,470.0 | 2,232.8 | 1.00 | 1 |
| 02/26/2014 10:00 | 17,689.2 | 4,155.5 | 21,844.7 | 21,844.7 | 102,470.0 | 2,238.4 | 1.00 | 1 |
| 02/26/2014 11:00 | 17,637.0 | 3,773.3 | 21,297.1 | 21,297.1 | 102,470.0 | 2,182.3 | 1.00 | 1 |
| 02/26/2014 12:00 | 17,656.8 | 2,696.0 | 19,894.5 | 19,894.5 | 102,470.0 | 2,038.6 | 1.00 | 1 |
| 02/26/2014 13:00 | 17,613.5 | 3,591.8 | 21,205.3 | 21,205.3 | 102,470.0 | 2,172.9 | 1.00 | 1 |
| 02/26/2014 14:00 | 17,547.3 | 2,976.3 | 20,523.6 | 20,523.6 | 102,470.0 | 2,103.1 | 1.00 | 1 |
| 02/26/2014 15:00 | 17,541.8 | 2,812.8 | 20,354.6 | 20,354.6 | 102,470.0 | 2,085.7 | 1.00 | 1 |
| 02/26/2014 16:00 | 17,532.3 | 2,240.9 | 19,773.2 | 19,773.2 | 102,470.0 | 2,026.2 | 1.00 | 1 |
| 02/26/2014 17:00 | 17,551.9 | 3,236.6 | 20,788.5 | 20,788.5 | 102,470.0 | 2,130.2 | 1.00 | 1 |
| 02/26/2014 18:00 | 17,546.2 | 3,520.5 | 21,066.7 | 21,066.7 | 102,470.0 | 2,158.7 | 1.00 | 1 |
| 02/26/2014 19:00 | 17,518.9 | 4,212.6 | 21,731.5 | 21,731.5 | 102,470.0 | 2,226.8 | 1.00 | 1 |
| 02/26/2014 20:00 | 17,456.2 | 4,149.0 | 21,605.2 | 21,605.2 | 102,470.0 | 2,213.9 | 1.00 | 1 |
| 02/26/2014 21:00 | 17,458.6 | 3,987.7 | 21,446.3 | 21,446.3 | 102,470.0 | 2,197.6 | 1.00 | 1 |
| 02/26/2014 22:00 | 17,444.7 | 3,815.3 | 21,260.0 | 21,260.0 | 102,470.0 | 2,178.5 | 1.00 | 1 |
| 02/26/2014 23:00 | 17,417.3 | 3,419.4 | 20,836.7 | 20,836.7 | 102,470.0 | 2,135.1 | 1.00 | 1 |
| **Average/Sum#:** | 17,393.2 | 3,001.7 | 20,371.1 | 488,906.6 # | 102,470.0 | 2,087.4 | 24.00 # | 24 # |
| **Minimum:** | 16,680.0 | 1,477.7 | 18,161.5 | 18,161.5 | 102,470.0 | 1,861.0 | 1.00 | 1 |
| **Maximum:** | 17,719.8 | 4,212.6 | 21,844.7 | 21,844.7 | 102,470.0 | 2,238.4 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/27/2014 00:00 | 17,434.8 | 2,097.6 | 19,532.4 | 19,532.4 | 102,470.0 | 2,001.5 | 1.00 | 1 |
| 02/27/2014 01:00 | 16,909.0 | 1,472.7 | 18,381.7 | 18,381.7 | 102,470.0 | 1,883.6 | 1.00 | 1 |
| 02/27/2014 02:00 | 15,102.5 | 528.3 | 15,298.0 | 15,298.0 | 102,470.0 | 1,567.6 | 1.00 | 1 |
| 02/27/2014 03:00 | 12,527.4 | 0.0 | 12,527.4 | 12,527.4 | 102,470.0 | 1,283.7 | 1.00 | 1 |
| 02/27/2014 04:00 | 15,293.7 | 0.0 | 15,293.7 | 15,293.7 | 102,470.0 | 1,567.1 | 1.00 | 1 |
| 02/27/2014 05:00 | 16,437.5 | 811.0 | 16,826.8 | 16,826.8 | 102,470.0 | 1,724.2 | 1.00 | 1 |
| 02/27/2014 06:00 | 17,144.7 | 1,544.3 | 18,689.0 | 18,689.0 | 102,470.0 | 1,915.1 | 1.00 | 1 |
| 02/27/2014 07:00 | 17,244.7 | 1,181.9 | 18,426.6 | 18,426.6 | 102,470.0 | 1,888.2 | 1.00 | 1 |
| 02/27/2014 08:00 | 17,585.0 | 2,375.2 | 19,960.2 | 19,960.2 | 102,470.0 | 2,045.3 | 1.00 | 1 |
| 02/27/2014 09:00 | 17,272.6 | 922.0 | 18,166.9 | 18,166.9 | 102,470.0 | 1,861.6 | 1.00 | 1 |
| 02/27/2014 10:00 | 17,227.9 | 805.5 | 18,033.4 | 18,033.4 | 102,470.0 | 1,847.9 | 1.00 | 1 |
| 02/27/2014 11:00 | 17,204.7 | 798.4 | 18,003.1 | 18,003.1 | 102,470.0 | 1,844.8 | 1.00 | 1 |
| 02/27/2014 12:00 | 17,135.3 | 876.6 | 18,011.9 | 18,011.9 | 102,470.0 | 1,845.7 | 1.00 | 1 |
| 02/27/2014 13:00 | 17,099.7 | 937.9 | 18,037.6 | 18,037.6 | 102,470.0 | 1,848.3 | 1.00 | 1 |
| 02/27/2014 14:00 | 17,065.9 | 938.7 | 18,004.6 | 18,004.6 | 102,470.0 | 1,844.9 | 1.00 | 1 |
| 02/27/2014 15:00 | 17,083.3 | 939.7 | 18,023.0 | 18,023.0 | 102,470.0 | 1,846.8 | 1.00 | 1 |
| 02/27/2014 16:00 | 17,090.8 | 941.3 | 18,032.1 | 18,032.1 | 102,470.0 | 1,847.7 | 1.00 | 1 |
| 02/27/2014 17:00 | 17,292.9 | 1,332.2 | 18,625.1 | 18,625.1 | 102,470.0 | 1,908.5 | 1.00 | 1 |
| 02/27/2014 18:00 | 17,005.6 | 1,661.4 | 18,667.0 | 18,667.0 | 102,470.0 | 1,912.8 | 1.00 | 1 |
| 02/27/2014 19:00 | 17,352.6 | 2,967.3 | 20,319.9 | 20,319.9 | 102,470.0 | 2,082.2 | 1.00 | 1 |
| 02/27/2014 20:00 | 17,393.7 | 2,733.4 | 20,127.1 | 20,127.1 | 102,470.0 | 2,062.4 | 1.00 | 1 |
| 02/27/2014 21:00 | 17,425.9 | 2,776.9 | 20,202.8 | 20,202.8 | 102,470.0 | 2,070.2 | 1.00 | 1 |
| 02/27/2014 22:00 | 17,412.0 | 2,576.6 | 19,988.6 | 19,988.6 | 102,470.0 | 2,048.2 | 1.00 | 1 |
| 02/27/2014 23:00 | 17,421.2 | 2,803.8 | 20,225.0 | 20,225.0 | 102,470.0 | 2,072.5 | 1.00 | 1 |
| **Average/Sum#:** | 16,840.1 | 1,417.6 | 18,225.2 | 437,403.9 # | 102,470.0 | 1,867.5 | 24.00 # | 24 # |
| **Minimum:** | 12,527.4 | 0.0 | 12,527.4 | 12,527.4 | 102,470.0 | 1,283.7 | 1.00 | 1 |
| **Maximum:** | 17,585.0 | 2,967.3 | 20,319.9 | 20,319.9 | 102,470.0 | 2,082.2 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 02/28/2014 00:00 | 17,054.2 | 1,759.7 | 18,813.9 | 18,813.9 | 102,470.0 | 1,927.9 | 1.00 | 1 |
| 02/28/2014 01:00 | 16,834.0 | 1,535.6 | 18,369.6 | 18,369.6 | 102,470.0 | 1,882.3 | 1.00 | 1 |
| 02/28/2014 02:00 | 17,209.7 | 1,776.2 | 18,985.9 | 18,985.9 | 102,470.0 | 1,945.5 | 1.00 | 1 |
| 02/28/2014 03:00 | 16,824.6 | 1,536.9 | 18,361.5 | 18,361.5 | 102,470.0 | 1,881.5 | 1.00 | 1 |
| 02/28/2014 04:00 | 16,850.7 | 1,534.5 | 18,385.2 | 18,385.2 | 102,470.0 | 1,883.9 | 1.00 | 1 |
| 02/28/2014 05:00 | 16,987.9 | 1,537.6 | 18,525.5 | 18,525.5 | 102,470.0 | 1,898.3 | 1.00 | 1 |
| 02/28/2014 06:00 | 16,930.0 | 1,543.3 | 18,473.3 | 18,473.3 | 102,470.0 | 1,893.0 | 1.00 | 1 |
| 02/28/2014 07:00 | 17,013.5 | 1,590.1 | 18,603.6 | 18,603.6 | 102,470.0 | 1,906.3 | 1.00 | 1 |
| 02/28/2014 08:00 | 17,463.8 | 2,520.0 | 19,983.8 | 19,983.8 | 102,470.0 | 2,047.7 | 1.00 | 1 |
| 02/28/2014 09:00 | 17,451.3 | 3,801.8 | 21,253.1 | 21,253.1 | 102,470.0 | 2,177.8 | 1.00 | 1 |
| 02/28/2014 10:00 | 17,453.6 | 4,233.3 | 21,686.9 | 21,686.9 | 102,470.0 | 2,222.3 | 1.00 | 1 |
| 02/28/2014 11:00 | 17,447.3 | 4,055.0 | 21,502.3 | 21,502.3 | 102,470.0 | 2,203.3 | 1.00 | 1 |
| 02/28/2014 12:00 | 17,439.1 | 3,719.6 | 21,158.7 | 21,158.7 | 102,470.0 | 2,168.1 | 1.00 | 1 |
| 02/28/2014 13:00 | 17,395.6 | 2,631.3 | 20,026.9 | 20,026.9 | 102,470.0 | 2,052.2 | 1.00 | 1 |
| 02/28/2014 14:00 | 17,002.6 | 1,544.7 | 18,547.3 | 18,547.3 | 102,470.0 | 1,900.5 | 1.00 | 1 |
| 02/28/2014 15:00 | 17,261.4 | 1,987.5 | 19,248.9 | 19,248.9 | 102,470.0 | 1,972.4 | 1.00 | 1 |
| 02/28/2014 16:00 | 17,394.0 | 3,552.3 | 20,946.3 | 20,946.3 | 102,470.0 | 2,146.4 | 1.00 | 1 |
| 02/28/2014 17:00 | 17,464.1 | 3,065.8 | 20,529.9 | 20,529.9 | 102,470.0 | 2,103.7 | 1.00 | 1 |
| 02/28/2014 18:00 | 17,480.9 | 1,833.4 | 19,314.3 | 19,314.3 | 102,470.0 | 1,979.1 | 1.00 | 1 |
| 02/28/2014 19:00 | 17,506.8 | 2,357.9 | 19,864.7 | 19,864.7 | 102,470.0 | 2,035.5 | 1.00 | 1 |
| 02/28/2014 20:00 | 16,785.2 | 1,533.7 | 18,318.9 | 18,318.9 | 102,470.0 | 1,877.1 | 1.00 | 1 |
| 02/28/2014 21:00 | 17,506.6 | 1,878.6 | 19,385.2 | 19,385.2 | 102,470.0 | 1,986.4 | 1.00 | 1 |
| 02/28/2014 22:00 | 17,568.1 | 2,208.8 | 19,776.9 | 19,776.9 | 102,470.0 | 2,026.5 | 1.00 | 1 |
| 02/28/2014 23:00 | 17,500.6 | 2,677.4 | 20,178.0 | 20,178.0 | 102,470.0 | 2,067.6 | 1.00 | 1 |
| **Average/Sum#:** | 17,242.7 | 2,350.6 | 19,593.4 | 470,240.6 # | 102,470.0 | 2,007.7 | 24.00 # | 24 # |
| **Minimum:** | 16,785.2 | 1,533.7 | 18,318.9 | 18,318.9 | 102,470.0 | 1,877.1 | 1.00 | 1 |
| **Maximum:** | 17,568.1 | 4,233.3 | 21,686.9 | 21,686.9 | 102,470.0 | 2,222.3 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/01/2014 00:00 | 17,295.9 | 1,947.3 | 19,243.2 | 19,243.2 | 102,470.0 | 1,971.9 | 1.00 | 1 |
| 03/01/2014 01:00 | 16,929.7 | 1,545.5 | 18,475.2 | 18,475.2 | 102,470.0 | 1,893.2 | 1.00 | 1 |
| 03/01/2014 02:00 | 16,676.2 | 1,529.7 | 18,205.9 | 18,205.9 | 102,470.0 | 1,865.6 | 1.00 | 1 |
| 03/01/2014 03:00 | 16,711.6 | 1,528.9 | 18,240.5 | 18,240.5 | 102,470.0 | 1,869.1 | 1.00 | 1 |
| 03/01/2014 04:00 | 16,736.5 | 1,529.3 | 18,265.8 | 18,265.8 | 102,470.0 | 1,871.7 | 1.00 | 1 |
| 03/01/2014 05:00 | 16,852.4 | 1,533.2 | 18,385.6 | 18,385.6 | 102,470.0 | 1,884.0 | 1.00 | 1 |
| 03/01/2014 06:00 | 16,692.2 | 1,537.6 | 18,229.8 | 18,229.8 | 102,470.0 | 1,868.0 | 1.00 | 1 |
| 03/01/2014 07:00 | 16,692.1 | 1,537.9 | 18,230.0 | 18,230.0 | 102,470.0 | 1,868.0 | 1.00 | 1 |
| 03/01/2014 08:00 | 16,796.9 | 1,536.8 | 18,333.7 | 18,333.7 | 102,470.0 | 1,878.7 | 1.00 | 1 |
| 03/01/2014 09:00 | 16,748.4 | 1,533.1 | 18,281.5 | 18,281.5 | 102,470.0 | 1,873.3 | 1.00 | 1 |
| 03/01/2014 10:00 | 16,792.6 | 1,526.9 | 18,319.5 | 18,319.5 | 102,470.0 | 1,877.2 | 1.00 | 1 |
| 03/01/2014 11:00 | 16,755.1 | 1,518.7 | 18,273.8 | 18,273.8 | 102,470.0 | 1,872.5 | 1.00 | 1 |
| 03/01/2014 12:00 | 16,722.4 | 1,514.9 | 18,237.3 | 18,237.3 | 102,470.0 | 1,868.8 | 1.00 | 1 |
| 03/01/2014 13:00 | 16,929.1 | 1,546.2 | 18,475.3 | 18,475.3 | 102,470.0 | 1,893.2 | 1.00 | 1 |
| 03/01/2014 14:00 | 17,525.8 | 2,220.3 | 19,746.1 | 19,746.1 | 102,470.0 | 2,023.4 | 1.00 | 1 |
| 03/01/2014 15:00 | 17,493.8 | 2,324.6 | 19,818.4 | 19,818.4 | 102,470.0 | 2,030.8 | 1.00 | 1 |
| 03/01/2014 16:00 | 17,040.7 | 1,533.1 | 18,573.8 | 18,573.8 | 102,470.0 | 1,903.3 | 1.00 | 1 |
| 03/01/2014 17:00 | 16,709.7 | 1,524.8 | 18,234.5 | 18,234.5 | 102,470.0 | 1,868.5 | 1.00 | 1 |
| 03/01/2014 18:00 | 16,722.9 | 1,526.6 | 18,249.5 | 18,249.5 | 102,470.0 | 1,870.0 | 1.00 | 1 |
| 03/01/2014 19:00 | 17,297.0 | 2,008.1 | 19,305.1 | 19,305.1 | 102,470.0 | 1,978.2 | 1.00 | 1 |
| 03/01/2014 20:00 | 17,310.6 | 1,816.8 | 19,127.4 | 19,127.4 | 102,470.0 | 1,960.0 | 1.00 | 1 |
| 03/01/2014 21:00 | 17,462.9 | 2,224.2 | 19,687.1 | 19,687.1 | 102,470.0 | 2,017.3 | 1.00 | 1 |
| 03/01/2014 22:00 | 17,593.9 | 2,102.4 | 19,696.3 | 19,696.3 | 102,470.0 | 2,018.3 | 1.00 | 1 |
| 03/01/2014 23:00 | 17,548.1 | 2,466.5 | 20,014.6 | 20,014.6 | 102,470.0 | 2,050.9 | 1.00 | 1 |
| **Average/Sum#:** | 17,001.5 | 1,733.9 | 18,735.4 | 449,649.9 # | 102,470.0 | 1,919.8 | 24.00 # | 24 # |
| **Minimum:** | 16,676.2 | 1,514.9 | 18,205.9 | 18,205.9 | 102,470.0 | 1,865.6 | 1.00 | 1 |
| **Maximum:** | 17,593.9 | 2,466.5 | 20,014.6 | 20,014.6 | 102,470.0 | 2,050.9 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/02/2014 00:00 | 17,302.3 | 1,626.8 | 18,929.1 | 18,929.1 | 102,470.0 | 1,939.7 | 1.00 | 1 |
| 03/02/2014 01:00 | 17,760.4 | 2,166.1 | 19,926.5 | 19,926.5 | 102,470.0 | 2,041.9 | 1.00 | 1 |
| 03/02/2014 02:00 | 17,878.9 | 1,860.1 | 19,739.0 | 19,739.0 | 102,470.0 | 2,022.7 | 1.00 | 1 |
| 03/02/2014 03:00 | 16,909.2 | 1,537.0 | 18,446.2 | 18,446.2 | 102,470.0 | 1,890.2 | 1.00 | 1 |
| 03/02/2014 04:00 | 16,678.7 | 1,534.6 | 18,213.3 | 18,213.3 | 102,470.0 | 1,866.3 | 1.00 | 1 |
| 03/02/2014 05:00 | 17,143.6 | 1,533.3 | 18,676.9 | 18,676.9 | 102,470.0 | 1,913.8 | 1.00 | 1 |
| 03/02/2014 06:00 | 17,695.3 | 1,906.8 | 19,602.1 | 19,602.1 | 102,470.0 | 2,008.6 | 1.00 | 1 |
| 03/02/2014 07:00 | 18,038.6 | 2,347.9 | 20,386.5 | 20,386.5 | 102,470.0 | 2,089.0 | 1.00 | 1 |
| 03/02/2014 08:00 | 17,990.6 | 2,328.8 | 20,319.4 | 20,319.4 | 102,470.0 | 2,082.1 | 1.00 | 1 |
| 03/02/2014 09:00 | 17,681.1 | 1,596.2 | 19,277.3 | 19,277.3 | 102,470.0 | 1,975.3 | 1.00 | 1 |
| 03/02/2014 10:00 | 17,788.1 | 2,364.1 | 20,152.2 | 20,152.2 | 102,470.0 | 2,065.0 | 1.00 | 1 |
| 03/02/2014 11:00 | 17,748.7 | 4,045.9 | 21,794.6 | 21,794.6 | 102,470.0 | 2,233.3 | 1.00 | 1 |
| 03/02/2014 12:00 | 17,730.9 | 3,826.9 | 21,557.8 | 21,557.8 | 102,470.0 | 2,209.0 | 1.00 | 1 |
| 03/02/2014 13:00 | 17,593.8 | 4,459.0 | 22,052.8 | 22,052.8 | 102,470.0 | 2,259.8 | 1.00 | 1 |
| 03/02/2014 14:00 | 17,554.3 | 4,410.9 | 21,965.2 | 21,965.2 | 102,470.0 | 2,250.8 | 1.00 | 1 |
| 03/02/2014 15:00 | 17,515.6 | 4,363.9 | 21,879.5 | 21,879.5 | 102,470.0 | 2,242.0 | 1.00 | 1 |
| 03/02/2014 16:00 | 17,487.5 | 4,364.6 | 21,852.1 | 21,852.1 | 102,470.0 | 2,239.2 | 1.00 | 1 |
| 03/02/2014 17:00 | 17,475.9 | 4,016.9 | 21,492.8 | 21,492.8 | 102,470.0 | 2,202.4 | 1.00 | 1 |
| 03/02/2014 18:00 | 17,473.2 | 3,271.4 | 20,744.6 | 20,744.6 | 102,470.0 | 2,125.7 | 1.00 | 1 |
| 03/02/2014 19:00 | 17,525.5 | 3,274.2 | 20,799.7 | 20,799.7 | 102,470.0 | 2,131.3 | 1.00 | 1 |
| 03/02/2014 20:00 | 17,596.3 | 2,566.3 | 20,162.6 | 20,162.6 | 102,470.0 | 2,066.1 | 1.00 | 1 |
| 03/02/2014 21:00 | 17,737.8 | 3,373.2 | 21,111.0 | 21,111.0 | 102,470.0 | 2,163.2 | 1.00 | 1 |
| 03/02/2014 22:00 | 17,957.4 | 2,302.7 | 20,260.1 | 20,260.1 | 102,470.0 | 2,076.1 | 1.00 | 1 |
| 03/02/2014 23:00 | 17,758.5 | 2,022.9 | 19,781.4 | 19,781.4 | 102,470.0 | 2,027.0 | 1.00 | 1 |
| **Average/Sum#:** | 17,584.3 | 2,795.9 | 20,380.1 | 489,122.7 # | 102,470.0 | 2,088.4 | 24.00 # | 24 # |
| **Minimum:** | 16,678.7 | 1,533.3 | 18,213.3 | 18,213.3 | 102,470.0 | 1,866.3 | 1.00 | 1 |
| **Maximum:** | 18,038.6 | 4,459.0 | 22,052.8 | 22,052.8 | 102,470.0 | 2,259.8 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/03/2014 00:00 | 15,320.9 | 806.1 | 15,748.1 | 15,748.1 | 102,470.0 | 1,613.7 | 1.00 | 1 |
| 03/03/2014 01:00 | 14,017.9 | 0.0 | 14,017.9 | 14,017.9 | 102,470.0 | 1,436.4 | 1.00 | 1 |
| 03/03/2014 02:00 | 12,600.1 | 0.0 | 12,600.1 | 12,600.1 | 102,470.0 | 1,291.1 | 1.00 | 1 |
| 03/03/2014 03:00 | 12,575.8 | 0.0 | 12,575.8 | 12,575.8 | 102,470.0 | 1,288.6 | 1.00 | 1 |
| 03/03/2014 04:00 | 12,629.4 | 0.0 | 12,629.4 | 12,629.4 | 102,470.0 | 1,294.1 | 1.00 | 1 |
| 03/03/2014 05:00 | 15,279.4 | 667.1 | 15,579.6 | 15,579.6 | 102,470.0 | 1,596.4 | 1.00 | 1 |
| 03/03/2014 06:00 | 17,122.4 | 1,526.5 | 18,648.9 | 18,648.9 | 102,470.0 | 1,911.0 | 1.00 | 1 |
| 03/03/2014 07:00 | 17,826.6 | 1,992.6 | 19,819.2 | 19,819.2 | 102,470.0 | 2,030.9 | 1.00 | 1 |
| 03/03/2014 08:00 | 17,806.6 | 3,883.7 | 21,690.3 | 21,690.3 | 102,470.0 | 2,222.6 | 1.00 | 1 |
| 03/03/2014 09:00 | 17,745.0 | 3,400.3 | 21,145.3 | 21,145.3 | 102,470.0 | 2,166.8 | 1.00 | 1 |
| 03/03/2014 10:00 | 17,732.3 | 2,016.2 | 19,748.5 | 19,748.5 | 102,470.0 | 2,023.6 | 1.00 | 1 |
| 03/03/2014 11:00 | 17,404.9 | 1,612.4 | 19,017.3 | 19,017.3 | 102,470.0 | 1,948.7 | 1.00 | 1 |
| 03/03/2014 12:00 | 17,055.7 | 1,532.5 | 18,588.2 | 18,588.2 | 102,470.0 | 1,904.7 | 1.00 | 1 |
| 03/03/2014 13:00 | 16,849.3 | 1,517.9 | 18,367.2 | 18,367.2 | 102,470.0 | 1,882.1 | 1.00 | 1 |
| 03/03/2014 14:00 | 17,083.6 | 1,519.7 | 18,603.3 | 18,603.3 | 102,470.0 | 1,906.3 | 1.00 | 1 |
| 03/03/2014 15:00 | 17,440.4 | 1,569.0 | 19,009.4 | 19,009.4 | 102,470.0 | 1,947.9 | 1.00 | 1 |
| 03/03/2014 16:00 | 17,896.6 | 1,975.4 | 19,872.0 | 19,872.0 | 102,470.0 | 2,036.3 | 1.00 | 1 |
| 03/03/2014 17:00 | 17,879.7 | 3,760.8 | 21,640.5 | 21,640.5 | 102,470.0 | 2,217.5 | 1.00 | 1 |
| 03/03/2014 18:00 | 17,702.3 | 2,768.7 | 20,471.0 | 20,471.0 | 102,470.0 | 2,097.7 | 1.00 | 1 |
| 03/03/2014 19:00 | 17,720.0 | 3,806.3 | 21,526.3 | 21,526.3 | 102,470.0 | 2,205.8 | 1.00 | 1 |
| 03/03/2014 20:00 | 17,721.2 | 4,117.7 | 21,838.9 | 21,838.9 | 102,470.0 | 2,237.8 | 1.00 | 1 |
| 03/03/2014 21:00 | 17,759.8 | 3,888.0 | 21,647.8 | 21,647.8 | 102,470.0 | 2,218.3 | 1.00 | 1 |
| 03/03/2014 22:00 | 17,378.5 | 2,042.5 | 19,421.0 | 19,421.0 | 102,470.0 | 1,990.1 | 1.00 | 1 |
| 03/03/2014 23:00 | 16,681.9 | 1,529.7 | 18,211.6 | 18,211.6 | 102,470.0 | 1,866.1 | 1.00 | 1 |
| **Average/Sum#:** | 16,551.3 | 1,913.9 | 18,434.1 | 442,417.6 # | 102,470.0 | 1,888.9 | 24.00 # | 24 # |
| **Minimum:** | 12,575.8 | 0.0 | 12,575.8 | 12,575.8 | 102,470.0 | 1,288.6 | 1.00 | 1 |
| **Maximum:** | 17,896.6 | 4,117.7 | 21,838.9 | 21,838.9 | 102,470.0 | 2,237.8 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/04/2014 00:00 | 15,002.3 | 782.4 | 15,409.1 | 15,409.1 | 102,470.0 | 1,579.0 | 1.00 | 1 |
| 03/04/2014 01:00 | 12,297.9 | 0.0 | 12,297.9 | 12,297.9 | 102,470.0 | 1,260.2 | 1.00 | 1 |
| 03/04/2014 02:00 | 12,391.6 | 0.0 | 12,391.6 | 12,391.6 | 102,470.0 | 1,269.8 | 1.00 | 1 |
| 03/04/2014 03:00 | 12,999.7 | 0.0 | 12,999.7 | 12,999.7 | 102,470.0 | 1,332.1 | 1.00 | 1 |
| 03/04/2014 04:00 | 12,490.7 | 0.0 | 12,490.7 | 12,490.7 | 102,470.0 | 1,279.9 | 1.00 | 1 |
| 03/04/2014 05:00 | 12,650.1 | 0.0 | 12,650.1 | 12,650.1 | 102,470.0 | 1,296.3 | 1.00 | 1 |
| 03/04/2014 06:00 | 15,324.1 | 529.0 | 15,535.7 | 15,535.7 | 102,470.0 | 1,591.9 | 1.00 | 1 |
| 03/04/2014 07:00 | 17,164.4 | 1,178.2 | 18,342.6 | 18,342.6 | 102,470.0 | 1,879.6 | 1.00 | 1 |
| 03/04/2014 08:00 | 17,052.7 | 1,185.2 | 18,237.9 | 18,237.9 | 102,470.0 | 1,868.8 | 1.00 | 1 |
| 03/04/2014 09:00 | 14,109.3 | 36.4 | 14,110.4 | 14,110.4 | 102,470.0 | 1,445.9 | 1.00 | 1 |
| 03/04/2014 10:00 | 12,067.3 | 0.0 | 12,067.3 | 12,067.3 | 102,470.0 | 1,236.5 | 1.00 | 1 |
| 03/04/2014 11:00 | 12,075.7 | 0.0 | 12,075.7 | 12,075.7 | 102,470.0 | 1,237.4 | 1.00 | 1 |
| 03/04/2014 12:00 | 12,375.6 | 0.0 | 12,375.6 | 12,375.6 | 102,470.0 | 1,268.1 | 1.00 | 1 |
| 03/04/2014 13:00 | 13,868.5 | 0.0 | 13,868.5 | 13,868.5 | 102,470.0 | 1,421.1 | 1.00 | 1 |
| 03/04/2014 14:00 | 17,027.5 | 1,187.8 | 18,120.3 | 18,120.3 | 102,470.0 | 1,856.8 | 1.00 | 1 |
| 03/04/2014 15:00 | 16,995.0 | 1,306.9 | 18,301.9 | 18,301.9 | 102,470.0 | 1,875.4 | 1.00 | 1 |
| 03/04/2014 16:00 | 17,010.3 | 1,306.6 | 18,316.9 | 18,316.9 | 102,470.0 | 1,876.9 | 1.00 | 1 |
| 03/04/2014 17:00 | 16,989.7 | 1,308.3 | 18,298.0 | 18,298.0 | 102,470.0 | 1,875.0 | 1.00 | 1 |
| 03/04/2014 18:00 | 17,280.2 | 1,362.6 | 18,642.8 | 18,642.8 | 102,470.0 | 1,910.3 | 1.00 | 1 |
| 03/04/2014 19:00 | 17,607.9 | 3,254.7 | 20,862.6 | 20,862.6 | 102,470.0 | 2,137.8 | 1.00 | 1 |
| 03/04/2014 20:00 | 17,618.8 | 2,988.9 | 20,607.7 | 20,607.7 | 102,470.0 | 2,111.7 | 1.00 | 1 |
| 03/04/2014 21:00 | 17,594.0 | 2,194.6 | 19,788.6 | 19,788.6 | 102,470.0 | 2,027.7 | 1.00 | 1 |
| 03/04/2014 22:00 | 17,354.9 | 1,762.4 | 19,117.3 | 19,117.3 | 102,470.0 | 1,958.9 | 1.00 | 1 |
| 03/04/2014 23:00 | 16,918.0 | 1,324.9 | 18,242.9 | 18,242.9 | 102,470.0 | 1,869.3 | 1.00 | 1 |
| **Average/Sum#:** | 15,177.8 | 904.5 | 16,048.0 | 385,151.8 # | 102,470.0 | 1,644.4 | 24.00 # | 24 # |
| **Minimum:** | 12,067.3 | 0.0 | 12,067.3 | 12,067.3 | 102,470.0 | 1,236.5 | 1.00 | 1 |
| **Maximum:** | 17,618.8 | 3,254.7 | 20,862.6 | 20,862.6 | 102,470.0 | 2,137.8 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/05/2014 00:00 | 17,114.2 | 1,332.1 | 18,446.3 | 18,446.3 | 102,470.0 | 1,890.2 | 1.00 | 1 |
| 03/05/2014 01:00 | 17,682.1 | 1,948.5 | 19,630.6 | 19,630.6 | 102,470.0 | 2,011.5 | 1.00 | 1 |
| 03/05/2014 02:00 | 17,710.1 | 2,053.8 | 19,763.9 | 19,763.9 | 102,470.0 | 2,025.2 | 1.00 | 1 |
| 03/05/2014 03:00 | 17,136.5 | 1,435.7 | 18,572.2 | 18,572.2 | 102,470.0 | 1,903.1 | 1.00 | 1 |
| 03/05/2014 04:00 | 16,879.1 | 1,328.0 | 18,207.1 | 18,207.1 | 102,470.0 | 1,865.7 | 1.00 | 1 |
| 03/05/2014 05:00 | 17,504.8 | 1,835.2 | 19,340.0 | 19,340.0 | 102,470.0 | 1,981.8 | 1.00 | 1 |
| 03/05/2014 06:00 | 17,499.7 | 1,551.9 | 19,051.6 | 19,051.6 | 102,470.0 | 1,952.2 | 1.00 | 1 |
| 03/05/2014 07:00 | 17,679.2 | 1,558.1 | 19,237.3 | 19,237.3 | 102,470.0 | 1,971.2 | 1.00 | 1 |
| 03/05/2014 08:00 | 17,490.0 | 1,800.0 | 19,290.0 | 19,290.0 | 102,470.0 | 1,976.6 | 1.00 | 1 |
| 03/05/2014 09:00 | 16,913.0 | 1,531.7 | 18,444.7 | 18,444.7 | 102,470.0 | 1,890.0 | 1.00 | 1 |
| 03/05/2014 10:00 | 16,927.3 | 1,527.0 | 18,454.3 | 18,454.3 | 102,470.0 | 1,891.0 | 1.00 | 1 |
| 03/05/2014 11:00 | 16,936.8 | 1,522.7 | 18,459.5 | 18,459.5 | 102,470.0 | 1,891.5 | 1.00 | 1 |
| 03/05/2014 12:00 | 16,943.6 | 1,520.8 | 18,464.4 | 18,464.4 | 102,470.0 | 1,892.0 | 1.00 | 1 |
| 03/05/2014 13:00 | 16,950.2 | 1,518.6 | 18,468.8 | 18,468.8 | 102,470.0 | 1,892.5 | 1.00 | 1 |
| 03/05/2014 14:00 | 16,958.8 | 1,513.8 | 18,472.6 | 18,472.6 | 102,470.0 | 1,892.9 | 1.00 | 1 |
| 03/05/2014 15:00 | 16,980.5 | 1,506.9 | 18,487.4 | 18,487.4 | 102,470.0 | 1,894.4 | 1.00 | 1 |
| 03/05/2014 16:00 | 17,187.4 | 1,704.4 | 18,891.8 | 18,891.8 | 102,470.0 | 1,935.8 | 1.00 | 1 |
| 03/05/2014 17:00 | 17,346.5 | 1,910.8 | 19,257.3 | 19,257.3 | 102,470.0 | 1,973.3 | 1.00 | 1 |
| 03/05/2014 18:00 | 17,369.5 | 1,954.6 | 19,324.1 | 19,324.1 | 102,470.0 | 1,980.1 | 1.00 | 1 |
| 03/05/2014 19:00 | 17,511.3 | 2,748.7 | 20,260.0 | 20,260.0 | 102,470.0 | 2,076.0 | 1.00 | 1 |
| 03/05/2014 20:00 | 17,609.8 | 2,238.9 | 19,848.7 | 19,848.7 | 102,470.0 | 2,033.9 | 1.00 | 1 |
| 03/05/2014 21:00 | 17,567.7 | 2,014.3 | 19,582.0 | 19,582.0 | 102,470.0 | 2,006.6 | 1.00 | 1 |
| 03/05/2014 22:00 | 17,446.6 | 1,995.4 | 19,442.0 | 19,442.0 | 102,470.0 | 1,992.2 | 1.00 | 1 |
| 03/05/2014 23:00 | 16,736.3 | 1,525.1 | 18,261.4 | 18,261.4 | 102,470.0 | 1,871.2 | 1.00 | 1 |
| **Average/Sum#:** | 17,253.4 | 1,732.4 | 18,985.8 | 455,658.0 # | 102,470.0 | 1,945.5 | 24.00 # | 24 # |
| **Minimum:** | 16,736.3 | 1,328.0 | 18,207.1 | 18,207.1 | 102,470.0 | 1,865.7 | 1.00 | 1 |
| **Maximum:** | 17,710.1 | 2,748.7 | 20,260.0 | 20,260.0 | 102,470.0 | 2,076.0 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/06/2014 00:00 | 16,703.2 | 1,516.7 | 18,219.9 | 18,219.9 | 102,470.0 | 1,867.0 | 1.00 | 1 |
| 03/06/2014 01:00 | 16,559.6 | 1,342.4 | 17,740.9 | 17,740.9 | 102,470.0 | 1,817.9 | 1.00 | 1 |
| 03/06/2014 02:00 | 12,450.1 | 0.0 | 12,450.1 | 12,450.1 | 102,470.0 | 1,275.8 | 1.00 | 1 |
| 03/06/2014 03:00 | 6,178.3 | 0.0 | 6,178.3 | 1,544.6 | 102,470.0 | 633.1 | 0.25 | 0 |
| 03/06/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/06/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 12,972.8 | 714.8 | 13,647.3 | 49,955.5 # | 102,470.0 | 1,398.5 | 3.25 # | 3 # |
| **Minimum:** | 6,178.3 | 0.0 | 6,178.3 | 1,544.6 | 102,470.0 | 633.1 | 0.00 | 0 |
| **Maximum:** | 16,703.2 | 1,516.7 | 18,219.9 | 18,219.9 | 102,470.0 | 1,867.0 | 1.00 | 1 |
| **%SI** | 83.3 | 83.3 | 83.3 | 83.3 | 0.0 | 83.3 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/07/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/07/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/07/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/07/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/07/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/07/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/07/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/07/2014 07:00 | 4,814.0 | 0.0 | 4,814.0 | 3,032.8 | 102,470.0 | 493.3 | 0.63 | 0 |
| 03/07/2014 08:00 | 11,003.3 | 0.0 | 11,003.3 | 11,003.3 | 102,470.0 | 1,127.5 | 1.00 | 0 |
| 03/07/2014 09:00 | 13,050.8 | 0.0 | 13,050.8 | 13,050.8 | 102,470.0 | 1,337.3 | 1.00 | 1 |
| 03/07/2014 10:00 | 16,692.1 | 1,226.1 | 17,709.8 | 17,709.8 | 102,470.0 | 1,814.7 | 1.00 | 1 |
| 03/07/2014 11:00 | 16,682.5 | 1,475.6 | 18,158.1 | 18,158.1 | 102,470.0 | 1,860.7 | 1.00 | 1 |
| 03/07/2014 12:00 | 16,691.4 | 1,456.9 | 18,148.3 | 18,148.3 | 102,470.0 | 1,859.7 | 1.00 | 1 |
| 03/07/2014 13:00 | 16,659.1 | 1,455.0 | 18,114.1 | 18,114.1 | 102,470.0 | 1,856.2 | 1.00 | 1 |
| 03/07/2014 14:00 | 16,662.4 | 1,480.9 | 18,143.3 | 18,143.3 | 102,470.0 | 1,859.1 | 1.00 | 1 |
| 03/07/2014 15:00 | 16,653.3 | 1,484.6 | 18,137.9 | 18,137.9 | 102,470.0 | 1,858.6 | 1.00 | 1 |
| 03/07/2014 16:00 | 16,860.0 | 1,550.9 | 18,410.9 | 18,410.9 | 102,470.0 | 1,886.6 | 1.00 | 1 |
| 03/07/2014 17:00 | 17,538.7 | 2,242.7 | 19,781.4 | 19,781.4 | 102,470.0 | 2,027.0 | 1.00 | 1 |
| 03/07/2014 18:00 | 17,652.6 | 2,241.7 | 19,894.3 | 19,894.3 | 102,470.0 | 2,038.6 | 1.00 | 1 |
| 03/07/2014 19:00 | 17,707.4 | 3,895.7 | 21,603.1 | 21,603.1 | 102,470.0 | 2,213.7 | 1.00 | 1 |
| 03/07/2014 20:00 | 17,772.1 | 4,603.4 | 22,375.5 | 22,375.5 | 102,470.0 | 2,292.8 | 1.00 | 1 |
| 03/07/2014 21:00 | 17,773.3 | 4,556.9 | 22,330.2 | 22,330.2 | 102,470.0 | 2,288.2 | 1.00 | 1 |
| 03/07/2014 22:00 | 17,763.5 | 4,553.1 | 22,316.6 | 22,316.6 | 102,470.0 | 2,286.8 | 1.00 | 1 |
| 03/07/2014 23:00 | 17,771.1 | 3,946.6 | 21,717.7 | 21,717.7 | 102,470.0 | 2,225.4 | 1.00 | 1 |
| **Average/Sum#:** | 15,867.5 | 2,127.7 | 17,982.9 | 303,928.1 # | 102,470.0 | 1,842.7 | 16.63 # | 15 # |
| **Minimum:** | 4,814.0 | 0.0 | 4,814.0 | 3,032.8 | 102,470.0 | 493.3 | 0.00 | 0 |
| **Maximum:** | 17,773.3 | 4,603.4 | 22,375.5 | 22,375.5 | 102,470.0 | 2,292.8 | 1.00 | 1 |
| **%SI** | 29.2 | 29.2 | 29.2 | 29.2 | 0.0 | 29.2 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/08/2014 00:00 | 17,638.9 | 2,057.9 | 19,696.8 | 19,696.8 | 102,470.0 | 2,018.3 | 1.00 | 1 |
| 03/08/2014 01:00 | 17,694.9 | 1,827.6 | 19,522.5 | 19,522.5 | 102,470.0 | 2,000.5 | 1.00 | 1 |
| 03/08/2014 02:00 | 17,413.8 | 1,622.1 | 19,035.9 | 19,035.9 | 102,470.0 | 1,950.6 | 1.00 | 1 |
| 03/08/2014 03:00 | 17,212.1 | 1,597.6 | 18,809.7 | 18,809.7 | 102,470.0 | 1,927.4 | 1.00 | 1 |
| 03/08/2014 04:00 | 17,660.4 | 1,684.7 | 19,345.1 | 19,345.1 | 102,470.0 | 1,982.3 | 1.00 | 1 |
| 03/08/2014 05:00 | 17,713.3 | 2,073.1 | 19,786.4 | 19,786.4 | 102,470.0 | 2,027.5 | 1.00 | 1 |
| 03/08/2014 06:00 | 17,738.5 | 2,422.2 | 20,160.7 | 20,160.7 | 102,470.0 | 2,065.9 | 1.00 | 1 |
| 03/08/2014 07:00 | 17,711.0 | 2,236.4 | 19,947.4 | 19,947.4 | 102,470.0 | 2,044.0 | 1.00 | 1 |
| 03/08/2014 08:00 | 17,075.8 | 1,535.6 | 18,611.4 | 18,611.4 | 102,470.0 | 1,907.1 | 1.00 | 1 |
| 03/08/2014 09:00 | 16,578.1 | 1,517.6 | 18,095.7 | 18,095.7 | 102,470.0 | 1,854.3 | 1.00 | 1 |
| 03/08/2014 10:00 | 16,596.9 | 1,502.8 | 18,099.7 | 18,099.7 | 102,470.0 | 1,854.7 | 1.00 | 1 |
| 03/08/2014 11:00 | 16,588.6 | 1,485.6 | 18,074.2 | 18,074.2 | 102,470.0 | 1,852.1 | 1.00 | 1 |
| 03/08/2014 12:00 | 16,608.5 | 1,470.0 | 18,078.5 | 18,078.5 | 102,470.0 | 1,852.5 | 1.00 | 1 |
| 03/08/2014 13:00 | 16,635.6 | 1,472.0 | 18,107.6 | 18,107.6 | 102,470.0 | 1,855.5 | 1.00 | 1 |
| 03/08/2014 14:00 | 16,591.0 | 1,488.7 | 18,079.7 | 18,079.7 | 102,470.0 | 1,852.6 | 1.00 | 1 |
| 03/08/2014 15:00 | 16,593.5 | 1,487.0 | 18,080.5 | 18,080.5 | 102,470.0 | 1,852.7 | 1.00 | 1 |
| 03/08/2014 16:00 | 16,690.0 | 1,489.3 | 18,179.3 | 18,179.3 | 102,470.0 | 1,862.8 | 1.00 | 1 |
| 03/08/2014 17:00 | 16,798.5 | 1,626.9 | 18,425.4 | 18,425.4 | 102,470.0 | 1,888.1 | 1.00 | 1 |
| 03/08/2014 18:00 | 17,503.6 | 3,349.1 | 20,852.7 | 20,852.7 | 102,470.0 | 2,136.8 | 1.00 | 1 |
| 03/08/2014 19:00 | 17,573.2 | 4,380.8 | 21,954.0 | 21,954.0 | 102,470.0 | 2,249.6 | 1.00 | 1 |
| 03/08/2014 20:00 | 17,528.5 | 4,618.8 | 22,147.3 | 22,147.3 | 102,470.0 | 2,269.4 | 1.00 | 1 |
| 03/08/2014 21:00 | 17,500.9 | 4,578.0 | 22,078.9 | 22,078.9 | 102,470.0 | 2,262.4 | 1.00 | 1 |
| 03/08/2014 22:00 | 17,536.2 | 4,558.8 | 22,095.0 | 22,095.0 | 102,470.0 | 2,264.1 | 1.00 | 1 |
| 03/08/2014 23:00 | 17,565.9 | 4,155.1 | 21,721.0 | 21,721.0 | 102,470.0 | 2,225.8 | 1.00 | 1 |
| **Average/Sum#:** | 17,197.8 | 2,343.2 | 19,541.1 | 468,985.4 # | 102,470.0 | 2,002.4 | 24.00 # | 24 # |
| **Minimum:** | 16,578.1 | 1,470.0 | 18,074.2 | 18,074.2 | 102,470.0 | 1,852.1 | 1.00 | 1 |
| **Maximum:** | 17,738.5 | 4,618.8 | 22,147.3 | 22,147.3 | 102,470.0 | 2,269.4 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/09/2014 00:00 | 16,638.2 | 1,497.1 | 17,805.9 | 17,805.9 | 102,470.0 | 1,824.6 | 1.00 | 1 |
| 03/09/2014 01:00 | 13,456.6 | 0.0 | 13,456.6 | 13,456.6 | 102,470.0 | 1,378.9 | 1.00 | 1 |
| 03/09/2014 02:00 | 6,429.5 | 0.0 | 6,429.5 | 1,478.8 | 102,470.0 | 658.8 | 0.23 | 0 |
| 03/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/09/2014 15:00 | 5,247.0 | 0.0 | 5,247.0 | 4,092.7 | 102,470.0 | 537.7 | 0.78 | 0 |
| 03/09/2014 16:00 | 13,732.9 | 0.0 | 13,732.9 | 13,732.9 | 102,470.0 | 1,407.2 | 1.00 | 0 |
| 03/09/2014 17:00 | 17,502.8 | 2,745.7 | 20,248.5 | 20,248.5 | 102,470.0 | 2,074.9 | 1.00 | 1 |
| 03/09/2014 18:00 | 17,526.5 | 4,112.9 | 21,639.4 | 21,639.4 | 102,470.0 | 2,217.4 | 1.00 | 1 |
| 03/09/2014 19:00 | 17,522.3 | 4,378.1 | 21,900.4 | 21,900.4 | 102,470.0 | 2,244.1 | 1.00 | 1 |
| 03/09/2014 20:00 | 17,530.8 | 4,400.2 | 21,931.0 | 21,931.0 | 102,470.0 | 2,247.3 | 1.00 | 1 |
| 03/09/2014 21:00 | 17,533.1 | 4,402.3 | 21,935.4 | 21,935.4 | 102,470.0 | 2,247.7 | 1.00 | 1 |
| 03/09/2014 22:00 | 17,524.5 | 156.2 | 17,555.7 | 17,555.7 | 102,470.0 | 1,798.9 | 1.00 | 1 |
| 03/09/2014 23:00 | 17,556.0 | 0.0 | 17,556.0 | 17,556.0 | 102,470.0 | 1,799.0 | 1.00 | 1 |
| **Average/Sum#:** | 14,850.0 | 1,807.7 | 16,619.9 | 193,333.3 # | 102,470.0 | 1,703.0 | 11.01 # | 9 # |
| **Minimum:** | 5,247.0 | 0.0 | 5,247.0 | 1,478.8 | 102,470.0 | 537.7 | 0.00 | 0 |
| **Maximum:** | 17,556.0 | 4,402.3 | 21,935.4 | 21,935.4 | 102,470.0 | 2,247.7 | 1.00 | 1 |
| **%SI** | 50.0 | 50.0 | 50.0 | 50.0 | 0.0 | 50.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/10/2014 00:00 | 17,568.3 | 0.0 | 17,568.3 | 17,568.3 | 102,470.0 | 1,800.2 | 1.00 | 1 |
| 03/10/2014 01:00 | 12,824.3 | 0.0 | 12,824.3 | 12,824.3 | 102,470.0 | 1,314.1 | 1.00 | 1 |
| 03/10/2014 02:00 | 12,108.9 | 0.0 | 12,108.9 | 12,108.9 | 102,470.0 | 1,240.8 | 1.00 | 1 |
| 03/10/2014 03:00 | 12,144.3 | 0.0 | 12,144.3 | 12,144.3 | 102,470.0 | 1,244.4 | 1.00 | 1 |
| 03/10/2014 04:00 | 12,201.5 | 0.0 | 12,201.5 | 12,201.5 | 102,470.0 | 1,250.3 | 1.00 | 1 |
| 03/10/2014 05:00 | 14,921.7 | 0.0 | 14,921.7 | 14,921.7 | 102,470.0 | 1,529.0 | 1.00 | 1 |
| 03/10/2014 06:00 | 17,456.1 | 0.0 | 17,456.1 | 17,456.1 | 102,470.0 | 1,788.7 | 1.00 | 1 |
| 03/10/2014 07:00 | 17,725.1 | 1.6 | 17,725.1 | 17,725.1 | 102,470.0 | 1,816.3 | 1.00 | 1 |
| 03/10/2014 08:00 | 17,706.7 | 1,118.1 | 18,467.0 | 18,467.0 | 102,470.0 | 1,892.3 | 1.00 | 1 |
| 03/10/2014 09:00 | 17,049.5 | 1,537.8 | 18,587.3 | 18,587.3 | 102,470.0 | 1,904.6 | 1.00 | 1 |
| 03/10/2014 10:00 | 16,567.5 | 1,533.3 | 18,100.8 | 18,100.8 | 102,470.0 | 1,854.8 | 1.00 | 1 |
| 03/10/2014 11:00 | 16,638.3 | 1,512.2 | 18,150.5 | 18,150.5 | 102,470.0 | 1,859.9 | 1.00 | 1 |
| 03/10/2014 12:00 | 16,649.3 | 1,500.0 | 18,149.3 | 18,149.3 | 102,470.0 | 1,859.8 | 1.00 | 1 |
| 03/10/2014 13:00 | 16,664.2 | 1,507.1 | 18,171.3 | 18,171.3 | 102,470.0 | 1,862.0 | 1.00 | 1 |
| 03/10/2014 14:00 | 16,664.7 | 1,534.6 | 18,199.3 | 18,199.3 | 102,470.0 | 1,864.9 | 1.00 | 1 |
| 03/10/2014 15:00 | 16,693.5 | 1,533.5 | 18,227.0 | 18,227.0 | 102,470.0 | 1,867.7 | 1.00 | 1 |
| 03/10/2014 16:00 | 16,670.3 | 1,535.0 | 18,205.3 | 18,205.3 | 102,470.0 | 1,865.5 | 1.00 | 1 |
| 03/10/2014 17:00 | 16,687.1 | 1,488.6 | 18,175.7 | 18,175.7 | 102,470.0 | 1,862.5 | 1.00 | 1 |
| 03/10/2014 18:00 | 17,014.7 | 1,248.2 | 18,262.9 | 18,262.9 | 102,470.0 | 1,871.4 | 1.00 | 1 |
| 03/10/2014 19:00 | 17,614.0 | 3,554.4 | 21,168.4 | 21,168.4 | 102,470.0 | 2,169.1 | 1.00 | 1 |
| 03/10/2014 20:00 | 17,813.1 | 2,926.2 | 20,739.3 | 20,739.3 | 102,470.0 | 2,125.2 | 1.00 | 1 |
| 03/10/2014 21:00 | 16,125.1 | 1,105.3 | 16,987.2 | 16,987.2 | 102,470.0 | 1,740.7 | 1.00 | 1 |
| 03/10/2014 22:00 | 13,606.3 | 0.0 | 13,606.3 | 13,606.3 | 102,470.0 | 1,394.2 | 1.00 | 1 |
| 03/10/2014 23:00 | 5,947.0 | 0.0 | 5,947.0 | 1,367.8 | 102,470.0 | 609.4 | 0.23 | 0 |
| **Average/Sum#:** | 15,544.2 | 984.8 | 16,504.0 | 391,515.6 # | 102,470.0 | 1,691.2 | 23.23 # | 23 # |
| **Minimum:** | 5,947.0 | 0.0 | 5,947.0 | 1,367.8 | 102,470.0 | 609.4 | 0.23 | 0 |
| **Maximum:** | 17,813.1 | 3,554.4 | 21,168.4 | 21,168.4 | 102,470.0 | 2,169.1 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/11/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/11/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/11/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,470.0 | 0.0 | 0.00 | 0 |
| 03/11/2014 05:00 | 4,047.0 | 0.0 | 4,047.0 | 1,295.0 | 102,470.0 | 414.7 | 0.32 | 0 |
| 03/11/2014 06:00 | 8,641.5 | 0.0 | 8,641.5 | 8,641.5 | 102,470.0 | 885.5 | 1.00 | 0 |
| 03/11/2014 07:00 | 17,270.0 | 0.0 | 17,270.0 | 17,270.0 | 102,470.0 | 1,769.7 | 1.00 | 1 |
| 03/11/2014 08:00 | 17,391.8 | 998.7 | 18,120.9 | 18,120.9 | 102,470.0 | 1,856.8 | 1.00 | 1 |
| 03/11/2014 09:00 | 16,645.2 | 1,496.4 | 18,141.6 | 18,141.6 | 102,470.0 | 1,859.0 | 1.00 | 1 |
| 03/11/2014 10:00 | 16,633.0 | 1,491.2 | 18,124.2 | 18,124.2 | 102,470.0 | 1,857.2 | 1.00 | 1 |
| 03/11/2014 11:00 | 16,635.4 | 1,460.7 | 18,096.1 | 18,096.1 | 102,470.0 | 1,854.3 | 1.00 | 1 |
| 03/11/2014 12:00 | 16,071.9 | 1,132.4 | 16,977.8 | 16,977.8 | 102,470.0 | 1,739.7 | 1.00 | 1 |
| 03/11/2014 13:00 | 13,037.0 | 0.0 | 13,037.0 | 13,037.0 | 102,470.0 | 1,335.9 | 1.00 | 1 |
| 03/11/2014 14:00 | 12,457.6 | 0.0 | 12,457.6 | 12,457.6 | 102,470.0 | 1,276.5 | 1.00 | 1 |
| 03/11/2014 15:00 | 12,718.9 | 0.0 | 12,718.9 | 12,718.9 | 102,470.0 | 1,303.3 | 1.00 | 1 |
| 03/11/2014 16:00 | 13,451.7 | 0.0 | 13,451.7 | 13,451.7 | 102,470.0 | 1,378.4 | 1.00 | 1 |
| 03/11/2014 17:00 | 13,537.6 | 0.0 | 13,537.6 | 13,537.6 | 102,470.0 | 1,387.2 | 1.00 | 1 |
| 03/11/2014 18:00 | 15,004.9 | 670.6 | 15,320.1 | 15,320.1 | 102,470.0 | 1,569.9 | 1.00 | 1 |
| 03/11/2014 19:00 | 17,290.5 | 3,066.5 | 20,357.0 | 20,357.0 | 102,470.0 | 2,086.0 | 1.00 | 1 |
| 03/11/2014 20:00 | 17,811.6 | 3,456.1 | 21,267.7 | 21,267.7 | 102,470.0 | 2,179.3 | 1.00 | 1 |
| 03/11/2014 21:00 | 17,915.8 | 2,863.2 | 20,779.0 | 20,779.0 | 102,470.0 | 2,129.2 | 1.00 | 1 |
| 03/11/2014 22:00 | 17,958.3 | 3,482.0 | 21,440.3 | 21,440.3 | 102,470.0 | 2,197.0 | 1.00 | 1 |
| 03/11/2014 23:00 | 16,246.9 | 1,227.6 | 17,204.4 | 17,204.4 | 102,470.0 | 1,762.9 | 1.00 | 1 |
| **Average/Sum#:** | 14,777.2 | 1,123.4 | 15,841.6 | 298,238.4 # | 102,470.0 | 1,623.3 | 18.32 # | 17 # |
| **Minimum:** | 4,047.0 | 0.0 | 4,047.0 | 1,295.0 | 102,470.0 | 414.7 | 0.00 | 0 |
| **Maximum:** | 17,958.3 | 3,482.0 | 21,440.3 | 21,440.3 | 102,470.0 | 2,197.0 | 1.00 | 1 |
| **%SI** | 20.8 | 20.8 | 20.8 | 20.8 | 0.0 | 20.8 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/12/2014 00:00 | 12,494.3 | 0.0 | 12,494.3 | 12,494.3 | 102,470.0 | 1,280.3 | 1.00 | 1 |
| 03/12/2014 01:00 | 12,332.2 | 0.0 | 12,332.2 | 12,332.2 | 102,470.0 | 1,263.7 | 1.00 | 1 |
| 03/12/2014 02:00 | 12,120.4 | 0.0 | 12,120.4 | 12,120.4 | 102,470.0 | 1,242.0 | 1.00 | 1 |
| 03/12/2014 03:00 | 12,034.3 | 0.0 | 12,034.3 | 12,034.3 | 102,470.0 | 1,233.2 | 1.00 | 1 |
| 03/12/2014 04:00 | 12,078.1 | 0.0 | 12,078.1 | 12,078.1 | 102,470.0 | 1,237.6 | 1.00 | 1 |
| 03/12/2014 05:00 | 16,060.4 | 1,120.5 | 16,900.8 | 16,900.8 | 102,470.0 | 1,731.8 | 1.00 | 1 |
| 03/12/2014 06:00 | 17,582.3 | 1,837.2 | 19,419.5 | 19,419.5 | 102,470.0 | 1,989.9 | 1.00 | 1 |
| 03/12/2014 07:00 | 17,730.0 | 3,731.8 | 21,461.8 | 21,461.8 | 102,470.0 | 2,199.2 | 1.00 | 1 |
| 03/12/2014 08:00 | 17,642.5 | 2,011.7 | 19,654.2 | 19,654.2 | 102,470.0 | 2,014.0 | 1.00 | 1 |
| 03/12/2014 09:00 | 16,903.8 | 1,313.5 | 18,217.3 | 18,217.3 | 102,470.0 | 1,866.7 | 1.00 | 1 |
| 03/12/2014 10:00 | 16,791.8 | 1,301.8 | 18,093.6 | 18,093.6 | 102,470.0 | 1,854.1 | 1.00 | 1 |
| 03/12/2014 11:00 | 16,808.4 | 1,285.3 | 18,093.7 | 18,093.7 | 102,470.0 | 1,854.1 | 1.00 | 1 |
| 03/12/2014 12:00 | 13,259.4 | 179.4 | 13,286.3 | 13,286.3 | 102,470.0 | 1,361.4 | 1.00 | 1 |
| 03/12/2014 13:00 | 13,448.2 | 0.0 | 13,448.2 | 13,448.2 | 102,470.0 | 1,378.0 | 1.00 | 1 |
| 03/12/2014 14:00 | 12,231.6 | 0.0 | 12,231.6 | 12,231.6 | 102,470.0 | 1,253.4 | 1.00 | 1 |
| 03/12/2014 15:00 | 12,227.8 | 0.0 | 12,227.8 | 12,227.8 | 102,470.0 | 1,253.0 | 1.00 | 1 |
| 03/12/2014 16:00 | 12,219.1 | 0.0 | 12,219.1 | 12,219.1 | 102,470.0 | 1,252.1 | 1.00 | 1 |
| 03/12/2014 17:00 | 14,858.1 | 532.9 | 15,087.2 | 15,087.2 | 102,470.0 | 1,546.0 | 1.00 | 1 |
| 03/12/2014 18:00 | 17,216.2 | 1,476.7 | 18,692.9 | 18,692.9 | 102,470.0 | 1,915.5 | 1.00 | 1 |
| 03/12/2014 19:00 | 17,695.6 | 3,540.9 | 21,236.5 | 21,236.5 | 102,470.0 | 2,176.1 | 1.00 | 1 |
| 03/12/2014 20:00 | 17,769.1 | 3,729.2 | 21,498.3 | 21,498.3 | 102,470.0 | 2,202.9 | 1.00 | 1 |
| 03/12/2014 21:00 | 17,831.2 | 4,317.4 | 22,148.6 | 22,148.6 | 102,470.0 | 2,269.6 | 1.00 | 1 |
| 03/12/2014 22:00 | 17,843.7 | 4,346.8 | 22,190.5 | 22,190.5 | 102,470.0 | 2,273.9 | 1.00 | 1 |
| 03/12/2014 23:00 | 17,854.1 | 3,438.5 | 21,292.6 | 21,292.6 | 102,470.0 | 2,181.9 | 1.00 | 1 |
| **Average/Sum#:** | 15,209.7 | 1,423.5 | 16,602.5 | 398,459.8 # | 102,470.0 | 1,701.3 | 24.00 # | 24 # |
| **Minimum:** | 12,034.3 | 0.0 | 12,034.3 | 12,034.3 | 102,470.0 | 1,233.2 | 1.00 | 1 |
| **Maximum:** | 17,854.1 | 4,346.8 | 22,190.5 | 22,190.5 | 102,470.0 | 2,273.9 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/13/2014 00:00 | 16,231.8 | 404.2 | 16,353.1 | 16,353.1 | 102,470.0 | 1,675.7 | 1.00 | 1 |
| 03/13/2014 01:00 | 17,307.9 | 0.0 | 17,307.9 | 17,307.9 | 102,470.0 | 1,773.5 | 1.00 | 1 |
| 03/13/2014 02:00 | 13,591.5 | 0.0 | 13,591.5 | 13,591.5 | 102,470.0 | 1,392.7 | 1.00 | 1 |
| 03/13/2014 03:00 | 13,439.4 | 0.0 | 13,439.4 | 13,439.4 | 102,470.0 | 1,377.1 | 1.00 | 1 |
| 03/13/2014 04:00 | 13,463.9 | 0.0 | 13,463.9 | 13,463.9 | 102,470.0 | 1,379.6 | 1.00 | 1 |
| 03/13/2014 05:00 | 17,189.7 | 1,479.3 | 18,299.2 | 18,299.2 | 102,470.0 | 1,875.1 | 1.00 | 1 |
| 03/13/2014 06:00 | 17,585.5 | 1,900.3 | 19,485.8 | 19,485.8 | 102,470.0 | 1,996.7 | 1.00 | 1 |
| 03/13/2014 07:00 | 17,577.7 | 4,457.3 | 22,035.0 | 22,035.0 | 102,470.0 | 2,257.9 | 1.00 | 1 |
| 03/13/2014 08:00 | 17,885.3 | 3,284.3 | 21,169.6 | 21,169.6 | 102,470.0 | 2,169.2 | 1.00 | 1 |
| 03/13/2014 09:00 | 17,539.8 | 2,215.4 | 19,755.2 | 19,755.2 | 102,470.0 | 2,024.3 | 1.00 | 1 |
| 03/13/2014 10:00 | 17,149.3 | 1,550.4 | 18,699.7 | 18,699.7 | 102,470.0 | 1,916.2 | 1.00 | 1 |
| 03/13/2014 11:00 | 16,826.9 | 1,290.9 | 18,117.8 | 18,117.8 | 102,470.0 | 1,856.5 | 1.00 | 1 |
| 03/13/2014 12:00 | 17,374.9 | 1,350.3 | 18,725.2 | 18,725.2 | 102,470.0 | 1,918.8 | 1.00 | 1 |
| 03/13/2014 13:00 | 17,665.2 | 1,564.2 | 19,229.4 | 19,229.4 | 102,470.0 | 1,970.4 | 1.00 | 1 |
| 03/13/2014 14:00 | 17,585.5 | 1,666.5 | 19,252.0 | 19,252.0 | 102,470.0 | 1,972.8 | 1.00 | 1 |
| 03/13/2014 15:00 | 17,539.9 | 1,699.5 | 19,239.4 | 19,239.4 | 102,470.0 | 1,971.5 | 1.00 | 1 |
| 03/13/2014 16:00 | 17,261.0 | 1,462.2 | 18,723.2 | 18,723.2 | 102,470.0 | 1,918.6 | 1.00 | 1 |
| 03/13/2014 17:00 | 16,847.6 | 1,302.1 | 18,149.7 | 18,149.7 | 102,470.0 | 1,859.8 | 1.00 | 1 |
| 03/13/2014 18:00 | 17,023.1 | 1,351.2 | 18,374.3 | 18,374.3 | 102,470.0 | 1,882.8 | 1.00 | 1 |
| 03/13/2014 19:00 | 17,356.5 | 1,718.0 | 19,074.5 | 19,074.5 | 102,470.0 | 1,954.6 | 1.00 | 1 |
| 03/13/2014 20:00 | 17,186.8 | 1,320.9 | 18,507.7 | 18,507.7 | 102,470.0 | 1,896.5 | 1.00 | 1 |
| 03/13/2014 21:00 | 16,393.8 | 1,145.6 | 17,287.4 | 17,287.4 | 102,470.0 | 1,771.4 | 1.00 | 1 |
| 03/13/2014 22:00 | 14,631.4 | 0.0 | 14,631.4 | 14,631.4 | 102,470.0 | 1,499.3 | 1.00 | 1 |
| 03/13/2014 23:00 | 17,111.2 | 0.0 | 17,111.2 | 17,111.2 | 102,470.0 | 1,753.4 | 1.00 | 1 |
| **Average/Sum#:** | 16,656.9 | 1,298.4 | 17,917.6 | 430,023.5 # | 102,470.0 | 1,836.0 | 24.00 # | 24 # |
| **Minimum:** | 13,439.4 | 0.0 | 13,439.4 | 13,439.4 | 102,470.0 | 1,377.1 | 1.00 | 1 |
| **Maximum:** | 17,885.3 | 4,457.3 | 22,035.0 | 22,035.0 | 102,470.0 | 2,257.9 | 1.00 | 1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/14/2014 00:00 | 17,050.3 | 0.0 | 17,050.3 | 17,050.3 | 102,830.0 | 1,753.3 | 1.00 | 1 |
| 03/14/2014 01:00 | 13,905.9 | 0.0 | 13,905.9 | 11,541.9 | 102,830.0 | 1,429.9 | 0.83 | 0 |
| 03/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/14/2014 06:00 | 1,458.3 | 0.0 | 1,458.3 | 175.0 | 102,830.0 | 150.0 | 0.12 | 0 |
| 03/14/2014 07:00 | 8,030.4 | 0.0 | 8,030.4 | 8,030.4 | 102,830.0 | 825.8 | 1.00 | 0 |
| 03/14/2014 08:00 | 17,410.0 | 0.0 | 17,410.0 | 17,410.0 | 102,830.0 | 1,790.3 | 1.00 | 1 |
| 03/14/2014 09:00 | 17,527.8 | 0.0 | 17,527.8 | 17,527.8 | 102,830.0 | 1,802.4 | 1.00 | 1 |
| 03/14/2014 10:00 | 17,464.9 | 0.0 | 17,464.9 | 17,464.9 | 102,830.0 | 1,795.9 | 1.00 | 1 |
| 03/14/2014 11:00 | 17,362.8 | 0.0 | 17,362.8 | 17,362.8 | 102,830.0 | 1,785.4 | 1.00 | 1 |
| 03/14/2014 12:00 | 17,277.9 | 0.0 | 17,277.9 | 17,277.9 | 102,830.0 | 1,776.7 | 1.00 | 1 |
| 03/14/2014 13:00 | 17,189.5 | 0.0 | 17,189.5 | 17,189.5 | 102,830.0 | 1,767.6 | 1.00 | 1 |
| 03/14/2014 14:00 | 17,128.7 | 0.0 | 17,128.7 | 17,128.7 | 102,830.0 | 1,761.3 | 1.00 | 1 |
| 03/14/2014 15:00 | 17,100.3 | 0.0 | 17,100.3 | 17,100.3 | 102,830.0 | 1,758.4 | 1.00 | 1 |
| 03/14/2014 16:00 | 17,001.4 | 0.0 | 17,001.4 | 17,001.4 | 102,830.0 | 1,748.3 | 1.00 | 1 |
| 03/14/2014 17:00 | 16,971.5 | 0.0 | 16,971.5 | 16,971.5 | 102,830.0 | 1,745.2 | 1.00 | 1 |
| 03/14/2014 18:00 | 16,975.2 | 0.0 | 16,975.2 | 16,975.2 | 102,830.0 | 1,745.6 | 1.00 | 1 |
| 03/14/2014 19:00 | 17,111.8 | 0.0 | 17,111.8 | 17,111.8 | 102,830.0 | 1,759.6 | 1.00 | 1 |
| 03/14/2014 20:00 | 17,178.1 | 0.0 | 17,178.1 | 17,178.1 | 102,830.0 | 1,766.4 | 1.00 | 1 |
| 03/14/2014 21:00 | 17,244.4 | 0.0 | 17,244.4 | 17,244.4 | 102,830.0 | 1,773.2 | 1.00 | 1 |
| 03/14/2014 22:00 | 17,321.8 | 0.0 | 17,321.8 | 17,321.8 | 102,830.0 | 1,781.2 | 1.00 | 1 |
| 03/14/2014 23:00 | 17,379.9 | 0.0 | 17,379.9 | 17,379.9 | 102,830.0 | 1,787.2 | 1.00 | 1 |
| **Average/Sum#:** | 15,804.5 | 0.0 | 15,804.5 | 312,443.6 # | 102,830.0 | 1,625.2 | 18.95 # | 17 # |
| **Minimum:** | 1,458.3 | 0.0 | 1,458.3 | 175.0 | 102,830.0 | 150.0 | 0.00 | 0 |
| **Maximum:** | 17,527.8 | 0.0 | 17,527.8 | 17,527.8 | 102,830.0 | 1,802.4 | 1.00 | 1 |
| **%SI** | 16.7 | 16.7 | 16.7 | 16.7 | 0.0 | 16.7 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/15/2014 00:00 | 6,462.3 | 0.0 | 6,462.3 | 1,615.6 | 102,830.0 | 664.5 | 0.25 | 0 |
| 03/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 6,462.3 | 0.0 | 6,462.3 | 1,615.6 # | 102,830.0 | 664.5 | 0.25 # | 0 # |
| **Minimum:** | 6,462.3 | 0.0 | 6,462.3 | 1,615.6 | 102,830.0 | 664.5 | 0.00 | 0 |
| **Maximum:** | 6,462.3 | 0.0 | 6,462.3 | 1,615.6 | 102,830.0 | 664.5 | 0.25 | 0 |
| **%SI** | 95.8 | 95.8 | 95.8 | 95.8 | 0.0 | 95.8 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/29/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/30/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/30/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# Daily Summary Report

## CT2 - Fuel Gas Daily Summary

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlow, CT, 100scfh 1 Hour(s) | Unit CT2 GasFlow, DB, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scfh 1 Hour(s) | Unit CT2 GasFlow, Total, 100scf 1 Hour(s) | Unit CT2 GCVGas, BtuPer100scf 1 Hour(s) | Unit CT2 HI, MBtuPerHr 1 Hour(s) | Unit CT2 OperatingTime, Hr 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|---|---|
| 03/31/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| 03/31/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Average/Sum#:** | 0.0 | 0.0 | 0.0 | 0.0 # | 102,830.0 | 0.0 | 0.00 # | 0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 102,830.0 | 0.0 | 0.00 | 0 |
| **%SI** | 100.0 | 100.0 | 100.0 | 100.0 | 0.0 | 100.0 | 0.00 | 0 |

# ATTACHMENT 10
## Maximum Emissions (AQ-25)

AQ-25 Emission Limits

| Maximum Emissions Both Turbines (lbs) | | |
|---|---|---|
| Pollutant | 1-Hour Emissions | 24-Hour Emissions |
| $NO_x$ | 666.60 | 2,994.60 |
| CO | 967.00 | 7,659.00 |
| VOC | 55.40 | 630.60 |
| PM10 | 27.00 | 648.00 |
| $SO_2$ | 14.80 | 355.20 |

# Excess Emission Report

## CT1 and CT2 CO Lb/Day

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:18 **Location:** Maxwell, CA

---

**Tag Name:** ALL_CO_Lb_1D
**Total Operating Time:** 54.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 36.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 54.00 Day(s) |
| Total Duration (Online only): | 0.00 Day(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT1 and CT2 CO Lb/Hr

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:18 **Location:** Maxwell, CA

---

**Tag Name:** ALL_CO_Lb_1H
**Total Operating Time:** 1,209.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 951.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,209.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT1 and CT2 NOx Lb/Day

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** ALL_NOx_Lb_1D
**Total Operating Time:** 54.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 36.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 54.00 Day(s) |
| Total Duration (Online only): | 0.00 Day(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT1 and CT2 NOx Lb/Hr

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** ALL_NOx_Lb_1H
**Total Operating Time:** 1,209.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 951.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,209.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT1 and CT2 PM10 Lb/Day

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** ALL_PM10_Lb_1D
**Total Operating Time:** 54.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 36.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 54.00 Day(s) |
| Total Duration (Online only): | 0.00 Day(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT1 and CT2 PM10 Lb/Hr

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** ALL_PM10_Lb_1H
**Total Operating Time:** 1,209.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 951.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,209.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT1 and CT2 SO2 Lb/Day

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** ALL_SO2_Lb_1D
**Total Operating Time:** 54.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 36.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 54.00 Day(s) |
| Total Duration (Online only): | 0.00 Day(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT1 and CT2 SO2 Lb/Hr

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** ALL_SO2_Lb_1H
**Total Operating Time:** 1,209.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 951.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,209.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT1 and CT2 VOC Lb/Day

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** ALL_VOC_Lb_1D
**Total Operating Time:** 54.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 36.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 54.00 Day(s) |
| Total Duration (Online only): | 0.00 Day(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Excess Emission Report

## CT1 and CT2 VOC Lb/Hr

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/23/2014 07:19 **Location:** Maxwell, CA

---

**Tag Name:** ALL_VOC_Lb_1H
**Total Operating Time:** 1,209.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 951.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

| | |
|---|---|
| Total Operating Time: | 1,209.00 Hour(s) |
| Total Duration (Online only): | 0.00 Hour(s) |
| Time in exceedance as a percentage of operating time: | 0.00 % |
| Time in compliance as a percentage of operating time: | 100.00 % |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/01/2014 00:00 | 11.5 | 0.9 | 1.6 | 9.0 | 2.0 |
| 01/01/2014 01:00 | 12.7 | 1.0 | 1.8 | 10.0 | 2.2 |
| 01/01/2014 02:00 | 11.9 | 0.9 | 1.7 | 9.3 | 2.0 |
| 01/01/2014 03:00 | 14.1 | 18.4 | 0.6 | 3.2 | 0.7 |
| 01/01/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/01/2014 13:00 | 67.3 | 26.3 | 0.1 | 0.9 | 0.2 |
| 01/01/2014 14:00 | 66.0 | 72.4 | 0.3 | 2.8 | 0.6 |
| 01/01/2014 15:00 | 5.0 | 0.0 | 0.5 | 5.0 | 1.0 |
| 01/01/2014 16:00 | 63.8 | 28.1 | 0.7 | 5.9 | 1.2 |
| 01/01/2014 17:00 | 77.3 | 48.1 | 1.2 | 7.1 | 1.5 |
| 01/01/2014 18:00 | 12.4 | 1.6 | 1.7 | 9.7 | 2.2 |
| 01/01/2014 19:00 | 14.6 | 4.6 | 2.0 | 11.4 | 2.5 |
| 01/01/2014 20:00 | 15.1 | 3.9 | 2.2 | 11.8 | 2.6 |
| 01/01/2014 21:00 | 15.3 | 4.0 | 2.2 | 12.0 | 2.6 |
| 01/01/2014 22:00 | 14.6 | 4.3 | 2.0 | 11.5 | 2.5 |
| 01/01/2014 23:00 | 14.6 | 4.3 | 2.0 | 11.5 | 2.5 |
| **Average/Sum#:** | 416.2 # | 218.8 # | 20.6 # | 121.1 # | 26.3 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 77.3 | 72.4 | 2.2 | 12.0 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/02/2014 00:00 | 14.4 | 4.3 | 2.0 | 11.4 | 2.5 |
| 01/02/2014 01:00 | 13.0 | 1.9 | 1.9 | 10.2 | 2.2 |
| 01/02/2014 02:00 | 9.6 | 0.9 | 1.6 | 8.8 | 2.0 |
| 01/02/2014 03:00 | 12.0 | 1.0 | 1.7 | 9.5 | 2.0 |
| 01/02/2014 04:00 | 9.6 | 0.9 | 1.6 | 8.8 | 2.0 |
| 01/02/2014 05:00 | 12.6 | 2.5 | 1.8 | 9.9 | 2.2 |
| 01/02/2014 06:00 | 12.0 | 4.0 | 2.0 | 11.1 | 2.4 |
| 01/02/2014 07:00 | 14.0 | 4.0 | 2.0 | 11.0 | 2.4 |
| 01/02/2014 08:00 | 14.2 | 4.3 | 2.0 | 11.2 | 2.4 |
| 01/02/2014 09:00 | 14.4 | 4.3 | 2.0 | 11.3 | 2.4 |
| 01/02/2014 10:00 | 14.2 | 4.3 | 2.0 | 11.2 | 2.4 |
| 01/02/2014 11:00 | 14.2 | 4.3 | 2.0 | 11.1 | 2.4 |
| 01/02/2014 12:00 | 14.1 | 4.3 | 2.0 | 11.1 | 2.4 |
| 01/02/2014 13:00 | 14.1 | 3.9 | 2.0 | 11.1 | 2.4 |
| 01/02/2014 14:00 | 13.8 | 3.5 | 2.0 | 10.8 | 2.4 |
| 01/02/2014 15:00 | 14.0 | 3.8 | 2.0 | 11.0 | 2.4 |
| 01/02/2014 16:00 | 14.1 | 3.8 | 2.0 | 11.1 | 2.4 |
| 01/02/2014 17:00 | 14.2 | 3.8 | 2.0 | 11.1 | 2.4 |
| 01/02/2014 18:00 | 14.9 | 3.9 | 2.1 | 11.7 | 2.6 |
| 01/02/2014 19:00 | 17.2 | 3.2 | 2.2 | 11.8 | 2.6 |
| 01/02/2014 20:00 | 15.0 | 3.5 | 2.1 | 11.8 | 2.6 |
| 01/02/2014 21:00 | 17.0 | 3.9 | 2.1 | 11.7 | 2.6 |
| 01/02/2014 22:00 | 14.6 | 4.0 | 2.0 | 11.4 | 2.5 |
| 01/02/2014 23:00 | 17.1 | 4.0 | 2.1 | 11.8 | 2.6 |
| **Average/Sum#:** | 334.3 # | 82.3 # | 47.2 # | 261.9 # | 57.2 # |
| **Minimum:** | 9.6 | 0.9 | 1.6 | 8.8 | 2.0 |
| **Maximum:** | 17.2 | 4.3 | 2.2 | 11.8 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/03/2014 00:00 | 14.2 | 3.6 | 2.0 | 11.1 | 2.4 |
| 01/03/2014 01:00 | 12.2 | 1.6 | 1.7 | 9.7 | 2.1 |
| 01/03/2014 02:00 | 7.9 | 0.7 | 1.3 | 7.3 | 1.6 |
| 01/03/2014 03:00 | 7.5 | 0.7 | 1.3 | 6.8 | 1.4 |
| 01/03/2014 04:00 | 7.5 | 0.7 | 1.3 | 6.9 | 1.5 |
| 01/03/2014 05:00 | 7.5 | 0.9 | 1.3 | 6.9 | 1.5 |
| 01/03/2014 06:00 | 10.8 | 1.9 | 1.6 | 8.6 | 1.8 |
| 01/03/2014 07:00 | 13.5 | 3.6 | 1.9 | 10.5 | 2.3 |
| 01/03/2014 08:00 | 14.0 | 3.7 | 2.0 | 11.0 | 2.4 |
| 01/03/2014 09:00 | 14.4 | 4.3 | 2.0 | 11.3 | 2.4 |
| 01/03/2014 10:00 | 14.4 | 4.3 | 2.0 | 11.3 | 2.4 |
| 01/03/2014 11:00 | 14.2 | 4.3 | 2.0 | 11.2 | 2.4 |
| 01/03/2014 12:00 | 14.1 | 4.0 | 2.0 | 11.1 | 2.4 |
| 01/03/2014 13:00 | 13.9 | 3.9 | 2.0 | 10.9 | 2.4 |
| 01/03/2014 14:00 | 13.9 | 4.0 | 2.0 | 10.9 | 2.4 |
| 01/03/2014 15:00 | 13.6 | 3.3 | 2.0 | 10.7 | 2.4 |
| 01/03/2014 16:00 | 14.0 | 4.3 | 2.0 | 11.0 | 2.4 |
| 01/03/2014 17:00 | 14.4 | 4.1 | 2.0 | 11.3 | 2.4 |
| 01/03/2014 18:00 | 15.0 | 3.8 | 2.1 | 11.8 | 2.6 |
| 01/03/2014 19:00 | 16.9 | 3.9 | 2.1 | 11.6 | 2.6 |
| 01/03/2014 20:00 | 14.8 | 3.9 | 2.1 | 11.6 | 2.6 |
| 01/03/2014 21:00 | 17.8 | 2.8 | 2.3 | 12.2 | 2.6 |
| 01/03/2014 22:00 | 17.5 | 3.2 | 2.2 | 12.1 | 2.6 |
| 01/03/2014 23:00 | 17.2 | 3.5 | 2.2 | 11.8 | 2.6 |
| **Average/Sum#:** | 321.2 # | 75.0 # | 45.4 # | 249.6 # | 54.2 # |
| **Minimum:** | 7.5 | 0.7 | 1.3 | 6.8 | 1.4 |
| **Maximum:** | 17.8 | 4.3 | 2.3 | 12.2 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/04/2014 00:00 | 14.4 | 4.0 | 2.0 | 11.3 | 2.4 |
| 01/04/2014 01:00 | 14.7 | 4.0 | 2.0 | 11.5 | 2.5 |
| 01/04/2014 02:00 | 9.7 | 0.9 | 1.6 | 9.0 | 2.0 |
| 01/04/2014 03:00 | 9.6 | 0.9 | 1.6 | 8.8 | 2.0 |
| 01/04/2014 04:00 | 7.1 | 0.8 | 1.4 | 7.9 | 1.8 |
| 01/04/2014 05:00 | 9.9 | 0.9 | 1.7 | 9.1 | 2.0 |
| 01/04/2014 06:00 | 10.0 | 0.9 | 1.7 | 9.2 | 2.0 |
| 01/04/2014 07:00 | 12.8 | 1.0 | 1.9 | 10.1 | 2.2 |
| 01/04/2014 08:00 | 13.4 | 3.0 | 1.9 | 10.6 | 2.3 |
| 01/04/2014 09:00 | 14.9 | 4.9 | 2.1 | 11.7 | 2.6 |
| 01/04/2014 10:00 | 14.4 | 4.3 | 2.0 | 11.3 | 2.4 |
| 01/04/2014 11:00 | 13.9 | 3.6 | 2.0 | 10.9 | 2.4 |
| 01/04/2014 12:00 | 13.4 | 2.7 | 1.9 | 10.6 | 2.3 |
| 01/04/2014 13:00 | 13.1 | 2.7 | 1.9 | 10.3 | 2.2 |
| 01/04/2014 14:00 | 15.9 | 3.6 | 2.0 | 10.9 | 2.4 |
| 01/04/2014 15:00 | 16.2 | 3.8 | 2.0 | 11.1 | 2.4 |
| 01/04/2014 16:00 | 16.4 | 3.8 | 2.0 | 11.3 | 2.4 |
| 01/04/2014 17:00 | 16.7 | 4.0 | 2.1 | 11.5 | 2.5 |
| 01/04/2014 18:00 | 17.1 | 3.9 | 2.1 | 11.7 | 2.6 |
| 01/04/2014 19:00 | 17.2 | 3.2 | 2.1 | 11.7 | 2.6 |
| 01/04/2014 20:00 | 16.4 | 4.0 | 2.0 | 11.3 | 2.4 |
| 01/04/2014 21:00 | 17.6 | 3.2 | 2.2 | 12.1 | 2.6 |
| 01/04/2014 22:00 | 17.8 | 2.9 | 2.3 | 12.2 | 2.6 |
| 01/04/2014 23:00 | 16.5 | 3.6 | 2.0 | 11.3 | 2.4 |
| **Average/Sum#:** | 339.1 # | 70.6 # | 46.5 # | 257.4 # | 56.0 # |
| **Minimum:** | 7.1 | 0.8 | 1.4 | 7.9 | 1.8 |
| **Maximum:** | 17.8 | 4.9 | 2.3 | 12.2 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/05/2014 00:00 | 14.3 | 3.7 | 2.0 | 11.3 | 2.4 |
| 01/05/2014 01:00 | 16.7 | 3.9 | 2.0 | 11.5 | 2.5 |
| 01/05/2014 02:00 | 11.3 | 0.9 | 1.6 | 8.9 | 2.0 |
| 01/05/2014 03:00 | 11.2 | 0.6 | 1.6 | 8.8 | 2.0 |
| 01/05/2014 04:00 | 11.9 | 1.0 | 1.7 | 9.3 | 2.0 |
| 01/05/2014 05:00 | 12.8 | 1.0 | 1.8 | 10.1 | 2.2 |
| 01/05/2014 06:00 | 13.3 | 3.3 | 1.9 | 10.4 | 2.2 |
| 01/05/2014 07:00 | 16.9 | 4.6 | 2.1 | 11.6 | 2.6 |
| 01/05/2014 08:00 | 17.9 | 3.2 | 2.3 | 12.4 | 2.7 |
| 01/05/2014 09:00 | 17.7 | 3.2 | 2.2 | 12.2 | 2.6 |
| 01/05/2014 10:00 | 16.6 | 4.0 | 2.0 | 11.4 | 2.5 |
| 01/05/2014 11:00 | 16.0 | 3.3 | 2.0 | 11.0 | 2.4 |
| 01/05/2014 12:00 | 13.4 | 2.7 | 1.9 | 10.6 | 2.3 |
| 01/05/2014 13:00 | 15.6 | 3.0 | 2.0 | 10.8 | 2.4 |
| 01/05/2014 14:00 | 16.1 | 4.0 | 2.0 | 11.1 | 2.4 |
| 01/05/2014 15:00 | 9.8 | 0.9 | 1.6 | 9.0 | 2.0 |
| 01/05/2014 16:00 | 13.1 | 2.6 | 1.9 | 10.3 | 2.2 |
| 01/05/2014 17:00 | 17.4 | 3.2 | 2.2 | 12.0 | 2.6 |
| 01/05/2014 18:00 | 17.8 | 2.9 | 2.2 | 12.2 | 2.6 |
| 01/05/2014 19:00 | 17.8 | 2.6 | 2.2 | 12.2 | 2.6 |
| 01/05/2014 20:00 | 17.9 | 2.6 | 2.3 | 12.3 | 2.6 |
| 01/05/2014 21:00 | 17.9 | 2.6 | 2.3 | 12.2 | 2.6 |
| 01/05/2014 22:00 | 17.9 | 2.9 | 2.3 | 12.4 | 2.7 |
| 01/05/2014 23:00 | 17.6 | 3.2 | 2.2 | 12.1 | 2.6 |
| **Average/Sum#:** | 368.9 # | 65.9 # | 48.3 # | 266.1 # | 57.7 # |
| **Minimum:** | 9.8 | 0.6 | 1.6 | 8.8 | 2.0 |
| **Maximum:** | 17.9 | 4.6 | 2.3 | 12.4 | 2.7 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/06/2014 00:00 | 17.5 | 3.6 | 2.2 | 12.0 | 2.6 |
| 01/06/2014 01:00 | 16.9 | 4.0 | 2.1 | 11.6 | 2.6 |
| 01/06/2014 02:00 | 17.2 | 4.0 | 2.2 | 11.8 | 2.6 |
| 01/06/2014 03:00 | 16.2 | 3.7 | 2.0 | 11.2 | 2.4 |
| 01/06/2014 04:00 | 16.2 | 3.4 | 2.0 | 11.1 | 2.4 |
| 01/06/2014 05:00 | 17.4 | 4.0 | 2.2 | 12.0 | 2.6 |
| 01/06/2014 06:00 | 14.6 | 4.0 | 2.0 | 11.5 | 2.5 |
| 01/06/2014 07:00 | 16.4 | 4.0 | 2.0 | 11.3 | 2.4 |
| 01/06/2014 08:00 | 17.4 | 4.0 | 2.2 | 12.0 | 2.6 |
| 01/06/2014 09:00 | 15.0 | 4.4 | 2.2 | 11.8 | 2.6 |
| 01/06/2014 10:00 | 17.4 | 4.3 | 2.2 | 12.0 | 2.6 |
| 01/06/2014 11:00 | 17.7 | 3.6 | 2.2 | 12.2 | 2.6 |
| 01/06/2014 12:00 | 17.8 | 3.2 | 2.2 | 12.2 | 2.6 |
| 01/06/2014 13:00 | 17.9 | 3.2 | 2.3 | 12.2 | 2.6 |
| 01/06/2014 14:00 | 17.1 | 3.2 | 2.1 | 11.8 | 2.6 |
| 01/06/2014 15:00 | 14.1 | 3.7 | 2.0 | 11.1 | 2.4 |
| 01/06/2014 16:00 | 14.2 | 3.7 | 2.0 | 11.1 | 2.4 |
| 01/06/2014 17:00 | 14.6 | 4.3 | 2.1 | 11.5 | 2.5 |
| 01/06/2014 18:00 | 14.8 | 4.0 | 2.1 | 11.6 | 2.6 |
| 01/06/2014 19:00 | 17.9 | 3.2 | 2.3 | 12.3 | 2.7 |
| 01/06/2014 20:00 | 17.0 | 4.0 | 2.1 | 11.7 | 2.6 |
| 01/06/2014 21:00 | 18.0 | 3.3 | 2.3 | 12.4 | 2.7 |
| 01/06/2014 22:00 | 18.1 | 3.2 | 2.3 | 12.4 | 2.7 |
| 01/06/2014 23:00 | 17.0 | 4.0 | 2.1 | 11.8 | 2.6 |
| **Average/Sum#:** | 398.4 # | 90.0 # | 51.4 # | 282.6 # | 61.5 # |
| **Minimum:** | 14.1 | 3.2 | 2.0 | 11.1 | 2.4 |
| **Maximum:** | 18.1 | 4.4 | 2.3 | 12.4 | 2.7 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/07/2014 00:00 | 13.9 | 3.4 | 2.0 | 10.9 | 2.4 |
| 01/07/2014 01:00 | 12.3 | 1.8 | 1.7 | 9.7 | 2.1 |
| 01/07/2014 02:00 | 9.0 | 0.8 | 1.4 | 8.2 | 1.8 |
| 01/07/2014 03:00 | 9.6 | 0.9 | 1.6 | 8.8 | 2.0 |
| 01/07/2014 04:00 | 9.5 | 0.9 | 1.6 | 8.6 | 1.8 |
| 01/07/2014 05:00 | 11.2 | 0.9 | 1.6 | 8.8 | 2.0 |
| 01/07/2014 06:00 | 12.7 | 2.5 | 1.8 | 10.0 | 2.2 |
| 01/07/2014 07:00 | 14.2 | 4.0 | 2.0 | 11.1 | 2.4 |
| 01/07/2014 08:00 | 17.4 | 4.0 | 2.2 | 11.9 | 2.6 |
| 01/07/2014 09:00 | 17.3 | 4.0 | 2.2 | 11.9 | 2.6 |
| 01/07/2014 10:00 | 14.7 | 4.0 | 2.0 | 11.6 | 2.5 |
| 01/07/2014 11:00 | 14.5 | 4.0 | 2.0 | 11.4 | 2.5 |
| 01/07/2014 12:00 | 17.9 | 3.6 | 2.2 | 12.2 | 2.6 |
| 01/07/2014 13:00 | 17.8 | 3.5 | 2.2 | 12.2 | 2.6 |
| 01/07/2014 14:00 | 16.6 | 4.3 | 2.0 | 11.5 | 2.5 |
| 01/07/2014 15:00 | 16.7 | 4.3 | 2.1 | 11.5 | 2.5 |
| 01/07/2014 16:00 | 14.0 | 3.7 | 2.0 | 11.1 | 2.4 |
| 01/07/2014 17:00 | 14.0 | 4.0 | 2.0 | 11.1 | 2.4 |
| 01/07/2014 18:00 | 14.4 | 4.6 | 2.0 | 11.3 | 2.4 |
| 01/07/2014 19:00 | 17.5 | 4.3 | 2.2 | 12.0 | 2.6 |
| 01/07/2014 20:00 | 17.9 | 3.2 | 2.3 | 12.4 | 2.7 |
| 01/07/2014 21:00 | 14.6 | 4.0 | 2.0 | 11.5 | 2.5 |
| 01/07/2014 22:00 | 14.4 | 4.0 | 2.0 | 11.3 | 2.4 |
| 01/07/2014 23:00 | 13.2 | 2.9 | 1.9 | 10.4 | 2.2 |
| **Average/Sum#:** | 345.3 # | 77.6 # | 47.0 # | 261.4 # | 56.7 # |
| **Minimum:** | 9.0 | 0.8 | 1.4 | 8.2 | 1.8 |
| **Maximum:** | 17.9 | 4.6 | 2.3 | 12.4 | 2.7 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/08/2014 00:00 | 8.2 | 0.8 | 1.4 | 7.5 | 1.6 |
| 01/08/2014 01:00 | 6.5 | 0.7 | 1.3 | 7.2 | 1.6 |
| 01/08/2014 02:00 | 7.8 | 0.7 | 1.3 | 7.1 | 1.6 |
| 01/08/2014 03:00 | 7.6 | 1.0 | 1.3 | 7.0 | 1.6 |
| 01/08/2014 04:00 | 7.8 | 1.0 | 1.3 | 7.1 | 1.6 |
| 01/08/2014 05:00 | 11.5 | 1.2 | 1.6 | 9.0 | 2.0 |
| 01/08/2014 06:00 | 12.0 | 2.1 | 1.7 | 9.5 | 2.0 |
| 01/08/2014 07:00 | 15.6 | 3.0 | 1.9 | 10.7 | 2.4 |
| 01/08/2014 08:00 | 14.2 | 3.7 | 2.0 | 11.1 | 2.4 |
| 01/08/2014 09:00 | 12.5 | 1.9 | 1.7 | 9.8 | 2.2 |
| 01/08/2014 10:00 | 6.2 | 0.9 | 1.3 | 6.8 | 1.4 |
| 01/08/2014 11:00 | 8.3 | 1.0 | 1.4 | 7.5 | 1.6 |
| 01/08/2014 12:00 | 11.9 | 0.9 | 1.7 | 9.4 | 2.0 |
| 01/08/2014 13:00 | 8.9 | 0.8 | 1.4 | 8.2 | 1.8 |
| 01/08/2014 14:00 | 7.5 | 0.7 | 1.3 | 6.9 | 1.6 |
| 01/08/2014 15:00 | 8.4 | 0.8 | 1.4 | 7.7 | 1.6 |
| 01/08/2014 16:00 | 9.2 | 0.9 | 1.6 | 8.4 | 1.8 |
| 01/08/2014 17:00 | 12.6 | 3.1 | 1.8 | 9.9 | 2.2 |
| 01/08/2014 18:00 | 7.2 | 0.8 | 1.4 | 7.9 | 1.8 |
| 01/08/2014 19:00 | 7.7 | 0.9 | 1.6 | 8.4 | 1.8 |
| 01/08/2014 20:00 | 9.0 | 0.8 | 1.4 | 8.2 | 1.8 |
| 01/08/2014 21:00 | 7.5 | 0.8 | 1.4 | 8.2 | 1.8 |
| 01/08/2014 22:00 | 9.8 | 9.5 | 0.2 | 1.1 | 0.2 |
| 01/08/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 217.9 # | 38.0 # | 33.4 # | 184.6 # | 40.4 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 15.6 | 9.5 | 2.0 | 11.1 | 2.4 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/09/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/09/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/10/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/12/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/13/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/14/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/15/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 08:00 | 71.1 | 117.1 | 0.1 | 0.9 | 0.2 |
| 01/29/2014 09:00 | 123.8 | 33.9 | 0.2 | 1.8 | 0.4 |
| 01/29/2014 10:00 | 42.2 | 49.9 | 0.2 | 1.9 | 0.4 |
| 01/29/2014 11:00 | 53.8 | 43.1 | 0.2 | 1.9 | 0.4 |
| 01/29/2014 12:00 | 56.1 | 36.7 | 0.4 | 3.9 | 0.8 |
| 01/29/2014 13:00 | 7.3 | 0.0 | 0.5 | 5.5 | 1.1 |
| 01/29/2014 14:00 | 101.7 | 121.4 | 0.8 | 6.5 | 1.4 |
| 01/29/2014 15:00 | 88.7 | 40.4 | 1.0 | 6.9 | 1.5 |
| 01/29/2014 16:00 | 5.2 | 0.7 | 1.3 | 7.2 | 1.6 |
| 01/29/2014 17:00 | 7.7 | 0.9 | 1.6 | 8.5 | 1.8 |
| 01/29/2014 18:00 | 12.8 | 1.0 | 1.8 | 10.0 | 2.2 |
| 01/29/2014 19:00 | 12.8 | 1.0 | 1.8 | 9.9 | 2.2 |
| 01/29/2014 20:00 | 10.6 | 1.0 | 1.7 | 9.7 | 2.2 |
| 01/29/2014 21:00 | 10.8 | 1.0 | 1.8 | 9.9 | 2.2 |
| 01/29/2014 22:00 | 8.3 | 0.9 | 1.7 | 9.2 | 2.0 |
| 01/29/2014 23:00 | 6.5 | 1.0 | 1.3 | 7.1 | 1.6 |
| **Average/Sum#:** | 619.4 # | 450.0 # | 16.4 # | 100.8 # | 22.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 123.8 | 121.4 | 1.8 | 10.0 | 2.2 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/30/2014 00:00 | 7.3 | 1.1 | 1.4 | 8.1 | 1.8 |
| 01/30/2014 01:00 | 12.3 | 1.3 | 1.7 | 9.7 | 2.2 |
| 01/30/2014 02:00 | 6.7 | 1.0 | 1.3 | 7.3 | 1.6 |
| 01/30/2014 03:00 | 6.3 | 0.9 | 1.3 | 6.9 | 1.6 |
| 01/30/2014 04:00 | 6.5 | 1.0 | 1.3 | 7.1 | 1.6 |
| 01/30/2014 05:00 | 6.3 | 1.0 | 1.3 | 6.9 | 1.6 |
| 01/30/2014 06:00 | 8.7 | 1.1 | 1.4 | 8.0 | 1.8 |
| 01/30/2014 07:00 | 9.2 | 1.2 | 1.6 | 8.5 | 1.8 |
| 01/30/2014 08:00 | 7.8 | 1.2 | 1.6 | 8.6 | 1.8 |
| 01/30/2014 09:00 | 6.2 | 1.0 | 1.3 | 6.8 | 1.4 |
| 01/30/2014 10:00 | 7.6 | 1.1 | 1.6 | 8.4 | 1.8 |
| 01/30/2014 11:00 | 13.2 | 2.3 | 1.9 | 10.4 | 2.3 |
| 01/30/2014 12:00 | 13.6 | 3.9 | 1.9 | 10.7 | 2.3 |
| 01/30/2014 13:00 | 14.6 | 4.9 | 2.0 | 11.5 | 2.5 |
| 01/30/2014 14:00 | 17.5 | 3.5 | 2.2 | 12.0 | 2.6 |
| 01/30/2014 15:00 | 17.7 | 3.2 | 2.2 | 12.2 | 2.6 |
| 01/30/2014 16:00 | 11.2 | 2.5 | 1.9 | 10.3 | 2.2 |
| 01/30/2014 17:00 | 7.8 | 0.9 | 1.6 | 8.6 | 1.8 |
| 01/30/2014 18:00 | 8.2 | 0.9 | 1.6 | 9.0 | 2.0 |
| 01/30/2014 19:00 | 13.5 | 3.5 | 1.9 | 10.6 | 2.4 |
| 01/30/2014 20:00 | 14.4 | 4.2 | 2.0 | 11.4 | 2.5 |
| 01/30/2014 21:00 | 14.4 | 4.2 | 2.0 | 11.3 | 2.4 |
| 01/30/2014 22:00 | 13.8 | 3.6 | 2.0 | 10.9 | 2.4 |
| 01/30/2014 23:00 | 13.5 | 2.9 | 1.9 | 10.6 | 2.3 |
| **Average/Sum#:** | 258.3 # | 52.4 # | 40.9 # | 225.8 # | 49.3 # |
| **Minimum:** | 6.2 | 0.9 | 1.3 | 6.8 | 1.4 |
| **Maximum:** | 17.7 | 4.9 | 2.2 | 12.2 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 01/31/2014 00:00 | 7.8 | 0.9 | 1.6 | 8.5 | 1.8 |
| 01/31/2014 01:00 | 7.5 | 0.8 | 1.4 | 8.2 | 1.8 |
| 01/31/2014 02:00 | 11.4 | 0.9 | 1.6 | 9.0 | 2.0 |
| 01/31/2014 03:00 | 7.0 | 0.8 | 1.4 | 7.7 | 1.6 |
| 01/31/2014 04:00 | 7.9 | 1.0 | 1.3 | 7.3 | 1.6 |
| 01/31/2014 05:00 | 12.4 | 1.0 | 1.7 | 9.7 | 2.2 |
| 01/31/2014 06:00 | 13.2 | 2.7 | 1.9 | 10.3 | 2.3 |
| 01/31/2014 07:00 | 13.2 | 1.7 | 1.9 | 10.3 | 2.2 |
| 01/31/2014 08:00 | 13.5 | 2.0 | 1.9 | 10.6 | 2.3 |
| 01/31/2014 09:00 | 11.5 | 2.0 | 1.9 | 10.4 | 2.3 |
| 01/31/2014 10:00 | 13.3 | 2.4 | 1.9 | 10.4 | 2.3 |
| 01/31/2014 11:00 | 13.5 | 3.0 | 1.9 | 10.6 | 2.3 |
| 01/31/2014 12:00 | 13.9 | 4.0 | 2.0 | 10.9 | 2.4 |
| 01/31/2014 13:00 | 13.9 | 3.7 | 2.0 | 10.9 | 2.4 |
| 01/31/2014 14:00 | 13.6 | 3.0 | 1.9 | 10.7 | 2.4 |
| 01/31/2014 15:00 | 13.5 | 3.1 | 1.9 | 10.6 | 2.3 |
| 01/31/2014 16:00 | 13.4 | 3.0 | 1.9 | 10.6 | 2.3 |
| 01/31/2014 17:00 | 13.6 | 3.0 | 1.9 | 10.7 | 2.4 |
| 01/31/2014 18:00 | 13.4 | 3.0 | 1.9 | 10.6 | 2.3 |
| 01/31/2014 19:00 | 14.6 | 4.3 | 2.0 | 11.4 | 2.5 |
| 01/31/2014 20:00 | 14.1 | 3.7 | 2.0 | 11.1 | 2.4 |
| 01/31/2014 21:00 | 14.4 | 4.3 | 2.0 | 11.3 | 2.4 |
| 01/31/2014 22:00 | 14.9 | 4.3 | 2.1 | 11.7 | 2.6 |
| 01/31/2014 23:00 | 14.8 | 4.0 | 2.1 | 11.6 | 2.6 |
| **Average/Sum#:** | 300.3 # | 62.6 # | 44.1 # | 245.1 # | 53.7 # |
| **Minimum:** | 7.0 | 0.8 | 1.3 | 7.3 | 1.6 |
| **Maximum:** | 14.9 | 4.3 | 2.1 | 11.7 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/01/2014 00:00 | 12.6 | 2.2 | 1.7 | 9.9 | 2.2 |
| 02/01/2014 01:00 | 8.1 | 0.9 | 1.6 | 9.0 | 2.0 |
| 02/01/2014 02:00 | 9.9 | 0.9 | 1.7 | 9.1 | 2.0 |
| 02/01/2014 03:00 | 12.4 | 1.0 | 1.7 | 9.9 | 2.2 |
| 02/01/2014 04:00 | 7.3 | 0.8 | 1.4 | 8.1 | 1.8 |
| 02/01/2014 05:00 | 13.1 | 3.3 | 1.9 | 10.2 | 2.2 |
| 02/01/2014 06:00 | 17.8 | 4.6 | 2.2 | 12.3 | 2.7 |
| 02/01/2014 07:00 | 17.8 | 3.9 | 2.2 | 12.3 | 2.7 |
| 02/01/2014 08:00 | 15.3 | 4.3 | 2.2 | 12.0 | 2.6 |
| 02/01/2014 09:00 | 14.9 | 4.4 | 2.1 | 11.6 | 2.6 |
| 02/01/2014 10:00 | 12.9 | 2.3 | 1.9 | 10.2 | 2.2 |
| 02/01/2014 11:00 | 7.8 | 0.9 | 1.6 | 8.6 | 1.8 |
| 02/01/2014 12:00 | 7.7 | 0.9 | 1.6 | 8.4 | 1.8 |
| 02/01/2014 13:00 | 9.6 | 0.9 | 1.6 | 8.8 | 2.0 |
| 02/01/2014 14:00 | 8.6 | 0.8 | 1.4 | 7.9 | 1.8 |
| 02/01/2014 15:00 | 6.3 | 0.7 | 1.3 | 6.9 | 1.6 |
| 02/01/2014 16:00 | 6.5 | 0.8 | 1.3 | 7.2 | 1.6 |
| 02/01/2014 17:00 | 11.9 | 2.1 | 1.7 | 9.3 | 2.0 |
| 02/01/2014 18:00 | 14.1 | 4.3 | 2.0 | 11.1 | 2.4 |
| 02/01/2014 19:00 | 17.6 | 3.9 | 2.2 | 12.1 | 2.6 |
| 02/01/2014 20:00 | 17.9 | 3.5 | 2.3 | 12.4 | 2.7 |
| 02/01/2014 21:00 | 18.0 | 3.5 | 2.3 | 12.4 | 2.7 |
| 02/01/2014 22:00 | 18.0 | 3.6 | 2.3 | 12.4 | 2.7 |
| 02/01/2014 23:00 | 17.8 | 4.0 | 2.2 | 12.3 | 2.7 |
| **Average/Sum#:** | 303.9 # | 58.5 # | 44.4 # | 244.4 # | 53.6 # |
| **Minimum:** | 6.3 | 0.7 | 1.3 | 6.9 | 1.6 |
| **Maximum:** | 18.0 | 4.6 | 2.3 | 12.4 | 2.7 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/02/2014 00:00 | 17.4 | 4.3 | 2.2 | 12.0 | 2.6 |
| 02/02/2014 01:00 | 14.6 | 4.7 | 2.0 | 11.5 | 2.5 |
| 02/02/2014 02:00 | 14.6 | 4.7 | 2.0 | 11.5 | 2.5 |
| 02/02/2014 03:00 | 14.6 | 4.3 | 2.1 | 11.5 | 2.5 |
| 02/02/2014 04:00 | 14.3 | 4.1 | 2.0 | 11.3 | 2.4 |
| 02/02/2014 05:00 | 14.3 | 4.1 | 2.0 | 11.3 | 2.4 |
| 02/02/2014 06:00 | 14.4 | 4.4 | 2.0 | 11.3 | 2.4 |
| 02/02/2014 07:00 | 17.7 | 4.6 | 2.2 | 12.2 | 2.6 |
| 02/02/2014 08:00 | 18.0 | 4.7 | 2.3 | 12.4 | 2.7 |
| 02/02/2014 09:00 | 18.0 | 4.4 | 2.3 | 12.4 | 2.7 |
| 02/02/2014 10:00 | 18.0 | 3.9 | 2.3 | 12.4 | 2.7 |
| 02/02/2014 11:00 | 18.0 | 3.6 | 2.3 | 12.4 | 2.7 |
| 02/02/2014 12:00 | 17.9 | 3.6 | 2.3 | 12.3 | 2.7 |
| 02/02/2014 13:00 | 17.8 | 3.6 | 2.2 | 12.2 | 2.6 |
| 02/02/2014 14:00 | 14.6 | 4.3 | 2.0 | 11.5 | 2.5 |
| 02/02/2014 15:00 | 17.8 | 3.5 | 2.2 | 12.2 | 2.6 |
| 02/02/2014 16:00 | 18.1 | 3.2 | 2.3 | 12.4 | 2.7 |
| 02/02/2014 17:00 | 15.1 | 4.0 | 2.2 | 11.8 | 2.6 |
| 02/02/2014 18:00 | 13.9 | 3.0 | 2.0 | 10.9 | 2.4 |
| 02/02/2014 19:00 | 14.9 | 4.3 | 2.1 | 11.6 | 2.6 |
| 02/02/2014 20:00 | 17.8 | 3.9 | 2.2 | 12.2 | 2.6 |
| 02/02/2014 21:00 | 18.0 | 3.5 | 2.3 | 12.4 | 2.7 |
| 02/02/2014 22:00 | 15.2 | 4.3 | 2.2 | 12.0 | 2.6 |
| 02/02/2014 23:00 | 17.9 | 3.6 | 2.3 | 12.3 | 2.7 |
| **Average/Sum#:** | 392.9 # | 96.6 # | 52.0 # | 286.0 # | 62.0 # |
| **Minimum:** | 13.9 | 3.0 | 2.0 | 10.9 | 2.4 |
| **Maximum:** | 18.1 | 4.7 | 2.3 | 12.4 | 2.7 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/03/2014 00:00 | 17.8 | 3.6 | 2.2 | 12.2 | 2.6 |
| 02/03/2014 01:00 | 14.7 | 4.3 | 2.1 | 11.6 | 2.5 |
| 02/03/2014 02:00 | 14.1 | 3.7 | 2.0 | 11.1 | 2.4 |
| 02/03/2014 03:00 | 13.9 | 3.4 | 2.0 | 10.9 | 2.4 |
| 02/03/2014 04:00 | 14.2 | 3.7 | 2.0 | 11.1 | 2.4 |
| 02/03/2014 05:00 | 14.9 | 5.0 | 2.1 | 11.6 | 2.6 |
| 02/03/2014 06:00 | 14.4 | 4.3 | 2.0 | 11.4 | 2.5 |
| 02/03/2014 07:00 | 14.5 | 4.6 | 2.0 | 11.4 | 2.5 |
| 02/03/2014 08:00 | 15.6 | 4.7 | 2.2 | 12.3 | 2.7 |
| 02/03/2014 09:00 | 15.3 | 4.3 | 2.2 | 12.0 | 2.6 |
| 02/03/2014 10:00 | 14.6 | 4.4 | 2.0 | 11.5 | 2.5 |
| 02/03/2014 11:00 | 13.3 | 3.0 | 1.9 | 10.5 | 2.3 |
| 02/03/2014 12:00 | 13.5 | 3.0 | 1.9 | 10.7 | 2.3 |
| 02/03/2014 13:00 | 14.0 | 4.0 | 2.0 | 10.9 | 2.4 |
| 02/03/2014 14:00 | 14.1 | 4.3 | 2.0 | 11.1 | 2.4 |
| 02/03/2014 15:00 | 13.7 | 3.3 | 2.0 | 10.8 | 2.4 |
| 02/03/2014 16:00 | 13.9 | 4.0 | 2.0 | 10.9 | 2.4 |
| 02/03/2014 17:00 | 14.6 | 4.0 | 2.0 | 11.4 | 2.5 |
| 02/03/2014 18:00 | 17.7 | 3.5 | 2.2 | 12.2 | 2.6 |
| 02/03/2014 19:00 | 18.1 | 3.2 | 2.3 | 12.4 | 2.7 |
| 02/03/2014 20:00 | 18.1 | 3.2 | 2.3 | 12.4 | 2.7 |
| 02/03/2014 21:00 | 18.0 | 3.2 | 2.3 | 12.4 | 2.7 |
| 02/03/2014 22:00 | 17.8 | 3.6 | 2.2 | 12.2 | 2.6 |
| 02/03/2014 23:00 | 14.9 | 4.0 | 2.1 | 11.8 | 2.6 |
| **Average/Sum#:** | 365.7 # | 92.3 # | 50.0 # | 276.8 # | 60.3 # |
| **Minimum:** | 13.3 | 3.0 | 1.9 | 10.5 | 2.3 |
| **Maximum:** | 18.1 | 5.0 | 2.3 | 12.4 | 2.7 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/04/2014 00:00 | 14.6 | 4.4 | 2.0 | 11.5 | 2.5 |
| 02/04/2014 01:00 | 14.2 | 3.7 | 2.0 | 11.1 | 2.4 |
| 02/04/2014 02:00 | 13.6 | 3.0 | 1.9 | 10.7 | 2.4 |
| 02/04/2014 03:00 | 13.9 | 3.4 | 2.0 | 10.9 | 2.4 |
| 02/04/2014 04:00 | 13.2 | 3.0 | 1.9 | 10.3 | 2.2 |
| 02/04/2014 05:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/04/2014 06:00 | 14.1 | 4.0 | 2.0 | 11.1 | 2.4 |
| 02/04/2014 07:00 | 14.3 | 4.0 | 2.0 | 11.2 | 2.4 |
| 02/04/2014 08:00 | 14.4 | 4.0 | 2.0 | 11.2 | 2.4 |
| 02/04/2014 09:00 | 13.9 | 3.4 | 2.0 | 10.9 | 2.4 |
| 02/04/2014 10:00 | 14.2 | 4.0 | 2.0 | 11.1 | 2.4 |
| 02/04/2014 11:00 | 14.2 | 4.0 | 2.0 | 11.1 | 2.4 |
| 02/04/2014 12:00 | 13.9 | 3.4 | 2.0 | 10.9 | 2.4 |
| 02/04/2014 13:00 | 13.5 | 3.0 | 1.9 | 10.6 | 2.3 |
| 02/04/2014 14:00 | 14.1 | 4.3 | 2.0 | 11.1 | 2.4 |
| 02/04/2014 15:00 | 14.4 | 4.6 | 2.0 | 11.3 | 2.4 |
| 02/04/2014 16:00 | 14.2 | 4.3 | 2.0 | 11.1 | 2.4 |
| 02/04/2014 17:00 | 14.2 | 4.3 | 2.0 | 11.2 | 2.4 |
| 02/04/2014 18:00 | 14.8 | 4.7 | 2.1 | 11.6 | 2.6 |
| 02/04/2014 19:00 | 17.7 | 3.9 | 2.2 | 12.2 | 2.6 |
| 02/04/2014 20:00 | 17.4 | 4.3 | 2.2 | 12.0 | 2.6 |
| 02/04/2014 21:00 | 17.9 | 3.5 | 2.3 | 12.4 | 2.7 |
| 02/04/2014 22:00 | 17.8 | 3.6 | 2.2 | 12.2 | 2.6 |
| 02/04/2014 23:00 | 14.7 | 4.3 | 2.1 | 11.6 | 2.5 |
| **Average/Sum#:** | 352.2 # | 91.9 # | 48.7 # | 269.5 # | 58.4 # |
| **Minimum:** | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| **Maximum:** | 17.9 | 4.7 | 2.3 | 12.4 | 2.7 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/05/2014 00:00 | 14.4 | 4.3 | 2.0 | 11.3 | 2.4 |
| 02/05/2014 01:00 | 13.2 | 3.0 | 1.9 | 10.3 | 2.2 |
| 02/05/2014 02:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/05/2014 03:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/05/2014 04:00 | 13.0 | 3.2 | 1.9 | 10.2 | 2.2 |
| 02/05/2014 05:00 | 13.3 | 3.3 | 1.9 | 10.4 | 2.2 |
| 02/05/2014 06:00 | 11.7 | 3.7 | 2.0 | 10.7 | 2.4 |
| 02/05/2014 07:00 | 17.0 | 4.9 | 2.1 | 11.7 | 2.6 |
| 02/05/2014 08:00 | 17.9 | 4.6 | 2.3 | 12.3 | 2.7 |
| 02/05/2014 09:00 | 14.5 | 3.7 | 2.0 | 11.4 | 2.5 |
| 02/05/2014 10:00 | 6.8 | 1.2 | 1.3 | 7.5 | 1.6 |
| 02/05/2014 11:00 | 9.3 | 2.0 | 1.6 | 8.6 | 1.8 |
| 02/05/2014 12:00 | 18.0 | 4.6 | 2.3 | 12.4 | 2.7 |
| 02/05/2014 13:00 | 15.3 | 4.0 | 2.2 | 12.0 | 2.6 |
| 02/05/2014 14:00 | 13.2 | 3.0 | 1.9 | 10.4 | 2.2 |
| 02/05/2014 15:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/05/2014 16:00 | 13.2 | 3.3 | 1.9 | 10.3 | 2.2 |
| 02/05/2014 17:00 | 14.2 | 4.3 | 2.0 | 11.1 | 2.4 |
| 02/05/2014 18:00 | 14.6 | 4.6 | 2.0 | 11.4 | 2.5 |
| 02/05/2014 19:00 | 17.8 | 4.3 | 2.3 | 12.3 | 2.6 |
| 02/05/2014 20:00 | 18.0 | 3.5 | 2.3 | 12.4 | 2.7 |
| 02/05/2014 21:00 | 18.0 | 3.5 | 2.3 | 12.4 | 2.7 |
| 02/05/2014 22:00 | 18.0 | 3.5 | 2.3 | 12.4 | 2.7 |
| 02/05/2014 23:00 | 18.0 | 3.5 | 2.3 | 12.4 | 2.7 |
| **Average/Sum#:** | 348.4 # | 84.4 # | 48.5 # | 264.5 # | 57.2 # |
| **Minimum:** | 6.8 | 1.2 | 1.3 | 7.5 | 1.6 |
| **Maximum:** | 18.0 | 4.9 | 2.3 | 12.4 | 2.7 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/06/2014 00:00 | 17.7 | 3.6 | 2.2 | 12.2 | 2.6 |
| 02/06/2014 01:00 | 13.7 | 3.3 | 2.0 | 10.7 | 2.4 |
| 02/06/2014 02:00 | 13.0 | 2.8 | 1.9 | 10.1 | 2.2 |
| 02/06/2014 03:00 | 13.0 | 2.8 | 1.9 | 10.1 | 2.2 |
| 02/06/2014 04:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/06/2014 05:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/06/2014 06:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/06/2014 07:00 | 13.2 | 3.0 | 1.9 | 10.3 | 2.2 |
| 02/06/2014 08:00 | 13.6 | 3.6 | 1.9 | 10.7 | 2.4 |
| 02/06/2014 09:00 | 13.4 | 3.0 | 1.9 | 10.5 | 2.3 |
| 02/06/2014 10:00 | 13.0 | 2.8 | 1.9 | 10.3 | 2.2 |
| 02/06/2014 11:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/06/2014 12:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/06/2014 13:00 | 13.0 | 3.1 | 1.9 | 10.2 | 2.2 |
| 02/06/2014 14:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/06/2014 15:00 | 13.2 | 3.0 | 1.9 | 10.4 | 2.2 |
| 02/06/2014 16:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/06/2014 17:00 | 13.3 | 3.0 | 1.9 | 10.5 | 2.3 |
| 02/06/2014 18:00 | 13.1 | 3.0 | 1.9 | 10.3 | 2.2 |
| 02/06/2014 19:00 | 13.5 | 3.0 | 1.9 | 10.6 | 2.3 |
| 02/06/2014 20:00 | 13.2 | 3.0 | 1.9 | 10.3 | 2.2 |
| 02/06/2014 21:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/06/2014 22:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/06/2014 23:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| **Average/Sum#:** | 319.9 # | 71.0 # | 46.0 # | 249.2 # | 53.9 # |
| **Minimum:** | 13.0 | 2.8 | 1.9 | 10.1 | 2.2 |
| **Maximum:** | 17.7 | 3.6 | 2.2 | 12.2 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/07/2014 00:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/07/2014 01:00 | 14.1 | 3.9 | 2.0 | 11.1 | 2.4 |
| 02/07/2014 02:00 | 14.4 | 4.2 | 2.0 | 11.3 | 2.4 |
| 02/07/2014 03:00 | 14.4 | 4.3 | 2.0 | 11.3 | 2.4 |
| 02/07/2014 04:00 | 15.4 | 3.9 | 2.2 | 12.1 | 2.6 |
| 02/07/2014 05:00 | 15.5 | 3.9 | 2.2 | 12.2 | 2.6 |
| 02/07/2014 06:00 | 18.0 | 3.2 | 2.3 | 12.4 | 2.7 |
| 02/07/2014 07:00 | 18.1 | 3.2 | 2.3 | 12.4 | 2.8 |
| 02/07/2014 08:00 | 18.1 | 3.2 | 2.3 | 12.4 | 2.8 |
| 02/07/2014 09:00 | 15.1 | 4.0 | 2.2 | 11.9 | 2.6 |
| 02/07/2014 10:00 | 14.3 | 4.3 | 2.0 | 11.3 | 2.4 |
| 02/07/2014 11:00 | 14.3 | 4.3 | 2.0 | 11.2 | 2.4 |
| 02/07/2014 12:00 | 14.4 | 4.3 | 2.0 | 11.3 | 2.4 |
| 02/07/2014 13:00 | 14.1 | 4.3 | 2.0 | 11.1 | 2.4 |
| 02/07/2014 14:00 | 11.7 | 3.2 | 1.9 | 10.7 | 2.4 |
| 02/07/2014 15:00 | 11.2 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/07/2014 16:00 | 14.1 | 4.3 | 2.0 | 11.1 | 2.4 |
| 02/07/2014 17:00 | 14.1 | 4.6 | 2.0 | 11.1 | 2.4 |
| 02/07/2014 18:00 | 14.6 | 4.6 | 2.0 | 11.5 | 2.5 |
| 02/07/2014 19:00 | 15.5 | 3.5 | 2.3 | 12.2 | 2.6 |
| 02/07/2014 20:00 | 14.5 | 4.3 | 2.0 | 11.3 | 2.4 |
| 02/07/2014 21:00 | 14.3 | 4.2 | 2.0 | 11.2 | 2.4 |
| 02/07/2014 22:00 | 14.3 | 4.2 | 2.0 | 11.2 | 2.4 |
| 02/07/2014 23:00 | 14.4 | 4.2 | 2.0 | 11.2 | 2.4 |
| **Average/Sum#:** | 351.9 # | 93.7 # | 49.5 # | 273.9 # | 59.2 # |
| **Minimum:** | 11.2 | 2.8 | 1.9 | 10.2 | 2.2 |
| **Maximum:** | 18.1 | 4.6 | 2.3 | 12.4 | 2.8 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/08/2014 00:00 | 13.7 | 3.6 | 1.9 | 10.7 | 2.4 |
| 02/08/2014 01:00 | 13.5 | 3.6 | 1.9 | 10.5 | 2.3 |
| 02/08/2014 02:00 | 13.2 | 3.6 | 1.9 | 10.4 | 2.2 |
| 02/08/2014 03:00 | 11.3 | 4.0 | 1.9 | 10.3 | 2.2 |
| 02/08/2014 04:00 | 11.3 | 4.0 | 1.9 | 10.4 | 2.2 |
| 02/08/2014 05:00 | 11.3 | 4.0 | 1.9 | 10.4 | 2.2 |
| 02/08/2014 06:00 | 13.0 | 3.6 | 1.9 | 10.3 | 2.2 |
| 02/08/2014 07:00 | 13.3 | 3.3 | 1.9 | 10.5 | 2.3 |
| 02/08/2014 08:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/08/2014 09:00 | 12.9 | 2.8 | 1.9 | 10.1 | 2.2 |
| 02/08/2014 10:00 | 11.1 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/08/2014 11:00 | 11.1 | 2.8 | 1.9 | 10.1 | 2.2 |
| 02/08/2014 12:00 | 11.1 | 2.8 | 1.9 | 10.1 | 2.2 |
| 02/08/2014 13:00 | 11.3 | 3.1 | 1.9 | 10.3 | 2.2 |
| 02/08/2014 14:00 | 11.1 | 2.8 | 1.9 | 10.1 | 2.2 |
| 02/08/2014 15:00 | 11.1 | 3.1 | 1.9 | 10.1 | 2.2 |
| 02/08/2014 16:00 | 11.1 | 3.1 | 1.9 | 10.1 | 2.2 |
| 02/08/2014 17:00 | 11.1 | 3.1 | 1.9 | 10.2 | 2.2 |
| 02/08/2014 18:00 | 13.7 | 3.6 | 1.9 | 10.7 | 2.4 |
| 02/08/2014 19:00 | 14.9 | 3.8 | 2.1 | 11.8 | 2.6 |
| 02/08/2014 20:00 | 14.4 | 4.2 | 2.0 | 11.3 | 2.4 |
| 02/08/2014 21:00 | 14.5 | 4.2 | 2.0 | 11.4 | 2.5 |
| 02/08/2014 22:00 | 11.5 | 3.5 | 1.9 | 10.5 | 2.3 |
| 02/08/2014 23:00 | 10.9 | 3.8 | 1.9 | 10.0 | 2.2 |
| **Average/Sum#:** | 295.4 # | 82.0 # | 46.0 # | 250.7 # | 54.4 # |
| **Minimum:** | 10.9 | 2.8 | 1.9 | 10.0 | 2.2 |
| **Maximum:** | 14.9 | 4.2 | 2.1 | 11.8 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/09/2014 00:00 | 10.9 | 3.6 | 1.9 | 10.0 | 2.2 |
| 02/09/2014 01:00 | 13.5 | 3.6 | 1.9 | 10.6 | 2.3 |
| 02/09/2014 02:00 | 11.0 | 4.3 | 1.9 | 10.1 | 2.2 |
| 02/09/2014 03:00 | 12.8 | 4.3 | 1.9 | 10.0 | 2.2 |
| 02/09/2014 04:00 | 12.8 | 4.6 | 1.9 | 10.0 | 2.2 |
| 02/09/2014 05:00 | 10.9 | 4.6 | 1.9 | 10.0 | 2.2 |
| 02/09/2014 06:00 | 10.9 | 4.3 | 1.9 | 10.0 | 2.2 |
| 02/09/2014 07:00 | 12.9 | 3.5 | 1.9 | 10.2 | 2.2 |
| 02/09/2014 08:00 | 12.9 | 3.5 | 1.9 | 10.2 | 2.2 |
| 02/09/2014 09:00 | 13.0 | 3.1 | 1.9 | 10.2 | 2.2 |
| 02/09/2014 10:00 | 12.9 | 3.1 | 1.9 | 10.2 | 2.2 |
| 02/09/2014 11:00 | 12.9 | 3.1 | 1.9 | 10.1 | 2.2 |
| 02/09/2014 12:00 | 12.8 | 2.8 | 1.9 | 10.1 | 2.2 |
| 02/09/2014 13:00 | 12.8 | 2.8 | 1.9 | 10.1 | 2.2 |
| 02/09/2014 14:00 | 11.1 | 2.8 | 1.9 | 10.1 | 2.2 |
| 02/09/2014 15:00 | 9.2 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/09/2014 16:00 | 13.0 | 3.1 | 1.9 | 10.3 | 2.2 |
| 02/09/2014 17:00 | 13.2 | 3.1 | 1.9 | 10.3 | 2.2 |
| 02/09/2014 18:00 | 13.7 | 3.9 | 2.0 | 10.7 | 2.4 |
| 02/09/2014 19:00 | 17.8 | 3.1 | 2.2 | 12.2 | 2.6 |
| 02/09/2014 20:00 | 17.8 | 2.8 | 2.2 | 12.3 | 2.7 |
| 02/09/2014 21:00 | 17.8 | 2.8 | 2.2 | 12.3 | 2.7 |
| 02/09/2014 22:00 | 14.9 | 2.8 | 2.1 | 11.7 | 2.6 |
| 02/09/2014 23:00 | 14.4 | 3.4 | 2.0 | 11.4 | 2.5 |
| **Average/Sum#:** | 315.9 # | 81.8 # | 46.9 # | 253.3 # | 55.2 # |
| **Minimum:** | 9.2 | 2.8 | 1.9 | 10.0 | 2.2 |
| **Maximum:** | 17.8 | 4.6 | 2.2 | 12.3 | 2.7 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/10/2014 00:00 | 7.5 | 1.4 | 1.4 | 8.2 | 1.8 |
| 02/10/2014 01:00 | 6.7 | 0.7 | 1.3 | 7.3 | 1.6 |
| 02/10/2014 02:00 | 6.8 | 1.0 | 1.4 | 7.5 | 1.6 |
| 02/10/2014 03:00 | 5.0 | 0.9 | 1.3 | 6.8 | 1.4 |
| 02/10/2014 04:00 | 6.2 | 0.9 | 1.3 | 6.8 | 1.4 |
| 02/10/2014 05:00 | 7.1 | 1.6 | 1.4 | 7.9 | 1.8 |
| 02/10/2014 06:00 | 13.2 | 4.6 | 1.9 | 10.3 | 2.2 |
| 02/10/2014 07:00 | 13.4 | 3.3 | 1.9 | 10.5 | 2.3 |
| 02/10/2014 08:00 | 13.9 | 3.6 | 2.0 | 10.9 | 2.4 |
| 02/10/2014 09:00 | 13.2 | 3.0 | 1.9 | 10.4 | 2.2 |
| 02/10/2014 10:00 | 13.2 | 2.9 | 1.9 | 10.3 | 2.2 |
| 02/10/2014 11:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/10/2014 12:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/10/2014 13:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/10/2014 14:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/10/2014 15:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/10/2014 16:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/10/2014 17:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/10/2014 18:00 | 13.3 | 2.9 | 1.9 | 10.4 | 2.2 |
| 02/10/2014 19:00 | 14.2 | 4.6 | 2.0 | 11.1 | 2.4 |
| 02/10/2014 20:00 | 14.3 | 4.6 | 2.0 | 11.2 | 2.4 |
| 02/10/2014 21:00 | 14.9 | 4.5 | 2.1 | 11.6 | 2.6 |
| 02/10/2014 22:00 | 13.9 | 3.6 | 2.0 | 10.9 | 2.4 |
| 02/10/2014 23:00 | 11.1 | 4.6 | 1.9 | 10.2 | 2.2 |
| **Average/Sum#:** | 278.9 # | 68.3 # | 42.9 # | 233.7 # | 50.5 # |
| **Minimum:** | 5.0 | 0.7 | 1.3 | 6.8 | 1.4 |
| **Maximum:** | 14.9 | 4.6 | 2.1 | 11.6 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/11/2014 00:00 | 12.9 | 3.5 | 1.9 | 10.1 | 2.2 |
| 02/11/2014 01:00 | 12.9 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/11/2014 02:00 | 12.9 | 3.1 | 1.9 | 10.1 | 2.2 |
| 02/11/2014 03:00 | 8.0 | 2.0 | 1.6 | 8.8 | 2.0 |
| 02/11/2014 04:00 | 6.3 | 0.9 | 1.3 | 6.9 | 1.5 |
| 02/11/2014 05:00 | 7.5 | 1.1 | 1.6 | 8.3 | 1.8 |
| 02/11/2014 06:00 | 13.0 | 3.1 | 1.9 | 10.1 | 2.2 |
| 02/11/2014 07:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/11/2014 08:00 | 14.4 | 4.3 | 2.0 | 11.3 | 2.4 |
| 02/11/2014 09:00 | 14.1 | 4.0 | 2.0 | 11.1 | 2.4 |
| 02/11/2014 10:00 | 13.3 | 2.9 | 1.9 | 10.4 | 2.2 |
| 02/11/2014 11:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/11/2014 12:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/11/2014 13:00 | 13.0 | 2.9 | 1.9 | 10.2 | 2.2 |
| 02/11/2014 14:00 | 13.0 | 2.9 | 1.9 | 10.2 | 2.2 |
| 02/11/2014 15:00 | 13.0 | 2.9 | 1.9 | 10.2 | 2.2 |
| 02/11/2014 16:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/11/2014 17:00 | 13.0 | 2.9 | 1.9 | 10.2 | 2.2 |
| 02/11/2014 18:00 | 13.2 | 2.9 | 1.9 | 10.4 | 2.2 |
| 02/11/2014 19:00 | 14.3 | 4.6 | 2.0 | 11.1 | 2.4 |
| 02/11/2014 20:00 | 14.3 | 4.6 | 2.0 | 11.2 | 2.4 |
| 02/11/2014 21:00 | 14.8 | 4.6 | 2.1 | 11.7 | 2.6 |
| 02/11/2014 22:00 | 14.1 | 3.9 | 2.0 | 11.1 | 2.4 |
| 02/11/2014 23:00 | 13.6 | 3.0 | 1.9 | 10.7 | 2.4 |
| **Average/Sum#:** | 303.6 # | 74.1 # | 45.1 # | 245.1 # | 53.1 # |
| **Minimum:** | 6.3 | 0.9 | 1.3 | 6.9 | 1.5 |
| **Maximum:** | 14.8 | 4.6 | 2.1 | 11.7 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/12/2014 00:00 | 13.2 | 2.8 | 1.9 | 10.3 | 2.2 |
| 02/12/2014 01:00 | 13.9 | 3.9 | 2.0 | 10.9 | 2.4 |
| 02/12/2014 02:00 | 13.9 | 3.9 | 2.0 | 11.0 | 2.4 |
| 02/12/2014 03:00 | 14.1 | 4.0 | 2.0 | 11.0 | 2.4 |
| 02/12/2014 04:00 | 14.1 | 4.3 | 2.0 | 11.1 | 2.4 |
| 02/12/2014 05:00 | 14.1 | 4.3 | 2.0 | 11.1 | 2.4 |
| 02/12/2014 06:00 | 13.7 | 3.6 | 2.0 | 10.9 | 2.4 |
| 02/12/2014 07:00 | 14.4 | 4.9 | 2.0 | 11.3 | 2.4 |
| 02/12/2014 08:00 | 14.3 | 4.3 | 2.0 | 11.3 | 2.4 |
| 02/12/2014 09:00 | 13.3 | 2.8 | 1.9 | 10.4 | 2.2 |
| 02/12/2014 10:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/12/2014 11:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/12/2014 12:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/12/2014 13:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/12/2014 14:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/12/2014 15:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/12/2014 16:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/12/2014 17:00 | 13.0 | 2.8 | 1.9 | 10.3 | 2.2 |
| 02/12/2014 18:00 | 14.4 | 4.5 | 2.0 | 11.3 | 2.4 |
| 02/12/2014 19:00 | 18.0 | 3.1 | 2.3 | 12.4 | 2.7 |
| 02/12/2014 20:00 | 18.1 | 2.8 | 2.2 | 12.4 | 2.7 |
| 02/12/2014 21:00 | 17.8 | 2.8 | 2.2 | 12.2 | 2.7 |
| 02/12/2014 22:00 | 14.9 | 3.6 | 2.2 | 11.7 | 2.5 |
| 02/12/2014 23:00 | 13.9 | 3.3 | 2.0 | 11.0 | 2.4 |
| **Average/Sum#:** | 340.1 # | 81.3 # | 47.9 # | 262.0 # | 56.6 # |
| **Minimum:** | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| **Maximum:** | 18.1 | 4.9 | 2.3 | 12.4 | 2.7 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/13/2014 00:00 | 11.3 | 2.8 | 1.9 | 10.4 | 2.2 |
| 02/13/2014 01:00 | 11.1 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/13/2014 02:00 | 11.1 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/13/2014 03:00 | 11.1 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/13/2014 04:00 | 11.0 | 2.8 | 1.9 | 10.1 | 2.2 |
| 02/13/2014 05:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/13/2014 06:00 | 13.4 | 3.6 | 1.9 | 10.5 | 2.3 |
| 02/13/2014 07:00 | 14.8 | 4.1 | 2.1 | 11.5 | 2.6 |
| 02/13/2014 08:00 | 17.8 | 3.5 | 2.2 | 12.2 | 2.6 |
| 02/13/2014 09:00 | 14.9 | 3.9 | 2.1 | 11.7 | 2.6 |
| 02/13/2014 10:00 | 14.8 | 3.9 | 2.1 | 11.6 | 2.6 |
| 02/13/2014 11:00 | 14.8 | 3.9 | 2.1 | 11.6 | 2.6 |
| 02/13/2014 12:00 | 14.8 | 3.9 | 2.1 | 11.6 | 2.6 |
| 02/13/2014 13:00 | 14.8 | 3.8 | 2.1 | 11.6 | 2.6 |
| 02/13/2014 14:00 | 14.8 | 3.8 | 2.1 | 11.7 | 2.6 |
| 02/13/2014 15:00 | 14.8 | 3.8 | 2.1 | 11.6 | 2.6 |
| 02/13/2014 16:00 | 14.8 | 3.5 | 2.1 | 11.7 | 2.6 |
| 02/13/2014 17:00 | 15.0 | 3.5 | 2.1 | 11.7 | 2.6 |
| 02/13/2014 18:00 | 14.8 | 3.4 | 2.1 | 11.7 | 2.6 |
| 02/13/2014 19:00 | 17.6 | 2.8 | 2.2 | 12.2 | 2.6 |
| 02/13/2014 20:00 | 18.0 | 2.8 | 2.3 | 12.4 | 2.7 |
| 02/13/2014 21:00 | 18.0 | 2.5 | 2.3 | 12.4 | 2.7 |
| 02/13/2014 22:00 | 17.5 | 2.8 | 2.2 | 12.1 | 2.6 |
| 02/13/2014 23:00 | 15.1 | 3.2 | 2.2 | 11.8 | 2.6 |
| **Average/Sum#:** | 349.1 # | 79.5 # | 49.8 # | 272.9 # | 59.9 # |
| **Minimum:** | 11.0 | 2.5 | 1.9 | 10.1 | 2.2 |
| **Maximum:** | 18.0 | 4.1 | 2.3 | 12.4 | 2.7 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/14/2014 00:00 | 14.2 | 3.2 | 2.0 | 11.1 | 2.4 |
| 02/14/2014 01:00 | 12.8 | 2.8 | 1.9 | 10.1 | 2.2 |
| 02/14/2014 02:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/14/2014 03:00 | 12.9 | 2.8 | 1.9 | 10.1 | 2.2 |
| 02/14/2014 04:00 | 12.8 | 2.8 | 1.9 | 10.1 | 2.2 |
| 02/14/2014 05:00 | 12.9 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/14/2014 06:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/14/2014 07:00 | 13.3 | 2.8 | 1.9 | 10.4 | 2.2 |
| 02/14/2014 08:00 | 13.9 | 3.9 | 2.0 | 10.9 | 2.4 |
| 02/14/2014 09:00 | 14.6 | 3.5 | 2.1 | 11.5 | 2.5 |
| 02/14/2014 10:00 | 14.9 | 3.4 | 2.1 | 11.7 | 2.6 |
| 02/14/2014 11:00 | 17.1 | 2.8 | 2.1 | 11.7 | 2.6 |
| 02/14/2014 12:00 | 17.1 | 2.8 | 2.1 | 11.7 | 2.6 |
| 02/14/2014 13:00 | 17.1 | 3.7 | 2.1 | 11.7 | 2.6 |
| 02/14/2014 14:00 | 17.1 | 2.5 | 2.1 | 11.8 | 2.6 |
| 02/14/2014 15:00 | 17.1 | 2.8 | 2.1 | 11.8 | 2.6 |
| 02/14/2014 16:00 | 14.4 | 2.1 | 2.0 | 11.3 | 2.5 |
| 02/14/2014 17:00 | 17.1 | 2.8 | 2.1 | 11.7 | 2.6 |
| 02/14/2014 18:00 | 17.1 | 2.8 | 2.1 | 11.8 | 2.6 |
| 02/14/2014 19:00 | 14.4 | 3.4 | 2.0 | 11.3 | 2.4 |
| 02/14/2014 20:00 | 14.3 | 3.5 | 2.0 | 11.3 | 2.4 |
| 02/14/2014 21:00 | 14.8 | 3.5 | 2.1 | 11.6 | 2.6 |
| 02/14/2014 22:00 | 14.8 | 3.4 | 2.1 | 11.7 | 2.6 |
| 02/14/2014 23:00 | 14.3 | 3.1 | 2.0 | 11.2 | 2.4 |
| **Average/Sum#:** | 355.0 # | 72.8 # | 48.4 # | 267.1 # | 58.4 # |
| **Minimum:** | 12.8 | 2.1 | 1.9 | 10.1 | 2.2 |
| **Maximum:** | 17.1 | 3.9 | 2.1 | 11.8 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/15/2014 00:00 | 14.1 | 3.9 | 2.0 | 11.1 | 2.4 |
| 02/15/2014 01:00 | 14.6 | 3.9 | 2.0 | 11.5 | 2.5 |
| 02/15/2014 02:00 | 17.5 | 2.8 | 2.2 | 12.0 | 2.6 |
| 02/15/2014 03:00 | 17.7 | 2.8 | 2.2 | 12.2 | 2.6 |
| 02/15/2014 04:00 | 14.4 | 3.5 | 2.0 | 11.3 | 2.4 |
| 02/15/2014 05:00 | 14.1 | 3.6 | 2.0 | 11.1 | 2.4 |
| 02/15/2014 06:00 | 14.4 | 3.9 | 2.0 | 11.3 | 2.4 |
| 02/15/2014 07:00 | 13.9 | 3.6 | 2.0 | 10.9 | 2.4 |
| 02/15/2014 08:00 | 14.1 | 3.6 | 2.0 | 11.1 | 2.4 |
| 02/15/2014 09:00 | 14.3 | 4.2 | 2.0 | 11.3 | 2.4 |
| 02/15/2014 10:00 | 14.9 | 3.6 | 2.1 | 11.7 | 2.6 |
| 02/15/2014 11:00 | 17.9 | 2.8 | 2.2 | 12.2 | 2.6 |
| 02/15/2014 12:00 | 17.8 | 2.5 | 2.2 | 12.2 | 2.6 |
| 02/15/2014 13:00 | 17.4 | 2.8 | 2.2 | 12.0 | 2.6 |
| 02/15/2014 14:00 | 14.3 | 3.5 | 2.0 | 11.1 | 2.4 |
| 02/15/2014 15:00 | 14.1 | 3.5 | 2.0 | 11.0 | 2.4 |
| 02/15/2014 16:00 | 13.8 | 3.2 | 2.0 | 10.8 | 2.4 |
| 02/15/2014 17:00 | 14.0 | 3.1 | 2.0 | 11.0 | 2.4 |
| 02/15/2014 18:00 | 14.5 | 3.4 | 2.0 | 11.5 | 2.5 |
| 02/15/2014 19:00 | 17.7 | 2.5 | 2.2 | 12.2 | 2.6 |
| 02/15/2014 20:00 | 17.5 | 2.8 | 2.2 | 12.0 | 2.6 |
| 02/15/2014 21:00 | 17.7 | 2.5 | 2.2 | 12.2 | 2.6 |
| 02/15/2014 22:00 | 14.8 | 3.1 | 2.1 | 11.6 | 2.6 |
| 02/15/2014 23:00 | 13.5 | 2.8 | 1.9 | 10.5 | 2.3 |
| **Average/Sum#:** | 369.0 # | 77.9 # | 49.7 # | 275.8 # | 59.7 # |
| **Minimum:** | 13.5 | 2.5 | 1.9 | 10.5 | 2.3 |
| **Maximum:** | 17.9 | 4.2 | 2.2 | 12.2 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/16/2014 00:00 | 13.0 | 2.9 | 1.9 | 10.2 | 2.2 |
| 02/16/2014 01:00 | 13.1 | 2.9 | 1.9 | 10.3 | 2.2 |
| 02/16/2014 02:00 | 13.3 | 3.0 | 1.9 | 10.4 | 2.2 |
| 02/16/2014 03:00 | 12.0 | 2.1 | 1.7 | 9.5 | 2.0 |
| 02/16/2014 04:00 | 7.6 | 0.7 | 1.3 | 7.0 | 1.6 |
| 02/16/2014 05:00 | 8.8 | 0.8 | 1.4 | 8.1 | 1.8 |
| 02/16/2014 06:00 | 11.5 | 2.1 | 1.7 | 9.1 | 2.0 |
| 02/16/2014 07:00 | 15.7 | 4.0 | 2.0 | 10.9 | 2.4 |
| 02/16/2014 08:00 | 13.2 | 2.9 | 1.9 | 10.4 | 2.2 |
| 02/16/2014 09:00 | 12.9 | 3.3 | 1.9 | 10.2 | 2.2 |
| 02/16/2014 10:00 | 12.8 | 3.3 | 1.9 | 10.1 | 2.2 |
| 02/16/2014 11:00 | 12.8 | 3.3 | 1.9 | 10.0 | 2.2 |
| 02/16/2014 12:00 | 12.8 | 3.3 | 1.9 | 10.0 | 2.2 |
| 02/16/2014 13:00 | 12.7 | 3.3 | 1.9 | 10.0 | 2.2 |
| 02/16/2014 14:00 | 12.8 | 3.0 | 1.9 | 10.0 | 2.2 |
| 02/16/2014 15:00 | 12.9 | 3.0 | 1.9 | 10.2 | 2.2 |
| 02/16/2014 16:00 | 12.9 | 3.0 | 1.9 | 10.1 | 2.2 |
| 02/16/2014 17:00 | 12.9 | 3.0 | 1.9 | 10.1 | 2.2 |
| 02/16/2014 18:00 | 13.6 | 3.6 | 1.9 | 10.6 | 2.4 |
| 02/16/2014 19:00 | 17.6 | 3.2 | 2.2 | 12.2 | 2.6 |
| 02/16/2014 20:00 | 17.8 | 2.9 | 2.2 | 12.3 | 2.7 |
| 02/16/2014 21:00 | 17.8 | 2.9 | 2.2 | 12.3 | 2.7 |
| 02/16/2014 22:00 | 17.8 | 2.9 | 2.2 | 12.3 | 2.7 |
| 02/16/2014 23:00 | 14.2 | 3.3 | 2.0 | 11.2 | 2.4 |
| **Average/Sum#:** | 322.5 # | 68.7 # | 45.5 # | 247.5 # | 53.9 # |
| **Minimum:** | 7.6 | 0.7 | 1.3 | 7.0 | 1.6 |
| **Maximum:** | 17.8 | 4.0 | 2.2 | 12.3 | 2.7 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/17/2014 00:00 | 13.1 | 2.8 | 1.9 | 10.3 | 2.2 |
| 02/17/2014 01:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/17/2014 02:00 | 12.3 | 2.2 | 1.7 | 9.7 | 2.1 |
| 02/17/2014 03:00 | 7.8 | 1.0 | 1.3 | 7.1 | 1.6 |
| 02/17/2014 04:00 | 8.2 | 1.0 | 1.4 | 7.5 | 1.6 |
| 02/17/2014 05:00 | 10.9 | 1.7 | 1.6 | 8.6 | 1.8 |
| 02/17/2014 06:00 | 13.2 | 3.0 | 1.9 | 10.4 | 2.3 |
| 02/17/2014 07:00 | 13.3 | 3.3 | 1.9 | 10.5 | 2.3 |
| 02/17/2014 08:00 | 13.1 | 2.9 | 1.9 | 10.3 | 2.3 |
| 02/17/2014 09:00 | 12.8 | 2.6 | 1.8 | 10.0 | 2.2 |
| 02/17/2014 10:00 | 13.0 | 3.1 | 1.9 | 10.2 | 2.2 |
| 02/17/2014 11:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/17/2014 12:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/17/2014 13:00 | 12.9 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/17/2014 14:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/17/2014 15:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/17/2014 16:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/17/2014 17:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/17/2014 18:00 | 13.1 | 3.0 | 1.9 | 10.3 | 2.2 |
| 02/17/2014 19:00 | 13.4 | 3.0 | 1.9 | 10.5 | 2.3 |
| 02/17/2014 20:00 | 14.4 | 4.3 | 2.0 | 11.4 | 2.5 |
| 02/17/2014 21:00 | 17.5 | 3.2 | 2.2 | 12.0 | 2.6 |
| 02/17/2014 22:00 | 14.2 | 3.6 | 2.0 | 11.2 | 2.4 |
| 02/17/2014 23:00 | 13.3 | 3.0 | 1.9 | 10.5 | 2.3 |
| **Average/Sum#:** | 307.5 # | 66.1 # | 44.4 # | 242.1 # | 52.5 # |
| **Minimum:** | 7.8 | 1.0 | 1.3 | 7.1 | 1.6 |
| **Maximum:** | 17.5 | 4.3 | 2.2 | 12.0 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/18/2014 00:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/18/2014 01:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/18/2014 02:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/18/2014 03:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/18/2014 04:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/18/2014 05:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/18/2014 06:00 | 11.3 | 3.2 | 1.9 | 10.4 | 2.2 |
| 02/18/2014 07:00 | 14.3 | 3.9 | 2.0 | 11.2 | 2.4 |
| 02/18/2014 08:00 | 16.8 | 3.6 | 2.1 | 11.6 | 2.6 |
| 02/18/2014 09:00 | 13.9 | 3.6 | 2.0 | 10.9 | 2.4 |
| 02/18/2014 10:00 | 13.8 | 3.9 | 2.0 | 10.9 | 2.4 |
| 02/18/2014 11:00 | 14.1 | 3.6 | 2.0 | 11.1 | 2.4 |
| 02/18/2014 12:00 | 14.4 | 3.5 | 2.0 | 11.3 | 2.4 |
| 02/18/2014 13:00 | 13.7 | 3.5 | 2.0 | 10.9 | 2.4 |
| 02/18/2014 14:00 | 12.9 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/18/2014 15:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/18/2014 16:00 | 12.7 | 2.8 | 1.9 | 10.0 | 2.2 |
| 02/18/2014 17:00 | 13.7 | 3.1 | 1.9 | 10.7 | 2.4 |
| 02/18/2014 18:00 | 17.4 | 2.8 | 2.2 | 12.0 | 2.6 |
| 02/18/2014 19:00 | 17.8 | 2.2 | 2.2 | 12.2 | 2.6 |
| 02/18/2014 20:00 | 14.4 | 3.6 | 2.0 | 11.3 | 2.4 |
| 02/18/2014 21:00 | 17.5 | 2.8 | 2.2 | 12.0 | 2.6 |
| 02/18/2014 22:00 | 13.3 | 2.9 | 1.9 | 10.5 | 2.3 |
| 02/18/2014 23:00 | 11.0 | 2.0 | 1.6 | 8.6 | 1.8 |
| **Average/Sum#:** | 334.0 # | 73.4 # | 47.1 # | 257.2 # | 55.7 # |
| **Minimum:** | 11.0 | 2.0 | 1.6 | 8.6 | 1.8 |
| **Maximum:** | 17.8 | 3.9 | 2.2 | 12.2 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/19/2014 00:00 | 6.2 | 0.9 | 1.3 | 6.8 | 1.4 |
| 02/19/2014 01:00 | 8.4 | 1.1 | 1.4 | 7.7 | 1.6 |
| 02/19/2014 02:00 | 6.7 | 9.0 | 0.1 | 0.7 | 0.2 |
| 02/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 02/19/2014 12:00 | 69.7 | 24.8 | 0.3 | 0.8 | 0.2 |
| 02/19/2014 13:00 | 40.4 | 21.0 | 0.4 | 1.4 | 0.3 |
| 02/19/2014 14:00 | 56.4 | 58.7 | 0.6 | 2.2 | 0.5 |
| 02/19/2014 15:00 | 2.6 | 0.7 | 0.9 | 3.2 | 0.8 |
| 02/19/2014 16:00 | 4.8 | 1.2 | 1.1 | 4.0 | 1.0 |
| 02/19/2014 17:00 | 97.5 | 29.0 | 1.4 | 5.5 | 1.2 |
| 02/19/2014 18:00 | 68.3 | 25.3 | 1.5 | 8.4 | 1.9 |
| 02/19/2014 19:00 | 13.4 | 3.3 | 1.9 | 10.5 | 2.3 |
| 02/19/2014 20:00 | 17.6 | 3.2 | 2.2 | 12.1 | 2.6 |
| 02/19/2014 21:00 | 18.0 | 2.2 | 2.3 | 12.4 | 2.7 |
| 02/19/2014 22:00 | 17.2 | 2.9 | 2.2 | 11.8 | 2.6 |
| 02/19/2014 23:00 | 15.0 | 2.9 | 1.9 | 10.3 | 2.2 |
| **Average/Sum#:** | 442.2 # | 186.2 # | 19.5 # | 97.8 # | 21.5 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 97.5 | 58.7 | 2.3 | 12.4 | 2.7 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/20/2014 00:00 | 12.8 | 3.3 | 1.9 | 10.0 | 2.2 |
| 02/20/2014 01:00 | 7.6 | 0.7 | 1.3 | 7.0 | 1.6 |
| 02/20/2014 02:00 | 7.5 | 0.7 | 1.3 | 6.8 | 1.4 |
| 02/20/2014 03:00 | 7.5 | 0.7 | 1.3 | 6.8 | 1.4 |
| 02/20/2014 04:00 | 7.5 | 0.7 | 1.3 | 6.9 | 1.6 |
| 02/20/2014 05:00 | 7.8 | 1.0 | 1.3 | 7.2 | 1.6 |
| 02/20/2014 06:00 | 13.2 | 3.4 | 1.9 | 10.4 | 2.2 |
| 02/20/2014 07:00 | 14.4 | 4.0 | 2.0 | 11.4 | 2.5 |
| 02/20/2014 08:00 | 17.0 | 3.2 | 2.1 | 11.6 | 2.6 |
| 02/20/2014 09:00 | 13.2 | 2.5 | 1.9 | 10.3 | 2.2 |
| 02/20/2014 10:00 | 12.8 | 2.5 | 1.9 | 10.1 | 2.2 |
| 02/20/2014 11:00 | 12.8 | 2.5 | 1.9 | 10.1 | 2.2 |
| 02/20/2014 12:00 | 12.9 | 2.5 | 1.9 | 10.2 | 2.2 |
| 02/20/2014 13:00 | 15.7 | 3.2 | 2.0 | 10.8 | 2.4 |
| 02/20/2014 14:00 | 13.0 | 2.6 | 1.9 | 10.2 | 2.2 |
| 02/20/2014 15:00 | 15.6 | 2.9 | 2.0 | 10.8 | 2.4 |
| 02/20/2014 16:00 | 16.8 | 2.9 | 2.1 | 11.6 | 2.6 |
| 02/20/2014 17:00 | 17.8 | 1.9 | 2.3 | 12.2 | 2.6 |
| 02/20/2014 18:00 | 17.2 | 2.2 | 2.1 | 11.8 | 2.6 |
| 02/20/2014 19:00 | 17.8 | 1.9 | 2.3 | 12.2 | 2.6 |
| 02/20/2014 20:00 | 17.9 | 1.9 | 2.3 | 12.3 | 2.7 |
| 02/20/2014 21:00 | 17.7 | 1.9 | 2.3 | 12.2 | 2.6 |
| 02/20/2014 22:00 | 17.9 | 1.9 | 2.3 | 12.2 | 2.6 |
| 02/20/2014 23:00 | 17.4 | 2.2 | 2.2 | 11.9 | 2.6 |
| **Average/Sum#:** | 331.8 # | 53.2 # | 45.8 # | 247.0 # | 53.8 # |
| **Minimum:** | 7.5 | 0.7 | 1.3 | 6.8 | 1.4 |
| **Maximum:** | 17.9 | 4.0 | 2.3 | 12.3 | 2.7 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/21/2014 00:00 | 16.3 | 2.9 | 2.0 | 11.3 | 2.4 |
| 02/21/2014 01:00 | 13.0 | 2.3 | 1.9 | 10.2 | 2.2 |
| 02/21/2014 02:00 | 12.8 | 2.6 | 1.9 | 10.0 | 2.2 |
| 02/21/2014 03:00 | 12.8 | 2.9 | 1.9 | 10.0 | 2.2 |
| 02/21/2014 04:00 | 12.8 | 2.9 | 1.9 | 10.0 | 2.2 |
| 02/21/2014 05:00 | 12.8 | 2.9 | 1.9 | 10.0 | 2.2 |
| 02/21/2014 06:00 | 12.9 | 2.9 | 1.9 | 10.2 | 2.2 |
| 02/21/2014 07:00 | 15.9 | 3.9 | 2.0 | 11.0 | 2.4 |
| 02/21/2014 08:00 | 17.4 | 2.6 | 2.2 | 11.9 | 2.6 |
| 02/21/2014 09:00 | 13.6 | 2.6 | 1.9 | 10.6 | 2.4 |
| 02/21/2014 10:00 | 12.9 | 2.6 | 1.9 | 10.0 | 2.2 |
| 02/21/2014 11:00 | 12.9 | 2.3 | 1.9 | 10.2 | 2.2 |
| 02/21/2014 12:00 | 12.9 | 2.6 | 1.9 | 10.1 | 2.2 |
| 02/21/2014 13:00 | 12.9 | 2.6 | 1.9 | 10.1 | 2.2 |
| 02/21/2014 14:00 | 14.7 | 2.3 | 1.9 | 10.1 | 2.2 |
| 02/21/2014 15:00 | 14.6 | 2.3 | 1.9 | 10.1 | 2.2 |
| 02/21/2014 16:00 | 14.6 | 2.3 | 1.8 | 10.1 | 2.2 |
| 02/21/2014 17:00 | 14.8 | 2.2 | 1.9 | 10.1 | 2.2 |
| 02/21/2014 18:00 | 16.0 | 3.2 | 2.0 | 11.0 | 2.4 |
| 02/21/2014 19:00 | 16.8 | 3.2 | 2.1 | 11.6 | 2.6 |
| 02/21/2014 20:00 | 17.1 | 2.5 | 2.1 | 11.8 | 2.6 |
| 02/21/2014 21:00 | 17.5 | 2.2 | 2.2 | 12.0 | 2.6 |
| 02/21/2014 22:00 | 17.0 | 2.5 | 2.1 | 11.6 | 2.6 |
| 02/21/2014 23:00 | 16.6 | 3.2 | 2.0 | 11.4 | 2.4 |
| **Average/Sum#:** | 351.6 # | 64.5 # | 47.1 # | 255.4 # | 55.8 # |
| **Minimum:** | 12.8 | 2.2 | 1.8 | 10.0 | 2.2 |
| **Maximum:** | 17.5 | 3.9 | 2.2 | 12.0 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/22/2014 00:00 | 16.4 | 3.2 | 2.0 | 11.2 | 2.4 |
| 02/22/2014 01:00 | 14.0 | 2.9 | 2.0 | 11.0 | 2.4 |
| 02/22/2014 02:00 | 13.0 | 2.2 | 1.9 | 10.2 | 2.2 |
| 02/22/2014 03:00 | 13.8 | 3.5 | 2.0 | 10.8 | 2.4 |
| 02/22/2014 04:00 | 13.9 | 3.5 | 2.0 | 10.9 | 2.4 |
| 02/22/2014 05:00 | 13.4 | 3.3 | 1.9 | 10.5 | 2.3 |
| 02/22/2014 06:00 | 14.1 | 3.6 | 2.0 | 11.1 | 2.4 |
| 02/22/2014 07:00 | 14.1 | 3.6 | 2.0 | 11.1 | 2.4 |
| 02/22/2014 08:00 | 14.1 | 3.6 | 2.0 | 11.0 | 2.4 |
| 02/22/2014 09:00 | 13.2 | 3.0 | 1.9 | 10.3 | 2.2 |
| 02/22/2014 10:00 | 13.0 | 3.0 | 1.9 | 10.2 | 2.2 |
| 02/22/2014 11:00 | 13.0 | 3.0 | 1.9 | 10.2 | 2.2 |
| 02/22/2014 12:00 | 13.1 | 2.9 | 1.9 | 10.2 | 2.2 |
| 02/22/2014 13:00 | 13.0 | 2.9 | 1.9 | 10.2 | 2.2 |
| 02/22/2014 14:00 | 13.6 | 3.2 | 1.9 | 10.6 | 2.4 |
| 02/22/2014 15:00 | 15.8 | 3.2 | 2.0 | 10.8 | 2.4 |
| 02/22/2014 16:00 | 15.1 | 2.8 | 1.9 | 10.4 | 2.2 |
| 02/22/2014 17:00 | 13.5 | 2.5 | 1.9 | 10.6 | 2.3 |
| 02/22/2014 18:00 | 16.3 | 3.1 | 2.0 | 11.2 | 2.4 |
| 02/22/2014 19:00 | 16.5 | 2.8 | 2.0 | 11.3 | 2.4 |
| 02/22/2014 20:00 | 17.5 | 2.2 | 2.1 | 12.0 | 2.6 |
| 02/22/2014 21:00 | 17.6 | 1.8 | 2.3 | 12.1 | 2.6 |
| 02/22/2014 22:00 | 17.7 | 1.9 | 2.3 | 12.2 | 2.6 |
| 02/22/2014 23:00 | 17.7 | 1.9 | 2.3 | 12.2 | 2.6 |
| **Average/Sum#:** | 353.4 # | 69.6 # | 48.0 # | 262.3 # | 56.8 # |
| **Minimum:** | 13.0 | 1.8 | 1.9 | 10.2 | 2.2 |
| **Maximum:** | 17.7 | 3.6 | 2.3 | 12.2 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/23/2014 00:00 | 17.6 | 2.2 | 2.2 | 12.1 | 2.6 |
| 02/23/2014 01:00 | 17.0 | 3.2 | 2.1 | 11.7 | 2.6 |
| 02/23/2014 02:00 | 17.7 | 2.2 | 2.2 | 12.1 | 2.6 |
| 02/23/2014 03:00 | 17.7 | 2.2 | 2.3 | 12.2 | 2.6 |
| 02/23/2014 04:00 | 14.7 | 2.8 | 2.1 | 11.5 | 2.6 |
| 02/23/2014 05:00 | 14.1 | 3.6 | 2.0 | 11.1 | 2.4 |
| 02/23/2014 06:00 | 14.2 | 3.5 | 2.0 | 11.1 | 2.4 |
| 02/23/2014 07:00 | 13.9 | 3.3 | 2.0 | 10.9 | 2.4 |
| 02/23/2014 08:00 | 13.9 | 3.3 | 2.0 | 10.9 | 2.4 |
| 02/23/2014 09:00 | 13.7 | 3.3 | 2.0 | 10.8 | 2.4 |
| 02/23/2014 10:00 | 12.9 | 2.2 | 1.9 | 10.1 | 2.2 |
| 02/23/2014 11:00 | 13.2 | 2.6 | 1.9 | 10.4 | 2.2 |
| 02/23/2014 12:00 | 13.4 | 2.9 | 1.9 | 10.4 | 2.2 |
| 02/23/2014 13:00 | 12.9 | 2.3 | 1.9 | 10.2 | 2.2 |
| 02/23/2014 14:00 | 12.9 | 2.2 | 1.9 | 10.2 | 2.2 |
| 02/23/2014 15:00 | 13.0 | 2.2 | 1.9 | 10.2 | 2.2 |
| 02/23/2014 16:00 | 15.0 | 2.8 | 1.9 | 10.4 | 2.2 |
| 02/23/2014 17:00 | 13.4 | 2.5 | 1.9 | 10.6 | 2.3 |
| 02/23/2014 18:00 | 16.6 | 2.8 | 2.1 | 11.4 | 2.4 |
| 02/23/2014 19:00 | 17.3 | 2.2 | 2.1 | 12.0 | 2.6 |
| 02/23/2014 20:00 | 17.3 | 2.2 | 2.1 | 11.8 | 2.6 |
| 02/23/2014 21:00 | 17.3 | 2.2 | 2.1 | 11.8 | 2.6 |
| 02/23/2014 22:00 | 17.3 | 2.2 | 2.1 | 11.8 | 2.6 |
| 02/23/2014 23:00 | 17.1 | 2.5 | 2.1 | 11.8 | 2.6 |
| **Average/Sum#:** | 364.1 # | 63.4 # | 48.7 # | 267.5 # | 58.1 # |
| **Minimum:** | 12.9 | 2.2 | 1.9 | 10.1 | 2.2 |
| **Maximum:** | 17.7 | 3.6 | 2.3 | 12.2 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/24/2014 00:00 | 13.9 | 3.3 | 2.0 | 10.9 | 2.4 |
| 02/24/2014 01:00 | 12.8 | 2.2 | 1.9 | 10.1 | 2.2 |
| 02/24/2014 02:00 | 12.5 | 2.2 | 1.7 | 9.8 | 2.2 |
| 02/24/2014 03:00 | 7.5 | 0.7 | 1.3 | 6.9 | 1.5 |
| 02/24/2014 04:00 | 7.3 | 0.7 | 1.3 | 6.8 | 1.4 |
| 02/24/2014 05:00 | 10.6 | 1.7 | 1.6 | 8.4 | 1.8 |
| 02/24/2014 06:00 | 11.3 | 3.3 | 1.9 | 10.3 | 2.2 |
| 02/24/2014 07:00 | 15.5 | 3.3 | 1.9 | 10.7 | 2.4 |
| 02/24/2014 08:00 | 14.4 | 6.5 | 2.0 | 11.3 | 2.4 |
| 02/24/2014 09:00 | 13.5 | 3.2 | 1.9 | 10.6 | 2.3 |
| 02/24/2014 10:00 | 12.7 | 3.3 | 1.8 | 10.0 | 2.2 |
| 02/24/2014 11:00 | 14.7 | 2.6 | 1.9 | 10.2 | 2.2 |
| 02/24/2014 12:00 | 12.7 | 2.9 | 1.8 | 10.0 | 2.2 |
| 02/24/2014 13:00 | 12.7 | 2.9 | 1.8 | 10.0 | 2.2 |
| 02/24/2014 14:00 | 12.7 | 2.6 | 1.8 | 10.0 | 2.2 |
| 02/24/2014 15:00 | 15.7 | 3.4 | 2.0 | 10.8 | 2.4 |
| 02/24/2014 16:00 | 15.7 | 3.4 | 2.0 | 10.7 | 2.4 |
| 02/24/2014 17:00 | 16.3 | 3.1 | 2.0 | 11.1 | 2.4 |
| 02/24/2014 18:00 | 16.9 | 2.5 | 2.1 | 11.6 | 2.6 |
| 02/24/2014 19:00 | 17.4 | 2.1 | 2.2 | 12.0 | 2.6 |
| 02/24/2014 20:00 | 17.3 | 2.2 | 2.1 | 11.9 | 2.6 |
| 02/24/2014 21:00 | 17.2 | 2.2 | 2.1 | 11.8 | 2.6 |
| 02/24/2014 22:00 | 17.2 | 2.2 | 2.1 | 11.7 | 2.6 |
| 02/24/2014 23:00 | 17.2 | 2.2 | 2.1 | 11.9 | 2.6 |
| **Average/Sum#:** | 335.7 # | 64.7 # | 45.3 # | 249.5 # | 54.6 # |
| **Minimum:** | 7.3 | 0.7 | 1.3 | 6.8 | 1.4 |
| **Maximum:** | 17.4 | 6.5 | 2.2 | 12.0 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/25/2014 00:00 | 14.2 | 3.2 | 2.0 | 11.1 | 2.4 |
| 02/25/2014 01:00 | 13.7 | 3.3 | 2.0 | 10.7 | 2.4 |
| 02/25/2014 02:00 | 12.8 | 2.5 | 1.9 | 10.1 | 2.2 |
| 02/25/2014 03:00 | 12.8 | 2.8 | 1.9 | 10.0 | 2.2 |
| 02/25/2014 04:00 | 12.8 | 2.8 | 1.9 | 10.0 | 2.2 |
| 02/25/2014 05:00 | 13.9 | 3.6 | 2.0 | 10.9 | 2.4 |
| 02/25/2014 06:00 | 14.1 | 3.9 | 2.0 | 11.1 | 2.4 |
| 02/25/2014 07:00 | 19.3 | 3.3 | 1.9 | 10.7 | 2.4 |
| 02/25/2014 08:00 | 13.9 | 3.5 | 2.0 | 10.9 | 2.4 |
| 02/25/2014 09:00 | 12.8 | 2.2 | 1.9 | 10.0 | 2.2 |
| 02/25/2014 10:00 | 7.3 | 0.3 | 1.9 | 10.0 | 2.2 |
| 02/25/2014 11:00 | 7.3 | 0.3 | 1.8 | 10.0 | 2.2 |
| 02/25/2014 12:00 | 7.3 | 0.3 | 1.8 | 10.0 | 2.2 |
| 02/25/2014 13:00 | 7.4 | 0.3 | 1.9 | 10.1 | 2.2 |
| 02/25/2014 14:00 | 10.9 | 3.2 | 1.8 | 10.0 | 2.2 |
| 02/25/2014 15:00 | 10.9 | 3.2 | 1.8 | 10.0 | 2.2 |
| 02/25/2014 16:00 | 13.0 | 3.5 | 1.9 | 10.2 | 2.2 |
| 02/25/2014 17:00 | 12.9 | 2.5 | 1.9 | 10.1 | 2.2 |
| 02/25/2014 18:00 | 13.6 | 3.5 | 2.0 | 10.7 | 2.4 |
| 02/25/2014 19:00 | 16.8 | 3.4 | 2.1 | 11.5 | 2.6 |
| 02/25/2014 20:00 | 17.0 | 3.1 | 2.1 | 11.7 | 2.6 |
| 02/25/2014 21:00 | 14.3 | 3.8 | 2.0 | 11.3 | 2.4 |
| 02/25/2014 22:00 | 13.6 | 3.2 | 2.0 | 10.6 | 2.4 |
| 02/25/2014 23:00 | 17.0 | 3.5 | 2.1 | 11.7 | 2.6 |
| **Average/Sum#:** | 280.3 # | 64.0 # | 46.6 # | 253.4 # | 55.8 # |
| **Minimum:** | 10.9 | 2.2 | 1.8 | 10.0 | 2.2 |
| **Maximum:** | 19.3 | 3.9 | 2.1 | 11.7 | 2.6 |
| **%SI** | 16.7 | 16.7 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/26/2014 00:00 | 13.5 | 3.2 | 1.9 | 10.6 | 2.3 |
| 02/26/2014 01:00 | 13.1 | 3.2 | 1.9 | 10.2 | 2.2 |
| 02/26/2014 02:00 | 13.0 | 3.1 | 1.9 | 10.2 | 2.2 |
| 02/26/2014 03:00 | 13.0 | 3.5 | 1.9 | 10.2 | 2.2 |
| 02/26/2014 04:00 | 12.8 | 3.5 | 1.9 | 10.1 | 2.2 |
| 02/26/2014 05:00 | 13.2 | 3.5 | 1.9 | 10.3 | 2.2 |
| 02/26/2014 06:00 | 16.5 | 4.1 | 2.0 | 11.3 | 2.4 |
| 02/26/2014 07:00 | 17.2 | 3.5 | 2.1 | 11.9 | 2.6 |
| 02/26/2014 08:00 | 17.9 | 2.5 | 2.3 | 12.3 | 2.6 |
| 02/26/2014 09:00 | 17.9 | 2.5 | 2.3 | 12.3 | 2.6 |
| 02/26/2014 10:00 | 9.0 | 2.5 | 2.3 | 12.3 | 2.7 |
| 02/26/2014 11:00 | 8.9 | 2.5 | 2.3 | 12.1 | 2.6 |
| 02/26/2014 12:00 | 6.4 | 2.8 | 2.1 | 11.4 | 2.5 |
| 02/26/2014 13:00 | 8.6 | 2.8 | 2.2 | 11.9 | 2.6 |
| 02/26/2014 14:00 | 12.5 | 3.5 | 2.0 | 11.5 | 2.5 |
| 02/26/2014 15:00 | 14.4 | 3.5 | 2.0 | 11.4 | 2.5 |
| 02/26/2014 16:00 | 14.1 | 3.8 | 2.0 | 11.1 | 2.4 |
| 02/26/2014 17:00 | 14.8 | 3.2 | 2.1 | 11.7 | 2.6 |
| 02/26/2014 18:00 | 17.2 | 3.1 | 2.1 | 11.9 | 2.6 |
| 02/26/2014 19:00 | 17.9 | 2.5 | 2.3 | 12.3 | 2.6 |
| 02/26/2014 20:00 | 17.8 | 2.5 | 2.3 | 12.2 | 2.6 |
| 02/26/2014 21:00 | 17.6 | 2.2 | 2.2 | 12.1 | 2.6 |
| 02/26/2014 22:00 | 17.4 | 2.5 | 2.2 | 11.9 | 2.6 |
| 02/26/2014 23:00 | 14.9 | 2.8 | 2.1 | 11.7 | 2.6 |
| **Average/Sum#:** | 306.7 # | 62.2 # | 50.3 # | 274.9 # | 59.5 # |
| **Minimum:** | 12.5 | 2.2 | 1.9 | 10.1 | 2.2 |
| **Maximum:** | 17.9 | 4.1 | 2.3 | 12.3 | 2.7 |
| **%SI** | 16.7 | 16.7 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/27/2014 00:00 | 13.9 | 3.5 | 2.0 | 10.9 | 2.4 |
| 02/27/2014 01:00 | 13.0 | 2.8 | 1.9 | 10.3 | 2.2 |
| 02/27/2014 02:00 | 9.4 | 1.4 | 1.6 | 8.6 | 1.8 |
| 02/27/2014 03:00 | 7.7 | 0.7 | 1.3 | 7.1 | 1.6 |
| 02/27/2014 04:00 | 9.4 | 0.9 | 1.6 | 8.6 | 1.8 |
| 02/27/2014 05:00 | 12.1 | 2.1 | 1.7 | 9.5 | 2.0 |
| 02/27/2014 06:00 | 13.3 | 3.6 | 1.9 | 10.4 | 2.2 |
| 02/27/2014 07:00 | 13.2 | 3.6 | 1.9 | 10.3 | 2.2 |
| 02/27/2014 08:00 | 14.2 | 3.8 | 2.0 | 11.1 | 2.4 |
| 02/27/2014 09:00 | 12.9 | 4.6 | 1.9 | 10.2 | 2.2 |
| 02/27/2014 10:00 | 12.8 | 5.9 | 1.9 | 10.0 | 2.2 |
| 02/27/2014 11:00 | 12.8 | 5.2 | 1.9 | 10.0 | 2.2 |
| 02/27/2014 12:00 | 12.8 | 3.6 | 1.9 | 10.0 | 2.2 |
| 02/27/2014 13:00 | 12.9 | 2.9 | 1.9 | 10.0 | 2.2 |
| 02/27/2014 14:00 | 12.8 | 2.9 | 1.9 | 10.0 | 2.2 |
| 02/27/2014 15:00 | 12.9 | 2.9 | 1.9 | 10.0 | 2.2 |
| 02/27/2014 16:00 | 12.9 | 2.9 | 1.9 | 10.1 | 2.2 |
| 02/27/2014 17:00 | 13.2 | 3.3 | 1.9 | 10.4 | 2.2 |
| 02/27/2014 18:00 | 13.3 | 2.9 | 1.9 | 10.4 | 2.2 |
| 02/27/2014 19:00 | 14.4 | 4.5 | 2.0 | 11.3 | 2.4 |
| 02/27/2014 20:00 | 14.3 | 4.5 | 2.0 | 11.3 | 2.4 |
| 02/27/2014 21:00 | 14.4 | 4.6 | 2.0 | 11.3 | 2.4 |
| 02/27/2014 22:00 | 14.2 | 4.5 | 2.0 | 11.1 | 2.4 |
| 02/27/2014 23:00 | 14.4 | 4.5 | 2.0 | 11.3 | 2.4 |
| **Average/Sum#:** | 307.2 # | 82.1 # | 44.9 # | 244.2 # | 52.6 # |
| **Minimum:** | 7.7 | 0.7 | 1.3 | 7.1 | 1.6 |
| **Maximum:** | 14.4 | 5.9 | 2.0 | 11.3 | 2.4 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 02/28/2014 00:00 | 13.3 | 3.2 | 1.9 | 10.5 | 2.3 |
| 02/28/2014 01:00 | 13.0 | 3.0 | 1.9 | 10.2 | 2.2 |
| 02/28/2014 02:00 | 13.5 | 3.3 | 1.9 | 10.6 | 2.3 |
| 02/28/2014 03:00 | 13.0 | 3.0 | 1.9 | 10.2 | 2.2 |
| 02/28/2014 04:00 | 13.0 | 3.0 | 1.9 | 10.3 | 2.2 |
| 02/28/2014 05:00 | 13.1 | 3.3 | 1.9 | 10.3 | 2.2 |
| 02/28/2014 06:00 | 13.1 | 3.3 | 1.9 | 10.3 | 2.2 |
| 02/28/2014 07:00 | 13.2 | 3.3 | 1.9 | 10.3 | 2.2 |
| 02/28/2014 08:00 | 14.2 | 4.6 | 2.0 | 11.1 | 2.4 |
| 02/28/2014 09:00 | 15.1 | 4.1 | 2.2 | 11.8 | 2.6 |
| 02/28/2014 10:00 | 17.6 | 3.8 | 2.2 | 12.1 | 2.6 |
| 02/28/2014 11:00 | 15.3 | 3.8 | 2.2 | 12.0 | 2.6 |
| 02/28/2014 12:00 | 15.0 | 3.8 | 2.2 | 11.8 | 2.6 |
| 02/28/2014 13:00 | 14.2 | 3.8 | 2.0 | 11.2 | 2.4 |
| 02/28/2014 14:00 | 13.2 | 2.9 | 1.9 | 10.3 | 2.2 |
| 02/28/2014 15:00 | 13.7 | 3.9 | 1.9 | 10.7 | 2.4 |
| 02/28/2014 16:00 | 14.9 | 4.1 | 2.1 | 11.6 | 2.6 |
| 02/28/2014 17:00 | 14.6 | 4.5 | 2.0 | 11.4 | 2.5 |
| 02/28/2014 18:00 | 13.7 | 3.3 | 1.9 | 10.7 | 2.4 |
| 02/28/2014 19:00 | 14.1 | 4.2 | 2.0 | 11.1 | 2.4 |
| 02/28/2014 20:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 02/28/2014 21:00 | 13.8 | 3.9 | 2.0 | 10.9 | 2.4 |
| 02/28/2014 22:00 | 14.1 | 4.2 | 2.0 | 11.1 | 2.4 |
| 02/28/2014 23:00 | 14.4 | 4.5 | 2.0 | 11.3 | 2.4 |
| **Average/Sum#:** | 336.1 # | 87.6 # | 47.7 # | 262.0 # | 56.9 # |
| **Minimum:** | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| **Maximum:** | 17.6 | 4.6 | 2.2 | 12.1 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/01/2014 00:00 | 13.7 | 3.9 | 2.0 | 10.7 | 2.4 |
| 03/01/2014 01:00 | 13.1 | 2.8 | 1.9 | 10.3 | 2.2 |
| 03/01/2014 02:00 | 13.0 | 2.8 | 1.9 | 10.1 | 2.2 |
| 03/01/2014 03:00 | 13.0 | 2.8 | 1.9 | 10.1 | 2.2 |
| 03/01/2014 04:00 | 13.0 | 2.8 | 1.9 | 10.1 | 2.2 |
| 03/01/2014 05:00 | 13.0 | 2.8 | 1.9 | 10.3 | 2.2 |
| 03/01/2014 06:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 03/01/2014 07:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 03/01/2014 08:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 03/01/2014 09:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 03/01/2014 10:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 03/01/2014 11:00 | 13.0 | 2.9 | 1.9 | 10.2 | 2.2 |
| 03/01/2014 12:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 03/01/2014 13:00 | 13.2 | 2.9 | 1.9 | 10.3 | 2.2 |
| 03/01/2014 14:00 | 14.1 | 4.2 | 2.0 | 11.1 | 2.4 |
| 03/01/2014 15:00 | 14.1 | 4.3 | 2.0 | 11.1 | 2.4 |
| 03/01/2014 16:00 | 13.2 | 3.0 | 1.9 | 10.4 | 2.2 |
| 03/01/2014 17:00 | 13.0 | 2.9 | 1.9 | 10.2 | 2.2 |
| 03/01/2014 18:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 03/01/2014 19:00 | 13.7 | 3.9 | 2.0 | 10.7 | 2.4 |
| 03/01/2014 20:00 | 13.6 | 3.5 | 1.9 | 10.7 | 2.4 |
| 03/01/2014 21:00 | 14.0 | 4.2 | 2.0 | 11.1 | 2.4 |
| 03/01/2014 22:00 | 14.0 | 3.9 | 2.0 | 11.0 | 2.4 |
| 03/01/2014 23:00 | 14.2 | 4.5 | 2.0 | 11.2 | 2.4 |
| **Average/Sum#:** | 319.9 # | 77.7 # | 46.3 # | 251.0 # | 54.4 # |
| **Minimum:** | 13.0 | 2.8 | 1.9 | 10.1 | 2.2 |
| **Maximum:** | 14.2 | 4.5 | 2.0 | 11.2 | 2.4 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/02/2014 00:00 | 13.5 | 3.3 | 1.9 | 10.6 | 2.3 |
| 03/02/2014 01:00 | 14.2 | 4.3 | 2.0 | 11.1 | 2.4 |
| 03/02/2014 02:00 | 14.1 | 3.7 | 2.0 | 11.1 | 2.4 |
| 03/02/2014 03:00 | 13.1 | 2.9 | 1.9 | 10.3 | 2.2 |
| 03/02/2014 04:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 03/02/2014 05:00 | 13.3 | 3.0 | 1.9 | 10.4 | 2.2 |
| 03/02/2014 06:00 | 11.9 | 4.0 | 2.0 | 10.9 | 2.4 |
| 03/02/2014 07:00 | 14.5 | 4.6 | 2.0 | 11.4 | 2.5 |
| 03/02/2014 08:00 | 14.4 | 4.3 | 2.0 | 11.3 | 2.4 |
| 03/02/2014 09:00 | 13.7 | 3.0 | 2.0 | 10.7 | 2.4 |
| 03/02/2014 10:00 | 14.4 | 4.3 | 2.0 | 11.2 | 2.4 |
| 03/02/2014 11:00 | 17.6 | 4.2 | 2.2 | 12.2 | 2.6 |
| 03/02/2014 12:00 | 15.3 | 4.2 | 2.2 | 12.0 | 2.6 |
| 03/02/2014 13:00 | 17.8 | 3.2 | 2.2 | 12.3 | 2.7 |
| 03/02/2014 14:00 | 17.8 | 3.1 | 2.2 | 12.3 | 2.7 |
| 03/02/2014 15:00 | 17.8 | 3.1 | 2.2 | 12.2 | 2.6 |
| 03/02/2014 16:00 | 17.7 | 3.1 | 2.2 | 12.2 | 2.6 |
| 03/02/2014 17:00 | 17.4 | 3.5 | 2.2 | 12.0 | 2.6 |
| 03/02/2014 18:00 | 14.7 | 3.7 | 2.1 | 11.6 | 2.5 |
| 03/02/2014 19:00 | 14.8 | 4.1 | 2.1 | 11.6 | 2.6 |
| 03/02/2014 20:00 | 14.4 | 4.2 | 2.0 | 11.3 | 2.4 |
| 03/02/2014 21:00 | 15.0 | 4.2 | 2.1 | 11.8 | 2.6 |
| 03/02/2014 22:00 | 14.4 | 3.9 | 2.0 | 11.3 | 2.4 |
| 03/02/2014 23:00 | 14.0 | 3.3 | 2.0 | 11.0 | 2.4 |
| **Average/Sum#:** | 358.8 # | 88.0 # | 49.3 # | 273.0 # | 59.1 # |
| **Minimum:** | 11.9 | 2.8 | 1.9 | 10.2 | 2.2 |
| **Maximum:** | 17.8 | 4.6 | 2.2 | 12.3 | 2.7 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/03/2014 00:00 | 9.7 | 1.7 | 1.6 | 8.8 | 2.0 |
| 03/03/2014 01:00 | 7.2 | 0.8 | 1.4 | 7.9 | 1.8 |
| 03/03/2014 02:00 | 6.5 | 1.0 | 1.3 | 7.1 | 1.6 |
| 03/03/2014 03:00 | 6.5 | 1.0 | 1.3 | 7.1 | 1.6 |
| 03/03/2014 04:00 | 6.5 | 1.0 | 1.3 | 7.1 | 1.6 |
| 03/03/2014 05:00 | 9.6 | 2.0 | 1.6 | 8.8 | 1.9 |
| 03/03/2014 06:00 | 13.2 | 2.8 | 1.9 | 10.4 | 2.2 |
| 03/03/2014 07:00 | 14.0 | 3.9 | 2.0 | 11.1 | 2.4 |
| 03/03/2014 08:00 | 17.7 | 3.8 | 2.2 | 12.2 | 2.6 |
| 03/03/2014 09:00 | 17.3 | 3.5 | 2.2 | 11.8 | 2.6 |
| 03/03/2014 10:00 | 14.0 | 3.6 | 2.0 | 11.0 | 2.4 |
| 03/03/2014 11:00 | 13.5 | 3.0 | 1.9 | 10.6 | 2.3 |
| 03/03/2014 12:00 | 13.2 | 2.8 | 1.9 | 10.4 | 2.2 |
| 03/03/2014 13:00 | 13.0 | 2.8 | 1.9 | 10.2 | 2.2 |
| 03/03/2014 14:00 | 13.2 | 2.9 | 1.9 | 10.3 | 2.2 |
| 03/03/2014 15:00 | 13.5 | 3.0 | 1.9 | 10.6 | 2.3 |
| 03/03/2014 16:00 | 14.1 | 3.7 | 2.0 | 11.1 | 2.4 |
| 03/03/2014 17:00 | 15.5 | 3.9 | 2.2 | 12.2 | 2.6 |
| 03/03/2014 18:00 | 14.6 | 3.5 | 2.0 | 11.4 | 2.5 |
| 03/03/2014 19:00 | 17.6 | 3.2 | 2.2 | 12.1 | 2.6 |
| 03/03/2014 20:00 | 17.9 | 2.9 | 2.3 | 12.3 | 2.6 |
| 03/03/2014 21:00 | 17.7 | 2.9 | 2.2 | 12.2 | 2.6 |
| 03/03/2014 22:00 | 13.8 | 3.2 | 2.0 | 10.9 | 2.4 |
| 03/03/2014 23:00 | 13.0 | 2.5 | 1.9 | 10.1 | 2.2 |
| **Average/Sum#:** | 312.8 # | 65.4 # | 45.1 # | 247.7 # | 53.8 # |
| **Minimum:** | 6.5 | 0.8 | 1.3 | 7.1 | 1.6 |
| **Maximum:** | 17.9 | 3.9 | 2.3 | 12.3 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/04/2014 00:00 | 9.4 | 1.7 | 1.6 | 8.6 | 1.8 |
| 03/04/2014 01:00 | 6.3 | 0.7 | 1.3 | 6.9 | 1.6 |
| 03/04/2014 02:00 | 6.3 | 0.9 | 1.3 | 7.0 | 1.6 |
| 03/04/2014 03:00 | 6.7 | 1.0 | 1.3 | 7.3 | 1.6 |
| 03/04/2014 04:00 | 6.4 | 0.9 | 1.3 | 7.0 | 1.6 |
| 03/04/2014 05:00 | 6.5 | 1.2 | 1.3 | 7.1 | 1.6 |
| 03/04/2014 06:00 | 8.0 | 2.0 | 1.6 | 8.8 | 2.0 |
| 03/04/2014 07:00 | 13.0 | 2.6 | 1.9 | 10.2 | 2.2 |
| 03/04/2014 08:00 | 13.0 | 2.5 | 1.9 | 10.2 | 2.2 |
| 03/04/2014 09:00 | 7.2 | 1.1 | 1.4 | 7.9 | 1.8 |
| 03/04/2014 10:00 | 6.2 | 0.9 | 1.3 | 6.8 | 1.4 |
| 03/04/2014 11:00 | 6.2 | 0.9 | 1.3 | 6.8 | 1.4 |
| 03/04/2014 12:00 | 7.6 | 0.9 | 1.3 | 7.0 | 1.6 |
| 03/04/2014 13:00 | 8.5 | 1.1 | 1.4 | 7.8 | 1.8 |
| 03/04/2014 14:00 | 12.9 | 2.9 | 1.9 | 10.2 | 2.2 |
| 03/04/2014 15:00 | 13.0 | 3.0 | 1.9 | 10.2 | 2.2 |
| 03/04/2014 16:00 | 13.0 | 3.0 | 1.9 | 10.2 | 2.2 |
| 03/04/2014 17:00 | 13.0 | 2.6 | 1.9 | 10.2 | 2.2 |
| 03/04/2014 18:00 | 13.2 | 3.0 | 1.9 | 10.4 | 2.2 |
| 03/04/2014 19:00 | 15.0 | 3.9 | 2.1 | 11.7 | 2.6 |
| 03/04/2014 20:00 | 16.8 | 3.5 | 2.1 | 11.5 | 2.6 |
| 03/04/2014 21:00 | 14.1 | 3.9 | 2.0 | 11.1 | 2.4 |
| 03/04/2014 22:00 | 13.6 | 3.2 | 2.0 | 10.7 | 2.4 |
| 03/04/2014 23:00 | 13.0 | 2.5 | 1.9 | 10.2 | 2.2 |
| **Average/Sum#:** | 248.9 # | 49.9 # | 39.8 # | 215.8 # | 47.4 # |
| **Minimum:** | 6.2 | 0.7 | 1.3 | 6.8 | 1.4 |
| **Maximum:** | 16.8 | 3.9 | 2.1 | 11.7 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/05/2014 00:00 | 13.2 | 2.6 | 1.9 | 10.3 | 2.2 |
| 03/05/2014 01:00 | 13.9 | 3.5 | 2.0 | 11.0 | 2.4 |
| 03/05/2014 02:00 | 14.1 | 3.6 | 2.0 | 11.1 | 2.4 |
| 03/05/2014 03:00 | 13.2 | 2.8 | 1.9 | 10.4 | 2.2 |
| 03/05/2014 04:00 | 13.0 | 2.5 | 1.9 | 10.2 | 2.2 |
| 03/05/2014 05:00 | 13.7 | 3.3 | 2.0 | 10.8 | 2.4 |
| 03/05/2014 06:00 | 13.5 | 3.0 | 1.9 | 10.7 | 2.3 |
| 03/05/2014 07:00 | 13.7 | 3.3 | 2.0 | 10.7 | 2.4 |
| 03/05/2014 08:00 | 13.7 | 3.6 | 2.0 | 10.8 | 2.4 |
| 03/05/2014 09:00 | 13.1 | 2.8 | 1.9 | 10.3 | 2.2 |
| 03/05/2014 10:00 | 13.1 | 2.8 | 1.9 | 10.3 | 2.2 |
| 03/05/2014 11:00 | 13.2 | 2.9 | 1.9 | 10.3 | 2.2 |
| 03/05/2014 12:00 | 13.2 | 2.9 | 1.9 | 10.3 | 2.2 |
| 03/05/2014 13:00 | 13.2 | 2.9 | 1.9 | 10.3 | 2.2 |
| 03/05/2014 14:00 | 13.2 | 3.2 | 1.9 | 10.3 | 2.2 |
| 03/05/2014 15:00 | 13.2 | 2.9 | 1.9 | 10.3 | 2.2 |
| 03/05/2014 16:00 | 13.4 | 3.2 | 1.9 | 10.5 | 2.3 |
| 03/05/2014 17:00 | 13.7 | 3.5 | 2.0 | 10.7 | 2.4 |
| 03/05/2014 18:00 | 13.7 | 3.5 | 2.0 | 10.8 | 2.4 |
| 03/05/2014 19:00 | 14.4 | 4.1 | 2.0 | 11.3 | 2.4 |
| 03/05/2014 20:00 | 14.1 | 3.8 | 2.0 | 11.1 | 2.4 |
| 03/05/2014 21:00 | 13.9 | 3.5 | 2.0 | 10.9 | 2.4 |
| 03/05/2014 22:00 | 13.9 | 3.5 | 2.0 | 10.9 | 2.4 |
| 03/05/2014 23:00 | 11.2 | 2.8 | 1.9 | 10.2 | 2.2 |
| **Average/Sum#:** | 322.5 # | 76.5 # | 46.7 # | 254.5 # | 55.2 # |
| **Minimum:** | 11.2 | 2.5 | 1.9 | 10.2 | 2.2 |
| **Maximum:** | 14.4 | 4.1 | 2.0 | 11.3 | 2.4 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/06/2014 00:00 | 11.2 | 2.8 | 1.9 | 10.2 | 2.2 |
| 03/06/2014 01:00 | 12.6 | 2.8 | 1.7 | 10.0 | 2.2 |
| 03/06/2014 02:00 | 6.3 | 0.7 | 1.3 | 7.0 | 1.6 |
| 03/06/2014 03:00 | 6.0 | 9.2 | 0.2 | 0.8 | 0.2 |
| 03/06/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/06/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 36.1 # | 15.5 # | 5.1 # | 28.0 # | 6.2 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 12.6 | 9.2 | 1.9 | 10.2 | 2.2 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/07/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/07/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/07/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/07/2014 03:00 | 62.9 | 69.0 | 0.2 | 0.8 | 0.2 |
| 03/07/2014 04:00 | 57.8 | 40.3 | 0.4 | 1.6 | 0.4 |
| 03/07/2014 05:00 | 51.1 | 59.2 | 0.7 | 2.4 | 0.6 |
| 03/07/2014 06:00 | 2.9 | 0.8 | 1.0 | 3.6 | 0.9 |
| 03/07/2014 07:00 | 78.7 | 76.5 | 1.4 | 5.4 | 1.3 |
| 03/07/2014 08:00 | 92.2 | 30.4 | 1.4 | 7.3 | 1.6 |
| 03/07/2014 09:00 | 6.7 | 0.8 | 1.3 | 7.3 | 1.6 |
| 03/07/2014 10:00 | 12.7 | 2.5 | 1.8 | 9.9 | 2.2 |
| 03/07/2014 11:00 | 12.9 | 2.5 | 1.9 | 10.2 | 2.2 |
| 03/07/2014 12:00 | 12.9 | 2.5 | 1.9 | 10.2 | 2.2 |
| 03/07/2014 13:00 | 12.9 | 2.6 | 1.9 | 10.2 | 2.2 |
| 03/07/2014 14:00 | 12.9 | 2.6 | 1.9 | 10.2 | 2.2 |
| 03/07/2014 15:00 | 12.9 | 2.6 | 1.9 | 10.2 | 2.2 |
| 03/07/2014 16:00 | 13.1 | 2.6 | 1.9 | 10.3 | 2.2 |
| 03/07/2014 17:00 | 14.1 | 4.0 | 2.0 | 11.1 | 2.4 |
| 03/07/2014 18:00 | 14.2 | 3.9 | 2.0 | 11.1 | 2.4 |
| 03/07/2014 19:00 | 15.4 | 3.9 | 2.2 | 12.0 | 2.6 |
| 03/07/2014 20:00 | 18.2 | 2.9 | 2.3 | 12.5 | 2.7 |
| 03/07/2014 21:00 | 18.1 | 2.9 | 2.3 | 12.5 | 2.7 |
| 03/07/2014 22:00 | 18.0 | 2.9 | 2.3 | 12.4 | 2.7 |
| 03/07/2014 23:00 | 15.3 | 3.2 | 2.2 | 12.1 | 2.6 |
| **Average/Sum#:** | 555.9 # | 318.6 # | 34.9 # | 183.3 # | 40.1 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 92.2 | 76.5 | 2.3 | 12.5 | 2.7 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/08/2014 00:00 | 13.9 | 2.7 | 1.9 | 10.9 | 2.4 |
| 03/08/2014 01:00 | 13.8 | 3.0 | 2.0 | 10.9 | 2.4 |
| 03/08/2014 02:00 | 13.5 | 3.0 | 1.9 | 10.7 | 2.3 |
| 03/08/2014 03:00 | 13.4 | 3.0 | 1.9 | 10.5 | 2.3 |
| 03/08/2014 04:00 | 13.7 | 3.0 | 2.0 | 10.8 | 2.4 |
| 03/08/2014 05:00 | 14.1 | 3.7 | 2.0 | 11.1 | 2.4 |
| 03/08/2014 06:00 | 14.4 | 3.6 | 2.0 | 11.3 | 2.4 |
| 03/08/2014 07:00 | 14.2 | 3.4 | 2.0 | 11.1 | 2.4 |
| 03/08/2014 08:00 | 13.2 | 2.2 | 1.9 | 10.3 | 2.2 |
| 03/08/2014 09:00 | 12.8 | 2.2 | 1.9 | 10.1 | 2.2 |
| 03/08/2014 10:00 | 12.8 | 2.2 | 1.9 | 10.1 | 2.2 |
| 03/08/2014 11:00 | 12.8 | 2.2 | 1.9 | 10.1 | 2.2 |
| 03/08/2014 12:00 | 12.8 | 2.2 | 1.9 | 10.1 | 2.2 |
| 03/08/2014 13:00 | 12.8 | 2.5 | 1.9 | 10.1 | 2.2 |
| 03/08/2014 14:00 | 12.8 | 2.2 | 1.9 | 10.1 | 2.2 |
| 03/08/2014 15:00 | 12.8 | 2.2 | 1.9 | 10.1 | 2.2 |
| 03/08/2014 16:00 | 13.0 | 2.2 | 1.9 | 10.2 | 2.2 |
| 03/08/2014 17:00 | 13.2 | 2.6 | 1.9 | 10.3 | 2.2 |
| 03/08/2014 18:00 | 14.8 | 3.8 | 2.1 | 11.6 | 2.6 |
| 03/08/2014 19:00 | 15.5 | 3.5 | 2.2 | 12.2 | 2.6 |
| 03/08/2014 20:00 | 18.0 | 2.8 | 2.3 | 12.3 | 2.7 |
| 03/08/2014 21:00 | 17.8 | 2.5 | 2.2 | 12.3 | 2.7 |
| 03/08/2014 22:00 | 18.0 | 2.5 | 2.3 | 12.3 | 2.7 |
| 03/08/2014 23:00 | 15.4 | 2.9 | 2.2 | 12.1 | 2.6 |
| **Average/Sum#:** | 339.5 # | 66.1 # | 48.0 # | 261.6 # | 56.9 # |
| **Minimum:** | 12.8 | 2.2 | 1.9 | 10.1 | 2.2 |
| **Maximum:** | 18.0 | 3.8 | 2.3 | 12.3 | 2.7 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/09/2014 00:00 | 12.7 | 2.4 | 1.8 | 10.0 | 2.2 |
| 03/09/2014 01:00 | 6.9 | 0.8 | 1.4 | 7.5 | 1.6 |
| 03/09/2014 02:00 | 5.6 | 10.3 | 0.1 | 0.8 | 0.2 |
| 03/09/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/09/2014 11:00 | 49.0 | 44.8 | 0.3 | 1.1 | 0.3 |
| 03/09/2014 12:00 | 39.2 | 84.2 | 0.6 | 2.2 | 0.5 |
| 03/09/2014 13:00 | 1.3 | 1.0 | 0.9 | 3.4 | 0.8 |
| 03/09/2014 14:00 | 5.3 | 1.3 | 1.2 | 4.4 | 1.1 |
| 03/09/2014 15:00 | 79.1 | 40.2 | 1.4 | 5.6 | 1.4 |
| 03/09/2014 16:00 | 50.8 | 22.7 | 1.5 | 8.0 | 1.7 |
| 03/09/2014 17:00 | 14.5 | 4.3 | 2.0 | 11.3 | 2.4 |
| 03/09/2014 18:00 | 15.5 | 3.5 | 2.2 | 12.2 | 2.6 |
| 03/09/2014 19:00 | 17.9 | 3.1 | 2.3 | 12.3 | 2.6 |
| 03/09/2014 20:00 | 17.9 | 2.8 | 2.3 | 12.3 | 2.6 |
| 03/09/2014 21:00 | 17.9 | 2.5 | 2.3 | 12.3 | 2.6 |
| 03/09/2014 22:00 | 11.6 | 3.2 | 1.9 | 10.6 | 2.3 |
| 03/09/2014 23:00 | 14.2 | 2.8 | 2.0 | 10.9 | 2.4 |
| **Average/Sum#:** | 359.4 # | 229.9 # | 24.2 # | 124.9 # | 27.3 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 79.1 | 84.2 | 2.3 | 12.3 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/10/2014 00:00 | 11.6 | 3.2 | 2.0 | 10.6 | 2.3 |
| 03/10/2014 01:00 | 6.5 | 1.0 | 1.3 | 7.2 | 1.6 |
| 03/10/2014 02:00 | 6.2 | 0.9 | 1.3 | 6.8 | 1.4 |
| 03/10/2014 03:00 | 6.2 | 0.9 | 1.3 | 6.8 | 1.4 |
| 03/10/2014 04:00 | 6.3 | 0.9 | 1.3 | 6.9 | 1.5 |
| 03/10/2014 05:00 | 7.7 | 1.4 | 1.6 | 8.5 | 1.8 |
| 03/10/2014 06:00 | 13.1 | 3.3 | 1.9 | 10.3 | 2.3 |
| 03/10/2014 07:00 | 14.0 | 3.6 | 2.0 | 10.8 | 2.4 |
| 03/10/2014 08:00 | 16.0 | 3.5 | 2.1 | 11.0 | 2.4 |
| 03/10/2014 09:00 | 13.2 | 2.8 | 1.9 | 10.3 | 2.2 |
| 03/10/2014 10:00 | 12.8 | 2.5 | 1.9 | 10.1 | 2.2 |
| 03/10/2014 11:00 | 12.9 | 2.5 | 1.9 | 10.2 | 2.2 |
| 03/10/2014 12:00 | 12.9 | 2.5 | 1.9 | 10.2 | 2.2 |
| 03/10/2014 13:00 | 12.9 | 2.5 | 1.9 | 10.2 | 2.2 |
| 03/10/2014 14:00 | 13.0 | 2.6 | 1.9 | 10.2 | 2.2 |
| 03/10/2014 15:00 | 13.0 | 2.6 | 1.9 | 10.2 | 2.2 |
| 03/10/2014 16:00 | 13.0 | 2.6 | 1.9 | 10.2 | 2.2 |
| 03/10/2014 17:00 | 13.0 | 2.6 | 1.9 | 10.2 | 2.2 |
| 03/10/2014 18:00 | 13.0 | 2.3 | 1.9 | 10.2 | 2.2 |
| 03/10/2014 19:00 | 15.1 | 4.3 | 2.2 | 11.9 | 2.6 |
| 03/10/2014 20:00 | 14.7 | 3.6 | 2.1 | 11.6 | 2.5 |
| 03/10/2014 21:00 | 12.1 | 2.1 | 1.7 | 9.5 | 2.0 |
| 03/10/2014 22:00 | 8.4 | 0.8 | 1.4 | 7.7 | 1.6 |
| 03/10/2014 23:00 | 7.8 | 8.7 | 0.1 | 0.7 | 0.2 |
| **Average/Sum#:** | 275.4 # | 63.7 # | 41.3 # | 222.3 # | 48.0 # |
| **Minimum:** | 6.2 | 0.8 | 0.1 | 0.7 | 0.2 |
| **Maximum:** | 16.0 | 8.7 | 2.2 | 11.9 | 2.6 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/11/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/11/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/11/2014 02:00 | 3.2 | 12.2 | 0.2 | 0.7 | 0.2 |
| 03/11/2014 03:00 | 41.7 | 33.4 | 0.6 | 2.3 | 0.6 |
| 03/11/2014 04:00 | 2.7 | 0.8 | 0.9 | 3.3 | 0.8 |
| 03/11/2014 05:00 | 26.6 | 7.6 | 1.1 | 4.4 | 1.0 |
| 03/11/2014 06:00 | 103.1 | 51.0 | 1.4 | 6.5 | 1.4 |
| 03/11/2014 07:00 | 12.4 | 1.3 | 1.7 | 9.7 | 2.2 |
| 03/11/2014 08:00 | 13.1 | 2.9 | 1.9 | 10.4 | 2.2 |
| 03/11/2014 09:00 | 12.8 | 2.5 | 1.9 | 10.1 | 2.2 |
| 03/11/2014 10:00 | 5.4 | 2.5 | 1.9 | 10.1 | 2.2 |
| 03/11/2014 11:00 | 5.4 | 2.8 | 1.9 | 10.1 | 2.2 |
| 03/11/2014 12:00 | 5.2 | 2.1 | 1.7 | 9.5 | 2.0 |
| 03/11/2014 13:00 | 8.0 | 0.8 | 1.3 | 7.3 | 1.6 |
| 03/11/2014 14:00 | 7.6 | 0.7 | 1.3 | 7.0 | 1.6 |
| 03/11/2014 15:00 | 7.8 | 0.7 | 1.3 | 7.1 | 1.6 |
| 03/11/2014 16:00 | 9.6 | 0.8 | 1.4 | 7.5 | 1.6 |
| 03/11/2014 17:00 | 9.6 | 0.8 | 1.4 | 7.7 | 1.6 |
| 03/11/2014 18:00 | 11.0 | 1.7 | 1.6 | 8.6 | 1.8 |
| 03/11/2014 19:00 | 14.5 | 3.9 | 2.0 | 11.5 | 2.5 |
| 03/11/2014 20:00 | 15.1 | 3.9 | 2.2 | 11.9 | 2.6 |
| 03/11/2014 21:00 | 14.7 | 4.0 | 2.1 | 11.6 | 2.5 |
| 03/11/2014 22:00 | 15.2 | 3.9 | 2.2 | 12.0 | 2.6 |
| 03/11/2014 23:00 | 12.3 | 2.4 | 1.7 | 9.6 | 2.1 |
| **Average/Sum#:** | 341.0 # | 142.7 # | 33.7 # | 178.9 # | 39.1 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 103.1 | 51.0 | 2.2 | 12.0 | 2.6 |
| **%SI** | 12.5 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/12/2014 00:00 | 6.3 | 0.7 | 1.3 | 7.0 | 1.6 |
| 03/12/2014 01:00 | 7.6 | 0.7 | 1.3 | 6.9 | 1.6 |
| 03/12/2014 02:00 | 7.5 | 0.7 | 1.3 | 6.8 | 1.4 |
| 03/12/2014 03:00 | 7.4 | 0.7 | 1.3 | 6.8 | 1.4 |
| 03/12/2014 04:00 | 7.5 | 0.9 | 1.3 | 6.8 | 1.4 |
| 03/12/2014 05:00 | 12.0 | 2.4 | 1.7 | 9.5 | 2.0 |
| 03/12/2014 06:00 | 13.9 | 3.6 | 2.0 | 10.9 | 2.4 |
| 03/12/2014 07:00 | 15.3 | 3.9 | 2.2 | 12.0 | 2.6 |
| 03/12/2014 08:00 | 14.0 | 3.3 | 2.0 | 10.9 | 2.4 |
| 03/12/2014 09:00 | 13.0 | 2.2 | 1.9 | 10.2 | 2.2 |
| 03/12/2014 10:00 | 12.9 | 2.2 | 1.9 | 10.2 | 2.2 |
| 03/12/2014 11:00 | 11.1 | 2.2 | 1.9 | 10.2 | 2.2 |
| 03/12/2014 12:00 | 6.8 | 1.0 | 1.3 | 7.5 | 1.6 |
| 03/12/2014 13:00 | 9.6 | 0.8 | 1.4 | 7.5 | 1.6 |
| 03/12/2014 14:00 | 8.7 | 0.7 | 1.3 | 6.9 | 1.5 |
| 03/12/2014 15:00 | 8.7 | 0.7 | 1.3 | 6.9 | 1.5 |
| 03/12/2014 16:00 | 8.7 | 0.7 | 1.3 | 6.9 | 1.5 |
| 03/12/2014 17:00 | 10.8 | 1.4 | 1.6 | 8.5 | 1.8 |
| 03/12/2014 18:00 | 13.4 | 3.3 | 1.9 | 10.5 | 2.2 |
| 03/12/2014 19:00 | 15.2 | 4.3 | 2.2 | 11.9 | 2.6 |
| 03/12/2014 20:00 | 17.6 | 4.0 | 2.2 | 12.1 | 2.6 |
| 03/12/2014 21:00 | 18.1 | 3.2 | 2.3 | 12.4 | 2.8 |
| 03/12/2014 22:00 | 18.1 | 3.2 | 2.3 | 12.4 | 2.8 |
| 03/12/2014 23:00 | 15.1 | 3.2 | 2.2 | 11.9 | 2.6 |
| **Average/Sum#:** | 279.3 # | 50.0 # | 41.4 # | 223.6 # | 48.5 # |
| **Minimum:** | 6.3 | 0.7 | 1.3 | 6.8 | 1.4 |
| **Maximum:** | 18.1 | 4.3 | 2.3 | 12.4 | 2.8 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/13/2014 00:00 | 10.0 | 1.2 | 1.7 | 9.2 | 2.0 |
| 03/13/2014 01:00 | 12.5 | 1.0 | 1.8 | 9.8 | 2.2 |
| 03/13/2014 02:00 | 7.0 | 1.0 | 1.4 | 7.7 | 1.6 |
| 03/13/2014 03:00 | 8.2 | 1.0 | 1.4 | 7.5 | 1.6 |
| 03/13/2014 04:00 | 8.3 | 1.0 | 1.4 | 7.5 | 1.6 |
| 03/13/2014 05:00 | 13.1 | 3.5 | 1.9 | 10.2 | 2.2 |
| 03/13/2014 06:00 | 13.9 | 4.0 | 2.0 | 10.9 | 2.4 |
| 03/13/2014 07:00 | 17.8 | 3.5 | 2.2 | 12.3 | 2.7 |
| 03/13/2014 08:00 | 15.0 | 4.0 | 2.2 | 11.7 | 2.6 |
| 03/13/2014 09:00 | 14.0 | 3.6 | 2.0 | 11.0 | 2.4 |
| 03/13/2014 10:00 | 13.3 | 2.6 | 1.9 | 10.4 | 2.2 |
| 03/13/2014 11:00 | 11.1 | 2.3 | 1.9 | 10.2 | 2.2 |
| 03/13/2014 12:00 | 13.4 | 3.0 | 1.9 | 10.5 | 2.3 |
| 03/13/2014 13:00 | 13.7 | 3.7 | 2.0 | 10.8 | 2.4 |
| 03/13/2014 14:00 | 13.7 | 3.7 | 2.0 | 10.8 | 2.4 |
| 03/13/2014 15:00 | 13.7 | 3.7 | 2.0 | 10.8 | 2.4 |
| 03/13/2014 16:00 | 13.4 | 3.2 | 1.9 | 10.5 | 2.3 |
| 03/13/2014 17:00 | 12.9 | 2.9 | 1.9 | 10.2 | 2.2 |
| 03/13/2014 18:00 | 13.1 | 2.9 | 1.9 | 10.2 | 2.2 |
| 03/13/2014 19:00 | 13.6 | 3.6 | 1.9 | 10.7 | 2.4 |
| 03/13/2014 20:00 | 13.2 | 3.0 | 1.9 | 10.4 | 2.2 |
| 03/13/2014 21:00 | 12.4 | 2.5 | 1.7 | 9.7 | 2.2 |
| 03/13/2014 22:00 | 4.7 | 0.0 | 0.4 | 4.7 | 0.9 |
| 03/13/2014 23:00 | 5.3 | 0.0 | 0.5 | 5.3 | 1.1 |
| **Average/Sum#:** | 287.3 # | 60.9 # | 41.8 # | 233.0 # | 50.7 # |
| **Minimum:** | 4.7 | 0.0 | 0.4 | 4.7 | 0.9 |
| **Maximum:** | 17.8 | 4.0 | 2.2 | 12.3 | 2.7 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/14/2014 00:00 | 5.3 | 0.0 | 0.5 | 5.3 | 1.1 |
| 03/14/2014 01:00 | 10.7 | 5.8 | 0.3 | 3.6 | 0.7 |
| 03/14/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/14/2014 06:00 | 0.0 | 0.3 | 0.0 | 0.1 | 0.0 |
| 03/14/2014 07:00 | 89.2 | 46.7 | 0.2 | 2.5 | 0.5 |
| 03/14/2014 08:00 | 5.4 | 0.0 | 0.5 | 5.4 | 1.1 |
| 03/14/2014 09:00 | 7.2 | 0.0 | 0.5 | 5.4 | 1.1 |
| 03/14/2014 10:00 | 7.2 | 0.0 | 0.5 | 5.4 | 1.1 |
| 03/14/2014 11:00 | 7.1 | 0.0 | 0.5 | 5.4 | 1.1 |
| 03/14/2014 12:00 | 7.1 | 0.0 | 0.5 | 5.3 | 1.1 |
| 03/14/2014 13:00 | 7.1 | 0.0 | 0.5 | 5.3 | 1.1 |
| 03/14/2014 14:00 | 7.0 | 0.0 | 0.5 | 5.3 | 1.1 |
| 03/14/2014 15:00 | 7.0 | 0.0 | 0.5 | 5.3 | 1.1 |
| 03/14/2014 16:00 | 7.0 | 0.0 | 0.5 | 5.2 | 1.0 |
| 03/14/2014 17:00 | 7.0 | 0.0 | 0.5 | 5.2 | 1.0 |
| 03/14/2014 18:00 | 7.0 | 0.0 | 0.5 | 5.2 | 1.0 |
| 03/14/2014 19:00 | 7.0 | 0.0 | 0.5 | 5.3 | 1.1 |
| 03/14/2014 20:00 | 7.1 | 0.0 | 0.5 | 5.3 | 1.1 |
| 03/14/2014 21:00 | 7.1 | 0.0 | 0.5 | 5.3 | 1.1 |
| 03/14/2014 22:00 | 7.1 | 0.0 | 0.5 | 5.3 | 1.1 |
| 03/14/2014 23:00 | 7.1 | 0.0 | 0.5 | 5.4 | 1.1 |
| **Average/Sum#:** | 216.7 # | 52.8 # | 9.0 # | 96.5 # | 19.6 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 89.2 | 46.7 | 0.5 | 5.4 | 1.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/15/2014 00:00 | 4.2 | 4.8 | 0.1 | 0.5 | 0.1 |
| 03/15/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/15/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 4.2 # | 4.8 # | 0.1 # | 0.5 # | 0.1 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 4.2 | 4.8 | 0.1 | 0.5 | 0.1 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/16/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/16/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/17/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/18/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/19/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/20/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/21/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/22/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/23/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/24/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/25/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/26/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/27/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/28/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/29/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/30/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Daily Summary Report

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
**Generated:** 04/22/2014 15:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | PlantWide NOx, Lb 1 Hour(s) | PlantWide CO, Lb 1 Hour(s) | PlantWide VOC, Lb 1 Hour(s) | PlantWide PM10, Lb 1 Hour(s) | PlantWide SO2, Lb 1 Hour(s) |
|---|---|---|---|---|---|
| 03/31/2014 00:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 01:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 02:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 03:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 04:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 05:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 06:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 07:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 08:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 09:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 10:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 11:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 12:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 13:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 14:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 15:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 16:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 17:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 18:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 19:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 20:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 21:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 22:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 23:00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Average/Sum#:** | 0.0 # | 0.0 # | 0.0 # | 0.0 # | 0.0 # |
| **Minimum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Maximum:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **%SI** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |

# Monthly Summary By Day Report

## AQ-25

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

| Date/Time | PlantWide NOx, Lb 1 Day(s) | PlantWide CO, Lb 1 Day(s) | PlantWide VOC, Lb 1 Day(s) | PlantWide PM10, Lb 1 Day(s) | PlantWide SO2, Lb 1 Day(s) |
|---|---|---|---|---|---|
| 01/01/2014 | 416.3 | 218.8 | 20.6 | 121.1 | 0.0 |
| 01/02/2014 | 334.3 | 82.3 | 47.2 | 261.9 | 0.0 |
| 01/03/2014 | 321.2 | 75.0 | 45.4 | 249.6 | 0.0 |
| 01/04/2014 | 339.1 | 70.6 | 46.5 | 257.4 | 0.0 |
| 01/05/2014 | 368.9 | 65.9 | 48.3 | 266.1 | 0.0 |
| 01/06/2014 | 398.4 | 90.0 | 51.4 | 282.6 | 0.0 |
| 01/07/2014 | 345.3 | 77.6 | 47.0 | 261.4 | 0.0 |
| 01/08/2014 | 217.9 | 38.0 | 33.4 | 184.6 | 0.0 |
| 01/09/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/10/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/11/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/12/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/13/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/14/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/15/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/16/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/17/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/18/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/19/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/20/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/21/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/22/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/23/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/24/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/25/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/26/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/27/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/28/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 01/29/2014 | 619.4 | 450.0 | 16.4 | 100.8 | 0.0 |
| 01/30/2014 | 258.3 | 52.4 | 40.9 | 225.8 | 49.3 |
| 01/31/2014 | 300.3 | 62.6 | 44.1 | 245.1 | 53.7 |
| **Monthly Avg/Sum*:** | 3,919.4 * | 1,283.2 * | 441.2 * | 2,456.4 * | 103.0 * |
| **Daily Min:** | 0.0 | 0.0 | 0.0 | 0.0 | 49.3 |
| **Daily Max:** | 619.4 | 450.0 | 51.4 | 282.6 | 53.7 |
| **Jan 14 - Jan 14** | 3,919.4 | 1,283.2 | 441.2 | 2,456.4 | 103.0 |
| **QTD:** | 3,919.4 * | 1,283.2 * | 441.2 * | 2,456.4 * | 103.0 * |
| **YTD 14:** | 3,919.4 * | 1,283.2 * | 441.2 * | 2,456.4 * | 103.0 * |

# Monthly Summary By Day Report

## AQ-25

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

| Date/Time | PlantWide NOx, Lb 1 Day(s) | PlantWide CO, Lb 1 Day(s) | PlantWide VOC, Lb 1 Day(s) | PlantWide PM10, Lb 1 Day(s) | PlantWide SO2, Lb 1 Day(s) |
|---|---|---|---|---|---|
| 02/01/2014 | 303.9 | 58.5 | 44.4 | 244.4 | 53.6 |
| 02/02/2014 | 392.9 | 96.6 | 52.0 | 286.0 | 62.0 |
| 02/03/2014 | 365.7 | 92.3 | 50.0 | 276.8 | 60.3 |
| 02/04/2014 | 352.2 | 91.9 | 48.7 | 269.5 | 58.4 |
| 02/05/2014 | 348.4 | 84.4 | 48.5 | 264.5 | 57.2 |
| 02/06/2014 | 319.9 | 71.0 | 46.0 | 249.2 | 53.9 |
| 02/07/2014 | 351.9 | 93.7 | 49.5 | 273.9 | 59.2 |
| 02/08/2014 | 295.4 | 82.0 | 46.0 | 250.7 | 54.4 |
| 02/09/2014 | 315.9 | 81.8 | 46.9 | 253.3 | 55.2 |
| 02/10/2014 | 278.9 | 68.3 | 42.9 | 233.7 | 50.5 |
| 02/11/2014 | 303.6 | 74.1 | 45.1 | 245.1 | 53.1 |
| 02/12/2014 | 340.1 | 81.3 | 47.9 | 262.0 | 56.6 |
| 02/13/2014 | 349.1 | 79.5 | 49.8 | 272.9 | 59.9 |
| 02/14/2014 | 355.0 | 72.8 | 48.4 | 267.1 | 58.4 |
| 02/15/2014 | 369.0 | 77.9 | 49.7 | 275.8 | 59.7 |
| 02/16/2014 | 322.5 | 68.7 | 45.5 | 247.5 | 53.9 |
| 02/17/2014 | 307.5 | 66.1 | 44.4 | 242.1 | 52.5 |
| 02/18/2014 | 334.0 | 73.4 | 47.1 | 257.2 | 55.7 |
| 02/19/2014 | 442.2 | 186.2 | 19.5 | 97.8 | 21.5 |
| 02/20/2014 | 331.8 | 53.2 | 45.8 | 247.0 | 53.8 |
| 02/21/2014 | 351.6 | 64.5 | 47.1 | 255.4 | 55.8 |
| 02/22/2014 | 353.4 | 69.6 | 48.0 | 262.3 | 56.8 |
| 02/23/2014 | 364.1 | 63.4 | 48.7 | 267.5 | 58.1 |
| 02/24/2014 | 335.7 | 64.7 | 45.3 | 249.5 | 54.6 |
| 02/25/2014 | 309.6 | 65.2 | 46.6 | 253.4 | 55.8 |
| 02/26/2014 | 339.6 | 72.8 | 50.3 | 274.9 | 59.5 |
| 02/27/2014 | 307.2 | 82.1 | 44.9 | 244.2 | 52.6 |
| 02/28/2014 | 336.1 | 87.6 | 47.7 | 262.0 | 56.9 |
| **Monthly Avg/Sum*:** | 9,477.2 * | 2,223.6 * | 1,296.7 * | 7,085.7 * | 1,539.9 * |
| **Daily Min:** | 278.9 | 53.2 | 19.5 | 97.8 | 21.5 |
| **Daily Max:** | 442.2 | 186.2 | 52.0 | 286.0 | 62.0 |
| **Jan 14 - Feb 14** | 13,396.6 | 3,506.8 | 1,737.9 | 9,542.1 | 1,642.9 |
| **QTD:** | 13,396.6 * | 3,506.8 * | 1,737.9 * | 9,542.1 * | 1,642.9 * |
| **YTD 14:** | 13,396.6 * | 3,506.8 * | 1,737.9 * | 9,542.1 * | 1,642.9 * |

# Monthly Summary By Day Report

## AQ-25

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:24 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

| Date/Time | PlantWide NOx, Lb 1 Day(s) | PlantWide CO, Lb 1 Day(s) | PlantWide VOC, Lb 1 Day(s) | PlantWide PM10, Lb 1 Day(s) | PlantWide SO2, Lb 1 Day(s) |
|---|---|---|---|---|---|
| 03/01/2014 | 319.9 | 77.7 | 46.3 | 251.0 | 54.4 |
| 03/02/2014 | 358.8 | 88.0 | 49.3 | 273.0 | 59.1 |
| 03/03/2014 | 312.8 | 65.4 | 45.1 | 247.7 | 53.8 |
| 03/04/2014 | 248.9 | 49.9 | 39.8 | 215.8 | 47.4 |
| 03/05/2014 | 322.5 | 76.5 | 46.7 | 254.5 | 55.2 |
| 03/06/2014 | 36.1 | 15.5 | 5.1 | 28.0 | 6.2 |
| 03/07/2014 | 555.9 | 318.6 | 34.9 | 183.3 | 40.1 |
| 03/08/2014 | 339.5 | 66.1 | 48.0 | 261.6 | 56.9 |
| 03/09/2014 | 359.4 | 229.9 | 24.2 | 124.9 | 27.3 |
| 03/10/2014 | 275.5 | 63.7 | 41.3 | 222.3 | 48.0 |
| 03/11/2014 | 357.0 | 142.7 | 33.7 | 178.9 | 39.1 |
| 03/12/2014 | 279.3 | 50.0 | 41.4 | 223.6 | 48.5 |
| 03/13/2014 | 287.3 | 60.9 | 41.8 | 233.0 | 50.7 |
| 03/14/2014 | 216.7 | 52.8 | 9.0 | 96.5 | 19.6 |
| 03/15/2014 | 4.2 | 4.8 | 0.1 | 0.5 | 0.1 |
| 03/16/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/17/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/18/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/19/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/20/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/21/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/22/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/23/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/24/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/25/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/26/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/27/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/28/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/29/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/30/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 03/31/2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Monthly Avg/Sum*:** | 4,273.8 * | 1,362.5 * | 506.7 * | 2,794.6 * | 606.4 * |
| **Daily Min:** | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| **Daily Max:** | 555.9 | 318.6 | 49.3 | 273.0 | 59.1 |
| **Jan 14 - Mar 14** | 17,670.4 | 4,869.3 | 2,244.6 | 12,336.7 | 2,249.3 |
| **QTD:** | 17,670.4 * | 4,869.3 * | 2,244.6 * | 12,336.7 * | 2,249.3 * |
| **YTD 14:** | 17,670.4 * | 4,869.3 * | 2,244.6 * | 12,336.7 * | 2,249.3 * |

# ATTACHMENT 11
## CGA/Linearity (AQ-19)

# Cylinder Gas Audit

04/23/2014



Facility: COLUSA GENERATION

Unit/Stack: CT1

Parameter/Scale: CO / High

Test Date: 02/25/2014

Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

| Date | Time | Test Level | Span Value | Reference Value | Measured Value | Ref Value As Pct Span |
|---|---|---|---|---|---|---|
| 02/25/2014 | 11:25 | L | 2000 | 508.800 | 496.100 | 25.4 % |
| 02/25/2014 | 11:31 | M | 2000 | 1139.000 | 1151.100 | 57.0 % |
| 02/25/2014 | 11:40 | L | 2000 | 508.800 | 497.500 | 25.4 % |
| 02/25/2014 | 11:46 | M | 2000 | 1139.000 | 1148.900 | 57.0 % |
| 02/25/2014 | 11:54 | L | 2000 | 508.800 | 496.400 | 25.4 % |
| 02/25/2014 | 12:00 | M | 2000 | 1139.000 | 1151.900 | 57.0 % |

**Summary Statistics:**

| Cal Gas Level | Reference Mean | CEMS Mean | Specification Used | Results |
|---|---|---|---|---|
| L | 508.800 | 496.667 | Std | **2.4** |
| M | 1139.000 | 1150.633 | Std | **1.0** |

# Cylinder Gas Audit

04/23/2014



Facility: COLUSA GENERATION

Unit/Stack: CT1

Parameter/Scale: CO / Low

Test Date: 02/25/2014

Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

| Date | Time | Test Level | Span Value | Reference Value | Measured Value | Ref Value As Pct Span |
|---|---|---|---|---|---|---|
| 02/25/2014 | 10:03 | L | 20 | 4.900 | 5.100 | 24.5 % |
| 02/25/2014 | 10:09 | M | 20 | 11.100 | 10.900 | 55.5 % |
| 02/25/2014 | 10:18 | L | 20 | 4.900 | 5.000 | 24.5 % |
| 02/25/2014 | 10:24 | M | 20 | 11.100 | 11.000 | 55.5 % |
| 02/25/2014 | 10:32 | L | 20 | 4.900 | 5.100 | 24.5 % |
| 02/25/2014 | 10:38 | M | 20 | 11.100 | 10.900 | 55.5 % |

**Summary Statistics:**

| Cal Gas Level | Reference Mean | CEMS Mean | Specification Used | Results |
|---|---|---|---|---|
| L | 4.900 | 5.067 | Std | **3.4** |
| M | 11.100 | 10.933 | Std | **1.5** |

# Cylinder Gas Audit

04/23/2014



Facility: COLUSA GENERATION

Unit/Stack: CT1

Parameter/Scale: NOX / High

Test Date: 02/25/2014

Test Result: **Pass**

Instrument Name: CT1_NOXInlet_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

| Date | Time | Test Level | Span Value | Reference Value | Measured Value | Ref Value As Pct Span |
|---|---|---|---|---|---|---|
| 02/25/2014 | 14:05 | L | 200 | 50.600 | 49.500 | 25.3 % |
| 02/25/2014 | 14:11 | M | 200 | 109.100 | 106.600 | 54.6 % |
| 02/25/2014 | 14:20 | L | 200 | 50.600 | 50.100 | 25.3 % |
| 02/25/2014 | 14:26 | M | 200 | 109.100 | 106.900 | 54.6 % |
| 02/25/2014 | 14:34 | L | 200 | 50.600 | 49.600 | 25.3 % |
| 02/25/2014 | 14:40 | M | 200 | 109.100 | 108.300 | 54.6 % |

**Summary Statistics:**

| Cal Gas Level | Reference Mean | CEMS Mean | Specification Used | Results |
|---|---|---|---|---|
| L | 50.600 | 49.733 | Std | **1.7** |
| M | 109.100 | 107.267 | Std | **1.7** |

# Cylinder Gas Audit

04/23/2014



Facility: COLUSA GENERATION

Unit/Stack: CT1

Parameter/Scale: NOX / Low

Test Date: 02/25/2014

Test Result: **Pass**

Instrument Name: CT1_NOXDualRg_P_Instru

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

| Date | Time | Test Level | Span Value | Reference Value | Measured Value | Ref Value As Pct Span |
|---|---|---|---|---|---|---|
| 02/25/2014 | 10:44 | L | 10 | 2.500 | 2.300 | 25.0 % |
| 02/25/2014 | 10:50 | M | 10 | 5.500 | 5.300 | 55.0 % |
| 02/25/2014 | 10:59 | L | 10 | 2.500 | 2.300 | 25.0 % |
| 02/25/2014 | 11:05 | M | 10 | 5.500 | 5.300 | 55.0 % |
| 02/25/2014 | 11:13 | L | 10 | 2.500 | 2.300 | 25.0 % |
| 02/25/2014 | 11:19 | M | 10 | 5.500 | 5.400 | 55.0 % |

**Summary Statistics:**

| Cal Gas Level | Reference Mean | CEMS Mean | Specification Used | Results |
|---|---|---|---|---|
| L | 2.500 | 2.300 | Std | **8.0** |
| M | 5.500 | 5.333 | Std | **3.0** |

# Cylinder Gas Audit

04/23/2014



Facility: COLUSA GENERATION

Unit/Stack: CT1

Parameter/Scale: O2D / High

Test Date: 02/25/2014

Test Result: **Pass**

Instrument Name: CT1_O2DInlet_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 0.5 Pct

| Date | Time | Test Level | Span Value | Reference Value | Measured Value | Ref Value As Pct Span |
|---|---|---|---|---|---|---|
| 02/25/2014 | 15:01 | L | 25 | 5.500 | 5.500 | 22.0 % |
| 02/25/2014 | 15:07 | M | 25 | 13.000 | 13.000 | 52.0 % |
| 02/25/2014 | 15:15 | L | 25 | 5.500 | 5.500 | 22.0 % |
| 02/25/2014 | 15:21 | M | 25 | 13.000 | 13.000 | 52.0 % |

**Summary Statistics:**

| Cal Gas Level | Reference Mean | CEMS Mean | Specification Used | Results |
|---|---|---|---|---|
| L | 5.500 | 5.500 | Std | **0.0** |
| M | 13.000 | 13.000 | Std | **0.0** |

# Cylinder Gas Audit

04/23/2014



Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: O2D / High

Test Date: 02/25/2014
Test Result: **Pass**

Instrument Name: CT1_O2DInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 0.5 Pct

| Date | Time | Test Level | Span Value | Reference Value | Measured Value | Ref Value As Pct Span |
|---|---|---|---|---|---|---|
| 02/25/2014 | 15:01 | L | 25 | 5.500 | 5.500 | 22.0 % |
| 02/25/2014 | 15:07 | M | 25 | 13.000 | 13.000 | 52.0 % |
| 02/25/2014 | 15:15 | L | 25 | 5.500 | 5.500 | 22.0 % |
| 02/25/2014 | 15:21 | M | 25 | 13.000 | 13.000 | 52.0 % |
| 02/25/2014 | 15:29 | L | 25 | 5.500 | 5.500 | 22.0 % |
| 02/25/2014 | 15:35 | M | 25 | 13.000 | 13.000 | 52.0 % |

**Summary Statistics:**

| Cal Gas Level | Reference Mean | CEMS Mean | Specification Used | Results |
|---|---|---|---|---|
| L | 5.500 | 5.500 | Std | **0.0** |
| M | 13.000 | 13.000 | Std | **0.0** |

# Cylinder Gas Audit

04/23/2014



Facility: COLUSA GENERATION

Unit/Stack: CT2

Parameter/Scale: CO / High

Test Date: 02/26/2014

Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

| Date | Time | Test Level | Span Value | Reference Value | Measured Value | Ref Value As Pct Span |
|---|---|---|---|---|---|---|
| 02/26/2014 | 11:27 | L | 2000 | 509.800 | 504.700 | 25.5 % |
| 02/26/2014 | 11:33 | M | 2000 | 1151.000 | 1171.100 | 57.6 % |
| 02/26/2014 | 11:42 | L | 2000 | 509.800 | 505.000 | 25.5 % |
| 02/26/2014 | 11:48 | M | 2000 | 1151.000 | 1171.100 | 57.6 % |
| 02/26/2014 | 11:56 | L | 2000 | 509.800 | 505.000 | 25.5 % |
| 02/26/2014 | 12:02 | M | 2000 | 1151.000 | 1171.100 | 57.6 % |

**Summary Statistics:**

| Cal Gas Level | Reference Mean | CEMS Mean | Specification Used | Results |
|---|---|---|---|---|
| L | 509.800 | 504.900 | Std | **1.0** |
| M | 1151.000 | 1171.100 | Std | **1.7** |

# Cylinder Gas Audit

04/23/2014



Facility: COLUSA GENERATION

Unit/Stack: CT2

Parameter/Scale: CO / Low

Test Date: 02/26/2014

Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

| Date | Time | Test Level | Span Value | Reference Value | Measured Value | Ref Value As Pct Span |
|---|---|---|---|---|---|---|
| 02/26/2014 | 10:04 | L | 20 | 4.900 | 4.700 | 24.5 % |
| 02/26/2014 | 10:10 | M | 20 | 10.900 | 11.000 | 54.5 % |
| 02/26/2014 | 10:19 | L | 20 | 4.900 | 4.700 | 24.5 % |
| 02/26/2014 | 10:25 | M | 20 | 10.900 | 11.000 | 54.5 % |
| 02/26/2014 | 10:33 | L | 20 | 4.900 | 4.700 | 24.5 % |
| 02/26/2014 | 10:39 | M | 20 | 10.900 | 11.000 | 54.5 % |

**Summary Statistics:**

| Cal Gas Level | Reference Mean | CEMS Mean | Specification Used | Results |
|---|---|---|---|---|
| L | 4.900 | 4.700 | Std | **4.1** |
| M | 10.900 | 11.000 | Std | **0.9** |

# Cylinder Gas Audit

04/23/2014



Facility: COLUSA GENERATION

Unit/Stack: CT2

Parameter/Scale: NOX / High

Test Date: 02/26/2014

Test Result: **Pass**

Instrument Name: CT2_NOXInlet_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

| Date | Time | Test Level | Span Value | Reference Value | Measured Value | Ref Value As Pct Span |
|---|---|---|---|---|---|---|
| 02/26/2014 | 14:09 | L | 200 | 49.700 | 46.300 | 24.9 % |
| 02/26/2014 | 14:15 | M | 200 | 108.500 | 102.700 | 54.3 % |
| 02/26/2014 | 14:24 | L | 200 | 49.700 | 46.300 | 24.9 % |
| 02/26/2014 | 14:30 | M | 200 | 108.500 | 102.400 | 54.3 % |
| 02/26/2014 | 14:38 | L | 200 | 49.700 | 46.400 | 24.9 % |
| 02/26/2014 | 14:44 | M | 200 | 108.500 | 102.400 | 54.3 % |

**Summary Statistics:**

| Cal Gas Level | Reference Mean | CEMS Mean | Specification Used | Results |
|---|---|---|---|---|
| L | 49.700 | 46.333 | Std | **6.8** |
| M | 108.500 | 102.500 | Std | **5.5** |

# Cylinder Gas Audit

04/23/2014



Facility: COLUSA GENERATION

Unit/Stack: CT2

Parameter/Scale: NOX / Low

Test Date: 02/26/2014

Test Result: **Pass**

Instrument Name: CT2_NOXDualRg_P_Instru

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

| Date | Time | Test Level | Span Value | Reference Value | Measured Value | Ref Value As Pct Span |
|---|---|---|---|---|---|---|
| 02/26/2014 | 10:46 | L | 10 | 2.400 | 2.200 | 24.0 % |
| 02/26/2014 | 10:52 | M | 10 | 5.600 | 5.400 | 56.0 % |
| 02/26/2014 | 11:01 | L | 10 | 2.400 | 2.200 | 24.0 % |
| 02/26/2014 | 11:07 | M | 10 | 5.600 | 5.400 | 56.0 % |
| 02/26/2014 | 11:15 | L | 10 | 2.400 | 2.300 | 24.0 % |
| 02/26/2014 | 11:21 | M | 10 | 5.600 | 5.500 | 56.0 % |

**Summary Statistics:**

| Cal Gas Level | Reference Mean | CEMS Mean | Specification Used | Results |
|---|---|---|---|---|
| L | 2.400 | 2.233 | Std | **6.9** |
| M | 5.600 | 5.433 | Std | **3.0** |

# Cylinder Gas Audit

04/23/2014



Facility: COLUSA GENERATION

Unit/Stack: CT2

Parameter/Scale: O2D / High

Test Date: 02/26/2014

Test Result: **Pass**

Instrument Name: CT2_O2DInlet_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 0.5 Pct

| Date | Time | Test Level | Span Value | Reference Value | Measured Value | Ref Value As Pct Span |
|---|---|---|---|---|---|---|
| 02/26/2014 | 14:52 | L | 25 | 5.600 | 5.600 | 22.4 % |
| 02/26/2014 | 14:58 | M | 25 | 13.000 | 13.000 | 52.0 % |
| 02/26/2014 | 15:07 | L | 25 | 5.600 | 5.600 | 22.4 % |
| 02/26/2014 | 15:13 | M | 25 | 13.000 | 13.000 | 52.0 % |
| 02/26/2014 | 15:21 | L | 25 | 5.600 | 5.600 | 22.4 % |
| 02/26/2014 | 15:27 | M | 25 | 13.000 | 13.000 | 52.0 % |

**Summary Statistics:**

| Cal Gas Level | Reference Mean | CEMS Mean | Specification Used | Results |
|---|---|---|---|---|
| L | 5.600 | 5.600 | Std | **0.0** |
| M | 13.000 | 13.000 | Std | **0.0** |

# Linearity Report



| | | | | | |
|---|---|---|---|---|---|
| ORIS Code: | 56298 | Facility Name: | COLUSA GENERATION | | |
| EDR Site ID: | CT1 | Component ID: | A11 | ReasonForTest: | QA |
| | | Component Type: | NOXA | Grace Period: | 0 |
| Instrument Name: | CT1_NOXDualRg_P_Instrume | Test End Date/Time: | 02/25/2014 | Scale: | High |
| Performance Spec: | 5 % | Test No.: | 42 | Highest Error: | 3.3 |
| | | Status (Pass/Fail): | **Passed** | | |

| Date | Time | Cal Gas Level | Span Value | Ref Value | Meas Value | Aborted Test Indicator | Ref Value As Pct Span |
|---|---|---|---|---|---|---|---|
| 02/25/2014 | 1207 | L | 200.0 | 50.6 | 50.9 | | 25.3 % |
| 02/25/2014 | 1213 | M | 200.0 | 109.1 | 108.7 | | 54.6 % |
| 02/25/2014 | 1219 | H | 200.0 | 177.8 | 183.4 | | 88.9 % |
| 02/25/2014 | 1228 | L | 200.0 | 50.6 | 50.7 | | 25.3 % |
| 02/25/2014 | 1234 | M | 200.0 | 109.1 | 108.8 | | 54.6 % |
| 02/25/2014 | 1240 | H | 200.0 | 177.8 | 183.7 | | 88.9 % |
| 02/25/2014 | 1248 | L | 200.0 | 50.6 | 50.5 | | 25.3 % |
| 02/25/2014 | 1254 | M | 200.0 | 109.1 | 109.0 | | 54.6 % |
| 02/25/2014 | 1300 | H | 200.0 | 177.8 | 184.0 | | 88.9 % |

**Summary Statistics:**

| Cal Gas Level | Reference Mean | CEMS Mean | Alt Perf Spec | Results |
|---|---|---|---|---|
| L | 50.600 | 50.700 | No | **0.2** |
| M | 109.100 | 108.833 | No | **0.2** |
| H | 177.800 | 183.700 | No | **3.3** |

# Linearity Report



| | | | | | |
|---|---|---|---|---|---|
| ORIS Code: | 56298 | Facility Name: | COLUSA GENERATION | | |
| EDR Site ID: | CT1 | Component ID: | A12 | ReasonForTest: | QA |
| | | Component Type: | O2D | Grace Period: | 0 |
| Instrument Name: | CT1_O2D_P_Instrument | Test End Date/Time: | 02/25/2014 | Scale: | High |
| Performance Spec: | 5 % | Test No.: | 43 | Highest Error: | 0.0 |
| | | Status (Pass/Fail): | **Passed** | | |

| Date | Time | Cal Gas Level | Span Value | Ref Value | Meas Value | Aborted Test Indicator | Ref Value As Pct Span |
|---|---|---|---|---|---|---|---|
| 02/25/2014 | 1306 | L | 25.0 | 5.5 | 5.5 | | 22.0 % |
| 02/25/2014 | 1312 | M | 25.0 | 13.0 | 13.0 | | 52.0 % |
| 02/25/2014 | 1318 | H | 25.0 | 21.1 | 21.1 | | 84.4 % |
| 02/25/2014 | 1327 | L | 25.0 | 5.5 | 5.5 | | 22.0 % |
| 02/25/2014 | 1333 | M | 25.0 | 13.0 | 13.0 | | 52.0 % |
| 02/25/2014 | 1339 | H | 25.0 | 21.1 | 21.1 | | 84.4 % |
| 02/25/2014 | 1347 | L | 25.0 | 5.5 | 5.5 | | 22.0 % |
| 02/25/2014 | 1353 | M | 25.0 | 13.0 | 13.0 | | 52.0 % |
| 02/25/2014 | 1359 | H | 25.0 | 21.1 | 21.1 | | 84.4 % |

**Summary Statistics:**

| Cal Gas Level | Reference Mean | CEMS Mean | Alt Perf Spec | Results |
|---|---|---|---|---|
| L | 5.500 | 5.500 | No | **0.0** |
| M | 13.000 | 13.000 | No | **0.0** |
| H | 21.100 | 21.100 | No | **0.0** |

# Linearity Report

04/23/2014



| | | | | | |
|---|---|---|---|---|---|
| ORIS Code: | 56298 | Facility Name: | COLUSA GENERATION | | |
| EDR Site ID: | CT2 | Component ID: | A21 | ReasonForTest: | QA |
| | | Component Type: | NOXA | Grace Period: | 0 |
| Instrument Name: | CT2_NOXDualRg_P_Instrume | Test End Date/Time: | 02/26/2014 | Scale: | High |
| Performance Spec: | 5 % | Test No.: | 36 | Highest Error: | 2.1 |
| | | Status (Pass/Fail): | **Passed** | | |

| Date | Time | Cal Gas Level | Span Value | Ref Value | Meas Value | Aborted Test Indicator | Ref Value As Pct Span |
|---|---|---|---|---|---|---|---|
| 02/26/2014 | 1209 | L | 200.0 | 49.7 | 50.1 | | 24.9 % |
| 02/26/2014 | 1215 | M | 200.0 | 108.5 | 110.0 | | 54.3 % |
| 02/26/2014 | 1221 | H | 200.0 | 184.5 | 180.8 | | 92.3 % |
| 02/26/2014 | 1230 | L | 200.0 | 49.7 | 50.3 | | 24.9 % |
| 02/26/2014 | 1236 | M | 200.0 | 108.5 | 110.0 | | 54.3 % |
| 02/26/2014 | 1242 | H | 200.0 | 184.5 | 180.9 | | 92.3 % |
| 02/26/2014 | 1250 | L | 200.0 | 49.7 | 50.3 | | 24.9 % |
| 02/26/2014 | 1256 | M | 200.0 | 108.5 | 109.6 | | 54.3 % |
| 02/26/2014 | 1302 | H | 200.0 | 184.5 | 180.4 | | 92.3 % |

**Summary Statistics:**

| Cal Gas Level | Reference Mean | CEMS Mean | Alt Perf Spec | Results |
|---|---|---|---|---|
| L | 49.700 | 50.233 | No | **1.1** |
| M | 108.500 | 109.867 | No | **1.3** |
| H | 184.500 | 180.700 | No | **2.1** |

# Linearity Report

04/23/2014



| | | | | | |
|---|---|---|---|---|---|
| ORIS Code: | 56298 | Facility Name: | COLUSA GENERATION | | |
| EDR Site ID: | CT2 | Component ID: | A22 | ReasonForTest: | QA |
| | | Component Type: | O2D | Grace Period: | 0 |
| Instrument Name: | CT2_O2D_P_Instrument | Test End Date/Time: | 02/26/2014 | Scale: | High |
| Performance Spec: | 5 % | Test No.: | 38 | Highest Error: | 0.6 |
| | | Status (Pass/Fail): | **Passed** | | |

| Date | Time | Cal Gas Level | Span Value | Ref Value | Meas Value | Aborted Test Indicator | Ref Value As Pct Span |
|---|---|---|---|---|---|---|---|
| 02/26/2014 | 1308 | L | 25.0 | 5.6 | 5.5 | | 22.4 % |
| 02/26/2014 | 1314 | M | 25.0 | 13.0 | 13.0 | | 52.0 % |
| 02/26/2014 | 1320 | H | 25.0 | 21.1 | 21.0 | | 84.4 % |
| 02/26/2014 | 1329 | L | 25.0 | 5.6 | 5.6 | | 22.4 % |
| 02/26/2014 | 1335 | M | 25.0 | 13.0 | 13.0 | | 52.0 % |
| 02/26/2014 | 1341 | H | 25.0 | 21.1 | 21.0 | | 84.4 % |
| 02/26/2014 | 1349 | L | 25.0 | 5.6 | 5.6 | | 22.4 % |
| 02/26/2014 | 1355 | M | 25.0 | 13.0 | 13.0 | | 52.0 % |
| 02/26/2014 | 1401 | H | 25.0 | 21.1 | 21.0 | | 84.4 % |

**Summary Statistics:**

| Cal Gas Level | Reference Mean | CEMS Mean | Alt Perf Spec | Results |
|---|---|---|---|---|
| L | 5.600 | 5.567 | No | **0.6** |
| M | 13.000 | 13.000 | No | **0.0** |
| H | 21.100 | 21.000 | No | **0.5** |

# ATTACHMENT 12
## Startup/Shutdown Emissions (AQ-22)

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/01/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 03:00 | 2.9 | 0 | 0 | 0 | 1 | 0 |
| 01/01/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 16:00 | 28.1 | 0 | 1 | 0 | 0 | 0 |
| 01/01/2014 17:00 | 36.1 | 0 | 1 | 0 | 0 | 0 |
| 01/01/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 67.1 # | 0 # | 2 # | 0 # | 1 # | 9 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 36.1 | 0 | 1 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/02/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/03/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/04/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/05/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/06/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/07/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/08/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 22:00 | 2.2 | 0 | 0 | 0 | 1 | 0 |
| 01/08/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 2.2 # | 0 # | 0 # | 0 # | 1 # | 22 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 2.2 | 0 | 0 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/09/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/10/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/11/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/12/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/13/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/14/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/15/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/16/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/17/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/18/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/19/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/20/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/21/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/22/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/23/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/24/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/25/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/26/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/27/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/28/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/29/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 14:00 | 121.4 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 15:00 | 40.4 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 16:00 | 0.1 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 161.9 # | 3 # | 0 # | 0 # | 0 # | 7 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 121.4 | 1 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/30/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/31/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/01/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/02/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/03/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/04/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/05/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/06/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/07/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/08/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/09/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/10/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/11/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/12/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/13/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/14/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/15/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/16/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/17/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/18/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/19/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 02:00 | 1.9 | 0 | 0 | 0 | 1 | 0 |
| 02/19/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 12:00 | 24.8 | 0 | 1 | 0 | 0 | 0 |
| 02/19/2014 13:00 | 21.0 | 0 | 1 | 0 | 0 | 0 |
| 02/19/2014 14:00 | 49.9 | 0 | 1 | 0 | 0 | 0 |
| 02/19/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 97.6 # | 0 # | 3 # | 0 # | 1 # | 11 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 49.9 | 0 | 1 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/20/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/21/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/22/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/23/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/24/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/25/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/26/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/27/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/28/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/01/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/02/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/03/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/04/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/05/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/06/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/06/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/06/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/06/2014 03:00 | 2.4 | 0 | 0 | 0 | 1 | 0 |
| 03/06/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 2.4 # | 0 # | 0 # | 0 # | 1 # | 3 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 2.4 | 0 | 0 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/07/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 03:00 | 69.0 | 0 | 1 | 0 | 0 | 0 |
| 03/07/2014 04:00 | 40.3 | 0 | 1 | 0 | 0 | 0 |
| 03/07/2014 05:00 | 46.2 | 0 | 1 | 0 | 0 | 0 |
| 03/07/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 155.5 # | 0 # | 3 # | 0 # | 0 # | 18 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 69.0 | 0 | 1 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/08/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/09/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 02:00 | 2.6 | 0 | 0 | 0 | 1 | 0 |
| 03/09/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 11:00 | 44.8 | 0 | 1 | 0 | 0 | 0 |
| 03/09/2014 12:00 | 74.1 | 0 | 1 | 0 | 0 | 0 |
| 03/09/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 121.5 # | 0 # | 2 # | 0 # | 1 # | 13 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 74.1 | 0 | 1 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/10/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 23:00 | 2.7 | 0 | 0 | 0 | 1 | 0 |
| **Average/Sum#:** | 2.7 # | 0 # | 0 # | 0 # | 1 # | 23 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 2.7 | 0 | 0 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/11/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 02:00 | 12.2 | 0 | 0 | 1 | 0 | 0 |
| 03/11/2014 03:00 | 24.4 | 0 | 0 | 1 | 0 | 0 |
| 03/11/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 36.6 # | 0 # | 0 # | 2 # | 0 # | 20 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 24.4 | 0 | 0 | 1 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/12/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/13/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 23 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/14/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/15/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/16/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/17/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/18/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/19/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/20/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/21/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/22/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/23/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/24/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/25/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/26/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/27/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/28/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/29/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/30/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 CO_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/31/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Pound Per Event Report

## CT1 - CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

**Tag Name:** CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,170.80 Hours

Non-Operating Time: 989.20 Hours Report Time: 2,160.00 Hours

## Unit Operation and Excess Events

| Event Period | | | | Reason | Action |
|---|---|---|---|---|---|
| Begin/End | Duration in Minute(s) | Value (Sum) | Limit | Code - Description | Code - Description |
| 01/01/2014 03:20<br>01/01/2014 03:28<br>Shut Down - Gas | 9 | 3.5 | 483.5 | | |
| 01/01/2014 16:23<br>01/01/2014 17:44<br>Warm Start - Gas | 82 | 63.2 | 790.5 | | |
| 01/08/2014 22:08<br>01/08/2014 22:15<br>Shut Down - Gas | 8 | 2.1 | 483.5 | | |
| 01/29/2014 14:10<br>01/29/2014 16:04<br>Cold Start - Gas | 115 | 155.7 | 1,355.6 | | |
| 02/19/2014 02:06<br>02/19/2014 02:10<br>Shut Down - Gas | 5 | 2.6 | 483.5 | | |
| 02/19/2014 12:22<br>02/19/2014 14:50<br>Warm Start - Gas | 149 | 94.7 | 790.5 | | |
| 03/06/2014 03:07<br>03/06/2014 03:13<br>Shut Down - Gas | 7 | 2.0 | 483.5 | | |
| 03/07/2014 03:23<br>03/07/2014 05:46<br>Warm Start - Gas | 144 | 157.2 | 790.5 | | |
| 03/09/2014 02:07<br>03/09/2014 02:13<br>Shut Down - Gas | 7 | 2.3 | 483.5 | | |
| 03/09/2014 11:12<br>03/09/2014 12:52<br>Warm Start - Gas | 101 | 119.3 | 790.5 | | |
| 03/10/2014 23:06<br>03/10/2014 23:13<br>Shut Down - Gas | 8 | 2.6 | 483.5 | | |
| 03/11/2014 02:24<br>03/11/2014 03:43<br>Hot Start - Gas | 80 | 42.0 | 679.6 | | |

**No excess emissions were found in the reporting period.**

# Pound Per Event Report

## CT1 - CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

**Tag Name:** CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,170.80 Hours

Non-Operating Time: 989.20 Hours Report Time: 2,160.00 Hours

## Event Invalid Information

No invalid events were found in the reporting period.

# Pound Per Event Report

## CT1 - CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

**Tag Name:** CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,170.80 Hours

Non-Operating Time: 989.20 Hours Report Time: 2,160.00 Hours

## Periodic Excess and Invalid Summary

### Emission Data Summary

| | |
|---|---|
| 1. Duration of excess emission in event reporting period due to: | |
| a. Startup/shutdown | 0 |
| b. Control equipment problems | 0 |
| c. Process problems | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Total Duration of Excess Emission in Minute(s) | 0 |
| 3. Time of Excess Emission as a percentage of operating time | 0.00 |
| 4. Time in compliance as percentage of operating time | 100.00 |

### CMS Performance Summary

| | |
|---|---|
| 1. CMS downtime in event reporting period due to: | |
| a. Monitor equipment malfunctions | 0 |
| b. Non-Monitor equipment malfunctions | 0 |
| c. Quality assurance calibration | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Total CMS Downtime in Minute(s) | 0 |
| 3. Total Downtime as a percentage of operating time | 0.00 |
| 4. Total Availability as a percentage of operating time | 100.00 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/01/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 03:00 | 511.4 | 0 | 0 | 0 | 1 | 0 |
| 01/01/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 16:00 | 2,988.2 | 0 | 1 | 0 | 0 | 0 |
| 01/01/2014 17:00 | 6,343.3 | 0 | 1 | 0 | 0 | 0 |
| 01/01/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 9,842.9 # | 0 # | 2 # | 0 # | 1 # | 9 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 6,343.3 | 0 | 1 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/02/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/03/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/04/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/05/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/06/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/07/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/08/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 22:00 | 379.1 | 0 | 0 | 0 | 1 | 0 |
| 01/08/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 379.1 # | 0 # | 0 # | 0 # | 1 # | 22 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 379.1 | 0 | 0 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/09/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/10/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/11/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/12/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/13/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/14/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/15/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/16/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/17/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/18/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/19/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/20/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/21/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/22/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/23/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/24/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/25/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/26/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/27/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/28/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/29/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 14:00 | 4,281.9 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 15:00 | 7,388.8 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 16:00 | 1,114.8 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 12,785.5 # | 3 # | 0 # | 0 # | 0 # | 7 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 7,388.8 | 1 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/30/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/31/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/01/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/02/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/03/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/04/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/05/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/06/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/07/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/08/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/09/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/10/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/11/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/12/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/13/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/14/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/15/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/16/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/17/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/18/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/19/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 02:00 | 350.3 | 0 | 0 | 0 | 1 | 0 |
| 02/19/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 12:00 | 3,122.6 | 0 | 1 | 0 | 0 | 0 |
| 02/19/2014 13:00 | 5,549.5 | 0 | 1 | 0 | 0 | 0 |
| 02/19/2014 14:00 | 6,763.5 | 0 | 1 | 0 | 0 | 0 |
| 02/19/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 15,785.9 # | 0 # | 3 # | 0 # | 1 # | 11 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 6,763.5 | 0 | 1 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/20/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/21/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/22/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/23/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/24/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/25/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/26/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/27/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/28/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/01/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/02/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/03/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/04/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/05/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/06/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/06/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/06/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/06/2014 03:00 | 201.6 | 0 | 0 | 0 | 1 | 0 |
| 03/06/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 201.6 # | 0 # | 0 # | 0 # | 1 # | 3 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 201.6 | 0 | 0 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/07/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 03:00 | 3,009.9 | 0 | 1 | 0 | 0 | 0 |
| 03/07/2014 04:00 | 6,068.8 | 0 | 1 | 0 | 0 | 0 |
| 03/07/2014 05:00 | 6,521.9 | 0 | 1 | 0 | 0 | 0 |
| 03/07/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 15,600.6 # | 0 # | 3 # | 0 # | 0 # | 18 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 6,521.9 | 0 | 1 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/08/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/09/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 02:00 | 242.4 | 0 | 0 | 0 | 1 | 0 |
| 03/09/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 11:00 | 4,507.5 | 0 | 1 | 0 | 0 | 0 |
| 03/09/2014 12:00 | 7,167.9 | 0 | 1 | 0 | 0 | 0 |
| 03/09/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 11,917.8 # | 0 # | 2 # | 0 # | 1 # | 13 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 7,167.9 | 0 | 1 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/10/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 23:00 | 296.3 | 0 | 0 | 0 | 1 | 0 |
| **Average/Sum#:** | 296.3 # | 0 # | 0 # | 0 # | 1 # | 23 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 296.3 | 0 | 0 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/11/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 02:00 | 2,831.2 | 0 | 0 | 1 | 0 | 0 |
| 03/11/2014 03:00 | 5,511.8 | 0 | 0 | 1 | 0 | 0 |
| 03/11/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 8,343.0 # | 0 # | 0 # | 2 # | 0 # | 20 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 5,511.8 | 0 | 0 | 1 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/12/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/13/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 23 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/14/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/15/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/16/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/17/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/18/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/19/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/20/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/21/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/22/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/23/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/24/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/25/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/26/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/27/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/28/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/29/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/30/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event GasFlow Total 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/31/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# 100scf Per Event Report

## CT1 - GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

**Tag Name:** CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,170.80 Hours

Non-Operating Time: 989.20 Hours Report Time: 2,160.00 Hours

## Unit Operation and Excess Events

| Event Period | | | Reason | Action |
|---|---|---|---|---|
| Begin/End | Duration in Minute(s) | Lb/Event | Code - Description | Code - Description |
| 01/01/2014 03:20<br>01/01/2014 03:28<br>Shut Down - Gas | 9 | 8.5 | | |
| 01/01/2014 16:23<br>01/01/2014 17:44<br>Warm Start - Gas | 82 | 155.5 | | |
| 01/08/2014 22:08<br>01/08/2014 22:15<br>Shut Down - Gas | 8 | 6.3 | | |
| 01/29/2014 14:10<br>01/29/2014 16:04<br>Cold Start - Gas | 115 | 213.1 | | |
| 02/19/2014 02:06<br>02/19/2014 02:10<br>Shut Down - Gas | 5 | 5.8 | | |
| 02/19/2014 12:22<br>02/19/2014 14:50<br>Warm Start - Gas | 149 | 257.3 | | |
| 03/06/2014 03:07<br>03/06/2014 03:13<br>Shut Down - Gas | 7 | 3.4 | | |
| 03/07/2014 03:23<br>03/07/2014 05:46<br>Warm Start - Gas | 144 | 260.0 | | |
| 03/09/2014 02:07<br>03/09/2014 02:13<br>Shut Down - Gas | 7 | 4.0 | | |
| 03/09/2014 11:12<br>03/09/2014 12:52<br>Warm Start - Gas | 101 | 194.6 | | |
| 03/10/2014 23:06<br>03/10/2014 23:13<br>Shut Down - Gas | 8 | 4.9 | | |
| 03/11/2014 02:24<br>03/11/2014 03:43<br>Hot Start - Gas | 80 | 139.1 | | |

**No excess emissions were found in the reporting period.**

# 100scf Per Event Report

## CT1 - GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

**Tag Name:** CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,170.80 Hours

Non-Operating Time: 989.20 Hours Report Time: 2,160.00 Hours

## Event Invalid Information

No invalid events were found in the reporting period.

# 100scf Per Event Report

## CT1 - GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

**Tag Name:** CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,170.80 Hours

Non-Operating Time: 989.20 Hours Report Time: 2,160.00 Hours

## Periodic Excess and Invalid Summary

### Emission Data Summary

| | |
|---|---|
| 1. Duration of excess emission in event reporting period due to: | |
| a. Startup/shutdown | 0 |
| b. Control equipment problems | 0 |
| c. Process problems | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Total Duration of Excess Emission in Minute(s) | 0 |
| 3. Time of Excess Emission as a percentage of operating time | 0.00 |
| 4. Time in compliance as percentage of operating time | 100.00 |

### CMS Performance Summary

| | |
|---|---|
| 1. CMS downtime in event reporting period due to: | |
| a. Monitor equipment malfunctions | 0 |
| b. Non-Monitor equipment malfunctions | 0 |
| c. Quality assurance calibration | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Total CMS Downtime in Minute(s) | 0 |
| 3. Total Downtime as a percentage of operating time | 0.00 |
| 4. Total Availability as a percentage of operating time | 100.00 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/01/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 03:00 | 1.7 | 0 | 0 | 0 | 1 | 0 |
| 01/01/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 16:00 | 56.9 | 0 | 1 | 0 | 0 | 0 |
| 01/01/2014 17:00 | 54.6 | 0 | 1 | 0 | 0 | 0 |
| 01/01/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 113.2 # | 0 # | 2 # | 0 # | 1 # | 9 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 56.9 | 0 | 1 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/02/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/03/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/04/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/05/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/06/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/07/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/08/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 22:00 | 1.6 | 0 | 0 | 0 | 1 | 0 |
| 01/08/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 1.6 # | 0 # | 0 # | 0 # | 1 # | 22 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 1.6 | 0 | 0 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/09/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/10/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/11/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/12/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/13/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/14/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/15/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/16/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/17/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/18/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/19/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/20/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/21/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/22/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/23/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/24/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/25/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/26/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/27/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/28/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/29/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 14:00 | 94.5 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 15:00 | 83.7 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 16:00 | 0.2 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 178.4 # | 3 # | 0 # | 0 # | 0 # | 7 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 94.5 | 1 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/30/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/31/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/01/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/02/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/03/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/04/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/05/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/06/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/07/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/08/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/09/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/10/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/11/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/12/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/13/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/14/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/15/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/16/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/17/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/18/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/19/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 02:00 | 1.1 | 0 | 0 | 0 | 1 | 0 |
| 02/19/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 12:00 | 69.7 | 0 | 1 | 0 | 0 | 0 |
| 02/19/2014 13:00 | 40.4 | 0 | 1 | 0 | 0 | 0 |
| 02/19/2014 14:00 | 47.9 | 0 | 1 | 0 | 0 | 0 |
| 02/19/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 159.1 # | 0 # | 3 # | 0 # | 1 # | 11 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 69.7 | 0 | 1 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/20/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/21/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/22/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/23/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/24/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/25/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/26/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/27/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/28/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/01/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/02/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/03/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/04/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/05/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/06/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/06/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/06/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/06/2014 03:00 | 1.0 | 0 | 0 | 0 | 1 | 0 |
| 03/06/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 1.0 # | 0 # | 0 # | 0 # | 1 # | 3 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 1.0 | 0 | 0 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/07/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 03:00 | 62.9 | 0 | 1 | 0 | 0 | 0 |
| 03/07/2014 04:00 | 57.8 | 0 | 1 | 0 | 0 | 0 |
| 03/07/2014 05:00 | 39.9 | 0 | 1 | 0 | 0 | 0 |
| 03/07/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 160.6 # | 0 # | 3 # | 0 # | 0 # | 18 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 62.9 | 0 | 1 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/08/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/09/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 02:00 | 1.0 | 0 | 0 | 0 | 1 | 0 |
| 03/09/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 11:00 | 49.0 | 0 | 1 | 0 | 0 | 0 |
| 03/09/2014 12:00 | 34.5 | 0 | 1 | 0 | 0 | 0 |
| 03/09/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 84.5 # | 0 # | 2 # | 0 # | 1 # | 13 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 49.0 | 0 | 1 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/10/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 23:00 | 1.5 | 0 | 0 | 0 | 1 | 0 |
| **Average/Sum#:** | 1.5 # | 0 # | 0 # | 0 # | 1 # | 23 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 1.5 | 0 | 0 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/11/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 02:00 | 3.2 | 0 | 0 | 1 | 0 | 0 |
| 03/11/2014 03:00 | 30.4 | 0 | 0 | 1 | 0 | 0 |
| 03/11/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 33.6 # | 0 # | 0 # | 2 # | 0 # | 20 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 30.4 | 0 | 0 | 1 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/12/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/13/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 23 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/14/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/15/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/16/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/17/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/18/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/19/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/20/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/21/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/22/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/23/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/24/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/25/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/26/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/27/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/28/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/29/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/30/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT1 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT1 NOx_Event, Lb 1 Hour(s) | Unit CT1 Startup, Cold, TF 1 Hour(s) | Unit CT1 Startup, Warm, TF 1 Hour(s) | Unit CT1 Startup, Hot, TF 1 Hour(s) | Unit CT1 Shutdown, TF 1 Hour(s) | Unit CT1 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/31/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Pound Per Event Report

## CT1 - NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

**Tag Name:** CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,170.80 Hours

Non-Operating Time: 989.20 Hours Report Time: 2,160.00 Hours

## Unit Operation and Excess Events

| Event Period | | | | Reason | Action |
|---|---|---|---|---|---|
| Begin/End | Duration in Minute(s) | Value (Sum) | Limit | Code - Description | Code - Description |
| 01/01/2014 03:20<br>01/01/2014 03:28<br>Shut Down - Gas | 9 | 2.36 | 115.00 | | |
| 01/01/2014 16:23<br>01/01/2014 17:44<br>Warm Start - Gas | 82 | 120.13 | 456.20 | | |
| 01/08/2014 22:08<br>01/08/2014 22:15<br>Shut Down - Gas | 8 | 1.82 | 115.00 | | |
| 01/29/2014 14:10<br>01/29/2014 16:04<br>Cold Start - Gas | 115 | 178.90 | 779.10 | | |
| 02/19/2014 02:06<br>02/19/2014 02:10<br>Shut Down - Gas | 5 | 0.92 | 115.00 | | |
| 02/19/2014 12:22<br>02/19/2014 14:50<br>Warm Start - Gas | 149 | 161.91 | 456.20 | | |
| 03/06/2014 03:07<br>03/06/2014 03:13<br>Shut Down - Gas | 7 | 0.53 | 115.00 | | |
| 03/07/2014 03:23<br>03/07/2014 05:46<br>Warm Start - Gas | 144 | 167.81 | 456.20 | | |
| 03/09/2014 02:07<br>03/09/2014 02:13<br>Shut Down - Gas | 7 | 0.61 | 115.00 | | |
| 03/09/2014 11:12<br>03/09/2014 12:52<br>Warm Start - Gas | 101 | 87.09 | 456.20 | | |
| 03/10/2014 23:06<br>03/10/2014 23:13<br>Shut Down - Gas | 8 | 1.12 | 115.00 | | |
| 03/11/2014 02:24<br>03/11/2014 03:43<br>Hot Start - Gas | 80 | 43.49 | 259.90 | | |

**No excess emissions were found in the reporting period.**

# Pound Per Event Report

## CT1 - NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

**Tag Name:** CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,170.80 Hours

Non-Operating Time: 989.20 Hours Report Time: 2,160.00 Hours

## Event Invalid Information

No invalid events were found in the reporting period.

# Pound Per Event Report

## CT1 - NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:11 **Location:** Maxwell, CA

**Tag Name:** CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,170.80 Hours

Non-Operating Time: 989.20 Hours Report Time: 2,160.00 Hours

## Periodic Excess and Invalid Summary

### Emission Data Summary

| | |
|---|---|
| 1. Duration of excess emission in event reporting period due to: | |
| a. Startup/shutdown | 0 |
| b. Control equipment problems | 0 |
| c. Process problems | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Total Duration of Excess Emission in Minute(s) | 0 |
| 3. Time of Excess Emission as a percentage of operating time | 0.00 |
| 4. Time in compliance as percentage of operating time | 100.00 |

### CMS Performance Summary

| | |
|---|---|
| 1. CMS downtime in event reporting period due to: | |
| a. Monitor equipment malfunctions | 0 |
| b. Non-Monitor equipment malfunctions | 0 |
| c. Quality assurance calibration | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Total CMS Downtime in Minute(s) | 0 |
| 3. Total Downtime as a percentage of operating time | 0.00 |
| 4. Total Availability as a percentage of operating time | 100.00 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/01/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 03:00 | 2.5 | 0 | 0 | 0 | 1 | 0 |
| 01/01/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 13:00 | 26.3 | 0 | 1 | 0 | 0 | 0 |
| 01/01/2014 14:00 | 60.1 | 0 | 1 | 0 | 0 | 0 |
| 01/01/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 88.9 # | 0 # | 2 # | 0 # | 1 # | 12 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 60.1 | 0 | 1 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/02/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/03/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/04/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/05/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/06/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/07/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/08/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 22:00 | 2.2 | 0 | 0 | 0 | 1 | 0 |
| 01/08/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 2.2 # | 0 # | 0 # | 0 # | 1 # | 22 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 2.2 | 0 | 0 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/09/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/10/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/11/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/12/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/13/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/14/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/15/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/16/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/17/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/18/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/19/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/20/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/21/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/22/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/23/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/24/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/25/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/26/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/27/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/28/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/29/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 08:00 | 117.1 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 09:00 | 33.9 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 10:00 | 49.9 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 11:00 | 43.1 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 12:00 | 19.1 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 263.1 # | 5 # | 0 # | 0 # | 0 # | 11 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 117.1 | 1 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/30/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/31/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/01/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/02/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/03/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/04/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/05/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/06/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/07/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/08/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/09/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/10/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/11/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/12/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/13/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/14/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/15/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/16/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/17/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/18/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/19/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 02:00 | 2.5 | 0 | 0 | 0 | 1 | 0 |
| 02/19/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 17:00 | 27.7 | 0 | 1 | 0 | 0 | 0 |
| 02/19/2014 18:00 | 8.9 | 0 | 1 | 0 | 0 | 0 |
| 02/19/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 39.1 # | 0 # | 2 # | 0 # | 1 # | 7 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 27.7 | 0 | 1 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/20/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/21/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/22/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/23/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/24/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/25/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/26/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/27/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/28/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/01/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/02/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/03/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/04/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/05/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/06/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/06/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/06/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/06/2014 03:00 | 2.2 | 0 | 0 | 0 | 1 | 0 |
| 03/06/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 2.2 # | 0 # | 0 # | 0 # | 1 # | 3 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 2.2 | 0 | 0 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/07/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 07:00 | 75.5 | 0 | 1 | 0 | 0 | 0 |
| 03/07/2014 08:00 | 18.6 | 0 | 1 | 0 | 0 | 0 |
| 03/07/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 94.1 # | 0 # | 2 # | 0 # | 0 # | 15 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 75.5 | 0 | 1 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/08/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/09/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 02:00 | 2.8 | 0 | 0 | 0 | 1 | 0 |
| 03/09/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 15:00 | 38.9 | 0 | 1 | 0 | 0 | 0 |
| 03/09/2014 16:00 | 7.6 | 0 | 1 | 0 | 0 | 0 |
| 03/09/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 49.3 # | 0 # | 2 # | 0 # | 1 # | 9 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 38.9 | 0 | 1 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/10/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 23:00 | 2.1 | 0 | 0 | 0 | 1 | 0 |
| **Average/Sum#:** | 2.1 # | 0 # | 0 # | 0 # | 1 # | 23 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 2.1 | 0 | 0 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/11/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 05:00 | 6.7 | 0 | 0 | 1 | 0 | 0 |
| 03/11/2014 06:00 | 44.1 | 0 | 0 | 1 | 0 | 0 |
| 03/11/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 50.8 # | 0 # | 0 # | 2 # | 0 # | 17 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 44.1 | 0 | 0 | 1 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/12/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/13/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/14/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 01:00 | 1.4 | 0 | 0 | 0 | 1 | 0 |
| 03/14/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 06:00 | 0.3 | 0 | 0 | 1 | 0 | 0 |
| 03/14/2014 07:00 | 43.0 | 0 | 0 | 1 | 0 | 0 |
| 03/14/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 44.7 # | 0 # | 0 # | 2 # | 1 # | 17 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 43.0 | 0 | 0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/15/2014 00:00 | 3.2 | 0 | 0 | 0 | 1 | 0 |
| 03/15/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 3.2 # | 0 # | 0 # | 0 # | 1 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 3.2 | 0 | 0 | 0 | 1 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/16/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/17/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/18/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/19/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/20/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/21/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/22/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/23/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/24/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/25/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/26/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/27/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/28/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/29/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/30/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 CO_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/31/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Pound Per Event Report

## CT2 - CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

**Tag Name:** CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,170.80 Hours

Non-Operating Time: 989.20 Hours Report Time: 2,160.00 Hours

## Unit Operation and Excess Events

| Event Period | | | | Reason | Action |
|---|---|---|---|---|---|
| Begin/End | Duration in Minute(s) | Value (Sum) | Limit | Code - Description | Code - Description |
| 01/01/2014 03:24<br>01/01/2014 03:32<br>Shut Down - Gas | 9 | 3.6 | 483.5 | | |
| 01/01/2014 13:20<br>01/01/2014 14:49<br>Warm Start - Gas | 90 | 88.9 | 790.5 | | |
| 01/08/2014 22:09<br>01/08/2014 22:16<br>Shut Down - Gas | 8 | 2.1 | 483.5 | | |
| 01/29/2014 08:22<br>01/29/2014 12:30<br>Cold Start - Gas | 249 | 281.6 | 1,355.6 | | |
| 02/19/2014 02:07<br>02/19/2014 02:13<br>Shut Down - Gas | 7 | 2.2 | 483.5 | | |
| 02/19/2014 17:14<br>02/19/2014 18:21<br>Warm Start - Gas | 68 | 42.5 | 790.5 | | |
| 03/06/2014 03:08<br>03/06/2014 03:14<br>Shut Down - Gas | 7 | 2.0 | 483.5 | | |
| 03/07/2014 07:22<br>03/07/2014 08:37<br>Warm Start - Gas | 76 | 98.6 | 790.5 | | |
| 03/09/2014 02:07<br>03/09/2014 02:13<br>Shut Down - Gas | 7 | 2.7 | 483.5 | | |
| 03/09/2014 15:13<br>03/09/2014 16:20<br>Warm Start - Gas | 68 | 53.2 | 790.5 | | |
| 03/10/2014 23:07<br>03/10/2014 23:13<br>Shut Down - Gas | 7 | 1.7 | 483.5 | | |
| 03/11/2014 05:41<br>03/11/2014 06:52<br>Hot Start - Gas | 72 | 49.1 | 679.6 | | |
| 03/14/2014 01:38<br>03/14/2014 01:49<br>Shut Down - Gas | 12 | 1.5 | 483.5 | | |

# Pound Per Event Report

## CT2 - CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

**Tag Name:** CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,170.80 Hours

Non-Operating Time: 989.20 Hours Report Time: 2,160.00 Hours

| Event Period | | | | Reason | Action |
|---|---|---|---|---|---|
| Begin/End | Duration in Minute(s) | Value (Sum) | Limit | Code - Description | Code - Description |
| 03/14/2014 06:53<br>03/14/2014 07:54<br>Hot Start - Gas | 62 | 41.5 | 679.6 | | |
| 03/15/2014 00:05<br>03/15/2014 00:14<br>Shut Down - Gas | 10 | 2.7 | 483.5 | | |

No excess emissions were found in the reporting period.

# Pound Per Event Report

## CT2 - CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

**Tag Name:** CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,170.80 Hours

Non-Operating Time: 989.20 Hours Report Time: 2,160.00 Hours

## Event Invalid Information

No invalid events were found in the reporting period.

# Pound Per Event Report

## CT2 - CO Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

**Tag Name:** CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,170.80 Hours

Non-Operating Time: 989.20 Hours Report Time: 2,160.00 Hours

## Periodic Excess and Invalid Summary

### Emission Data Summary

| | |
|---|---|
| 1. Duration of excess emission in event reporting period due to: | |
| a. Startup/shutdown | 0 |
| b. Control equipment problems | 0 |
| c. Process problems | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Total Duration of Excess Emission in Minute(s) | 0 |
| 3. Time of Excess Emission as a percentage of operating time | 0.00 |
| 4. Time in compliance as percentage of operating time | 100.00 |

### CMS Performance Summary

| | |
|---|---|
| 1. CMS downtime in event reporting period due to: | |
| a. Monitor equipment malfunctions | 0 |
| b. Non-Monitor equipment malfunctions | 0 |
| c. Quality assurance calibration | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Total CMS Downtime in Minute(s) | 0 |
| 3. Total Downtime as a percentage of operating time | 0.00 |
| 4. Total Availability as a percentage of operating time | 100.00 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/01/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 03:00 | 540.5 | 0 | 0 | 0 | 1 | 0 |
| 01/01/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 13:00 | 2,997.1 | 0 | 1 | 0 | 0 | 0 |
| 01/01/2014 14:00 | 6,829.2 | 0 | 1 | 0 | 0 | 0 |
| 01/01/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 10,366.8 # | 0 # | 2 # | 0 # | 1 # | 12 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 6,829.2 | 0 | 1 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/02/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/03/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/04/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/05/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/06/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/07/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/08/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 22:00 | 352.4 | 0 | 0 | 0 | 1 | 0 |
| 01/08/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 352.4 # | 0 # | 0 # | 0 # | 1 # | 22 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 352.4 | 0 | 0 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/09/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/10/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/11/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/12/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/13/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/14/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/15/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/16/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/17/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/18/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/19/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/20/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/21/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/22/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/23/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/24/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/25/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/26/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/27/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/28/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/29/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 08:00 | 3,099.0 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 09:00 | 5,920.1 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 10:00 | 6,116.9 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 11:00 | 6,222.0 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 12:00 | 4,623.9 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 25,981.9 # | 5 # | 0 # | 0 # | 0 # | 11 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 6,222.0 | 1 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/30/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/31/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/01/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/02/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/03/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/04/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/05/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/06/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/07/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/08/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/09/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/10/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/11/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/12/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/13/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/14/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/15/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/16/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/17/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/18/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/19/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 02:00 | 209.3 | 0 | 0 | 0 | 1 | 0 |
| 02/19/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 17:00 | 3,969.2 | 0 | 1 | 0 | 0 | 0 |
| 02/19/2014 18:00 | 3,720.9 | 0 | 1 | 0 | 0 | 0 |
| 02/19/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 7,899.4 # | 0 # | 2 # | 0 # | 1 # | 7 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 3,969.2 | 0 | 1 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/20/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/21/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/22/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/23/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/24/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/25/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/26/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/27/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/28/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/01/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/02/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/03/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/04/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/05/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/06/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/06/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/06/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/06/2014 03:00 | 205.6 | 0 | 0 | 0 | 1 | 0 |
| 03/06/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 205.6 # | 0 # | 0 # | 0 # | 1 # | 3 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 205.6 | 0 | 0 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/07/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 07:00 | 3,048.9 | 0 | 1 | 0 | 0 | 0 |
| 03/07/2014 08:00 | 5,467.1 | 0 | 1 | 0 | 0 | 0 |
| 03/07/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 8,516.0 # | 0 # | 2 # | 0 # | 0 # | 15 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 5,467.1 | 0 | 1 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/08/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/09/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 02:00 | 275.9 | 0 | 0 | 0 | 1 | 0 |
| 03/09/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 15:00 | 4,109.8 | 0 | 1 | 0 | 0 | 0 |
| 03/09/2014 16:00 | 3,650.2 | 0 | 1 | 0 | 0 | 0 |
| 03/09/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 8,035.9 # | 0 # | 2 # | 0 # | 1 # | 9 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 4,109.8 | 0 | 1 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/10/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 23:00 | 216.6 | 0 | 0 | 0 | 1 | 0 |
| **Average/Sum#:** | 216.6 # | 0 # | 0 # | 0 # | 1 # | 23 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 216.6 | 0 | 0 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/11/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 05:00 | 1,281.6 | 0 | 0 | 1 | 0 | 0 |
| 03/11/2014 06:00 | 7,083.7 | 0 | 0 | 1 | 0 | 0 |
| 03/11/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 8,365.3 # | 0 # | 0 # | 2 # | 0 # | 17 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 7,083.7 | 0 | 0 | 1 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/12/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/13/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/14/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 01:00 | 1,001.4 | 0 | 0 | 0 | 1 | 0 |
| 03/14/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 06:00 | 170.3 | 0 | 0 | 1 | 0 | 0 |
| 03/14/2014 07:00 | 6,755.5 | 0 | 0 | 1 | 0 | 0 |
| 03/14/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 7,927.2 # | 0 # | 0 # | 2 # | 1 # | 17 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 6,755.5 | 0 | 0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/15/2014 00:00 | 602.9 | 0 | 0 | 0 | 1 | 0 |
| 03/15/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 602.9 # | 0 # | 0 # | 0 # | 1 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 602.9 | 0 | 0 | 0 | 1 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/16/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/17/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/18/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/19/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/20/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/21/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/22/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/23/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/24/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/25/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/26/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/27/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/28/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/29/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/30/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/31/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# 100scf Per Event Report

## CT2 - GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

**Tag Name:** CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,184.78 Hours

Non-Operating Time: 975.22 Hours Report Time: 2,160.00 Hours

## Unit Operation and Excess Events

| Event Period | | | Reason | Action |
|---|---|---|---|---|
| Begin/End | Duration in Minute(s) | Lb/Event | Code - Description | Code - Description |
| 01/01/2014 03:24<br>01/01/2014 03:32<br>Shut Down - Gas | 9 | 9.0 | | |
| 01/01/2014 13:20<br>01/01/2014 14:49<br>Warm Start - Gas | 90 | 163.8 | | |
| 01/08/2014 22:09<br>01/08/2014 22:16<br>Shut Down - Gas | 8 | 5.9 | | |
| 01/29/2014 08:22<br>01/29/2014 12:30<br>Cold Start - Gas | 249 | 433.0 | | |
| 02/19/2014 02:07<br>02/19/2014 02:13<br>Shut Down - Gas | 7 | 3.5 | | |
| 02/19/2014 17:14<br>02/19/2014 18:21<br>Warm Start - Gas | 68 | 128.2 | | |
| 03/06/2014 03:08<br>03/06/2014 03:14<br>Shut Down - Gas | 7 | 3.4 | | |
| 03/07/2014 07:22<br>03/07/2014 08:37<br>Warm Start - Gas | 76 | 141.9 | | |
| 03/09/2014 02:07<br>03/09/2014 02:13<br>Shut Down - Gas | 7 | 4.6 | | |
| 03/09/2014 15:13<br>03/09/2014 16:20<br>Warm Start - Gas | 68 | 129.3 | | |
| 03/10/2014 23:07<br>03/10/2014 23:13<br>Shut Down - Gas | 7 | 3.6 | | |
| 03/11/2014 05:41<br>03/11/2014 06:52<br>Hot Start - Gas | 72 | 139.4 | | |
| 03/14/2014 01:38<br>03/14/2014 01:49<br>Shut Down - Gas | 12 | 16.7 | | |

# 100scf Per Event Report

## CT2 - GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

**Tag Name:** CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,184.78 Hours

Non-Operating Time: 975.22 Hours Report Time: 2,160.00 Hours

| Event Period | | | Reason | Action |
|---|---|---|---|---|
| Begin/End | Duration in Minute(s) | Lb/Event | Code - Description | Code - Description |
| 03/14/2014 06:53<br>03/14/2014 07:54<br>Hot Start - Gas | 62 | 115.4 | | |
| 03/15/2014 00:05<br>03/15/2014 00:14<br>Shut Down - Gas | 10 | 10.0 | | |

No excess emissions were found in the reporting period.

# 100scf Per Event Report

## CT2 - GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

**Tag Name:** CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,184.78 Hours

Non-Operating Time: 975.22 Hours Report Time: 2,160.00 Hours

## Event Invalid Information

No invalid events were found in the reporting period.

# 100scf Per Event Report

## CT2 - GasFlowTotal 100scf

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

**Tag Name:** CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,184.78 Hours

Non-Operating Time: 975.22 Hours Report Time: 2,160.00 Hours

## Periodic Excess and Invalid Summary

### Emission Data Summary

| | |
|---|---|
| 1. Duration of excess emission in event reporting period due to: | |
| a. Startup/shutdown | 0 |
| b. Control equipment problems | 0 |
| c. Process problems | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Total Duration of Excess Emission in Minute(s) | 0 |
| 3. Time of Excess Emission as a percentage of operating time | 0.00 |
| 4. Time in compliance as percentage of operating time | 100.00 |

### CMS Performance Summary

| | |
|---|---|
| 1. CMS downtime in event reporting period due to: | |
| a. Monitor equipment malfunctions | 0 |
| b. Non-Monitor equipment malfunctions | 0 |
| c. Quality assurance calibration | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Total CMS Downtime in Minute(s) | 0 |
| 3. Total Downtime as a percentage of operating time | 0.00 |
| 4. Total Availability as a percentage of operating time | 100.00 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/01/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 03:00 | 2.4 | 0 | 0 | 0 | 1 | 0 |
| 01/01/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/01/2014 13:00 | 67.3 | 0 | 1 | 0 | 0 | 0 |
| 01/01/2014 14:00 | 54.8 | 0 | 1 | 0 | 0 | 0 |
| 01/01/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/01/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 124.5 # | 0 # | 2 # | 0 # | 1 # | 12 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 67.3 | 0 | 1 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/02/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/02/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/03/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/03/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/04/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/04/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/05/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/05/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/06/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/06/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/07/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/07/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/08/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/08/2014 22:00 | 3.0 | 0 | 0 | 0 | 1 | 0 |
| 01/08/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 3.0 # | 0 # | 0 # | 0 # | 1 # | 22 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 3.0 | 0 | 0 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/09/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/09/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/10/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/10/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/11/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/11/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/12/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/12/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/13/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/13/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/14/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/14/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/15/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/15/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/16/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/16/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/17/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/17/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/18/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/18/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/19/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/19/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/20/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/20/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/21/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/21/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/22/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/22/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/23/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/23/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/24/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/24/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/25/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/25/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/26/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/26/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/27/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/27/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/28/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/28/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/29/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 01/29/2014 08:00 | 71.1 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 09:00 | 123.8 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 10:00 | 42.2 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 11:00 | 53.8 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 12:00 | 29.2 | 1 | 0 | 0 | 0 | 0 |
| 01/29/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/29/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 320.1 # | 5 # | 0 # | 0 # | 0 # | 11 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 123.8 | 1 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/30/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/30/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 01/31/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 01/31/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/01/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/01/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/02/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/02/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/03/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/03/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/04/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/04/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/05/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/05/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/06/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/06/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/07/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/07/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/08/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/08/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/09/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/09/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/10/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/10/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/11/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/11/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/12/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/12/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/13/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/13/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/14/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/14/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/15/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/15/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/16/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/16/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/17/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/17/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/18/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/18/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/19/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 02:00 | 2.2 | 0 | 0 | 0 | 1 | 0 |
| 02/19/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 02/19/2014 17:00 | 92.3 | 0 | 1 | 0 | 0 | 0 |
| 02/19/2014 18:00 | 23.5 | 0 | 1 | 0 | 0 | 0 |
| 02/19/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/19/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 118.0 # | 0 # | 2 # | 0 # | 1 # | 7 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 92.3 | 0 | 1 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/20/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/20/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/21/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/21/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/22/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/22/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/23/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/23/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/24/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/24/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/25/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/25/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/26/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/26/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/27/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/27/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 02/28/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 02/28/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/01/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/01/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/02/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/02/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/03/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/03/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/04/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/04/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/05/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/05/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/06/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/06/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/06/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/06/2014 03:00 | 2.0 | 0 | 0 | 0 | 1 | 0 |
| 03/06/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/06/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 2.0 # | 0 # | 0 # | 0 # | 1 # | 3 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 2.0 | 0 | 0 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/07/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/07/2014 07:00 | 73.3 | 0 | 1 | 0 | 0 | 0 |
| 03/07/2014 08:00 | 56.1 | 0 | 1 | 0 | 0 | 0 |
| 03/07/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/07/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 129.4 # | 0 # | 2 # | 0 # | 0 # | 15 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 73.3 | 0 | 1 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/08/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/08/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/09/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 02:00 | 2.0 | 0 | 0 | 0 | 1 | 0 |
| 03/09/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/09/2014 15:00 | 73.8 | 0 | 1 | 0 | 0 | 0 |
| 03/09/2014 16:00 | 16.7 | 0 | 1 | 0 | 0 | 0 |
| 03/09/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/09/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 92.5 # | 0 # | 2 # | 0 # | 1 # | 9 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 73.8 | 0 | 1 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/10/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/10/2014 23:00 | 2.7 | 0 | 0 | 0 | 1 | 0 |
| **Average/Sum#:** | 2.7 # | 0 # | 0 # | 0 # | 1 # | 23 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 2.7 | 0 | 0 | 0 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/11/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/11/2014 05:00 | 21.9 | 0 | 0 | 1 | 0 | 0 |
| 03/11/2014 06:00 | 88.1 | 0 | 0 | 1 | 0 | 0 |
| 03/11/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/11/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 110.0 # | 0 # | 0 # | 2 # | 0 # | 17 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 88.1 | 0 | 0 | 1 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/12/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/12/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/13/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/13/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 24 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/14/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 01:00 | 2.6 | 0 | 0 | 0 | 1 | 0 |
| 03/14/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/14/2014 06:00 | 0.0 | 0 | 0 | 1 | 0 | 0 |
| 03/14/2014 07:00 | 82.1 | 0 | 0 | 1 | 0 | 0 |
| 03/14/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| 03/14/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 1 |
| **Average/Sum#:** | 84.7 # | 0 # | 0 # | 2 # | 1 # | 17 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 82.1 | 0 | 0 | 1 | 1 | 1 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/15/2014 00:00 | 2.8 | 0 | 0 | 0 | 1 | 0 |
| 03/15/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/15/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 2.8 # | 0 # | 0 # | 0 # | 1 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 2.8 | 0 | 0 | 0 | 1 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/16/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/16/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/17/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/17/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/18/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/18/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/19/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/19/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/20/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/20/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/21/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/21/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/22/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/22/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/23/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/23/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/24/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/24/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/25/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/25/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/26/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/26/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/27/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/27/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/28/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/28/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/29/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/29/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/30/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/30/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Daily Summary Report

## CT2 Event NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:15 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Unit CT2 NOx_Event, Lb 1 Hour(s) | Unit CT2 Startup, Cold, TF 1 Hour(s) | Unit CT2 Startup, Warm, TF 1 Hour(s) | Unit CT2 Startup, Hot, TF 1 Hour(s) | Unit CT2 Shutdown, TF 1 Hour(s) | Unit CT2 NormalOp, TF 1 Hour(s) |
|---|---|---|---|---|---|---|
| 03/31/2014 00:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 01:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 02:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 03:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 04:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 05:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 06:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 07:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 08:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 09:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 10:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 11:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 12:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 13:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 14:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 15:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 16:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 17:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 18:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 19:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 20:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 21:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 22:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| 03/31/2014 23:00 | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Average/Sum#:** | 0.0 # | 0 # | 0 # | 0 # | 0 # | 0 # |
| **Minimum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **Maximum:** | 0.0 | 0 | 0 | 0 | 0 | 0 |
| **%SI** | 0.0 | 0 | 0 | 0 | 0 | 0 |

# Pound Per Event Report

## CT2 - NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

**Tag Name:** CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,184.78 Hours

Non-Operating Time: 975.22 Hours Report Time: 2,160.00 Hours

## Unit Operation and Excess Events

| Event Period | | | | Reason | Action |
|---|---|---|---|---|---|
| Begin/End | Duration in Minute(s) | Value (Sum) | Limit | Code - Description | Code - Description |
| 01/01/2014 03:24<br>01/01/2014 03:32<br>Shut Down - Gas | 9 | 4.00 | 115.00 | | |
| 01/01/2014 13:20<br>01/01/2014 14:49<br>Warm Start - Gas | 90 | 129.66 | 456.20 | | |
| 01/08/2014 22:09<br>01/08/2014 22:16<br>Shut Down - Gas | 8 | 3.33 | 115.00 | | |
| 01/29/2014 08:22<br>01/29/2014 12:30<br>Cold Start - Gas | 249 | 317.69 | 779.10 | | |
| 02/19/2014 02:07<br>02/19/2014 02:13<br>Shut Down - Gas | 7 | 1.33 | 115.00 | | |
| 02/19/2014 17:14<br>02/19/2014 18:21<br>Warm Start - Gas | 68 | 138.41 | 456.20 | | |
| 03/06/2014 03:08<br>03/06/2014 03:14<br>Shut Down - Gas | 7 | 1.09 | 115.00 | | |
| 03/07/2014 07:22<br>03/07/2014 08:37<br>Warm Start - Gas | 76 | 148.12 | 456.20 | | |
| 03/09/2014 02:07<br>03/09/2014 02:13<br>Shut Down - Gas | 7 | 1.82 | 115.00 | | |
| 03/09/2014 15:13<br>03/09/2014 16:20<br>Warm Start - Gas | 68 | 110.89 | 456.20 | | |
| 03/10/2014 23:07<br>03/10/2014 23:13<br>Shut Down - Gas | 7 | 1.68 | 115.00 | | |
| 03/11/2014 05:41<br>03/11/2014 06:52<br>Hot Start - Gas | 72 | 113.51 | 259.90 | | |
| 03/14/2014 01:38<br>03/14/2014 01:49<br>Shut Down - Gas | 12 | 3.24 | 115.00 | | |

# Pound Per Event Report

## CT2 - NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

**Tag Name:** CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,184.78 Hours

Non-Operating Time: 975.22 Hours Report Time: 2,160.00 Hours

| Event Period | | | | Reason | Action |
|---|---|---|---|---|---|
| Begin/End | Duration in Minute(s) | Value (Sum) | Limit | Code - Description | Code - Description |
| 03/14/2014 06:53<br>03/14/2014 07:54<br>Hot Start - Gas | 62 | 81.76 | 259.90 | | |
| 03/15/2014 00:05<br>03/15/2014 00:14<br>Shut Down - Gas | 10 | 3.01 | 115.00 | | |

No excess emissions were found in the reporting period.

# Pound Per Event Report

## CT2 - NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

**Tag Name:** CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,184.78 Hours

Non-Operating Time: 975.22 Hours Report Time: 2,160.00 Hours

## Event Invalid Information

No invalid events were found in the reporting period.

# Pound Per Event Report

## CT2 - NOx Lbs

**From:** 01/01/2014 00:00 **To:** 03/31/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

**Generated:** 04/22/2014 15:10 **Location:** Maxwell, CA

**Tag Name:** CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

**Total Operating Time:** 1,184.78 Hours

Non-Operating Time: 975.22 Hours Report Time: 2,160.00 Hours

## Periodic Excess and Invalid Summary

### Emission Data Summary

| | |
|---|---|
| 1. Duration of excess emission in event reporting period due to: | |
| a. Startup/shutdown | 0 |
| b. Control equipment problems | 0 |
| c. Process problems | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Total Duration of Excess Emission in Minute(s) | 0 |
| 3. Time of Excess Emission as a percentage of operating time | 0.00 |
| 4. Time in compliance as percentage of operating time | 100.00 |

### CMS Performance Summary

| | |
|---|---|
| 1. CMS downtime in event reporting period due to: | |
| a. Monitor equipment malfunctions | 0 |
| b. Non-Monitor equipment malfunctions | 0 |
| c. Quality assurance calibration | 0 |
| d. Other known causes | 0 |
| e. Unknown causes | 0 |
| 2. Total CMS Downtime in Minute(s) | 0 |
| 3. Total Downtime as a percentage of operating time | 0.00 |
| 4. Total Availability as a percentage of operating time | 100.00 |

# ATTACHMENT 13
## Water Bath Heater Operations (AQ-17)

The Natural Gas Fired Water Bath Heater did not operate in the 1st Quarter of 2014.

# ATTACHMENT 14
## Toxics (AQ-29)

**TOXICS AND GHG TRACKING AND COMPLIANCE PLAN**

**PG&E Colusa Generating Station**

Reporting/Tracking Year: 2014

**Combustion Turbines/HRSGs**

| | CAS # | Emissions Factors lb/mmbtu | Emissions Factors lb/mmscf | EF Source | Source Test Results lb/hr | Max Hourly Emissions lbs | Annual Emissions lbs | Annual Emissions tons |
|---|---|---|---|---|---|---|---|---|
| Ammonia Unit #1 | 7664417 | 0.00E+00 | 0.00E+00 | Test 11/10 | 4.06 | 4.06 | 4754.26 | 2.377 |
| Formaldehyde Unit #1 | 50000 | 7.00E-05 | 9.19E-02 | Test | 0.029 | 0.029 | 33.96 | 0.017 |
| Ammonia Unit #2 | 7664417 | 0.00E+00 | 0.00E+00 | Test 11/10 | 4.37 | 4.37 | 23357.65 | 11.679 |
| Formaldehyde Unit #2 | 50000 | 7.00E-05 | 9.19E-02 | Test | 0.014 | 0.014 | 74.83 | 0.037 |
| 1-3 Butadiene | 106990 | 1.24E-07 | 1.27E-04 | CATEF | 0 | 0.001 | 0.56 | 0.000 |
| Acetaldehyde | 75070 | 1.34E-04 | 1.37E-01 | CATEF | 0 | 0.656 | 599.08 | 0.300 |
| Acrolein | 107028 | 1.85E-05 | 1.89E-02 | CATEF | 0 | 0.091 | 82.65 | 0.041 |
| Benzene | 71432 | 1.30E-05 | 1.33E-02 | CATEF | 0 | 0.064 | 58.16 | 0.029 |
| Ethylbenzene | 100414 | 1.75E-05 | 1.79E-02 | CATEF | 0 | 0.086 | 78.27 | 0.039 |
| Hexane | 110543 | 2.53E-04 | 2.59E-01 | CATEF | 0 | 1.240 | 1132.58 | 0.566 |
| Propylene | 115071 | 7.53E-04 | 7.71E-01 | CATEF | 0 | 3.692 | 3371.49 | 1.686 |
| Propylene Oxide | 75569 | 4.67E-05 | 4.78E-02 | CATEF | 0 | 0.229 | 209.02 | 0.105 |
| Toluene | 108883 | 6.93E-05 | 7.10E-02 | CATEF | 0 | 0.340 | 310.47 | 0.155 |
| Xylenes | 1330207 | 2.55E-05 | 2.61E-02 | CATEF | 0 | 0.125 | 114.13 | 0.057 |
| Naphthalene | 91203 | 1.62E-06 | 1.66E-03 | CATEF | 0 | 0.008 | 7.26 | 0.004 |
| Total PAH w/o Naph | 1151 | 1.30E-07 | 1.31E-04 | CATEF | 0 | 0.001 | 0.57 | 0.000 |

| **GHG** | kg/mmbtu | Frac Ox. | lbs/mmbtu | lb/mmscf | | | | |
|---|---|---|---|---|---|---|---|---|
| CO2 | 53.06 | 1 | 1.17E+02 | 1.20E+05 | CCAR | 0 | 573603.7 | 5.238E+08 | 2.619E+05 |
| CH4 | 0.003901 | na | 8.60E-03 | 8.81E+00 | CCAR | 0 | 42.172 | 3.851E+04 | 19.255 |
| N2O | 0.001361 | na | 3.00E-03 | 3.07E+00 | CCAR | 0 | 14.713 | 1.344E+04 | 6.718 |
| CO2e | 264386.3 | tons/yr | | *CO2e* | *239806.2* | *metric tons/yr* | | | |

**Total Turbines/HRSGs**

| | | | |
|---|---|---|---|
| Fuel Use Rate Data | | | |
| NG HHV | 1024 | btu/scf | |
| *Fuel Meter Data* | | | |
| Max Hourly Fuel Use | 4.7887 | mmscf | (for both units) |
| Annual Fuel Use | 4372.88 | mmscf | (for both units) |
| *Calculated Heat Rate Data* | | | |
| Max Hourly Heat Rate | 4903.60 | mmbtu | (for both units) |
| Annual Heat Rate | 4477829.1 | mmbtu | (for both units) |
| *DAHS/Op Log Data* | | | |
| Unit #1 Annual Ops Hrs | 1171 | Hrs/Yr | |
| Unit #2 Annual Ops Hrs | 5345 | Hrs/Yr | |
| Total Hrs, All Units | 6516 | Hrs/Yr | (for both units) |
| CT1 Annual Fuel Use | 2157.95 | mmscf | |
| CT2 Annual Fuel Use | 2214.93 | mmscf | |

**Fuel Gas Heater (10 mmbtu/hr)**

| | CAS # | Emissions Factors lb/mmbtu | Emissions Factors lb/mmscf | EF Source | Source Test Results lb/hr | Max Hourly Emissions lbs | Annual Emissions lbs | Annual Emissions tons |
|---|---|---|---|---|---|---|---|---|
| Acetaldehyde | 75070 | 8.66E-06 | 8.87E-03 | CATEF | 0 | 0.0001 | 0.000 | 0.0000 |
| Benzene | 71432 | 4.21E-06 | 4.31E-03 | CATEF | 0 | 0.0000 | 0.000 | 0.0000 |
| Formaldehyde | 50000 | 2.16E-04 | 2.21E-01 | CATEF | 0 | 0.0022 | 0.000 | 0.0000 |

**Total FG Heater**

| | | |
|---|---|---|
| Fuel Use Rate Data | | |
| NG HHV | 1000 | btu/scf |
| *Fuel Use Data* | | |
| Max Hourly Fuel Use | 0.00977 | mmscf |
| Annual Fuel Use | 0.00 | mmscf |
| *Calculated Heat Rate Data* | | |
| Max Hourly Heat Rate | 9.77 | mmbtu |
| Annual Heat Rate | 0.00 | mmbtu |