

DOCKETED

Docket Number:	09-AFC-07C
Project Title:	Palen Solar Power Project - Compliance
TN #:	202491
Document Title:	Ex.1143 - Comparison of Operational Benefits - PSEGS (Tower) versus PV Alternative
Description:	Subject - Override Considerations
Filer:	Marie Fleming
Organization:	Galati Blek LLP
Submitter Role:	Applicant Representative
Submission Date:	6/23/2014 3:20:09 PM
Docketed Date:	6/23/2014

COMPARISON OF OPERATIONAL BENEFITS: PSEGS (TOWER) vs. PV ALTERNATIVE

Attribute	PSEGS	PV
Future Thermal Storage	High	None
Reactive Power and Voltage Support	High	Low
Frequency Control	High	Low
Inertia Response	High	None
Solar Field Multiple and System Inertia	High	Low
Controllability	High	Medium
Increased Solar Energy and Reduced Variability with Use of Natural Gas	High	None
Transmission Reliability and Utilization Benefits	High	Low