

DOCKETED

Docket Number:	12-AFC-02
Project Title:	Huntington Beach Energy Project
TN #:	202707
Document Title:	Prehearing Conference Workshop Notes - 7/10/14
Description:	N/A
Filer:	Alicia Campos
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	7/15/2014 1:51:53 PM
Docketed Date:	7/15/2014

PREHEARING CONFERENCE WORKSHOP NOTES – 7/10/14

Air Quality

Air Quality remains contested. Applicant reiterated it does not intend to offer live testimony at EH on the issue that Applicant contests. Detailed discussion will be deferred to EH.

AQ-SC6: Staff approved changes proposed by AES, however an error occurred in staff's PHC statement. Correction as follows:

- Remove strikeover on "to"
- Include strikeover on "sweeping"

AQ-SC6 ~~During the construction phase of this project, the project owner shall conduct a local street sweeping program to provide at least 8.26 lbs/day PM10 and 0.79 lbs/day PM2.5 of emissions reductions. The project owner shall provide, for approval, a Construction Particular Matter Mitigation Plan (CPMMP) that details the steps to be taken and the reporting requirements necessary to ensure the implementation of the local street sweeping program.~~ **provide the equivalent of at least 8.26 lbs/day PM10 and 0.79 lbs/day PM2.5 of emissions reductions during the construction phase of the project. Construction emission reduction measures can include: localized street sweepers or programs; local ban of leaf blowing or blowers; sodding of local parks or playfields; fireplace or woodstove replacements; offsets or emission reduction credits; or other measures that can provide local emission reductions coincident with construction emissions.**

Verification: At least 90 days prior to the start of any ground disturbance, the project owner shall submit the CPMMP to the CPM for approval. The CPM will notify the project owner of any necessary modifications to the plan within 30 days from the date of receipt. The CPMMP must be approved by the CPM before the start of ground disturbance. During construction the project owner shall provide the records of the ~~sweeping program~~ **CPMMP** in the Monthly Compliance Report. "

Hazardous Materials

Staff does not accept proposed changes by AES to **HAZ-6**. Staff proposed AES submit a rewrite of **HAZ-6** and submit before EH. Parties will attempt to resolve prior to EH.

Land Use

Staff has approved AES changes to **LAND-1**.
No other contested issues related to Land Use.

Noise

Staff has approved AES recommendations to **NOISE-2, 4 and 7**.

No other contested issues related to Noise. An error was noted in Staff's PHC statement in that the strikethrough of L_{eq} in two places in Noise-4 was not captured.

Waste

Staff does not accept proposed changes by AES to **WASTE-1** and **2**. Parties discussed intent of proposed changes and Staff will further discuss internally. Parties will attempt to resolve prior to EH.

Soil & Water

Staff approved AES recommended corrections:

- Maximum HBEP water use from 115 AFY → 134 AFY
- Waste Discharge Order from R8-2010-0062 → R8-2006-001

Water remains contested by Intervenor Rudman.