

DOCKETED

Docket Number:	15-MISC-02
Project Title:	2013 Building Energy Efficiency Standards
TN #:	204106
Document Title:	Patricia Van Guilder Comments: Mandatory R30 / R38 in Roofs
Description:	N/A
Filer:	System
Organization:	Patricia Van Guilder
Submitter Role:	Public
Submission Date:	4/9/2015 5:16:36 PM
Docketed Date:	4/10/2015

Comment Received From: Patricia Van Guilder

Submitted On: 4/9/2015

Docket Number: 15-MISC-02

Mandatory R30 / R38 in Roofs

This is a difficult and expensive compliance requirement especially in additions where you may be constrained by existing framing or trying to match existing conditions. There should be a way to trade this off (make it not mandatory).

example As T24 consultants we just did a small patio conversion to conditioned space 181 sf, cathedral ceiling. It was simply ridiculous to tell the clients that they had to reframe this little area, with 2x12's (batt insulation) or have a spray foam contractor come out for 181 sf.