

## DOCKETED

<b>Docket Number:</b>	15-MISC-02
<b>Project Title:</b>	2013 Building Energy Efficiency Standards
<b>TN #:</b>	204893-1
<b>Document Title:</b>	Email to Mr. Splitt Regarding 2016 Language Changes from Petition
<b>Description:</b>	N/A
<b>Filer:</b>	Patty Paul
<b>Organization:</b>	California Energy Commission
<b>Submitter Role:</b>	Commission Staff
<b>Submission Date:</b>	6/3/2015 3:21:13 PM
<b>Docketed Date:</b>	6/3/2015

## Paul, Patricia@Energy

---

**From:** Strait, Peter@Energy  
**Sent:** Wednesday, June 03, 2015 9:45 AM  
**To:** Energy - Docket Optical System  
**Cc:** Geiszler, Eurlyne@Energy  
**Subject:** FW: 2016 Language Changes from Petition  
**Attachments:** Pages from 2016 T24 responding to Item 9.pdf; Pages from 2016 T24 responding to Item 10.pdf; Pages from 2016 T24 responding to Item 11.pdf; Pages from 2016 T24 responding to Item 12.pdf; Pages from 2016 T24 responding to Item 13.pdf; Pages from 2016 T24 responding to Item 19.pdf; Pages from 2016 T24 responding to Item 5.pdf

**Categories:** Ready to Docket

Hello Dockets,

Please docket the below letter to Pat Splitt, along with attachments, to both 15-MISC-01 and 15-MISC-02.

Thank you,

Peter

---

**From:** Strait, Peter@Energy  
**Sent:** Monday, June 01, 2015 3:53 PM  
**To:** 'info@app-techinc.com'  
**Subject:** 2016 Language Changes from Petition

Dear Mr. Splitt,

With the publication of the 15-Day Language, I wanted to reach out to you to highlight the changes we'd made to be responsive to the items you identified in your Emergency Rulemaking petition.

I've attached page excerpts containing the changes made to the 2016 Standards that address items in your petition, numbered according to the item each is responsive to (using the numbering in our staff response). The changes are as follows:

- Item 5: Section 150.2(b)(2)(B) - A note has been added to this Section to make explicit the ability to trade between two components of the same type, and the language has additionally been edited to align with the change made to address Item 10.
- Item 9: Section 141.0(b)2I - The language for nonresidential lighting alterations has been rewritten, and the rewritten language is clearer in regards to what activities trigger the requirements of this Section. There is also a path that allows a whole-project compliance approach.
- Item 10: Section 141.0(b)3B - The language of this Section has been edited to clearly state that the third party verification option means verifying the components for which additional credit is taken under that option. The same phrase has been added to Section 150.2(b)2B.

- Item 11: Table 141.0-E - This table has been rewritten as a part of rewriting Section 141.0(b)2I, and now provides more streamlined information regarding applicable lighting control requirements. This addresses the original concern that the table should only discuss control requirements and not lighting power densities.
- Item 12: Section 150.0(j)1A - This Section, regarding installation of a less-than-federally-compliant water heater, has been removed from the Standards.
- Item 13: Section 150.0(j)2 - The language in this Section has been edited to remove the specification of a psig for hot water systems. (The language of this Section has also been edited to remove a specification that buried pipes include a casing or sleeve “that allows for installation, removal, and replacement of the enclosed pipe and insulation”. I believe you requested that we look into removing this language at the April townhall meeting; the language was found to be unneeded as common practice is to replace the casing and insulation as well if the pipe is replaced.)
- Item 19: Section 130.2(b) - A note was added to this section to provide direction to the Title 24, Part 11, Section 5.106.8 requirements.

We’ve added highlighting comments to the PDFs to both show and explain the changes (hover or double-click on the highlighting if the comment text is not immediately visible). We’ve also internally drafted changes to the Compliance Manuals that address other items in your petition; I’ll be drafting a separate letter with those changes shortly.

Please let me know if there’s any additional information my team can provide.

Thank you,

Peter Strait

Supervisor, Building Standards Office  
California Energy Commission  
1516 9<sup>th</sup> Street, MS 37  
Sacramento, CA 95814  
(916) 654-2817