

DOCKETED

Docket Number:	15-BSTD-05
Project Title:	2016 Nonresidential Compliance Manual and Documents
TN #:	205950
Document Title:	Jack Yapp Comments: Acceptance Testing
Description:	N/A
Filer:	System
Organization:	Jack Yapp
Submitter Role:	Public
Submission Date:	8/31/2015 3:13:51 PM
Docketed Date:	8/31/2015

Comment Received From: Jack Yapp

Submitted On: 8/31/2015

Docket Number: 15-BSTD-05

Acceptance Testing

Additional submitted attachment is included below.

August 31, 2015

To: The California Energy Commission Building Energy Efficiency Standard Rulemaking

Re: Docket Number 15-BSTD-05

2016 Compliance Manual

DOCKET@energy.ca.gov

5.4 Mandatory Lighting Controls

4. Automatic Daylighting Controls separately controlling ~~some of~~ all the lights in the daylight area from the lights that are not in the daylight area.

Comments

To measure the required reduction of power and foot-candles the other contributing lighting must be off. Having the ability to shut off all general lighting from the Automatic Daylighting while performing Acceptance Testing will assure proper inputs for the calculations.

5.4.1 Area Lighting Controls

(C) 4. Automatic Daylighting

Comments

Area Controls are manual controls and having the ability of selecting Automatic Daylighting area controls will assure the power and or foot-candles are readings are not affected by the general lighting.

Michael Scalzo
President of NLCAA