

DOCKETED

| | |
|-------------------------|---|
| Docket Number: | 16-BSTD-05 |
| Project Title: | 2016 Nonresidential Compliance Manual Subchapters and Documents Related to Lighting Alterations |
| TN #: | 210636 |
| Document Title: | Adel Poursharif, P.E. Comments: Calculation for Lighting Alteration |
| Description: | N/A |
| Filer: | System |
| Organization: | Adel Poursharif, P.E. |
| Submitter Role: | Public |
| Submission Date: | 3/7/2016 4:55:55 PM |
| Docketed Date: | 3/7/2016 |

Comment Received From: Adel Poursharif, P.E.

Submitted On: 3/7/2016

Docket Number: 16-BSTD-05

Calculation for Lighting Alteration

Per ASHRAE Std.90.1-2010 9.1.2 Exception "Alterations that involve less than 10% of the connected "lighting load" in a space or area need ... But, per 2013 BEES TABLE 141.0-E less than 10% of existing "luminaires". Since, we are trying to save energy, it make sense to calculate based on the lighting load instead of lighting unit quantity or luminaires.