

DOCKETED

Docket Number:	08-AFC-07C
Project Title:	GWF Tracy (Compliance)
TN #:	211119
Document Title:	South County Fire Authority E-mail Response
Description:	N/A
Filer:	Patty Paul
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	4/18/2016 11:46:40 AM
Docketed Date:	4/18/2016

Fooks, Brett@Energy

From: Kevin Jorgensen <Kevin.Jorgensen@ci.tracy.ca.us>
Sent: Wednesday, July 08, 2015 6:07 PM
To: Fooks, Brett@Energy
Cc: Lesh, Geoff@Energy; Layton, Matthew@Energy; Scott Owen; Bryan Just; Steve Moncur; Christopher Landreth
Subject: RE: GWF Tracy Power Plant Possible Recycled Water Usage...

Brett,

The South County Fire Authority will accept recycled water in the static water supply at GWF Tracy Power Plant.

Kevin Jorgensen
Chief Building Official
Fire Code Official
City of Tracy
South County Fire Authority
333 Civic Center Plaza
Tracy, California 95376
(209)831-6400-office
(209)831-6415-direct
kevin.jorgensen@ci.tracy.ca.us



From: Fooks, Brett@Energy [<mailto:Brett.Fooks@energy.ca.gov>]
Sent: Tuesday, July 07, 2015 8:43 AM
To: Kevin Jorgensen
Cc: Lesh, Geoff@Energy; Layton, Matthew@Energy
Subject: GWF Tracy Power Plant Possible Recycled Water Usage...
Importance: High

Kevin,

I spoke with you yesterday afternoon about the possibility of the GWF Tracy Power Plant using recycled water for their fire suppression. The power plant uses a fire water storage tank to supply the fire loop and fire suppression systems on site. The power plant submitted an emergency petition to the California Energy Commission seeking alternative supplies of water in case the power plant can't get water from their current source. One of the alternatives was to purchase

recycled water from the City of Tracy. Recycled water is seen as the preferable alternative due to the tight supply of potable water during the current drought.

Per our conversation yesterday, I have attached some information that defines the quality of and how tertiary recycled water is made. Please let me know if the Tracy Fire Department has any concerns/issues that would prevent the use of recycled water for the fire suppression system at the GWF Tracy power plant.

If you need any additional information or clarification, don't hesitate to call or email me.

Regards,

Brett Fooks | Mechanical Engineer

Direct: 916.654.5593 | **Fax:** 916.654.3882

Brett.Fooks@energy.ca.gov



CALIFORNIA ENERGY COMMISSION

1516 Ninth Street, Sacramento, CA

www.energy.ca.gov