DOCKETE	DOCKETED					
Docket Number:	12-AFC-02C					
Project Title:	Huntington Beach Energy Project - Compliance					
TN #:	211437					
Document Title:	South Coast Air Quality Management District Correspondance 05-06-16 Part 9					
Description:	N/A					
Filer:	Patty Paul					
Organization:	CH2M HILL					
Submitter Role:	Applicant Consultant					
Submission Date:	5/10/2016 2:01:18 PM					
Docketed Date:	5/10/2016					



TABLE 3-4. RELATIVE ACCURACY SUMMARY: CO CONCENTRATION

Facility: OCSD, Plant No. 2

City: Huntington Beach, CA

Source: Engine 5

Facility ID: 29110

Job No.: 9849

Test Date: 10/01/15

Test: RATA

		Reference Method		Facility		Difference
Run	Time	CO	Report	CO	Report	CO
No.	(hh:mm)	ppm	Page No.	ppm	Page No.	ppm
1	7:43-8:12	591.37	D1-1	644.87	F1-1	-53.50
2	8:13-8:42	574.10	D1-1	627.39	F1-1	-53.29
3	8:43-9:12	580.31	D1-1	632.74	F1-1	-52.43
4	9:31-10:00	590.16	D1-1	638.91	F1-1	-48.75
5	10:01-10:30	578.80	D1-1	629.02	F1-1	-50.22
6	10:31-11:00	580.92	D1-1	634.26	F1-1	-53.34
7	11:16-11:45	579.05	D1-1	629.08	F1-1	-50.03
8	11:46-12:15	585.05	D1-1	632.51	F1-1	-47.46
9	12:16-12:45	573.98	D1-1	623.82	F1-1	-49.84

 RM Average
 CEMS Average
 (d)

 581.53
 632.51
 -50.98

Number of Valid Runs (n):9Standard Deviation (Sd):2.223t-value (0.975):2.306Confidence Coefficient (cc):1.709

Relative Accuracy Test Result: 9.06 % of RM

SCAQMD RULE 218/218.1 CRITERIA: ≤ 20.0 % of RM



TABLE 3-5. RELATIVE ACCURACY SUMMARY: CO CORRECTED CONCENTRATION

Facility: OCSD, Plant No. 2

City: Huntington Beach, CA

Source: Engine 5

Facility ID: 29110

Job No.: 9849

Test Date: 10/01/15

Test: RATA

		Reference Method		Facility		Difference
Run	Time	CO	Report	CO	Report	CO
No.	(hh:mm)	ppm@15%O2	Page No.	ppm@15%O2	Page No.	ppm@15%O2
1	7:43-8:12	382.42	D1-1	424.59	F1-1	-42.17
2	8:13-8:42	371.35	D1-1	410.59	F1-1	-39.24
3	8:43-9:12	378.55	D1-1	420.71	F1-1	-42.16
4	9:31-10:00	382.75	D1-1	419.45	F1-1	-36.70
5	10:01-10:30	376.45	D1-1	416.17	F1-1	-39.72
6	10:31-11:00	380.88	D1-1	419.98	F1-1	-39.10
7	11:16-11:45	373.19	D1-1	408.90	F1-1	-35.71
8	11:46-12:15	380.64	D1-1	419.20	F1-1	-38.56
9	12:16-12:45	372.37	D1-1	408.64	F1-1	-36.27

 RM Average
 CEMS Average
 (d)

 377.62
 416.47
 -38.85

Number of Valid Runs (n):9Standard Deviation (Sd):2.348t-value (0.975):2.306Confidence Coefficient (cc):1.804

Relative Accuracy Test Result: 10.77 % of RM

SCAQMD RULE 218/218.1 CRITERIA: ≤ 20.0 % of RM



TABLE 3-6. RELATIVE ACCURACY SUMMARY: CO MASS EMISSION RATE

Facility: OCSD, Plant No. 2

City: Huntington Beach, CA

Source: Engine 5

Facility ID: 29110

Job No.: 9849

Test Date: 10/01/15

Test: RATA

		Reference Method		Facility		Difference
Run	Time	CO	Report	CO	Report	CO
No.	(hh:mm)	lb/hr	Page No.	lb/hr	Page No.	lb/hr
1	7:43-8:12	25.151	D1-1	28.030	F1-1	-2.879
2	8:13-8:42	24.549	D1-1	27.380	F1-1	-2.831
3	8:43-9:12	24.882	D1-1	28.440	F1-1	-3.558
4	9:31-10:00	25.675	D1-1	27.880	F1-1	-2.205
5	10:01-10:30	25.161	D1-1	27.730	F1-1	-2.569
6	10:31-11:00	25.251	D1-1	28.450	F1-1	-3.199
7	11:16-11:45	24.577	D1-1	27.160	F1-1	-2.583
8	11:46-12:15	24.986	D1-1	27.880	F1-1	-2.894
9	12:16-12:45	24.566	D1-1	27.160	F1-1	-2.594

 RM Average
 CEMS Average
 (d)

 24.978
 27.790
 -2.812

Number of Valid Runs (n):9Standard Deviation (Sd):0.395t-value (0.975):2.306Confidence Coefficient (cc):0.303

Relative Accuracy Test Result: 12.47 % of RM

SCAQMD RULE 218/218.1 CRITERIA ≤ 20.0 % of RM



TABLE 3-7. RELATIVE ACCURACY SUMMARY: DRY VOLUMETRIC FLOW RATE

Facility: OCSD, Plant No. 2

City: Huntington Beach, CA

Source: Engine 5

Facility ID: 29110

Job No.: 9657

Test Date: 10/01/15

Test: RATA

		Reference Method		Facility		Difference
Run	Time	Dry Flow	Report	Dry Flow	Report	Dry Flow
No.	(hh:mm)	dscfh	Page No.	dscfh	Page No.	dscfh
1	7:43-8:12	576,377	D1-1	597,826	F1-1	-21,448
2	8:13-8:42	579,502	D1-1	600,191	F1-1	-20,689
3	8:43-9:12	581,080	D1-1	618,448	F1-1	-37,369
4	9:31-10:00	589,604	D1-1	600,512	F1-1	-10,908
5	10:01-10:30	589,123	D1-1	606,556	F1-1	-17,433
6	10:31-11:00	589,078	D1-1	617,090	F1-1	-28,012
7	11:16-11:45	575,211	D1-1	593,955	F1-1	-18,744
8	11:46-12:15	578,771	D1-1	606,370	F1-1	-27,599
9	12:16-12:45	580,031	D1-1	599,077	F1-1	-19,047

Difference Average

RM Average	CEMS Average	(d)
582,086	604,447	-22,361

Number of Valid Runs (n):9Standard Deviation (Sd):7,646t-value (0.975):2.306Confidence Coefficient (cc):5,878

Relative Accuracy Test Result: 4.85 % of RM

SCAQMD RULE 218/218.1 CRITERIA

RATA Allowable Limit ≤ 15.0 % of RM



TABLE 3-8. RELATIVE ACCURACY SUMMARY: O2 CONCENTRATION

Facility: OCSD, Plant No. 2

City: Huntington Beach, CA

Source: Engine 5

Facility ID: 29110

Job No.: 9849

Test Date: 10/01/15

Test: RATA

		Reference Method		Facility		Difference
Run	Time	O2	Report	O2	Report	O2
No.	(hh:mm)	%	Page No.	%	Page No.	%
1	7:43-8:12	11.78	D1-1	11.94	F1-1	-0.16
2	8:13-8:42	11.78	D1-1	11.88	F1-1	-0.10
3	8:43-9:12	11.86	D1-1	12.03	F1-1	-0.17
4	9:31-10:00	11.80	D1-1	11.91	F1-1	-0.11
5	10:01-10:30	11.83	D1-1	11.98	F1-1	-0.15
6	10:31-11:00	11.90	D1-1	11.99	F1-1	-0.09
7	11:16-11:45	11.75	D1-1	11.82	F1-1	-0.07
8	11:46-12:15	11.83	D1-1	12.00	F1-1	-0.17
9	12:16-12:45	11.81	D1-1	11.89	F1-1	-0.08

 RM Average
 CEMS Average
 (d)

 11.81
 11.94
 -0.124

Number of Valid Runs (n):9Standard Deviation (Sd):0.040t-value (0.975):2.306Confidence Coefficienct (cc):0.031

Relative Accuracy Test Result: 1.31 % of RM

SCAQMD RULE 218/218.1 CRITERIA

RATA Allowable Limit ≤ 10.0 % of RM



4.0 EQUIPMENT AND PROCESS DESCRIPTION

Orange County Sanitation District's wastewater treatment facility in Huntington Beach, California (Treatment Plant No. 2) operates a Central Power Generation System (CGS) to produce electrical power for the plant operations using five large digester gas-fired internal combustion (IC) engines fueled primarily by digester gas (a biogas) and supplemented by small amounts of natural gas. The process description and equipment tested are described below.

4.1 **Process Description**

Resource Recovery System No. 5 consists of Engine No. 5 (CG5-HB), which is fired on a mixture of digester gas and natural gas, driving a 3000 kW electrical generator, with an exhaust Heat Recovery Steam Generator (HRSG) rated at 6,010,200 Btu/hr capacity. An extractive continuous emissions monitoring system (CEMS) monitors the engine exhaust.

4.1.1 Facility Continuous Emission Monitoring System, CEMS

The CEMS is used to monitor stack gas concentrations for oxides of nitrogen (NO_X), carbon monoxide (CO) and oxygen (O_2). A continuous gas sample is extracted from the stack through a stainless steel probe, transported via a heated sample line to a conditioning system and analyzed by various parameter-specific analyzers. The CEMS includes the following analyzers:

Source	Parameter	Manufacturer	Model Number	Method of Detection	Analytical Range
ICE No. 5	NOx ppmv	Thermo	42i-LS	Chemiluminescent	0-100 ppm
(CG5-HB)	O ₂ %	Thermo	42i-LS	Paramagnetic	0-25%
	CO ppmv	Thermo	48i	Gas Filter Correlation	0-1000 ppm

TABLE 4-1. FACILITY CEMS UNIT ANALYZERS

The CEMS utilizes an electronic data acquisition system (DAS) to monitor, record and report emissions data. The CEMS operation, including periodic calibration checks, is controlled electronically.

4.2 Equipment Description

The CEMS is installed on a Cooper Bessemer Model No. LSVB-16-SGC internal combustion engine, Engine No. 5, which is a four-stroke, 4166 HP, turbocharged, spark-ignited unit, utilizing pre-combustion chambers to minimize NOx emissions. The engine is directly coupled to a synchronous generator rated at 3000 kW.

A schematic of the Treatment Plant No. 2 Resource Recovery System is shown in Figure 4-1.






Figure 4-1. Treatment Plant No. 2 – Process Diagram



4.3 Operating Conditions During Test

During RATA testing, the engine was operated at normal load while burning primarily digester gas fuel and supplemented with natural gas. The following operating parameters were observed during the test period. Supporting documentation of process conditions during the testing can be found in Appendix F.

Average Engine Operating Parameters During Testing					
Engine Load	83.4	%			
Natural Gas Usage	14.9	dscf/min			
Digester Gas Usage	740.0	dscf/min			

4.4 Sampling Locations


The reference method sampling locations are located on the exhaust stack. A schematic of the stack with sampling locations is shown in Figure 4-2. The reference method sampling locations meet the following specifications:

Sampling Location Configuration for Reference Method CEMS Probe:				
Upstream	135 in. (4.5 duct diameters)			
Downstream	54 in. (1.8 duct diameters)			
Port Length	5.5 in. (measured from outside wall)			
Port Inside Diameter	4 in.			
Number of Sampling ports	2 (located at 90° intervals)			
Stack Diameter	30 in. (internal diameter)			

The sampling location complies with the requirements of SCAQMD Method 1.1.



Figure 4-2. Stack Schematic





5.0 SAMPLING AND ANALYTICAL PROCEDURES

Test measurements were performed according to sampling and analysis procedures promulgated by the South Coast Air Quality Management District (SCAQMD), California Air Resources Board (CARB), or US Environmental Protection Agency (EPA). The sampling and analysis procedures used for this test program are summarized below. Any modifications or deviations not addressed herein are discussed in Section 3 of this report.

- 5.1 SCAQMD Methods 1.1-4.1 Determination of Stack Gas Volumetric Flow Rate, Molecular Weight, and Moisture Content
- 5.1.1 SCAQMD Method 1.1 Sampling Traverse Points
- 5.1.2 SCAQMD Method 2.1 Stack Gas Flow Rate
- 5.1.3 SCAQMD Method 3.1 Stack Gas Molecular Weight
- 5.1.4 SCAQMD Method 4.1 Stack Gas Moisture Content
- 5.2 SCAQMD Method 100.1 Continuous Monitoring of Gaseous Emissions, CEMS

5.1 SCAQMD Methods 1.1-4.1 – Determination of Stack Gas Volumetric Flow Rate, Molecular Weight, and Moisture Content

The flue gas flow characteristics (i.e. flow rate, molecular weight, and moisture content) were determined according to SCAQMD Methods 1.1 through 4.1. The testing was conducted as follows:

5.1.1 SAMPLING AND VELOCITY TRAVERSE POINTS

The number and location of traverse points are determined according to SCAQMD Method 1 based on the physical dimensions of the sampling location and process parameters. In principle, the stack cross-section is divided into equal areas, each of which is represented by a "traverse point". Generally, the number of traverse points diminishes as the flow profile at the sampling location becomes uniform. In most cases, the maximum number of sampling points is 24 for particulate testing and 16 for velocity traverses. Fewer traverse points are permitted as described in the method.

5.1.2 STACK GAS VELOCITY AND FLOW RATE

The velocity and volumetric flow rate of the stack gas was determined according to SCAQMD Method 2. In this method, the velocity head (differential pressure) and temperature are measured at the required traverse points. The stack gas differential pressure head was determined using an "S" type pitot tube and electronic micromanometer. The temperature was measured using a type "K" thermocouple and digital temperature readout.

Prior to testing, the measurement system was set-up and leak-checked. Then the velocity head and temperature are recorded at predetermined traverse points. After the last traverse was completed, the system was again leak-checked. After completion of the traverse, the static



pressure in the stack was determined in the centroid of the stack. The stack gas velocity was calculated using the velocity head, and stack gas temperature, pressure and molecular weight.

QA/QC for the method included field performance checks, and periodic calibrations of test equipment including the pitot tube, differential pressure gauge, thermocouple (Tc) and Tc-readout.

5.1.3 STACK GAS MOLECULAR WEIGHT

The stack gas molecular weight (MW) was calculated based on the fraction of its major constituents including: oxygen (O₂), carbon dioxide, (CO₂), nitrogen (N₂), carbon monoxide (CO), and water (H₂O). The dry MW was calculated based on the partial fractions of O₂, CO₂, N₂, and CO. Specifically, the O₂ and CO₂ fractions were determined by CEMS, integrated sampling, or grab sampling, and the balance was assumed to be N₂ and CO. The wet MW was calculated based on the fractions of dry gas and water vapor. The dry and wet MW were calculated according to the following equations:

```
MW_{DRY} = 0.32 \times \%O_2 + 0.44 \times \%CO_2 + 0.28 \times (\%N_2 + \%CO)
          MW_{WET} = 0.18 \text{ x } \%H_2O + MW_{DRY} \text{ x } (1 - \%H_2O/100)
where:
         MW<sub>DRY</sub> = stack gas molecular weight, dry-basis
          MW<sub>WET</sub> = stack gas molecular weight, wet-basis
          0.32
                     = molecular weight fraction for O<sub>2</sub>
          0.44
                     = molecular weight fraction for CO<sub>2</sub>
          0.28
                     = molecular weight fraction for N<sub>2</sub> and CO
          0.18
                     = molecular weight fraction for H_2O (water vapor)
          %X
                     = fraction of X in stack gas, dry basis, where X = O_2, CO_2, N_2, CO_3
          \%H_2O
                     = fraction of water vapor in stack gas, wet-basis
```

5.1.4 SCAQMD METHOD 4.1- STACK GAS MOISTURE CONTENT

The stack gas moisture content was determined according to SCAQMD Method 4.1. In this method, water vapor is collected in a condenser while the dry stack gas volume is measured using a dry gas meter. The volume of water vapor was calculated from the amount of water condensed and the total gas volume was the sum of water vapor plus dry stack gas. The moisture content was determined as a fraction of the total wet stack gas volume. The following calculations were used.

$$B_{WS} = \frac{V_{W,Std}}{V_{M,Std} + V_{W,Std}}$$



 $V_{W,Std} = K_1 \times V_{H2O}$

 $V_{M,Std} = T_{Std}/P_{Std} x Y_M x V_M x P_M/T_M$

where: B_{WS} = Fraction of water vapor in stack gas

 $V_{W,Std}$ = Volume of water vapor (scf)

 $V_{M,Std}$ = Volume of stack gas sampled (dscf)

 K_1 = Unit volume of water vapor (0.04707 scf @68°F or 0.0464 scf @60°F)

 T_{Std} = Standard Temperature (528°R or 520°R)

 P_{Std} = Standard Pressure, 29.92 in. Hg Y_M = Dry gas meter calibration factor

V_M = Measured volume of stack gas sampled


 P_M = Dry gas meter pressure (in. Hg) T_M = Dry gas meter temperature (°R)

Sampling for moisture content was performed as follows:

Moisture was collected in a sampling train consisting of a probe, TFE line, four impingers in an ice bath, a leak-free pump, a vacuum gauge and a dry gas meter. Figure 5-1 is a schematic of a typical moisture train. Initially, impingers #1 and #2 contain 100 ml of water, impinger #3 was empty, and impinger #4 contains a known amount (approximately 300 g) of desiccant (e.g. Silica Gel). Prior to sampling, a leak check of the sampling train was performed. Then, the sampling probe was inserted into the centroid of the stack, the initial meter readings (volume, temperatures, etc.) are recorded, the sample pump was started and the sampling rate was adjusted to the desired sampling rate (typically 0.75 dry cfm). Sampling was conducted until at least 63 dry cubic feet were collected per 90-minute moisture run (3 RATA runs). After sampling, the final meter readings were recorded and the impinger train was recovered. The change in volume and/or weight of the impinger train components was used to determine the amount of moisture condensed. The volume of water vapor and the corrected volume of dry gas sampled were used to calculate the moisture fraction as described above.



Figure 5-1. Moisture Train





5.2 SCAQMD Method 100.1 - Continuous Monitoring of Gaseous Emissions, CEMS

In this method, gaseous components of the stack gas (e.g. NO_X, SO₂, O₂, CO₂, CO) are measured continuously according to SCAQMD Method 100.1 using Almega's mobile continuous emissions monitoring system (CEMS). Figure 5-2 is a schematic of Almega's CEMS.

The CEMS extracts and conditions a representative stack gas sample and analyzes the gas using one or more analytical instruments. Typical CEMS instrumentation is described in Table 5-1. The extraction and conditioning system consists of a stainless steel heated probe, a short heated TFE sample line, a conditioning system, a TFE-diaphragm pump and a TFE transport (sample) line. The sample conditioning system, consisting of water knockout impingers and/or a thermoelectric condenser, removes moisture before the gas is delivered to the analyzers. Sample flow and delivery are controlled using a flow control panel that includes valves, pressure gauges, and flow meters (rotameters). The flow control panel allows the user to deliver sample gas to any and all instruments. Instrument readings are recorded using a real-time strip chart and an electronic data acquisition system (DAS). Other pertinent data such as calibration gas cylinder numbers and concentrations, test location, dates, times, and operator identification are also recorded on the strip chart and on the field data form.

Sampling included pretest and post-test calibration and bias checks for each sampling run. Raw concentration data were corrected for sampling system bias according to Method 100.1 using the following equation:

$$C_{CORR} = C_{MA} \mathbf{x} \frac{(C_i - BIAS_{ZERO})}{(BIAS_{SPAN} - BIAS_{ZERO})}$$

Where: C_{CORR} = Concentration, corrected for drift and bias

C_i = Average measured concentration (raw value)

BIAS_{ZERO} = Average instrument response during zero bias check

C_{MA} = Certified concentration of applicable span gas

 $BIAS_{SPAN}$ = Average instrument response during span bias check

The following QA/QC activities were performed during testing.

- Prior to testing, each individual analyzer was calibrated (adjusted) by introducing zero, highspan and mid-span gases directly into each analyzer and by making corresponding adjustments.
- Prior to testing, calibration error, linearity and system bias checks were performed on each analyzer. Calibration error and linearity checks were performed by injecting known calibration gases directly to each instrument. System bias checks were performed by injecting calibration gases at the sampling-probe/junction or at the sampling probe tip.



- The system response time for each parameter was determined at the moment when the calibration gas for the bias check reaches 95% of its expected concentration value.
- A leak check was conducted before sampling and periodically thereafter to ensure that no leakage occurs in the entire sampling apparatus. The leak check was performed on the vacuum side by sealing the probe tip and drawing vacuum to above 20 inches of mercury. After the vacuum stabilizes, it should hold constantly at about 20 in Hg with no loss of greater than 1 in Hg for about to 5 minutes. On the pressure side, the pressure gauge indicator should drop to zero and flow to each individual rotameter also should drop to zero to indicate a successful leak check.
- Calibration gases used to span instrumentation conform to EPA Protocol 1. Certificates of analysis for calibration gases are included in the report (See Appendix E2).
- The NO₂-to-NO conversion efficiency (CE) check was performed on the NO_x analyzer according to the procedure specified in Method 100.1. The result of the CE check is included in the report (See Appendix E3).



Figure 5-2. Continuous Emissions Monitoring System






TABLE 5-1. ALMEGA CEMS – GENERAL EQUIPMENT SPECIFICATIONS

ANALYZERS						
Specification	O2	CO2	NOx	CO	SO2	
Manufacturer	Teledyne	Servomex	T-API	Thermo Electron	Western Research	
Model	326RA	1400B	200AH	48C	921	
Analytical Principle	E-Chemical Cell	NDIR	Chemiluminescent	NDIR-GCC	NDUV	
Ranges	%: 0-5, -10, -25	%: 0-5, -10, -20	ppmv: 0-2.5, -10, -25, -50, -100, -250, -1,000	ppmv: 0-20, -50, -100, -200, -500, -1k, x10	ppmv: 0-10, -25, -50, -100, -200, -300	
Accuracy, % of Full Scale	± 1%	± 1%	± 1%	± 1%	+ 0.5%	
Repeatability, % of Full Scale	0.5%	0.5%	0.5%	0.5%	0.5%	
Sensitivity, % of Full Scale	0.5%	0.5%	0.5%	0.5%	<2% of Range	
Zero/Span Drift, % of Full Scale	± 1%, in 24 Hrs	± 1%, in 24 Hrs	± 1%, in 24 Hrs	± 1%, in 24 Hrs	-	
Response Time	3 Seconds	<2 Seconds	1.7 Seconds	<2.0 Seconds	30 seconds	
Linearity, % of Full Scale	< 1%	< 1%	< 1%	< 1%	< 1%	
Output	1V DC, 5V DC	0.1V DC, 1V DC	1V DC, 10V DC	1V DC, 10V DC	0-1V DC	

OTHER CEMS EQUIPMENT

Specification	Sample Co	nditioner	Stripchart	Recorder
System used	<u>Primary</u>	Back-up	System used	<u>Primary</u>
Manufacturer	Almega	Universal	Manufacturer	Yokogawa
Model	(in-house)	Model 1090	Model	Model HR 2400
Principle	Refrigeration	Refrigeration	Pen Response	3 sec.
Max. Inlet Temperature	>700 F	500 F	Input Voltage	user-selectable
Max. Inlet Pressure	50 psi	50 psi	Chart Speed	user-selectable
Max. Flow Rate	10 SCFH	7.0 Lpm	Chart Width	10 inches
Max. Water Concentration	50%	50%	Output	user-selectable
Outlet Dew-Point Temperature	< 37 F	$35 \text{ F} \pm 2 \text{ F}$	No. of Channels	30 user-select. 30 calc'd
Dew-Point Stability		± 0.5 F	Colors	10 color, user-selectable



6.0 QUALITY ASSURANCE AND QUALITY CONTROL

Almega applies stringent quality assurance and quality control (QA/QC) procedures to ensure the validity of measurements for all test methods. The following section discusses general and project-specific QA/QC measures.

6.1 General QA/QC

Almega's QA/QC procedures follow guidelines from the "Quality Assurance Handbook for Air Pollution Measurement Systems," Volume I through III. And, procedures for pretest preparation and calibration of sampling equipment are followed. Standardized written procedures, calculator programs, and computer spreadsheets are used for test planning, pre-survey, equipment checklist, preliminary calculations, testing, data analysis, and reporting. Typical pretest equipment preparation and maintenance include organization of the following equipment prior to testing:

- Mobile RM CEM test van: Check fluids, fuel, mechanical conditions, verify operation of CEM instruments, sample lines and sample conditioner prior to the date of the source test.
- Sampling Equipment: Check meter boxes, pitot tubes, manometers and thermocouples to ensure in good working conditions and in proper calibrations. Pre-clean sampling trains and seal all openings prior to use.

Calibrations are performed in accordance with Chapter III of the SCAQMD Source Test Manual (March 1989). Table 6-1 shows the test equipment calibration schedules. Table 6-2 shows the test equipment maintenance schedules.

6.2 Project-Specific QA/QC

This project included specific QA/QC activities required to validate the test results. These QA/QC activities are based on the test methods discussed in Section 5 and generally acceptable test procedures. Reference Methods used for source testing are promulgated by the South Coast Air Quality Management District (SCAQMD), the California Air Resource Board (CARB), or the US Environmental Protection Agency (EPA). Any deviations from published Methods are approved in advance by the regulatory agency (i.e. SCAQMD), prior to implementation if possible. Project-specific QA/QC activities and results that may impact test results are discussed in Section 3.



TABLE 6-1. TEST EQUIPMENT CALIBRATION SCHEDULE

Equipment	Calibration Period	Standard or Method of Calibration
Thermocouples	6 Months and 2 Months	Mercury Thermometer, three point (ice, boiling water, hot oil)
Dry Gas Meters	6 Months and 2 Months	Critical orifice
Field Barometers	6 Months, Check prior to usage	Mercury Barometer
S-Type Pitot	6 Months Check prior to usage	EPA Method 2, Measure physical configuration. Reshape pitot tips or calibrate if configuration does not meet the limits.
Pressure gauges	6 Months	Five-point calibration against manometer
	2 Months	Three-point check
Temp. Meters	6 Months	Precision Potentiometer
CEM Systems	Bimonthly, or as needed	Specified by Manufacturer



TABLE 6-2. TEST EQUIPMENT MAINTENANCE

Equipment	Check For	Correction	Frequency
CEM Systems	Absence of malfunction, noise, drift, conversion efficiency for NOx analyzer	As required by the manufacture, or depending on performance	Bimonthly
Pumps	Absence of leakage, flow, proper vacuum	Replace parts, inspect, clean	300 hours of usage
Flow Devices	Levelling, zeroing, obstruction, deformation	Clean, replace, or re- calibrate	300 hours of usage
Calibration Gases	Expiration date, tank pressure	Re-certify, order new gases	2 months and prior to field testing
Regulators	Malfunction, Gauge precision	Repair or replace	3 months and prior to field testing
Gas Divider	Malfunction, precision	Repair or replace	Monthly and before field testing
Condensers	Leakage, temperature	Repair or replace	Monthly and before field testing
Heated lines	Leakage, temperature, cleanliness	Repair, replace, clean	Monthly and before field testing



APPENDICES



APPENDIX A

GENERAL CALCULATIONS AND FORMULAE



GENERAL CALCULATIONS

Standard conditions: 29.92 in. Hg, 60 °F

Gas Moisture at standard conditions (scf): $V_{WTR} = K2*V_{COND}$

 $K2 = 0.04707 \ \text{@} 68 \ \text{°F}, 0.0464 \ \text{@} 60 \ \text{°F}$

Sample volume at standard conditions (scf):

Vmstd = K1*Vmacf*Ym*(Pbar+dH/13.6)/(Tm+460)

K1 = 17.64 @ 68 °F, 17.38 @ 60 °F

Percent of water: $\%H_2O = 100*Vmstd/(Vmstd+Vwtr)$

Dry molecular weight: $M_d = (44*\%CO_2+32*\%O_2+28*(\%N_2+\%CO))/100$

Wet molecular weight: $M_w = M_d*(1-\%H_2O/100)+18*(\%H_2O/100)$

Stack gas pressure (In. Hg): $P_{stk} = P_{bar} + P_{sta}/13.6$

Average velocity head: Ave. $dP = {SQRT (dP)}^2$

Stack gas velocity (fps): $V = 85.49 * C_p * SQRT(dP) * SQRT((T_S + 460)/(P_{STK} * M_w))$

Percent of excess air: $\%EXCA = 100*(\%O_2-0.5\%CO)/(0.264(\%N_2-(\%O_2-0.5\%CO)))$

Stack gas flow (dscfm): $Q_{STK} = 60(1-\%H_2O/100)*V*A*(528/(T_s+460))*P_{stk}/29.92$

Concentration at 3% O₂: PPM a 3% O₂ = PPM_{measured}*17.9/(20.9-%O₂)

Emissions lb/MMBtu:

lb/MMBtu = lb/hr /HI (heat input rate in MMBtu/hr)

Emissions lb/hr:

 $lb/hr = PPM*10^{-6}*((MW lb/lb-mole)/SV)*dscfm*60$

MMBtu/hr = facility fuel usage (scfh)*HHV (1050 Btu/scf)* 10⁻⁶

CALCULATIONS FOR METHOD 100.1:

Corrected PPM = $(PPM_{measured}-C_o)*C_{ma}/(C_m-C_o)$

Where: $C_0 = \text{Average of initial and final bias zeros}$

 C_m = Average of initial and final bias calibrations

 C_{ma} = Certified gas value used for the bias calibration.



GENERAL CALCULATIONS – continued

CALCULATIONS FOR METHOD 100.1, continued

Calibration Error= 100*(Certified value-Analyzer response)/Analyzer range

Percent Bias= 100*(Direct Analyzer response-Bias response)/Analyzer range

System Zero/Span Drifts= 100*(Final-Initial)/Analyzer range

Linearity= 100*(Analyzer mid. gas response-Predicted value)/range

Where the Predictive Value for the mid gas is found by a straight line drawn between the span gas and zero gas calibration points which can be calculated from the straight line equation, Y=mx+b where m is the slope of the line and b is the Y-intercept. The calculation is done by a computer spreadsheet for Method 100.1.

DEFINITIONS

A: Stack cross area, square feet

Cp: Pitot coefficient

@H: Orifice pressure, in. H₂O

MW: Molecular weight

Md: Dry molecular weight of flue gas Mw: Wet molecular weight of flue gas Pbar: Barometric pressure, in. Hg

Psta: Static pressure, in. H₂O Pstk: Stack pressure, in. Hg

P: Stack differential pressure, in. H₂O

Qstk: Stack gas flow, scfm
Tm: Meter temperature, °F
Ts: Stack gas temperature, °F

Vcond: Volume of water condensation, ml

Vm: Meter volume, acf

Vmstd: Sample gas at standard conditions, scf

Vwtr: Water vapor volume, scf Ym: Meter correction factor

SV: Specific molar volume, 379.5 dscf/lb-mole at 60°F, or 385.3 dscf/lb-mole at 68°F

FF: Fuel flow rate (scf/hr)

Fd: Dry fuel factor, for natural gas Fd=8710 dscf/MMBtu at 68°F



APPENDIX B APPROVALS AND CERTIFICATIONS



Appendix B1

SCAQMD and **CARB** Testing Approvals



June 10, 2015

Mr. John W. Phillips Almega Environmental 10602 Walker Street Cypress, CA 90630

Subject: LAP Approval Notice

Reference #93LA0827

(909) 396-2000 · www.aqmd.gov

Dear Mr. Phillips:

We completed our review of the renewal application you submitted for approval under the South Coast Air Quality Management District's Laboratory Approval Program (SCAQMD LAP). We are pleased to inform you that your firm is approved for the period beginning June 30, 2015, and ending June 30, 2016 for the following methods, subject to the requirements in the LAP Conditions For Approval Agreement and conditions listed in the attachment to this letter:

SCAQMD Methods 1-4	SCAQMD Method 7.1
SCAQMD Method 10.1	SCAQMD Rule 1121/1146.2 Protocols
SCAQMD Method 100.1	SCAQMD Rule 1420/1420.1 – (Lead) Source Sampling
SCAQMD Method 25.1 (Sampling)	SCAQMD Rule 1420/1420.1 – (Lead) Ambient Sampling
SCAQMD Method 25.1 (Analysis)	SCAQMD Rule 462 Testing
SCAQMD Method 25.3 (Analysis)	ASTM D6522-00/ USEPA CTM-030
SCAOMD Methods 5.1 and 6.1	

Thank you for participating in the SCAQMD LAP. Your cooperation helps us to achieve the goal of the LAP: to maintain high standards of quality in the sampling and analysis of source emissions. You may direct any questions or information to LAP Coordinator, Glenn Kasai. He may be reached by telephone at (909) 396-2271, or via e-mail at gkasai@aqmd.gov.

Sincere

Rudy Eden, Senior Manager Laboratory Services & Source Test Engineering

RE:GK/gk

Dipankar Sarkar

150610 LapRenewal.doc



ATTACHMENT

Conditions For Almega Environmental's LAP Approval

- 1) Almega shall adhere to the following requirements when conducting portable analyzer tests using CTM-030 or ASTM D6522:
 - a) Deviations to CTM-030 or ASTM D6522 shall be documented in the Test Critique section of the test report;
 - b) The test report shall be formatted and organized in a manner consistent with the example portable analyzer test report, dated September 24, 2011, and the District Source Test Manual, Chapter II; and,
 - c) NO₂ measurements may be quantified to 10% of the NO₂ span under the following conditions:
 - Calibrations shall be conducted per Sections 7.3 and 7.6 of CTM-030 at the span, mid-span (40-60% of span), low-span (10% of span), and zero level. The low-span calibration shall satisfy the requirements in Section 4.2 of CTM-030;
 - A linearity check shall be conducted once every five days using the lowspan calibration gas; and,
 - If the measured NO₂ emission is less than 10% of the NO₂ span, it shall be reported as less than 10% of the span, and added to the NO emission to determine the total NOx concentration.

State of California Air Resources Board

Approved Independent Contractor

Almega Environmental & Technical Services

This is to certify that the company isternations been approved by the Air Resource Beara to to the Company of the 17. Section 91207, until June 30, 2016 for those that ineffices, sted below:

ARB Source Test Methods: 1, 2, 3, 4, 5, 8 100 (CO, CO₂, NO_X, O₂, SO₂)

Dr. Michael T. Benjamin, Chief Monitoring and Laboratory Division

State of California Air Resources Board

Approved Independent Contractor

Almega Environmental & Technical Services

This is to certify that the company is tend below has been approved by the Air Resource Board to Ford Compliance testing pursuant to California Code of Regulations. Title 17. Section 91207, until June 30, 2016, for the company is tend below:

Visible Emissions Evaluation

Dr. Michael T. Benjamin, Chief Monitoring and Laboratory Division



Appendix B2

Certification of No Conflict-of-Interest



Certification of No Conflict-of-Interest

Almega Environmental & Technical Services 10602 Walker Street Cypress, CA 90630

I certify that I am responsible for the testing operations of Almega and am authorized to sign this certificate on the Company's behalf.

Almega may conduct tests as an independent tester pursuant to SCAQMD Rule 304(k). I further certify that Almega has no conflict-of-interests, and is not related or owned in any way to the company being tested.

Company being tested:	Orange County Sanitation District
Facility ID No.:	29110
Permit No.:	Permit G27398, A/N 540712
Signature:	at the
Name (printed or typed):	Christopher Lovett
Title:	Project Manager
Date:	10/15/15



Appendix B3

Non-RECLAIM CEMS Final Certification



March 2, 2010 S/T File:C06039 (Final Certification)

Terry Ahn
Orange County Sanitation District
P.O. Box 8127
Fountain Valley, CA 92728-8127

Subject:

Final Certification of Non-RECLAIM CEMS Serving IC Engine Unit 5 CG5-HB (A/N 414657)

Dear Ms. Terry Ahn:

I have completed the evaluation of your certification report (please refer to the accompanying attachments for specific information and conditions). The evaluation was made to determine if final certification could be granted based on the monitoring requirements of the applicable protocols found in <u>District Rules 218 and 218.1</u>, and <u>EPA 40CFR60 APPENDICES B and F.</u>

This letter serves as an official notification of final certification for the CEMS at your facility serving the process equipment described in the accompanying attachment, "DISTRICT RULE 218-EPA 40CFR60 APPENDICES B and F, NON-RECLAIM CEMS FINAL CERTIFICATION: Specific Device-Based Information and Conditions". If the CEMS information in the accompanying attachments is not accurate, please notify me as soon as possible at (909) 396-2265. Also, please remember to notify the District for direction, prior to replacement or modification of the described CEMS or the device(s) that it serves, since such modifications may change the compliance status of the affected CEMS. Again, thank you for your continued cooperation and support.

Sincerely,

P. Eric Padilla, Air Quality Engineer Source Test Engineering Branch (909) 396-2265 FAX (909) 396-2099 epadilla@aqmd.gov@aqmd.gov

Attachment MG:EP

cc: Rudy Eden Mike Garibay

840CEMS_Cert - OCSD Plant 2 Unit 5 - C06039.doc



South Coast Air Quality Management District



21865 Copley Drive, Diamond Bar, CA 91765-4178 (909) 396-2000 • www.aqmd.gov

Source Test I.D:

C06039

Date:

March 2, 2010

Facility I.D:

029110

Application/Permit No.:

414657

CEMS Certification Date:

CEMS Rule/Regulation:

Permit Condition 13

July 16, 2009

DISTRICT RULE 218 - EPA 40CFR60 APPENDICES B & F NON-RECLAIM CEMS FINAL CERTIFICATION:

Specific Device-Based Information and Conditions

(This document must be displayed on or near strip chart recorder or data handling system)

Name of Facility:

Orange County Sanitation District

Certification Test Date:

July 16, 2009

Test Operating Load: Equipment Description:

Mid Operating Load (> 50% capacity)

IC Engine Unit 5 - 4166 HP, 3000 kW Generator

Equipment Location:

Reclamation Plant 2, 22212 Brookhurst St,

Huntington Beach, CA 92646

Mailing Address:

P.O. Box 8127 Fountain Valley, CA 92728-8127

A. The components described below comprise the "CEMS" which has been granted Final Certification or Approval and they may not be changed or modified without prior District approval. (Unauthorized modification to the components shown below may void CEMS certification, and result in non-compliance with District Rule 218, EPA 40CFR60 APPENDIX B, and/or source specific rules pertaining to CEMS monitoring and recordkeeping. Be sure the information below is correct. Contact your District Source Testing representative if there are any questions):

Gaseous Emission Measurement Analyzer:

Gaseous Component Monitored	Make	Model No.	Serial No.	Method of Detection	Certified Range(s): Instrument Range (Valid Reporting Range ¹)
CO (Dry)	Thermo	48i	09010029	Gas Filter Correlation (GFC)	0-1000 ppm
NOx/O ₂ (Dry)	Thermo	42i-LS	0910435617	NOx: Chemiluminescence O ₂ : Paramagnetic	NOx: 0-100 ppm O ₂ : 0-25%

¹ The valid reporting range of a certified CEMS is normally 10-95% of the certified instrument range or ranges, unless additional QA testing is

Facility I.D.:

029110

Identification:

CG5-HB 414657

Source Test I.D.: C06039



Fuel or Flue Gas Flow Measurement Analyzer

Instrument Type	Manufacturer	Model No.	Serial No.
Natural Gas: Positive Displacement Meter	Dresser Roots	11M175 (Range 0 – 11,000 cfh)	NA – renewed annually for calibration purposes
Digester Gas: Positive Displacement Meter	Dresser Roots	16M175 (Range 0 – 16,000 cfh)	NA – renewed annually for calibration purposes

Page 2

Sample Condition and Calibration System

Туре	Manufacturer	Model No.	Serial No.
Gas Sample Conditioning Unit	M&C	ECM-2G	NA .

Supporting Equipment (Data Acquisition, Reduction, and Recording) Excluding RTU

		3/	
Туре	Manufacturer	Model No.	Serial No.
DAS	Dell		NA .
PLC	Modicon	M340	NA

DAHS, PLC Programming Formulas and Correction Factors

Parameter	Formula
NOx Concentration	Uncorrected, and standard correction to 15% O ₂ for concentration compliance requirement (no additional factors, BAFs or constants are authorized).
CO Concentration	Uncorrected, and std. correction to 15% O ₂ for concentration compliance requirement (no additional factors, BAFs or constants are authorized).
Stack Flow Rate	Based on fuel usage & standard fuel F-Factor calculation using default HHV of 1050 Btu/scf and Fd $_{\rm O2}$ of 8710 dscf/mmBtu for natural gas and using analysis results for digester gas (no additional factors, BAFs or constants are authorized).
NOx Emission Rate	Based on the product of uncorrected concentration and stack flow rate as described above (no additional factors, BAFs or constants are authorized).

Facility I.D.:

029110

Identification:

CG5-HB 414657

Source Test I.D.: C06039

CG3-11D 41403



B. The CEMS described above is subject to the following conditions:

1. CEMS Operating Range

The operating range(s) selected for each gas analyzer must be such that most all measurements fall within 10-95%² of range full-scale. With time, these ranges may not prove adequate and the analyzer(s) must be re-ranged, or more-than-one range must be used to maintain compliance. Always consult your AQMD CEMS Engineer before modifying the process monitored and/or the CEMS itself.

Page 3

2. CEMS Specific Operating Requirements

This CEMS shall be operated pursuant to the requirements of District Rules 218/218.1 and/or 40CFR60 Appendices B & F, and be subject to the following specific monitoring, reporting, and recordkeeping requirements:

PERMIT CONDITION 13:

- Monitor/record/report raw NOx concentration (ppm)
- Monitor/record/report raw O₂ concentration (%)
- Calculate/record/report NOx concentration (ppm), corrected to 15% O2
- Calculate/record/report exceedances in the permitted limit of: 36 ppmv for NOx or 2000 ppmv for CO, both corrected to 15% O₂

The Data Acquisition & Handling System/Programmable Logic Controller (DAHS/PLC) shall perform the calculations necessary to meet the above emission reporting requirements, using accepted methods.

3. Periodic Testing, Record Keeping, Quality Assurance, and Reporting

Orange County Sanitation District has elected to maintain this CEMS according to EPA 40CFR60 APPENDICES B & F. This includes periodic testing³, quality assurance, reporting, and recordkeeping. Designated personnel at Orange County Sanitation District shall be instructed and be responsible regarding periodic testing dates and requirements, scheduled and unscheduled breakdown and outage procedures, and CEMS and process modifications. A comprehensive Quality Assurance Plan describing the above procedures and other contingencies as described in EPA 40CFR60 APPENDIX F, must be compiled and stored on-site for review by authorized AQMD personnel. This Quality Assurance Plan must be regularly updated with CEMS, process, and responsibility changes.

4. On-Site Data Availability

Orange County Sanitation District understands that CEMS emission measurements shall be available in realtime display and as a continuous record, on-site, upon request by authorized

² There are circumstances where analyzer measurements less than 10% of full-scale are acceptable. See your assigned Source Testing Engineer for details.

Units must be tested annually at a minimum, or sooner if modifications to process and/or CEMS are performed, or as prescribed by the AQMD.

Facility I.D.:

029110

Identification:

CG5-HB 414657

Source Test I.D.: C06039



Dated: March 2, 2010

AQMD personnel. This also includes raw data and calculations used for realtime displays and records.

Page 4

5. RATA Protocol

Orange County Sanitation District shall submit a periodic CEMS assessment/RATA protocol for approval if the RATA procedures differ from the previously approved CEMS certification test protocol.

6. Notification of RATA Schedule

Orange County Sanitation District shall notify the District at least two weeks prior to conducting all subsequent periodic CEMS assessments/RATAs. Notification is to be made to Eric Padilla, either by phone at 909-296-2265, or via e-mail at epadilla@aqmd.gov.

7. Quality Assurance Program (QAP)

The QAP shall automatically be updated as needed (e.g., as personnel are reassigned, or the process and/or the CEMS components are modified).

Evaluated By:

P. Eric Padilla, Air Quality Engineer

Source Test Engineering Branch (909) 396-2265 FAX (909) 396-2099

epadilla@aqmd.gov@aqmd.gov

840CEMS_Cert - OCSD Plant 2 Unit 5 - C06039.doc



APPENDIX C SCAQMD METHOD 1.1-4.1 – STACK GAS FLOW RATE



Appendix C1

STACK GAS FLOW RATE – Results and Calculations

STACK GAS MOISTURE AND FLOW RATE CALCULATIONS

Facility: OCSD, Plant No. 2 City: Huntington Beach, CA Source: Engine 5 Test: RATA Test Date:

10/1/15

DATA ENTRY	Symbols	Units	RUN 1.0	RUN 2.0	RUN 3.0	RUN 4.0	RUN 5.0	RUN 6.0	RUN 7.0	RUN 8.0	RUN 9.0		
Stack Diameter	D	in.	30	30	30	30	30	30	30	30	30	T i	
Length	L	in.		0	0	0	0	0	0	0	0		
Width	W	in.		0	0	0	0	0	0	0	0	1	
Barometric Pressure	Pbar	in. Hg.	29.91	29.91	29.91	29.91	29.91	29.91	29.91	29.91	29.91		
Static Pressure	Ps	in. H2O	-0.25	-0.25	-0.25	-0.25	-0.25	-0.25	-0.25	-0.25	-0.25		
Pitot Coefficient	Ср	none	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84		
Meter Cal. Factor	Y	none	0.9871	0.9871	0.9871	0.9871	0.9871	0.9871	0.9871	0.9871	0.9871		
Standard Temperature	Tstd	deg. F	60	60	60	60	60	60	60	60	60		
Moisture Factor	KI	cu.ft./mL	.0464	.0464	.0464	.0464	.0464	.0464	.0464	.0464	.0464	1	
PT Factor	K2	R/in.Hg	17.38	17.38	17.38	17.38	17.38	17.38	17.38	17.38	17.38		
Velocity Head (dP)	(dP)	(in. H2O)	0.811	0.821	0.825	0.833	0.831	0.831	0.809	0.819	0.823	1	
Velocity Head (Sqrt dP)	Sqrt (dP)	Sqrt(in. H2O)	0.899	0.905	0.907	0.912	0.911	0.911	0.899	0.905	0.907	1	
Average Delta H	dH	in. H2O	2.000	2.000	2.000	2.000	2.000	2.000	2.000	2.000	2.000	1	
Gas Volume Collected	Vm	cf	68.105	68.105	68.105	68.144	68.144	68.144	68.117	68.117	68.117	1	
Stack Gas Temperature	Ts	deg. F	539.8	540.4	540.3	541.0	541.3	540.6	541.3	541.4	540.9	1	
Meter Temperature	Tm	deg. F	82.2	82.2	82.2	85.4	85.4	85.4	89.1	89.1	89.1	1	
%O2 in Stack Gas	%O2	%	11.78	11.78	11.86	11.80	11.83	11.90	11.75	11.83	11.81	1	
%CO2 in Stack Gas	%CO2	%	7.58	7.69	7.66	7.18	7.19	7.14	7.34	7.30	7.31		
Total Impinger Water	Ww	g	160.9	160.9	160.9	143.9	143.9	143.9	161.9	161.9	161.9		
CALCULATIONS	Symbols	Units	RUN 1.0	RUN 2.0	RUN 3.0	RUN 4.0	RUN 5.0	RUN 6.0	RUN 7.0	RUN 8.0	RUN 9.0		
Stack Area	As	sq. ft.	4.91	4.91	4.91	4.91	4.91	4.91	4.91	4.91	4.91		
Stack Gas Temperature	Ts,r	deg. R	1000	1000	1000	1001	1001	1001	1001	1001	1001		
Meter Temperature	Tm,r	deg. R	542	542	542	545	545	545	549	549	549		
Abs Stk Pressure	Pabs	in, Hg,	29.89	29.89	29.89	29.89	29.89	29.89	29.89	29.89	29.89	1	
Gas Vol. @ STD	Vmstd	dscf	64.77	64.77	64.77	64.43	64.43	64.43	63.97	63.97	63.97		
Vol. of Water Vapor	Vwstd	dscf	7.47	7.47	7.47	6.68	6.68	6.68	7.51	7.51	7.51		
Dry Mol. Wt.	Md	lb/lb-mol.	29.68	29.70	29.70	29.62	29.62	29.62	29.64	29.64	29.64		
Wet Mol. Wt.	Ms	lb/lb-mol.	28.48	28.49	28.49	28.53	28.53	28.53	28.42	28.42	28.42		
Average Velocity	Vs	ft/s	70.00	70.42	70.61	70.95	70.91	70.86	70.10	70.55	70.66	- 1	
Moisture Content	Bws	%	10.34	10.34	10.34	9.39	9.39	9.39	10.51	10.51	10.51		
Actual Stack Gas Flow Rate	Qa	acfin	20,618	20,741	20,795	20,896	20,885	20,870	20,647	20,778	20,813		
Dry Stack Gas Flow Rate	Qds	dscfm	9,606	9,658	9,685	9,827	9,819	9,818	9,587	9,646	9,667		
Dry Stack Gas Flow Rate	Qds	dscfh	576,377	579,502	581,080	589,604	589,123	589,078	575,211	578,771	580,031		
Wet Stack Gas Flow Rate	Qws	wscfm	10,714	10,772	10,801	10,845	10,836	10,835	10,713	10,779	10,802		
CALCULATIONS								104-					
Abs Stk Pressure	Pabs	Pabs=Pbar +(Ps	5/13.6)				Average Velocity			Vs	Vs = 85.49Cp Sqr	t(dp)[Sqrt(Ts,r/(Pabs Ms))]
Gas Vol. @ STD	Vmstd	Vmstd=17.64V	mY[Pbar+dH/13	6)]/Tm			Moisture Content				Bws = 100 Vwstd		
Vol. of Water Vapor	Vwstd	Vwstd=0.04707				1	Actual Stack Gas	Flow Rate			Qa = 60 Vs As	(
Dry Mol. Wt.	Md			100-(%CO2+%O	2)]		Dry Stack Gas Flo				Qds=17.64 Qa[1-(Bws/100)](Pabs	(Ts.r)
Wet Mol. Wt.	Ms		s/100)]+18(Bws/				Wet Stack Gas Flo				Qws= Qds(dscfm)		



STACK GAS MOISTURE AND FLOW RATE CALCULATIONS

Facility: OCSD, Plant No. 2 City: Huntington Beach, CA

ı		RU	N 1.0	
Point	dP (in. H2O)	Ts (deg F)	SQRT (dP)	Qds (dscfm)
Avg	0.811	539.8	.8995	9,606
1	0.87	531	.9327	10,006
2	0.87	540	.9327	9,960
2 3 4	0.92	542	.9592	10,232
4	0.79	543	.8888	9,477
5	0.76	542	.8718	9,300
5	0.71	541	.8426	8,994
7	0.80	540	.8944	9,551
8	0.74	539	.8602	9,191
9	0.87	532	.9327	10,000
10	0.89	540	.9434	10,074
11	0.94	541	.9695	10,348
12	0.78	543	.8832	9,417
13	0.76	542	.8718	9,300
14	0.74	541	.8602	9.182
15	0.82	541	.9055	9,665
16	0.71	539	.8426	9,003
17				
18				
19				
20			1	
21				
22				
23				
24				
25				

Г	Orifice	Meter T	emp.	DGM	Moist. Collect.	1
- 1	dH	Inlet	Outlet	Volume		
	2.00	Avg:	82.2	68.105	160.9	Net:
10	2.00	83	80	981.835	745.0	Initial
20	2.00	83	80	1049.940	867.2	Final
30	2.00	84	80		685.3	Initial
40	2.00	84	80	- 1	700.4	Final
50	2.00	84	18		606.8	Initial
60	2.00	84	81		613.0	Final
70	2.00	84	81		804.5	Initial
80	2.00	84	81		821.9	Final
90	2.00	85	81			

Source: Engine 5 Test: RATA

dP (in. H2O)	Ts (deg F)	SQRT (dP)	Qds (dscfm)
0.821	540.4	.9048	9,658
0.88	531	.9381	10,060
0.89	540	.9434	10,071
0.94	541	.9695	10,345
0.81	543	.9000	9,594
0.76	542	.8718	9,298
0.72	542	.8485	9,050
0.81	541	.9000	9,603
0.72	540	.8485	9,059
0.89	533	.9434	10,107
0.91	541	.9539	10,179
0.96	542	.9798	10,450
0.76	544	.8718	9,288
0.76	543	.8718	9,293
0.75	542	.8660	9,236
0.84	541	.9165	9,780
0.73	540	.8544	9,121

1	Moist.	DGM	emp.	Meter T	Orifice	
	Collect.	Volume	Outlet	Inlet	dH	
Net:	160.9	68.105	82.2	Avg:	2.00	
Initi	745.0	981.835	80	83	2.00	
Fina	867.2	1049.940	80	83	2.00	
Initi	685.3		80	84	2.00	
Fina	700.4	- 1	80	84	2.00	
Initia	606.8		81	84	2.00	
Fina	613.0	- 1	81	84	2.00	
Initia	804.5		81	84	2.00	
Fina	821.9		81	84	2.00	
_			81	85	2.00	

Test Date: 10/1/15

	RUI	N 3.0	
dP (in. H2O)	Ts (deg F)	SQRT (dP)	Qds (dscfin)
0.825	540.3	.9072	9,685
0.92	532	.9592	10,281
0.91	540	.9539	10,184
0.93	541	.9644	10,290
0.82	543	.9055	9,653
0.78	542	.8832	9,419
0.70	542	.8367	8,923
0.81	541	.9000	9,604
0.69	539	.8307	8,873
0.89	533	.9434	10,107
0.90	541	.9487	10,123
0.95	542	.9747	10,395
0.79	544	.8888	9,470
0.78	543	.8832	9,415
0.76	541	.8718	9,303
0.82	541	.9055	9,663
0.75	539	.8660	9,250

Orifice	Meter 7	Temp.	DGM	Moist.	1	
dH	Inlet	Outlet	Volume	Collect.		
2.00	Avg:	82.2	68.105	160.9	Net:	
2.00	83	80	981.835	745.0	Initial	
2.00	83	80	1049.940	867.2	Final	
2.00	84	80		685.3	Initial	
2.00	84	80	- 1	700.4	Final	
2.00	84	81		606.8	Initial	
2.00	84	81		613.0	Final	
2.00	84	81		804.5	Initial	
2.00	84	81		821.9	Final	
2.00	85	81				



18 19

STACK GAS MOISTURE AND FLOW RATE CALCULATIONS

Facility: OCSD, Plant No. 2 City: Huntington Beach, CA

- [RUN 4.0						
Point	dP (in. H2O)	Ts (deg F)	SQRT (dP)	Qds (dscfm)			
Avg	0.833	541.0	.9119	9,827			
1	0.84	533	.9165	9,916			
2	0.88	541	.9381	10,109			
3	0.94	542	.9695	10,442			
4	0.86	544	.9274	9,978			
5	0.82	543	.9055	9,748			
6	0.75	542	.8660	9,328			
7	0.81	541	.9000	9,698			
8	0.79	541	.8888	9,578			
9	0.84	533	.9165	9,916			
10	0.86	541	.9274	9,993			
11	0.93	543	.9644	10,382			
12	0.88	544	.9381	10,094			
13	0.81	543	.9000	9,689			
14	0.78	542	.8832	9,512			
15	0.77	542	.8775	9,451			
16	0.76	541	.8718	9,394			
17							

Γ	Orifice	Meter 7		DGM	Moist.
L	dH	Inlet	Outlet	Volume	Collect.
	2.00	Avg:	85.4	68.144	143.9 N
0	2.00	86	83	50.644	766.2 I
0	2.00	87	83	118.788	887.6 F
0	2.00	87	83		700.4 I
0	2.00	87	84		710.9 F
0	2.00	87	84		613.0 I
0	2.00	87	84		615.1 F
0	2.00	87	84		821.9 In
30	2.00	88	84		831.8 F
0	2.00	88	84		

Source: Engine 5 Test: RATA

dP (in, H2O)	Ts (deg F)	SQRT (dP)	Qds (dscfm)
0.831	541.3	.9113	9,819
0.84	532	.9165	9,920
0.89	541	.9434	10,165
0.89	543	.9434	10,155
0.88	545	.9381	10,088
0.77	543	.8775	9,446
0.80	542	.8944	9,633
0.82	542	.9055	9,753
0.81	541	.9000	9,698
0.83	534	.9110	9,851
0.88	542	.9381	10,103
0.92	544	.9592	10,320
0.86	544	.9274	9,978
0.80	543	.8944	9,628
0.76	542	.8718	9,389
0.78	542	.8832	9,512
0.77	540	.8775	9,460

1	Moist.	DGM	Meter Temp.		Orifice
	Collect.	Volume	Outlet	Inlet	dH
Net:	143.9	68.144	85.4	Avg:	2.00
Initia	766.2	50.644	83	86	2.00
Final	887.6	118.788	83	87	2.00
Initia	700.4		83	87	2.00
Final	710.9		84	87	2.00
Initia	613.0		84	87	2.00
Final	615.1		84	87	2.00
Initia	821.9		84	87	2.00
Final	831.8		84	88	2.00
			84	88	2.00

Test Date: 10/1/15

RUN 6.0						
dP (in. H2O)	Ts (deg F)	SQRT (dP)	Qds (dscfm)			
0.831	540.6	.9109	9,818			
0.83	532	.9110	9,862			
0.89	541	.9434	10,166			
0.91	542	.9539	10,275			
0.89	543	.9434	10,156			
0.78	542	.8832	9,513			
0.78	541	.8832	9,517			
0.80	540	.8944	9,643			
0.81	540	.9000	9,704			
0.82	533	.9055	9,798			
0.86	541	.9274	9,994			
0.94	542	.9695	10,443			
0.87	544	.9327	10,036			
0.81	543	.9000	9,689			
0.79	543	.8888	9,569			
0.75	542	.8660	9,328			
0.76	541	.8718	9,395			

Ī	Orifice	Meter Temp.		DGM	Moist.	
	dH	Inlet	Outlet	Volume	Collect.	
	2.00	Avg:	85.4	68.144	143.9	Net:
Ī	2.00	86	83	50.644	766.2	Initial
	2.00	87	83	118.738	887.6	Final
	2.00	87	83		700.4	Initial
	2.00	87	84		710.9	Final
	2.00	87	84		613.0	Initial
	2.00	87	84	- 1	615.1	Final
	2.00	87	84		821.9	Initial
	2.00	88	84		831.8	Final
ì	2.00	88	84			



STACK GAS MOISTURE AND FLOW RATE CALCULATIONS

Facility: OCSD, Plant No. 2 City: Huntington Beach, CA

- 1	RUN 7.0							
oint	dP (in. H2O)	Ts (deg F)	SQRT (dP)	Qds (dscfm)				
Avg	0.809	541.3	.8992	9,587				
1	0.82	534	.9055	9,690				
2	0.82	541	.9055	9,656				
2 3	0.88	543	.9381	9,993				
4	0.75	545	.8660	9,216				
5	0.75	543	.8660	9,225				
6	0.75	543	.8660	9,225				
7	0.79	542	.8888	9,473				
8	0.79	542	.8888	9,473				
9	0.84	533	.9165	9,812				
10	0.84	541	.9165	9,773				
11	0.93	542	.9644	10,278				
12	0.88	544	.9381	9,988				
13	0.81	543	.9000	9,587				
14	0.78	542	.8832	9,413				
15	0.77	542	.8775	9,352				
16	0.75	541	.8660	9,235				
17								
18								
19								
20								
21								
22								

- 1	RUN 7.0							
oint	dP (in. H2O)	Ts (deg F)	SQRT (dP)	Qds (dscfm)				
vg	0.809	541.3	.8992	9,587				
1	0.82	534	.9055	9,690				
2	0.82	541	.9055	9,656				
2 3	0.88	543	.9381	9,993				
4	0.75	545	.8660	9,216				
5	0.75	543	.8660	9,225				
6	0.75	543	.8660	9,225				
7	0.79	542	.8888	9.473				
8	0.79	542	.8888	9,473				
9	0.84	533	.9165	9,812				
10	0.84	541	.9165	9,773				
11	0.93	542	.9644	10,278				
12	0.88	544	.9381	9,988				
13	0.81	543	.9000	9,587				
14	0.78	542	.8832	9,413				
15	0.77	542	.8775	9,352				
16	0.75	541	.8660	9,235				
17 18 19 20								
21 22 23								
24								

Г	Orifice	Prifice Meter Temp.		DGM	Moist.	
- 1	dH	Inlet	Outlet	Volume	Collect.	
- 1	2.00	Avg:	89.1	68.117	161.9	Net:
10	2.00	90	87	119.020	782.5	Initial
20	2.00	90	87	187.137	912.3	Final
30	2.00	90	87		710.9	Initial
40	2.00	91	87		723.6	Final
50	2.00	91	88		615.1	Initial
60	2.00	91	88		619.5	Final
70	2.00	91	88		765.0	Initial
80	2.00	91	88		780.0	Final
00	2.00	0.1	0.0			-

Source: Engine 5 Test: RATA

	RUI	V 8.0	
dP (in. H2O)	Ts (deg F)	SQRT (dP)	Qds (dscfin)
0.819	541.4	.9048	9,646
0.86	533	.9274	9,929
0.83	541	.9110	9,715
0.89	542	.9434	10,055
0.75	544	.8660	9,221
0.76	544	.8718	9,282
0.76	542	.8718	9,292
0.80	542	.8944	9,533
0.79	541	.8888	9,478
0.85	534	.9220	9,866
0.86	542	.9274	9,884
0.92	544	.9592	10,213
0.88	545	.9381	9,983
0.81	543	.9000	9,588
0.79	543	.8888	9,469
0.78	542	.8832	9,413
0.78	541	.8832	9,418

Orifice	Meter T	Temp.	DGM	Moist.
dH	Inlet	Outlet	Volume	Collect.
2.00	Avg:	89.1	68.117	161.9
2.00	90	87	119.020	782.5
2.00	90	87	187.137	912.3
2.00	90	87		710.9
2.00	91	87		723.6
2.00	91	88		615.1
2.00	91	88		619.5
2.00	91	88		765.0
2.00	91	88		780.0
2.00	91	88		

Test Date: 10/01/15

	RUN	V 9.0	
dP (in. H2O)	Ts (deg F)	SQRT (dP)	Qds (dscfm)
0.823	540.9	.9065	9,667
0.87	533	.9327	9,986
0.84	541	.9165	9,773
0.89	543	.9434	10,050
0.73	544	.8544	9,097
0.76	543	.8718	9,287
0.77	542	.8775	9,352
0.82	540	.9055	9,661
0.79	540	.8888	9,483
0.84	533	.9165	9,813
0.87	542	.9327	9,941
0.91	542	.9539	10,167
0.86	544	.9274	9,874
0.82	543	.9055	9,647
0.81	542	.9000	9,592
0.79	542	.8888	9,473
0.79	541	.8888	9,478

Orifice		Meter Temp.		DGM	Moist.	ĺ
	dH	Inlet	Outlet	Volume	Collect.	
	2.00	Avg:	89.1	68.117	161.9	Net:
Т	2.00	90	87	119.020	782.5	Initial
	2.00	90	87	187.137	912.3	Final
	2.00	90	87		710.9	Initial
	2.00	91	87		723.6	Final
	2.00	91	88		615.1	Initial
	2.00	91	88		619.5	Final
	2.00	91	88		765.0	Initial
	2.00	91	88		780.0	Final
	2.00	91	88			






Appendix C2 STACK GAS FLOW RATE – Field Data



SAMPLING AND VELOCITY TRAVERSE POINT DETERMINATION SCAQMD METHOD 1.2



DRAWING NOT TO SCALE



SCAQMD METHODS 2-4



LNATEONMENTAL	SCAQIVID	IVIL TITODO Z-4	
Run#: 1,213	Pitot ID: STYPE	Impinger Initial Final Net	Pitot Leak Check
Date: 16/1/15	Pitot Coeff.: _84	Water 1: 7450 867.2	Initial:
Client: OCSD	Meter Box #: 002	Water 2: 685-3 780.4	Final:
Unit: ENGINES	Meter @ Dh : 1-987	Blank: 66.8 613.0	
Operator: L. Barrow	Meter Y: 9871	Sil. Gel: 804.57821.9	Meter Box Leak Check
Stack Dia: 300	TC#: 83	H2O Gain =	Rate "HG
Amb. Press: 29.91	Start Time: 7:43	Pressure Type/Range	Initial: (200) 22
Static Press :	Stop Time : 9:13	ADM SEOU -	Final: -600 22"

							Sample	Port 1:		Port 2 :			
Time (Minute)	Meter Volume (acf)	Pump Vac (inch Hg)	Meter Ter Inlet (F)	outlet (F)	Set Delta (Inch H20	The state of the s	Point #	Delta P ("H2O)	Stack Temp. (F)	Delta P ("H2O)		Cyclonic Flow ("H2O)	TE Cooler Temp. (F)
0	981.835				2.0	2	1	.87	531	-87	532		33
10	989.42	5	83	80		53	2	.87	540	-89	540		33
20	997.03		83	80		53	.3	.92	542	94	541		33
30	004-66		84	80		54	4	.79	543	.78	543		34
40	012.18		84	80		54	5	.76	542	.76	542		34
50	019.69		84	81		54	6	.71	541	.74	541		74
60	027.25		84	81		55	7	.80	540	.82	541		34
70	034.77		84	81		55	8	-74	539	.71	539		34
80	042.38	V	84	81	1	56	4		They				34
90	049.94	5	85	81	2,0	56	ĺ	.88	531	.89	533		
						1956	2	.89	540	.91	541		
						1	3	.94	541	-96	542		
						1676	4	.81	543	.76	544		
							5	.760	542	.76	543		
						1000	6	.72	542	:75	542		
						E.A.	7	-81	541	-84	541		
							8	.72	540	.73	540		
							1	.92	532	89	533		
		18.2	Tun-				2	91	540	.90	541		
							3	-93	541	.95	542		
							4	.82	543	.79	544		
							5	.78	542	.78	543		
				14			6	-70	542	.76			
							7	-81	541	. 82	541		
							8	-89	539	.75	539		





SCAQMD METHODS 2-4

ENVIRONMENTAL	SCAQIVIL	METHODS 2-4	
Run#: 4,5,6	Pitot ID: 5 type	Impinger Initial Final	Net Pitot Keak Check
Date: 10/1/15	Pitot Coeff.: .84	Water 1: 766.2887.6	Initial: V / V/
Client: OCSD	Meter Box #: 002	Water 2: 700,4 710.9	Final:
Unit: Engine 5	Meter @ Dh : 1,987	Blank: 6/3.0 615.1	
Operator: L. Barrov	J Meter Y: 19871	Sil. Gel: 821,9 831.8	Meter Box Leak Check
Stack Dia: 30"	TC#: 83	H2O Gain =	Rate "HG
Amb. Press : 29.91	Start Time: 9:31	Pressure Type/Rang	ge Initial: ,601 24"
Static Press : 25	Stop Time : //; 0/	ADM 880 C	- Final: 1001 24"

							Sample	Port 1:		Port 2 :		Pitot ID:	
Time (Minute)	Meter Volume	Pump Vac (inch Hg)		nperatures Outlet (F)	Set Delta H (Inch H2O)	Impinger	Point#	Delta P ("H2O)	Stack	Delta P	Stack	Cyclonic Flow ("H2O)	
(Minute)	050,644	(inch Hg)	met (F)	Juliet (F)	2,0	Temp. (F)	1	(H2O)	Temp. (F)	("H2O)	533	(HZO)	74 34
10	058,22	6	86	83	1	53	2	.88	541	.86	541		34
20	0581	1	87	83		54	3	.94	542	.93	543		35
30	003 44	1	87	83		54	4	.86	544	.88	544		35
40	081.03		87	84		55	5	.82	543	18.	543		35
50	088.62	- T	87	84		55	6	.75	542	78	542		35
10	096 18		87	84		56	7	.81	541	: 97	542		35
70	103 /9		87	84		57	8	70	541	71	541		35
80	111.24	V	88	84	V	53	- 0	1	2 (1	1,0	/	1	35
90	118.788	6	88	84	20	53	1	,84	532	.83	534		36
	110		00				2	,89	541	.88	542		
							3	,89	543	,92	544		
							4	. 88	545	.86	544		
							5	.77	543	.80	543		
							6	,80	542	.76	542		
							7	,82	542	,78	542		
							8	,81	541	.77	540		
							1	,83	532	,82	533		
							2	,89	541	.86	541		
							3	,91	542	.94	542	- /	
							4	.89	543	,87	544		
							5	.78	542	,81	343		
							6	.78	541	,79	543		
							7	,80	540	.75	542		
							8	.81	540	,76	541		
										,			



Almega

SCAQMD METHODS 2-4

EWALKON SHEST	11 (-		CHIGHNE	111211102						,	
Run # :	7,8,9	Pitot ID :	stype	Impinger	Initial	Final	Net		Pitot Lea	ak Check	
Date :	10/1/15	Pitot Coeff. :	.84	Water 1:	7825	412.3		Initial:	/	1/	
Client :	0650	Meter Box # :	002	Water 2:	710.9	723.6		Final:	V		
Unit:	Engine 5	Meter @ Dh:	1.987	Blank:	615.1	619.5					
Operator :	L. Barrows	Meter Y:	.9871	Sil. Gel:	765.0	780,0			Meter Box L	eak Check	
Stack Dia :	.30''	TC#:	83		H2O Gair	1 =			Rate	"HG	
Amb. Press :	29.91	Start Time :	11:16		Pressure	Type/Ran	ige	Initial:	.001	25"	
Static Press :	25	Stop Time :	12:46		HDM ?	380	_	Final:	1001	25"	

								the state of		G-10-10-10-10-10-10-10-10-10-10-10-10-10-			
			1600-		0.15	Lange Con-	Sample	Port 1:		Port 2 :		Pitot ID:	lee o
Time (Minute)	Meter Volume (acf)	Pump Vac (inch Hg)		outlet (F)	Set Delta H (Inch H2O)	Impinger Temp. (F)	Point #	Delta P ("H2O)	Stack Temp. (F)	Delta P ("H2O)	Stack Temp. (F)	Cyclonic Flow ("H2O)	TE Cooler Temp. (F)
(Minute)	119 120	(inch hg)	met (F)	Outlet (F)	20	remp. (F)	1	.82	534	84	533	(H2O)	36
10	12/14	6	90	87	1	53	2	.82	541	,84	541		36
20	134 20	1	90	87		53	3	.88	543	.93	542		36
.30	141.81		90	87		54	4	.75	545	88	544		36
40	149 43		91	87		54	5	75	543	,81	543		36
50	15/ 98		91	88		55	6	175	543	78	542		36
10	114 57		91	88	1	56	7	.79	542	,77	542		36
71	17711		91	88		57	8	79	542	.73	541		36
80	179 65		91	SE	1	53	0	. / (5-10	1.7	211		36
90	187 137	1	91	88 88	2.0	53	1	,86	533	.85	534		36
10	107.17	9	_1.(2.0	11	2	.83	5211	.86	542		
							3	.89	5217	92	544		
							4	75	5414	.88	545		
							5	.76	540	181	543		
							6	,76	542	79	543		
							7	.80	542	.78	52/2	- 1	
							8	.79	541	78	541		
								4 [[2 (1		211		
							1	.87	533	.84	533		
							2	.84	541	.87	542		
						1 1 1	3	.89	543	191	542		
							4	,73	544	,86	544		
\							5	76	543	182	543		
							6	,77	542	.81	542		
							7	,82	546	.79	542		
191							8	,79	540	79	54)		
7/									- 10				
									7 = 1		7		
													1




ALMEGA ENVIRONMENTAL TECHNICAL SERVICES 10602 Walker Street Cypress, CA 90630



SAMPLE POINT LOCATION DATA SHEET - Round Stack

Facility:	OCSD #2
Project Number:	9849
Date:	10/1/2015
Unit ID #	ENG 1->5
Inside of far wall to outside of port:	35.5
Port Distance:	5.5
Stack Diameter (D):	30 "
Upstream Distance (A):	54*
Equivalent Duct Diameter (A/D):	
Downstream Distance (B):	135"
Equivalent Duct Diameter (B/D):	
Total Number of Traverse Points :	16
Number of Sampling Ports Used:	2
Port Diameter:	4'



Sample Point No.	% of Stack Diameter	х	Stack Diameter	=	Distance from Wall	+	Port Distance	=	Distance from Sample Port
1	3.2	х	30	=	.96	+	5.5	=	6.46
2	10.5	х	1	=	3.15	+		n	8.65
3	19.4	х		=	5.82	+		=	11.32
4	22.3	x		=	9.69	+		=	15.19
5	67.7	х		=	20.31	+		=	25.81
6	80,6	х		=	24.18	+		=	29.68
7	89.5	х		=	26.85	+	1	=	32.35
8	96.8	х	V	=	29.04	+	0	=	34.54
		х		=		+		=	
		х		=		+		=	
		х		=		+		=	
		х		=		+		п	



APPENDIX D

SCAQMD METHOD 100.1 – CONTINUOUS MONITORING OF GASEOUS EMISSIONS



Appendix D1

CEMS – Results and Calculations

REFERENCE METHOD DATA SUMMARY

Facility: OCSD, Plant No. 2

City: Huntington Beach, CA

Source: Engine 5
Test: RATA

Run	Time	NOx	NOx	NOx	СО	CO	СО	Dry Flow	O2	CO2
No.	(hh:mm)	ppm	ppm@15%O2	lb/hr	ppm	ppm@15%O2	lb/hr	dscfh	%	%
1	7:43-8:12	34.05	22.02	2.38	591.37	382.4	25.151	576,377	11.78	7.58
2	8:13-8:42	35.97	23.27	2.53	574.10	371.4	24.549	579,502	11.78	7.69
3	8:43-9:12	36.47	23.79	2.57	580.31	378.6	24.882	581,080	11.86	7.66
4	9:31-10:00	35.03	22.72	2.50	590.16	382.7	25.675	589,604	11.80	7.18
5	10:01-10:30	35.63	23.17	2.54	578.80	376.5	25.161	589,123	11.83	7.19
6	10:31-11:00	35.86	23.51	2.56	580.92	380.9	25.251	589,078	11.90	7.14
7	11:16-11:45	36.38	23.44	2.54	579.05	373.2	24.577	575,211	11.75	7.34
8	11:46-12:15	35.90	23.36	2.52	585.05	380.6	24.986	578,771	11.83	7.30
9	12:16-12:45	36.55	23.71	2.57	573.98	372.4	24.566	580,031	11.81	7.31
		35.76	23.22	2.52	581.5	377.6	24.98	582,086	11.81	7.38



Reference Method CEMS Summary

Facility:

OCSD, Plant No. 2

City:

Huntington Beach, CA

Source:

Engine 5

Test: RATA

				Flu	ie Gas Com	position			Pollutant 1: NOx (MW: 46 lb/lb-mole)		Pollutant 2: CO (MW: 28 lb/lb-mole)			
	Run Information	on	Moisture	Flow	Rate:	O2	C	02	dry	dry ppm		dry	dry ppm	
No.	Date	Time	%	dry scfm	dry scfh	dry %	dry %	wet %	ppm	@15%O2	lbs/hr	ppm	@15%O2	lbs/hr
1	10/01/15	7:43-8:12	10.34	9,606	576,377	11.78	7.58	6.80	34.05	22.02	2.379	591.367	382.424	25.151
2	10/01/15	8:13-8:42	10.34	9,658	579,502	11.78	7.69	6.89	35.97	23.27	2.527	574.102	371.353	24.549
3	10/01/15	8:43-9:12	10.34	9,685	581,080	11.86	7.66	6.87	36.47	23.79	2.569	580.305	378.551	24.882
4	10/01/15	9:31-10:00	9.39	9,827	589,604	11.80	7.18	6.50	35.03	22.72	2.504	590.157	382.746	25.675
5	10/01/15	10:01-10:30	9.39	9,819	589,123	11.83	7.19	6.51	35.63	23.17	2.545	578.799	376.453	25.161
6	10/01/15	10:31-11:00	9.39	9,818	589,078	11.90	7.14	6.47	35.86	23.51	2.561	580.924	380.880	25.251
7	10/01/15	11:16-11:45	10.51	9,587	575,211	11.75	7.34	6.57	36.38	23.44	2.536	579.049	373.185	24.577
8	10/01/15	11:46-12:15	10.51	9,646	578,771	11.83	7.30	6.53	35.90	23.36	2.519	585.055	380.641	24.986
9	10/01/15	12:16-12:45	10.51	9,667	580,031	11.81	7.31	6.54	36.55	23.71	2.570	573.981	372.370	24.566

* Based on Standard

Conditions of:

60 deg. F and 29.92 in. Hg





OCSD, Plant No. 2 Facility: Run No.: City: Huntington Beach, CA Test Date: 10/01/15 Engine 5 Run Time: 7:43-8:12 Source: Test: RATA TEST DATA Pollutant 1 Pollutant 2 Diluent 1 Diluent 2 VARIABLE DESCRIPTION NOx CO 02 CO₂ ANALYTICAL RANGE 100 1000 25 A 10 % dry Unit of Measurement % dry ppmd ppmd CALIBRATION GAS INFORMATION В Zero Gas 0.00 0.00 0.00 0.00 Mid Gas Concentration 45.45 453.8 12.01 4.32 C Mid Gas Cylinder S/N: XC019657B CC39463 CC248731 CC248731 High Gas Concentration 89.91 899 21.99 D 8.749 High Gas Cylinder S/N: CC199782 CC259973 CC408131 CC408131 Primary Gas Cylinder S/N: UPSCALE CALIBRATION GAS USED 45.45 453.8 12.01 4.32 E L=Low, M=Mid, H=High M M M M INITIAL CALIBRATION ERROR TEST Zero Gas Response 0.00 0.70 0.03 0.00 Mid Gas Response 45,40 454.4 12.12 G 4.38 H High Gas Reponse 89.92 896.5 21.94 8.76 INITIAL SYSTEM CALIBRATION CHECK Zero Gas Response 0.27 0.80 0.03 0.00 Upscale Gas Response 45.38 450.2 12.11 4.31 FINAL SYSTEM CALIBRATION CHECK Zero Gas Response 0.48 0.20 0.04 -0.03K Upscale Gas Response 45.50 12.06 L 447.6 4.30 FINAL CALIBRATION ERROR CHECK M Zero Gas Response 0.38 0.40 0.03 -0.02Mid Gas Response 45.27 454.1 12.15 4.29 N 900.3 0 High Gas Reponse 89.88 21.94 8.75 AS MEASURED FLUE GAS CONCENTRATION 34.13 584.83 11.85 7.57 P CALCULATIONS **FORMULA** AVERAGE SYSTEM CALIBRATION (I+K)/2 Q Zero Response 0.38 0.50 0.04 -0.02448.90 12.09 R Upscale Response 45.44 4.31 (J+L)/2 34.05 591.37 11.78 CORRECTED CONC. 7.58 E*(P-Q)/(R-Q) QA/QC CALCULATIONS CALIBRATION GAS SELECTION, % of Range Low Gas C'*100/A Mid Gas 45.5 45.4 48.0 43.2 C*100/A High Gas 89.9 89.9 88.0 87.5 D*100/A CALIBRATION ERROR, % of Range Initial Zero Gas Error 0.00 0.07 0.12 0.00 (F-B)*100 A Initial Low Gas Error (G'-C')*100/A Initial Mid Gas Error -0.05 0.44 0.06 0.60 (G-C)*100/A Initial High Gas Error 0.01 -0.25-0.200.11 (H-D)*100/A Final Zero Gas Error 0.38 0.04 0.12 -0.20(M-B)*100'A Final Low Gas Error (N'-C')*100/A Final Mid Gas Error -0.180.03 0.56 -0.30 (N-C)*100:A Final High Gas Error -0.030.13 -0.200.01 (O-D)*100/A LINEARITY, % of Range -0.06 0.49 Initial 0.15 0.55 {(G-F)-[(H-F)*C]/D}*100/A -0.20 Final -0.35-0.060.61 {(N-M)-[(O-M)*C] D}*100 A SAMPLING SYSTEM BIAS, % of Range 0.27 Initial Zero Gas Bias 0.01 0.00 0.00 (I-F)*100'A Initial Upscale Gas Bias -0.02-0.42-0.04-0.70 (J-G[or G', or H]*100/A Final Zero Gas Bias 0.10 -0.020.04 -0.10 (K-M)*100/A Final Upscale Gas Bias 0.23 -0.65-0.360.10 (L-N[or N', or O]*100 A CALIBRATION DRIFT, % of Range 0.21 -0.06 0.04 -0.30(K-I)*100'A Zero Upscale 0.12 -0.20-0.10 (L-J) 100/A



Facility: City: OCSD, Plant No. 2 Run No.: Huntington Beach, CA Engine 5 Test Date: 10/01/15 Run Time: 8:13-8:42

Source:

est:	RATA			Atum Timo.	0.15-0.42	
EST DATA		Pollutant 1	Pollutant 2	Diluent 1	Diluent 2	
VARIABLE	DESCRIPTION	NOx	CO	<u>O2</u>	<u>CO2</u>	
A	ANALYTICAL RANGE	100	1000	25	10	
	Unit of Measurement	ppmd	ppmd	% dry	% dry	
	CALIBRATION GAS INFORMATION					
В	Zero Gas	0.00	0.00	0.00	0.00	
C	Mid Gas Concentration	45.45	453.8	12.01	4.32	
	Mid Gas Cylinder S/N:	XC019657B	CC39463	CC248731	CC248731	
D	High Gas Concentration	89.91	899	21.99	8.75	
	High Gas Cylinder S/N:	CC199782	CC259973	CC408131	CC408131	
	Primary Gas Cylinder S/N:					
E	UPSCALE CALIBRATION GAS USED	45.45	453.8	12.01	4.32	
-	L=Low, M=Mid, H=High	M	M	M	M	
	INITIAL CALIBRATION ERROR TEST	2000	925	106.0.1		
F	Zero Gas Response	0.00	0.70	0.03	0.00	
G	Mid Gas Response	45.40	454.4	12.12	4.38	
	50-13, 59 DDV 49, 55	89.92	896.5	21.94		
Н	High Gas Reponse	07.74	070,3	21.74	8.76	
¥	INITIAL SYSTEM CALIBRATION CHECK	0.27	0.00	0.02	0.00	
I	Zero Gas Response	0.27	0.80	0.03	0.00	
J	Upscale Gas Response	45.38	450.2	12.11	4.31	
100	FINAL SYSTEM CALIBRATION CHECK	0.40	0.00	0.04	0.00	
K	Zero Gas Response	0.48	0.20	0.04	-0.03	
L	Upscale Gas Response	45.50	447.6	12.06	4.30	
	FINAL CALIBRATION ERROR CHECK	9090270	324770000	9209282	0 6000	
M	Zero Gas Response	0.38	0.40	0.03	-0.02	
N	Mid Gas Response	45.27	454.1	12.15	4.29	
O	High Gas Reponse	89.88	900.3	21.94	8.75	
P	AS MEASURED FLUE GAS CONCENTRATION	36.04	567.77	11.85	7.67	
LOTILAT	PIONE					and the same of th
LCULAT					- W G	FORMULA
~	AVERAGE SYSTEM CALIBRATION	0.20	0.50	0.04	0.00	No. protect
Q	Zero Response	0.38	0.50	0.04	-0.02	(I+K)/2
R	Upscale Response	45.44	448.90	12.09	4.31	_(J+L)/2
S	CORRECTED CONC.	35.97	574.10	11.78	7.69	E*(P-Q)/(R-Q)
	CULATIONS				7.03	757. 47747
, V C C	CALIBRATION GAS SELECTION, % of Range					
	Mid Gas	45.5	45.4	48.0	43.2	C*100/A
	High Gas	89.9	89.9	88.0	87.5	D*100/A
	CALIBRATION ERROR, % of Range	32.22	07.7	00.0	07.3	D 100/11
	Initial Zero Gas Error	0.00	0.07	0.12	0.00	(F-B)*100/A
	Initial Mid Gas Error	-0.05	0.07	0.12	0.60	
	Initial High Gas Error	0.03	-0.25	-0.20		(G-C)*100/A
	minai riigii Gas Eitol	0.01	-0.23	-0.20	0.11	(H-D)*100/A
	Final Zero Gas Error	0.39	0.04	0.12	0.20	(M. D)\$100 A
	Final Zero Gas Error	0.38	0.04	0.12	-0.20	(M-B)*100/A
	Final Mid Gas Error	-0.18	0.03	0.56	-0.30	(N-C)*100/A
	Final High Gas Error	-0.03	0.13	-0.20	0.01	(O-D)*100/A
	LINEARITY, % of Range	0.04	0.15	0.10	0	Manager of the second of the s
	Initial	-0.06	0.15	0.49	0.55	{(G-F)-[(H-F)*C]/D}*100/A
	Final	-0.35	-0.06	0.61	-0.20	{(N-M)-[(O-M)*C]/D}*100/
	SAMPLING SYSTEM BIAS, % of Range			100	4550 4 4	
	Initial Zero Gas Bias	0.27	0.01	0.00	0.00	(I-F)*100/A
	Initial Upscale Gas Bias	-0.02	-0.42	-0.04	-0.70	(J-G[or G', or H]*100/A
			700000000	04445048073	2000 000000	
	Final Zero Gas Bias	0.10	-0.02	0.04	-0.10	(K-M)*100.'A
	Final Upscale Gas Bias	0.23	-0.65	-0.36	0.10	(L-N[or N', or O]*100/A
	CALIBRATION DRIFT, % of Range					
	CALIBRATION DRIFT, % of Range Zero Upscale	0.21 0.12	-0.06 -0.26	0.04	-0.30	(K-I)*100/A



						Aimega
Facility:	OCSD, Plant No. 2			Run No.:	3	ENVIRONMENTA
City:	Huntington Beach, CA			Test Date:	10/01/15	
Source:	Engine 5			Run Time:	8:43-9:12	
Test:	RATA					
TEST DATA	<u>A</u>	Pollutant 1	Pollutant 2	Diluent 1	Diluent 2	
VARIABLE	DESCRIPTION	NOx	CO	<u>O2</u>	CO2	
A	ANALYTICAL RANGE	100	1000	25	10	
	Unit of Measurement	ppmd	ppmd	% dry	% dry	
	CALIBRATION GAS INFORMATION	0.00		0.00		
В	Zero Gas	0.00	0.00	0.00	0.00	
C	Mid Gas Concentration	45.45 XC019657B	453.8 CC39463	12.01	4.32	
D	Mid Gas Cylinder S/N: High Gas Concentration	89.91	899	CC248731 21.99	CC248731 8.75	
В	High Gas Cylinder S/N:	CC199782	CC259973	CC408131	CC408131	
	Primary Gas Cylinder S/N:		0.0000000		00.00.51	
E	UPSCALE CALIBRATION GAS USED	45.45	453.8	12.01	4.32	
	L=Low, M=Mid, H=High	M	M	M	M	
	INITIAL CALIBRATION ERROR TEST					
F	Zero Gas Response	0.00	0.70	0.03	0.00	
G	Mid Gas Response	45.40	454.4	12.12	4.38	
Н	High Gas Reponse	89.92	896.5	21.94	8.76	
	INITIAL SYSTEM CALIBRATION CHECK	0.25	0.00	0.03	0.00	
I	Zero Gas Response	0.27	0.80	0.03	0.00	
J	Upscale Gas Response FINAL SYSTEM CALIBRATION CHECK	45.38	450.2	12.11	4.31	
ν	Zero Gas Response	0.48	0.20	0.04	-0.03	
K L	Upscale Gas Response	45.50	447.6	12.06	4.30	
L	FINAL CALIBRATION ERROR CHECK	43.30	447.0	12.00	4.50	
M	Zero Gas Response	0.38	0.40	0.03	-0.02	
N	Mid Gas Response	45.27	454.1	12.15	4.29	
0	High Gas Reponse	89.88	900.3	21.94	8.75	
	and September 1970 And the 1987 S					
P	AS MEASURED FLUE GAS CONCENTRATION	36.54	573.90	11.93	7.64	
CALCINA	CIONE					non
CALCULAT	AVERAGE SYSTEM CALIBRATION					FORMULA
Q	Zero Response	0.38	0.50	0.04	-0.02	(I+K)/2
R	Upscale Response	45.44	448.90	12.09	4.31	(J+L)/2
10	C pocule response	13.11	110.50	12.07	1.51	10.00
S	CORRECTED CONC.	36.47	580.31	11.86	7.66	E*(P-Q)/(R-Q)
QA/QC CAL	CULATIONS					1 3 30 5 30
	CALIBRATION GAS SELECTION, % of Range					
	Mid Gas	45.5	45.4	48.0	43.2	C*100/A
	High Gas	89.9	89.9	88.0	87.5	D*100/A
	CALIBRATION ERROR, % of Range				2.22	
	Initial Zero Gas Error	0.00	0.07	0.12	0.00	(F-B)*100/A
	Initial Mid Gas Error	-0.05	0.06	0.44	0.60	(G-C)*100/A
	Initial High Gas Error	0.01	-0.25	-0.20	0.11	(H-D)*100/A
	Final Zero Gas Error	0.38	0.04	0.12	-0.20	(M-B)*100/A
	Final Mid Gas Error	-0.18	0.03	0.56	-0.30	(N-C)*100/A
	Final High Gas Error	-0.03	0.13	-0.20	0.01	(O-D)*100/A
	LINEARITY, % of Range				-100	/
	Initial	-0.06	0.15	0.49	0.55	{(G-F)-[(H-F)*C]/D}*100/A
	Final	-0.35	-0.06	0.61	-0.20	{(N-M)-[(O-M)*C]/D}*100/A
	SAMPLING SYSTEM BIAS, % of Range	grater	2 22	4022	2 22	
	Initial Zero Gas Bias	0.27	0.01	0.00	0.00	(I-F)*100/A
	Initial Upscale Gas Bias	-0.02	-0.42	-0.04	-0.70	(J-G[or G', or H]*100/A
	Final Zana Car Bina	0.10	0.00	0.04	0.10	W. 3 404100''
	Final Upscale Gas Bias	0.10	-0.02	0.04	-0.10	(K-M)*100/A
	Final Upscale Gas Bias CALIBRATION DRIFT, % of Range	0.23	-0.65	-0.36	0.10	(L-N[or N', or O]*100/A
	Zero	0.21	-0.06	0.04	-0.30	(K-l)*100/A
	Upscale	0.12	-0.26	-0.20	-0.30	(L-J)*100/A
	Opseure	0.12	0.20	0.20	0.10	(D3) TOUR



 Facility:
 OCSD, Plant No. 2
 Run No.:
 4

 City:
 Huntington Beach, CA
 Test Date:
 10/01/15

 Source:
 Engine 5
 Run Time:
 9:31-10:00

Source:	Engine 5			Run Time:	9:31-10:00	
Test:	RATA					
TEST DATA	A	Pollutant 1	Pollutant 2	Diluent 1	Diluent 2	
VARIABLE	DESCRIPTION	NOx	CO	<u>O2</u>	CO2	
A	ANALYTICAL RANGE	100	1000	25	10	
15.0	Unit of Measurement	ppmd	ppmd	% dry	% dry	
	CALIBRATION GAS INFORMATION	The state of the s	E La Composition	50000000	t with the same of the	
В	Zero Gas	0.00	0.0	0.00	0.00	
C	Mid Gas Concentration	45.45	453.8	12.01	4.32	
	Mid Gas Cylinder S/N:	XC019657B	CC39463	CC248731	CC248731	
D	High Gas Concentration	89.91	899	21.99	8.75	
	High Gas Cylinder S/N:	CC199782	CC259973	CC408131	CC408131	
	Primary Gas Cylinder S/N:					
E	UPSCALE CALIBRATION GAS USED	45.45	453.8	12.01	4.32	
	L=Low, M=Mid, H=High	M	M	M	M	
	INITIAL CALIBRATION ERROR TEST					
F	Zero Gas Response	0.00	0.70	0.03	0.00	
G	Mid Gas Response	45.40	454.4	12.12	4.38	
H	High Gas Reponse	89.92	896.5	21.94	8.76	
	INITIAL SYSTEM CALIBRATION CHECK					
Ĩ	Zero Gas Response	0.48	0.20	0.04	-0.03	
J	Upscale Gas Response	45.50	447.6	12.06	4.30	
	FINAL SYSTEM CALIBRATION CHECK					
K	Zero Gas Response	0.48	1.00	0.09	0.05	
L	Upscale Gas Response	45.50	444.8	12.14	4.12	
	FINAL CALIBRATION ERROR CHECK					
M	Zero Gas Response	0.38	0.40	0.03	-0.02	
N	Mid Gas Response	45.27	454.1	12.15	4.29	
О	High Gas Reponse	89.88	900.3	21.94	8.75	
	E 8					
P	AS MEASURED FLUE GAS CONCENTRATION	35.18	580.09	11.89	6.99	
CALCULAT	TIONS					FORMULA
	AVERAGE SYSTEM CALIBRATION					
Q	Zero Response	0.48	0.60	0.07	0.01	(I+K)/2
R	Upscale Response	45.50	446.20	12.10	4.21	(J+L)/2
	no a same	25.02	500.16	11.00	7.10	Tarana rational as
S	CORRECTED CONC.	35.03	590.16	11.80	7.18	E*(P-Q)/(R-Q)
QA/QC CAL	CULATIONS					
	CALIBRATION GAS SELECTION, % of Range					Cuta a a u v
	Low Gas	nere.	STREET, ST	10.0	10.0	C'*100/A
	Mid Gas	45.5	45.4	48.0	43.2	C*100/A
	High Gas	89.9	89.9	88.0	87.5	D*100/A
	CALIBRATION ERROR, % of Range	0.00	0.07	0.10	0.00	NO TITUDO CONT.
	Initial Zero Gas Error	0.00	0.07	0.12	0.00	(F-B)*100/A
	Initial Low Gas Error					(G'-C')*100/A
	Initial Mid Gas Error	-0.05	0.06	0.44	0.60	(G-C)*100/A
	Initial High Gas Error	0.01	-0.25	-0.20	0.11	(H-D)*100/A
		0.50	0.0	0.45		
	Final Zero Gas Error	0.38	0.04	0.12	-0.20	(M-B)*100/A
	Final Low Gas Error	ey sould	55 pelast	225,000	91 29	(N'-C')*100/A
	Final Mid Gas Error	-0.18	0.03	0.56	-0.30	(N-C)*100/A
	Final High Gas Error	-0.03	0.13	-0.20	0.01	(O-D)*100/A
	LINEARITY, % of Range		-			
	Initial	-0.06	0.15	0.49	0.55	{(G-F)-[(H-F)*C]/D}*100/A
	Final	-0.35	-0.06	0.61	-0.20	$\{(N-M)-[(O-M)*C]/D\}*100/A$
	- AWAR				41 115	
	SAMPLING SYSTEM BIAS, % of Range	9500 94000	Ng Signal	Agreeme	1000000	
	Initial Zero Gas Bias	0.48	-0.05	0.04	-0.30	(I-F)*100/A
	Initial Upscale Gas Bias	0.10	-0.68	-0.24	-0.80	(J-G[or G', or H]*100/A
	D. 70 0 01	12 (19 12)	2 202	0.5	2 (22)	
	I Pinal Zona Con Dina	0.10	0.06	0.24	0.70	(K-M)*100/A
	Final Zero Gas Bias					
	Final Upscale Gas Bias	0.23	-0.93	-0.04	-1.70	(L-N[or N', or O]*100/A
	Final Upscale Gas Bias CALIBRATION DRIFT, % of Range	0.23	-0.93			
	Final Upscale Gas Bias			-0.04 0.20 0.32	-1.70 0.80 -1.80	(L-N[or N', or O]*100/A (K-J)*100/A (L-J)*100/A



Facility:

OCSD, Plant No. 2 Huntington Beach, CA Engine 5 RATA Run No.: 5 Test Date: 10/01/15 Run Time: 10:01-10:30 City: Source:

est:	RATA					
EST DATA	4	Pollutant 1	Pollutant 2	Diluent 1	Diluent 2	
VARIABLE	DESCRIPTION	NOx	CO	02	CO2	
A	ANALYTICAL RANGE	100	1000	25	10	
	Unit of Measurement	ppmd	ppmd	% dry	% dry	
	CALIBRATION GAS INFORMATION	1.1.	Larren		1.6.2.0	
B	Zero Gas	0.00	0.00	0.00	0.00	
C	Mid Gas Concentration	45.45	453.8	12.01	4.32	
-	Mid Gas Cylinder S/N:		CC39463	CC248731		
D					CC248731	
D	High Gas Concentration	89.91	899	21.99	8.75	
	High Gas Cylinder S/N: Primary Gas Cylinder S/N:	CC199782	CC259973	CC408131	CC408131	
E	UPSCALE CALIBRATION GAS USED	45.45	453.8	12.01	4.32	
	L=Low, M=Mid, H=High	M	M	M	M	
	INITIAL CALIBRATION ERROR TEST		2/5			
F	Zero Gas Response	0.00	0.70	0.03	0.00	
G	Mid Gas Response	45.40	454.4	12.12	4.38	
		89.92				
H	High Gas Reponse	09.92	896.5	21.94	8.76	
	INITIAL SYSTEM CALIBRATION CHECK	0.40	0.00	0.04	0.00	
1	Zero Gas Response	0.48	0.20	0.04	-0.03	
1	Upscale Gas Response	45.50	447.6	12.06	4.30	
	FINAL SYSTEM CALIBRATION CHECK	400	Tables.	0.26		
K	Zero Gas Response	0.48	1.00	0.09	0.05	
L	Upscale Gas Response	45.50	444.8	12.14	4.12	
	FINAL CALIBRATION ERROR CHECK					
M	Zero Gas Response	0.38	0.40	0.03	-0.02	
N	Mid Gas Response	45.27	454.1	12.15	4.29	
0	High Gas Reponse	89.88	900.3	21.94	8.75	
~	The case repende	5,100	3000		0.72	
P	AS MEASURED FLUE GAS CONCENTRATION	35.77	568,94	11.92	7.00	
LCULAT	TIONS					FORMULA
200111	AVERAGE SYSTEM CALIBRATION					7
Q	Zero Response	0.48	0.60	0.07	0.01	(I+K)/2
Ř	Upscale Response	45.50	446.20	12.10	4.21	(J+L)/2
K	Opscare response	45.50	740.20	12.10	4.41	
S	CORRECTED CONC.	35.63	578.80	11.83	7.19	E*(P-Q)/(R-Q)
	CULATIONS				7122	7-1. 4/14/
	CALIBRATION GAS SELECTION, % of Range					
	Low Gas					C'*100/A
	Mid Gas	45.5	45.4	48.0	43.2	C*100/A
	High Gas	89.9	89.9	88.0	87.5	D*100/A
	CALIBRATION ERROR, % of Range	07.7	07.7	00.0	07.5	D 100.71
	Initial Zero Gas Error	0.00	0.07	0.13	0.00	IF DISTOR I
		0.00	0.07	0.12	0.00	(F-B)*100/A
	Initial Low Gas Error					COLONAL DOLLA
		0.0-	0.00	0.44		(G'-C')*100/A
	Initial Mid Gas Error	-0.05	0.06	0.44	0.60	(G-C)*100 A
		-0.05 0.01	0.06 -0.25	0.44 -0.20	0.60 0.11	
	Initial Mid Gas Error Initial High Gas Error	0.01	-0.25	-0.20	0.11	(G-C)*100·A
	Initial Mid Gas Error		1000000			(G-C)*100·A
	Initial Mid Gas Error Initial High Gas Error	0.01	-0.25	-0.20	0.11	(G-C)*100·A (H-D)*100/A
	Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error	0.01	-0.25 0.04	0.12	-0.20	(G-C)*100 A (H-D)*100/A (M-B)*100 A (N'-C)*100 A
	Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error	0.01 0.38 -0.18	-0.25 0.04 0.03	-0.20 0.12 0.56	-0.20 -0.30	(G-C)*100·A (H-D)*100/A (M-B)*100·A (N'-C')*100·A (N-C)*100/A
	Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error	0.01	-0.25 0.04	0.12	-0.20	(G-C)*100 A (H-D)*100/A (M-B)*100 A (N'-C)*100 A
	Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range	0.01 0.38 -0.18 -0.03	-0.25 0.04 0.03 0.13	-0.20 0.12 0.56 -0.20	0.11 -0.20 -0.30 0.01	(G-C)*100 A (H-D)*100/A (M-B)*100 A (N'-C)*100 A (N-C)*100/A (O-D)*100/A
	Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial	0.01 0.38 -0.18 -0.03	-0.25 0.04 0.03 0.13 0.15	-0.20 0.12 0.56 -0.20 0.49	0.11 -0.20 -0.30 0.01 0.55	(G-C)*100 A (H-D)*100/A (M-B)*100 A (N'-C)*100 A (N-C)*100/A (O-D)*100/A {(G-F)-{(H-F)*C]-D}*100 A
	Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range	0.01 0.38 -0.18 -0.03	-0.25 0.04 0.03 0.13	-0.20 0.12 0.56 -0.20	0.11 -0.20 -0.30 0.01	(G-C)*100 A (H-D)*100/A (M-B)*100 A (N'-C)*100 A (N-C)*100/A (O-D)*100/A {(G-F)-{(H-F)*C]-D}*100 A
	Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final	0.01 0.38 -0.18 -0.03	-0.25 0.04 0.03 0.13 0.15	-0.20 0.12 0.56 -0.20 0.49	0.11 -0.20 -0.30 0.01 0.55	(G-C)*100 A (H-D)*100/A (M-B)*100 A (N'-C)*100 A (N-C)*100/A (O-D)*100/A {(G-F)-{(H-F)*C]-D}*100 A
	Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range	0.01 0.38 -0.18 -0.03 -0.06 -0.35	-0.25 0.04 0.03 0.13 0.15 -0.06	-0.20 0.12 0.56 -0.20 0.49 0.61	0.11 -0.20 -0.30 0.01 0.55 -0.20	(G-C)*100 A (H-D)*100/A (M-B)*100 A (N'-C)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-{(H-F)*C] D}*100 A {(N-M)-{(O-M)*C]'D}*100/A
	Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias	0.01 0.38 -0.18 -0.03 -0.06 -0.35	-0.25 0.04 0.03 0.13 0.15 -0.06	-0.20 0.12 0.56 -0.20 0.49 0.61	0.11 -0.20 -0.30 0.01 0.55 -0.20	(G-C)*100 A (H-D)*100/A (M-B)*100 A (N'-C)*100 A (N-C)*100/A (O-D)*100/A {(G-F)-{(H-F)*C] D}*100 A {(N-M)-{(O-M)*C]'D}*100/A (I-F)*100 A
	Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range	0.01 0.38 -0.18 -0.03 -0.06 -0.35	-0.25 0.04 0.03 0.13 0.15 -0.06	-0.20 0.12 0.56 -0.20 0.49 0.61	0.11 -0.20 -0.30 0.01 0.55 -0.20	(G-C)*100 A (H-D)*100/A (M-B)*100 A (N'-C)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-{(H-F)*C] D}*100 A {(N-M)-{(O-M)*C]'D}*100/A
	Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias	0.01 0.38 -0.18 -0.03 -0.06 -0.35	-0.25 0.04 0.03 0.13 0.15 -0.06	-0.20 0.12 0.56 -0.20 0.49 0.61	0.11 -0.20 -0.30 0.01 0.55 -0.20	(G-C)*100 A (H-D)*100/A (M-B)*100 A (N'-C)*100 A (N-C)*100/A (O-D)*100/A {(G-F)-{(H-F)*C] D}*100 A {(N-M)-{(O-M)*C]'D}*100/A (I-F)*100 A
	Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias	0.01 0.38 -0.18 -0.03 -0.06 -0.35	-0.25 0.04 0.03 0.13 0.15 -0.06	-0.20 0.12 0.56 -0.20 0.49 0.61 0.04 -0.24	0.11 -0.20 -0.30 0.01 0.55 -0.20 -0.30 -0.80	(G-C)*100 A (H-D)*100/A (M-B)*100 A (N'-C)*100 A (N-C)*100/A (O-D)*100/A {(G-F)-{(H-F)*C]-D}*100 A {(N-M)-{(O-M)*C]*D}*100 A (I-F)*100 A (J-G[or G', or H]*100 A
	Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias Final Zero Gas Bias Final Upscale Gas Bias CALIBRATION DRIFT, % of Range	0.01 0.38 -0.18 -0.03 -0.06 -0.35 0.48 0.10 0.10 0.23	-0.25 0.04 0.03 0.13 0.15 -0.06 -0.68 0.06 -0.93	-0.20 0.12 0.56 -0.20 0.49 0.61 0.04 -0.24 0.24 -0.04	0.11 -0.20 -0.30 0.01 0.55 -0.20 -0.30 -0.80 0.70 -1.70	(G-C)*100 A (H-D)*100/A (M-B)*100 A (N'-C)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-[(H-F)*C]-D}*100/A {(N-M)-[(O-M)*C]/D}*100/A (I-F)*100 A (J-G[or G', or H]*100/A (K-M)*100/A (L-N[or N', or O]*100/A
	Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias Final Zero Gas Bias Final Upscale Gas Bias	0.01 0.38 -0.18 -0.03 -0.06 -0.35 0.48 0.10	-0.25 0.04 0.03 0.13 0.15 -0.06 -0.68 0.06	-0.20 0.12 0.56 -0.20 0.49 0.61 0.04 -0.24 0.24	0.11 -0.20 -0.30 0.01 0.55 -0.20 -0.30 -0.80 0.70	(G-C)*100 A (H-D)*100/A (M-B)*100 A (N'-C)*100 A (N-C)*100/A (O-D)*100/A {(G-F)-{(H-F)*C]-D}*100 A {(N-M)-{(O-M)*C]/D}*100 A (I-F)*100 A (J-G[or G', or H]*100 A



OCSD, Plant No. 2 Facility: Run No.: Huntington Beach, CA Test Date: 10/01/15 City: Engine 5 RATA Source: Run Time: 10:31-11:00

Source:	Engine 5			Run Time:	10:31-11:00)
Test:	RATA					
		w 65 g	12 Str. 72	200	500 5	
TEST DAT	<u>^A</u>	Pollutant 1	Pollutant 2	Diluent 1	Diluent 2	
VARIABLE	DESCRIPTION	NOx	CO	<u>O2</u>	CO2	
A	ANALYTICAL RANGE	100	1000	25	10	
	Unit of Measurement	ppmd	ppmd	% dry	% dry	
	CALIBRATION GAS INFORMATION	ppina	ppma	70 dij	70 di y	
		0.00	0.00	0.00	0.00	
В	Zero Gas	0.00	0.00	0.00	0.00	
C	Mid Gas Concentration	45.45	453.8	12.01	4.32	
	Mid Gas Cylinder S/N:	XC019657B	CC39463	CC248731	CC248731	
D	High Gas Concentration	89.91	899	21.99	8.75	
D	High Gas Cylinder S/N:	CC199782	CC259973			
		CC199782	CC239973	CC408131	CC408131	
	Primary Gas Cylinder S/N:	1000 100	2223 0	1881 201	4	
E	UPSCALE CALIBRATION GAS USED	45.45	453.8	12.01	4.32	
	L=Low, M=Mid, H=High	M	M	M	M	
	INITIAL CALIBRATION ERROR TEST					
F	Zero Gas Response	0.00	0.70	0.03	0.00	
		45.40	454.4	12.12	4.38	
G	Mid Gas Response					
Н	High Gas Reponse	89.92	896.5	21.94	8.76	
	INITIAL SYSTEM CALIBRATION CHECK					
I	Zero Gas Response	0.48	0.20	0.04	-0.03	
J	Upscale Gas Response	45.50	447.6	12.06	4.30	
	FINAL SYSTEM CALIBRATION CHECK	10100		22100	1100	
700		0.40	1.00	0.00	0.05	
K	Zero Gas Response	0.48	1.00	0.09	0.05	
L	Upscale Gas Response	45.50	444.8	12.14	4.12	
	FINAL CALIBRATION ERROR CHECK					
M	Zero Gas Response	0.38	0.40	0.03	-0.02	
	Mid Gas Response	45.27	454.1	12.15	4.29	
N	17 C					
O	High Gas Reponse	89.88	900.3	21.94	8.75	
P	AS MEASURED FLUE GAS CONCENTRATION	36.00	571.03	11.99	6.95	
CALCULA	TIONS					FORMULA
CALCULA						1
	AVERAGE SYSTEM CALIBRATION			0.0=		50 1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
Q	Zero Response	0.48	0.60	0.07	0.01	(I+K)/2
R	Upscale Response	45.50	446.20	12.10	4.21	(J+L)/2
S	CORRECTED CONC.	35.86	580.92	11.90	7.14	E*(P-Q)/(R-Q)
	LCULATIONS	55.00	000.72	11170	7.1	12 (1 4) (11 4)
VA/VC CA						
	CALIBRATION GAS SELECTION, % of Range					
	Low Gas					C'*100/A
	Mid Gas	45.5	45.4	48.0	43.2	C*100/A
	High Gas	89.9	89.9	88.0	87.5	D*100/A
		07.7	07.7	00.0	01,3	5 100/11
	CALIBRATION ERROR, % of Range	0.00	0.0=	0.10	0.00	
	Initial Zero Gas Error	0.00	0.07	0.12	0.00	(F-B)*100/A
	Initial Mid Gas Error	-0.05	0.06	0.44	0.60	(G-C)*100/A
	Initial High Gas Error	0.01	-0.25	-0.20	0.11	(H-D)*100/A
				Marie Santari		Normania CONTRATA
	Final Zana Cas Farra	0.20	0.04	0.12	0.20	(2.1 D)**100.1
	Final Zero Gas Error	0.38	0.04	0.12	-0.20	(M-B)*100/A
					-0.30	(N-C)*100/A
	Final Mid Gas Error	-0.18	0.03	0.56	-0.30	(11 0) 10011
	Final Mid Gas Error Final High Gas Error	-0.18 -0.03	0.03	-0.20	0.01	(O-D)*100/A
	Final High Gas Error					
	Final High Gas Error LINEARITY, % of Range	-0.03	0.13	-0.20	0.01	(O-D)*100/A
	Final High Gas Error LINEARITY, % of Range Initial	-0.03 -0.06	0.13	-0.20 0.49	0.01	(O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A
	Final High Gas Error LINEARITY, % of Range	-0.03	0.13	-0.20	0.01	(O-D)*100/A
	Final High Gas Error LINEARITY, % of Range Initial	-0.03 -0.06	0.13	-0.20 0.49	0.01	(O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A
	Final High Gas Error LINEARITY, % of Range Initial	-0.03 -0.06	0.13	-0.20 0.49	0.01	(O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A
	Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range	-0.03 -0.06 -0.35	0.13 0.15 -0.06	-0.20 0.49 0.61	0.01 0.55 -0.20	(O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A {(N-M)-[(O-M)*C]/D}*100/A
	Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias	-0.03 -0.06 -0.35	0.13 0.15 -0.06	-0.20 0.49 0.61	0.01 0.55 -0.20	(O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A {(N-M)-[(O-M)*C]/D}*100/A (I-F)*100/A
	Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range	-0.03 -0.06 -0.35	0.13 0.15 -0.06	-0.20 0.49 0.61	0.01 0.55 -0.20	(O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A {(N-M)-[(O-M)*C]/D}*100/A
	Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias	-0.03 -0.06 -0.35 0.48 0.10	0.13 0.15 -0.06 -0.05 -0.68	-0.20 0.49 0.61 0.04 -0.24	0.01 0.55 -0.20 -0.30 -0.80	(O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A {(N-M)-[(O-M)*C]/D}*100/A (I-F)*100/A (J-G[or G', or H]*100/A
	Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias Final Zero Gas Bias	-0.03 -0.06 -0.35 0.48 0.10	0.13 0.15 -0.06 -0.05 -0.68 0.06	-0.20 0.49 0.61	0.01 0.55 -0.20 -0.30 -0.80 0.70	(O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A {(N-M)-[(O-M)*C]/D}*100/A (I-F)*100/A
	Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias Final Zero Gas Bias	-0.03 -0.06 -0.35 0.48 0.10	0.13 0.15 -0.06 -0.05 -0.68	-0.20 0.49 0.61 0.04 -0.24	0.01 0.55 -0.20 -0.30 -0.80	(O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A {(N-M)-[(O-M)*C]/D}*100/A (I-F)*100/A (J-G[or G', or H]*100/A (K-M)*100/A
	Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias Final Zero Gas Bias Final Zero Gas Bias	-0.03 -0.06 -0.35 0.48 0.10	0.13 0.15 -0.06 -0.05 -0.68 0.06	-0.20 0.49 0.61 0.04 -0.24	0.01 0.55 -0.20 -0.30 -0.80 0.70	(O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A {(N-M)-[(O-M)*C]/D}*100/A (I-F)*100/A (J-G[or G', or H]*100/A
	Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias Final Zero Gas Bias Final Zero Gas Bias CALIBRATION DRIFT, % of Range	-0.03 -0.06 -0.35 0.48 0.10 0.10 0.23	0.13 0.15 -0.06 -0.05 -0.68 0.06 -0.93	-0.20 0.49 0.61 0.04 -0.24 0.24 -0.04	0.01 0.55 -0.20 -0.30 -0.80 0.70 -1.70	(O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A {(N-M)-[(O-M)*C]/D}*100/A (I-F)*100/A (J-G[or G', or H]*100/A (K-M)*100/A (L-N[or N', or O]*100/A
	Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias Final Zero Gas Bias Final Zero Gas Bias	-0.03 -0.06 -0.35 0.48 0.10	0.13 0.15 -0.06 -0.05 -0.68 0.06	-0.20 0.49 0.61 0.04 -0.24	0.01 0.55 -0.20 -0.30 -0.80 0.70	(O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A {(N-M)-[(O-M)*C]/D}*100/A (I-F)*100/A (J-G[or G', or H]*100/A (K-M)*100/A



 Facility:
 OCSD, Plant No. 2
 Run No.:
 7

 City:
 Huntington Beach, CA
 Test Date:
 10/01/15

 Source:
 Engine 5
 Run Time:
 11:16-11:45

Γest: ΓEST DATA VARIABLE	Engine 5			Run Time.	11;10-11;4;	3
	RATA					
		Pollutant 1	Pollutant 2	Diluent 1	Diluent 2	
VARIABLE	DESCRIPTION	NOx	CO	02	CO2	
A	ANALYTICAL RANGE	100	1000	25	10	
	Unit of Measurement	ppmd	ppmd	% dry	% dry	
	CALIBRATION GAS INFORMATION	Ppma	ppina	70 423	70 tar 3	
В	Zero Gas	0.00	0.00	0.00	0.00	
C	Mid Gas Concentration	45.45	453.8	12.01	4.32	
C	Mid Gas Cylinder S/N:		CC39463	CC248731		
150	High Gas Concentration	89.91	899	21.99	CC248731	
D					8.75	
	High Gas Cylinder S/N:	CC199782	CC259973	CC408131	CC408131	
	Primary Gas Cylinder S/N:	45.45	453.0	10.01	4 22	
E	UPSCALE CALIBRATION GAS USED	45.45	453.8	12.01	4.32	
	L=Low, M=Mid, H=High	M	M	M	M	
	INITIAL CALIBRATION ERROR TEST					
F	Zero Gas Response	0.00	0.70	0.03	0.00	
G	Mid Gas Response	45.40	454.4	12.12	4.38	
H	High Gas Reponse	89.92	896.5	21.94	8.76	
	INITIAL SYSTEM CALIBRATION CHECK					
I	Zero Gas Response	0.48	1.00	0.09	0.05	
J	Upscale Gas Response	45.50	444.8	12.14	4.12	
	FINAL SYSTEM CALIBRATION CHECK					
K	Zero Gas Response	0.42	0.60	0.03	-0.01	
L	Upscale Gas Response	45.32	443.9	12.03	4.21	
15775	FINAL CALIBRATION ERROR CHECK					
M	Zero Gas Response	0.38	0.40	0.03	-0.02	
N	Mid Gas Response	45.27	454.1	12.15	4.29	
0	High Gas Reponse	89.88	900.3	21.94	8.75	
	riigii Gus Repolise	02.00	700.5	21.54	0.75	
P	AS MEASURED FLUE GAS CONCENTRATION	36.43	566.77	11.82	7.06	
	DIADE					
CALCULAT			200			FORMULA
1021	AVERAGE SYSTEM CALIBRATION	Securedo	No Peru	u 2005	1020075-0-57	=1. 21
Q	Zero Response	0.45	0.80	0.06	0.02	(I+K)/2
R	Upscale Response	45.41	444.35	12.09	4.17	J(J+L)/2
S	CORRECTED CONC.	36.38	579.05	11.75	7.34	E*(P-Q)/(R-Q)
	CULATIONS	50.50	573.05	111.75	7.51]= (1-0) (11-0)
	CALIBRATION GAS SELECTION, % of Range	70°				
1	Low Gas					C'*100/A
	Mid Gas	45.5	45.4	48.0	43.2	C*100/A
	High Gas	89.9			43.2	C 100/A
		07.7		990	075	D*100/A
			89.9	88.0	87.5	D*100/A
	CALIBRATION ERROR, % of Range		ES PACE	8 -8		
1	Initial Zero Gas Error	0.00	0.07	0.12	0.00	(F-B)*100/A
3	Initial Zero Gas Error Initial Low Gas Error	0.00	0.07	0.12	0.00	(F-B)*100/A (G'-C')*100/A
	Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error	0.00	0.07	0.12 0.44	0.00	(F-B)*100/A (G'-C')*100/A (G-C)*100 A
	Initial Zero Gas Error Initial Low Gas Error	0.00	0.07	0.12	0.00	(F-B)*100/A (G'-C')*100/A
	Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error	0.00 -0.05 0.01	0.07 0.06 -0.25	0.12 0.44 -0.20	0.00 0.60 0.11	(F-B)*100/A (G-C')*100/A (G-C)*100/A (H-D)*100/A
	Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error	0.00	0.07	0.12 0.44	0.00	(F-B)*100/A (G'-C')*100/A (G-C)*100 A
	Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error	0.00 -0.05 0.01 0.38	0.07 0.06 -0.25 0.04	0.12 0.44 -0.20 0.12	0.00 0.60 0.11	(F-B)*100/A (G-C')*100/A (G-C)*100/A (H-D)*100/A
	Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error	0.00 -0.05 0.01	0.07 0.06 -0.25	0.12 0.44 -0.20	0.00 0.60 0.11	(F-B)*100/A (G-C')*100/A (G-C)*100/A (H-D)*100/A (M-B)*100/A
	Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error	0.00 -0.05 0.01 0.38	0.07 0.06 -0.25 0.04	0.12 0.44 -0.20 0.12	0.00 0.60 0.11 -0.20	(F-B)*100/A (G'-C')*100/A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N'-C')*100/A
	Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error	0.00 -0.05 0.01 0.38 -0.18	0.07 0.06 -0.25 0.04 0.03 0.13	0.12 0.44 -0.20 0.12 0.56	0.00 0.60 0.11 -0.20 -0.30	(F-B)*100/A (G'-C')*100/A (G-C)*100 A (H-D)*100/A (M-B)*100 A (N'-C')*100/A (N-C)*100/A
	Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error	0.00 -0.05 0.01 0.38 -0.18	0.07 0.06 -0.25 0.04 0.03	0.12 0.44 -0.20 0.12 0.56	0.00 0.60 0.11 -0.20 -0.30	(F-B)*100/A (G'-C')*100/A (G-C)*100 A (H-D)*100/A (M-B)*100 A (N'-C')*100/A (N-C)*100/A
	Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range	0.00 -0.05 0.01 0.38 -0.18 -0.03	0.07 0.06 -0.25 0.04 0.03 0.13	0.12 0.44 -0.20 0.12 0.56 -0.20	0.00 0.60 0.11 -0.20 -0.30 0.01	(F-B)*100/A (G-C)*100/A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-[(H-F)*C]D}*100/A
	Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial	0.00 -0.05 0.01 0.38 -0.18 -0.03	0.07 0.06 -0.25 0.04 0.03 0.13	0.12 0.44 -0.20 0.12 0.56 -0.20 0.49	0.00 0.60 0.11 -0.20 -0.30 0.01 0.55	(F-B)*100/A (G-C)*100/A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-[(H-F)*C]D}*100/A
	Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial	0.00 -0.05 0.01 0.38 -0.18 -0.03	0.07 0.06 -0.25 0.04 0.03 0.13	0.12 0.44 -0.20 0.12 0.56 -0.20 0.49	0.00 0.60 0.11 -0.20 -0.30 0.01 0.55	(F-B)*100/A (G-C)*100/A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-[(H-F)*C]D}*100/A
	Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final	0.00 -0.05 0.01 0.38 -0.18 -0.03	0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06	0.12 0.44 -0.20 0.12 0.56 -0.20 0.49	0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20	(F-B)*100/A (G-C)*100/A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-[(H-F)*C]D}*100/A
	Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range	0.00 -0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35	0.07 0.06 -0.25 0.04 0.03 0.13	0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61	0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20	(F-B)*100/A (G'-C')*100/A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N'-C')*100/A (N-C)*100/A (O-D)*100/A ((G-F)-[(H-F)*C]D}*100/A ((N-M)-[(O-M)*C]/D}*100/A
	Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias	0.00 -0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35	0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06	0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61	0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20	(F-B)*100/A (G'-C')*100/A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N'-C')*100/A (N-C)*100/A (O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A {(N-M)-[(O-M)*C]/D}*100/A
	Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias	0.00 -0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35	0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06	0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61	0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20	(F-B)*100/A (G'-C')*100/A (G-C)*100 A (H-D)*100/A (M-B)*100/A (N'-C')*100/A (N-C')*100/A (O-D)*100/A ((G-F)-[(H-F)*C] D}*100/A ((N-M)-[(O-M)*C]/D}*100/A (I-F)*100/A (J-G[or G', or H]*100/A
	Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias Final Zero Gas Bias	0.00 -0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35	0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06 0.03 -0.96	0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61 0.24 0.08 0.00	0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20 0.50 -2.60 0.10	(F-B)*100/A (G-C)*100/A (G-C)*100/A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N'-C)*100/A (N'-C)*100/A (O-D)*100/A ((G-F)-[(H-F)*C]/D]*100/A ((N-M)-[(O-M)*C]/D]*100/A (I-F)*100/A (J-G[or G', or H]*100/A (K-M)*100/A
	Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias Final Zero Gas Bias Final Jero Gas Bias	0.00 -0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35	0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06	0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61 0.24 0.08	0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20 0.50 -2.60	(F-B)*100/A (G'-C')*100/A (G-C)*100 A (H-D)*100/A (M-B)*100/A (N'-C')*100/A (N-C')*100/A (O-D)*100/A ((G-F)-[(H-F)*C] D}*100/A ((N-M)-[(O-M)*C]/D}*100/A (I-F)*100/A (J-G[or G', or H]*100/A
	Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias Final Zero Gas Bias	0.00 -0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35	0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06 0.03 -0.96	0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61 0.24 0.08 0.00	0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20 0.50 -2.60 0.10	(F-B)*100/A (G-C)*100/A (G-C)*100/A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N'-C)*100/A (N'-C)*100/A (O-D)*100/A ((G-F)-[(H-F)*C]/D]*100/A ((N-M)-[(O-M)*C]/D]*100/A (I-F)*100/A (J-G[or G', or H]*100/A (K-M)*100/A



 Facility:
 OCSD, Plant No. 2
 Run No.:
 8

 City:
 Huntington Beach, CA
 Test Date:
 10/01/15

 Source:
 Engine 5
 Run Time:
 11:46-12:15

ource:	Engine 5			Run Time:	11:46-12:1	5
est:	RATA					
200000			EE 465 TES	-22422 - 5		
EST DATA	<u>A</u>	Pollutant 1	Pollutant 2	Diluent 1	Diluent 2	
VARIABLE	DESCRIPTION	NOx	CO	O2	CO2	
A	ANALYTICAL RANGE	100	1000	25	10	
1040871	Unit of Measurement	ppmd	ppmd	% dry	% dry	
		ppina	ppina	70 tily	70 ury	
	CALIBRATION GAS INFORMATION	8.06				
В	Zero Gas	0.00	0.00	0.00	0.00	
C	Mid Gas Concentration	45.45	453.8	12.01	4.32	
	Mid Gas Cylinder S/N:	XC019657B	CC39463	CC248731	CC248731	
D	High Gas Concentration	89.91	899	21.99	8.75	
-	High Gas Cylinder S/N:	CC199782	CC259973	CC408131	CC408131	
		CC199782	CC237713	CC408131	CC406131	
	Primary Gas Cylinder S/N:		450.0	10.01		
E	UPSCALE CALIBRATION GAS USED	45.45	453.8	12.01	4.32	
	L=Low, M=Mid, H=High	M	M	M	\mathbf{M}	
	INITIAL CALIBRATION ERROR TEST					
F	Zero Gas Response	0.00	0.70	0.03	0.00	
G	Mid Gas Response	45.40	454.4	12.12	4.38	
H	High Gas Reponse	89.92	896.5	21.94	8.76	
	INITIAL SYSTEM CALIBRATION CHECK			0.0		
I	Zero Gas Response	0.48	1.00	0.09	0.05	
J	Upscale Gas Response	45.50	444.8	12.14	4.12	
	FINAL SYSTEM CALIBRATION CHECK					
K	Zero Gas Response	0.42	0.60	0.03	-0.01	
		45.32	443.9	12.03		
L	Upscale Gas Response	45.34	443.7	12.03	4.21	
	FINAL CALIBRATION ERROR CHECK					
M	Zero Gas Response	0.38	0.40	0.03	-0.02	
N	Mid Gas Response	45.27	454.1	12.15	4.29	
0	High Gas Reponse	89.88	900.3	21.94	8.75	
P	AS MEASURED FLUE GAS CONCENTRATION	35.97	572.64	11.91	7.02	
ALCULAT	TIONS					FORMULA
	AVERAGE SYSTEM CALIBRATION					
Q	Zero Response	0.45	0.80	0.06	0.02	(I+K)/2
R	Upscale Response	45.41	444.35	12.09	4.17	(J+L)/2
10	Opseute Response	13.11	111.55	12.07	7.17](3.12)/2
S	CORRECTED CONC.	35.90	585.05	11.83	7.30	E*(P-Q)/(R-Q)
	LCULATIONS	33.70	000100		1.50]= (1 4)(1 4)
DOC CAL						
	CALIBRATION GAS SELECTION, % of Range	100000	200	10.0		
	Mid Gas	45.5	45.4	48.0	43.2	C*100/A
	High Gas	89.9	89.9	88.0	07 6	D*100/A
	201000700210000000		07.7	00.0	87.5	
	[CALIBRATION ERROR, % of Range		07.7	00.0	87.3	
	CALIBRATION ERROR, % of Range Initial Zero Gas Error	0.00				(F-B)*100/A
	Initial Zero Gas Error	0.00	0.07	0.12	0.00	(F-B)*100/A
	Initial Zero Gas Error Initial Mid Gas Error	-0.05	0.07 0.06	0.12 0.44	0.00 0.60	(G-C)*100/A
	Initial Zero Gas Error		0.07	0.12	0.00	
	Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error	-0.05 0.01	0.07 0.06 -0.25	0.12 0.44 -0.20	0.00 0.60 0.11	(G-C)*100/A (H-D)*100/A
	Initial Zero Gas Error Initial Mid Gas Error	-0.05 0.01 0.38	0.07 0.06	0.12 0.44 -0.20	0.00 0.60	(G-C)*100/A
	Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error	-0.05 0.01	0.07 0.06 -0.25	0.12 0.44 -0.20	0.00 0.60 0.11	(G-C)*100/A (H-D)*100/A
	Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Mid Gas Error	-0.05 0.01 0.38 -0.18	0.07 0.06 -0.25 0.04 0.03	0.12 0.44 -0.20 0.12 0.56	0.00 0.60 0.11 -0.20 -0.30	(G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A
	Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Mid Gas Error Final High Gas Error	-0.05 0.01 0.38	0.07 0.06 -0.25	0.12 0.44 -0.20	0.00 0.60 0.11 -0.20	(G-C)*100/A (H-D)*100/A (M-B)*100/A
	Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range	-0.05 0.01 0.38 -0.18 -0.03	0.07 0.06 -0.25 0.04 0.03 0.13	0.12 0.44 -0.20 0.12 0.56 -0.20	0.00 0.60 0.11 -0.20 -0.30 0.01	(G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (O-D)*100/A
	Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial	-0.05 0.01 0.38 -0.18 -0.03	0.07 0.06 -0.25 0.04 0.03 0.13	0.12 0.44 -0.20 0.12 0.56 -0.20	0.00 0.60 0.11 -0.20 -0.30 0.01	(G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A
	Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range	-0.05 0.01 0.38 -0.18 -0.03	0.07 0.06 -0.25 0.04 0.03 0.13	0.12 0.44 -0.20 0.12 0.56 -0.20	0.00 0.60 0.11 -0.20 -0.30 0.01	(G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A
	Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final	-0.05 0.01 0.38 -0.18 -0.03	0.07 0.06 -0.25 0.04 0.03 0.13	0.12 0.44 -0.20 0.12 0.56 -0.20	0.00 0.60 0.11 -0.20 -0.30 0.01	(G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A
	Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial	-0.05 0.01 0.38 -0.18 -0.03	0.07 0.06 -0.25 0.04 0.03 0.13	0.12 0.44 -0.20 0.12 0.56 -0.20	0.00 0.60 0.11 -0.20 -0.30 0.01	(G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A
	Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final	-0.05 0.01 0.38 -0.18 -0.03	0.07 0.06 -0.25 0.04 0.03 0.13	0.12 0.44 -0.20 0.12 0.56 -0.20	0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20	(G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A
	Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Mid Gas Error Final High Gas Error LINEARITY. % of Range Initial Final SAMPLING SYSTEM BIAS. % of Range Initial Zero Gas Bias	-0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35	0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06	0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61	0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20	(G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A {(N-M)-[(O-M)*C]/D}*100/A (I-F)*100/A
	Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range	-0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35	0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06	0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61	0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20	(G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A {(N-M)-[(O-M)*C]/D}*100/A
	Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias	-0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35	0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06	0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61	0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20	(G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A {(N-M)-[(O-M)*C]/D}*100/A (I-F)*100/A (J-G[or G', or H]*100/A
	Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias Final Zero Gas Bias	-0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35 0.48 0.10	0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06	0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61	0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20 0.50 -2.60	(G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A {(N-M)-[(O-M)*C]/D}*100/A (I-F)*100/A (J-G[or G', or H]*100/A
	Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias Final Zero Gas Bias Final Jero Gas Bias Final Jero Gas Bias	-0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35	0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06	0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61	0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20	(G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A {(N-M)-[(O-M)*C]/D}*100/A (I-F)*100/A (J-G[or G', or H]*100/A
	Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Mid Gas Error Final Mid Gas Error LINEARITY. % of Range Initial Final SAMPLING SYSTEM BIAS. % of Range Initial Zero Gas Bias Initial Upscale Gas Bias Final Zero Gas Bias Final Jero Gas Bias CALIBRATION DRIFT. % of Range	-0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35 0.48 0.10 0.04 0.05	0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06 0.03 -0.96	0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61 0.24 0.08	0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20 0.50 -2.60	(G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A {(N-M)-[(O-M)*C]/D}*100/A (I-F)*100/A (J-G[or G', or H]*100/A (K-M)*100/A (L-N[or N', or O]*100/A
	Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias Final Zero Gas Bias Final Jero Gas Bias Final Jero Gas Bias	-0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35 0.48 0.10	0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06	0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61	0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20 0.50 -2.60	(G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-[(H-F)*C]/D}*100/A {(N-M)-[(O-M)*C]/D}*100/A (I-F)*100/A (J-G[or G', or H]*100/A



Facility: City: Source:

OCSD, Plant No. 2 Huntington Beach, CA Run No.: 9
Test Date: 10/01/15
Run Time: 12:16-12:45 Engine 5 RATA

Run No.:

mk.	Engine 5			Run Time:	12:16-12:4:	5
est:	RATA					
COT DAT	•	Dollutant 1	Dollutont 2	Diluent 1	Dil 2	
EST DATA	77 /	Pollutant 1	Pollutant 2		Diluent 2	
VARIABLE	DESCRIPTION	NOx	CO	<u>O2</u>	CO2	
A	ANALYTICAL RANGE	100	1000	25	10	
	Unit of Measurement	ppmd	ppmd	% dry	% dry	
	CALIBRATION GAS INFORMATION					
В	Zero Gas	0.00	0.00	0.00	0.00	
C	Mid Gas Concentration	45.45	453.8	12.01	4.32	
	Mid Gas Cylinder S/N:	XC019657B	CC39463	CC248731	CC248731	
D	High Gas Concentration	89.91	899	21.99	8.75	
	High Gas Cylinder S/N:	CC199782	CC259973	CC408131	CC408131	
	Primary Gas Cylinder S/N:					
E	UPSCALE CALIBRATION GAS USED	45.45	453.8	12.01	4.32	
	L=Low, M=Mid, H=High	M	M	M	M	
	INITIAL CALIBRATION ERROR TEST					
F	Zero Gas Response	0.00	0.70	0.03	0.00	
	이 것 그렇게 하지 않아야 있었다. 아니를 이 제공하다 하다	45.40	454.4	12.12	4.38	
G	Mid Gas Response	89.92	896.5	21.94		
H	High Gas Reponse	69.92	090.3	21.94	8.76	
	INITIAL SYSTEM CALIBRATION CHECK	0.40	1.00	0.00	0.05	
I	Zero Gas Response	0.48	1.00	0.09	0.05	
J	Upscale Gas Response	45.50	444.8	12.14	4.12	
	FINAL SYSTEM CALIBRATION CHECK				213	
K	Zero Gas Response	0.42	0.60	0.03	-0.01	
L	Upscale Gas Response	45.32	443.9	12.03	4.21	
	FINAL CALIBRATION ERROR CHECK					
M	Zero Gas Response	0.38	0.40	0.03	-0.02	
N	Mid Gas Response	45.27	454.1	12.15	4.29	
0	High Gas Reponse	89.88	900.3	21.94	8.75	
6.50	0					
P	AS MEASURED FLUE GAS CONCENTRATION	36.60	561.82	11.88	7.03	
LCULAT	TIONS					FORMULA
LIC CLIFT	AVERAGE SYSTEM CALIBRATION					1
0	Zero Response	0.45	0.80	0.06	0.02	(I+K)/2
Q	5 C 20 C C C C C C C C C C C C C C C C C					
R	Upscale Response	45.41	444.35	12.09	4.17	(J+L) 2
S	CONDECTED COVIC	36.55	573.98	11.81	7.31	Tetra over ov
	CORRECTED CONC.	30.33	313.90	11.01	7.31	E*(P-Q)/(R-Q)
/QC CAL	CULATIONS					
VQC CAL	CALIBRATION GAS SELECTION, % of Range					Sittle and the
VQC CAI		2014 AN		1442-244		C'*100/A
VQC CAL	CALIBRATION GAS SELECTION, % of Range	45.5	45.4	48.0	43.2	C'*100/A C*100/A
JQC CAL	CALIBRATION GAS SELECTION, % of Range Low Gas	45.5 89.9	45.4 89.9	48.0 88.0	43.2 87.5	
VQC CAL	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas					C*100/A
VQC CAL	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas					C*100/A D*100/A
VQC CAI	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error	89.9	89.9	88.0	87.5	C*100/A D*100/A (F-B)*100/A
VQC CAI	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Low Gas Error	0.00	0.07	0.12	0.00	C*100/A D*100/A (F-B)*100/A (G'-C')*100 A
VQC CAI	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error	0.00 -0.05	0.07 0.06	0.12 0.44	0.00 0.60	C*100/A D*100/A (F-B)*100/A (G-C)*100/A (G-C)*100/A
VQC CAI	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Low Gas Error	0.00	0.07	0.12	0.00	C*100/A D*100/A (F-B)*100/A (G'-C')*100 A
VQC CAI	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error	0.00 -0.05 0.01	89.9 0.07 0.06 -0.25	0.12 0.44 -0.20	0.00 0.60 0.11	C*100/A D*100/A (F-B)*100/A (G-C)*100/A (G-C)*100/A (H-D)*100/A
VQC CAI	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error	0.00 -0.05	0.07 0.06	0.12 0.44	0.00 0.60	C*100/A D*100/A (F-B)*100/A (G-C)*100/A (G-C)*100/A (H-D)*100/A (M-B)*100/A
VQC CAI	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error	89.9 0.00 -0.05 0.01 0.38	89.9 0.07 0.06 -0.25 0.04	0.12 0.44 -0.20 0.12	0.00 0.60 0.11 -0.20	C*100/A D*100/A (F-B)*100/A (G-C)*100 A (G-C)*100/A (H-D)*100/A
VOC CAL	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Low Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Low Gas Error Final Low Gas Error Final Mid Gas Error	89.9 0.00 -0.05 0.01 0.38 -0.18	89.9 0.07 0.06 -0.25 0.04 0.03	88.0 0.12 0.44 -0.20 0.12 0.56	87.5 0.00 0.60 0.11 -0.20 -0.30	C*100/A D*100/A (F-B)*100/A (G'-C)*100/A (G-C)*100/A (H-D)*100/A (M'-B)*100/A (N'-C)*100/A (N'-C)*100/A
OC CAL	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final High Gas Error Final High Gas Error	89.9 0.00 -0.05 0.01 0.38	89.9 0.07 0.06 -0.25 0.04	0.12 0.44 -0.20 0.12	0.00 0.60 0.11 -0.20	C*100/A D*100/A (F-B)*100/A (G-C)*100/A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N'-C)*100/A
VOC CAL	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Low Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Low Gas Error Final Low Gas Error Final Mid Gas Error	89.9 0.00 -0.05 0.01 0.38 -0.18	89.9 0.07 0.06 -0.25 0.04 0.03	88.0 0.12 0.44 -0.20 0.12 0.56	87.5 0.00 0.60 0.11 -0.20 -0.30	C*100/A D*100/A (F-B)*100/A (G'-C)*100/A (G-C)*100/A (H-D)*100/A (M'-B)*100/A (N'-C')*100/A (N'-C')*100/A
OC CAL	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final High Gas Error Final High Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range	89.9 0.00 -0.05 0.01 0.38 -0.18 -0.03	89.9 0.07 0.06 -0.25 0.04 0.03	88.0 0.12 0.44 -0.20 0.12 0.56	87.5 0.00 0.60 0.11 -0.20 -0.30 0.01	C*100/A D*100/A (F-B)*100/A (G-C')*100 A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C')*100/A (N-C)*100/A (O-D)*100/A
OC CAL	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final High Gas Error Final High Gas Error Final Mid Gas Error Final Mid Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial	89.9 0.00 -0.05 0.01 0.38 -0.18 -0.03	89.9 0.07 0.06 -0.25 0.04 0.03 0.13	88.0 0.12 0.44 -0.20 0.12 0.56 -0.20 0.49	87.5 0.00 0.60 0.11 -0.20 -0.30 0.01 0.55	C*100/A D*100/A (F-B)*100/A (G-C)*100/A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N'-C)*100/A (N-C)*100/A ((O-D)*100/A ((G-F)-[(H-F)*C]/D)*100/A
VOC CAL	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final High Gas Error Final High Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range	89.9 0.00 -0.05 0.01 0.38 -0.18 -0.03	89.9 0.07 0.06 -0.25 0.04 0.03 0.13 0.15	88.0 0.12 0.44 -0.20 0.12 0.56 -0.20	87.5 0.00 0.60 0.11 -0.20 -0.30 0.01	C*100/A D*100/A (F-B)*100/A (G-C)*100 A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N'-C)*100/A (N-C)*100/A (O-D)*100/A ((G-F)-[(H-F)*C]/D)*100/A
VOC CAL	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Low Gas Error Final High Gas Error Final High Gas Error Final High Gas Error Final High Gas Error LINEARITY, % of Range Initial Final	89.9 0.00 -0.05 0.01 0.38 -0.18 -0.03	89.9 0.07 0.06 -0.25 0.04 0.03 0.13 0.15	88.0 0.12 0.44 -0.20 0.12 0.56 -0.20 0.49	87.5 0.00 0.60 0.11 -0.20 -0.30 0.01 0.55	C*100/A D*100/A (F-B)*100/A (G-C)*100 A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N'-C)*100/A (N-C)*100/A (O-D)*100/A ((G-F)-[(H-F)*C]/D)*100/A
OC CAL	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Low Gas Error Initial High Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final High Gas Error Final High Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range	89.9 0.00 -0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35	89.9 0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06	88.0 0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61	87.5 0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20	C*100/A D*100/A (F-B)*100/A (G-C)*100 A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-{(H-F)*C}/D}*100/A {(N-M)-{(O-M)*C} D}*100/A
OC CAL	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final High Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias	89.9 0.00 -0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35	89.9 0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06	88.0 0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61	87.5 0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20	C*100/A D*100/A (F-B)*100/A (G-C)*100 A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (N-C)*100/A (O-D)*100/A ((G-F)-{(H-F)*C]/D}*100/A ((N-M)-[(O-M)*C] D}*100/A
MQC CAL	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Low Gas Error Initial High Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final High Gas Error Final High Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range	89.9 0.00 -0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35	89.9 0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06	88.0 0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61	87.5 0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20	C*100/A D*100/A (F-B)*100/A (G-C)*100 A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (N-C)*100/A (O-D)*100/A {(G-F)-{(H-F)*C}/D}*100/A {(N-M)-{(O-M)*C} D}*100/A
VOC CAL	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final High Gas Error Final Mid Gas Error Final Mid Gas Error Final Mid Gas Error Final Mid Gas Error Final Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias	89.9 0.00 -0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35	89.9 0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06	88.0 0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61 0.24 0.08	87.5 0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20 0.50 -2.60	C*100/A D*100/A (F-B)*100/A (G-C)*100/A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N'-C)*100/A (N-C)*100/A (O-D)*100/A ((G-F)-[(H-F)*C]/D]*100/A {(N-M)-[(O-M)*C] D]*100/A (I-F)*100/A (J-G[or G', or H]*100/A
VQC CAL	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Low Gas Error Final High Gas Error Final Mid Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias Final Zero Gas Bias	89.9 0.00 -0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35 0.48 0.10 0.04	89.9 0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06 0.03 -0.96 0.02	88.0 0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61 0.24 0.08	87.5 0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20 0.50 -2.60 0.10	C*100/A D*100/A (F-B)*100/A (G-C)*100 A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (N-C)*100/A (O-D)*100/A ((G-F)-[(H-F)*C]/D]*100/A ((N-M)-[(O-M)*C] D]*100/A (J-G[or G', or H]*100/A (K-M)*100 A
VQC CAL	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias Final Zero Gas Bias Final Zero Gas Bias Final Upscale Gas Bias	89.9 0.00 -0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35	89.9 0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06	88.0 0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61 0.24 0.08	87.5 0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20 0.50 -2.60	C*100/A D*100/A (F-B)*100/A (G-C)*100 A (G-C)*100 A (G-C)*100/A (H-D)*100/A (M'-C)*100/A (N'-C)*100/A (O-D)*100/A ((G-F)-{(H-F)*C]/D}*100/A ((N-M)-[(O-M)*C] D}*100/A (I-F)*100/A (J-G[or G', or H]*100/A
MQC CAL	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Low Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final High Gas Error Final Mid Gas Error Final Mid Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias Final Zero Gas Bias Final Zero Gas Bias Final Upscale Gas Bias CALIBRATION DRIFT, % of Range	89.9 0.00 -0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35 0.48 0.10 0.04 0.05	89.9 0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06 0.03 -0.96 0.02 -1.02	0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61 0.24 0.08 0.00 -0.48	87.5 0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20 0.50 -2.60 0.10 -0.80	C*100/A D*100/A D*100/A (F-B)*100/A (G-C)*100/A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (N-C)*100/A (O-D)*100/A ((G-F)-[(H-F)*C]/D]*100/A ((I-F)*100/A (J-G[or G', or H]*100/A (K-M)*100 A (L-N[or N', or O]*100/A
VOC CAL	CALIBRATION GAS SELECTION, % of Range Low Gas Mid Gas High Gas CALIBRATION ERROR, % of Range Initial Zero Gas Error Initial Mid Gas Error Initial High Gas Error Final Zero Gas Error Final Low Gas Error Final Low Gas Error Final Mid Gas Error Final High Gas Error LINEARITY, % of Range Initial Final SAMPLING SYSTEM BIAS, % of Range Initial Zero Gas Bias Initial Upscale Gas Bias Final Zero Gas Bias Final Zero Gas Bias Final Upscale Gas Bias	89.9 0.00 -0.05 0.01 0.38 -0.18 -0.03 -0.06 -0.35 0.48 0.10 0.04	89.9 0.07 0.06 -0.25 0.04 0.03 0.13 0.15 -0.06 0.03 -0.96 0.02	88.0 0.12 0.44 -0.20 0.12 0.56 -0.20 0.49 0.61 0.24 0.08	87.5 0.00 0.60 0.11 -0.20 -0.30 0.01 0.55 -0.20 0.50 -2.60 0.10	C*100/A D*100/A (F-B)*100/A (G-C)*100/A (G-C)*100/A (H-D)*100/A (M-B)*100/A (N-C)*100/A (N-C)*100/A (O-D)*100/A ((G-F)-[(H-F)*C]/D]*100/A ((N-M)-[(O-M)*C] D]*100/A (J-G[or G', or H]*100/A (K-M)*100/A



			RUN 1.0			1			RUN 2.0		
	Time	NOx	CO	O2	CO2		Time	NOx	CO	O2	CO2
#	AVG	34.13	584.83	11.85	7.57	#	AVG	36.04	567.77	11.85	7.67
				44.00			0.10.00	26.25	555.00	11.70	7.74
1	7:43:03	33.09	594.80	11.80	7.44	1	8:13:03	36.35	555.80	11.69	7.74
2	7:44:03	34.06	586.60	11.76	7.50	2	8:14:03	36.10	553.60	11.72	7.76
3	7:45:03	33.31	593.90	11.81	7.50	3	8:15:03	36.34	556.80	11.74	7.75
4	7:46:03	33.21	590.20	11.82	7.50	4	8:16:03	36.75	547.20	11.73	7.75
5	7:47:03	33.19	598.90	11.85	7.51	5	8:17:03	36.38	550.10	11.72	7.75
6	7:48:03	34.06	583.50	11.84	7.52	6	8:18:03	37.00	550.80	11.73	7.75
7	7:49:03	33.03	592.70	11.89	7.51	7	8:19:03	36.66	551.60	11.77	7.75
8	7:50:03	32.73	608.30	11.91	7.45	8	8:20:03	35.73	565.40	11.86	7.66
9	7:51:03	33.41	592.00	11.80	7.57	9	8:21:03	35.50	573.00	11.88	7.66
10	7:52:03	33.43	582.50	11.88	7.55	10	8:22:03	36.39	566.90	11.81	7.66
11	7:53:03	33.47	592.00	11.82	7.55	11	8:23:03	36.61	554.50	11.82	7.67
12	7:54:03	34.01	586.30	11.81	7.59	12	8:24:03	35.34	566.90	11.86	7.67
13	7:55:03	33.60	588.40	11.91	7.55	13	8:25:03	35.45	573.50	11.83	7.67
14	7:56:03	33.56	585.70	11.90	7.54	14	8:26:03	35.32	572.20	11.86	7.67
15	7:57:03	34.86	585.70	11.85	7.56	15	8:27:03	35.21	581.10	11.90	7.66
16	7:58:03	34.62	572.30	11.87	7.58	16	8:28:03	36.11	566.40	11.85	7.67
17	7:59:03	34.15	596.30	11.94	7.53	17	8:29:03	35.78	562.70	11.90	7.65
18	8:00:03	34.58	585.30	11.92	7.54	18	8:30:03	36.73	560.90	11.75	7.71
19	8:01:03	34.21	580.80	11.95	7.54	19	8:31:03	36.44	564.80	11.79	7.73
20	8:02:03	34.64	584.60	11.88	7.56	20	8:32:03	35.77	570.70	11.89	7.70
21	8:03:03	33.99	588.70	11.93	7.58	21	8:33:03	36.29	569.20	11.84	7.67
22	8:04:03	33.51	604.70	11.94	7.54	22	8:34:03	35.96	574.30	11.90	7.67
23	8:05:03	34.66	589.30	11.86	7.61	23	8:35:03	35.94	574.90	11.94	7.65
24	8:06:03	34.51	580.10	11.85	7.63	24	8:36:03	36.57	573.10	11.93	7.65
25	8:07:03	34.32	587.30	11.91	7.59	25	8:37:03	35.86	573.30	12.01	7.60
26	8:08:03	35.76	573.00	11.77	7.66	26	8:38:03	35.80	580.60	11.99	7.56
27	8:09:03	35.47	565.40	11.77	7.68	27	8:39:03	35.45	583.20	12.03	7.57
28	8:10:03	35.62	559.50	11.76	7.70	28	8:40:03	36.66	581.20	11.88	7.64
29	8:11:03	35.17	560.70	11.77	7.70	29	8:41:03	35.72	577.30	11.96	7.63
30	8:12:03	35.77	555.40	11.75	7.71	30	8:42:03	35.03	601.10	12.01	7.57



Г			RUN 3.0			7 [RUN 4.0		
- 1	Time	NOx	CO	O2	CO2	7 [Time	NOx	CO	O2	CO2
#	AVG	36.54	573.90	11.93	7.64	#	AVG	35.18	580.09	11.89	6.99
1	8:43:03	35.96	589.80	11.93	7.61	1	9:31:03	37.86	564.00	11.62	7.03
2	8:44:03	36.64	571.90	11.91	7.65	2	9:32:03	37.07	568.60	11.72	7.05
3	8:45:03	36.04	576.20	11.97	7.63	3	9:33:03	36.43	577.80	11.76	7.05
4	8:46:03	36.17	578.90	11.94	7.63	4	9:34:03	35.88	583.40	11.84	7.04
5	8:47:03	36.58	580.40	11.90	7.62	5	9:35:03	35.56	580.40	11.92	6.99
6	8:48:03	36.88	565.70	11.92	7.63	6	9:36:03	35.73	578.50	11.87	7.00
7	8:49:03	37.16	566.80	11.90	7.65	7	9:37:03	34.96	585.80	11.99	6.95
8	8:50:03	36.60	575.40	11.97	7.64	8	9:38:03	34.70	582.30	12.01	6.91
9	8:51:03	36.41	577.50	11.96	7.62	9	9:39:03	35.00	583.20	11.94	6.92
10	8:52:03	35.87	583.60	12.00	7.61	10	9:40:03	35.43	583.00	11.86	6.99
11	8:53:03	36.25	580.20	11.97	7.61	11	9:41:03	35.43	575.30	11.92	6.99
12	8:54:03	36.12	572.60	11.99	7.61	12	9:42:03	34.93	576.20	12.00	6.94
13	8:55:03	36.37	572.10	12.02	7.59	13	9:43:03	35.01	584.60	11.85	6.98
14	8:56:03	36.79	566.90	11.94	7.60	14	9:44:03	35.11	583.20	11.87	7.00
15	8:57:03	38.02	564.90	11.87	7.66	15	9:45:03	35.36	583.10	11.86	7.00
16	8:58:03	37.07	558.90	11.95	7.66	16	9:46:03	35.27	572.80	11.94	6.99
17	8:59:03	36.83	567.10	11.92	7.64	17	9:47:03	34.84	572.10	11.94	6.97
18	9:00:03	36.62	570.00	11.93	7.65	18	9:48:03	35.06	586.30	11.92	6.97
19	9:01:03	36.27	571.70	11.93	7.64	19	9:49:03	34.62	573.70	11.98	6.96
20	9:02:03	36.38	582.20	11.94	7.64	20	9:50:03	34.20	588.70	11.96	6.92
21	9:03:03	36.04	583.80	11.98	7.64	21	9:51:03	35.56	588.80	11.78	7.04
22	9:04:03	35.90	581.50	11.94	7.64	22	9:52:03	35.52	578.00	11.80	7.07
23	9:05:03	36.26	581.20	11.89	7.67	23	9:53:03	34.66	583.30	11.91	7.03
24	9:06:03	36.65	578.30	11,86	7.68	24	9:54:03	35.21	575.50	11.86	7.03
25	9:07:03	36.62	569.90	11.88	7.69	25	9:55:03	34.17	572.00	11.99	6.96
26	9:08:03	36.68	566.00	11.91	7.69	26	9:56:03	33.58	599.00	11.99	6.92
27	9:09:03	37.15	567.10	11.87	7.67	27	9:57:03	34.34	580.20	11.93	6.97
28	9:10:03	36.98	563.30	11.88	7.68	28	9:58:03	34.33	582.80	11.95	6.97
29	9:11:03	36.74	569.20	11.91	7.69	29	9:59:03	34.63	581.40	11.89	6.97
30	9:12:03	36.07	583.90	11.92	7.66	30	10:00:03	34.99	578.80	11.90	6.99



			RUN 5.0			7 [RUN 6.0		
	Time	NOx	CO	O2	CO2	1 [Time	NOx	CO	O2	CO2
#	AVG	35.77	568.94	11.92	7.00	#	AVG	36.00	571.03	11.99	6.95
1	10:01:03	34.51	573.90	11.95	6.98	1	10:31:03	35.60	567.80	11.92	6.97
2	10:02:03	34.88	572.50	11.92	6.97	2	10:32:03	36.81	561.10	11.92	7.00
3	10:03:03	34.93	569.70	11.89	7.01	3	10:33:03	36.34	552.90	11.97	6.96
4	10:04:03	34.62	577.70	11.98	6.99	4	10:34:03	36.36	569.90	11.94	6.97
5	10:05:03	34.78	578.70	11.95	6.98	5	10:35:03	36.31	561.30	12.00	6.97
6	10:06:03	35.39	580.90	11.89	6.98	6	10:36:03	36.52	563.00	11.93	7.00
7	10:07:03	35.00	574.70	11.89	6.99	7	10:37:03	35.86	568.40	11.97	6.99
8	10:08:03	34.85	580.20	11.87	7.00	8	10:38:03	35.79	573.50	12.00	6.95
9	10:09:03	35.08	578.00	11.91	7.01	9	10:39:03	36.23	565.70	11.99	6.95
10	10:10:03	36.08	573.60	11.91	6.98	10	10:40:03	35.56	568.30	12.11	6.89
11	10:11:03	37.35	543.80	11.87	7.02	11	10:41:03	36.35	574.00	11.98	6.92
12	10:12:03	37.32	554.40	11.79	7.04	12	10:42:03	36.52	572.40	11.92	6.99
13	10:13:03	36.61	566.50	11.86	7.05	13	10:43:03	36.10	577.60	11.97	6.99
14	10:14:03	36.16	569.40	11.86	7.05	14	10:44:03	35.43	579.20	12.06	6.92
15	10:15:03	35.95	573.40	11.89	7.05	15	10:45:03	35.71	579.90	12.03	6.92
16	10:16:03	36.03	567.00	11.96	6.99	16	10:46:03	35.43	574.60	12.05	6.89
17	10:17:03	36.25	567.40	11.90	6.99	17	10:47:03	35.45	582.30	12.01	6.93
18	10:18:03	35.71	571.60	11.92	7.00	18	10:48:03	35.30	586.20	12.01	6.94
19	10:19:03	35.88	568.10	11.94	7.00	19	10:49:03	36.01	578.90	11.99	6.96
20	10:20:03	35.66	568.30	11.96	6.96	20	10:50:03	36.58	572.30	11.97	6.96
21	10:21:03	36.65	564.80	11.83	7.04	21	10:51:03	35.30	574.90	12.12	6.85
22	10:22:03	36.32	569.90	11.86	7.07	22	10:52:03	36.10	572.70	12.00	6.91
23	10:23:03	36.12	566.90	11.92	7.03	23	10:53:03	36.04	575.70	11.97	6.93
24	10:24:03	35.76	573.10	11.92	7.02	24	10:54:03	36.46	567.20	12.01	6.93
25	10:25:03	35.63	564.50	12.04	6.97	25	10:55:03	36.87	565.00	11.97	6.97
26	10:26:03	35.86	562.00	11.99	6.94	26	10:56:03	35.79	568.50	12.01	6.91
27	10:27:03	36.36	562.80	11.93	6.99	27	10:57:03	35.89	572.00	11.97	6.97
28	10:28:03	35.96	559.50	11.97	6.99	28	10:58:03	36.20	567.60	11.92	6.99
29	10:29:03	35.75	569.40	11.98	6.99	29	10:59:03	35.55	567.30	12.04	6.94
30	10:30:03	35.76	565.50	12.00	6.93	30	11:00:03	35.64	570.60	11.98	6.94



- 1			RUN 7.0			1 [RUN 8.0		
	Time	NOx	CO	O2	CO2	1	Time	NOx	CO	O2	CO2
#	AVG	36.43	566.77	11.82	7.06	#	AVG	35.97	572.64	11.91	7.02
1	11:16:03	36.15	575.20	11.67	7.03	1	11:46:03	35.94	570.20	11.93	7.04
2	11:17:03	35.71	581.30	11.73	7.03	2	11:47:03	36.03	577.30	11.92	7.00
3	11:18:03	36.29	574.50	11.72	7.07	3	11:48:03	36.10	579.20	11.94	7.00
4	11:19:03	35.91	565.70	11.78	7.07	4	11:49:03	35.62	574.70	11.94	7.00
5	11:20:03	35.78	572.10	11.79	7.07	5	11:50:03	36.64	573.20	11.87	7.06
6	11:21:03	36.74	564.60	11.74	7.08	6	11:51:03	35.91	571.70	11.94	7.02
7	11:22:03	36.71	560.00	11.77	7.10	7	11:52:03	36.16	577.50	11.91	7.02
8	11:23:03	36.68	564.90	11.77	7.10	8	11:53:03	36.04	566.40	11.93	7.01
9	11:24:03	37.16	554.60	11.79	7.07	9	11:54:03	35.90	570.70	11.91	7.01
10	11:25:03	37.56	551.70	11.76	7.08	10	11:55:03	36.66	567.00	11.83	7.05
11	11:26:03	36.84	558.70	11.76	7.09	11	11:56:03	36.32	559.30	11.89	7.04
12	11:27:03	36.06	564.00	11.84	7.08	12	11:57:03	35.88	570.50	11.86	7.03
13	11:28:03	36.52	564.70	11.82	7.06	13	11:58:03	36.41	569.60	11.83	7.05
14	11:29:03	36.28	560.00	11.91	7.03	14	11:59:03	35.59	570.90	11.96	7.00
15	11:30:03	36.37	567.20	11.83	7.03	15	12:00:03	35.32	575.70	11.95	6.99
16	11:31:03	36.69	562.30	11.83	7.05	16	12:01:03	34.90	582.20	11.96	6.99
17	11:32:03	36.29	569.70	11.85	7.05	17	12:02:03	35.49	581.30	11.91	7.00
18	11:33:03	37.09	561.90	11.84	7.05	18	12:03:03	35.36	577.00	11.96	7.02
19	11:34:03	36.60	562.40	11.90	7.03	19	12:04:03	35.96	569.20	11.90	7.02
20	11:35:03	36.01	566.30	11.89	7.04	20	12:05:03	35.90	570.30	11.88	7.05
21	11:36:03	36.50	574.80	11.82	7.05	21	12:06:03	35.36	580.10	11.96	7.01
22	11:37:03	36.04	566.40	11.92	7.04	22	12:07:03	36.12	572.80	11.88	7.03
23	11:38:03	36.19	571.70	11.84	7.05	23	12:08:03	36.84	567.60	11.81	7.06
24	11:39:03	36.25	568.10	11.82	7.08	24	12:09:03	36.15	560.60	11.95	7.04
25	11:40:03	35.82	574.40	11.94	7.05	25	12:10:03	35.97	582.10	11.91	7.01
26	11:41:03	36.71	567.10	11.83	7.07	26	12:11:03	36.17	576.50	11.90	7.03
27	11:42:03	36.66	565.30	11.89	7.06	27	12:12:03	36.00	577.20	11.87	7.03
28	11:43:03	36.56	565.10	11.88	7.04	28	12:13:03	36.16	566.90	11.91	7.04
29	11:44:03	36.27	572.40	11.82	7.08	29	12:14:03	35.89	571.60	11.90	7.02
30	11:45:03	36.58	576.00	11.85	7.08	30	12:15:03	36.18	569.90	11.88	7.03




T			RUN 9.0		7
	Time	NOx	CO	O2	CO2
#	AVG	36.60	561.82	11.88	7.03
ī	12:16:03	36.59	563.60	11.87	7.05
2	12:17:03	36.84	566.70	11.83	7.05
3	12:18:03	35.36	577.60	12.00	6.95
4	12:19:03	36.30	577.20	11.88	7.03
5	12:20:03	35.65	574.80	11.99	6.95
6	12:21:03	36.01	568.20	11.94	7.00
7	12:22:03	36.42	569.90	11.84	7.04
8	12:23:03	35.85	569.20	11.89	7.05
9	12:24:03	35.24	577.50	11.96	7.03
10	12:25:03	35.75	578.10	11.94	7.00
11	12:26:03	35.55	570.60	11.96	7.00
12	12:27:03	36.80	568.50	11.85	7.05
13	12:28:03	36.89	549.50	11.85	7.08
14	12:29:03	36.91	553.50	11.81	7.08
15	12:30:03	37.31	552.60	11.79	7.08
16	12:31:03	36.88	553.80	11.81	7.08
17	12:32:03	36.76	552.90	11.92	7.04
18	12:33:03	36.38	557.10	11.89	7.04
19	12:34:03	35.92	568.50	11.98	7.00
20	12:35:03	36.58	563.80	11.90	7.04
21	12:36:03	36.74	561.90	11.84	7.03
22	12:37:03	36.99	558.20	11.87	7.03
23	12:38:03	38.00	545.70	11.77	7.10
24	12:39:03	37.41	551.70	11.82	7.09
25	12:40:03	36,99	552.10	11.90	7.03
26	12:41:03	36.87	552.20	11.89	7.00
27	12:42:03	37.65	553.30	11.85	7.02
28	12:43:03	37.36	548.60	11.85	7.03
29	12:44:03	36.98	555.60	11.87	7.04
30	12:45:03	37.10	561.60	11.85	7.03




Appendix D2


CEMS – Strip Chart


	++++	+++	+++	++	+	+++	+++	+	+	+++	+++	H	++-	H	4	1	+	+++		+++	+++	++	+	H	+			No	1	-	1	6
		111												3	Sylvan					111					10	1			1		TII	
				14	191		111					4,	sal	3	100				18	100		111				9.	88	111		Ш		111
FITTE															4													111	111		111	1111
				-11	11	111	State of	7			7	H	T	runes	-		er-ole	1	+++	111	-	espression.			Carried Sec.	an me	111	111	111	411		
HOMUGI		111	11	4	11-	115	111		07:	111	-#	+++	+	++	+	-	1	+	HH	+++	++1	+1-		+++	1	1	Wan	10	0	2	00	2
111111	2719	992	911	3	0.2	111	1119	= 1	600	77	111	101	4		89	1 71	19	MAM	114		P	1 3	MONP	种	11	1		117	TII	111	111	MI
		111	111	11	1	1		H			111	11	1-1							111		111				19	Ha		SET	4		
++	+	Tit	11	H	1	111	1111	Н	ITT	1		11	11	11		11	111	111	ITI	111	111	111	111	TIT	11	III	1111	171			1	TTT
			111						1	111					111			111									1111					
HUNCH		111	Di	1		115			05:	\$4		-			1	1				111			kti The se		1	1	1	111	111	111	44	1111
		144	1	11	144	111	119	9 2	PH	FT	111	1			03	11,	1	7011		111	171	17-	MUMP	TTI		1	08			1	111	co
01111	1111	111	111	id	100		Hii					1	11			11		111	1 1 4	41	111	111			11	1	3	1	ψο	X	19	A.
44444		+++		+	++	HH	+++	H	++	++-	+	H	++-	+	1			111		111	-11-1		-1-1-1-	11	+			111	+		111	1131
	ĦĦ	111	111	1	1	Hi					-		100		100	1				-		DE U	11				1111	1		11	1	1111
MAHUAL	1111		10	3	01:	115			967	55				11											10		00	Ek	and a	6		1111
141111	PIG	342	111	T	10/2	111	1119	# 1.4 1.4	000	73		P				7	141	PA	14		1	= 40	Ankb	79	17		00	III	M	4		1 1
		1	11	id	08				1			1	211						111	1		11				1	1991			1		1
	111		111	+1	4	111		11	++	+	111	1	+	1	++	+	11	+11	111	+1-1	+++		+++	1-	++		1-1-	1-1-1		-++	+11	111
		111	111	11										11			11				111	11		111	11							
#ANUAH		111	P	1	41 =	125		1 1 5	061	52		1	-			0 40	11			TII		de	while		1	1	1111		111	111	111	
	110	1	117	1	20	TIT	1111	3	Carried Street	1		4		-	1	Liberary lak	ō			60	111		70		11	1 8	30	111	TIT	90	TIT	
	1171		111	H	ĬĬ			11	ĬI	111		111	44	1			111	111		111	111	111	111		16	1	DOX		200	do	111	111
			111					Ш					11	Ш				111			111		44	Ш	1	11	TY	111	mhand		de la la	
BUNEGA	ENV.	111	111	II		111							11	11		11					111							28		111		2 2
	delke	r S			11	111	1111						11							111							1111	111	111	111		
tonness:	= + +	900	30	+	+	+++	++++	+	++	++	+	+	+	1	1	++	111	+++	111	111	+++	11	TT	111	1	+	HH	+++	111	111	111	
114 188	9 + 40	9								111				H	Ш			111	11-11	111	111				11						111	
					Ш			-								•••••												111	-111		44	44
				1			Al	m	ega	2																		111			111	1111
					11		Proj	ject	No.		984	9				-							10/01						111	111	111	
+++++	+++		++	++	++	1	Faci				Ora	nge	Cour	nty !	Sani	tation	n Dis	strict	PR				Hunti		n Bea	ach,	CA	111	1	111	111	1111
			111	11	1		Unit	t:			Plan	nt 2 -	- Eng	gine	5							am:	T.Tr./	L.B.				111	111	111	111	
		111	111			11	Test	t:									ATA	s - Rul	le 218	/218.	1							111				
THIT	TITI	TH		T	T	П							Info	orm	atio				т • •		2.1.4			T7	D					111	111	1111
1111111	1111				11	1	Typ			_		ang	e				nc.		Jnit		Cyl. #				05/2			111				
1111111	1111	111	444	11	4	4	02 (_			25		_	_		.01		%		2487. 24081.		-		/21/2:		-1	111	4	+++	+++	444
		1 1 1	111	11			O2 (0			25 10					32		%		2487		117		05/2						111	A A
	1111	111	111	1 1		1				-		10					749		%		4081				/21/2:			111			111	120
							1000) (H	1				44.00	_			.45		PM		01965		dil.	06/	/09/1			TH	111		111	MIN
				++	#	H	CO2									13				CC	1997	20						The second second		6 1 1	1))	
				#			NOx	x (M	f)			100 100					.91	ŀ	PM	_	_	_			/07/2			111	111			00
					$\frac{1}{1}$		NOx NOx	х (М х (Н	f) ()			100	TF			89	3.8	P	PM	C	C3946	3		12/	/02/2:	2						Almega
				#	+		NOx NOx CO (x (M x (H (M) (H)	n)		1	100 100 1000 1000				89 45		P		C	_	3		12/		2						682
							NOx NOx CO (x (M x (H (M) (H) x Co	n)	ter C	1	100 100 1000 1000				89 45 89	3.8	P P	PM	CC	C3946	73		04/	/02/2:	2						82





14 - 1 Cal and 10 22

























Appendix D3

CEMS –DAS One-Minute Data



Client OCSD

Location Huntington Beach

Unit ICE 5

Date 10/1/2015

Job Number 9849

5		030/	6020/	60	NOV
Date	Time 6:50:03	O2 % 4.53	CO2%	CO ppm	NOXppm
10/1/2015	6:51:03	0.03	-0.21 0	1.4 0.6	0
10/1/2015	6:52:03	0.03	0	0.6	0 Zero
10/1/2015					
10/1/2015	6:53:03	0.03	0	0.7	0 zero NOx mode
10/1/2015	6:54:03	0.03		0.8	0
10/1/2015	6:55:03	0.03	0	0.9	0 zero NO mode
10/1/2015	6:56:03	15.8	5.74	134.5	143.65
10/1/2015	6:57:03	21.84	8.79	864.2	89.56
10/1/2015	6:58:03	21.94	8.76	896.5	89.92 high
10/1/2015	6:59:03	21.97	8.76	895.5	89.86 high NOx mode
10/1/2015	7:00:03	21.97	8.77	894.4	89.89
10/1/2015	7:01:03	21.98	8.77	893.8	89.86 high NO mode
10/1/2015	7:02:03	20.47	7.48	885.3	79.49
10/1/2015	7:03:03	11.85	4.02	540.6	42.19
10/1/2015	7:04:03	12.13	4.37	438.2	45.3
10/1/2015	7:05:03	12.12	4.37	448	45.36
10/1/2015	7:06:03	12.12	4.37	454.5	45.41
10/1/2015	7:07:03	12.12	4.38	454.4	45.4 mid
10/1/2015	7:08:03	12.12	4.37	454	45.37 mid NOx mode
10/1/2015	7:09:03	12.12	4.37	454	45.36
10/1/2015	7:10:03	12.12	4.36	453.6	45.31 mid NO mode
10/1/2015	7:11:03	12.12	4.36	447.8	38.96
10/1/2015	7:12:03	17.73	1.75	193.3	3.91
10/1/2015	7:13:03	21.03	0.28	7.4	0.16
10/1/2015	7:14:03	21.07	0.23	2.2	0.16 NO2 NO mode
10/1/2015	7:15:03	18.57	1.74	18.7	8.62
10/1/2015	7:16:03	11.36	7.27	309.3	15.91
10/1/2015	7:17:03	11.17	7.45	460.5	15.91 NO2 NOx mode
10/1/2015	7:18:03	11.22	7.49	449.5	25.89
10/1/2015	7:19:03	2.43	1.45	256.4	8.07
10/1/2015	7:20:03	0.15	0.37	5.2	1.05
10/1/2015	7:21:03	0.11	0.29	0.9	0.88
10/1/2015	7:22:03	0.06	0.26	0.9	0.81
10/1/2015	7:23:03	0.04	0.09	0.9	0.62
10/1/2015	7:24:03	0.03	0	0.8	0.27 bias zero
10/1/2015	7:25:03	0.03	0	0.8	0.21
10/1/2015	7:26:03	9.01	1.68	0.9	0.19
10/1/2015	7:27:03	12.08	4.08	0.8	0.18
10/1/2015	7:28:03	12.11	4.31	0.8	0.19 bias O2/CO2



Client

OCSD

Location

Huntington Beach

Unit

ICE 5

Date

10/1/2015

Job Number

Date	Time	02%	CO2%	CO ppm	NOXppm
10/1/2015	7:29:03	12.09	4.31	0.6	0.19
10/1/2015	7:30:03	6.79	2.34	0.9	17.07
10/1/2015	7:31:03	0.13	0.17	0.6	44.98
10/1/2015	7:32:03	0.04	0.1	0.9	45.38 bias NOx
10/1/2015	7:33:03	0.03	0.07	0.4	45.39
10/1/2015	7:34:03	0.2	0.05	172.9	8.15
10/1/2015	7:35:03	0.2	0.05	447.3	0.7
10/1/2015	7:36:03	0.18	0.05	450.2	0.66 bias CO
10/1/2015	7:37:03	0.17	0.09	450.4	0.65
10/1/2015	7:38:03	9.94	6.66	513.3	27.14
10/1/2015	7:39:03	11.47	7.46	587.9	32.97
10/1/2015	7:40:03	11.61	7.49	591.8	31.92
10/1/2015	7:41:03	11.66	7.52	593.9	31.87
10/1/2015	7:42:03	11.78	7.47	591.1	32.51
10/1/2015	7:43:03	11.8	7.44	594.8	33.09 R 1
10/1/2015	7:44:03	11.76	7.5	586.6	34.06
10/1/2015	7:45:03	11.81	7.5	593.9	33.31
10/1/2015	7:46:03	11.82	7.5	590.2	33.21
10/1/2015	7:47:03	11.85	7.51	598.9	33.19
10/1/2015	7:48:03	11.84	7.52	583.5	34.06
10/1/2015	7:49:03	11.89	7.51	592.7	33.03
10/1/2015	7:50:03	11.91	7.45	608.3	32.73
10/1/2015	7:51:03	11.8	7.57	592	33.41
10/1/2015	7:52:03	11.88	7.55	582.5	33.43
10/1/2015	7:53:03	11.82	7.55	592	33.47
10/1/2015	7:54:03	11.81	7.59	586.3	34.01
10/1/2015	7:55:03	11.91	7.55	588.4	33.6
10/1/2015	7:56:03	11.9	7.54	585.7	33.56
10/1/2015	7:57:03	11.85	7.56	585.7	34.86
10/1/2015	7:58:03	11.87	7.58	572.3	34.62
10/1/2015	7:59:03	11.94	7.53	596.3	34.15
10/1/2015	8:00:03	11.92	7.54	585.3	34.58
10/1/2015	8:01:03	11.95	7.54	580.8	34.21
10/1/2015	8:02:03	11.88	7.56	584.6	34.64
10/1/2015	8:03:03	11.93	7.58	588.7	33.99
10/1/2015	8:04:03	11.94	7.54	604.7	33.51
10/1/2015	8:05:03	11.86	7.61	589.3	34.66
10/1/2015	8:06:03	11.85	7.63	580.1	34.51
10/1/2015	8:07:03	11.91	7.59	587.3	34.32



Client

OCSD

Location

Huntington Beach

Unit

ICE 5

Date

10/1/2015

Job Number

D-4-	T	030/	6030/	60	NOV
Date	Time	O2 % 11.77	CO2 % 7.66	CO ppm 573	NOXppm
10/1/2015	8:08:03				35.76
10/1/2015	8:09:03	11.77 11.76	7.68 7.7	565.4	35.47
10/1/2015	8:10:03 8:11:03	11.76	7.7	559.5 560.7	35.62 35.17
10/1/2015		11.77	7.71		
10/1/2015	8:12:03 8:13:03	11.75	7.71	555.4 555.8	35.77 36.35 R 2
10/1/2015	8:14:03	11.72	7.74	553.6	36.1
10/1/2015	8:15:03	11.72	7.75	556.8	36.34
10/1/2015	8:16:03	11.74	7.75	547.2	36.75
10/1/2015	8:17:03	11.72	7.75	550.1	36.38
10/1/2015	8:18:03	11.72	7.75	550.8	37
10/1/2015	8:19:03	11.77	7.75	551.6	36.66
10/1/2015	8:20:03	11.86	7.66	565.4	35.73
10/1/2015	8:21:03	11.88	7.66	573	35.5
10/1/2015	8:22:03	11.81	7.66	566.9	36.39
10/1/2015	8:23:03	11.82	7.67	554.5	36.61
10/1/2015	8:24:03	11.86	7.67	566.9	35.34
10/1/2015	8:25:03	11.83	7.67	573.5	35.45
10/1/2015	8:26:03	11.86	7.67	572.2	35.32
10/1/2015	8:27:03	11.9	7.66	581.1	35.21
10/1/2015	8:28:03	11.85	7.67	566.4	36.11
10/1/2015	8:29:03	11.9	7.65	562.7	35.78
10/1/2015	8:30:03	11.75	7.71	560.9	36.73
10/1/2015	8:31:03	11.79	7.73	564.8	36.44
10/1/2015	8:32:03	11.89	7.7	570.7	35.77
10/1/2015	8:33:03	11.84	7.67	569.2	36.29
10/1/2015	8:34:03	11.9	7.67	574.3	35.96
10/1/2015	8:35:03	11.94	7.65	574.9	35.94
10/1/2015	8:36:03	11.93	7.65	573.1	36.57
10/1/2015	8:37:03	12.01	7.6	573.3	35.86
10/1/2015	8:38:03	11.99	7.56	580.6	35.8
10/1/2015	8:39:03	12.03	7.57	583.2	35.45
10/1/2015	8:40:03	11.88	7.64	581.2	36.66
10/1/2015	8:41:03	11.96	7.63	577.3	35.72
10/1/2015	8:42:03	12.01	7.57	601.1	35.03
10/1/2015	8:43:03	11.93	7.61	589.8	35.96 R 3
10/1/2015	8:44:03	11.91	7.65	571.9	36.64
10/1/2015	8:45:03	11.97	7.63	576.2	36.04
10/1/2015	8:46:03	11.94	7.63	578.9	36.17
10/1/2015	8:47:03	11.9	7.62	580.4	36.58



Client

OCSD

Location

Huntington Beach

Unit

ICE 5

Date

10/1/2015

Job Number

_		020/	6030/		NOV	
Date	Time	02%	CO2%	CO ppm	NOXppm	
10/1/2015	8:48:03	11.92	7.63	565.7	36.88	
10/1/2015	8:49:03	11.9	7.65	566.8	37.16	
10/1/2015	8:50:03	11.97	7.64	575.4	36.6	
10/1/2015	8:51:03	11.96	7.62	577.5	36.41	
10/1/2015	8:52:03	12	7.61	583.6	35.87	
10/1/2015	8:53:03	11.97	7.61	580.2	36.25	
10/1/2015	8:54:03	11.99	7.61	572.6	36.12	
10/1/2015	8:55:03	12.02	7.59	572.1	36.37	
10/1/2015	8:56:03	11.94	7.6	566.9	36.79	
10/1/2015	8:57:03	11.87	7.66	564.9	38.02	
10/1/2015	8:58:03	11.95	7.66	558.9	37.07	
10/1/2015	8:59:03	11.92	7.64	567.1	36.83	
10/1/2015	9:00:03	11.93	7.65	570	36.62	
10/1/2015	9:01:03	11.93	7.64	571.7	36.27	
10/1/2015	9:02:03	11.94	7.64	582.2	36.38	
10/1/2015	9:03:03	11.98	7.64	583.8	36.04	
10/1/2015	9:04:03	11.94	7.64	581.5	35.9	
10/1/2015	9:05:03	11.89	7.67	581.2	36.26	
10/1/2015	9:06:03	11.86	7.68	578.3	36.65	
10/1/2015	9:07:03	11.88	7.69	569.9	36.62	
10/1/2015	9:08:03	11.91	7.69	566	36.68	
10/1/2015	9:09:03	11.87	7.67	567.1	37.15	
10/1/2015	9:10:03	11.88	7.68	563.3	36.98	
10/1/2015	9:11:03	11.91	7.69	569.2	36.74	
10/1/2015	9:12:03	11.92	7.66	583.9	36.07	
10/1/2015	9:13:03	11.5	7.02	575.9	34.59	
10/1/2015	9:14:03	11.99	4.45	231.4	2.43	
10/1/2015	9:15:03	12.07	4.3	1.3	0.61	
10/1/2015	9:16:03	12.06	4.3	0.2	0.48	bias O2/CO2
10/1/2015	9:17:03	12.05	4.3	0.2	0.41	zero NOx/CO
10/1/2015	9:18:03	1.97	2.22	0.4	34.22	
10/1/2015	9:19:03	0.19	0.3	0.2	45.53	
10/1/2015	9:20:03	0.06	0.05	0.3	45.66	
10/1/2015	9:21:03	0.04	-0.03	0.2	45.5	bias NOx
10/1/2015	9:22:03	0.03	0	0	45.53	zero O2/CO2
10/1/2015	9:23:03	0.19	0	142.6	13.06	
10/1/2015	9:24:03	0.22	-0.01	441.7	1.72	
10/1/2015	9:25:03	0.2	-0.01	447.1	1.65	
10/1/2015	9:26:03	0.18	-0.01	447.2	1.62	



Client

OCSD

Location

Huntington Beach

Unit

ICE 5

Date

10/1/2015

Job Number

Date	Time	02%	CO2%(CO ppm	NOXppm
10/1/2015	9:27:03	0.18	-0.01	447.6	1.58 bias CO
10/1/2015	9:28:03	0.18	-0.01	447.5	1.56
10/1/2015	9:29:03	3.64	2.51	451.4	11.59
10/1/2015	9:30:03	11.55	6.85	550.9	36.76
10/1/2015	9:31:03	11.62	7.03	564	37.86 R 4
10/1/2015	9:32:03	11.72	7.05	568.6	37.07
10/1/2015	9:33:03	11.76	7.05	577.8	36.43
10/1/2015	9:34:03	11.84	7.04	583.4	35.88
10/1/2015	9:35:03	11.92	6.99	580.4	35.56
10/1/2015	9:36:03	11.87	7	578.5	35.73
10/1/2015	9:37:03	11.99	6.95	585.8	34.96
10/1/2015	9:38:03	12.01	6.91	582.3	34.7
10/1/2015	9:39:03	11.94	6.92	583.2	35
10/1/2015	9:40:03	11.86	6.99	583	35.43
10/1/2015	9:41:03	11.92	6.99	575.3	35.43
10/1/2015	9:42:03	12	6.94	576.2	34.93
10/1/2015	9:43:03	11.85	6.98	584.6	35.01
10/1/2015	9:44:03	11.87	7	583.2	35.11
10/1/2015	9:45:03	11.86	7	583.1	35.36
10/1/2015	9:46:03	11.94	6.99	572.8	35.27
10/1/2015	9:47:03	11.94	6.97	572.1	34.84
10/1/2015	9:48:03	11.92	6.97	586.3	35.06
10/1/2015	9:49:03	11.98	6.96	573.7	34.62
10/1/2015	9:50:03	11.96	6.92	588.7	34.2
10/1/2015	9:51:03	11.78	7.04	588.8	35.56
10/1/2015	9:52:03	11.8	7.07	578	35.52
10/1/2015	9:53:03	11.91	7.03	583.3	34.66
10/1/2015	9:54:03	11.86	7.03	575.5	35.21
10/1/2015	9:55:03	11.99	6.96	572	34.17
10/1/2015	9:56:03	11.99	6.92	599	33.58
10/1/2015	9:57:03	11.93	6.97	580.2	34.34
10/1/2015	9:58:03	11.95	6.97	582.8	34.33
10/1/2015	9:59:03	11.89	6.97	581.4	34.63
10/1/2015	10:00:03	11.9	6.99	578.8	34.99
10/1/2015	10:01:03	11.95	6.98	573.9	34.51 R 5
10/1/2015	10:02:03	11.92	6.97	572.5	34.88
10/1/2015	10:03:03	11.89	7.01	569.7	34.93
10/1/2015	10:04:03	11.98	6.99	577.7	34.62
10/1/2015	10:05:03	11.95	6.98	578.7	34.78



Client

OCSD

Location

Huntington Beach

Unit

ICE 5

Date

10/1/2015

Job Number 9849

	Date	Time	02%	CO2%	CO ppm	NOXppm
10	0/1/2015	10:06:03	11.89	6.98	580.9	35.39
10	0/1/2015	10:07:03	11.89	6.99	574.7	35
10	0/1/2015	10:08:03	11.87	7	580.2	34.85
10	0/1/2015	10:09:03	11.91	7.01	578	35.08
10	0/1/2015	10:10:03	11.91	6.98	573.6	36.08
10	0/1/2015	10:11:03	11.87	7.02	543.8	37.35
10	0/1/2015	10:12:03	11.79	7.04	554.4	37.32
10	0/1/2015	10:13:03	11.86	7.05	566.5	36.61
10	0/1/2015	10:14:03	11.86	7.05	569.4	36.16
10	0/1/2015	10:15:03	11.89	7.05	573.4	35.95
10	0/1/2015	10:16:03	11.96	6.99	567	36.03
10	0/1/2015	10:17:03	11.9	6.99	567.4	36.25
10	0/1/2015	10:18:03	11.92	7	571.6	35.71
10	0/1/2015	10:19:03	11.94	7	568.1	35.88
10	0/1/2015	10:20:03	11.96	6.96	568.3	35.66
10	0/1/2015	10:21:03	11.83	7.04	564.8	36.65
10	0/1/2015	10:22:03	11.86	7.07	569.9	36.32
10	0/1/2015	10:23:03	11.92	7.03	566.9	36.12
10	0/1/2015	10:24:03	11.92	7.02	573.1	35.76
10	0/1/2015	10:25:03	12.04	6.97	564.5	35.63
10	0/1/2015	10:26:03	11.99	6.94	562	35.86
10	0/1/2015	10:27:03	11.93	6.99	562.8	
10	0/1/2015	10:28:03	11.97	6.99	559.5	
10	0/1/2015	10:29:03	11.98	6.99	569.4	35.75
10	0/1/2015	10:30:03	12	6.93	565.5	
10	0/1/2015	10:31:03	11.92	6.97	567.8	
	0/1/2015	10:32:03	11.92	7	561.1	
10	0/1/2015	10:33:03	11.97	6.96	552.9	
	0/1/2015	10:34:03	11.94	6.97	569.9	
10	0/1/2015	10:35:03	12	6.97	561.3	
	0/1/2015	10:36:03	11.93	7	563	36.52
	0/1/2015	10:37:03	11.97	6.99	568.4	35.86
	0/1/2015	10:38:03	12	6.95	573.5	35.79
	0/1/2015	10:39:03	11.99	6.95	565.7	36.23
	0/1/2015	10:40:03	12.11	6.89	568.3	35.56
	0/1/2015	10:41:03	11.98	6.92	574	36.35
	0/1/2015	10:42:03	11.92	6.99	572.4	36.52
	0/1/2015	10:43:03	11.97	6.99	577.6	36.1
	0/1/2015	10:44:03	12.06	6.92	579.2	35.43
10	0/1/2015	10:45:03	12.03	6.92	579.9	35.71



Client OCSD

Location Huntington Beach

Unit ICE 5
Date 10/1/2015
Job Number 9849

Date	Time	02%	CO2%	CO ppm	NOXppm
10/1/2015	10:46:03	12.05	6.89	574.6	35.43
10/1/2015	10:47:03	12.01	6.93	582.3	35.45
10/1/2015	10:48:03	12.01	6.94	586.2	35.3
10/1/2015	10:49:03	11.99	6.96	578.9	36.01
10/1/2015	10:50:03	11.97	6.96	572.3	36.58
10/1/2015	10:51:03	12.12	6.85	574.9	35.3
10/1/2015	10:52:03	12	6.91	572.7	36.1
10/1/2015	10:53:03	11.97	6.93	575.7	36.04
10/1/2015	10:54:03	12.01	6.93	567.2	36.46
10/1/2015	10:55:03	11.97	6.97	565	36.87
10/1/2015	10:56:03	12.01	6.91	568.5	35.79
10/1/2015	10:57:03	11.97	6.97	572	35.89
10/1/2015	10:58:03	11.92	6.99	567.6	36.2
10/1/2015	10:59:03	12.04	6.94	567.3	35.55
10/1/2015	11:00:03	11.98	6.94	570.6	35.64
10/1/2015	11:01:03	11.96	6.96	574.2	35.81
10/1/2015	11:02:03	11.41	4.46	402	10.5
10/1/2015	11:03:03	12.03	4.13	15.1	0.62
10/1/2015	11:04:03	12.14	4.12	1	0.48 bias O2/CO2
10/1/2015	11:05:03	12.15	4.09	0.9	0.42 zero CO/NOx
10/1/2015	11:06:03	3.38	0.86	3	29.47
10/1/2015	11:07:03	0.19	0.12	1_	45.12
10/1/2015	11:08:03	0.09	0.05	0.9	45.5 bias NOx
10/1/2015	11:09:03	0.09	0.02	0.9	45.62 zero O2/CO2
10/1/2015	11:10:03	0.14	0	160.2	11.98
10/1/2015	11:11:03	0.14	0_	440.4	1.9
10/1/2015	11:12:03	0.12	0	444.8	1.84 bias CO
10/1/2015	11:13:03	0.17	0.07	445.3	1.83
10/1/2015	11:14:03	10.22	6.28	502.2	30.17
10/1/2015	11:15:03	11.61	6.96	575.1	36.15
10/1/2015	11:16:03	11.67	7.03	575.2	36.15 R 7
10/1/2015	11:17:03	11.73	7.03	581.3	35.71
10/1/2015	11:18:03	11.72	7.07	574.5	36.29
10/1/2015	11:19:03	11.78	7.07	565.7	35.91
10/1/2015	11:20:03	11.79	7.07	572.1	35.78
10/1/2015	11:21:03	11.74	7.08	564.6	36.74
10/1/2015	11:22:03	11.77	7.1	560	36.71
10/1/2015	11:23:03	11.77	7.1	564.9	36.68
10/1/2015	11:24:03	11.79	7.07	554.6	37.16



Client

OCSD

Location

Huntington Beach

Unit

ICE 5

Date

10/1/2015

Job Number 9849

10/1/2015 11:25:03 11.76 7.08 551.7 37.56 10/1/2015 11:26:03 11.76 7.09 558.7 36.84 10/1/2015 11:27:03 11.84 7.08 564 36.06 10/1/2015 11:28:03 11.82 7.06 564.7 36.52 10/1/2015 11:30:03 11.83 7.03 560 36.28 10/1/2015 11:31:03 11.83 7.03 567.2 36.37 10/1/2015 11:32:03 11.85 7.05 569.7 36.29 10/1/2015 11:33:03 11.84 7.05 561.9 37.09 10/1/2015 11:33:03 11.84 7.05 561.9 37.09 10/1/2015 11:33:03 11.89 7.04 566.3 36.01 10/1/2015 11:35:03 11.82 7.05 564.9 36.01 10/1/2015 11:38:03 11.82 7.05 574.8 36.04 10/1/2015 11:40:03 11.84	Date	Time	02%	CO2%	CO ppm	NOXppm	
10/1/2015 11:27:03 11.84 7.08 564 36.06 10/1/2015 11:28:03 11.82 7.06 564.7 36.52 10/1/2015 11:29:03 11.91 7.03 560 36.28 10/1/2015 11:30:03 11.83 7.03 567.2 36.37 10/1/2015 11:32:03 11.83 7.05 562.3 36.69 10/1/2015 11:33:03 11.85 7.05 569.7 36.29 10/1/2015 11:33:03 11.84 7.05 561.9 37.09 10/1/2015 11:33:03 11.89 7.04 566.3 36.01 10/1/2015 11:35:03 11.89 7.04 566.3 36.01 10/1/2015 11:38:03 11.82 7.05 574.8 36.5 10/1/2015 11:39:03 11.82 7.08 568.1 36.25 10/1/2015 11:39:03 11.82 7.08 568.1 36.25 10/1/2015 11:40:03 11.84	10/1/2015	11:25:03	11.76	7.08	551.7	37.56	
10/1/2015 11:28:03 11.82 7.06 564.7 36.52 10/1/2015 11:29:03 11.91 7.03 560 36.28 10/1/2015 11:30:03 11.83 7.03 567.2 36.37 10/1/2015 11:31:03 11.83 7.05 562.3 36.69 10/1/2015 11:33:03 11.85 7.05 569.7 36.29 10/1/2015 11:33:03 11.84 7.05 561.9 37.09 10/1/2015 11:36:03 11.9 7.03 562.4 36.6 10/1/2015 11:36:03 11.89 7.04 566.3 36.01 10/1/2015 11:36:03 11.82 7.05 574.8 36.5 10/1/2015 11:38:03 11.84 7.05 574.8 36.5 10/1/2015 11:39:03 11.84 7.05 571.7 36.19 10/1/2015 11:39:03 11.82 7.08 568.1 36.25 10/1/2015 11:40:03 11.94 <	10/1/2015	11:26:03	11.76	7.09	558.7	36.84	
10/1/2015 11:29:03 11.91 7.03 560 36.28 10/1/2015 11:30:03 11.83 7.03 567.2 36.37 10/1/2015 11:31:03 11.83 7.05 562.3 36.69 10/1/2015 11:32:03 11.85 7.05 569.7 36.29 10/1/2015 11:33:03 11.84 7.05 561.9 37.09 10/1/2015 11:35:03 11.89 7.04 566.3 36.01 10/1/2015 11:36:03 11.82 7.05 574.8 36.5 10/1/2015 11:36:03 11.82 7.05 574.8 36.5 10/1/2015 11:38:03 11.84 7.05 574.8 36.5 10/1/2015 11:39:03 11.82 7.08 566.4 36.04 10/1/2015 11:39:03 11.82 7.08 568.1 36.25 10/1/2015 11:40:03 11.94 7.05 574.4 35.82 10/1/2015 11:41:03 11.88	10/1/2015	11:27:03	11.84	7.08	564	36.06	
10/1/2015 11:30:03 11.83 7.03 567.2 36.37 10/1/2015 11:31:03 11.83 7.05 562.3 36.69 10/1/2015 11:32:03 11.85 7.05 569.7 36.29 10/1/2015 11:33:03 11.84 7.05 561.9 37.09 10/1/2015 11:34:03 11.9 7.03 562.4 36.6 10/1/2015 11:35:03 11.89 7.04 566.3 36.01 10/1/2015 11:36:03 11.82 7.05 574.8 36.5 10/1/2015 11:38:03 11.84 7.05 574.8 36.5 10/1/2015 11:39:03 11.82 7.08 568.1 36.25 10/1/2015 11:39:03 11.82 7.08 568.1 36.25 10/1/2015 11:40:03 11.83 7.07 567.1 36.71 10/1/2015 11:41:03 11.83 7.07 567.1 36.71 10/1/2015 11:42:03 11.88	10/1/2015	11:28:03	11.82	7.06	564.7	36.52	
10/1/2015 11:31:03 11.83 7.05 562.3 36.69 10/1/2015 11:32:03 11.85 7.05 569.7 36.29 10/1/2015 11:33:03 11.84 7.05 561.9 37.09 10/1/2015 11:34:03 11.9 7.03 562.4 36.6 10/1/2015 11:35:03 11.89 7.04 566.3 36.01 10/1/2015 11:36:03 11.82 7.05 574.8 36.5 10/1/2015 11:38:03 11.82 7.05 574.8 36.5 10/1/2015 11:38:03 11.84 7.05 571.7 36.19 10/1/2015 11:39:03 11.82 7.08 568.1 36.25 10/1/2015 11:40:03 11.83 7.07 567.1 36.19 10/1/2015 11:41:03 11.83 7.07 567.1 36.71 10/1/2015 11:42:03 11.89 7.06 565.3 36.66 10/1/2015 11:45:03 11.88	10/1/2015	11:29:03	11.91	7.03	560	36.28	
10/1/2015 11:32:03 11.85 7.05 569.7 36.29 10/1/2015 11:33:03 11.84 7.05 561.9 37.09 10/1/2015 11:34:03 11.9 7.03 562.4 36.6 10/1/2015 11:35:03 11.89 7.04 566.3 36.01 10/1/2015 11:36:03 11.82 7.05 574.8 36.5 10/1/2015 11:37:03 11.92 7.04 566.4 36.04 10/1/2015 11:38:03 11.84 7.05 571.7 36.19 10/1/2015 11:39:03 11.82 7.08 568.1 36.25 10/1/2015 11:40:03 11.94 7.05 574.4 35.82 10/1/2015 11:41:03 11.83 7.07 567.1 36.71 10/1/2015 11:42:03 11.89 7.06 565.3 36.66 10/1/2015 11:43:03 11.88 7.04 565.1 36.56 10/1/2015 11:45:03 11.87	10/1/2015	11:30:03	11.83	7.03	567.2	36.37	
10/1/2015 11:33:03 11.84 7.05 561.9 37.09 10/1/2015 11:34:03 11.9 7.03 562.4 36.6 10/1/2015 11:35:03 11.89 7.04 566.3 36.01 10/1/2015 11:36:03 11.82 7.05 574.8 36.5 10/1/2015 11:37:03 11.92 7.04 566.4 36.04 10/1/2015 11:38:03 11.84 7.05 571.7 36.19 10/1/2015 11:39:03 11.82 7.08 568.1 36.25 10/1/2015 11:40:03 11.94 7.05 574.4 35.82 10/1/2015 11:41:03 11.83 7.07 567.1 36.71 10/1/2015 11:42:03 11.89 7.06 565.3 36.66 10/1/2015 11:43:03 11.88 7.04 565.1 36.56 10/1/2015 11:44:03 11.85 7.08 576 36.58 10/1/2015 11:46:03 11.93	10/1/2015	11:31:03	11.83	7.05	562.3	36.69	
10/1/2015 11:34:03 11.9 7.03 562.4 36.6 10/1/2015 11:35:03 11.89 7.04 566.3 36.01 10/1/2015 11:36:03 11.82 7.05 574.8 36.5 10/1/2015 11:37:03 11.92 7.04 566.4 36.04 10/1/2015 11:38:03 11.84 7.05 571.7 36.19 10/1/2015 11:39:03 11.82 7.08 568.1 36.25 10/1/2015 11:40:03 11.94 7.05 574.4 35.82 10/1/2015 11:41:03 11.83 7.07 567.1 36.71 10/1/2015 11:42:03 11.89 7.06 565.3 36.56 10/1/2015 11:43:03 11.82 7.08 572.4 36.27 10/1/2015 11:44:03 11.82 7.08 576.3 36.58 10/1/2015 11:45:03 11.93 7.04 570.2 35.94 R 8 10/1/2015 11:46:03 11.93	10/1/2015	11:32:03	11.85	7.05	569.7	36.29	
10/1/2015 11:35:03 11.89 7.04 566.3 36.01 10/1/2015 11:36:03 11.82 7.05 574.8 36.5 10/1/2015 11:37:03 11.92 7.04 566.4 36.04 10/1/2015 11:38:03 11.84 7.05 571.7 36.19 10/1/2015 11:39:03 11.82 7.08 568.1 36.25 10/1/2015 11:40:03 11.94 7.05 574.4 35.82 10/1/2015 11:41:03 11.83 7.07 567.1 36.71 10/1/2015 11:42:03 11.89 7.06 565.3 36.66 10/1/2015 11:43:03 11.88 7.04 565.1 36.56 10/1/2015 11:44:03 11.82 7.08 572.4 36.27 10/1/2015 11:46:03 11.93 7.04 570.2 35.94 R 8 10/1/2015 11:47:03 11.93 7.04 570.2 36.1 10/1/2015 11:48:03 11.94	10/1/2015	11:33:03	11.84	7.05	561.9	37.09	
10/1/2015 11:36:03 11.82 7.05 574.8 36.5 10/1/2015 11:37:03 11.92 7.04 566.4 36.04 10/1/2015 11:38:03 11.84 7.05 571.7 36.19 10/1/2015 11:39:03 11.82 7.08 568.1 36.25 10/1/2015 11:40:03 11.94 7.05 574.4 35.82 10/1/2015 11:41:03 11.83 7.07 567.1 36.71 10/1/2015 11:42:03 11.89 7.06 565.3 36.66 10/1/2015 11:43:03 11.88 7.04 565.1 36.56 10/1/2015 11:44:03 11.82 7.08 572.4 36.27 10/1/2015 11:45:03 11.85 7.08 576 36.58 10/1/2015 11:47:03 11.93 7.04 570.2 35.94 R 8 10/1/2015 11:48:03 11.94 7 577.3 36.03 10/1/2015 11:49:03 11.94	10/1/2015	11:34:03	11.9	7.03	562.4	36.6	
10/1/2015 11:37:03 11.92 7.04 566.4 36.04 10/1/2015 11:38:03 11.84 7.05 571.7 36.19 10/1/2015 11:39:03 11.82 7.08 568.1 36.25 10/1/2015 11:40:03 11.94 7.05 574.4 35.82 10/1/2015 11:41:03 11.83 7.07 567.1 36.71 10/1/2015 11:43:03 11.89 7.06 565.3 36.66 10/1/2015 11:43:03 11.88 7.04 565.1 36.56 10/1/2015 11:45:03 11.85 7.08 576 36.58 10/1/2015 11:45:03 11.85 7.08 576 36.58 10/1/2015 11:46:03 11.93 7.04 570.2 35.94 R 8 10/1/2015 11:48:03 11.94 7 577.3 36.03 10/1/2015 11:49:03 11.94 7 574.7 35.62 10/1/2015 11:50:03 11.87 7.06 573.2 36.64 10/1/2015 11:51:03 11.94 <td>10/1/2015</td> <td>11:35:03</td> <td>11.89</td> <td>7.04</td> <td>566.3</td> <td>36.01</td> <td></td>	10/1/2015	11:35:03	11.89	7.04	566.3	36.01	
10/1/2015 11:38:03 11.84 7.05 571.7 36.19 10/1/2015 11:39:03 11.82 7.08 568.1 36.25 10/1/2015 11:40:03 11.94 7.05 574.4 35.82 10/1/2015 11:41:03 11.83 7.07 567.1 36.71 10/1/2015 11:42:03 11.89 7.06 565.3 36.66 10/1/2015 11:43:03 11.88 7.04 565.1 36.56 10/1/2015 11:45:03 11.85 7.08 576 36.58 10/1/2015 11:45:03 11.85 7.08 576 36.58 10/1/2015 11:46:03 11.93 7.04 570.2 35.94 R 8 10/1/2015 11:48:03 11.92 7 577.3 36.03 10/1/2015 11:49:03 11.94 7 574.7 35.62 10/1/2015 11:50:03 11.87 7.06 573.2 36.64 10/1/2015 11:51:03 11.94 <	10/1/2015	11:36:03	11.82	7.05	574.8	36.5	
10/1/2015 11:39:03 11.82 7.08 568.1 36.25 10/1/2015 11:40:03 11.94 7.05 574.4 35.82 10/1/2015 11:41:03 11.83 7.07 567.1 36.71 10/1/2015 11:42:03 11.89 7.06 565.3 36.66 10/1/2015 11:43:03 11.88 7.04 565.1 36.56 10/1/2015 11:45:03 11.85 7.08 572.4 36.27 10/1/2015 11:45:03 11.85 7.08 576 36.58 10/1/2015 11:46:03 11.93 7.04 570.2 35.94 R 8 10/1/2015 11:47:03 11.92 7 577.3 36.03 10/1/2015 11:48:03 11.94 7 579.2 36.1 10/1/2015 11:49:03 11.94 7 574.7 35.62 10/1/2015 11:50:03 11.87 7.06 573.2 36.64 10/1/2015 11:55:03 11.91 <td< td=""><td>10/1/2015</td><td>11:37:03</td><td>11.92</td><td>7.04</td><td>566.4</td><td>36.04</td><td></td></td<>	10/1/2015	11:37:03	11.92	7.04	566.4	36.04	
10/1/2015 11:40:03 11.94 7.05 574.4 35.82 10/1/2015 11:41:03 11.83 7.07 567.1 36.71 10/1/2015 11:42:03 11.89 7.06 565.3 36.66 10/1/2015 11:43:03 11.88 7.04 565.1 36.56 10/1/2015 11:44:03 11.82 7.08 572.4 36.27 10/1/2015 11:45:03 11.85 7.08 576 36.58 10/1/2015 11:46:03 11.93 7.04 570.2 35.94 R 8 10/1/2015 11:47:03 11.92 7 577.3 36.03 10/1/2015 11:48:03 11.94 7 579.2 36.1 10/1/2015 11:49:03 11.94 7 574.7 35.62 10/1/2015 11:50:03 11.87 7.06 573.2 36.64 10/1/2015 11:51:03 11.94 7.02 571.7 35.91 10/1/2015 11:53:03 11.91 <td< td=""><td>10/1/2015</td><td>11:38:03</td><td>11.84</td><td>7.05</td><td>571.7</td><td>36.19</td><td></td></td<>	10/1/2015	11:38:03	11.84	7.05	571.7	36.19	
10/1/2015 11:41:03 11.83 7.07 567.1 36.71 10/1/2015 11:42:03 11.89 7.06 565.3 36.66 10/1/2015 11:43:03 11.88 7.04 565.1 36.56 10/1/2015 11:45:03 11.82 7.08 572.4 36.27 10/1/2015 11:45:03 11.85 7.08 576 36.58 10/1/2015 11:46:03 11.93 7.04 570.2 35.94 R 8 10/1/2015 11:47:03 11.92 7 577.3 36.03 10/1/2015 11:48:03 11.94 7 579.2 36.1 10/1/2015 11:50:03 11.87 7.06 573.2 36.64 10/1/2015 11:51:03 11.94 7.02 571.7 35.91 10/1/2015 11:52:03 11.91 7.02 577.5 36.16 10/1/2015 11:53:03 11.93 7.01 566.4 36.04 10/1/2015 11:54:03 11.91	10/1/2015	11:39:03	11.82	7.08	568.1	36.25	
10/1/2015 11:42:03 11.89 7.06 565.3 36.66 10/1/2015 11:43:03 11.88 7.04 565.1 36.56 10/1/2015 11:44:03 11.82 7.08 572.4 36.27 10/1/2015 11:45:03 11.85 7.08 576 36.58 10/1/2015 11:46:03 11.93 7.04 570.2 35.94 R 8 10/1/2015 11:47:03 11.92 7 577.3 36.03 10/1/2015 11:48:03 11.94 7 579.2 36.1 10/1/2015 11:50:03 11.87 7.06 573.2 36.64 10/1/2015 11:50:03 11.87 7.06 573.2 36.64 10/1/2015 11:51:03 11.94 7.02 571.7 35.91 10/1/2015 11:52:03 11.91 7.02 577.5 36.16 10/1/2015 11:53:03 11.93 7.01 566.4 36.04 10/1/2015 11:54:03 11.91 7.01 570.7 35.9 10/1/2015 11:55:03 11.83 <td>10/1/2015</td> <td>11:40:03</td> <td>11.94</td> <td>7.05</td> <td>574.4</td> <td>35.82</td> <td></td>	10/1/2015	11:40:03	11.94	7.05	574.4	35.82	
10/1/2015 11:43:03 11.88 7.04 565.1 36.56 10/1/2015 11:44:03 11.82 7.08 572.4 36.27 10/1/2015 11:45:03 11.85 7.08 576 36.58 10/1/2015 11:46:03 11.93 7.04 570.2 35.94 R 8 10/1/2015 11:47:03 11.92 7 577.3 36.03 10/1/2015 11:48:03 11.94 7 579.2 36.1 10/1/2015 11:49:03 11.94 7 574.7 35.62 10/1/2015 11:50:03 11.87 7.06 573.2 36.64 10/1/2015 11:51:03 11.94 7.02 571.7 35.91 10/1/2015 11:52:03 11.91 7.02 577.5 36.16 10/1/2015 11:53:03 11.93 7.01 566.4 36.04 10/1/2015 11:54:03 11.91 7.01 570.7 35.9 10/1/2015 11:55:03 11.83	10/1/2015	11:41:03	11.83	7.07	567.1	36.71	
10/1/2015 11:44:03 11.82 7.08 572.4 36.27 10/1/2015 11:45:03 11.85 7.08 576 36.58 10/1/2015 11:46:03 11.93 7.04 570.2 35.94 R 8 10/1/2015 11:47:03 11.92 7 577.3 36.03 10/1/2015 11:48:03 11.94 7 579.2 36.1 10/1/2015 11:49:03 11.94 7 574.7 35.62 10/1/2015 11:50:03 11.87 7.06 573.2 36.64 10/1/2015 11:51:03 11.94 7.02 571.7 35.91 10/1/2015 11:52:03 11.91 7.02 577.5 36.16 10/1/2015 11:53:03 11.91 7.02 577.5 36.16 10/1/2015 11:54:03 11.91 7.01 566.4 36.04 10/1/2015 11:55:03 11.83 7.05 567 36.66 10/1/2015 11:56:03 11.89 7.04 559.3 36.32 10/1/2015 11:58:03 11.86	10/1/2015	11:42:03	11.89	7.06	565.3	36.66	
10/1/2015 11:45:03 11.85 7.08 576 36.58 10/1/2015 11:46:03 11.93 7.04 570.2 35.94 R 8 10/1/2015 11:47:03 11.92 7 577.3 36.03 10/1/2015 11:48:03 11.94 7 579.2 36.1 10/1/2015 11:49:03 11.94 7 574.7 35.62 10/1/2015 11:50:03 11.87 7.06 573.2 36.64 10/1/2015 11:51:03 11.94 7.02 571.7 35.91 10/1/2015 11:52:03 11.91 7.02 577.5 36.16 10/1/2015 11:53:03 11.93 7.01 566.4 36.04 10/1/2015 11:54:03 11.91 7.01 570.7 35.9 10/1/2015 11:55:03 11.83 7.05 567 36.66 10/1/2015 11:56:03 11.86 7.03 570.5 35.88 10/1/2015 11:58:03 11.86 7.	10/1/2015	11:43:03	11.88	7.04	565.1	36.56	
10/1/2015 11:46:03 11.93 7.04 570.2 35.94 R 8 10/1/2015 11:47:03 11.92 7 577.3 36.03 10/1/2015 11:48:03 11.94 7 579.2 36.1 10/1/2015 11:50:03 11.87 7.06 573.2 36.64 10/1/2015 11:51:03 11.94 7.02 571.7 35.91 10/1/2015 11:52:03 11.91 7.02 577.5 36.16 10/1/2015 11:53:03 11.91 7.02 577.5 36.16 10/1/2015 11:53:03 11.93 7.01 566.4 36.04 10/1/2015 11:54:03 11.91 7.01 570.7 35.9 10/1/2015 11:55:03 11.83 7.05 567 36.66 10/1/2015 11:56:03 11.89 7.04 559.3 36.32 10/1/2015 11:58:03 11.86 7.03 570.5 35.88 10/1/2015 11:59:03 11.96 7 570.9 35.59 10/1/2015 12:00:03 11.95	10/1/2015	11:44:03	11.82	7.08	572.4	36.27	
10/1/2015 11:47:03 11.92 7 577.3 36.03 10/1/2015 11:48:03 11.94 7 579.2 36.1 10/1/2015 11:49:03 11.94 7 574.7 35.62 10/1/2015 11:50:03 11.87 7.06 573.2 36.64 10/1/2015 11:51:03 11.94 7.02 571.7 35.91 10/1/2015 11:52:03 11.91 7.02 577.5 36.16 10/1/2015 11:53:03 11.93 7.01 566.4 36.04 10/1/2015 11:54:03 11.91 7.01 570.7 35.9 10/1/2015 11:55:03 11.83 7.05 567 36.66 10/1/2015 11:56:03 11.89 7.04 559.3 36.32 10/1/2015 11:57:03 11.86 7.03 570.5 35.88 10/1/2015 11:59:03 11.83 7.05 569.6 36.41 10/1/2015 12:00:03 11.96 7 570.9 35.59 10/1/2015 12:01:03 11.96 <t< td=""><td>10/1/2015</td><td>11:45:03</td><td>11.85</td><td>7.08</td><td>576</td><td>36.58</td><td></td></t<>	10/1/2015	11:45:03	11.85	7.08	576	36.58	
10/1/2015 11:48:03 11.94 7 579.2 36.1 10/1/2015 11:49:03 11.94 7 574.7 35.62 10/1/2015 11:50:03 11.87 7.06 573.2 36.64 10/1/2015 11:51:03 11.94 7.02 571.7 35.91 10/1/2015 11:52:03 11.91 7.02 577.5 36.16 10/1/2015 11:53:03 11.93 7.01 566.4 36.04 10/1/2015 11:54:03 11.91 7.01 570.7 35.9 10/1/2015 11:55:03 11.83 7.05 567 36.66 10/1/2015 11:56:03 11.89 7.04 559.3 36.32 10/1/2015 11:57:03 11.86 7.03 570.5 35.88 10/1/2015 11:58:03 11.83 7.05 569.6 36.41 10/1/2015 11:59:03 11.96 7 570.9 35.59 10/1/2015 12:00:03 11.96 6.99 575.7 35.32 10/1/2015 12:02:03 11.91	10/1/2015	11:46:03					
10/1/2015 11:49:03 11.94 7 574.7 35.62 10/1/2015 11:50:03 11.87 7.06 573.2 36.64 10/1/2015 11:51:03 11.94 7.02 571.7 35.91 10/1/2015 11:52:03 11.91 7.02 577.5 36.16 10/1/2015 11:53:03 11.93 7.01 566.4 36.04 10/1/2015 11:54:03 11.91 7.01 570.7 35.9 10/1/2015 11:55:03 11.83 7.05 567 36.66 10/1/2015 11:56:03 11.89 7.04 559.3 36.32 10/1/2015 11:57:03 11.86 7.03 570.5 35.88 10/1/2015 11:58:03 11.83 7.05 569.6 36.41 10/1/2015 11:59:03 11.96 7 570.9 35.59 10/1/2015 12:00:03 11.95 6.99 575.7 35.32 10/1/2015 12:01:03 11.96 6.99 582.2 34.9 10/1/2015 12:02:03 11.91							
10/1/2015 11:50:03 11.87 7.06 573.2 36.64 10/1/2015 11:51:03 11.94 7.02 571.7 35.91 10/1/2015 11:52:03 11.91 7.02 577.5 36.16 10/1/2015 11:53:03 11.93 7.01 566.4 36.04 10/1/2015 11:54:03 11.91 7.01 570.7 35.9 10/1/2015 11:55:03 11.83 7.05 567 36.66 10/1/2015 11:56:03 11.89 7.04 559.3 36.32 10/1/2015 11:57:03 11.86 7.03 570.5 35.88 10/1/2015 11:58:03 11.83 7.05 569.6 36.41 10/1/2015 11:59:03 11.96 7 570.9 35.59 10/1/2015 12:00:03 11.95 6.99 575.7 35.32 10/1/2015 12:01:03 11.96 6.99 582.2 34.9 10/1/2015 12:02:03 11.91 7 581.3 35.49 10/1/2015 12:03:03 11.96	140. 5.	11:48:03					
10/1/2015 11:51:03 11.94 7.02 571.7 35.91 10/1/2015 11:52:03 11.91 7.02 577.5 36.16 10/1/2015 11:53:03 11.93 7.01 566.4 36.04 10/1/2015 11:54:03 11.91 7.01 570.7 35.9 10/1/2015 11:55:03 11.83 7.05 567 36.66 10/1/2015 11:56:03 11.89 7.04 559.3 36.32 10/1/2015 11:57:03 11.86 7.03 570.5 35.88 10/1/2015 11:58:03 11.83 7.05 569.6 36.41 10/1/2015 11:59:03 11.96 7 570.9 35.59 10/1/2015 12:00:03 11.95 6.99 575.7 35.32 10/1/2015 12:01:03 11.96 6.99 582.2 34.9 10/1/2015 12:02:03 11.91 7 581.3 35.49 10/1/2015 12:03:03 11.96 7.02 577 35.36	10/1/2015	11:49:03			574.7		
10/1/2015 11:52:03 11.91 7.02 577.5 36.16 10/1/2015 11:53:03 11.93 7.01 566.4 36.04 10/1/2015 11:54:03 11.91 7.01 570.7 35.9 10/1/2015 11:55:03 11.83 7.05 567 36.66 10/1/2015 11:56:03 11.89 7.04 559.3 36.32 10/1/2015 11:57:03 11.86 7.03 570.5 35.88 10/1/2015 11:58:03 11.83 7.05 569.6 36.41 10/1/2015 11:59:03 11.96 7 570.9 35.59 10/1/2015 12:00:03 11.95 6.99 575.7 35.32 10/1/2015 12:01:03 11.96 6.99 582.2 34.9 10/1/2015 12:02:03 11.91 7 581.3 35.49 10/1/2015 12:03:03 11.96 7.02 577 35.36	10/1/2015	11:50:03	11.87		573.2		
10/1/2015 11:53:03 11.93 7.01 566.4 36.04 10/1/2015 11:54:03 11.91 7.01 570.7 35.9 10/1/2015 11:55:03 11.83 7.05 567 36.66 10/1/2015 11:56:03 11.89 7.04 559.3 36.32 10/1/2015 11:57:03 11.86 7.03 570.5 35.88 10/1/2015 11:58:03 11.83 7.05 569.6 36.41 10/1/2015 11:59:03 11.96 7 570.9 35.59 10/1/2015 12:00:03 11.95 6.99 575.7 35.32 10/1/2015 12:01:03 11.96 6.99 582.2 34.9 10/1/2015 12:02:03 11.91 7 581.3 35.49 10/1/2015 12:03:03 11.96 7.02 577 35.36	1.5) 5)	11:51:03	11.94				
10/1/2015 11:54:03 11.91 7.01 570.7 35.9 10/1/2015 11:55:03 11.83 7.05 567 36.66 10/1/2015 11:56:03 11.89 7.04 559.3 36.32 10/1/2015 11:57:03 11.86 7.03 570.5 35.88 10/1/2015 11:58:03 11.83 7.05 569.6 36.41 10/1/2015 11:59:03 11.96 7 570.9 35.59 10/1/2015 12:00:03 11.95 6.99 575.7 35.32 10/1/2015 12:01:03 11.96 6.99 582.2 34.9 10/1/2015 12:02:03 11.91 7 581.3 35.49 10/1/2015 12:03:03 11.96 7.02 577 35.36	10/1/2015	11:52:03					
10/1/2015 11:55:03 11.83 7.05 567 36.66 10/1/2015 11:56:03 11.89 7.04 559.3 36.32 10/1/2015 11:57:03 11.86 7.03 570.5 35.88 10/1/2015 11:58:03 11.83 7.05 569.6 36.41 10/1/2015 11:59:03 11.96 7 570.9 35.59 10/1/2015 12:00:03 11.95 6.99 575.7 35.32 10/1/2015 12:01:03 11.96 6.99 582.2 34.9 10/1/2015 12:02:03 11.91 7 581.3 35.49 10/1/2015 12:03:03 11.96 7.02 577 35.36	10/1/2015	11:53:03	11.93				
10/1/2015 11:56:03 11.89 7.04 559.3 36.32 10/1/2015 11:57:03 11.86 7.03 570.5 35.88 10/1/2015 11:58:03 11.83 7.05 569.6 36.41 10/1/2015 11:59:03 11.96 7 570.9 35.59 10/1/2015 12:00:03 11.95 6.99 575.7 35.32 10/1/2015 12:01:03 11.96 6.99 582.2 34.9 10/1/2015 12:02:03 11.91 7 581.3 35.49 10/1/2015 12:03:03 11.96 7.02 577 35.36	10/1/2015	11:54:03	11.91				
10/1/2015 11:57:03 11.86 7.03 570.5 35.88 10/1/2015 11:58:03 11.83 7.05 569.6 36.41 10/1/2015 11:59:03 11.96 7 570.9 35.59 10/1/2015 12:00:03 11.95 6.99 575.7 35.32 10/1/2015 12:01:03 11.96 6.99 582.2 34.9 10/1/2015 12:02:03 11.91 7 581.3 35.49 10/1/2015 12:03:03 11.96 7.02 577 35.36	150 50						
10/1/2015 11:58:03 11.83 7.05 569.6 36.41 10/1/2015 11:59:03 11.96 7 570.9 35.59 10/1/2015 12:00:03 11.95 6.99 575.7 35.32 10/1/2015 12:01:03 11.96 6.99 582.2 34.9 10/1/2015 12:02:03 11.91 7 581.3 35.49 10/1/2015 12:03:03 11.96 7.02 577 35.36		11:56:03					
10/1/2015 11:59:03 11.96 7 570.9 35.59 10/1/2015 12:00:03 11.95 6.99 575.7 35.32 10/1/2015 12:01:03 11.96 6.99 582.2 34.9 10/1/2015 12:02:03 11.91 7 581.3 35.49 10/1/2015 12:03:03 11.96 7.02 577 35.36	The state of the s	11:57:03					
10/1/2015 12:00:03 11.95 6.99 575.7 35.32 10/1/2015 12:01:03 11.96 6.99 582.2 34.9 10/1/2015 12:02:03 11.91 7 581.3 35.49 10/1/2015 12:03:03 11.96 7.02 577 35.36		11:58:03		7.05			
10/1/2015 12:01:03 11.96 6.99 582.2 34.9 10/1/2015 12:02:03 11.91 7 581.3 35.49 10/1/2015 12:03:03 11.96 7.02 577 35.36							
10/1/2015 12:02:03 11.91 7 581.3 35.49 10/1/2015 12:03:03 11.96 7.02 577 35.36							
10/1/2015 12:03:03 11.96 7.02 577 35.36	CONTRACTOR CONTRACTOR						
TO STATE OF THE PROPERTY OF TH							
10/1/2015 12:04:03 11.9 7.02 569.2 35.96	100						
	10/1/2015	12:04:03	11.9	7.02	569.2	35.96	



Client

OCSD

Location

Huntington Beach

Unit

ICE 5

Date

10/1/2015

Job Number

Date	Time	02%	CO2%	CO ppm	NOXppm	
10/1/2015	12:05:03	11.88	7.05	570.3	35.9	
10/1/2015	12:06:03	11.96	7.01	580.1	35.36	
10/1/2015	12:07:03	11.88	7.03	572.8		
10/1/2015	12:08:03	11.81	7.06	567.6	36.84	
10/1/2015	12:09:03	11.95	7.04	560.6		
10/1/2015	12:10:03	11.91	7.01	582.1	35.97	
10/1/2015	12:11:03	11.9	7.03	576.5		
10/1/2015	12:12:03	11.87	7.03	577.2	36	
10/1/2015	12:13:03	11.91	7.04	566.9		
10/1/2015	12:14:03	11.9	7.02	571.6	35.89	
10/1/2015	12:15:03	11.88	7.03	569.9	36.18	
10/1/2015	12:16:03	11.87	7.05	563.6	36.59	R 9
10/1/2015	12:17:03	11.83	7.05	566.7	36.84	
10/1/2015	12:18:03	12	6.95	577.6	35.36	
10/1/2015	12:19:03	11.88	7.03	577.2	36.3	
10/1/2015	12:20:03	11.99	6.95	574.8	35.65	
10/1/2015	12:21:03	11.94	7	568.2	36.01	
10/1/2015	12:22:03	11.84	7.04	569.9	36.42	
10/1/2015	12:23:03	11.89	7.05	569.2	35.85	
10/1/2015	12:24:03	11.96	7.03	577.5	35.24	
10/1/2015	12:25:03	11.94	7	578.1	35.75	
10/1/2015	12:26:03	11.96	7	570.6	35.55	
10/1/2015	12:27:03	11.85	7.05	568.5	36.8	
10/1/2015	12:28:03	11.85	7.08	549.5	36.89	
10/1/2015	12:29:03	11.81	7.08	553.5	36.91	
10/1/2015	12:30:03	11.79	7.08	552.6	37.31	
10/1/2015	12:31:03	11.81	7.08	553.8	36.88	
10/1/2015	12:32:03	11.92	7.04	552.9	36.76	
10/1/2015	12:33:03	11.89	7.04	557.1	36.38	
10/1/2015	12:34:03	11.98	7	568.5	35.92	
10/1/2015	12:35:03	11.9	7.04	563.8	36.58	
10/1/2015	12:36:03	11.84	7.03	561.9	36.74	
10/1/2015	12:37:03	11.87	7.03	558.2	36.99	
10/1/2015	12:38:03	11.77	7.1	545.7	38	
10/1/2015	12:39:03	11.82	7.09	551.7	37.41	
10/1/2015	12:40:03	11.9	7.03	552.1	36.99	
10/1/2015	12:41:03	11.89	7	552.2	36.87	
10/1/2015	12:42:03	11.85	7.02	553.3	37.65	
10/1/2015	12:43:03	11.85	7.03	548.6	37.36	
10/1/2015	12:44:03	11.87	7.04	555.6	36.98	



Client

OCSD

Location

Huntington Beach

Unit

ICE 5

Date

10/1/2015

Job Number

Date	Time	02%	CO2%	CO ppm	NOXppm
10/1/2015	12:45:03	11.85	7.03	561.6	37.1
10/1/2015	12:46:03	9.2	5.42	549.5	32.54
10/1/2015	12:47:03	0.35	0.35	173.4	1.43
10/1/2015	12:48:03	0.07	0.06	1.5	0.62
10/1/2015	12:49:03	0.03	-0.01	0.7	0.5
10/1/2015	12:50:03	0.03	-0.01	0.7	0.44
10/1/2015	12:51:03	0.03	-0.01	0.6	0.42 bias zero
10/1/2015	12:52:03	7.07	2.37	1	0.36
10/1/2015	12:53:03	12.09	4.1	1.1	0.33
10/1/2015	12:54:03	12.03	4.21	0.7	0.31 bias O2/CO2
10/1/2015	12:55:03	12	4.17	0.8	0.3
10/1/2015	12:56:03	2.55	0.76	1	0.28
10/1/2015	12:57:03	0.1	0.1	0.4	40.15
10/1/2015	12:58:03	0.11	0.04	0.6	45.32 bias NOx
10/1/2015	12:59:03	0.09	0.02	1	44.25
10/1/2015	13:00:03	0.15	0	243.8	4.36
10/1/2015	13:01:03	0.12	0_	443.1	2.02
10/1/2015	13:02:03	0.13	0	443.9	1.97 bias CO
10/1/2015	13:03:03	0.07	-0.01	334.9	1.21
10/1/2015	13:04:03	0.03	-0.02	9.5	0.45
10/1/2015	13:05:03	0.03	-0.02	0.4	0.38 zero
10/1/2015	13:06:03	13.45	5.23	93.4	70.12
10/1/2015	13:07:03	21.67	8.35	842.2	81.81
10/1/2015	13:08:03	21.84	8.71	902.6	90.98
10/1/2015	13:09:03	21.94	8.75	900.3	89.88 high
10/1/2015	13:10:03	19.09	7.59	874.5	78.75
10/1/2015	13:11:03	12.19	4.3	510.1	45.3
10/1/2015	13:12:03	12.15	4.29	454.1	45.27 mid
10/1/2015	13:13:03	9.35	3.19	447.5	39.46
10/1/2015	13:14:03	0.07	-0.02	103.3	0.38
10/1/2015	13:15:03	0.03	-0.02	0.5	0.29



APPENDIX E

QUALITY ASSURANCE AND QUALITY CONTROL (QA/QC)



Appendix E1

Test Equipment Calibration Data



Semi-Annual Field Dry Gas Meter Calibration* Calibration Date. 8/7/2015

Orifice Series: Serial Number: 33-73 AE₁/AE₂ Calibrated by: MC

(signature)

Cal Type:

Semi-Annual

Reviewed by: Cur

DGM ID. MB-00	3	ONTROL CHECKS	QUALITY CO				S	ER READING	RY GAS MET	D		
Serial #. 22416	dH@ _{Leve}	Average	0.98 <	(Y _{Im,max} -	Reading	Orifice f	eading	Meter R	UTLET	DGM C	NLET	DGM I
	< (dH@	Coeff (Y)	(Y_{im}/Y_{im})	Y _{fm.mm}) <	Final	Initial	Final	Initial	Final	Initial	Final	Initial
Calibration Interval:	± 0 15)	(0.95 <y<1.05)< td=""><td>1.02</td><td>0.010 **</td><td>(in H2O)</td><td>(in.H2O)</td><td>(cu.ft.)</td><td>(cu.fl.)</td><td>(°F)</td><td>(°F)</td><td>(°F)</td><td>(°F)</td></y<1.05)<>	1.02	0.010 **	(in H2O)	(in.H2O)	(cu.ft.)	(cu.fl.)	(°F)	(°F)	(°F)	(°F)
Semi-Annual: x					0 150	0.150	834.155	828.305	76.0	76.0	76.0	76.0
Bi-monthly.	2.049	0.986	0.999	0.0013	0.150	0.150	840.010	834.155	78.0	76.0	76.0	76.0
Olher	PASS	PASS	PASS	PASS	0.150	0.150	845.868	840.010	76.0	76.0	76 0	76,0
					0.840	0.840	853.420	847.300	77.0	77.0	77.0	76,0
Standard	1.941	0.984	0.997	0 0025	0.840	0.840	859.540	853.420	77.0	77.0	77.0	77,0
Temperature (deg F)	PASS	PASS	PASS	PASS	0.840	0.840	865,650	859.540	77.0	77.0	78.0	77.0
Tstd = 60					2.100	2.100	873.245	867.700	77.0	77.0	80.0	78.0
Barometric	1,997	0.987	1.000	0.0045	2.100	2.100	878.815	873,245	77.0	77.0	81.0	0,08
Pressure (in.Ha)	PASS	PASS	PASS	PASS	2.100	2,100	884.365	878.815	77.0	77.0	82.0	81.0
Initial: 29.8					3.900	3,900	895.555	889.000	78.0	77.0	86.0	83.0
Final: 29.8	1.962	0.990	1.003	0.0056	3,900	3.900	902.100	895,555	78.0	78.0	87.0	86.0
Pbar _{trep} : 29.8	PASS	PASS	PASS	PASS	3.900	3.900	908.636	902,100	78.0	78.0	87.0	87.0

			CR	ITICAL ORIF	ICE				DRY GAS ME	TER		CALCUL	ATIONS
Orifice					Corre	ected	11			Corre	ecled	Coefficient	
Series No.	Run Time (min)	Orifice K-factor	Tested Vacuum (in.Hg)	Ambient Temp. (°F)	Flowrate Q'rm (SCFM)	Volume (cu.ft.)	Onfice dH (in.H2O)	AVG Temp (°F)	NET Volume (cu.fl.)	Flowrate Q'fm (SCFM)	Volume (SCF)	Y _{fm} , (0.95 < Y _{fm} , < 1.05)	Orifice dH@, (in.H2O)
33	28	0.1549	26,50	76.0	0.2000	5.600	0.150	76 00	5.850	0.203	5.674	0.9870	2.049
33	28	0.1549	26.50	76.0	0.200	5.600	0.150	76 00	5.855	0.203	5.679	0.9861	2 049
33	28	0.1549	26,50	76.0	0.200	5.600	0.150	76 00	5.858	0.203	5.682	0.9856	2.049
52	12	0.3769	22.50	76.0	0.487	5.840	0.840	76 75	6.120	0.495	5.938	0 9835	1.942
52	12	0.3769	22.50	76,0	0.487	5.840	0.840	77.00	6.120	0.495	5,935	0.9840	1.941
52	12	0.3769	22,50	76.0	0.487	5,840	0.840	77.25	6,110	0.494	5.923	0.9860	1.940
63	7	0,5890	20.50	77.0	0.760	5.319	2 100	78.00	5.545	0.769	5.384	0.9879	1.999
63	7	0.5890	20,50	77.0	0.760	5.319	2.100	78.75	5.570	0.772	5.401	0.9848	1.996
63	7	0.5890	20.50	77.0	0.760	5.319	2.100	79.25	5.550	0.768	5.376	0.9893	1.995
73	6	0.8109	18 00	77.0	1 046	6.276	3.900	81.00	6.555	1.060	6.357	0.9873	1.965
73	6	0,8109	18.00	77.0	1.046	6.276	3,900	82.25	6,545	1.055	6.333	0.9911	1.961
73	6	0.8109	18.00	77 0	1.046	6.276	3.900	82.50	6,536	1.054	6 321	0.9929	1.960

^{*} Critical Orifice used.





Bi-Monthly Field Dry Gas Meter Calibration*

Calibration Date: 10/7/2015

 SEMI TO BI CHECK
 DRY GAS METER
 ORIFICE

 (+2% of Y)
 (-2% of Y)
 CALIBRATION FACTOR
 CALIBRATION FACTOR

 1.0068
 0.9674
 Y
 dH@

 PASS
 Yds = 0.9675
 dH@ = 1.975

Orifice Series:

52,63

Calibrated by: DJ

Serial Number:

AE₁/AE₂

(signature):

Cal Type:

Bi-Monthly

Reviewed by: Sun

	DRY GAS METER READINGS QUALITY CONTROL CHECKS						DGM ID:	MB-002					
DGM I	INLET	DGM C	UTLET	Meter F	Reading	Orifice	Reading	(Y _{fm,max} -	0.98 <	Average	dH@ _{i,avg}	Serial #:	
Initial	Final	Initial	Final	Initial	Final	Initial	Final	Y _{fm,min}) <	$(Y_{fm,i}/Y_{fm})$	Coeff.	< (dH@	Semi A Yfm:	0.9871
(°F)	(°F)	(°F)	(°F)	(cu.ft.)	(cu.ft.)	(in.H2O)	(in.H2O)	0.010 **	1.02	$Y_{fm,l}$	<u>+</u> 0.15)	Calibration	Interval:
74.0	74.0	74.0	74.0	416.467	422.685	0.850	0.850					Bi-monthly:	×
74.0	76.0	74.0	75.0	422.685	428.911	0.850	0.850	0.0032	0.997	0.965	1.962	Standa	ard
75.0	77.0	75.0	75.0	428.911	435.120	0.850	0.850	PASS	PASS	PASS	PASS	Temperature	e (deg.F)
79.0	80.0	76.0	76.0	452.990	458.620	2.100	2.100					Tstd =	60
80.0	81.0	76.0	77.0	458.620	464.255	2.100	2.100	0.0098	1,003	0.970	1.989	Barometric Pres	ssure (in.Hg
81.0	81.0	77.0	77.0	464.255	469.950	2.100	2.100	PASS	PASS	PASS	PASS	Pbar:	30.00

		CRITICAL ORIFICE					DRY GAS METER					CALCULATIONS	
Orifice					Corre	ected				Corr	ected	Coefficient	
No. Time	Run Time (min)	Orifice K-factor	Tested Vacuum (in.Hg)	uum Temp.	Flowrate Q'rm (SCFM)	Volume (cu.fl.)	Orifice dH (in.H2O)	AVG Temp. (°F)	NET Volume (cu.ft.)	Flowrate Q'fm (SCFM)	Volume (SCF)	Y _{fm.i} (0.95 < Y _{fm.i} < 1.05)	Orifice dH@ _i (in.H2O)
52	12	0.3769	23.0	75.0	0.489	5.868	0.850	74.00	6.218	0.507	6.087	0.9639	1.964
52	12	0.3769	23.0	75.0	0.489	5.868	0.850	74.75	6.226	0.507	6.087	0.9640	1.961
52	12	0.3769	23.0	76.0	0.489	5.862	0.850	75.50	6.209	0,505	6.062	0.9671	1.962
63	7	0.5890	21.0	76.0	0.763	5.344	2.100	77.75	5.630	0.784	5.490	0.9734	1.989
63	7	0.5890	21.0	77.0	0.763	5.339	2.100	78.50	5.635	0.784	5.487	0.9730	1.990
63	7	0.5890	21.0	77.0	0.763	5.339	2.100	79.00	5.695	0.792	5.541	0.9636	1.988

^{*} Critical Orifice used.







TYPE S PITOT TUBE SEMIANNUAL INSPECTION SHEET

CAL DATE: 7/2/2015

NEXT DUE DATE: 12/31/2015

PITOT ID: PT-83

	Parameter	Values	Allowable Range
Degree indicating level position for determining	Level and Perpendicular?	Yes OR No	Yes
α_1 and α_2	Obstruction?	Yes OR No	No
	Damaged?	Yes OR No	No
β, Degree	α1	1	$-10^{\circ} \le \alpha 1 \le +10^{\circ}$
β, indicating level position for determining	α2	+1	$-10^{\circ} \le \alpha 2 \le +10^{\circ}$
β_1 and β_2	β1	1	$-5^{\circ} \le \beta 1 \le +5^{\circ}$
	β2	1	$-5^{\circ} \le \beta 2 \le +5^{\circ}$
Degree indicating	γ	2	NA
level position for determining θ	θ	2	NA
	$Z = A (\tan \gamma)$	0.022	\leq 0.125 in.
Degree indicating level position	$W = A (\tan \theta)$	0.022	≤ 0.031 in.
	Dt	0.248	$0.188 \le Dt \le 0.375$
for determining y, then calculating z.	A	0.640	NA
	A/2/(Dt)	1.29	$1.05 \le PA/Dt \le 1.5$

Certification:

I certify that this pitot tube meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor Cp of 0.84.

Certified	By:
-----------	-----

Jan Date: 7/2/2015





ALMEGA ENVIRONMENTAL AND TECHNICAL SERVICES 10602 WALKER STREET CYPRESS, CA 90630

STACK TEMPERATURE SENSOR SEMI-ANNUAL CALIBRATION

83	REF. IMMERSION GLASS THERMOMETER ID: :1, 2 & 3
TRO-2	ICE BATH: YES
S-83	BOILING WATER: YES
113 inch	HOT OIL: YES
9/24/2015	CALIBRATED BY: LB Slufe
	TRO-2 S-83 113 inch

ICE BATH							
REF. IN HG. GLASS THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (^O F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	%	DIFFERENCE (%)			
35.0	35.0	0.0	euxer - 1.5	0.0			
35.0	35.0	0.0		0.0			
34.0	34.0	0.0		0.0			

BOILING WATER							
REF. IN HG. GLASS THERMOMETER TEMPERATURE (OF)	FIELD METER TEMPERATURE (^O F)	ABSOLUTE DIFFERENCE TEMPERATURE	%	DIFFERENCE (%)			
212.0	211.0	1.0		0.5			
213.0	212.0	1.0	99911112	0.5			
214.0	213.0	1.0		0.5			

HOT OIL							
REF. IN HG. GLASS THERMOMETER TEMPERATURE (OF)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE	%	DIFFERENCE (%)			
446.0	446.0	0.0		0.0			
448.0	448.0	0.0		0.0			
448.0	447.0	1.0		0.2			

NOTE:

MAXIMUM TOLERANCE BETWEEN ANY TWO MEASUREMENT IS 1.5%. TAKE READING EVERY ONE MINUTE.

REF. ICE BATH THERMOMETER: -30 - 120 (F)

REF. BOILING WATER THERMOMETER: 20 - 500 (F)

REF. HOT OIL THERMOMETER: 20 - 500 (F)





ALMEGA ENVIRONMENTAL AND TECHNICAL SERVICES 10602 WALKER STREET CYPRESS, CA 90630

STACK TEMPERATURE SENSOR BI-MONTHLY CALIBRATION

TEMPERATURE SENSOR I.D:	83	REF. IMMERSION GLASS THERMOMETER ID: : 1, 2	& 3
READ OUT I.D:	TRO-1	ICE BATH: YES	
PITOT TUBE I.D:	83	BOILING WATER: YES	
PITOT TUBE LENGTH:	113'	HOT OIL: YES	
DATE:	8/17/2015	CALIBRATED BY: LB L. S.	

ICE BATH							
REF. IN HG. GLASS THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE	%	DIFFERENCE (%)			
34.0	33.5	0.5		1.5			

BOILING WATER							
REF. IN HG. GLASS THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE (°F)	%	DIFFERÊNCE (%)			
213.0	215.0	2.0		0.9			

	}	HOT OIL		
REF. IN HG. GLASS THERMOMETER TEMPERATURE (°F)	FIELD METER TEMPERATURE (°F)	ABSOLUTE DIFFERENCE TEMPERATURE	%	DIFFERENCE (%)
415.0	414.0	1.0		0.2

NOTE:

MAXIMUM TOLERANCE BETWEEN ANY TWO MEASUREMENT IS 1.5%. TAKE READING EVERY ONE MINUTE.

REF. ICE BATH THERMOMETER: -30 - 120 (F)

REF. BOILING WATER THERMOMETER: 20 - 500 (F)

REF. HOT OIL THERMOMETER: 20 - 500 (F)





CERTIFICATE OF CALIBRATION

CUSTOMER:

ALMEGA ENVIRONMENTAL

CALIBRATION DATE: CALIBRATION DUE: 07/13/2015

PO NUMBER:

SHORTRIDGE

07/13/2016

INST. MANUFACTURER:

AIR FLOW TESTER

PROCEDURE:

NAVAIR-17-20MP-03

INST. DESCRIPTION:

ADM-880C

CALIBRATION FLUID:

AIR @ 70F A321 DUE 2-2016

MODEL NUMBER: SERIAL NUMBER:

M10327

STANDARD(S) USED: NIST TRACE #' 5:

1236086968

RATED UNCERTAINTY:

+/- 3% RD. + 5 FPM

AMBIENT CONDITIONS: 764 mmHGA, 43% RH, 74F

UNCERTAINTY GIVEN:

+/- .17% RD.; K=2

CERTIFICATE FILE #:

460189.2015A

NOTES:

AS RECEIVED / AS LEFT WITHIN SPECS.

	RUN 1			RUN 2			RUN 3	
UUT	DM.STD.		UUT	DM.STD.		UUT	DM.STD.	
INDICATED	ACTUAL	% RD.	INDICATED	ACTUAL	% RD.	INDICATED	ACTUAL	% RD.
"H2O	"H2O	ERROR	"H2O	"H2O	ERROR	"H20	"H2O	ERROR
0.0000	0.00000	0.000	0.0000	0.00000	0.000	0.0000	0.00000	0,000
0.0010	0.00102	2.000	0.0010	0.00101	1.000	0.0010	0.00102	2.000
0.0025	0.00252	0.800	0.0025	0.00252	0.800	0.0025	0.00252	0.800
0.0050	0.00505	1.000	0.0050	0.00507	1.400	0.0050	0.00506	1.200
0.0100	0.01009	0.900	0.0100	0.01008	0.800	0.0100	0.01010	1.000
0.0500	0.05015	0.300	0.0500	0.05012	0.240	0.0500	0.05011	0.220
0.5000	0.50033	0.066	0.5000	0.50025	0.050	0.5000	0.50028	0.056
1.0000	1.00530	0.530	1.0000	1.00041	0.041	1.0000	1.00045	0.045
2.5000	2.50099	0.040	2.5000	2.50097	0.039	2.5000	2.50089	0.036
5.0000	5.00174	0.035	5.0000	5.00122	0.024	5.0000	5.00115	0.023
7.5000	7.50185	0.025	7.5000	7.50179	0,024	7.5000	7.50153	0.020
10.0000	10.00256	0.026	10.0000	10.00255	0.025	10.0000	10.00224	0.022
	AVERAGE =	0.477	-	AVERAGE =	0.370	-	VERAGE =	0.452

All instruments used in the performance of the shown calibration have traceability to the National Institute of Standards and Technology (NIST). The uncertainty ratio between the calibration standards (DM.STD.) used and the unit under test (UUT) is a minimum of 4:1, unless otherwise noted. Calibration has been performed per the shown procedure number, in accordance with ISO 10012:2003, ISO 17025:2005. ANSI/NCSL-Z-540.3, and/or MIL-STD-45662A. Test methods: AP12530-92 & ASME MFC-3M-1989,

> Dick Munns Company • 10572 Calle Lee #130 • Los Alamitos, CA 90720 Phone (714) 827-1215 • Fax (714) 827-0823

This I alternation Certalia are sticil and the reported and ends or in state of expension of the state of the

Date

Approved By

Calibration Technician:

9849 OCSD Plant 2 Engine 5

E1-6

Page 1 of Page 107 of 1



Appendix E2

CEMS Calibration Gas Certificates



CERTIFICATE OF ANALYSIS

11711 S. Alameda Sireet Los Angeles , CA 90059

Grade of Product: EPA Protocol

(323) 568-2208 Fax (323) 567-3686

Airgas Specialty Gases

Part Number: Cylinder Number: E03NI69E15A3B32

CC408131

Reference Number: Cylinder Volume:

48-12-4459216-1 151.4 CF

Laboratory:

ASG - Los Angeles - CA

Cylinder Pressure:

2015 PSIG

PGVP Number: Gas Code:

B32014

Valve Outlet:

590

CO2,O2,BALN

Certification Date:

Oct 21, 2014

Expiration Date: Oct 21, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibra tion Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical Interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 pslg, i.e. 0.7 megapascals.

			ANALYTICAL	L RESULTS		
Compon	ent	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON	DIOXIDE	8.750 %	8.749 %	G1	+/- 0.6% NIST Traceable	10/21/2014
OXYGEN		22.00 %	21.99 %	G1	+/- 0.4% NIST Traceable	10/21/2014
NITROGE	N	Balance				
			CALIBRATION	STANDARDS		
Туре	Lot JD	Cylinder No	Concentration		Uncertainty	Expiration Date
NTRM	12061353	CC360995	11.002 % CARBON DI	OXIDE/NITROGEN	+/- 0.6%	Jan 11, 2018
NTRM	09061417	CC273563	22.53 % OXYGEN/NIT	ROGEN	+/- 0.4%	Mar 08, 2019
	,		ANALYTICAL	EQUIPMENT		4
Instrume	ent/Make/Mode	el '	Analytical Principle	-	Last Multipoint Calibrat	tion
SIEMENS	6E CO2		NDIR		Dct 13, 2D14	
SIEMENS	OXYMAT 6		PARAMAGNETIC		Oct 13, 2014	

Triad Data Available Upon Request







000082722

Praxair 5700 South Alameda Street Los Angeles, CA 90058 Tel: (323) 585-2154 Fax:(714) 542-6689 PGVPID: F22015

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR WHSE SIGNAL HILL 2677 SIGNAL PARKWAY

DocNumber:

SIGNAL HILL

907550 CA

Praxair Order Number: 32010813

Customer P. O. Number: 05655758

Customer Reference Number:

Fill Date Pari Number: 7/30/2015 NI CD4 301E-AS

109521109 Les Number:

Cylinder Style & Outlet: 2000 paig

CGA 590

Cylinder Pressure & Volume:

140 cu. ft

Certified Concentration:

Expiration Date:		8/5/2023	NIST Traceable		
Cylinder Number	er.	CC248731	Analytical Uncertainty		
	-		· · · · · · · · · · · · · · · · · · ·		
4,32	%	CARBON DIOXIDE	± 0.7 %		
12.01	%	OXYGEN	± 0.4 %		
	Balance	NITROGEN			

Certification Information:

Certification Date: 8/5/2015

Term: 96 Months

Expiration Date: 8/5/2023

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

O2 responses have been corrected for CO2 interference.

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate) Analytical Data:

1. Component: CARBON DIOXIDE

Requested Concentration. Certified Concentration. 4.32 %

Honba VIA-510 S/N 2807014 Instrument Used NDIR Analytical Method

7/13/2015 Last Multipoint Calibration

	4								_
	First	t Analys	is Dat	R;			Date:	8/5/2015	
į	Z:	0	R:	9.87	C:	4.32	Conc:	4.32	
į	R:	9 B7	Z:	D	C:	4.32	Conc:	4 32	
!	Z:	0	C:	4.32	R:	9 87	Conc:	4.32	
l	UON	A; %			Mea	n Test	Assay:	4 32 %	
L								-	

2. Component: OXYGEN

Requested Concentration. 12 01 % Certified Concentration OXYMAT 5E Instrument Used PARAMAGNETIC Analytical Method 7/24/2015 Last Multipoint Calibration:

	First	Analysi	e Dat	A:			Date:	8/5/2015	
1	Z:	0	R:	199	C:	12 01	Conc:	12 01	
	R:	19.9	Z:	0	C:	12 01	Conc:	12 01	
	Z:	0	C:	12 01	R:	19 9	Conc:	12 01	
	NOF	1: %			Men	n Test A	Assay:	12 01 %	

Analyzed by:

Reference Standard Type GMIS Ref Std Cylinder # . SA17695 Ref Std Conc 9 B7% Ref Std Traceable to SRM#. 1574b SRM Semple # 7-H-07 SRM Cylinder # FF10631

Second Analysis Data: Date: n R: n C 0 Conc: R: 0 Z: 0 C: 0 D Z: 0 n 0 Mean Tesi Assay: UOM: D %

Reference Standard Type GMIS Ref Std Cylinder# SA16022 Ref Std Conc 19 90% Ref Std Traceable to SRM# 2659a SRM Sample # 71-E-19 SRM Cylinder # FF22331

Second Analysis Data: Dale: n 7: D R. C: 0 Conc: R: D Z: 0 C: 0 Conc: D D Z! C: 0 R: 0 Conc: n UOM:

Certified by:

Jack Fu



Air Liquide America Specialty Gases LLC



COMPLIANCE CLASS

Dual-Analyzed Calibration Standard

8832 DICE ROAD, SANTA FE SPRINGS, CA 90670-2516

Phone: 800-323-2212

Fax: 562-464-5262

CERTIFICATE OF ACCURACY: EPA Protocol Gas

Assay Laboratory - PGVP Vendor ID: A52012

P.O. No.: RECERT

AIR LIQUIDE AMERICA SPECIALTY GASES LLC Document #: 45861199-001

8832 DICE ROAD

SANTA FE SPRINGS, CA 90670-2516

ALMEGA ENVIRONMENTAL & TECHNICAL SE

WEDNESDAY DELIVERY ONLY U 5251 MC FADDEN AVE. HUNTINGTON BEACH CA 92649

US

ANALYTICAL INFORMATION Gas Type: CO,BALN

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Ga seous Calibration Standards;

Procedure G-1; September, 1997.

CC259973

Certification Date:

18Apr2012

Exp. Date:

19Apr2020

Almega

Cylinder Number: Cylinder Pressure * * *:

1700 PSIG

Prev Certification Date: 07Apr2009

Batch No:

SB00052655

COMPONENT

CERTIFIED CONCENTRATION (Moles)

ACCURACY**

TRACEABILITY

CARBON MONOXIDE NITROGEN

PPM BALANCE

NIST and VSL

*** Do not use when cylinder pressure is below 150 psig.

** Analytical accuracy is based on the requirements of EPA Protocol procedures , September 1997.

REFERENCE STANDARD

TYPE/SRM NO.

NTRM 1681

EXPIRATION DATE

15Jun2015

CYLINDER NUMBER

KAL004633

CONCENTRATION

970.0 PPM

COMPONENT CARBON MONOXIDE

INSTRUMENTATION INSTRUMENT/MODEL/SERIAL# FTIR//001785245

DATE LAST CALIBRATED 09Apr2012

ANALYTICAL PRINCIPLE

Special Notes:

The expiration date has been extended without re-assay per EPA 600/R-12/531.

APPROVED BY:

9849 OCSD Plant 2 Engine 5 RATA

Page 111 of 142



CERTIFICATE OF ANALYSIS

Airgas Specialty Gases

Grade of Product: EPA Protocol

Los Angeles , CA 90059 323-568-2208 Fax: 323-567-3686

11711 S. Alameda Street

Part Number: Cylinder Number: E02NI99E15A0499

CC39463

ASG - Los Angeles - CA

Laboratory: PGVP Number: Gas Code:

B32014

CO.BALN

Reference Number:

48-124465925-1 as.com

Cylinder Volume: Cylinder Pressure: 144.3 CF 2015 PSIG

Valve Outlet:

350

Certification Date:

Dec 02, 2014

Expiration Date: Dec 02, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical Interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals

			ANALYTICAL	RESULTS		
Compon	ent	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON	MONOXIDE N	450.0 PPM Balance	453.8 PPM	G1	+/- 0.8% NIST Traceable	12/02/2014
Type	Lot ID	Cylinder No	CALIBRATION :	STANDARDS	Uncertainty	Expiration Date
NTRM	12062425	CC366875	487.1 PPM CARBON MO	NOXIDE/NITROGEN	+/- 0.6%	Jun 22, 2018
Instrume	ent/Make/Mode	ı	ANALYTICAL E Analytical Principle		Last Multipoint Calibra	ation
Nicolet 67	00 AMP0900118	CO	FTIR		Nov 21, 2014	

Triad Data Available Upon Request





Airgas Specialty Gases

11711 S. Alameda Street Los Angeles , CA 90059 323-568-2208 Fax: 323-567-3686 Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: Cylinder Number:

XC019657B

Laboratory: PGVP Number:

Gas Code:

E02NI99E15AC0D7

ASG - Los Angeles - CA

B32015

NO.NOX,BALN

Reference Number:

Cylinder Volume:

48-124495805-1 144.3 CF

Cylinder Pressure:

2015 PSIG

Valve Outlet:

660

Certification Date:

Jun 09, 2015

Expiration Date: Jun 09, 2018

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals

ANALYTICAL RESULTS							
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates		
NOX	45.00 PPM	45.45 PPM	G1	+/- 1.0% NIST Traceable	06/01/2015, 06/09/2015		
NITRIC OXIDE NITROGEN	45.00 PPM Balance	45.31 PPM	G1	+/- 1.0% NIST Traceable	06/01/2015, 06/09/2015		

Туре	Lot ID	Cylinder No	CALIBRATION STANDARDS Concentration	Uncertainty	Expiration Date
NTRM	13061216	CC403894	49.40 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Nov 19, 2019
PRM	12328	680179	10.01 PPM NITROGEN DIOXIDE/NITROGEN	+/- 2.0%	Oct 15, 2014
NTRM	13061245	CC403940	49.40 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Nov 19, 2019
GMIS	1211201301	CC501041	4.950 PPM NITROGEN DIOXIDE/NITROGEN	+/- 2.0%	Dec 11, 2016

	ANALYTICAL EQUIP	MENT
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801551 NO	FTIR	May 22, 2015
Nicolet 6700 AHR0801551 NO2	FTIR	May 21, 2015

Triad Data Available Upon Request



Approved for Release



CERTIFICATE OF ANALYSIS Grade of Product: EPA Protocol

Airgas Specialty Gases 11711 South Alameda Street Los Angeles, CA 90059 (323) 568-2203 Fax: (323) 567-3686 www.alrgas.com

Part Number:

E02NI99E15A3576

Cylinder Number:

CC199782

Laboratory:

ASG - Los Angeles - CA

PGVP Number:

B32013

Gas Code:

NO, BALN

Reference Number: 48-12-4376725-6

Cylinder Volume:

Cylinder Pressure: 2015 PSIG

Valve Outlet:

660

Certification Date:

Jun 07, 2013

144.3 Cubic Feet

Expiration Date: Jun 07, 2021

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical Interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

Component	Requested Concentration	ANALYTICAL I Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	90.00 PPM	89.91 PPM	G1	+/- 0.9% NIST Traceable	05/31/2013, 06/07/2013
NITRIC OXIDE	90.00 PPM	89.88 PPM	G1	+/- 0.9% NIST Traceable	05/31/2013, 06/07/2013
NITROGEN	Balance				

CALIBRATION STANDARDS							
Туре	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date		
NTRM	11060532	CC331845	101.2 PPM NITRIC OXIDE/NITROGEN	+/- 0.6%	Feb 16, 2017		
PRM	12312	680179	10.01 PPM NITROGEN DIOXIDE/NITROGEN	+/- 2.0%	Feb 14, 2012		
GMIS	124208889129	CC323206	4.835 PPM NITROGEN DIOXIDE/NITROGEN	+/-2.0%	Oct 11, 2013		
	,		MIS used in the assay and not part of the analysis.	7 2.0 /0	00111, 2013		

ANALYTICAL EQUIPMENT						
Instrument/Make/Model Analytical Principle Last Multipoint Calibration						
Nicolet 6700 AMP0900118 NO	FTIR	May 09, 2013				
Nicolet 6700 AMP0900118 NO2	FTIR	May 20, 2013				

Triad Data Available Upon

Request

Notes:

Approved for Release

Mar



Airgas Specialty Gases

11711 S. Alameda Street Los Angeles, CA 90059 (323) 568-2208 Fax: (323) 567-3686 www.airgas.com

CERTIFICATE OF ANALYSIS Grade of Product: EPA Protocol

Part Number:

E02NI99E15W4BQ4

Reference Number:

48-124424353-1

Cylinder Number:

CC502676

Cylinder Volume:

Laboratory:

ASG - Los Angeles - CA

Cylinder Pressure:

CF

PGVP Number:

B32014

Valve Outlet:

660

Gas Code:

Certification Date:

Mar 27, 2014

NO2, BALN

Expiration Date: Apr 03, 2017

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

			ANALYTICAL I	RESULTS		
NITROGEN DIOXIDE 16		Requested Concentration	Actual	Protocol Method	Total Relative Uncertainty +/- 2.0% NIST Traceable	Assay Dates 03/27/2014, 04/03/2014
		16.50 PPM				
		Balance				
			CALIBRATION ST	FANDARDS		
Туре	Lot ID	Cylinder No	Concentration		Uncertainty	Expiration Date
GMIS	1211201301	CC500610	14.91 PPM NITROGEN DIOXIDE/NITROGEN		+/- 1.6%	Dec 11, 2016
PRM	12329	726612	25.02 PPM NITROGEN DI	OXIDE/NITROGEN	+/- 1.5%	Oct 15, 2014
The SRM.	, PRM or RGM noted	above is only in reference to the	ne GMIS used in the assay and	not part of the analys	sis.	
			ANALYTICAL EQ	UIPMENT		
Instrument/Make/Model			Analytical Principle	Last Multi	Last Multipoint Calibration	
Nicolet 6700 AHR0801551 NO2			FTIR	Mar 13, 201	Mar 13, 2014	

Triad Data Available Upon Request

Permanent Notes OXYGEN ADDED

TO MAINTAIN STABILITY

Notes:

Approved for Release



Appendix E3

Other QA/QC



Reference Method QA/QC

Facility: OCSD, Plant No. 2 City: Huntington Beach, CA

Source: Engine 5
Test: RATA
Test Date: 10/01/15

NO₂-to-NO CONVERTER EFFICIENCY CALCULATION

NO2 CONCENTRATION (Co):	16.46
AUDIT GAS WITH NO MODE (C1):	0.16
AUDIT GAS WITH NOx MODE (C2):	15.91

CALCULATIONS:

D1=|C2-C1|= 15.75 D2=|Co-C2|= **0.55**

% CONVERTER EFFICIENCY: %CE=D1*100/Co= 95.7

Acceptance Criteria* (Yes/No)
D2 < 1 ppm: yes
% Converter Efficiency > 90%: yes

STATUS: PASS

Note: Stripchart and DAS can be found in Appendix D2 and D3 respectively. NOx analyzer was calibrated on a 0-100ppm range, while the NO_2 calibration gas used was below 20% of this range (16.46ppm). Converter efficiency value is still considered valid.

^{*} NO2-to-NO Conversion Efficiency must be greater than 90%



NOx Converter, QA/QC Check

Facility:

OCSD, Plant No. 2

Huntington Beach, CA

Run No.: 1

City:

Engine 5

Test Date: 10/01/2015 **Test: NOx Converter Check**

Source: Test:

RATA

TEST DATA		Pollutant 1	
VARIABLE	DESCRIPTION	<u>NOx</u>	
Α	ANALYTICAL RANGE	100	
	Unit of Measurement	ppmd	
	CALIBRATION GAS INFORMATION		
В	Zero Gas	0.00	
C	Mid Gas Concentration	45.31	
	Mid Gas Cylinder S/N:	XC019657B	
D	High Gas Concentration	89.88	
	High Gas Cylinder S/N:	CC199782	
	Primary Gas Cylinder S/N:		
E	UPSCALE CALIBRATION GAS USED	45.31	
	L=Low, M=Mid, H=High	\mathbf{M}	
	INITIAL CALIBRATION ERROR TEST		
F	Zero Gas Response	0.00	
G	Mid Gas Response	45.31	
H	High Gas Reponse	89.86	

QA/QC CALCULATIONS

CALIBRATION GAS SELECTION, % of Range		
Mid Gas	45.3	C*100/A
High Gas	89.9	D*100/A
CALIBRATION ERROR, % of Range		
Initial Zero Gas Error	0.00	(F-B)*100/A
Initial Mid Gas Error	0.00	(G-C)*100/A
Initial High Gas Error	-0.02	(H-D)*100/A
LINEARITY, % of Range		
Initial	0.01	{(G-F)-[(H-F)*C]/D}*100/A



APPENDIX F FACILITY CEMS DATA



Appendix F1

FACILITY CEMS - Results and Calculations



Facility CEMS Data Summary

Facility: OCSD, Plant No. 2

City: Huntington Beach, CA

Source: Engine 5 Test: RATA Date: 10/1/2015

Run No.	Time (hh:mm)	NOx ppm	NOx ppm@15%O2	NOx lb/hr	CO ppm	CO ppm@15%O2	CO lb/hr	Dry Flow dscfh	O2 %
1	7:43-8:12	38.01	25.02	2.71	644.87	424.59	28.03	597,826	11.94
2	8:13-8:42	39.79	26.03	2.85	627.39	410.59	27.38	600,191	11.88
3	8:43-9:12	39.60	26.33	2.93	632.74	420.71	28.44	618,448	12.03
4	9:31-10:00	38.89	25.53	2.79	638.91	419.45	27.88	600,512	11.91
5	10:01-10:30	40.14	26.56	2.91	629.02	416.17	27.73	606,556	11.98
6	10:31-11:00	39.73	26.31	2.93	634.26	419.98	28.45	617,090	11.99
7	11:16-11:45	39.61	25.75	2.81	629.08	408.90	27.16	593,955	11.82
8	11:46-12:15	39.46	26.15	2.86	632.51	419.20	27.88	606,370	12.00
9	12:16-12:45	40.01	26.21	2.86	623.82	408.64	27.16	599,077	11.89
Average:		39.47	25.99	2.85	632.51	416.47	27.79	604,447	11.94



Facility Process Data

Facility: OCSD, Plant No. 2

City: Huntington Beach, CA

Source: Engine 5
Test: RATA
Date: 10/1/2015

Run	Load	Nat Gas Flow	Dig Gas Flow
No.	%	dscfm	dscfm
1	80.46	14.55	732.22
2	83.18	14.70	739.55
3	84.78	15.00	749.90
4	82.32	14.64	737.63
5	83.86	14.70	739.24
6	84.96	14.98	751.40
7	84.30	14.62	736.90
8	83.50	14.87	737.46
9	83.17	15.64	735.93
Average:	83.39	14.86	740.03

RATA Report 1

10/1/2015 8:28:56 AM Page 1 of 1

Unit Name: OCSD P2 Unit 5 Report Start Date/Time: Thu 10/01/2015 7:43

Report End Date/Time: Thu 10/01/2015 8:12

DATE/TIME	NOx Raw (ppmvd)	NOx @15%O2 (ppmvd)	NOx Lbs/Hr	O2 (%)	Stack Flow (dscfm)	CO Raw (ppmvd)	CO @15%O2 (ppmvd)	CO Lbs/Hr
10/01/2015 7:43	37.61 V	24.86 V	2.75 V	11.97 V	10208.54 V	656.50 V	433.87 V	29.23 V
10/01/2015 7:44	38.10 V	25.57 V	2.83 V	12.11 V	10368.84 V	643.90 V	432.20 V	29.12 V
10/01/2015 7:45	37.89 V	25.12 V	2.78 V	12.00 V	10240.38 V	648.80 V	430.10 V	28.97 V
10/01/2015 7:46	36.95 V	24.54 V	2.71 V	12.02 V	10225.46 V	662.10 V	439.79 V	29.52 V
10/01/2015 7:47	37.54 V	24.81 V	2.74 V	11.97 V	10192.42 V	649.90 V	429.51 V	28.89 V
10/01/2015 7:48	37.78 V	25.09 V	2.79 V	12.02 V	10284.66 V	644.30 V	427.84 V	28.90 V
10/01/2015 7:49	37.02 V	24.93 V	2.70 V	12.14 V	10162.03 V	671.40 V	452.07 V	29.75 V
10/01/2015 7:50	37.24 V	24.62 V	2.64 V	11.98 V	9896.09 V	654.70 V	432.80 V	28.25 V
10/01/2015 7:51	37.44 V	24.44 V	2.65 V	11.86 V	9873.67 V	653.40 V	426.45 V	28.13 V
10/01/2015 7:52	37.05 V	24.42 V	2.65 V	11.95 V	9983.97 V	655.90 V	432.38 V	28.56 V
10/01/2015 7:53	37.54 V	24.62 V	2.71 V	11.91 V	10051.94 V	648.20 V	425.17 V	28.41 V
10/01/2015 7:54	37.44 V	24.67 V	2.69 V	11.95 V	10016.01 V	648.50 V	427.38 V	28.33 V
10/01/2015 7:55	38.24 V	25.27 V	2.77 V	11.97 V	10089.73 V	646.70 V	427.39 V	28.45 V
10/01/2015 7:56	37.55 V	24.75 V	2.71 V	11.95 V	10079.71 V	653.50 V	430.68 V	28.73 V
10/01/2015 7:57	39.11 V	25.65 V	2.82 V	11.91 V	10072.08 V	624.20 V	409.43 V	27.42 V
10/01/2015 7:58	37.38 V	24.96 V	2.73 V	12.06 V	10197.61 V	657.80 V	439.15 V	29.25 V
10/01/2015 7:59	38.66 V	25.61 V	2.81 V	12.00 V	10128.69 V	645.00 V	427.34 V	28.49 V
10/01/2015 8:00	38.45 V	25.41 V	2.75 V	11.97 V	9958.09 V	639.10 V	422.37 V	27.75 V
10/01/2015 8:01	37.54 V	24.69 V	2.68 V	11.93 V	9958.74 V	654.80 V	430.69 V	28.44 V
10/01/2015 8:02	38.21 V	25.25 V	2.76 V	11.97 V	10089.43 V	641.30 V	423.82 V	28.22 V
10/01/2015 8:03	37.34 V	24.94 V	2.71 V	12.07 V	10108.50 V	658.60 V	439.81 V	29.03 V
10/01/2015 8:04	36.87 V	24.25 V	2.61 V	11.93 V	9859.81 V	659.30 V	433.65 V	28.35 V
10/01/2015 8:05	37.92 V	24.75 V	2.67 V	11.86 V	9817.36 V	639.10 V	417.11 V	27.36 V
10/01/2015 8:06	37.99 V	25.04 V	2.68 V	11.95 V	9833.54 V	645,60 V	425.47 V	27.69 V
10/01/2015 8:07	38.02 V	24.75 V	2.61 V	11.84 V	9560.39 V	644.30 V	419.46 V	26.86 V
10/01/2015 8:08	39.57 V	25.63 V	2.71 V	11.79 V	9549.14 V	617.80 V	400.22 V	25.73 V
10/01/2015 8:09	39,68 V	25.70 V	2.72 V	11.79 V	9556.76 V	623.00 V	403.48 V	25,96 V
10/01/2015 8:10	39.22 V	25.41 V	2.69 V	11.79 V	9564.94 V	619.00 V	401.00 V	25.82 V
10/01/2015 8:11	39.26 V	25.29 V	2.67 V	11.74 V	9491.79 V	621.20 V	400.12 V	25.71 V
10/01/2015 8:12	39.64 V	25.46 V	2.70 V	11.72 V	9492.36 V	618.10 V	397.04 V	25.59 V
Average:	38.01	25.02	2.71	11.94	9963.76	644.87	424.59	28.03
Maximum:	39.68	25.70	2.83	12.14	10368.84	671.40	452.07	29.75
Minimum:	36.87	24.25	2.61	11.72	9491.79	617.80	397.04	25.59





Unit Name: OCSD P2 Unit 5 Report Start Date/Time: Thu 10/01/2015 7:43

Report End Date/Time: Thu 10/01/2015 8:12

DATE/TIME	ICE % Load	Digester Gas Flow (dscfm)	Natural Gas Flow (dscfm)	NOx @15%O2 (ppmvd)	CO @15%O2 (ppmvd)	
10/01/2015 7:43	78.31	747.24	14.93	24.86	433.87	
10/01/2015 7:44	78.07	746.84	15.21	25.57	432.20	
10/01/2015 7:45	80.77	747.04	15,07	25.12	430.10	
10/01/2015 7:46	80.21	744.40	15.07	24.54	439.79	
10/01/2015 7:47	79.94	746.03	14.93	24.81	429.51	
10/01/2015 7:48	77.17	749.07	15.07	25.09	427.84	
10/01/2015 7:49	82.54	729.99	14.65	24.93	452.07	
10/01/2015 7:50	85.54	724.10	14.51	24.62	432.80	
10/01/2015 7:51	80.51	732.02	14.51	24.44	426.45	
10/01/2015 7:52	84.29	732.63	14.65	24.42	432.38	
10/01/2015 7:53	79.23	741.15	14.93	24.62	425.17	
10/01/2015 7:54	82.78	735.27	14.65	24.67	427.38	
10/01/2015 7:55	80.32	738.72	14.65	25.27	427.39	
10/01/2015 7:56	82.39	740.54	14.37	24.75	430.68	
10/01/2015 7:57	76.99	743.59	14.37	25.65	409.43	
10/01/2015 7:58	86.02	739.33	14.51	24.96	439.15	
10/01/2015 7:59	80.75	739.73	14.65	25.61	427.34	
10/01/2015 8:00	78.33	728.77	14.65	25.41	422.37	
10/01/2015 8:01	82.13	732.63	14.51	24.69	430.69	
10/01/2015 8:02	77.36	738.92	14.51	25.25	423.82	
10/01/2015 8:03	83.50	732.22	14.65	24.94	439.81	
10/01/2015 8:04	76.34	725.12	14.51	24.25	433.65	
10/01/2015 8:05	81.63	728.16	14.23	24.75	417.11	
10/01/2015 8:06	79.81	721.67	14.51	25.04	425.47	
10/01/2015 8:07	83.63	710.09	14.37	24.75	419.46	
10/01/2015 8:08	76.21	713.55	13.95	25.63	400.22	
10/01/2015 8:09	82.29	714.56	13.81	25.70	403.48	
10/01/2015 8:10	79.76	714.76	13.95	25.41	401.00	
10/01/2015 8:11	79.19	713.34	13.95	25.29	400.12	
10/01/2015 8:12	77.84	715.17	14.09	25.46	397.04	
Total:		and the	10000	73.736.	Tuesday	
Average:	80.46	732.22	14.55	25.02	424.59	
Maximum:	86.02	749.07	15.21	25.70	452.07	
Minimum:	76.21	710.09	13,81	24.25	397.04	

Rel



OCSD P2 Unit 5

Report Start Date/Time :

Thu 10/01/2015 8:13

Report End Date/Time :

Thu 10/01/2015 8:42

DATE/TIME	NOx Raw	NOx @15%O2	NOx Lbs/Hr	O2 (%)	Stack Flow	CO Raw	CO @15%O2	CO Lbs/Hr
	(ppmvd)	(ppmvd)			(dscfm)	(ppmvd)	(ppmvd)	
10/01/2015 8:13	40.72 V	26.15 V	2.77 V	11.71 V	9482.23 V	609.10 V	391.15 V	25.19 V
10/01/2015 8:14	39.51 V	25.37 V	2.70 V	11.71 V	9523.71 V	616.80 V	396.10 V	25.62 V
10/01/2015 8:15	40.79 V	26.20 V	2.78 V	11.72 V	9508.03 V	603.80 V	387.85 V	25.04 V
10/01/2015 8:16	40.88 V	26.25 V	2.83 V	11.71 V	9651.33 V	607.80 V	390.32 V	25.58 V
10/01/2015 8:17	40.40 V	25.94 V	2.84 V	11.71 V	9805.93 V	608.10 V	390.51 V	26.00 V
10/01/2015 8:18	41.02 V	26.49 V	2.88 V	11.76 V	9778.52 V	608.50 V	392.90 V	25.95 V
10/01/2015 8:19	40.23 V	26.25 V	2.86 V	11.86 V	9929.88 V	618.10 V	403.29 V	26.77 V
10/01/2015 8:20	40.33 V	26.32 V	2.85 V	11.86 V	9861.29 V	628.50 V	410.19 V	27.03 V
10/01/2015 8:21	39.32 V	25.52 V	2.74 V	11.81 V	9713.82 V	635.40 V	412.42 V	26.92 V
10/01/2015 8:22	40.22 V	25.91 V	2.85 V	11.74 V	9867.08 V	617.50 V	397.74 V	26.57 V
10/01/2015 8:23	40.65 V	26.46 V	2.88 V	11.84 V	9887.01 V	617.20 V	401.71 V	26.61 V
10/01/2015 8:24	38.98 V	25.37 V	2.74 V	11.84 V	9817.63 V	640.50 V	416.87 V	27.42 V
10/01/2015 8:25	38.97 V	25.36 V	2.76 V	11.84 V	9869.95 V	625.40 V	407.05 V	26.92 V
10/01/2015 8:26	38.87 V	25.42 V	2.76 V	11.88 V	9890.16 V	642.20 V	419.95 V	27.70 V
10/01/2015 8:27	39.64 V	25.67 V	2.76 V	11.79 V	9710.63 V	635.10 V	411.32 V	26.89 V
10/01/2015 8:28	39.32 V	25.59 V	2.76 V	11.84 V	9801.76 V	627.50 V	408.41 V	26.82 V
10/01/2015 8:29	39.50 V	25.58 V	2.78 V	11.79 V	9829.39 V	622.60 V	403.22 V	26.69 V
10/01/2015 8:30	39.97 V	25.89 V	2.85 V	11.79 V	9929.73 V	620.50 V	401.86 V	26.87 V
10/01/2015 8:31	39.82 V	26.11 V	2.88 V	11.90 V	10077.87 V	630.20 V	413.25 V	27.70 V
10/01/2015 8:32	38.93 V	25.45 V	2.82 V	11.88 V	10087.03 V	632.30 V	413.36 V	27.81 V
10/01/2015 8:33	39.57 V	26.07 V	2.93 V	11.95 V	10314.08 V	626.00 V	412.44 V	28.16 V
10/01/2015 8:34	39.88 V	26.36 V	2.95 V	11.97 V	10318.98 V	632.00 V	417.68 V	28.44 V
10/01/2015 8:35	39.95 V	26.40 V	2.97 V	11.97 V	10357.49 V	635.00 V	419.66 V	28.68 V
10/01/2015 8:36	39.94 V	26.52 V	3.00 V	12.02 V	10471.22 V	631.20 V	419.14 V	28.82 V.
10/01/2015 8:37	39.54 V	26.32 V	2.98 V	12.04 V	10497.80 V	642.50 V	427.73 V	29.41 V
10/01/2015 8:38	39.66 V	26.48 V	2.95 V	12.06 V	10386.99 V	636.40 V	424.87 V	28.83 V
10/01/2015 8:39	39.00 V	25.97 V	2.89 V	12.04 V	10345.86 V	644.90 V	429.45 V	29.10 V
10/01/2015 8:40	40.49 V	26.96 V	3.01 V	12.04 V	10365.42 V	621.10 V	413.60 V	28.08 V
10/01/2015 8:41	38.93 V	26.49 V	2.96 V	12.23 V	10606.09 V	656.80 V	446.96 V	30.38 V
10/01/2015 8:42	38.62 V	26.00 V	2.88 V	12.14 V	10408.74 V	648.80 V	436.73 V	29.45 V
Average:	39.79	26.03	2.85	11.88	10003.19	627.39	410.59	27.38
Maximum:	41.02	26.96	3.01	12.23	10606.09	656.80	446.96	30.38
Minimum:	38.62	25.36	2.70	11.71	9482.23	603.80	387.85	25.04





OCSD P2 Unit 5

Report Start Date/Time :

Thu 10/01/2015 8:13

Report End Date/Time:

Thu 10/01/2015 8:42

DATE/TIME	ICE % Load	Digester Gas Flow (dscfm)	Natural Gas Flow (dscfm)	NOx @15%O2 (ppmvd)	CO @15%O2 (ppmvd)		
10/01/2015 8:13	81.71	714.36	14.23	26.15	391.15		
10/01/2015 8:14	83.03	717.81	14.09	25.37	396.10		
10/01/2015 8:15	77.20	716.39	14.09	26.20	387.85		
10/01/2015 8:16	79.17	727.96	13.95	26.25	390.32		
10/01/2015 8:17	81.21	739.53	14.23	25.94	390.51		
10/01/2015 8:18	83.18	733.03	14.37	26.49	392.90		
10/01/2015 8:19	79.77	736.08	14.79	26.25	403.29		
10/01/2015 8:20	79.90	730.39	14.93	26.32	410.19		
10/01/2015 8:21	80.86	723.90	14.51	25.52	412.42		
10/01/2015 8:22	88.48	741.76	14.37	25.91	397.74		
10/01/2015 8:23	80.18	734.45	14.93	26.46	401.71		
10/01/2015 8:24	82.65	729.58	14.65	25.37	416.87		
10/01/2015 8:25	85.94	734.05	14.37	25.36	407.05		
10/01/2015 8:26	83.33	731.82	14.51	25.42	419.95		
10/01/2015 8:27	79.13	725.52	14.37	25.67	411.32		
10/01/2015 8:28	84.65	728.36	14.65	25.59	408.41		
10/01/2015 8:29	84.32	734.45	14.51	25.58	403.22		
10/01/2015 8:30	85.16	741.97	14.65	25.89	401.86		
10/01/2015 8:31	84.82	743.79	14.65	26.11	413.25		
10/01/2015 8:32	88.39	746.84	14.65	25.45	413.36		
10/01/2015 8:33	87.25	757.39	15.07	26.07	412.44		
10/01/2015 8:34	87.87	755.36	15.07	26.36	417.68		
10/01/2015 8:35	82.91	757.60	15.48	26.40	419.66		
10/01/2015 8:36	82.97	762.87	15.21	26.52	419.14		
10/01/2015 8:37	84.67	762.87	15.21	26.32	427.73		
10/01/2015 8:38	84.88	751.91	15.48	26.48	424.87		
10/01/2015 8:39	82.42	751.71	14.93	25.97	429.45		
10/01/2015 8:40	81.83	752.72	15.21	26.96	413.60		
10/01/2015 8:41	82.95	753.94	15.07	26.49	446.96		
10/01/2015 8:42	84.70	748.06	14.93	26.00	436.73		
Total:							
Average:	83.18	739.55	14.70	26.03	410.59		
Maximum:	88.48	762.87	15.48	26.96	446.96		
Minimum:	77.20	714.36	13.95	25.36	387.85		



OCSD P2 Unit 5



Report Start Date/Time: Thu 10/01/2015 8:43

Report End Date/Time: Thu 10/01/2015 9:12

DATE/TIME	NOx Raw (ppmvd)	NOx @15%O2 (ppmvd)	NOx Lbs/Hr	O2 (%)	Stack Flow (dscfm)	CO Raw (ppmvd)	CO @15%O2 (ppmvd)	CO Lbs/Hr
10/01/2015 8:43	39.71 V	26.44 V	2.95 V	12.04 V	10351.28 V	629.80 V	419.39 V	28.43 \
10/01/2015 8:44	40.08 V	26.82 V	2.98 V	12.08 V	10363.39 V	629.80 V	421.41 V	28.46 V
10/01/2015 8:45	39.25 V	26.15 V	2.91 V	12.04 V	10335.25 V	640.10 V	426.37 V	28.85 V
10/01/2015 8:46	39.35 V	26.21 V	2.91 V	12.04 V	10327.43 V	640.40 V	426.57 V	28.84 \
10/01/2015 8:47	39.81 V	26.31 V	2.94 V	11.97 V	10286.74 V	627.50 V	414.70 V	28.15 V
10/01/2015 8:48	40.19 V	26.89 V	3.03 V	12.08 V	10496.67 V	627.90 V	420.14 V	28.74 V
10/01/2015 8:49	40.39 V	26.90 V	3.03 V	12.04 V	10449.33 V	623.90 V	415.46 V	28.43 V
10/01/2015 8:50	39.28 V	26.23 V	2.94 V	12.07 V	10446.93 V	641.60 V	428.46 V	29.23 V
10/01/2015 8:51	39.27 V	26.43 V	2.98 V	12.14 V	10568.67 V	637,70 V	429.26 V	29.39 V
10/01/2015 8:52	39.46 V	26.40 V	2.93 V	12.08 V	10357.65 V	642.80 V	430.11 V	29.03 V
10/01/2015 8:53	39.60 V	26.38 V	2.95 V	12.04 V	10370.45 V	633.70 V	422.11 V	28.66 V
10/01/2015 8:54	39.28 V	26.36 V	2.97 V	12.11 V	10526.21 V	642.00 V	430.80 V	29.47 V
10/01/2015 8:55	40.13 V	26.72 V	2.99 V	12.04 V	10403.31 V	629.80 V	419.39 V	28.57 V
10/01/2015 8:56	39.88 V	26.43 V	2.95 V	12.00 V	10324.02 V	633.70 V	419.98 V	28.53 V
10/01/2015 8:57	41.34 V	27.53 V	3.06 V	12.04 V	10338.35 V	611.20 V	407.01 V	27.56 V
10/01/2015 8:58	39.67 V	26.09 V	2.90 V	11.93 V	10200.41 V	629.80 V	414.13 V	28.02 V
10/01/2015 8:59	39.78 V	26.57 V	2.96 V	12.07 V	10380.87 V	631.90 V	421.98 V	28,61 V
10/01/2015 9:00	39.60 V	26.30 V	2.94 V	12.02 V	10354.54 V	626.00 V	415.69 V	28.27 V
10/01/2015 9:01	39.11 V	26.05 V	2.91 V	12.04 V	10365.33 V	636.90 V	424.24 V	28.79 V
10/01/2015 9:02	39.25 V	26.14 V	2.89 V	12.04 V	10251.42 V	640.80 V	426.72 V	28.65 V
10/01/2015 9:03	38.83 V	25.73 V	2.84 V	12.00 V	10197.10 V	647.50 V	429.12 V	28.79 V
10/01/2015 9:04	38.27 V	25.41 V	2.80 V	12.02 V	10216.27 V	645.00 V	428.31 V	28.74 V
10/01/2015 9:05	39.11 V	26.12 V	2.87 V	12.07 V	10247.25 V	634.80 V	423,92 V	28.37 V
10/01/2015 9:06	40.12 V	26.64 V	2.93 V	12.02 V	10181.18 V	620.80 V	412.24 V	27.56 V
10/01/2015 9:07	39.78 V	26.22 V	2.89 V	11.95 V	10128.23 V	627.40 V	413.48 V	27.71 V
10/01/2015 9:08	39.32 V	25.78 V	2.85 V	11.90 V	10102.46 V	631.90 V	414.36 V	27.84 V
10/01/2015 9:09	40.40 V	26.63 V	2.94 V	11.95 V	10147.88 V	619.20 V	408.07 V	27.40 V
10/01/2015 9:10	39.92 V	26.31 V	2.93 V	11.95 V	10238.67 V	624.20 V	411.37 V	27.87 V
10/01/2015 9:11	38,66 V	25.75 V	2.82 V	12.04 V	10164.96 V	639.20 V	425.77 V	28.33 V
10/01/2015 9:12	39.14 V	25.94 V	2.84 V	12.00 V	10101.90 V	635.00 V	420.84 V	27.97 V
Average:	39.60	26.33	2.93	12.03	10307.47	632.74	420.71	28.44
Maximum:	41.34	27.53	3.06	12.14	10568.67	647.50	430.80	29.47
Minimum:	38.27	25.41	2.80	11.90	10101.90	611.20	407.01	27.40





OCSD P2 Unit 5

Report Start Date/Time :

Thu 10/01/2015 8:43

Report End Date/Time:

Thu 10/01/2015 9:12

DATE/TIME	ICE % Load	Digester Gas	Natural Gas	NOx @15%O2	CO @15%O2	- H X -	
		Flow (dscfm)	Flow (dscfm)	(ppmvd)	(ppmvd)		
10/01/2015 8:43	89.11	752.12	14.93	26.44	419.39		
10/01/2015 8:44	83.15	749.07	15.07	26.82	421.41		
10/01/2015 8:45	86.24	750.69	14.93	26.15	426.37		
10/01/2015 8:46	87.46	749.88	15.07	26.21	426.57		
10/01/2015 8:47	91.15	752.93	15.07	26.31	414.70		
10/01/2015 8:48	85.42	759.02	15.07	26.89	420.14		
10/01/2015 8:49	86.05	759.02	15.21	26.90	415.46		
10/01/2015 8:50	85.21	756.18	15.48	26.23	428.46		
10/01/2015 8:51	87.09	759.02	15.48	26.43	429.26		
10/01/2015 8:52	81.29	748.87	14.93	26.40	430.11		
10/01/2015 8:53	81.52	753.33	14.93	26.38	422.11		
10/01/2015 8:54	80.64	759.22	14.93	26.36	430.80		
10/01/2015 8:55	83.19	755.57	15.21	26.72	419.39		
10/01/2015 8:56	81.21	753.33	15.21	26.43	419.98		
10/01/2015 8:57	86.00	750.69	15.21	27.53	407.01		
10/01/2015 8:58	84.87	750.29	15.07	26.09	414.13		
10/01/2015 8:59	86.69	751.91	15.07	26.57	421.98		
10/01/2015 9:00	83.23	754.55	14.93	26.30	415.69		
10/01/2015 9:01	89.03	752.72	15.07	26.05	424.24		
10/01/2015 9:02	87.59	744.40	15.07	26.14	426.72		
10/01/2015 9:03	82.42	744.00	15.07	25.73	429.12		
10/01/2015 9:04	85.94	744.60	14.65	25.41	428.31		
10/01/2015 9:05	79.45	742.37	14.79	26.12	423.92		
10/01/2015 9:06	80.82	741.97	14.65	26.64	412.24		
10/01/2015 9:07	90.56	744.00	14.51	26.22	413.48		
10/01/2015 9:08	84.54	745.21	14.93	25.78	414.36		
10/01/2015 9:09	78.51	744.81	14.93	26.63	408.07		
10/01/2015 9:10	83.72	751.91	14.79	26.31	411.37		
10/01/2015 9:11	86.91	737.70	15.07	25.75	425.77		
10/01/2015 9:12	84.34	737.50	14.65	25.94	420.84		
Total:							
Average:	84.78	749.90	15.00	26.33	420.71		
Maximum:	91.15	759.22	15.48	27.53	430.80		
Minimum:	78.51	737.50	14.51	25.41	407.01		

R.3





OCSD P2 Unit 5

Report Start Date/Time: Thu 10/01/2015 9:31

Report End Date/Time: Thu 10/01/2015 10:00

DATE/TIME	NOx Raw (ppmvd)	NOx @15%O2 (ppmvd)	NOx Lbs/Hr	O2 (%)	Stack Flow (dscfm)	CO Raw (ppmvd)	CO @15%O2 (ppmvd)	CO Lbs/Hr
	(рршча)	(рріпуа)			(daciiii)	(ррпіча)	(рршча)	
10/01/2015 9:31	41.38 V	27.06 V	2.98 V	11.88 V	10031.34 V	614.00 V	401.51 V	26.86 V
10/01/2015 9:32	40.33 V	26.59 V	2.94 V	11.95 V	10160.84 V	624.20 V	411.48 V	27.66 V
10/01/2015 9:33	39.36 V	26.01 V	2.88 V	11.97 V	10197.19 V	629.50 V	416.02 V	27.99 V
10/01/2015 9:34	39.54 V	26.21 V	2.88 V	12.00 V	10148.60 V	634.10 V	420.24 V	28.06 V
10/01/2015 9:35	39.88 V	26.28 V	2.90 V	11.95 V	10139.84 V	633.10 V	417.23 V	27.99 V
10/01/2015 9:36	38.52 V	25.45 V	2.79 V	11.97 V	10113.16 V	641.70 V	423.97 V	28.30 V
10/01/2015 9:37	38.73 V	25.52 V	2.79 V	11.95 V	10061.42 V	640.10 V	421.73 V	28.09 V
10/01/2015 9:38	38.35 V	25.23 V	2.76 V	11.93 V	10018.46 V	651.00 V	428.19 V	28.44 V
10/01/2015 9:39	39.18 V	25.69 V	2.79 V	11.90 V	9944.59 V	642.80 V	421.51 V	27.88 V
10/01/2015 9:40	38.73 V	25.20 V	2.74 V	11.83 V	9849.31 V	637.50 V	414.81 V	27.38 V
10/01/2015 9:41	39.22 V	25.72 V	2.82 V	11.90 V	10014.20 V	640.50 V	420.00 V	27.97 V
10/01/2015 9:42	38.47 V	25.49 V	2.76 V	12.00 V	10018.27 V	648.60 V	429.73 V	28.34 V
10/01/2015 9:43	38.52 V	25.19 V	2.78 V	11.88 V	10065.60 V	638.50 V	417.53 V	28.03 V
10/01/2015 9:44	38.42 V	25.39 V	2.79 V	11.97 V	10116.90 V	638.50 V	421.97 V	28.17 V
10/01/2015 9:45	39.35 V	25.80 V	2.83 V	11.90 V	10035.52 V	630.90 V	413.71 V	27.61 V
10/01/2015 9:46	39.47 V	25.88 V	2.85 V	11.90 V	10065.14 V	629.10 V	412.53 V	27.61 V
10/01/2015 9:47	37.96 V	24.96 V	2.74 V	11.93 V	10068.53 V	650.00 V	427.42 V	28.54 V
10/01/2015 9:48	39.22 V	25.72 V	2.81 V	11.90 V	9998.20 V	629.20 V	412.59 V	27.43 V
10/01/2015 9:49	38.24 V	25.35 V	2.78 V	12.00 V	10145.16 V	650.30 V	431.10 V	28.77 V
10/01/2015 9:50	38.16 V	24.95 V	2.73 V	11.88 V	9989.00 V	653.10 V	426.96 V	28.45 V
10/01/2015 9:51	38.67 V	25.16 V	2.77 V	11.83 V	9992.14 V	630.90 V	410.51 V	27.49 V
10/01/2015 9:52	38.42 V	25.20 V	2.74 V	11.91 V	9931.06 V	639.20 V	419.26 V	27.68 V
10/01/2015 9:53	39.15 V	25.48 V	2.77 V	11.84 V	9864.96 V	638.90 V	415.83 V	27.49 V
10/01/2015 9:54	38.87 V	25.29 V	2.77 V	11.83 V	9941.88 V	631.70 V	411.03 V	27.39 V
10/01/2015 9:55	36.84 V	24.42 V	2.65 V	12.00 V	10042.15 V	668.40 V	443.10 V	29.27 V
10/01/2015 9:56	38.41 V	25.19 V	2.74 V	11.91 V	9939.06 V	639.60 V	419.53 V	27.72 V
10/01/2015 9:57	38.70 V	25.46 V	2.77 V	11.93 V	9995.57 V	641.00 V	421.62 V	27.94 V
10/01/2015 9:58	38.52 V	25.20 V	2.71 V	11.88 V	9802.50 V	643.30 V	420.78 V	27.50 V
10/01/2015 9:59	38.73 V	25.21 V	2.72 V	11.84 V	9809.10 V	639.70 V	416.35 V	27.36 V
10/01/2015 10:00	39.28 V	25.57 V	2.75 V	11.84 V	9756.53 V	637.80 V	415.23 V	27.14 V
Average:	38.89	25.53	2.79	11.91	10008.54	638.91	419.45	27.88
Maximum:	41.38	27.06	2.98	12.00	10197.19	668.40	443.10	29.27
Minimum:	36.84	24.42	2.65	11.83	9756.53	614.00	401.51	26.86







Unit Name: OCSD P2 Unit 5 Report Start Date/Time: Thu 10/01/2015 9:31

Report End Date/Time: Thu 10/01/2015 10:00

DATE/TIME	ICE % Load	Digester Gas Flow (dscfm)	Natural Gas Flow (dscfm)	NOx @15%O2 (ppmvd)	CO @15%O2 (ppmvd)		
10/01/2015 9:31	83.12	742.37	14.65	27.06	401.51	1	
10/01/2015 9:32	80.01	746.03	14.65	26.59	411.48		
10/01/2015 9:33	84.37	746.84	14.65	26.01	416.02		
10/01/2015 9:34	83.20	740.34	15.07	26.21	420.24		
10/01/2015 9:35	84.28	744.20	14.93	26.28	417.23		
10/01/2015 9:36	85.90	741.15	14.37	25.45	423.97		
10/01/2015 9:37	85.65	738.92	14.65	25.52	421.73		
10/01/2015 9:38	78.99	736.48	14.93	25,23	428.19		
10/01/2015 9:39	82.59	733.64	14.65	25.69	421.51		
10/01/2015 9:40	82.16	732.22	14.65	25.20	414.81		
10/01/2015 9:41	84.13	738.72	14.79	25.72	420.00		
10/01/2015 9:42	80.87	731.41	14.65	25.49	429.73		
10/01/2015 9:43	83.38	745.21	14,51	25.19	417.53		
10/01/2015 9:44	78.43	740.54	14.79	25.39	421.97		
10/01/2015 9:45	84.10	740.34	14.79	25.80	413.71		
10/01/2015 9:46	81.50	742.37	14.93	25.88	412.53		
10/01/2015 9:47	79.27	740.95	14.65	24.96	427.42		
10/01/2015 9:48	79.67	737.50	14.79	25.72	412.59		
10/01/2015 9:49	81.90	740.54	14.65	25.35	431.10		
10/01/2015 9:50	79.59	739.12	14.79	24.95	426.96		
10/01/2015 9:51	79.05	743.18	14.65	25.16	410.51		
10/01/2015 9:52	85.16	732.63	14.51	25.20	419.26		
10/01/2015 9:53	86.53	733.44	14.51	25.48	415.83		
10/01/2015 9:54	79.99	739.33	14.65	25.29	411.03		
10/01/2015 9:55	81.10	733.24	14.37	24.42	443.10		
10/01/2015 9:56	84.36	733.24	14.51	25.19	419.53		
10/01/2015 9:57	81.96	735.88	14.23	25.46	421.62		
10/01/2015 9:58	80.70	724.91	14.51	25.20	420.78		
10/01/2015 9:59	81.72	729.38	14.37	25.21	416.35		
10/01/2015 10:00	86.06	724.91	14.51	25.57	415.23	_	
Total:							
Average:	82.32	737.63	14.64	25.53	419.45		
Maximum:	86.53	746.84	15.07	27.06	443.10		
Minimum:	78.43	724.91	14.23	24.42	401.51		



Almega ENVIRONMENTAL

Unit Name:

OCSD P2 Unit 5

Report Start Date/Time: Thu 10/01/2015 10:01

Report End Date/Time :

Thu 10/01/2015 10:30

DATE/TIME	NOx Raw (ppmvd)	NOx @15%O2 (ppmvd)	NOx Lbs/Hr	O2 (%)	Stack Flow (dscfm)	CO Raw (ppmvd)	CO @15%O2 (ppmvd)	CO Lbs/Hr
10/01/2015 10:01	38.45 V	25.03 V	2.68 V	11.84 V	9710.91 V	639.90 V	416.48 V	27.10 V
10/01/2015 10:02	38.62 V	25.14 V	2.76 V	11.84 V	9957.56 V	627.50 V	408.41 V	27.25 V
10/01/2015 10:03	39.38 V	26.03 V	2.81 V	11.97 V	9946.45 V	633.80 V	418.87 V	27.49 V
10/01/2015 10:04	39.56 V	26.06 V	2.86 V	11.95 V	10064.10 V	636.90 V	419.62 V	27.95 V
10/01/2015 10:05	38.55 V	25.35 V	2.76 V	11.93 V	9982.70 V	644.70 V	423.93 V	28.07 V
10/01/2015 10:06	39.67 V	26.21 V	2.83 V	11.97 V	9941.58 V	630.20 V	416.37 V	27.32 V
10/01/2015 10:07	38.72 V	25.52 V	2.76 V	11.95 V	9922.25 V	638.50 V	420.79 V	27.63 V
10/01/2015 10:08	39.21 V	25.91 V	2.83 V	11.97 V	10055.41 V	632.70 V	418.14 V	27.74 V
10/01/2015 10:09	39.31 V	25.90 V	2.84 V	11.95 V	10061.72 V	644.00 V	424.30 V	28.26 V
10/01/2015 10:10	42.22 V	27.47 V	3.04 V	11.83 V	10037.10 V	603.90 V	392.94 V	26.43 V
10/01/2015 10:11	41.86 V	27.74 V	3.09 V	12.00 V	10302.16 V	613.00 V	406.26 V	27.54 V
10/01/2015 10:12	41.44 V	27.51 V	3.03 V	12.01 V	10205.30 V	613.30 V	407.14 V	27.29 V
10/01/2015 10:13	40.98 V	27.15 V	2.98 V	12.00 V	10148.15 V	625.00 V	414.09 V	27.66 V
10/01/2015 10:14	40.50 V	26.83 V	2.93 V	11.99 V	10095.93 V	631.50 V	418.28 V	27.80 V
10/01/2015 10:15	40.53 V	26.86 V	2.97 V	12.00 V	10212.35 V	629.10 V	416.93 V	28.02 V
10/01/2015 10:16	41.09 V	27.44 V	3.03 V	12.07 V	10269.27 V	628.80 V	419.91 V	28.16 V
10/01/2015 10:17	40.01 V	26.64 V	2.94 V	12.04 V	10251.12 V	631.90 V	420.79 V	28.25 V
10/01/2015 10:18	40.15 V	26.61 V	2.93 V	12.00 V	10169.55 V	629.40 V	417.13 V	27.91 V
10/01/2015 10:19	39.78 V	26.42 V	2.91 V	12.02 V	10189.58 V	630.50 V	418.68 V	28.02 V
10/01/2015 10:20	40.47 V	26.67 V	2.96 V	11.95 V	10190.75 V	629.40 V	414.80 V	27.97 V
10/01/2015 10:21	40.95 V	27.34 V	3.02 V	12.06 V	10290.18 V	625.60 V	417.66 V	28.07 V
10/01/2015 10:22	41.01 V	27.44 V	3.01 V	12.08 V	10246.13 V	621.90 V	416.13 V	27.79 V
10/01/2015 10:23	40.12 V	26.79 V	2.92 V	12.07 V	10141.38 V	631.10 V	421.45 V	27.91 V
10/01/2015 10:24	40.57 V	26.89 V	2.94 V	12.00 V	10099.21 V	628.70 V	416.66 V	27.69 V
10/01/2015 10:25	39.95 V	26.48 V	2.88 V	12.00 V	10061.49 V	631.50 V	418.52 V	27.71 V
10/01/2015 10:26	40.40 V	26.62 V	2.91 V	11.95 V	10058.75 V	626.40 V	412.70 V	27.48 V
10/01/2015 10:27	40.57 V	26.94 V	2.96 V	12.02 V	10170.08 V	619.20 V	411.17 V	27.46 V
10/01/2015 10:28	40.22 V	26.71 V	2.91 V	12.02 V	10095.41 V	630.50 V	418.68 V	27.76 V
10/01/2015 10:29	40.08 V	26.56 V	2.91 V	12.00 V	10126.45 V	636.40 V	421.77 V	28.10 V
10/01/2015 10:30	39.78 V	26.49 V	2.93 V	12.04 V	10275.18 V	625.30 V	416.40 V	28.02 V
Average:	40.14	26.56	2.91	11.98	10109.27	629.02	416.17	27.73
Maximum:	42.22	27.74	3.09	12.08	10302.16	644.70	424.30	28.26
Minimum:	38.45	25.03	2.68	11.83	9710.91	603.90	392.94	26.43



Engine 5 Minute Emissions Data



10/1/2015 10:33:25 AM

Page 1 of 1

Unit Name:

OCSD P2 Unit 5

Report Start Date/Time :

Thu 10/01/2015 10:01

Report End Date/Time :

Thu 10/01/2015 10:30

DATE/TIME	ICE % Load	Digester Gas	Natural Gas	NOx @15%O2	CO @15%O2		
		Flow (dscfm)	Flow (dscfm)	(ppmvd)	(ppmvd)		
L							
10/01/2015 10:01	83.94	722.07	14.23	25.03	416.48		
10/01/2015 10:02	80.49	740.54	14.51	25.14	408.41		
10/01/2015 10:03	85.20	728.57	14.23	26.03	418.87		
10/01/2015 10:04	79.59	739.12	14.65	26.06	419.62		
10/01/2015 10:05	76.46	734.66	14.51	25.35	423.93		
10/01/2015 10:06	82.73	727.96	14.51	26.21	416.37		
10/01/2015 10:07	78.33	728.16	14.65	25.52	420.79		
10/01/2015 10:08	82.51	735.67	14.93	25.91	418.14		
10/01/2015 10:09	84.18	738.72	14.79	25.90	424.30		
10/01/2015 10:10	85.90	746.63	14.65	27.47	392.94		
10/01/2015 10:11	89.07	751.91	15.07	27.74	406.26		
10/01/2015 10:12	86.41	744.00	14.65	27.51	407.14		
10/01/2015 10:13	84.51	740.75	14.93	27.15	414.09		
10/01/2015 10:14	81.86	737.70	14.51	26.83	418.28		
10/01/2015 10:15	85.32	745.82	14.65	26.86	416.93		
10/01/2015 10:16	84.44	743.79	14.93	27.44	419.91		
10/01/2015 10:17	81.66	744.60	14.93	26.64	420.79		
10/01/2015 10:18	81.21	742.37	14.79	26.61	417.13		
10/01/2015 10:19	91.40	742.37	14.79	26.42	418.68		
10/01/2015 10:20	86.76	748.06	14.93	26.67	414.80		
10/01/2015 10:21	83.63	746.03	14.65	27.34	417.66		
10/01/2015 10:22	84.34	740.54	14.93	27.44	416.13		
10/01/2015 10:23	80.82	734.45	14.79	26.79	421.45		
10/01/2015 10:24	84.94	737.30	14.65	26.89	416.66		
10/01/2015 10:25	84.70	734.45	14.65	26.48	418.52		
10/01/2015 10:26	86.36	738.72	14.65	26.62	412.70		
10/01/2015 10:27	83.12	741.36	14.51	26.94	411.17		
10/01/2015 10:28	82.19	735.06	14.93	26.71	418.68		
10/01/2015 10:29	89.25	739.12	14.79	26.56	421.77		
10/01/2015 10:30	84.51	746.63	14.79	26.49	416.40		
Total:							
Average:	83.86	739.24	14.70	26.56	416.17		
Maximum:	91.40	751.91	15.07	27.74	424.30		
Minimum:	76.46	722.07	14.23	25.03	392.94		



Page 1 of 1

Unit Name: OCSD P2 Unit 5

Report Start Date/Time: Thu 10/01/2015 10:31

Report End Date/Time: Thu 10/01/2015 11:00

DATE/TIME	NOx Raw (ppmvd)	NOx @15%O2 (ppmvd)	NOx Lbs/Hr	O2 (%)	Stack Flow (dscfm)	CO Raw (ppmvd)	CO @15%O2 (ppmvd)	CO Lbs/Hr
10/01/2015 10:31	40.43 V	26.65 V	2.96 V	11.95 V	10219.61 V	625.60 V	412.29 V	27.88 V
10/01/2015 10:32	41.72 V	27.56 V	3.07 V	11.97 V	10251.94 V	612.60 V	404.74 V	27.39 V
10/01/2015 10:33	40.19 V	26.77 V	3.00 V	12.04 V	10405.65 V	629.10 V	419.05 V	28.55 V
10/01/2015 10:34	40.39 V	26.61 V	2.97 V	11.95 V	10260.21 V	622.20 V	409.94 V	27.84 V
10/01/2015 10:35	40.46 V	26.74 V	2.98 V	11.97 V	10284.36 V	625.90 V	413.64 V	28.07 V
10/01/2015 10:36	39.92 V	26.38 V	2.95 V	11.97 V	10292.12 V	627.70 V	414.83 V	28.17 V
10/01/2015 10:37	39.60 V	26.45 V	2.95 V	12.07 V	10383,59 V	635.30 V	424.25 V	28.77 V
10/01/2015 10:38	39.85 V	26.41 V	2.97 V	12.00 V	10380.59 V	627.10 V	415.60 V	28.39 V
10/01/2015 10:39	40.19 V	26.70 V	2.98 V	12.02 V	10347.86 V	630.20 V	418.60 V	28.44 V
10/01/2015 10:40	38.94 V	25.86 V	2.88 V	12.02 V	10311.66 V	648.50 V	430.63 V	29.16 V
10/01/2015 10:41	39.85 V	26.46 V	2.97 V	12.02 V	10376.14 V	626.50 V	416.02 V	28.35 V
10/01/2015 10:42	40.12 V	26.80 V	3.02 V	12.07 V	10500.57 V	635.00 V	424.17 V	29.08 V
10/01/2015 10:43	39.99 V	26.77 V	2.99 V	12.09 V	10442.52 V	636.50 V	426.02 V	28.99 V
10/01/2015 10:44	38.51 V	25.45 V	2.88 V	11.97 V	10410.62 V	648.40 V	428.51 V	29.44 V
10/01/2015 10:45	39.28 V	26.28 V	2.98 V	12.08 V	10575.55 V	633,50 V	423.89 V	29.22 V
10/01/2015 10:46	39.75 V	26.48 V	2.96 V	12.04 V	10370.45 V	639.50 V	425.97 V	28.92 V
10/01/2015 10:47	38.69 V	25.88 V	2.89 V	12.08 V	10425.41 V	646.00 V	432.13 V	29.37 V
10/01/2015 10:48	38.80 V	25.65 V	2.85 V	11.98 V	10249.32 V	645.40 V	426.65 V	28.85 V
10/01/2015 10:49	39.91 V	26.30 V	2.95 V	11.95 V	10319.43 V	636.10 V	419.09 V	28.63 V
10/01/2015 10:50	39.47 V	26,21 V	2.92 V	12.02 V	10333.55 V	640.10 V	425.05 V	28.85 V
10/01/2015 10:51	39.28 V	25.96 V	2.88 V	11.97 V	10230.03 V	644.30 V	425.81 V	28.74 V
10/01/2015 10:52	39.15 V	25.87 V	2.88 V	11.97 V	10241.07 V	638.80 V	422.17 V	28.53 V
10/01/2015 10:53	39.99 V	26.30 V	2.94 V	11.93 V	10243.06 V	633.30 V	416.55 V	28.29 V
10/01/2015 10:54	40.46 V	26.61 V	2.95 V	11.93 V	10176.21 V	628.20 V	413.20 V	27.88 V
10/01/2015 10:55	39.57 V	26.09 V	2.89 V	11.95 V	10180.19 V	632.80 V	417.15 V	28.09 V
10/01/2015 10:56	39.74 V	26.26 V	2.88 V	11.97 V	10100.33 V	633.10 V	418.29 V	27.89 V
10/01/2015 10:57	39.99 V	26.30 V	2.88 V	11.93 V	10049.82 V	631.00 V	414.92 V	27.65 V
10/01/2015 10:58	39.57 V	26.15 V	2.87 V	11.97 V	10119.28 V	633.70 V	418.80 V	27.96 V
10/01/2015 10:59	39.12 V	25.72 V	2.82 V	11.93 V	10036.16 V	633.70 V	416.70 V	27.73 V
10/01/2015 11:00	38.94 V	25.53 V	2.80 V	11.90 V	10027.82 V	647.80 V	424.79 V	28.33 V
Average:	39.73	26.31	2.93	11.99	10284.84	634.26	419.98	28.45
Maximum:	41.72	27.56	3.07	12.09	10575.55	648.50	432.13	29.44
Minimum:	38.51	25.45	2.80	11.90	10027.82	612.60	404.74	27.39



Engine 5 Minute Emissions Data



10/1/2015 11:06:32 AM

OCSD P2 Unit 5

Unit Name:

Report Start Date/Time: Thu 10/01/2015 10:31

Report End Date/Time: Thu 10/01/2015 11:00

DATE/TIME	ICE % Load	Digester Gas	Natural Gas	NOx @15%O2	CO @15%O2		
		Flow (dscfm)	Flow (dscfm)	(ppmvd)	(ppmvd)	i	ļ
10/01/2015 10:31	85.53	750.69	14.65	26.65	412.29		
10/01/2015 10:32	88.10	750.29	15.21	27.56	404.74		
10/01/2015 10:33	81.87	755.97	14.93	26.77	419.05		
10/01/2015 10:34	83.27	753.54	14.93	26.61	409.94		
10/01/2015 10:35	81.57	752.52	15.21	26.74	413.64		
10/01/2015 10:36	84.33	753.33	15.07	26.38	414.83		
10/01/2015 10:37	87.59	752.12	15.07	26.45	424.25		
10/01/2015 10:38	88.97	757.60	15.21	26.41	415.60		
10/01/2015 10:39	87.88	752.93	15.48	26.70	418.60		
10/01/2015 10:40	88.42	751.10	15.07	25.86	430.63		
10/01/2015 10:41	88.63	756.18	14.93	26.46	416.02		
10/01/2015 10:42	82.25	760.64	15.07	26.80	424.17		
10/01/2015 10:43	81.28	754.75	15.07	26.77	426.02		
10/01/2015 10:44	84.52	762.06	15.21	25.45	428.51		
10/01/2015 10:45	82.20	764.90	15.07	26.28	423.89		
10/01/2015 10:46	78.90	753.33	14.93	26.48	425.97		
10/01/2015 10:47	78.97	754.15	14.93	25.88	432.13		
10/01/2015 10:48	88.78	749.88	15.07	25.65	426.65		
10/01/2015 10:49	88.97	757.80	15.07	26.30	419.09		
10/01/2015 10:50	86.32	752.52	15.21	26.21	425.05		
10/01/2015 10:51	84.38	748.87	14.93	25.96	425.81		
10/01/2015 10:52	88.53	749.48	15.07	25.87	422.17		
10/01/2015 10:53	83.71	753.54	14.93	26.30	416.55		
10/01/2015 10:54	85.66	748.46	14.93	26.61	413.20		
10/01/2015 10:55	84.81	747.04	14.93	26.09	417.15		
10/01/2015 10:56	85.65	739.73	14.65	26.26	418.29		
10/01/2015 10:57	87.67	739.53	14.65	26.30	414.92		
10/01/2015 10:58	82.78	740.95	14.65	26.15	418.80		
10/01/2015 10:59	84.29	738.72	14.51	25.72	416.70		
10/01/2015 11:00	82.90	739.53	14.93	25.53	424.79		
Total:				-,,,,,			
Average:	84.96	751.40	14.98	26.31	419.98		
Maximum:	88.97	764.90	15.48	27.56	432.13		
Minimum:	78.90	738.72	14.51	25.45	404.74		

Page 1 of 1

Almega =

Unit Name:

OCSD P2 Unit 5

Report Start Date/Time: Thu 10/01/2015 11:16

Report End Date/Time: Thu 10/01/2015 11:45

DATE/TIME	NOx Raw (ppmvd)	NOx @15%O2 (ppmvd)	NOx Lbs/Hr	O2 (%)	Stack Flow (dscfm)	CO Raw (ppmvd)	CO @15%O2 (ppmvd)	CO Lbs/Hr
10/01/2015 11:16	38.48 V	25.11 V	2.69 V	11.86 V	9756.93 V	640.80 V	418.22 V	27.27 V
10/01/2015 11:17	38.59 V	25.04 V	2.74 V	11.81 V	9903.70 V	637.90 V	413.93 V	27.55 V
10/01/2015 11:18	40.12 V	26.11 V	2.82 V	11.84 V	9811.45 V	621.00 V	404.18 V	26.57 V
10/01/2015 11:19	38.91 V	25.25 V	2.72 V	11.81 V	9734.89 V	637.70 V	413.80 V	27.07 V
10/01/2015 11:20	39.32 V	25.52 V	2.75 V	11.81 V	9737.56 V	631.00 V	409.56 V	26.80 V
10/01/2015 11:21	40.05 V	25.87 V	2.80 V	11.77 V	9759.90 V	618.50 V	399.47 V	26.32 V
10/01/2015 11:22	39.68 V	25.75 V	2.79 V	11.81 V	9800.83 V	626.40 V	406.46 V	26.77 V
10/01/2015 11:23	40.39 V	26.08 V	2.83 V	11.76 V	9770.94 V	616.40 V	398.00 V	26.26 V
10/01/2015 11:24	40.51 V	26.10 V	2.86 V	11.74 V	9833.11 V	613.70 V	395.40 V	26.32 V
10/01/2015 11:25	40.75 V	26.45 V	2.90 V	11.81 V	9908.47 V	612.70 V	397.68 V	26.47 V
10/01/2015 11:26	40.26 V	26.20 V	2.85 V	11.84 V	9867.60 V	622.30 V	405.03 V	26.78 V
10/01/2015 11:27	39.35 V	25.53 V	2.78 V	11.81 V	9868.82 V	629.90 V	408.73 V	27.11 V
10/01/2015 11:28	39.85 V	25.81 V	2.82 V	11.79 V	9861.87 V	623.60 V	403.87 V	26.82 V
10/01/2015 11:29	39.67 V	25.81 V	2.82 V	11.83 V	9920.63 V	632.40 V	411.37 V	27.36 V
10/01/2015 11:30	40.09 V	25.89 V	2.85 V	11.76 V	9912.96 V	625.10 V	403.62 V	27.02 V
10/01/2015 11:31	39.44 V	25.66 V	2.79 V	11.83 V	9864.88 V	631.90 V	411.16 V	27.18 V
10/01/2015 11:32	39.54 V	25.54 V	2.81 V	11.77 V	9903.14 V	627.20 V	405.09 V	27.09 V
10/01/2015 11:33	40.47 V	26.54 V	2.93 V	11.90 V	10096.53 V	626.10 V	410.56 V	27.57 V
10/01/2015 11:34	39.84 V	25.93 V	2.85 V	11.84 V	9968.44 V	620.80 V	404.05 V	26.99 V
10/01/2015 11:35	38.94 V	25.34 V	2.76 V	11.83 V	9888.98 V	648.20 V	421.77 V	27.95 V
10/01/2015 11:36	39.61 V	25.66 V	2.81 V	11.79 V	9888.27 V	625.70 V	405.34 V	26.98 V
10/01/2015 11:37	38.97 V	25.28 V	2.77 V	11.81 V	9906.84 V	642.40 V	416.73 V	27.75 V
10/01/2015 11:38	39.21 V	25.51 V	2.80 V	11.83 V	9955.11 V	635.50 V	413.50 V	27.59 V
10/01/2015 11:39	38.94 V	25.46 V	2.79 V	11.88 V	9992.06 V	634.50 V	414.91 V	27.65 V
10/01/2015 11:40	39.50 V	25.70 V	2.84 V	11.83 V	10023.58 V	636.20 V	413.96 V	27.81 V
10/01/2015 11:41	39.77 V	26.00 V	2.85 V	11.88 V	9986.04 V	626.40 V	409.50 V	27.28 V
10/01/2015 11:42	39.39 V	25.64 V	2.82 V	11.84 V	9976.67 V	624.00 V	406.13 V	27.15 V
10/01/2015 11:43	39.84 V	26.05 V	2.86 V	11.88 V	10018.64 V	632.40 V	413.54 V	27.63 V
10/01/2015 11:44	39.25 V	25.67 V	2.82 V	11.88 V	10008.01 V	638.50 V	417.53 V	27.87 V
10/01/2015 11:45	39.57 V	25.88 V	2.85 V	11.88 V	10050.54 V	633.10 V	414.00 V	27.75 V
Average:	39.61	25.75	2.81	11.82	9899.25	629.08	408.90	27.16
Maximum:	40.75	26.54	2.93	11.90	10096.53	648.20	421.77	27.95
Minimum:	38.48	25.04	2.69	11.74	9734.89	612.70	395.40	26.26

Engine 5 Minute Emissions Data



10/1/2015 11:53:43 AM

Page 1 of 1

Unit Name:

OCSD P2 Unit 5

Report Start Date/Time :

Thu 10/01/2015 11:16

Report End Date/Time :

Thu 10/01/2015 11:45

DATE/TIME	ICE % Load	Digester Gas	Natural Gas	NOx @15%O2	CO @15%O2		
		Flow (dscfm)	Flow (dscfm)	(ppmvd)	(ppmvd)		
10/01/2015 11:16	81.62	723.09	14.51	25.11	418.22		
10/01/2015 11:17	85.28	738.72	14.51	25.04	413.93		
10/01/2015 11:18	82.01	729.79	14.23	26.11	404.18		
10/01/2015 11:19	82.16	725.73	14.51	25.25	413.80		
10/01/2015 11:20	84.54	725.73	14.51	25.52	409.56		
10/01/2015 11:21	84.74	731.61	14.23	25.87	399.47		
10/01/2015 11:22	83.11	730.80	14.51	25.75	406.46		
10/01/2015 11:23	83.62	732.22	14.51	26.08	398.00		
10/01/2015 11:24	84.21	738.92	14.37	26.10	395.40		
10/01/2015 11:25	85.64	739.33	14.23	26.45	397.68		
10/01/2015 11:26	85.35	733.64	14.51	26.20	405.03		
10/01/2015 11:27	81.41	736.48	14.23	25.53	408.73		
10/01/2015 11:28	81.36	736.28	14.93	25.81	403.87		
10/01/2015 11:29	90.22	737.91	14.65	25.81	411.37		
10/01/2015 11:30	82.58	742.98	14.65	25.89	403.62		
10/01/2015 11:31	83.42	733.64	14.51	25.66	411.16		
10/01/2015 11:32	87.13	741.56	14.93	25.54	405.09		
10/01/2015 11:33	80.53	745.21	14.65	26.54	410.56		
10/01/2015 11:34	82.56	741.15	14.65	25.93	404.05		
10/01/2015 11:35	82.86	735.27	14.65	25.34	421.77		
10/01/2015 11:36	86.63	738.11	14.93	25.66	405.34		
10/01/2015 11:37	86.01	738.72	14.79	25.28	416.73		
10/01/2015 11:38	82.18	740.34	14.65	25.51	413.50		
10/01/2015 11:39	84.89	738.92	14.93	25.46	414.91		
10/01/2015 11:40	85.39	745.82	14.51	25.70	413.96		
10/01/2015 11:41	87.89	739.12	14.65	26.00	409.50		
10/01/2015 11:42	84.81	741.56	14.79	25.64	406.13		
10/01/2015 11:43	79.85	740.95	14.93	26.05	413.54		
10/01/2015 11:44	86.94	740.14	14.93	25.67	417.53		
10/01/2015 11:45	89.94	743.39	14.93	25.88	414.00		
Total:							
Average:	84.30	736.90	14.62	25.75	408.90		
Maximum:	90.22	745.82	14.93	26.54	421.77		
Minimum:	79.85	723.09	14.23	25.04	395.40		



Unit Name: OCSD P2 Unit 5 Report Start Date/Time: Thu 10/01/2015 11:46

Report End Date/Time: Thu 10/01/2015 12:15

DATE/TIME	NOx Raw (ppmvd)	NOx @15%O2 (ppmvd)	NOx Lbs/Hr	O2 (%)	Stack Flow (dscfm)	CO Raw (ppmvd)	CO @15%O2 (ppmvd)	CO Lbs/Hr
10/01/2015 11:46	38.79 V	25.56 V	2.82 V	11.95 V	10120.94 V	638.90 V	420.94 V	28.20 V
10/01/2015 11:47	39.50 V	26.38 V	2.89 V	12.07 V	10214.37 V	635.70 V	424.52 V	28.32 V
10/01/2015 11:48	39.60 V	26.24 V	2.84 V	12.00 V	9996.72 V	632.60 V	419.13 V	27.58 V
10/01/2015 11:49	38.86 V	25.55 V	2.82 V	11.93 V	10114.57 V	639.20 V	420.32 V	28.19 V
10/01/2015 11:50	40.11 V	26.64 V	2.94 V	12.02 V	10227.07 V	625.30 V	415.23 V	27.89 V
10/01/2015 11:51	39.38 V	26.10 V	2.87 V	12.00 V	10166.86 V	639.80 V	424.02 V	28.37 V
10/01/2015 11:52	39.70 V	26.30 V	2.88 V	12.00 V	10104.45 V	626.40 V	415.02 V	27.60 V
10/01/2015 11:53	40.11 V	26.71 V	2.86 V	12.04 V	9954.55 V	629.90 V	419.46 V	27.34 V
10/01/2015 11:54	39.74 V	26.33 V	2.85 V	12.00 V	10015.27 V	635.70 V	421.18 V	27.76 V
10/01/2015 11:55	40.67 V	26.80 V	2.86 V	11.95 V	9817.40 V	614.70 V	405.00 V	26.32 V
10/01/2015 11:56	39.31 V	26.05 V	2.78 V	12.00 V	9875.22 V	631.90 V	418.67 V	27.21 V
10/01/2015 11:57	39.81 V	26.31 V	2.88 V	11.97 V	10094.20 V	633.70 V	418.80 V	27.90 V
10/01/2015 11:58	39.67 V	26.42 V	2.89 V	12.04 V	10145.55 V	626.70 V	417.33 V	27.73 V
10/01/2015 11:59	39.21 V	26.24 V	2.84 V	12.08 V	10090.48 V	633.80 V	424.09 V	27.89 V
10/01/2015 12:00	38.86 V	25.96 V	2.82 V	12.07 V	10133.08 V	639.10 V	426.91 V	28.24 V
10/01/2015 12:01	38.62 V	25.78 V	2.81 V	12.06 V	10162.63 V	647.10 V	432.01 V	28.68 V
10/01/2015 12:02	38.86 V	25.95 V	2.83 V	12.07 V	10163.10 V	631.20 V	421.51 V	27.97 V
10/01/2015 12:03	38.93 V	25.73 V	2.83 V	11.97 V	10141.07 V	636.40 V	420.58 V	28.14 V
10/01/2015 12:04	39.60 V	26.09 V	2.87 V	11.95 V	10104.88 V	629.50 V	414.75 V	27.74 V
10/01/2015 12:05	38.90 V	25.90 V	2.82 V	12.04 V	10105.55 V	638.40 V	425.12 V	28.13 V
10/01/2015 12:06	39.17 V	25.89 V	2.87 V	11.97 V	10200.78 V	635.70 V	420.12 V	28.28 V
10/01/2015 12:07	39.35 V	25.93 V	2.88 V	11.95 V	10199.08 V	633.70 V	417.63 V	28.19 V
10/01/2015 12:08	40.61 V	26.83 V	2.99 V	11.97 V	10251.64 V	611.40 V	403.95 V	27.33 V
10/01/2015 12:09	38.69 V	25.77 V	2.84 V	12.04 V	10235.66 V	643.90 V	428.90 V	28.74 V
10/01/2015 12:10	39.25 V	26.01 V	2.84 V	12.00 V	10100.41 V	641.60 V	425.21 V	28.26 V
10/01/2015 12:11	39.25 V	26.01 V	2.84 V	12.00 V	10102.81 V	633.10 V	419.58 V	27.89 V
10/01/2015 12:12	39.89 V	26.29 V	2.88 V		10078.23 V	628.20 V	414.01 V	27.61 V
10/01/2015 12:13	39.61 V	26.30 V	2.88 V		10150.00 V	631.30 V	419.21 V	27.94 V
10/01/2015 12:14	39.67 V	26.14 V	2.86 V		10058.76 V	629.50 V	414.75 V	27.61 V
10/01/2015 12:15	40.08 V	26.35 V	2.89 V	11.93 V	10059.80 V	620.90 V	408.17 V	27.24 V
Average:	39.46	26.15	2.86	12.00	10106.17	632.51	419.20	27.88
Maximum:	40.67	26.83	2.99	12.08	10251.64	647.10	432.01	28.74
Minimum:	38.62	25.55	2.78	11.93	9817.40	611.40	403.95	26.32



Engine 5 Minute Emissions Data





Unit Name:

OCSD P2 Unit 5

Report Start Date/Time :

Thu 10/01/2015 11:46

Report End Date/Time :

Thu 10/01/2015 12:15

DATE/TIME	ICE % Load	Digester Gas Flow (dscfm)	Natural Gas Flow (dscfm)	NOx @15%O2 (ppmvd)	CO @15%O2 (ppmvd)		
10/01/2015 11:46	87.00	742.98	14.93	25.56	420.94		
10/01/2015 11:47	81.86	742.96	14.65	25.56 26.38	424.52		
10/01/2015 11:48	87.70	729.79	14.65	26.24	419.13		
10/01/2015 11:49	81.00	744.00	14.93	25.55	420.32		
10/01/2015 11:50	83.00	745.42	14.65	26.64	415.23		
10/01/2015 11:51	85.86	743.42	14.79	26.10	424.02		
			14.79				
10/01/2015 11:52	80.10	737.91		26.30	415.02		
10/01/2015 11:53	80.86	723.49	14.23	26.71	419.46		
10/01/2015 11:54	81.04	731.41	14.51	26.33	421.18		
10/01/2015 11:55	82.65	720.65	14.51	26.80	405.00		
10/01/2015 11:56	80.72	720.85	14.51	26.05	418.67		
10/01/2015 11:57	82.09	739.73	14.23	26.31	418.80		
10/01/2015 11:58	85.57	736.69	14.93	26.42	417.33		
10/01/2015 11:59	85.49	729.38	14.65	26.24	424.09		
10/01/2015 12:00	81.32	733.85	14.65	25.96	426.91		
10/01/2015 12:01	87.14	736.48	14.65	25.78	432.01		
10/01/2015 12:02	83.75	736.08	14.79	25.95	421.51		
10/01/2015 12:03	81.84	742.37	14.79	25.73	420.58		
10/01/2015 12:04	76.14	741.76	14.93	26.09	414.75		
10/01/2015 12:05	85.26	733.24	15.21	25.90	425.12		
10/01/2015 12:06	80.99	746.43	15.07	25.89	420.12		
10/01/2015 12:07	86.42	748.46	15.07	25.93	417.63		
10/01/2015 12:08	83.70	750.49	15.07	26.83	403.95		
10/01/2015 12:09	83.07	742.78	15.21	25.77	428.90		
10/01/2015 12:10	87.69	736.48	15.21	26.01	425.21		
10/01/2015 12:11	86.14	736.89	15.07	26.01	419.58		
10/01/2015 12:12	88.68	739.53	14.93	26.29	414.01		
10/01/2015 12:13	84.49	738.72	15.21	26.30	419.21		
10/01/2015 12:14	84.18	736.69	15.90	26.14	414.75		
10/01/2015 12:15	79.23	738.92	15.62	26.35	408.17		
Total:							
Average:	83.50	737.46	14.87	26.15	419.20		
Maximum:	88.68	750.49	15.90	26.83	432.01		
Minimum:	76.14	720.65	14.23	25.55	403.95		

Page 1 of 1

Unit Name:

OCSD P2 Unit 5

Report Start Date/Time: Thu 10/01/2015 12:16

Report End Date/Time: Thu 10/01/2015 12:45

DATE/TIME	NOx Raw	NOx @15%O2	NOx Lbs/Hr	O2 (%)	Stack Flow	CO Raw	CO @15%O2	CO Lbs/Hr
	(ppmvd)	(ppmvd)			(dscfm)	(ppmvd)	(ppmvd)	
10/01/2015 12:16	40.06 V	26.40 V	2.92 V	11.95 V	10159.54 V	624.80 V	411.76 V	27.68 V
10/01/2015 12:17	39.75 V	26.67 V	2.93 V	12.11 V	10268.04 V	625.40 V	419.66 V	28.00 V
10/01/2015 12:18	39.71 V	26.16 V	2.89 V	11.95 V	10134.67 V	642.60 V	423.38 V	28.40 V
10/01/2015 12:19	39.35 V	26.28 V	2.89 V	12.07 V	10237.94 V	632.70 V	422.52 V	28.25 V
10/01/2015 12:20	39.46 V	26.00 V	2.84 V	11.95 V	10021.28 V	633.10 V	417.12 V	27.67 V
10/01/2015 12:21	39.39 V	25.83 V	2.83 V	11.90 V	10009.18 V	634.60 V	416.13 V	27.70 V
10/01/2015 12:22	39.99 V	26.43 V	2.88 V	11.97 V	10045.88 V	626.80 V	414.24 V	27.46 V
10/01/2015 12:23	38.80 V	25.65 V	2.81 V	11.98 V	10085.71 V	636.90 V	421.03 V	28.01 V
10/01/2015 12:24	37.99 V	25.11 V	2.75 V	11.97 V	10079.00 V	646.40 V	427.19 V	28.41 V
10/01/2015 12:25	39.61 V	26.17 V	2.86 V	11.97 V	10084.84 V	628.80 V	415.45 V	27.65 V
10/01/2015 12:26	39.32 V	25.86 V	2.80 V	11.93 V	9940.54 V	640.20 V	420.97 V	27.75 V
10/01/2015 12:27	40.68 V	26.55 V	2.88 V	11.86 V	9882.23 V	608.90 V	397.40 V	26.24 V
10/01/2015 12:28	40.12 V	26.03 V	2.80 V	11.81 V	9743.40 V	615.00 V	399.07 V	26.13 V
10/01/2015 12:29	40.65 V	26.38 V	2.89 V	11.81 V	9907.52 V	616.50 V	400.04 V	26.64 V
10/01/2015 12:30	40.12 V	26.19 V	2.87 V	11.86 V	9967.52 V	613.00 V	400.19 V	26.65 V
10/01/2015 12:31	40.15 V	26.21 V	2.86 V	11.86 V	9926.82 V	619.00 V	404.11 V	26.80 V
10/01/2015 12:32	40.65 V	26.66 V	2.92 V	11.90 V	10026.33 V	614.40 V	402.89 V	26.86 V
10/01/2015 12:33	39.35 V	25.80 V	2.79 V	11.90 V	9888.62 V	632.00 V	414.43 V	27.25 V
10/01/2015 12:34	39.28 V	25.56 V	2.80 V	11.83 V	9936.59 V	636.80 V	414.35 V	27.59 V
10/01/2015 12:35	39.38 V	25.82 V	2.85 V	11.90 V	10074.31 V	623.90 V	409.12 V	27.41 V
10/01/2015 12:36	40.81 V	26.69 V	2.88 V	11.88 V	9844.97 V	620,50 V	405.76 V	26.64 V
10/01/2015 12:37	41.02 V	26.49 V	2.90 V	11.77 V	9852.67 V	615.00 V	397.21 V	26.42 V
10/01/2015 12:38	40.54 V	26.39 V	2.89 V	11.84 V	9946.38 V	612.60 V	398.71 V	26.57 V
10/01/2015 12:39	41.20 V	26.82 V	2.96 V	11.84 V	10026.64 V	611.70 V	398.13 V	26.75 V
10/01/2015 12:40	40.65 V	26.34 V	2.86 V	11.80 V	9827.18 V	616.80 V	399.68 V	26.43 V
10/01/2015 12:41	39.75 V	25.74 V	2.83 V	11.79 V	9919.78 V	623.10 V	403.54 V	26.95 V
10/01/2015 12:42	41.10 V	26.75 V	2.94 V	11.84 V	9963.14 V	606.60 V	394.81 V	26.36 V
10/01/2015 12:43	40.58 V	26.41 V	2.90 V	11.84 V	9955.80 V	612.00 V	398.32 V	26.57 V
10/01/2015 12:44	40.30 V	26.35 V	2.86 V	11.88 V	9893.11 V	628.80 V	411.19 V	27.13 V
10/01/2015 12:45	40.68 V	26.48 V	2.88 V	11.84 V	9889.06 V	615.80 V	400.80 V	26.56 V
Average:	40.01	26.21	2.86	11.89	9984.62	623.82	408.64	27.16
Maximum:	41.20	26.82	2.96	12.11	10268.04	646.40	427.19	28.41
Minimum:	37.99	25.11	2.75	11.77	9743.40	606.60	394.81	26.13



Engine 5 Minute Emissions Data



10/1/2015 12:45:50 PM

Page 1 of 1

Unit Name:

OCSD P2 Unit 5

Report Start Date/Time:

Thu 10/01/2015 12:16

Report End Date/Time:

Thu 10/01/2015 12:45

DATE/TIME	ICE % Load	Digester Gas Flow (dscfm)	Natural Gas Flow (dscfm)	NOx @15%O2 (ppmvd)	CO @15%O2 (ppmvd)		
		Flow (uscilli)	riow (dsciiii)	(рршчи)	(ppinva)		
10/01/2015 12:16	88.29	738.92	19.11	26.40	411.76		
10/01/2015 12:17	83.69	733.24	19.11	26.67	419.66		
10/01/2015 12:18	83.60	739.73	17.58	26.16	423.38		
10/01/2015 12:19	80.86	736.48	18.00	26.28	422.52		
10/01/2015 12:20	85.71	731.82	17.16	26.00	417.12		
10/01/2015 12:21	86.35	736.08	16.18	25.83	416.13		
10/01/2015 12:22	80.96	732.02	16.74	26.43	414.24		
10/01/2015 12:23	81.91	735.27	16.46	25.65	421.03		
10/01/2015 12:24	81.58	735.88	15.90	25.11	427.19		
10/01/2015 12:25	82.82	736.08	16.18	26.17	415.45		
10/01/2015 12:26	90.26	728.97	16.04	25.86	420.97		
10/01/2015 12:27	85.87	730.19	16.04	26.55	397.40		
10/01/2015 12:28	83.44	723.90	16.04	26.03	399.07		
10/01/2015 12:29	84.07	738.11	15.07	26.38	400.04		
10/01/2015 12:30	84.47	738.31	14.93	26.19	400.19		
10/01/2015 12:31	80.30	735.88	14.51	26.21	404.11		
10/01/2015 12:32	80.93	740.54	14.23	26.66	402.89		
10/01/2015 12:33	86.27	729.38	14.65	25.80	414.43		
10/01/2015 12:34	82.21	738.92	14.65	25.56	414.35		
10/01/2015 12:35	79.89	744.20	14.23	25.82	409.12		
10/01/2015 12:36	81.87	728.36	14.51	26.69	405.76		
10/01/2015 12:37	80.83	738.11	14.65	26.49	397.21		
10/01/2015 12:38	85.18	740.14	14.23	26.39	398.71		
10/01/2015 12:39	80.45	745.62	14.65	26.82	398.13		
10/01/2015 12:40	81.18	733.64	14.65	26.34	399.68		
10/01/2015 12:41	84.85	740.75	14.93	25.74	403.54		
10/01/2015 12:42	79.57	740.75	14.65	26.75	394.81		
10/01/2015 12:43	77.68	739.73	14.93	26.41	398.32		
10/01/2015 12:44	84.18	731.82	14.65	26.35	411.19		
10/01/2015 12:45	85.82	735.06	14.65	26.48	400.80		
Total:							
Average:	83.17	735.93	15.64	26.21	408.64		
Maximum:	90.26	745.62	19.11	26.82	427.19		
Minimum:	77.68	723.90	14.23	25.11	394.81		




APPENDIX G

SCAQMD CHECKLIST FOR SOURCE TEST REPORTS



ENGINEERING FORM CHECK LIST FOR SOURCE TEST REPORTS

Please check off <u>all</u> the following items to verify that the information is provided in the source test report, and then send the checklist along with the source test report.



Title Page

Facility ID: Revision #: 029110

Date: February 05, 2015

FACILITY PERMIT TO OPERATE

ORANGE COUNTY SANITATION DISTRICT 22212 BROOKHURST ST HUNTINGTON BEACH, CA 92646

NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Barry R. Wallerstein, D. Env.

EXECUTIVE OFFICER

Mohsen Nazemi, P.E.

Deputy Executive Officer

Engineering & Compliance

Table of Content

Facility ID: Revision #: 029110 11

Date: February 05, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	2	04/16/2014
В	RECLAIM Annual Emission Allocation	1	04/16/2014
С	Facility Plot Plan	TO BE DEVEL	OPED
D	Facility Description and Equipment Specific Conditions	7	02/05/2015
E	Administrative Conditions	1	04/16/2014
F	RECLAIM Monitoring and Source Testing Requirements	1	04/16/2014
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	1	04/16/2014
Н	Permit To Construct and Temporary Permit to Operate	9	02/05/2015
I	Compliance Plans & Schedules	1	04/16/2014
J	Air Toxics	1	04/16/2014
K	Title V Administration	1	04/16/2014
Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	1	04/16/2014
В	Rule Emission Limits	1	04/16/2014



Section A
Facility ID:
Revision #:

Page: 1 029110 2

te: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION A: FACILITY INFORMATION

LEGAL OWNER &/OR OPERATOR:

ORANGE COUNTY SANITATION DISTRICT

LEGAL OPERATOR (if different than owner):

EQUIPMENT LOCATION:

22212 BROOKHURST ST

HUNTINGTON BEACH, CA 92646-8457

MAILING ADDRESS:

P O BOX 8127

FOUNTAIN VALLEY, CA 92728-8127

RESPONSIBLE OFFICIAL:

JAMES HERBERG

TITLE:

GENERAL MANAGER

TELEPHONE NUMBER:

(714) 593-7300

CONTACT PERSON:

LISA ROTHBART

TITLE:

ENVIRONMENTAL SUPERVISOR

TELEPHONE NUMBER:

(714) 593-7405

TITLE V PERMIT ISSUED:

April 16, 2014

TITLE V PERMIT EXPIRATION DATE:

April 15, 2019

TITLE V	RECLAIM	
YES	NOx:	NO
	SOx:	NO
	CYCLE:	0
	ZONE:	COASTAL



Section B Facility ID: Revision #: Page: 1 029110

Date:

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

NOT APPLICABLE



Section C Facility ID; Revision #; Date; Page: 1 029110

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION C: FACILITY PLOT PLAN

(TO BE DEVELOPED)



Section D Page 1 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

Facility Equipment and Requirements (Section D)

This section consists of a table listing all permitted equipment at the facility, facility wide requirements, copies of all individual Permits to Construct and Permits to Operate issued to various equipment at the facility, and Rule 219-exempt equipment subject to source-specific requirements. Each permit and Rule 219-exempt equipment will list operating conditions including periodic monitoring requirements, and applicable emission limits and requirements that the equipment is subject to. Also included is the rule origin and authority of each emission limit and permit condition.

Section D Page 2
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMITTED EQUIPMENT LIST

The following is a list of all permits to construct and operate at this facility:

Application Permit Equipment Description		Page	
Number	Number	<u> </u>	Number
06045A	R-M29144	ICE (>500 HP) EMERGENCY ELECTRICAL GENERATOR DIESEL	6
06046A	R-M29146	ICE (>500 HP) EMERGENCY ELECTRICAL GENERATOR DIESEL	8
06047A	R-M29147	ICE (>500 HP) EMERGENCY ELECTRICAL GENERATOR DIESEL	10
06048A	R-M29148	ICE (>500 HP) EMERGENCY ELECTRICAL GENERATOR DIESEL	12
291030	R-D94235	BOILER (5-20 MMBTU/HR) NATURAL & DIGESTER GAS	14
291031	R-D94232	BOILER (5-20 MMBTU/HR) NATURAL & DIGESTER GAS	16
331911	F11229	SCRUBBER, ODOR	
424369	F65823	ICE (>500 HP) EMERGENCY ELECTRICAL GENERATOR DIESEL	20
428804	G34370	ODOR CONTROL FACILITY, TRUNKLINES AND HEADWORKS	22
429663	F71055	FLARE, ENCLOSED LANDFILL/DIGESTER GAS	25
444111	F99405	SCRUBBER, ODOR	29
444112	F99406	SCRUBBER, ODOR	31
444113	F99408	SCRUBBER, ODOR	33
453240	G25942	SEWAGE TREATMENT (>5 MGD) ANAEROBIC	35
453244	G27920	APC SYSTEM, ACTIVATED CARBON ADSORBER	38
455670	R-F81554	ICE (>500 HP) EMERGENCY ELECTRICAL GENERATOR DIESEL	41
455671	R-F81555	ICE (>500 HP) EMERGENCY ELECTRICAL GENERATOR DIESEL	42
455673	R-F81556	ICE (>500 HP) EMERGENCY ELECTRICAL GENERATOR DIESEL	44
457410	G24634	ACTIVATED CARBON ADSORBER, DRUM VENT SINGLE SOURCE	
474766	F95584	ICE (>500 HP) EMERGENCY ELECTRICAL GENERATOR DIESEL	48
474767	F95585	ICE (>500 HP) EMERGENCY ELECTRICAL GENERATOR DIESEL	50
474768	F95586	ICE (>500 HP) EMERGENCY ELECTRICAL GENERATOR DIESEL	52
474769	F95587	ICE (>500 HP) EMERGENCY ELECTRICAL GENERATOR DIESEL	54
474770	F95588	ICE (>500 HP) EMERGENCY ELECTRICAL GENERATOR DIESEL	56
512604	G12233	STORAGE TANK, FIXED ROOF, HCI, W/SPARGER	58
512832	G12234	STORAGE TANK, FIXED ROOF, HCI, W/CONTROL	59
512833	G12235	STORAGE TANK, FIXED ROOF, HCI, W/CONTROL	60

Section D Page 3 Facility I.D. #: 29110 Revision #: 07

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMITTED EQUIPMENT LIST (CONT'D)

The following is a list of all permits to construct and permits to operate at this facility:

Application Number	Permit Number	Equipment Description	Page Number
540708	G27394	ICE (>500 HP) NATURAL & DIGESTER GAS	61
540709	G27395	ICE (>500 HP) NATURAL & DIGESTER GAS	64
540710	G27396	ICE (>500 HP) NATURAL & DIGESTER GAS	67
540711	G27397	ICE (>500 HP) NATURAL & DIGESTER GAS	70
540712	G27398	ICE (>500 HP) NATURAL & DIGESTER GAS	73

NOTE: APPLICATIONS THAT ARE STILL BEING PROCESSED AND HAVE NOT BEEN ISSUED PERMITS TO CONSTRUCT OR PERMITS TO OPERATE WILL NOT BE FOUND IN THIS TITLE V PERMIT.



Section D Page 4
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

FACILITY WIDE CONDITION (S)

Condition(s):

- 1. EXCEPT FOR OPEN ABRASIVE BLASTING OPERATIONS, THE OPERATOR SHALL NOT DISCHARGE INTO THE ATMOSPHERE FROM ANY SINGLE SOURCE OF EMISSIONS WHATSOEVER ANY AIR CONTAMINANT FOR A PERIOD OR PERIODS AGGREGATING MORE THAN THREE MINUTES IN ANY ONE HOUR WHICH IS:
 - A. AS DARK OR DARKER IN SHADE AS THAT DESIGNATED NO. I ON THE RINGLEMANN CHART, AS PUBLISHED BY THE UNITED STATES BUREAU OF MINES; OR
 - B. OF SUCH OPACITY AS TO OBSCURE AN OBSERVER'S VIEW TO A DEGREE EQUAL TO OR GREATER THAN DOES SMOKE DESCRIBED IN SUBPARAGRAPH (A) OF THIS CONDITION. [RULE 401]
- 2. THE OPERATOR SHALL NOT COMBUST DIGESTER GAS CONTAINING SULFUR COMPOUNDS IN EXCESS OF 40 PPMV CALCULATED AS HYDROGEN SULFIDE AVERAGED DAILY.
 [RULE 431.1]
- 3. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 0.05 PERCENT BY WEIGHT. ON OR AFTER JUNE 1, 2004, A PERSON SHALL NOT PURCHASE ANY DIESEL FUEL FOR STATIONARY SOURCE APPLICATION IN THE DISTRICT, UNLESS THE FUEL IS LOW SULFUR DIESEL FOR WHICH THE SULFUR CONTENT SHALL NOT EXCEED 15 PPM BY WEIGHT AS SUPPLIED BY THE SUPPLIER.
 [RULE 431.2]
- 4. THE OWNER/OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF 40 CFR 63 SUBPART VVV NON-INDUSTRIAL POTW PLANT NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS (NESHAP) AND ALL APPLICABLE REQUIREMENTS OF 40 CFR 63 SUBPART ZZZZ STATIONARY RECIPROCATING INTERNAL COMBUSTION ENGINES NESHAP. [40 CFR 63 SUBPART VVV, AND 40 CFR 63 SUBPART ZZZZ]
- 5. THE OPERATOR SHALL MEASURE THE SULFUR CONTENT OF THE DIGESTER GAS ACCORDING TO THE FOLLOWING:
 - A. FOR READINGS UP TO 36 PPM AS H2S, DAILY ANALYSIS OF THE DIGESTER GAS FOR H2S, USING COLORIMETRIC TUBES, AND WEEKLY ANALYSIS OF THE DIGESTER GAS BY AQMD METHOD 307 TOTAL SULFUR COMPOUNDS IN FUEL GAS BY GAS CHROMATOGRAPHY AND SULFUR CHEMILUMINESCENCE DETECTOR.
 - B. FOR READINGS ABOVE 36 PPM AS H2S, DAILY ANALYSIS OF THE DIGESTER GAS FOR H2S BY AQMD METHOD 307 TOTAL SULFUR COMPOUNDS IN FUEL GAS BY GAS CHROMATOGRAPHY AND SULFUR CHEMILUMINESCENCE DETECTOR. A MINIMUM OF THREE CONSECUTIVE DAILY SAMPLES ARE REQUIRED TO DEMONSTRATE THE TOTAL SULFUR CONTENT IS BELOW 36 PPM.

 [RULE 431.1]



Section D Page 5
Facility I.D. #: 29110
Revision #: 07

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

6. A COMPLETE APPLICATION FOR COMPLIANCE ASSURANCE MONITORING (CAM, 40 CFR PART 64) SHALL BE SUBMITTED WHENEVER ANNUAL MASS OF VOC OF THE DIGESTER GAS EXCEEDS 19,999 LBS/YR. THE VOC CONTENT OF THE DIGESTER GAS SHALL BE ANALYZED IN CONJUNCTION WITH THE ANNUAL SOURCE TESTING OF THE CGS ENGINES USING THE APPROVED METHODS. FOR EACH CALENDAR YEAR, THE VOC EMISSIONS SHALL BE CALCULATED BY MARCH 31ST OF THE SUBSEQUENT CALENDAR YEAR BASED ON THE DIGESTER GAS CONCENTRATION DATA FROM THE MOST RECENT ANNUAL RULE 1110.2 SOURCE TESTING OF THE ENGINES. IF THE VOC EMISSIONS EXCEED 19,999 LBS/YR, THE CAM APPLICATION SHALL BE SUBMITTED BY MAY 31ST (WITHIN 60 DAYS AFTER THE CALCULATION DUE DATE).

[40 CFR PART 64, CAM]



Section D Page 6
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. R-M29144 A/N 06045A

Equipment Description:

INTERNAL COMBUSTION ENGINE NO. 1, DETROIT DIESEL, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 9163-7305, DIESEL-FUELED, 16 CYLINDERS, TURBOCHARGED, 1515 BHP.

- 1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 5. THE OPERATION OF ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.

 [RULE 1304 (a) (1)-BACT, RULE 1470]
- 6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.

 [RULE 1303 (a) (1)-BACT, RULE 1470]



Section D Page 7
Facility I.D. #: 29110
Revision #: 07

Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - **B. MAINTENANCE AND TESTING HOURS**
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(A), RULE 1110.2, RULE 1470]

8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

THIS PERMIT TO OPERATE R-M29144 SUPERSEDES PERMIT TO OPERATE M29144 ISSUED 01/20/1983.

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS.

PM: RULE 1470



Page 8 Section D Facility I.D. #: 29110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. R-M29146 A/N 06046A

Equipment Description:

INTERNAL COMBUSTION ENGINE NO. 2, DETROIT DIESEL, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 9163-7305, DIESEL-FUELED, 16 CYLINDERS, TURBOCHARGED, 1515 BHP.

- 1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW. [RULE 204]
- THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING 2. CONDITION AT ALL TIMES. **FRULE 2041**
- THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH 3. INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES. [RULE 1304(a), RULE 1110.2, RULE 1470]
- AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND 4. MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME. [RULE 1304(a), RULE 1110.2, RULE 1470]
- THE OPERATION OF ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE 5. MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT. [RULE 1304 (a) (1)-BACT, RULE 1470]
- THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING 6. INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR. [RULE 1303 (a) (1)-BACT, RULE 1470]

Section D Page 9
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - **B. MAINTENANCE AND TESTING HOURS**
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR. [RULE 1304(A), RULE 1110.2, RULE 1470]

8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

THIS PERMIT TO OPERATE R-M29146 SUPERSEDES PERMIT TO OPERATE M29146 ISSUED 01/20/1983.

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS.

PM: RULE 1470



Section D Page 10 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. R-M29147 A/N 06047A

Equipment Description:

INTERNAL COMBUSTION ENGINE NO. 3, DETROIT DIESEL, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 9163-7305, DIESEL-FUELED, 16 CYLINDERS, TURBOCHARGED, 1515 BHP.

- 1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 5. THE OPERATION OF ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.

 [RULE 1304 (a) (1)-BACT, RULE 1470]
- 6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.

 [RULE 1303 (a) (1)-BACT, RULE 1470]

Section D Page 11
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - **B. MAINTENANCE AND TESTING HOURS**
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR. [RULE 1304(A), RULE 1110.2, RULE 1470]

8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

THIS PERMIT TO OPERATE R-M29147 SUPERSEDES PERMIT TO OPERATE M29147 ISSUED 01/20/1983.

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS.

PM: RULE 1470



Section D Page 12 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. R-M29148 A/N 06048A

Equipment Description:

INTERNAL COMBUSTION ENGINE NO. 4, DETROIT DIESEL, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 9163-7305. DIESEL-FUELED, 16 CYLINDERS, TURBOCHARGED, 1,515-H.P.

- 1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 5. THE OPERATION OF ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.

 [RULE 1304 (a) (1)-BACT, RULE 1470]
- 6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.

 [RULE 1303 (a) (1)-BACT, RULE 1470]



Section D Page 13
Facility I.D. #: 29110
Revision #: 07

Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - **B. MAINTENANCE AND TESTING HOURS**
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR. [RULE 1304(A), RULE 1110.2, RULE 1470]

8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

THIS PERMIT TO OPERATE R-M29148 SUPERSEDES PERMIT TO OPERATE M29148 ISSUED 01/20/1983.

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS.

PM: RULE 1470



Section D Page 14
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. R-D94235 A/N 291030

Equipment Description:

BOILER, CLEAVER BROOKS, FIRE TUBE TYPE, MODEL CB700-250, SERIAL NO. L-092869, 10.46 MMBTU PER HOUR, DIGESTER GAS AND NATURAL GAS FIRED WITH LO-NOx BURNERS AND FLUE GAS RECIRCULATION (FGR) SYSTEM.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS BOILER SHALL BE FIRED ON DIGESTER GAS AND OR NATURAL GAS ONLY. [RULE 204]
- 4. CSDOC SHALL PROPERLY MAINTAIN AND OPERATE A DRY GAS METER TO MEASURE THE QUANTITY (IN CFM) OF DIGESTER GAS USED IN THIS EQUIPMENT.
 [RULE 1146, RULE 1303(b) (1), (b) (2)-MODELING AND OFFSETS]
- 5. RECORDS OF THE DAILY FUEL USAGE OF THIS EQUIPMENT SHALL BE KEPT AND MAINTAINED FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
 [RULE 204]
- 6. EMISSIONS OF NOX SHALL NOT EXCEED 40 PPM REFERENCED AT 3% 02 ON A DRY BASIS, AVERAGED OVER A PERIOD OF 15 CONSECUTIVE MINUTES.
 [RULE 1146]
- 7. EMISSIONS OF CO SHALL NOT EXCEED 400 PPM REFERENCED AT 3% 02 ON A DRY BASIS, AVERAGED OVER A PERIOD OF 15 CONSECUTIVE MINUTES.
 [RULE 1146]
- 8. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.

 [RULE 1303(A) (1)-BACT]



Section D Page 15
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407 CO: 400 PPMV, RULE 1146 NOx 30 PPMV, RULE 1146

PM: RULE 404, SEE APPENDIX B.

PM: 0.1 gr/scf, RULE 409

SO2: 500 PPMV AS SO2, ORANGE COUNTY, RULE 53

10. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO AND NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1 (METHOD 7.1 FOR NOX); OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD.. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATIONS LIMITS. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

[RULE 3004 (a) (4)]

THIS PERMIT TO OPERATE R-D94235 SUPERSEDES PERMIT TO OPERATE D94235 ISSUED 11/06/1995.



Section D Page 16
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. R-D94232 A/N 291031

Equipment Description:

BOILER, CLEAVER BROOKS, FIRE TUBE TYPE, MODEL CB700-250, SERIAL NO. L-092868, 10.46 MMBTU PER HOUR, DIGESTER GAS AND NATURAL GAS FIRED WITH LO-NOX BURNERS AND FLUE GAS RECIRCULATION (FGR) SYSTEM.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS BOILER SHALL BE FIRED ON DIGESTER GAS AND OR NATURAL GAS ONLY. [RULE 204]
- 4. CSDOC SHALL PROPERLY MAINTAIN AND OPERATE A DRY GAS METER TO MEASURE THE QUANTITY (IN CFM) OF DIGESTER GAS USED IN THIS EQUIPMENT.
 [RULE 1146; RULE 1303(b) (1), (b) (2)-MODELING AND OFFSETS]
- 5. RECORDS OF THE DAILY FUEL USAGE OF THIS EQUIPMENT SHALL BE KEPT AND MAINTAINED FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
 [RULE 204]
- 6. EMISSIONS OF NOX SHALL NOT EXCEED 40 PPM REFERENCED AT 3% 02 ON A DRY BASIS, AVERAGED OVER A PERIOD OF 15 CONSECUTIVE MINUTES.
 [RULE 1146]
- EMISSIONS OF CO SHALL NOT EXCEED 400 PPM REFERENCED AT 3% 02 ON A DRY BASIS, AVERAGED OVER A PERIOD OF 15 CONSECUTIVE MINUTES. [RULE 1146]
- 8. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
 [RULE 1303(A) (1)-BACT]



Section D Page 17
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407 CO: 400 PPMV, RULE 1146 NOx 30 PPMV, RULE 1146

PM: RULE 404, SEE APPENDIX B.

PM: 0.1 gr/scf, RULE 409

SO2: 500 PPMV AS SO2, ORANGE COUNTY, RULE 53

10. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE CO AND NOX EMISSION LIMIT(S) EITHER BY: (a) CONDUCTING A SOURCE TEST AT LEAST ONCE EVERY FIVE YEARS USING AQMD METHOD 100.1 OR 10.1 (METHOD 7.1 FOR NOX); OR (b) CONDUCTING A TEST AT LEAST ANNUALLY USING A PORTABLE ANALYZER AND AQMD-APPROVED TEST METHOD.. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATIONS LIMITS. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

[RULE 3004 (a) (4)]

THIS PERMIT TO OPERATE R-D94232 SUPERSEDES PERMIT TO OPERATE D94232 ISSUED 11/06/1995.



Section D Page 18
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. F11229 A/N 331911

Equipment Description:

AIR POLLUTION CONTROL SYSTEM (SOUTH COMPLEX, P2-33) CONSISTING OF:

- 1. FOUR SCRUBBERS NOS. U THROUGH X, EACH VERTICAL TYPE, PACKED TOWER, 10'-0" DIA. X 33'-0" H., WITH ASSOCIATED PUMPS.
- 2. ACID AND CAUSTIC FEED SYSTEM.
- 3. AUTOMATIC CHEMICAL FEED AND HYDROGEN SULFIDE (H2S) MONITORING SYSTEM.
- 4. EXHAUST SYSTEM WITH ASSOCIATED BLOWERS VENTING PRIMARY TREATMENT CLARIFIERS.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
 [RULE 204]
- 4. A SUFFICIENT NUMBER OF SCRUBBERS, FROM U THROUGH X, SHALL BE IN OPERATION WHEN THE BASIC EQUIPMENT ARE IN OPERATION TO MAINTAIN THE SCRUBBER OUTLET H2S CONCENTRATIONS, AS MEASURED BY THE AUTOMATIC CHEMICAL FEED AND H2S MONITORING SYSTEM, LESS THAN THE MAXIMUM OUTLET H2S LIMITS AS SPECIFIED IN CONDITION NO. 7 EXCEPT DURING UNFORESEEN AND ROUTINE MAINTENANCE WORK OR POWER OUTAGE IN THE PLANT THAT REQUIRES THE SCRUBBERS TO BE SHUTDOWN FOR A PERIOD NOT TO EXCEED 10 HOURS PER INCIDENT PER EQUIPMENT AND 50 HOURS PER YEAR PER EQUIPMENT.

 [RULE 402]



Section D Page 19
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 5. WHEN THE SCRUBBERS ARE IN OPERATION, AUTOMATIC CHEMICAL FEED AND HYDROGEN SULFIDE (H2S) MONITORING SYSTEM SHALL BE IN OPERATION AND MAINTAINED TO RECORD THE SCRUBBER OUTLET H2S CONCENTRATION, IN PPMV, EXCEPT DURING SHUTDOWN FOR MAINTENANCE. THE H2S MONITORING SYSTEM SHALL BE CALIBRATED PURSUANT TO MANUFACTURER'S RECOMMENDATIONS AND SPECIFICATIONS.

 [RULE 402]
- 6. WHEN THE AUTOMATIC CHEMICAL FEED AND H2S MONITORING SYSTEM IS SHUTDOWN FOR MAINTENANCE, PH OF THE SCRUBBING LIQUID AND THE SCRUBBER OUTLET H2S CONCENTRATION SHALL BE MEASURED AND RECORDED AT LEAST ONCE PER SHIFT. [RULE 402]
- 7. WHEN THE SCRUBBERS ARE IN OPERATION, THE DAILY AVERAGE CONCENTRATION OF SULFUR COMPOUNDS, CALCULATED AS H2S MEASURED AT THE OUTLET OF EACH SCRUBBER SHALL NOT EXCEED 1.33 PPMV AND 2 PPMV, WHEN THE EXHAUST BLOWER IS OPERATING AT LOW AND HIGH SPEED, RESPECTIVELY.

 [RULE 402]
- 8. RECORDS SHALL BE KEPT AND MAINTAINED FOR EACH SCRUBBER'S OUTLET H2S CONCENTRATION, AND THE DAILY AVERAGE H2S CONCENTRATION, IN PPMV, AT THE OUTLET OF EACH SCRUBBER.

 [RULE 204]



Section D Page 20 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. F65823 A/N 424369

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, 16 CYLINDER, "TURBOCHARGED, AFTERCOOLED," MODEL T1 637 M36 (2936 BHP), 2936 BHP, DIESEL FUEL-FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

- 1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 5. THE OPERATION OF ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.

 [RULE 1303 (a) (1)-BACT, RULE 1470]
- 6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.

 [RULE 1303 (a) (1)-BACT, RULE 1470]

Section D Page 21
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - **B. MAINTENANCE AND TESTING HOURS**
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR. [RULE 1304(A), RULE 1110.2, RULE 1470]

8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS.

PM: RULE 1470



Section D Page 22
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. G34370 A/N 428804

Equipment Description:

ODOR CONTROL FACILITY CONSISTING OF:

- A. TRUNKLINES ODOR CONTROL SYSTEM:
- THREE (3) SINGLE STAGE BIOTRICKLING FILTERS (BIOTOWERS), IDENTICAL, (ONE STAND-BY), VERTICAL TYPE, EACH 10'- 0" DIA. X 47'- 9" H., OVERALL DIMENSIONS, WITH 8' 6" H. POLYURETHANE FOAM PACKING AND A MIST ELIMINATOR, ASSOCIATED RECIRCULATING PUMPS, AND AN EXHAUST SYSTEM WITH THREE 75 HP BLOWERS (40,000 SCFM TOTAL), TREATING FOUL AIR EXHAUST FROM THE DIVERSION STRUCTURE AND INFLUENT TRUNKLINES, VENTING TO THE 1ST STAGE BIOTRICKLING FILTERS AT THE HEADWORKS ODOR CONTROL FACILITY.
- B. HEADWORKS ODOR CONTROL SYSTEM:
- 1) 1ST STAGE, THIRTEEN (13) BIOTRICKLING FILTERS (BIOTOWERS), IDENTICAL, (THREE ON STAND-BY), VERTICAL TYPE, EACH 10'- 0" DIA. X 47'- 9" H., OVERALL DIMENSIONS, WITH 8'- 6" H. POLYURETHANE FOAM PACKING, A MIST ELIMINATOR, ASSOCIATED PUMPS, AND AN EXHAUST SYSTEM WITH THIRTEEN 75 HP BLOWERS (188,300 SCFM TOTAL), TREATING FOUL AIR FROM HEADWORKS FACILITY AND PRETREATED EXHAUST AIR FROM TRUNKLINE ODOR CONTROL FACILITY VENTING TO THE 2ND STAGE CHEMICAL SCRUBBERS AT THE HEADWORKS ODOR CONTROL FACILITY.
- 2) 2ND STAGE, EIGHT (8) CHEMICAL SCRUBBERS, IDENTICAL, (TWO ON STAND-BY), VERTICAL TYPE, EACH 10'- 0" DIA. X 52'- 7" H., OVERALL DIMENSIONS (INCLUDES 3' 6" DIA. X 8' 9" H. STACK EXTENSION), WITH Q-PAC OR TRIPACK TYPE, 10' 0" H. POLYURETHANE PACKING, A MIST ELIMINATOR, AUTOMATIC CHEMICAL FEED, ASSOCIATED RECIRCULATION PUMPS, AND AN EXHAUST SYSTEM WITH EIGHT 60 HP BLOWERS (188,300 SCFM TOTAL), TREATING EXHAUST AIR FROM 1ST STAGE BIOTRICKLING FILTERS, AND VENTING TO THE ATMOSPHERE.
- C. SODIUM HYPOCHLORITE, SODIUM HYDROXIDE AND HYDROCHLORIC ACID STORAGE TANKS.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED, UNLESS OTHERWISE NOTED BELOW.
 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]



Section D Page 23 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
 [RULE 204]
- 4. THIS EQUIPMENT SHALL ONLY TREAT FOUL AIR GENERATED FROM THE DIVERSION STRUCTURE AND TRUNKLINES, GRIT HANDLING BUILDING, BAR SCREEN BUILDING AND CHANNELS, PUMP STATION WET WELL, SCREENINGS WASHING AND LOADING BUILDINGS, GRIT BASINS, PRIMARY SPLITTER BOX, AND INFLUENT PUMP STATION DISCHARGE CHANNEL. [RULE 402]
- 5. ALL THE EXHAUST FROM THE BIOTRICKLING FILTERS (TRUNKLINE AND HEADWORKS BIOTRICKLING FILTERS) SHALL BE VENTED TO AND TREATED BY THE FINAL CHEMICAL SCRUBBERS PRIOR TO RELEASE TO THE ATMOSPHERE.

 [RULE 1303 (a) (1) BACT]
- 6. A SUFFICIENT NUMBER OF BIOTRICKLING (BIOTOWERS) AND CHEMICAL SCRUBBERS SHALL BE IN OPERATION WHEN THE BASIC EQUIPMENT ARE IN OPERATION TO MAINTAIN THE CHEMICAL SCRUBBERS OUTLET H2S CONCENTRATIONS, AS MEASURED BY THE AUTOMATIC CHEMICAL FEED AND H2S MONITORING SYSTEM, LESS THAN THE MAXIMUM OUTLET H2S LIMITS AS SPECIFIED IN CONDITION NO. 14 EXCEPT DURING UNFORESEEN AND ROUTINE MAINTENANCE WORK OR POWER OUTAGE IN THE PLANT THAT REQUIRES THE SCRUBBERS TO BE SHUTDOWN FOR A PERIOD NOT TO EXCEED 10 HOURS PER INCIDENT PER EQUIPMENT AND 50 HOURS PER YEAR PER EQUIPMENT.

 [RULE 204]
- 7. ALL BIOTRICKLING FILTERS AND CHEMICAL SCRUBBERS SHALL BE EQUIPPED WITH INLET AND OUTLET CONTINUOUS HYDROGEN SULFIDE MONITORING SYSTEM (VAPAX UNIT OR EQUIVALENT).

 [RULE 204]
- 8. WHEN THE CHEMICAL SCRUBBERS ARE IN OPERATION, AUTOMATIC CHEMICAL FEED AND HYDROGEN SULFIDE (H₂S) MONITORING SYSTEM SHALL BE IN OPERATION AND MAINTAINED TO RECORD THE SCRUBBER INLET AND OUTLET H2S CONCENTRATIONS, IN PPMV, EXCEPT DURING SHUTDOWN FOR MAINTENANCE. THE H₂S MONITORING SYSTEM SHALL BE CALIBRATED PERIODICALLY PURSUANT TO MANUFACTURER'S RECOMMENDATIONS AND SPECIFICATIONS.

 [RULE 204]
- 9. A FLOW METER, INDICATING GALLONS PER MINUTE (GPM) SHALL BE INSTALLED AND MAINTAINED IN THE CHEMICAL SCRUBBING SOLUTION [SODIUM HYDROXIDE (NaOH) AND SODIUM HYPOCHLORITE (NaOCI)] RECIRCULATION LINE FOR EACH OF THE CHEMICAL SCRUBBER. AT LEAST 785 GPM OF CHEMICAL SCRUBBING SOLUTION SHALL BE SUPPLIED TO EACH CHEMICAL SCRUBBER WHEN IT IS IN OPERATION. [RULE 204]
- 10. FOR THE CHEMICAL SCRUBBER(S), A DIFFERENTIAL PRESSURE GAUGE OR OTHER DEVICE SHALL BE INSTALLED AND MAINTAINED TO INDICATE, IN INCHES OF WATER COLUMN, THE DIFFERENTIAL PRESSURE DROP ACROSS THE SCRUBBER. DURING NORMAL OPERATION, THE PRESSURE DROP MEASURED ACROSS THE SCRUBBER SHALL BE LESS THAN 4 INCHES OF WATER COLUMN.

 [RULE 204]



Section D Page 24
Facility I.D. #: 29110
Revision #: 07

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 11. THE PH OF THE CHEMICAL SCRUBBING SOLUTION SHALL BE MAINTAINED BETWEEN 9 TO 10.5. [RULE 204]
- 12. WHEN THE AUTOMATIC CHEMICAL FEED AND H₂S MONITORING SYSTEM IS NOT OPERATING, PH OF THE SCRUBBING LIQUID, SCRUBBER SOLUTION RECIRCULATION RATE (GPM), THE SCRUBBER INLET AND OUTLET H₂S CONCENTRATION (PPMV) AND DIFFERENTIAL PRESSURE (INCHES OF WATER COLUMN) ACROSS THE SCRUBBER SHALL BE MEASURED AND RECORDED AT LEAST ONCE PER SHIFT.

 [RULE 204]
- 13. WHEN THE CHEMICAL SCRUBBERS ARE IN OPERATION, THE DAILY AVERAGE CONCENTRATION OF SULFUR COMPOUNDS, CALCULATED AS H2S MEASURED AT THE OUTLET OF THE SCRUBBER SHALL NOT EXCEED 1 PPMV.

 [RULE 402, 1401]
- 14. ALL RECORDS SHALL BE KEPT AND MAINTAINED FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO SCAQMD PERSONNEL UPON REQUEST.
 [RULE 204]



Section D Page 25
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. F71055 A/N 429663

Equipment Description:

DIGESTER GAS FLARING SYSTEM (PLANT NO. 2) CONSISTING OF:

- 1. THREE FLARES NOS. A, B AND C, EACH SUR-LITE CORP., VERTICAL TYPE, 6'-6" W. X 6'-6- L. X 24'-3" H., 27,000,000 BTU PER HOUR MAXIMUM HEAT INPUT, WITH A DIGESTER GAS PILOT BURNER, A NATURAL GAS PILOT BURNER, AN AUTOMATIC COMBUSTION AIR DAMPER AND A RESTART IGNITION SYSTEM.
- 2. THREE GAS FILTERS, DOLLINGER, MODEL GP-188.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
 [RULE 204]
- 4. THE HOURLY AVERAGE VOLUME OF DIGESTER GAS BURNED IN EACH FLARE SHALL NOT EXCEED 750 SCFM.
 [RULE 1303 (b) (1) AND 1303 (b) (2)-MODELING & OFFSETS]
- 5. THE HOURLY AVERAGE OF TOTAL VOLUME OF DIGESTER GAS BURNED IN THE FLARING SYSTEM (3-FLARES) SHALL NOT EXCEED 2250 SCFM.
 [RULE 1303 (b) (1) AND 1303 (b) (2)-MODELING & OFFSETS]
- 6. FLOW INDICATORS, AND RECORDERS SHALL BE MAINTAINED TO MEASURE THE INDIVIDUAL FLOW RATE TO EACH FLARE AND TOTAL FLOW RATE TO THE FLARING SYSTEM. [RULE 1303(b) (2)-OFFSETS]



Section D Page 26
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 7. WHEN THE FLARES ARE IN OPERATION, A TEMPERATURE OF NOT LESS THAN 1400 DEGREES F, AVERAGED OVER ONE HOUR, AS MEASURED BY THE TEMPERATURE INDICATOR SHALL BE MAINTAINED IN THE FLARE STACK, EXCEPT FOR A MAXIMUM OF THIRTY- MINUTES DURING START-UP AND FIFTEEN- MINUTES DURING SHUT-DOWN, AND THREE MINUTES WHEN THERMOCOUPLES SWITCH OCCURS. THE THERMOCOUPLE USED TO MEASURE THE TEMPERATURE SHALL BE ABOVE THE FLAME ZONE AND AT LEAST 0.6 SECONDS DOWNSTREAM OF THE BURNER.

 [RULE 1303(a) (1) BACT]
- 8. A TEMPERATURE INDICATOR AND RECORDER SHALL BE MAINTAINED TO MEASURE THE EXHAUST GAS TEMPERATURE IN EACH OF THE FLARE STACKS. [RULE 1303(a) (1)-BACT]
- 9. AUTOMATIC DAMPERS TO REGULATE THE FLOW OF COMBUSTION AIR SHALL BE MAINTAINED ON EACH FLARE.
 [RULE 1303(a) (1)-BACT]
- 10. THE OPERATOR SHALL KEEP THE RECORDS OF DIGESTER GAS FLOW RATES AND OPERATING TEMPERATURE. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE UPON REQUEST TO AQMD PERSONNEL.

 [RULE 204]
- 11. A FLARE FAILURE ALARM SYSTEM CONSISTING OF A FLAME-OUT WARNING LIGHT BY THE FLARE STATION AND AN AUDIBLE ALARM IN THE CONTROL ROOM SHALL BE MAINTAINED. THIS SAFETY SYSTEM SHALL BE TESTED MONTHLY FOR PROPER OPERATION AND THE RESULTS RECORDED AND MAINTAINED FOR FIVE YEARS.

 [RULE 204, RULE 1303(a) (1)-BACT]
- 12. THE ORANGE COUNTY SANITATION DISTRICT SHALL, AT LEAST ONCE EVERY FIVE YEARS, CONDUCT TEST ON ONE OF THE THREE FLARES IN ACCORDANCE WITH SCAQMD TEST PROCEDURES AND FURNISH THE AQMD WITH WRITTEN RESULTS OF SUCH PERFORMANCE TEST WITHIN 45 DAYS AFTER THE TESTING. SUBSEQUENT TESTS SHALL BE PERFORMED ON ALTERNATE FLARES AT THE MAXIMUM FIRING RATE. WRITTEN NOTICE OF THE PERFORMANCE TESTS SHALL BE PROVIDED TO THE AQMD 7 DAYS PRIOR TO THE TEST SO THAT AN OBSERVER MAY BE PRESENT. THE PERFORMANCE TESTS SHALL INCLUDE, BUT MAY NOT BE LIMITED TO, A TEST OF THE DIGESTER GAS INLET TO THE FLARE AND THE FLARE EXHAUST FOR THE FOLLOWING:
 - I. METHANE (LBS/HR)
 - II. TOTAL NON-METHANE HYDROCARBONS (LB/HR)
 - III. OXIDES OF NITROGEN (AS NO2, EXHAUST ONLY, PPMV @ 3% 02, DRY, LBS/HR)
 - IV. CARBON MONOXIDE (EXHAUST ONLY, PPMV @3% 02, DRY, LBS/HR).
 - V. TOTAL PARTICULATES (EXHAUST ONLY, GR/DSCF, LBS/HR).
 - VI. CHEMICAL COMPOUNDS CONCENTRATION IN UG/M3,-INCLUDING BUT NOT LIMITED TO:
 - a. ACETALDEHYDE
 - b. ACROLEIN
 - c. BENZENE
 - d. CARBON TETRACHLORIDE



Section D Page 27
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- e. CHLOROBENZENE
- f. CHLOROFORM
- g. 1, 4 (p)-DICHLOROBENZENE
- h. 1, 2 DICHLOROETHANE
- i. FORMALDEHYDE
- j. METHYLENE CHLORIDE
- k. STYRENE
- 1. TETRACHLOROETHYLENE
- m. TOLUENE
- n. TRICHLOROETHYLENE
- o. 1, 1, 1 TRICHLOROETHANE
- p. VINYL CHLORIDE
- a. XYLENES

[RULE 1303(a) (1)-BACT, RULE 1303(b) (2) - OFFSETS, RULE 1401]

- 13. SAMPLING PORTS SHALL BE MAINTAINED IN EACH FLARE STACK AT LEAST 3 FEET UPSTREAM OF FLARE OUTLET AND SHALL CONSIST OF 4-INCH COUPLINGS WITH PLUGS. AN EQUIVALENT METHOD OF EMISSION SAMPLING MAY BE USED UPON APPROVAL BY THE AQMD. ADEQUATE AND SAFE ACCESS TO THE TEST PORTS SHALL BE PROVIDED BY THE COUNTY SANITATION DISTRICTS OF ORANGE COUNTY.

 [RULE 217]
- 14. EMISSIONS RESULTING FROM EACH FLARE OPERATION SHALL NOT EXCEED THE FOLLOWING:

POLLUTANT	LBS/HR
NOX, AS N02	1.75
SOX, AS S02	0.30
CO	8.33
PM	1.13
ROG	0.50
[RULE 1303(b) (2) – OFFSETS, RULE 431.1]	

15. EMISSIONS RESULTING FROM THE FLARING OPERATION (3-FLARES) SHALL NOT EXCEED THE FOLLOWING:

POLLUTANT	LBS/DAY
NOX, AS N02	126
SOX, AS S02	22
CO	600
PM	81
ROG	36
[RULE 1303(b) (2) - OFFSE	TS]

Section D Page 28
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 16. THESE FLARES SHALL NOT OPERATE SIMULTANEOUSLY WITH THE CENTRAL POWER GENERATION ENGINES, AT PLANT NO. 2, EXCEPT DURING ROUTINE AND UNFORESEEN MAINTENANCE PERIODS, ENGINE START-UP, SOURCE TESTING PERIODS, AND WHEN THERE IS EXCESS DIGESTER GAS THAT CANNOT BE USED BY THE ENGINES DUE TO MAINTENANCE. [RULE 1303(b) (2) OFFSETS]
- 17. ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF DAY. [RULE 204]
- 18. A SAMPLING PORT SHALL BE MAINTAINED AT THE INLET GAS LINE TO THE FLARING SYSTEM TO ALLOW THE COLLECTION OF A DIGESTER GAS SAMPLE.
 [RULE 217]
- 19. ALL RECORDS AS REQUIRED BY THIS PERMIT SHALL BE MAINTAINED ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.

 [RULE 204]
- 20. THIS EQUIPMENT SHALL BE OPERATED IN COMPLIANCE WITH RULE 431.1.

Emissions and Requirements:

21. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: 0.1 gr/scf, RULE 409

NO_X 0.06 lb/MMBTU, RULE 1303 (a) (1)- BACT.

Section D Page 29
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. F99405 A/N 444111

Equipment Description:

AIR POLLUTION CONTROL SYSTEM (NORTH SCRUBBER COMPLEX, P2-33) CONSISTING OF:

- 1. SCRUBBER 'H', VERTICAL TYPE, PACKED TOWER, 6'- 0" DIA. X 27'- 0" H., WITH ASSOCIATED PUMPS AND INLET BLOWER.
- 2. BIOTRICKLING FILTER 'I', WITH POLYURETHANE FOAM PACKING, 6'-0" DIA. X 27'- 0" H., WITH ASSOCIATED PUMPS AND INLET BLOWER.
- 3. SEVEN (7) SCRUBBERS 'M' THROUGH 'P' AND 'R' THROUGH T', VERTICAL TYPE, PACKED TOWER, 10'- 0" DIA. X 27'- 0" H., WITH ASSOCIATED PUMPS AND INLET BLOWERS.
- 4. BIOTRICKLING FILTER 'Q', WITH POLYURETHANE FOAM PACKING, 10'-0" DIA. X 27'- 0" H., WITH ASSOCIATED PUMPS AND INLET BLOWER.
- 5. AUTOMATIC CHEMICAL FEED AND HYDROGEN SULFIDE (H2S) MONITORING SYSTEMS.
- 6. EXHAUST SYSTEM WITH ASSOCIATED BLOWERS VENTING THE INFLUENT TRUNKLINES, HEADWORKS AND PRIMARY TREATMENT FACILITIES.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED, UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.

 [RULE 204]
- 4. SCRUBBER 'H' AND BIOTRICKLING FILTER 'I' SHALL ONLY EXHAUST INTO THE SCRUBBERS 'M' THROUGH 'P' AND 'R' THROUGH 'T' AND BIOTRICKLING FILTER 'Q'.

 [RULE 204]

Section D Page 30 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

5. AT LEAST THREE APC EQUIPMENT (SCRUBBERS OR BIOTRICKLING FILTERS) SHALL BE IN OPERATION WHEN THE BASIC EQUIPMENT ARE IN OPERATION EXCEPT DURING THE FOLLOWING EVENTS:

UNFORESEEN AND ROUTINE MAINTENANCE WORK OR POWER OUTAGE IN THE PLANT THAT REQUIRES THE SCRUBBERS OR BIOTRICKLING FILTERS TO BE SHUTDOWN FOR A PERIOD NOT TO EXCEED 10 HOURS PER INCIDENT PER EQUIPMENT AND 50 HOURS PER YEAR PER EQUIPMENT, OR LONGER IF CHEMICAL TREATMENT OF THE BASIC EQUIPMENT REDUCES THE OUTLET H2S CONCENTRATION OF THE AIR POLLUTION CONTROL SYSTEM TO LESS THAN THE LIMIT AS SPECIFIED IN CONDITION NO. 8. A LOG OF SHUTDOWN DATE, DURATION, AND REASON FOR THE SHUTDOWN SHALL BE MAINTAINED.

[RULE 204, 402]

- 6. WHEN ANY OF THE SCRUBBERS, 'M' THROUGH 'P' AND 'R' THROUGH 'T' OR SCRUBBER 'H' OR BIOTRICKLING FILTERS ARE IN OPERATION, AUTOMATIC HYDROGEN SULFIDE (H2S) MONITORING SYSTEM SHALL BE IN OPERATION AND MAINTAINED TO RECORD THE AIR POLLUTION CONTROL SYSTEM OUTLET H2S CONCENTRATION, IN PPMV. THE H2S MONITORING SYSTEM SHALL BE CALIBRATED PURSUANT TO MANUFACTURER'S RECOMMENDATIONS AND SPECIFICATIONS.

 [RULE 204]
- 7. WHEN THE AUTOMATIC CHEMICAL FEED AND H2S MONITORING SYSTEM IS NOT OPERATING, THE PH OF THE SCRUBBING OR RECYCLING LIQUID, MAKEUP WATER FLOW RATE (GPM), DIFFERENTIAL PRESSURE DROP (IN INCHES OF WATER COLUMN), FOR SCRUBBERS 'M' THROUGH 'P', 'R' THROUGH 'T' OR SCRUBBER 'H' OR BIOTRICKLING FILTERS SHALL BE MAINTAINED AS PER MANUFACTURER'S RECOMMENDATIONS. THE OPERATING PARAMETERS SHALL BE MEASURED AND RECORDED AT LEAST ONCE PER SHIFT.

 [RULE 204]
- 8. THE DAILY AVERAGE CONCENTRATION OF SULFUR COMPOUNDS, MEASURED, AND CALCULATED AS H2S, AT THE OUTLET OF THE AIR POLLUTION CONTROL SYSTEM SHALL NOT EXCEED 1.33 PPMV AND 2 PPMV, WHEN THE EXHAUST BLOWER IS OPERATING AT LOW AND HIGH SPEED, RESPECTIVELY. EMISSION AT THE EXHAUST STACK SHALL BE MONITORED AND RECORDED AT LEAST ONCE PER SHIFT.

 [RULE 402, 1401]
- 9. RECORDS SHALL BE KEPT AND MAINTAINED FOR DAILY AVERAGE OPERATING PARAMETERS AND H2S CONCENTRATION, IN PPMV, AT THE OUTLET OF EACH SCRUBBER OR BIOFILETER IN OPERATION. ALL RECORDS AS REQUIRED BY THIS PERMIT SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST. [RULE 204]



Section D Page 31
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. F99406 A/N 444112

Equipment Description:

AIR POLLUTION CONTROL SYSTEM (DEWATERING, P2-28-1) CONSISTING OF:

- 1. TWO (2) SCRUBBERS, 'C', AND 'D' (STAND-BY MODE), EACH VERTICAL TYPE, PACKED TOWER, 10'- 0" DIA. X 35'- 9" H., WITH ASSOCIATED PUMPS AND INLET BLOWERS.
- 2. BIOTRICKLING FILTERS 'J' AND 'K', EACH 10'- 0" DIA. X 35'- 9" H., 23,000 CFM AIR FLOW, WITH 10' POLYURETHANE FOAM PACKING HEIGHT, SPRAY NOZZLES, MIST ELIMINATOR PAD, ASSOCIATED PUMPS AND INLET BLOWER.
- 3. CHEMICAL FEED SYSTEM FOR SCRUBBERS.
- 4. EXHAUST SYSTEM WITH ASSOCIATED BLOWERS VENTING THE BELT FILTER PRESSES AND THE DEWATERING BUILDING.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED, UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
 [RULE 204]
- 4. WHEN ANY OF THE SCRUBBERS OR BIOTRICKLING FILTERS ARE IN OPERATION, THE PH OF THE SCRUBBING OR RECYCLING LIQUID, MAKEUP WATER FLOW RATE (GPM), DIFFERENTIAL PRESSURE DROP (IN INCHES OF WATER COLUMN), SHALL BE MAINTAINED AS PER MANUFACTURER'S RECOMMENDATIONS. THE OPERATING PARAMETERS AS DESCRIBED SHALL BE MEASURED AND RECORDED AT LEAST ONCE PER SHIFT.

 [RULE 204]
- 5. WHEN ANY OF THE SCRUBBERS OR BIOTRICKLING FILTER ARE IN OPERATION, THE H2S EMISSION AT THE EXHAUST STACK SHALL BE MONITORED AND RECORDED AT LEAST ONCE PER SHIFT. THE DAILY AVERAGE CONCENTRATION OF SULFUR COMPOUNDS MEASURED, AND CALCULATED AS H2S, AT THE OUTLET OF SCRUBBERS OR THE BIOTRICKLING FILTER SHALL NOT EXCEED 2.5 PPMV. [RULE 402, 1401]



Section D Page 32 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

6. RECORDS SHALL BE KEPT AND MAINTAINED FOR DAILY AVERAGE OPERATING PARAMETERS, AND H2S CONCENTRATION, IN PPMV, AT THE OUTLET OF EACH SCRUBBER IN OPERATION. THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 204]



Section D Page 33 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. F99408 A/N 444113

Equipment Description:

AIR POLLUTION CONTROL SYSTEM (DISSOLVED AIR FLOATATION FACILITY) CONSISTING OF:

- 1. SCRUBBER 'F' (STAND-BY MODE), VERTICAL TYPE, PACKED TOWER, 9'- 6" DIA. X 21'- 4" H., WITH ASSOCIATED PUMPS AND INLET BLOWER.
- 2. BIOTRICKLING FILTER 'G', WITH POLYURETHANE FOAM PACKING, 9'- 6" DIA. X 21'- 4" H., WITH ASSOCIATED PUMPS AND INLET BLOWER.
- 3. CHEMICAL FEED SYSTEM FOR SCRUBBERS.
- 4. EXHAUST SYSTEM WITH ASSOCIATED BLOWERS VENTING DISSOLVED AIR FLOATATION THICKENERS.

CONDITIONS:

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED, UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.

 [RULE 204]
- 4. WHEN SCRUBBER 'F' OR BIOTRICKLING FILTER 'G' IS IN OPERATION, THE PH OF THE SCRUBBING OR RECYCLING LIQUID, MAKEUP WATER FLOW RATE (GPM), DIFFERENTIAL PRESSURE DROP (IN INCHES OF WATER COLUMN), SHALL BE MAINTAINED AS PER MANUFACTURER'S RECOMMENDATIONS. THE OPERATING PARAMETERS AS DESCRIBED SHALL BE MEASURED AND RECORDED AT LEAST ONCE PER SHIFT.

 [RULE 204]
- 5. WHEN SCRUBBER 'F' OR BIOTRICKLING FILTER 'G' IS IN OPERATION, THE H2S EMISSION AT THE EXHAUST STACK SHALL BE MONITORED AND RECORDED AT LEAST ONCE PER SHIFT. THE DAILY AVERAGE CONCENTRATION OF SULFUR COMPOUNDS, MEASURED, AND CALCULATED AS H2S, AT THE OUTLET OF SCRUBBER OR THE BIOTRICKLING FILTER SHALL NOT EXCEED 3.5 PPMV.

 [RULE 204]



Section D Page 34
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

6. RECORDS SHALL BE KEPT AND MAINTAINED FOR DAILY AVERAGE OPERATING PARAMETERS, AND H2S CONCENTRATION, IN PPMV, AT THE OUTLET OF THE SCRUBBER IN OPERATION. THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.

[RULE 3004 (a) (4)]



Section D Page 35 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. G25942 A/N 453240

Equipment Description:

SEWAGE TREATMENT PLANT, 250 MGD CAPACITY, CONSISTING OF:

- 1. INFLUENT STATION (HEADWORKS "D") CONSISTING OF INFLUENT TRUNKLINES, INFLUENT DIVERSION AND METERING, SIX (5 DUTY + 1 STANDBY) BARSCREENS, SCREENING HANDLING, INFLUENT PUMPS, GRIT REMOVAL AND HANDLING, PRIMARY INFLUENT SPLITTER AND METERING, AND FERRIC CHLORIDE FACILITY.
- 2. WETWELL (WASTE SIDE STREAM PUMP STATION) WITH ASSOCIATED PUMPS.
- 3. SEVENTEEN PRIMARY BASINS, THREE 41'-0" W. X 179'-0" L. X 8'-0" D., WITH ALUMINUM COVERS, FOURTEEN 140'-0" DIA. X 9'-0" D., WITH ALUMINUM GEODESIC DOME COVERS, AND ASSOCIATED SLUDGE AND SCUM COLLECTORS AND PUMPS.
- 4. EIGHT ACTIVATED SLUDGE OXYGEN REACTORS, 139,656 CUBIC FEET CAPACITY, 46'-0" W. X 184'-0" L. X 16'-6" D., WITH ASSOCIATED MIXERS.
- 5. TWO PURE OXYGEN GENERATION UNITS, 40,000 GALLON CAPACITY EACH, WITH TWO STORAGE TANKS AND ASSOCIATED COMPRESSORS.
- 6. TWELVE SECONDARY CLARIFIERS, 61'-0" W. X 171'-0" L. X 14'-0" D., WITH ASSOCIATED SLUDGE COLLECTORS.
- EAST SECONDARY SLUDGE PUMP STATION WITH ASSOCIATED PUMPS.
- 8. WEST SECONDARY SLUDGE PUMP STATION WITH ASSOCIATED PUMPS.
- 9. FOUR DISSOLVED AIR FLOATATION THICKENERS, EACH 55'-0" DIA. X 8'-6" D., WITH ASSOCIATED COLLECTOR DRIVES AND PUMPS.
- 10. TWENTY DIGESTER TANKS, TWO 90'-0" DIA. X 30'-0" D., EACH 190,800 CUBIC FEET CAPACITY, SIX 80'-0" DIA. X 33'-0" D., EACH 164,120 CUBIC FEET CAPACITY, THREE 80'-0" DIA. X 33'-0" D., EACH 166,630 CUBIC FEET CAPACITY, FOUR 105'-0" DIA. X 30'-0" D., EACH 293,680 CUBIC FEET CAPACITY, FIVE 80'-0" DIA. X 18'-0" H., WITH ASSOCIATED PUMPS AND GRINDERS. EQUIPPED WITH OPTIONAL PASSIVE CARBON ADSORBERS.
- 11. LOW PRESSURE DIGESTER GAS STORAGE TANK, 25,000 CUBIC FEET CAPACITY, 42'-0" DIA. X 30'-0" H., WITH ASSOCIATED COMPRESSORS.
- 12. FERROUS AND/OR FERRIC CHLORIDE INJECTION STATION WITH TWO STORAGE TANKS, EACH 12'-0" DIA. X 18'-0" H., AND ASSOCIATED PUMPS.

Section D Page 36
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 13. SLUDGE PROCESSING STATION WITH ASSOCIATED GRINDERS, BELT FILTER PRESSES, DEWATERED STORAGE HOPPERS, AND TRUCK LOADING HOPPER.
- 14. TWO POLYMER STORAGE TANKS, EACH 20,000 GALLON CAPACITY, WITH ASSOCIATED PUMPS.
- 15. FOUR POLYMER MIX TANKS, EACH 8,500 GALLON CAPACITY, WITH ASSOCIATED MIXERS AND PUMPS.
- 16. PRIMARY EFFLUENT DIVERSION STRUCTURE.
- 17. THREE TRICKLING FILTERS, COVERED, PRIMARY EFFLUENT TREATMENT (TOTAL 60 MGD AVERAGE CAPACITY AND 182 MGD PEAK FLOW), EACH 150' DIA. X 28' H., OVERALL, WITH MODULAR PLASTIC CROSS FLOW FILTER MEDIA, SPRAY NOZZLES, AND ASSOCIATED PUMPS.
- 18. FOUR SOLIDS CONTACT (SC) REACTORS, FOUR SLUDGE RE-AERATION (SR) REACTORS, UNCOVERED, TWO MIXED LIQUOR CHANNELS (TOTAL 1.68 MG VOLUME), AND WITH ASSOCIATED AIR BLOWERS.
- 19. SIX TRICKLING FILTER CLARIFIERS, UNCOVERED, EACH 135' DIA. X 19' SIDEWATER DEPTH, WITH FLOCCULATING CENTER WELLS, HYDRAULIC SLUDGE COLLECTORS, AND INBOARD LAUNDERS.
- 20. SLUDGE BLENDING FACILITY WITH TWO SLUDGE BLENDING TANKS (SBTs), EACH 26,000 GALLON CAPACITY, WITH ASSOCIATED PIPING AND PUMPS.

Conditions:

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
 [RULE 204]
- 4. HEADWORKS FACILITY, PRIMARY BASINS, SLUDGE BLENDING FACILITY, DISSOLVED AIR FLOATATION THICKENERS, TRICKLING FILTER FACILITY AND SLUDGE PROCESSING STATION SHALL BE VENTED TO THEIR DESIGNATED AIR POLLUTION CONTROL SYSTEMS WHICH ARE IN OPERATION PER ITS' VALID PERMITS TO CONSTRUCT OR OPERATE ISSUED BY THE SCAQMD. IN THE EVENT AN AIR POLLUTION CONTROL SYSTEM IS REMOVED FROM OPERATION DURING CONSTRUCTION OR MAINTENANCE WORK, THE H2S CONCENTRATION IN EXHAUST AIR SHALL BE BELOW THE LIMITS SPECIFIED IN THE REMOVED AIR POLLUTION CONTROL SYSTEM'S PERMIT. EACH SUCH CONSTRUCTION OR MAINTENANCE EVENT SHALL BE RECORDED IN A DAILY LOG.

[RULE 402, 1303(a) (1)-BACT, 1401]



Section D Page 37 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 5. THE FERROUS AND/OR FERRIC CHLORIDE INJECTION STATION SHALL BE IN USE TO THE EXTENT NECESSARY TO MAINTAIN THE H2S CONCENTRATION IN THE DIGESTER GAS TO THE PERMITTED LIMIT.

 [RULE 431.1]
- 6. RAW DIGESTER GAS PRODUCED AT THIS FACILITY SHALL NOT BE RELEASED INTO THE ATMOSPHERE, EXCEPT DURING MOMENTARY AUTOMATIC ACTIVATION OF PRESSURE RELIEF SAFETY DEVICES. ALL COLLECTED DIGESTER GAS SHALL BE EITHER COMBUSTED IN DIGESTER GAS FLARES, INTERNAL COMBUSTION ENGINES, OR BOILERS WITH VALID AQMD PERMIT, OR SHALL BE TREATED THROUGH OPTIONAL PASSIVE CARBON ADSORBERS. EACH SUCH PRESSURE RELIEF ACTIVATION SHALL BE MAINTAINED IN A DAILY LOG. [RULE 402, RULE 1401]
- 7. RAW DIGESTER GAS RELEASES DUE TO EQUIPMENT FAILURE SHALL BE REPORTED IN ACCORDANCE WITH RULE 430. UPON DISCOVERY OF SUCH EMISSIONS, IMMEDIATE REMEDIAL MEASURES SHALL BE PUT INTO ACTION TO CORRECT THE PROBLEM AND PREVENT FURTHER EMISSIONS INTO THE ATMOSPHERE.

 [RULE 402, RULE 430]
- 8. THE CALENDAR MONTHLY AVERAGE DAILY PRIMARY EFFLUENT FLOW RATE, TO THE SECONDARY TREATMENT PROCESS, SHALL NOT EXCEED 150 MILLIONS GALLONS PER DAY, EXCEPT DURING WET WEATHER PERIODS AND EMERGENCY PERIODS INVOLVING PUBLIC HEALTH SAFETY. THE RECORDS FOR THE PRIMARY EFFLUENT AVERAGE DAILY FLOW RATE (MGD), TREATED BY THE SECONDARY PROCESS, SHALL BE KEPT ON FILE. [RULE 1303(b) (2) –OFFSETS, 402, 1401]
- 9. THE CALENDAR MONTHLY AVERAGE DAILY FLOW RATE OF WASTEWATER TREATED AT THIS FACILITY SHALL NOT EXCEED 250 MILLION GALLONS PER DAY (MGD) EXCEPT DURING WET WEATHER PERIODS. THE RECORDS FOR THE WASTEWATER FLOW RATE (MGD) MEASURED SHALL BE RECORDED AND KEPT ON FILE.

 [RULE 1303(b) (2) –OFFSETS, 402, 1401]



Section D Page 38
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. G27920 A/N 453244

Equipment Description:

AIR POLLUTION CONTROL SYSTEM, CONSISTING OF;

- 1. FOUL AIR EXHAUST DUCTS FROM THREE (3) TRICKLING FILTERS, TRICKLING FILTER FACILITY'S (JOB NO. P2-90), IN PARALLEL.
- THREE (3) EXHAUST BLOWERS, IN PARALLEL, EACH 11,000 SCFM, 25 H.P.
- 3. THREE (3) CAUSTIC IMPREGNATED ACTIVATED CARBON UNITS, IN PARALLEL, EACH CONTAINING MINIMUM OF 10,600 LBS OF ACTIVATED CARBON BY NORIT AMERICAS OR WESTATES OR EQUIVALENT, EACH VENTING A SINGLE TRICKLING FILTER.
- 4. THREE (3) EXHAUST STACKS, EACH 2.0'- 3" DIA. X 28' HIGH.

- OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATIONS UNDER WHICH THIS PERMIT IS ISSUED.
 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.
 [RULE 204]
- 3. A FLOW METER SHALL BE INSTALLED AND MAINTAINED AT THE INLET STREAM TO EACH OF THE CARBON UNIT TO INDICATE THE TOTAL FOUL AIR EXHAUST FROM THE TRICKLING FILTER TREATED, IN STANDARD CUBIC FEET PER MINUTE (SCFM). IN CASE A PRESSURE SENSOR DEVICE IS USED TO DETERMINE FLOW RATE, IN PLACE OF THE FLOW METER, A CONVERSION CHART SHALL BE MAINTAINED TO INDICATE THE CORRESPONDENT FLOW RATE, IN SCFM, TO THE PRESSURE READING.
 [RULE 204]
- 4. MAXIMUM FOUL AIR EXHAUST FLOW RATE FROM EACH TRICKLING FILTER TO BE TREATED BY EACH CARBON UNIT SHALL NOT EXCEED 11,000 SCFM, AVERAGED OVER CALENDAR MONTH.

 [RULE 204]
- 5. THIS EQUIPMENT SHALL BE OPERATED IN SUCH A MANNER THAT THE PRESSURE ACROSS THE CARBON BED IS LESS THAN 6.0 INCHES WATER COLUMN. TO COMPLY WITH THIS CONDITION THE OPERATOR SHALL INSTALL AND MAINTAIN A DIFFERENTIAL PRESSURE GAUGE TO ACCURATELY INDICATE THE DIFFERENTIAL PRESSURE ACROSS THE CARBON BED. THE OPERATOR SHALL DETERMINE AND RECORD THE PARAMETER BEING MONITORED ONCE EVERY WEEK.

 [RULE 204]



Section D Page 39
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 6. WHENEVER THE CARBON UNIT IS IN OPERATION THE HYDROGEN SULFIDE (H2S)
 CONCENTRATION IN THE EXHAUST SHALL BE MONITORED USING AN AUTOMATIC H2S
 MONITORING DEVICE OR MEASURED MANUALLY AT LEAST ONCE A WEEK USING AN
 APPROVED AND CALIBRATED INSTRUMENT. H2S MEASUREMENT READINGS SHALL BE
 RECORDED AND MAINTAINED ON FILE.
 [RULE 402, 1401]
- 7. CONCENTRATIONS MEASURED AT THE OUTLET OF THE CARBON ADSORBER SHALL NOT EXCEED THE FOLLOWING:

CONSTITUENT

CONCENTRATION, IN PPMV (DAILY AVG.)

H₂S

[RULE 402, 1401]

1.0

- 8. WHENEVER THE DAILY AVERAGE HYDROGEN SULFIDE (H2S) CONCENTRATION IS 0.9 PPMV OR HIGHER, THEN OPERATOR SHALL INVESTIGATE THE CAUSE AND TAKE IMMEDIATE CORRECTIVE MEASURES THAT MAY INCLUDE FRESH ACTIVATED CARBON REPLACEMENT AS PER MANUFACTURER'S RECOMMENDATIONS AND SPECIFICATIONS. THE OPERATOR SHALL RECORD THE DATE AND QUANTITY OF CARBON AT EACH REPLACEMENT EVENT, THE RESULTS OF THE INVESTIGATION AND CORRECTIVE MEASURES TAKEN.

 [RULE 204]
- 9. SPENT CARBON REMOVED FROM THIS SYSTEM SHALL BE MAINTAINED OR STORED IN CLOSED CONTAINERS PRIOR TO REMOVAL FROM SITE.
 [RULE 402]
- 10. RECORDS SHALL BE MAINTAINED AS REQUIRED BY THIS PERMIT FOR COMPLIANCE. THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
 [RULE 204]

Section D Page 40 Facility I.D. #: 29110 Revision #: 07

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. R-F81554 A/N 455670

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, 16 CYLINDER, TURBOCHARGED, AFTERCOOLED, MODEL T1637M36 (2936 BHP), SERIAL NO. 527200-2104, 2936 BHP, DIESEL FUEL-FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

- OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA 1. AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW. [RULE 204]
- 2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES. [RULE 204]
- THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH 3. INCLUDES NOT MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES. [RULE 1304(a), RULE 1110.2, RULE 1470]
- THE OPERATION OF ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE 4. MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT. [RULE 1304 (a) (1)-BACT, RULE 1470]
- AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND 5. MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME. [RULE 1304(a), RULE 1110.2, RULE 1470]
- THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING 6. INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR. [RULE 1303 (a) (1)-BACT, RULE 1470]



Section D Page 41 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - **B. MAINTENANCE AND TESTING HOURS**
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR. [RULE 1304(A), RULE 1110.2, RULE 1470]

8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

THIS PERMIT TO OPERATE R-F81554 SUPERSEDES PERMIT TO OPERATE F81554 ISSUED 6/14/2007.

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS.

PM: RULE 1470.

Section D Page 42 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. R-F81555 A/N 455671

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, 16 CYLINDER, TURBOCHARGED, AFTERCOOLED, MODEL T1637M36 (2936 BHP), SERIAL NO. 527200-2105, 2936 BHP, DIESEL FUEL-FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 4. THE OPERATION OF ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.

 [RULE 1304 (a) (1)-BACT, RULE 1470]
- 5. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.

 [RULE 1303 (a) (1)-BACT, RULE 1470]

Section D Page 43 Facility I.D. #: 29110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR. [RULE 1304(A), RULE 1110.2, RULE 1470]

8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND [RULE 431.2, RULE 1470]

Emissions And Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES 9. AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS.

PM: **RULE 1470.**

THIS PERMIT TO OPERATE R-F81555 SUPERSEDES PERMIT TO OPERATE F81555 ISSUED 4/12/2006.

Section D Page 44
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. R-F81556 A/N 455673

Equipment Description:

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, 16 CYLINDER, TURBOCHARGED, AFTERCOOLED, MODEL T1637M36 (2936 BHP), SERIAL NO. 527200-2106, 2936 BHP, DIESEL FUEL-FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 4. THE OPERATION OF ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.

 [RULE 1304 (a) (1)-BACT, RULE 1470]
- 5. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.

 [RULE 1303 (a) (1)-BACT, RULE 1470]

Section D Page 45
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - **B. MAINTENANCE AND TESTING HOURS**
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR. [RULE 1304(A), RULE 1110.2, RULE 1470]

8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS.

PM: RULE 1470.

THIS PERMIT TO OPERATE R-F81556 SUPERSEDES PERMIT TO OPERATE F81556 ISSUED 04/12/2006.

Section D Page 46 Facility I.D. #: 29110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. G24634 A/N 457410

Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF;

- FOUL AIR EXHAUST DUCTS FROM TWO (2) SLUDGE BLENDING TANKS (ONE STAND-BY), IN 1. PARALLEL.
- 2. TWO (2) EXHAUST BLOWERS (ONE STAND-BY), IN PARALLEL, EACH 400 CFM, 1.5 H.P.
- TWO (2) ADSORBERS (ONE STAND-BY), IN PARALLEL, CARBTROL CORPORATION, MODEL GC-21 3. SP, EACH CONTAINING MINIMUM OF 200 LBS OF GRANULAR ACTIVATED CARBON.
- TWO (2) EXHAUST STACKS (ONE STAND-BY), EACH 0'- 6" DIA. X 8' HIGH. 4.

Conditions:

- OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA 1. AND SPECIFICATIONS SUBMITTED WITH THE APPLICATIONS UNDER WHICH THIS PERMIT IS ISSUED. [RULE 204]
- THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING 2. CONDITIONS AT ALL TIMES. [RULE 204]
- THE OPERATOR SHALL INSTALL AND MAINTAIN DIFFERENTIAL PRESSURE GAUGES TO 3. ACCURATELY INDICATE THE DIFFERENTIAL PRESSURE ACROSS EACH CARBON BED AND EACH EXHAUST BLOWER. [RULE 402]
- ONCE A MONTH, DIFFERENTIAL PRESSURE DROP ACROSS THE BLOWER AND THE ADSORBER 4. SHALL ME MEASURED, IN INCHES OF WATER COLUMN, AND SHALL BE MAINTAINED AS FOLLOWS;

DIFFERENTIAL PRESSURE DROP (INCHES OF WATER COLUMN)

BLOWER ADSORBER [RULE 204]

8.0 - 11.06.5 - 8.5



Section D Page 47
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 5. HYDROGEN SULFIDE (H2S) CONCENTRATION (PPMV) IN THE EXHAUST SHALL BE CONTINUOUSLY MONITORED OR MEASURED MANUALLY AND RECORDED AT LEAST ONCE A DAY USING A DISTRICT APPROVED DEVICE.
 [RULE 204]
- 6. THE HYDROGEN SULFIDE (H2S) CONCENTRATION IN THE EXHAUST SHALL NOT EXCEED I PPMV.
 [RULE 402, 1401]
- 7. IF THE AVERAGE HYDROGEN SULFIDE (H2S) CONCENTRATION IS DETECTED 0.9 PPMV OR HIGHER, THE CARBON SHALL BE REPLACED AS PER MANUFACTURER'S RECOMMENDATIONS AND SPECIFICATIONS.

 [RULE 402]
- 8. SPENT CARBON REMOVED FROM THIS SYSTEM SHALL BE MAINTAINED OR STORED IN CLOSED CONTAINERS PRIOR TO REMOVAL FROM SITE.
 [RULE 402]
- 9. RECORDS SHALL BE MAINTAINED AS REQUIRED BY THIS PERMIT INCLUDING CARBON CHANGE OVER DATE(S) FOR COMPLIANCE. THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.

 [RULE 204]



Section D Page 48
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. F95584 A/N 474766

Equipment Description:

INTERNAL COMBUSTION ENGINE, NO. 2, AT PB-C, CATERPILLAR, COMPRESSION-IGNITION, FOUR STROKE, TURBOCHARGED-AFTERCOOLED, V-12 TYPE, MODEL NO. 3512, SERIAL NUMBER 24Z01547, 1482 HP, DIESEL OIL-FIRED, DRIVING A 1000 KW EMERGENCY ELECTRICAL GENERATOR.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 5. THE OPERATION OF ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.

 [RULE 1304 (a) (1)-BACT, RULE 1470]
- 6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.

 [RULE 1303 (a) (1)-BACT, RULE 1470]

Section D Page 49
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - **B. MAINTENANCE AND TESTING HOURS**
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.
[RULE 1304(A), RULE 1110.2, RULE 1470]

8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS.

PM: RULE 1470.



Section D Page 50 Facility I.D. #: 29110 Revision #: 07

Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. F95585 A/N 474767

Equipment Description:

INTERNAL COMBUSTION ENGINE, NO. 1, AT PB-C, CATERPILLAR, COMPRESSION-IGNITION, FOUR STROKE, TURBOCHARGED-AFTERCOOLED, V-12 TYPE, MODEL NO. 3512, SERIAL NUMBER 24Z01541, 1482 HP, DIESEL OIL-FIRED, DRIVING A 1000 KW EMERGENCY ELECTRICAL GENERATOR.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 5. THE OPERATION OF ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.

 [RULE 1304 (a) (1)-BACT, RULE 1470]
- 6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.

 [RULE 1303 (a) (1)-BACT, RULE 1470]

Section D Page 51 Facility I.D. #: 29110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - **B. MAINTENANCE AND TESTING HOURS**
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR. [RULE 1304(A), RULE 1110.2, RULE 1470]

THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 8. 1470. [RULE 431.2, RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

RULE 404, SEE APPENDIX B FOR EMISSION LIMITS. PM:

PM: **RULE 1470.**



Section D Page 52 Facility I.D. #: 29110 Revision #: 07

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. F95586 A/N 474768

Equipment Description:

INTERNAL COMBUSTION ENGINE, NO. 1, AT PB-D, CATERPILLAR, COMPRESSION-IGNITION, FOUR STROKE, TURBOCHARGED-AFTERCOOLED, V-12 TYPE, MODEL NO. 3512, SERIAL NUMBER 24Z01544, 1482 HP, DIESEL OIL-FIRED, DRIVING A 1000 KW EMERGENCY ELECTRICAL GENERATOR.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 5. THE OPERATION OF ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.

 [RULE 1304 (a) (1)-BACT, RULE 1470]
- 6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.

 [RULE 1303 (a) (1)-BACT, RULE 1470]

Section D Page 53 Facility I.D. #: 29110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - B. MAINTENANCE AND TESTING HOURS
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR. [RULE 1304(A), RULE 1110.2, RULE 1470]

THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 8. 1470. [RULE 431.2, RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS.

PM: **RULE 1470.**



Section D Page 54
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. F95587 A/N 474769

Equipment Description:

INTERNAL COMBUSTION ENGINE, NO. 2, AT PB-B, DETROIT DIESEL, 16 CYLINDER, TURBOCHARGED, AFTERCOOLED, MODEL T163-7K16, 2935 BHP, SERIAL NUMBER DD5272000531, DIESEL - FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.

 [RULE 204]
- 3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 5. THE OPERATION OF ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.

 [RULE 1304 (a) (1)-BACT, RULE 1470]
- 6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.

 [RULE 1303 (a) (1)-BACT, RULE 1470]



Section D Page 55 Facility I.D. #: 29110 Revision #: 07

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - **B. MAINTENANCE AND TESTING HOURS**
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR. [RULE 1304(A), RULE 1110.2, RULE 1470]

8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS.

PM: RULE 1470.



Section D Page 56
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. F95588 A/N 474770

Equipment Description:

INTERNAL COMBUSTION ENGINE, NO. 1, AT PB-B, DETROIT DIESEL, 16 CYLINDER, TURBOCHARGED, AFTERCOOLED, MODEL T163-7K16, 2935 BHP, SERIAL NUMBER DD5272000532, DIESEL - FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.

 [RULE 204]
- 3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NOT MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.

 [RULE 1304(a), RULE 1110.2, RULE 1470]
- 5. THE OPERATION OF ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.

 [RULE 1304 (a) (1)-BACT, RULE 1470]
- 6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR.

 [RULE 1303 (a) (1)-BACT, RULE 1470]

Section D Page 57 Facility I.D. #: 29110 Revision #: 07

Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
 - A. EMERGENCY USE HOURS OF OPERATION
 - **B. MAINTENANCE AND TESTING HOURS**
 - C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR. [RULE 1304(A), RULE 1110.2, RULE 1470]

8. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.
[RULE 431.2, RULE 1470]

Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS.

PM: RULE 1470.

Section D Page 58
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT/OPERATE

Permit No. G12233 A/N 512604

Equipment Description:

STORAGE TANK, VERTICAL FIXED ROOF, ID NO. 20GTNK500, HYDROCHLORIC ACID, 10' - 0" DIA. X 17' - 0" H., 10,000- GALLON CAPACITY, AND VENTING THROUGH A SPARGER TANK, 370 GALLON CAPACITY, CONTAINING WATER.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS PERMIT SHALL EXPIRE IF CONSTRUCTION OF THIS EQUIPMENT IS NOT COMPLETED WITHIN ONE YEAR FROM MARCH 3, 2011 UNLESS AN EXTENSION IS GRANTED BY THE EXECUTIVE OFFICER.

 [RULE 205]
- 4. THIS EQUIPMENT SHALL STORE HYDROCHLORIC ACID WITH CONCENTRATION OF 38 WEIGHT PERCENT OR LESS ONLY.
 [RULE 204]
- 5. THE MAXIMUM AMOUNT OF HYDROCHLORIC ACID FILLED INTO THIS STORAGE TANK SHALL NOT EXCEED 10,000 GALLONS PER MONTH.
 [RULE 1303 (b) (1) OFFSET]
- 6. THE OPERATOR SHALL NOT OPERATE THIS TANK UNLESS VENT GASES ARE SPARGED AT LEAST 10 INCHES BELOW THE LIQUID SURFACE OF A TRAP CONTAINING AT LEAST 190 GALLONS OF WATER.

 [RULE 1303 (a) (1)-BACT]
- 7. THE SPARGER TANK SHALL BE FILLED WITH FRESH WATER PRIOR TO EACH ACID TANK FILLING EVENT.
 [RULE 204]
- 8. RECORDS REQUIRED BY THIS PERMIT SHALL BE KEPT AND MAINTAINED FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
 [RULE 204]



Section D Page 59
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. G12234 A/N 512832

Equipment Description:

STORAGE TANK, FIXED ROOF, ID NO. 211TNK076 (P2 NSC), HYDROCHLORIC ACID, 8' - 0" DIA. X 13' - 0" H., 4,000- GALLON CAPACITY AND VENTING PASSIVELY THROUGH A 55-GALLON DRUM CONTAINING (50% SULPHASORB XL AND 50% SAFETYSORB BLEND OR EQUAL) ACTIVATED CARBON.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- THIS EQUIPMENT SHALL STORE HYDROCHLORIC ACID WITH CONCENTRATION OF 38 WEIGHT PERCENT OR LESS ONLY.

 [RULE 204]
- 4. THE MAXIMUM AMOUNT OF HYDROCHLORIC ACID FILLED INTO THIS STORAGE TANK SHALL NOT EXCEED 2,000 GALLONS PER MONTH.
 [RULE 1303 (b) (1) OFFSET]
- 5. THIS EQUIPMENT SHALL NOT BE FILLED UNLESS THE VENT GASES PASS THROUGH A 55-GALLON DRUM CONTAINING ACTIVATED CARBON.
 [RULE 1303 (a) (1)-BACT]
- 6. THE OPERATOR SHALL REPLACE THE CARBON PER MANUFACTURER'S RECOMMENDATION. [RULE 204]
- 7. RECORDS REQUIRED BY THIS PERMIT SHALL BE KEPT AND MAINTAINED FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.

 [RULE 204]



Section D Page 60 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. G12235 A/N 512833

Equipment Description:

STORAGE TANK, FIXED ROOF, ID NO. 201TNK450 (P2 SSC), HYDROCHLORIC ACID, 7' - 0" DIA. X 10' - 0" H., 2,000- GALLON CAPACITY AND VENTING PASSIVELY THROUGH A 55-GALLON DRUM CONTAINING (50% SULPHASORB XL AND 50% SAFETYSORB BLEND OR EQUAL) ACTIVATED CARBON.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS EQUIPMENT SHALL STORE HYDROCHLORIC ACID WITH CONCENTRATION OF 38 WEIGHT PERCENT OR LESS ONLY.
 [RULE 204]
- 4. THE MAXIMUM AMOUNT OF HYDROCHLORIC ACID FILLED INTO THIS STORAGE TANK SHALL NOT EXCEED 2000 GALLONS PER MONTH.

 [RULE 1303 (b) (1) OFFSET]
- 5. THIS EQUIPMENT SHALL NOT BE FILLED UNLESS THE VENT GASES PASS THROUGH A 55-GALLON DRUM CONTAINING ACTIVATED CARBON.
 [RULE 1303 (a) (1)-BACT]
- 6. THE OPERATOR SHALL REPLACE THE CARBON PER MANUFACTURER'S RECOMMENDATION. [RULE 204]
- 7. RECORDS REQUIRED BY THIS PERMIT SHALL BE KEPT AND MAINTAINED FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.

 [RULE 204]



Section D Page 61 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. G27394 A/N 540708

Equipment Description:

RESOURCE RECOVERY SYSTEM NO. 1 CONSISTING OF:

INTERNAL COMBUSTION ENGINE (CG1-HB), COOPER BESSMER, SPARK IGNITION, FOUR STROKE, WITH A MODIFIED TURBOCHARGED-INTERCOOLED V-16 TYPE, MODEL NO. LSVB-16-SGC, 4166 HP, NATURAL GAS AND/OR DIGESTER GAS FIRED, DRIVING A 3000 KW ELECTRIC GENERATOR, WITH AN EXHAUST HEAT RECOVERY STEAM GENERATOR, 6,010,200 BTU/HR CAPACITY, UNFIRED.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION. [RULE 204]
- 4. THIS ENGINE SHALL HAVE AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER TO DETERMINE THE ENGINE ELAPSED OPERATING TIME FOR EACH FUEL BLEND BURNED.
 [RULE 1110.2]
- 5. A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE FUEL GAS, OR FUEL BLEND, SUPPLY LINE TO THE ENGINE TO MEASURE AND RECORD THE QUANTITY OF EACH FUEL GAS (IN SCFM) BURNED.

 [RULE 204]
- 6. SAMPLING PORT SHALL BE INSTALLED FOR THE INLET GAS LINE TO THE ENGINE TO ALLOW THE COLLECTION OF A FUEL GAS OR FUEL BLEND SAMPLES.
 [RULE 204]
- 7. MONTHLY READINGS OF THE BTU CONTENT OF FUEL GAS (BTU/SCF) AT THE COMBINED INLET TO THE CGS ENGINES SHALL BE TAKEN USING AN INSTRUMENT APPROVED BY THE SCAQMD. ALL RESULTS SHALL BE RECORDED.

 [RULE 204]
- 8. ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF THE DAY. [RULE 204]



Section D Page 62
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 9. THE TOTAL HEAT INPUT OF GASEOUS FUEL, OR FUEL BLEND, BURNED IN THIS ENGINE SHALL NOT EXCEED 33 MM BTU PER HOUR. A LOG SHALL BE KEPT INDICATING THE TOTAL HEATING VALUE OF FUEL GAS, OR FUEL BLEND, BURNED IN THIS ENGINE BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING.
 [RULE 1303 (b) (1) AND 1303 (b) (2)-MODELING AND EMISSIONS OFFSET]
- 10. THIS EQUIPMENT SHALL BE OPERATED IN COMPLIANCE WITH RULES 218, 431.1 AND 1110.2. [RULE 218, 431.1 AND 1110.2]
- 11. THIS EQUIPMENT SHALL BE OPERATED IN SUCH A MANNER THAT THE FOLLOWING EMISSION RATES ARE NOT EXCEEDED.

AIR CONTAMINANT

CARBON MONOXIDE 600 PPMV AT 15% O2
PARTICULATES (PM10) 0.0058 GRAINS/ DSCF
ROG OR TNMHC (AS CARBON) 115 PPMV AT 15% O2

[RULE 1303 (a) (1), 1303(b) (1) AND 1303 (b) (2)-BACT, MODELING AND EMISSIONS OFFSET]

12. THE COMBINED EMISSIONS FROM THE FOUR (4) CGS ENGINES, USING CALENDAR MONTHLY EMISSIONS DIVIDED BY 30, SHALL NOT EXCEED THE FOLLOWING:

AIR CONTAMINANT	LBS/DAY
CARBON MONOXIDE	2,644
NITROGEN OXIDES (AS NO2)	828
PARTICULATES (PM10)	72
ROG OR TNMHC (AS CH4)	372
SULFUR DIOXIDE	84
[RULE 1303 (b) (2)-EMISSIONS OFFS	SET]

- 13. THE OPERATOR SHALL INSTALL AND MAINTAIN A CONTINUOUS EMISSION MONITORING SYSTEM (CEMS), OR AN ALTERNATIVE SYSTEM, AS APPROVED BY THE EXECUTIVE OFFICER, TO MEASURE THE ENGINE EXHAUST FOR NOX AND O2 CONCENTRATIONS ON A DRY BASIS, EXCEPT DURING SHUTDOWN FOR MAINTENANCE OF THE SYSTEM. IN ADDITION, THE CEMS SHALL CONVERT THE ACTUAL NOX TO MASS EMISSION RATES; AND RECORD THE ACTUAL AND CORRECTED ENGINE NOX CONCENTRATION AT 15% O2 AND MASS EMISSION RATES ON AN HOURLY AND DAILY BASIS.

 [RULE 218, RULE 1110.2]
- 14. THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS ANNUALLY. WRITTEN NOTICE OF THE PERFORMANCE TEST SHALL BE PROVIDED TO THE AQMD AT LEAST 7 DAYS PRIOR TO THE TEST SO THAT AN OBSERVER MAY BE PRESENT. A COMPLETE FINAL REPORT OF THE TEST (LBS/HR, PPMVD AT 15% O2, LBS/MMBTU, ETC.) SHALL BE PROVIDED TO THE AQMD WITHIN 45 DAYS AFTER TESTING. ALL TEST RUNS REQUIRED BY AQMD SHALL BE REPORTED. THE TESTS SHALL INCLUDE BUT NOT BE LIMITED TO, A TEST OF THE FUELS BURNED AND ENGINE EXHAUST FOR:
 - A. TOTAL NON-METHANE HYDROCARBONS (EXHAUST ONLY)
 - B. CARBON MONOXIDE (EXHAUST ONLY)
 - C. TOTAL PARTICULATE MATTER (EXHAUST ONLY).
 - D. OXIDES OF NITROGEN (EXHAUST ONLY).



Section D Page 63 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- E. OXYGEN
- F. FLOW RATE
- G. MOISTURE
- H. TOXIC AIR CONTAMINANTS (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
- I. ALDEHYDES (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
- J. TOTAL REDUCED SULFUR COMPOUNDS (FUEL ONLY)
- K. NITROGEN AND CARBON DIOXIDE
- L. BTU CONTENTS (FUEL ONLY)
- M. POWER OUTPUT

[RULE 1303(b) (1) AND 1303(b) (2) - MODELING AND EMISSION OFFSET], [RULE 1110.2], [RULE 404]

15 RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.

[RULE 204]

Emissions And Requirements:

16. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 1110.2

NOx: 45.4 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26) ROG: 315 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26)

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS.



Section D Page 64
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. G27395 A/N 540709

Equipment Description:

RESOURCE RECOVERY SYSTEM NO. 2 CONSISTING OF:

INTERNAL COMBUSTION ENGINE (CG2-HB), COOPER BESSMER, SPARK IGNITION, FOUR STROKE, WITH A MODIFIED TURBOCHARGED-INTERCOOLED V-16 TYPE, MODEL NO. LSVB-16-SGC, 4166 HP, NATURAL GAS AND/OR DIGESTER GAS FIRED, DRIVING A 3000 KW ELECTRIC GENERATOR, WITH AN EXHAUST HEAT RECOVERY STEAM GENERATOR, 6,010,200 BTU/HR CAPACITY, UNFIRED.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION. [RULE 204]
- 4. THIS ENGINE SHALL HAVE AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER TO DETERMINE THE ENGINE ELAPSED OPERATING TIME FOR EACH FUEL BLEND BURNED. [RULE 1110.2]
- 5. A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE FUEL GAS, OR FUEL BLEND, SUPPLY LINE TO THE ENGINE TO MEASURE AND RECORD THE QUANTITY OF EACH FUEL GAS (IN SCFM) BURNED.
 [RULE 204]
- 6. SAMPLING PORT SHALL BE INSTALLED FOR THE INLET GAS LINE TO THE ENGINE TO ALLOW THE COLLECTION OF A FUEL GAS OR FUEL BLEND SAMPLES.
 [RULE 204]
- 7. MONTHLY READINGS OF THE BTU CONTENT OF FUEL GAS (BTU/SCF) AT THE COMBINED INLET TO THE CGS ENGINES SHALL BE TAKEN USING AN INSTRUMENT APPROVED BY THE SCAQMD. ALL RESULTS SHALL BE RECORDED.
 [RULE 204]
- 8. ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF THE DAY. [RULE 204]



Section D Page 65
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 9. THE TOTAL HEAT INPUT OF GASEOUS FUEL, OR FUEL BLEND, BURNED IN THIS ENGINE SHALL NOT EXCEED 33 MM BTU PER HOUR. A LOG SHALL BE KEPT INDICATING THE TOTAL HEATING VALUE OF FUEL GAS, OR FUEL BLEND, BURNED IN THIS ENGINE BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING.
 [RULE 1303 (b) (1) AND 1303 (b) (2)-MODELING AND EMISSIONS OFFSET]
- 10. THIS EQUIPMENT SHALL BE OPERATED IN COMPLIANCE WITH RULES 218, 431.1 AND 1110.2. [RULE 218, 431.1 AND 1110.2]
- 11. THIS EQUIPMENT SHALL BE OPERATED IN SUCH A MANNER THAT THE FOLLOWING EMISSION RATES ARE NOT EXCEEDED.

AIR CONTAMINANT

CARBON MONOXIDE 600 PPMV AT 15% O2
PARTICULATES (PM10) 0.0058 GRAINS/ DSCF
ROG OR TNMHC (AS CARBON) 115 PPMV AT 15% O2
[RULE 1303 (a) (1), 1303(b) (1) AND 1303 (b) (2)-BACT, MODELING AND EMISSIONS OFFSET]

12. THE COMBINED EMISSIONS FROM THE FOUR (4) CGS ENGINES, USING CALENDAR MONTHLY EMISSIONS DIVIDED BY 30, SHALL NOT EXCEED THE FOLLOWING:

AIR CONTAMINANT	LBS/DAY
CARBON MONOXIDE	2,644
NITROGEN OXIDES (AS NO2)	828
PARTICULATES (PM10)	72
ROG OR TNMHC (AS CH4)	372
SULFUR DIOXIDE	84
[RULE 1303 (b) (2)-EMISSIONS OFFS	SET)

- 13. THE OPERATOR SHALL INSTALL AND MAINTAIN A CONTINUOUS EMISSION MONITORING SYSTEM (CEMS), OR AN ALTERNATIVE SYSTEM, AS APPROVED BY THE EXECUTIVE OFFICER, TO MEASURE THE ENGINE EXHAUST FOR NOx AND O2 CONCENTRATIONS ON A DRY BASIS, EXCEPT DURING SHUTDOWN FOR MAINTENANCE OF THE SYSTEM. IN ADDITION, THE CEMS SHALL CONVERT THE ACTUAL NOx TO MASS EMISSION RATES; AND RECORD THE ACTUAL AND CORRECTED ENGINE NOX CONCENTRATION AT 15% O2 AND MASS EMISSION RATES ON AN HOURLY AND DAILY BASIS.

 [RULE 218, RULE 1110.2]
- 14. THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS ANNUALLY. WRITTEN NOTICE OF THE PERFORMANCE TEST SHALL BE PROVIDED TO THE AQMD AT LEAST 7 DAYS PRIOR TO THE TEST SO THAT AN OBSERVER MAY BE PRESENT. A COMPLETE FINAL REPORT OF THE TEST (LBS/HR, PPMVD AT 15% O2, LBS/MMBTU, ETC.) SHALL BE PROVIDED TO THE AQMD WITHIN 45 DAYS AFTER TESTING. ALL TEST RUNS REQUIRED BY AQMD SHALL BE REPORTED. THE TESTS SHALL INCLUDE BUT NOT BE LIMITED TO, A TEST OF THE FUELS BURNED AND ENGINE EXHAUST FOR:
 - A. TOTAL NON-METHANE HYDROCARBONS (EXHAUST ONLY)
 - B. CARBON MONOXIDE (EXHAUST ONLY)
 - C. TOTAL PARTICULATE MATTER (EXHAUST ONLY).
 - D. OXIDES OF NITROGEN (EXHAUST ONLY).



Section D Page 66
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- E. OXYGEN
- F. FLOW RATE
- G. MOISTURE
- H. TOXIC AIR CONTAMINANTS (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
- 1. ALDEHYDES (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
- J. TOTAL REDUCED SULFUR COMPOUNDS (FUEL ONLY)
- K. NITROGEN AND CARBON DIOXIDE
- L. BTU CONTENTS (FUEL ONLY)
- M. POWER OUTPUT

[RULE 1303(b) (1) AND 1303(b) (2) - MODELING AND EMISSION OFFSET], [RULE 1110.2], [RULE 404]

15 RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 204]

Emissions And Requirements:

16. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 1110.2

NOx: 45.4 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26) ROG: 315 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26).

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



Section D Page 67 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. G27396 A/N 540710

Equipment Description:

RESOURCE RECOVERY SYSTEM NO. 3 CONSISTING OF:

INTERNAL COMBUSTION ENGINE (CG3-HB), COOPER BESSMER, SPARK IGNITION, FOUR STROKE, WITH A MODIFIED TURBOCHARGED-INTERCOOLED V-16 TYPE, MODEL NO. LSVB-16-SGC, 4166 HP, NATURAL GAS AND/OR DIGESTER GAS FIRED, DRIVING A 3000 KW ELECTRIC GENERATOR, WITH AN EXHAUST HEAT RECOVERY STEAM GENERATOR, 6,010,200 BTU/HR CAPACITY, UNFIRED.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION. [RULE 204]
- 4. THIS ENGINE SHALL HAVE AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER TO DETERMINE THE ENGINE ELAPSED OPERATING TIME FOR EACH FUEL BLEND BURNED. [RULE 1110.2]
- 5. A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE FUEL GAS, OR FUEL BLEND, SUPPLY LINE TO THE ENGINE TO MEASURE AND RECORD THE QUANTITY OF EACH FUEL GAS (IN SCFM) BURNED.
 [RULE 204]
- 6. SAMPLING PORT SHALL BE INSTALLED FOR THE INLET GAS LINE TO THE ENGINE TO ALLOW THE COLLECTION OF A FUEL GAS OR FUEL BLEND SAMPLES.
 [RULE 204]
- 7. MONTHLY READINGS OF THE BTU CONTENT OF FUEL GAS (BTU/SCF) AT THE COMBINED INLET TO THE CGS ENGINES SHALL BE TAKEN USING AN INSTRUMENT APPROVED BY THE SCAQMD. ALL RESULTS SHALL BE RECORDED.

 [RULE 204]
- 8. ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF THE DAY. [RULE 204]



Section D Page 68
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 9. THE TOTAL HEAT INPUT OF GASEOUS FUEL, OR FUEL BLEND, BURNED IN THIS ENGINE SHALL NOT EXCEED 33 MM BTU PER HOUR. A LOG SHALL BE KEPT INDICATING THE TOTAL HEATING VALUE OF FUEL GAS, OR FUEL BLEND, BURNED IN THIS ENGINE BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING.
 [RULE 1303 (b) (1) AND 1303 (b) (2)-MODELING AND EMISSIONS OFFSET]
- 10. THIS EQUIPMENT SHALL BE OPERATED IN COMPLIANCE WITH RULES 218, 431.1 AND 1110.2. [RULE 218, 431.1 AND 1110.2]
- 11. THIS EQUIPMENT SHALL BE OPERATED IN SUCH A MANNER THAT THE FOLLOWING EMISSION RATES ARE NOT EXCEEDED.

AIR CONTAMINANT

CARBON MONOXIDE PARTICULATES (PM10)

600 PPMV AT 15% O2

0.0058 GRAINS/ DSCF

ROG OR TNMHC (AS CARBON)

115 PPMV AT 15% O2

[RULE 1303 (a) (1), 1303(b) (1) AND 1303 (b) (2)-BACT, MODELING AND EMISSIONS OFFSET]

12. THE COMBINED EMISSIONS FROM THE FOUR (4) CGS ENGINES, USING CALENDAR MONTHLY EMISSIONS DIVIDED BY 30, SHALL NOT EXCEED THE FOLLOWING:

AIR CONTAMINANT	LBS/DAY
CARBON MONOXIDE	2,644
NITROGEN OXIDES (AS NO2)	828
PARTICULATES (PM10)	72
ROG OR TNMHC (AS CH4)	372
SULFUR DIOXIDE	84
[RULE 1303 (b) (2)-EMISSIONS OFFSET]	

- 13. THE OPERATOR SHALL INSTALL AND MAINTAIN A CONTINUOUS EMISSION MONITORING SYSTEM (CEMS), OR AN ALTERNATIVE SYSTEM, AS APPROVED BY THE EXECUTIVE OFFICER, TO MEASURE THE ENGINE EXHAUST FOR NOx AND O2 CONCENTRATIONS ON A DRY BASIS, EXCEPT DURING SHUTDOWN FOR MAINTENANCE OF THE SYSTEM. IN ADDITION, THE CEMS SHALL CONVERT THE ACTUAL NOx TO MASS EMISSION RATES; AND RECORD THE ACTUAL AND CORRECTED ENGINE NOx CONCENTRATION AT 15% O2 AND MASS EMISSION RATES ON AN HOURLY AND DAILY BASIS.

 [RULE 218, RULE 1110.2]
- 14. THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS ANNUALLY. WRITTEN NOTICE OF THE PERFORMANCE TEST SHALL BE PROVIDED TO THE AQMD AT LEAST 7 DAYS PRIOR TO THE TEST SO THAT AN OBSERVER MAY BE PRESENT. A COMPLETE FINAL REPORT OF THE TEST (LBS/HR, PPMVD AT 15% O2, LBS/MMBTU, ETC.) SHALL BE PROVIDED TO THE AQMD WITHIN 45 DAYS AFTER TESTING. ALL TEST RUNS REQUIRED BY AQMD SHALL BE REPORTED. THE TESTS SHALL INCLUDE BUT NOT BE LIMITED TO, A TEST OF THE FUELS BURNED AND ENGINE EXHAUST FOR:
 - A. TOTAL NON-METHANE HYDROCARBONS (EXHAUST ONLY)
 - B. CARBON MONOXIDE (EXHAUST ONLY)
 - C. TOTAL PARTICULATE MATTER (EXHAUST ONLY).
 - D. OXIDES OF NITROGEN (EXHAUST ONLY).



Section D Page 69
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- E. OXYGEN
- F. FLOW RATE
- G. MOISTURE
- H. TOXIC AIR CONTAMINANTS (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
- I. ALDEHYDES (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
- J. TOTAL REDUCED SULFUR COMPOUNDS (FUEL ONLY)
- K. NITROGEN AND CARBON DIOXIDE
- L. BTU CONTENTS (FUEL ONLY)
- M. POWER OUTPUT

[RULE 1303(b) (1) AND 1303(b) (2) - MODELING AND EMISSION OFFSET], [RULE 1110.2], [RULE 404]

15 RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.

[RULE 204]

Emissions And Requirements:

16. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 1110.2

NOx: 45.4 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26) ROG: 315 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26)

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



Section D Page 70 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. G27397 A/N 540711

Equipment Description:

RESOURCE RECOVERY SYSTEM NO. 4 CONSISTING OF:

INTERNAL COMBUSTION ENGINE (CG4-HB), COOPER BESSMER, SPARK IGNITION, FOUR STROKE, WITH A MODIFIED TURBOCHARGED-INTERCOOLED V-16 TYPE, MODEL NO. LSVB-16-SGC, 4166 HP, NATURAL GAS AND/OR DIGESTER GAS FIRED, DRIVING A 3000 KW ELECTRIC GENERATOR, WITH AN EXHAUST HEAT RECOVERY STEAM GENERATOR, 6,010,200 BTU/HR CAPACITY, UNFIRED.

- OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW. [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION. [RULE 204]
- 4. THIS ENGINE SHALL HAVE AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER TO DETERMINE THE ENGINE ELAPSED OPERATING TIME FOR EACH FUEL BLEND BURNED. [RULE 1110.2]
- 5. A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE FUEL GAS, OR FUEL BLEND, SUPPLY LINE TO THE ENGINE TO MEASURE AND RECORD THE QUANTITY OF EACH FUEL GAS (IN SCFM) BURNED.
 [RULE 204]
- 6. SAMPLING PORT SHALL BE INSTALLED FOR THE INLET GAS LINE TO THE ENGINE TO ALLOW THE COLLECTION OF A FUEL GAS OR FUEL BLEND SAMPLES.
 [RULE 204]
- 7. MONTHLY READINGS OF THE BTU CONTENT OF FUEL GAS (BTU/SCF) AT THE COMBINED INLET TO THE CGS ENGINES SHALL BE TAKEN USING AN INSTRUMENT APPROVED BY THE SCAQMD. ALL RESULTS SHALL BE RECORDED.
 [RULE 204]
- 8. ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF THE DAY. [RULE 204]



Section D Page 71 Facility I.D. #: 29110 Revision #: Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 9. THE TOTAL HEAT INPUT OF GASEOUS FUEL, OR FUEL BLEND, BURNED IN THIS ENGINE SHALL NOT EXCEED 33 MM BTU PER HOUR. A LOG SHALL BE KEPT INDICATING THE TOTAL HEATING VALUE OF FUEL GAS, OR FUEL BLEND, BURNED IN THIS ENGINE BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING. [RULE 1303 (b) (1) AND 1303 (b) (2)-MODELING AND EMISSIONS OFFSET]
- THIS EQUIPMENT SHALL BE OPERATED IN COMPLIANCE WITH RULES 218, 431.1 AND 1110.2. 10. [RULE 218, 431.1 AND 1110.2]
- THIS EQUIPMENT SHALL BE OPERATED IN SUCH A MANNER THAT THE FOLLOWING EMISSION 11. RATES ARE NOT EXCEEDED.

AIR CONTAMINANT

600 PPMV AT 15% O2 CARBON MONOXIDE PARTICULATES (PM10) 0.0058 GRAINS/ DSCF ROG OR TNMHC (AS CARBON) 115 PPMV AT 15% O2

[RULE 1303 (a) (1), 1303(b) (1) AND 1303 (b) (2)-BACT, MODELING AND EMISSIONS OFFSET]

THE COMBINED EMISSIONS FROM THE FOUR (4) CGS ENGINES, USING CALENDAR MONTHLY 12. EMISSIONS DIVIDED BY 30, SHALL NOT EXCEED THE FOLLOWING:

AIR CONTAMINANT	LBS/DAY
CARBON MONOXIDE	2,644
NITROGEN OXIDES (AS NO2)	828
PARTICULATES (PM10)	72
ROG OR TNMHC (AS CH4)	372
SULFUR DIOXIDE	84
[RULE 1303 (b) (2)-EMISSIONS OFFS	SET]

- THE OPERATOR SHALL INSTALL AND MAINTAIN A CONTINUOUS EMISSION MONITORING 13. SYSTEM (CEMS), OR AN ALTERNATIVE SYSTEM, AS APPROVED BY THE EXECUTIVE OFFICER. TO MEASURE THE ENGINE EXHAUST FOR NOx AND O2 CONCENTRATIONS ON A DRY BASIS, EXCEPT DURING SHUTDOWN FOR MAINTENANCE OF THE SYSTEM. IN ADDITION, THE CEMS SHALL CONVERT THE ACTUAL NOX TO MASS EMISSION RATES; AND RECORD THE ACTUAL AND CORRECTED ENGINE NOx CONCENTRATION AT 15% O2 AND MASS EMISSION RATES ON AN HOURLY AND DAILY BASIS. [RULE 218, RULE 1110.2]
- THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS ANNUALLY. WRITTEN NOTICE OF THE 14. PERFORMANCE TEST SHALL BE PROVIDED TO THE AQMD AT LEAST 7 DAYS PRIOR TO THE TEST SO THAT AN OBSERVER MAY BE PRESENT. A COMPLETE FINAL REPORT OF THE TEST (LBS/HR, PPMVD AT 15% O2, LBS/MMBTU, ETC.) SHALL BE PROVIDED TO THE AQMD WITHIN 45 DAYS AFTER TESTING. ALL TEST RUNS REQUIRED BY AQMD SHALL BE REPORTED. THE TESTS SHALL INCLUDE BUT NOT BE LIMITED TO, A TEST OF THE FUELS BURNED AND ENGINE EXHAUST FOR:
 - TOTAL NON-METHANE HYDROCARBONS (EXHAUST ONLY) A.
 - CARBON MONOXIDE (EXHAUST ONLY) B.
 - TOTAL PARTICULATE MATTER (EXHAUST ONLY). C.
 - OXIDES OF NITROGEN (EXHAUST ONLY). D.



Section D Page 72
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- E. OXYGEN
- F. FLOW RATE
- G. MOISTURE
- H. TOXIC AIR CONTAMINANTS (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
- I. ALDEHYDES (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
- J. TOTAL REDUCED SULFUR COMPOUNDS (FUEL ONLY)
- K. NITROGEN AND CARBON DIOXIDE
- L. BTU CONTENTS (FUEL ONLY)
- M. POWER OUTPUT

[RULE 1303(b) (1) AND 1303(b) (2) - MODELING AND EMISSION OFFSET], [RULE 1110.2], [RULE 404]

15 RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 204]

Emissions And Requirements:

16. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 1110.2

NOx: 45.4 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26)

ROG: 315 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26)

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



Section D Page 73 Facility I.D. #: 29110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. G27398 A/N 540712

Equipment Description:

RESOURCE RECOVERY SYSTEM NO. 5 CONSISTING OF:

INTERNAL COMBUSTION ENGINE (CG5-HB), COOPER BESSMER, SPARK IGNITION, FOUR STROKE, WITH A MODIFIED TURBOCHARGED-INTERCOOLED V-16 TYPE, MODEL NO. LSVB-16-SGC, 4166 HP, NATURAL GAS AND/OR DIGESTER GAS FIRED, DRIVING A 3000 KW ELECTRIC GENERATOR, WITH AN EXHAUST HEAT RECOVERY STEAM GENERATOR, 6,010,200 BTU/HR CAPACITY, UNFIRED.

- OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND 1. SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW. [RULE 204]
- THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING 2. CONDITION AT ALL TIMES. [RULE 204]
- THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION. [RULE 204]
- THIS ENGINE SHALL HAVE AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER TO 4. DETERMINE THE ENGINE ELAPSED OPERATING TIME FOR EACH FUEL BLEND BURNED. [RULE 1110.2]
- A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE FUEL GAS, OR FUEL BLEND, SUPPLY LINE TO THE ENGINE TO MEASURE AND RECORD THE QUANTITY OF EACH FUEL GAS (IN SCFM) BURNED. [RULE 204]
- SAMPLING PORT SHALL BE INSTALLED FOR THE INLET GAS LINE TO THE ENGINE TO ALLOW 6. THE COLLECTION OF A FUEL GAS OR FUEL BLEND SAMPLES. [RULE 204]
- 7. MONTHLY READINGS OF THE BTU CONTENT OF FUEL GAS (BTU/SCF) AT THE COMBINED INLET TO THE CGS ENGINES SHALL BE TAKEN USING AN INSTRUMENT APPROVED BY THE SCAOMD. ALL RESULTS SHALL BE RECORDED. [RULE 204]
- ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF THE DAY. 8. [RULE 204]



Section D Page 74
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 9. THE TOTAL HEAT INPUT OF GASEOUS FUEL, OR FUEL BLEND, BURNED IN THIS ENGINE SHALL NOT EXCEED 33 MM BTU PER HOUR. A LOG SHALL BE KEPT INDICATING THE TOTAL HEATING VALUE OF FUEL GAS, OR FUEL BLEND, BURNED IN THIS ENGINE BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING.
 [RULE 1303 (b) (1) AND 1303 (b) (2)-MODELING AND EMISSIONS OFFSET]
- 10. THIS EQUIPMENT SHALL BE OPERATED IN COMPLIANCE WITH RULES 218, 431.1 AND 1110.2. [RULE 218, 431.1 AND 1110.2]
- 11. THIS EQUIPMENT SHALL BE OPERATED IN SUCH A MANNER THAT THE FOLLOWING EMISSION RATES ARE NOT EXCEED.

AIR CONTAMINANT

CARBON MONOXIDE PARTICULATES (PM10)

600 PPMV AT 15% O2

0.0058 GRAINS/ DSCF 115 PPMV AT 15% O2

ROG OR TNMHC (AS CARBON)

[RULE 1303 (a) (1), 1303(b) (1) AND 1303 (b) (2)-BACT, MODELING AND EMISSIONS OFFSET]

12. THE COMBINED EMISSIONS FROM THE FOUR (4) CGS ENGINES, USING CALENDAR MONTHLY EMISSIONS DIVIDED BY 30, SHALL NOT EXCEED THE FOLLOWING:

AIR CONTAMINANT	LBS/DAY
CARBON MONOXIDE	2,644
NITROGEN OXIDES (AS NO2)	828
PARTICULATES (PM10)	72
ROG OR TNMHC (AS CH4)	372
SULFUR DIOXIDE	84
[RULE 1303 (b) (2)-EMISSIONS OFFSE	T]

- 13. THE OPERATOR SHALL INSTALL AND MAINTAIN A CONTINUOUS EMISSION MONITORING SYSTEM (CEMS), OR AN ALTERNATIVE SYSTEM, AS APPROVED BY THE EXECUTIVE OFFICER, TO MEASURE THE ENGINE EXHAUST FOR NOx AND O2 CONCENTRATIONS ON A DRY BASIS, EXCEPT DURING SHUTDOWN FOR MAINTENANCE OF THE SYSTEM. IN ADDITION, THE CEMS SHALL CONVERT THE ACTUAL NOx TO MASS EMISSION RATES; AND RECORD THE ACTUAL AND CORRECTED ENGINE NOX CONCENTRATION AT 15% O2 AND MASS EMISSION RATES ON AN HOURLY AND DAILY BASIS.

 [RULE 218, RULE 1110.2]
- 14. THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS ANNUALLY. WRITTEN NOTICE OF THE PERFORMANCE TEST SHALL BE PROVIDED TO THE AQMD AT LEAST 7 DAYS PRIOR TO THE TEST SO THAT AN OBSERVER MAY BE PRESENT. A COMPLETE FINAL REPORT OF THE TEST (LBS/HR, PPMVD AT 15% O2, LBS/MMBTU, ETC.) SHALL BE PROVIDED TO THE AQMD WITHIN 45 DAYS AFTER TESTING. ALL TEST RUNS REQUIRED BY AQMD SHALL BE REPORTED. THE TESTS SHALL INCLUDE BUT NOT BE LIMITED TO, A TEST OF THE FUELS BURNED AND ENGINE EXHAUST FOR:
 - A. TOTAL NON-METHANE HYDROCARBONS (EXHAUST ONLY)
 - B. CARBON MONOXIDE (EXHAUST ONLY)
 - C. TOTAL PARTICULATE MATTER (EXHAUST ONLY).
 - D. OXIDES OF NITROGEN (EXHAUST ONLY).



Section D Page 75
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- E. OXYGEN
- F. FLOW RATE
- G. MOISTURE
- H. TOXIC AIR CONTAMINANTS (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
- I. ALDEHYDES (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
- J. TOTAL REDUCED SULFUR COMPOUNDS (FUEL ONLY)
- K. NITROGEN AND CARBON DIOXIDE
- L. BTU CONTENTS (FUEL ONLY)
- M. POWER OUTPUT

[RULE 1303(b) (1) AND 1303(b) (2) - MODELING AND EMISSION OFFSET], [RULE 1110.2], [RULE 404]

15 RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.

[RULE 204]

Emissions And Requirements:

16. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 1110.2

NOx: 45.4 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26) ROG: 315 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26)

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



Section D Page 76
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, ABRASIVE BLASTING EQUIPMENT, GLOVE-BOX, < 53 FT³, WITH DUST FILTER.

Periodic Monitoring:

- 1. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):
 - A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
 - B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
 - C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

- 2. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS.
 [RULE 3004 (a)(4)]
- 3. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON AN ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD. THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION:
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED. [RULE 3004 (a)(4)]



Section D Page 77
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, CLEANING EQUIPMENT, SMALL UNHEATED, NON-CONVEYORIZED

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1122

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS



Section D Page 78
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, BOILER, WITH RATED HEAT INPUT STARTING AT 75, 000 BTU/HR UP TO AND INCLUDING 2 MMBTU/HR.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: 0.1 gr/scf, RULE 409 CO: 2000 PPMV, RULE 407

NOx; 30 PPMV @3% O2, DRY-TYPE 2 UNIT, > 400,000 BTU/HR AND ≤2 MM BTU/HR, RULE 1146.2 NOx; 55 PPMV @3% O2, DRY-TYPE 1 UNIT, ≥ 400,000 BTU/HR AND ≤400,000 BTU/HR, RULE 1146.2



Section D Page 79
Facility I.D. #: 29110
Revision #: 07

Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, ABRASIVE BLASTING EQUIPMENT, GLOVE-BOX, < 53 FT³, WITH DUST FILTER.

Periodic Monitoring:

- 4. THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):
 - D. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
 - E. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
 - F. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.

[RULE 3004 (a)(4)]

- 5. THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS.

 [RULE 3004 (a)(4)]
- 6. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON AN ANNUAL BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD. THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED, THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- D. STACK OR EMISSION POINT IDENTIFICATION;
- E. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS; AND
- F. DATE AND TIME VISIBLE EMISSION WAS ABATED. [RULE 3004 (a)(4)]



Section D Page 80 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, CLEANING EQUIPMENT, SMALL UNHEATED, NON-CONVEYORIZED

Emissions And Requirements:

2. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1122

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS



Section D Page 81 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, HAND WIPING OPERATIONS.

Emissions and Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS



Section D Page 82 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, BOILER, WITH RATED HEAT INPUT STARTING AT 75, 000 BTU/HR UP TO AND INCLUDING 2 MMBTU/HR.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: 0.1 gr/scf, RULE 409 CO: 2000 PPMV, RULE 407

NOx; 30 PPMV @3% O2, DRY-TYPE 2 UNIT, > 400,000 BTU/HR AND ≤2 MM BTU/HR, RULE 1146.2 NOx; 55 PPMV @3% O2, DRY-TYPE 1 UNIT, ≥ 400,000 BTU/HR AND ≤400,000 BTU/HR, RULE 1146.2

Section D Page 83 Facility I.D. #: 29110 Revision #: 07 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS.

Periodic Monitoring:

1. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):

FOR ARCHITECTURAL APPLICATIONS WHERE NO THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN SEMI-ANNUAL RECORDS OF ALL COATINGS CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS SUPPLIED IN GRAMS PER LITER (g/l) OF MATERIALS FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS SUPPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

FOR OTHER ARCHITECTURAL APPLICATIONS WHERE THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN DAILY RECORDS FOR EACH COATING CONSISTING OF (a) COATING TYPE, (b) VOC CONTENT AS APPLIED IN GRAMS PER LITER (g/l) OF MATERIALS USED FOR LOW-SOLIDS COATINGS, (c) VOC CONTENT AS APPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING. [RULE 3004(a)(4)]

Emissions And Requirements:

2. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1113, SEE APPENDIX B FOR EMISSION LIMITS VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS



Section D Page 84
Facility I.D.#: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, AIR CONDITIONING UNITS.

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1415

VOC: 40CFR 82 SUBPART F



Section D Page 85
Facility I.D. #: 29110
Revision #: 07
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

RULE 219 EQUIPMENT

Equipment Description:

RULE 219 EXEMPT EQUIPMENT, FIRE EXTINGUISHING EQUIPMENT

Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

HALON:

RULE 1418

Section E Facility ID: Revision #: Page: 1 029110 1

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION E: ADMINISTRATIVE CONDITIONS

The operating conditions in this section shall apply to all permitted equipment at this facility unless superseded by condition(s) listed elsewhere in this permit.

- 1. The permit shall remain effective unless this permit is suspended, revoked, modified, reissued, denied, or it is expired for nonpayment of permit processing or annual operating fees. [201, 203, 209, 301]
 - a. The permit must be renewed annually by paying annual operating fees, and the permit shall expire if annual operating fees are not paid pursuant to requirements of Rule 301(d). [301(d)]
 - b. The Permit to Construct listed in Section H shall expire one year from the Permit to Construct issuance date, unless a Permit to Construct extension has been granted by the Executive Officer or unless the equipment has been constructed and the operator has notified the Executive Officer prior to the operation of the equipment, in which case the Permit to Construct serves as a temporary Permit to Operate. [202, 205]
 - c. The Title V permit shall expire as specified under Section K of the Title V permit. The permit expiration date of the Title V facility permit does not supercede the requirements of Rule 205. [205, 3004]
- 2. The operator shall maintain all equipment in such a manner that ensures proper operation of the equipment. [204]
- 3. This permit does not authorize the emissions of air contaminants in excess of those allowed by Division 26 of the Health and Safety Code of the State of California or the Rules and Regulations of the AQMD. This permit cannot be considered as permission to violate existing laws, ordinances, regulations, or statutes of other governmental agencies. [204]
- 4. The operator shall not use equipment identified in this facility permit as being connected to air pollution control equipment unless they are so vented to the identified air pollution control equipment which is in full use and which has been included in this permit. [204]

Section E Facility ID: Revision #:

Date:

Page: 2 029110 1

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION E: ADMINISTRATIVE CONDITIONS

- 5. The operator shall not use any equipment having air pollution control device(s) incorporated within the equipment unless the air pollution control device is in full operation. [204]
- 6. The operator shall maintain records to demonstrate compliance with rules or permit conditions that limit equipment operating parameters, or the type or quantity of material processed. These records shall be made available to AQMD personnel upon request and be maintained for at least five years. [204]
- 7. The operator shall maintain and operate all equipment to ensure compliance with all emission limits as specified in this facility permit. Compliance with emission limits shall be determined according to the following specifications, unless otherwise specified by AQMD rules or permit conditions: [204]
 - a. For internal combustion engines and gas turbines, measured concentrations shall be corrected to 15 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1110.2, 1134]
 - b. For other combustion devices, measured concentrations shall be corrected to 3 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1146, 1146.1, 204]
 - c. For non-combustion sources, compliance with emission limits shall be determined and averaged over a period of 60 minutes; [204]
 - d. For the purpose of determining compliance with Rule 407, carbon monoxide (CO) shall be measured on a dry basis and be averaged over 15 consecutive minutes, and sulfur compounds which would exist as liquid or gas at standard conditions shall be calculated as sulfur dioxide (SO2) and be averaged over 15 consecutive minutes; [407]
 - e. For the purpose of determining compliance with Rule 409, combustion contaminant emission measurements shall be corrected to 12 percent of carbon dioxide (CO2) at standard conditions and averaged over a minimum of 15 consecutive minutes. [409]

Section E Facility ID: Revision #: Page: 3 029110 1

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION E: ADMINISTRATIVE CONDITIONS

- f. For the purpose of determining compliance with Rule 475, combustion contaminant emission measurements shall be corrected to 3 percent of oxygen (O2) at standard conditions and averaged over 15 consecutive minutes or any other averaging time specified by the Executive Officer. [475]
- 8. The operator shall, when a source test is required by AQMD, provide a source test protocol to AQMD no later than 60 days before the proposed test date. The test shall not commence until the protocol is approved by AQMD. The test protocol shall contain the following information: [204, 304]
 - a. Brief description of the equipment tested.
 - b. Brief process description, including maximum and normal operating temperatures, pressures, throughput, etc.
 - c. Operating conditions under which the test will be performed.
 - d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts and stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
 - e. Brief description of sampling and analytical methods used to measure each pollutant, temperature, flow rates, and moisture.
 - f. Description of calibration and quality assurance procedures.
 - g. Determination that the testing laboratory qualifies as an "independent testing laboratory" under Rule 304 (conflict of interest).
- 9. The operator shall submit a report no later than 60 days after conducting a source test, unless otherwise required by AQMD rules or equipment-specific conditions. The report shall contain the following information: [204]
 - a. The results of the source test.

Section E Facility ID: Revision #:

Date:

Page: 4 029110

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION E: ADMINISTRATIVE CONDITIONS

- b. Brief description of the equipment tested.
- c. Operating conditions under which the test was performed.
- d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts and stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
- e. Field and laboratory data forms, strip charts and analyses.
- f. Calculations for volumetric flow rates, emission rates, control efficiency, and overall control efficiency.
- 10. The operator shall, when a source test is required, provide and maintain facilities for sampling and testing. These facilities shall comply with the requirements of AQMD Source Test Method 1.1 and 1.2. [217]
- 11. Whenever required to submit a written report, notification or other submittal to the Executive Officer, AQMD, or the District, the operator shall mail or deliver the material to: Deputy Executive Officer, Engineering and Compliance, AQMD, 21865 E. Copley Drive, Diamond Bar, CA 91765-4182. [204]



Section F Facility ID: Revision # Page: 1 029110

Date:

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION F: RECLAIM MONITORING AND SOURCE TESTING REQUIREMENTS

NOT APPLICABLE

Section G Facility ID:

Page: 1029110

Revision #: Date:

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION G: RECORDKEEPING AND REPORTING REQUIREMENTS FOR RECLAIM SOURCES

NOT APPLICABLE



Section H Page 1 Facility I.D. #: 029110 Revision #: 09 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

This section consists of a table listing all equipment with Permits to Construct and copies of all individual Permits to Construct issued to various equipment at the facility. Each permit will list operating conditions including periodic monitoring requirements and applicable emission limits and requirements that the equipment is subject to. Also included is the rule origin and authority of each emission limit and permit condition.



Section H Page 2 Facility l.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMITTED EQUIPMENT LIST

THE FOLLOWING IS A LIST OF ALL PERMITS TO CONSTRUCT AND PERMITS TO OPERATE AT THIS FACILITY:

Application	Permit to Construct	Equipment Description	Page Number
Number	Granted On		
519422	6/07/2012	ODOR CONTROL SYSTEM, FOR BIOSOLIDS	5
		TRUCK LOADING STATION	
518276	6/07/2012	ODOR CONTROL SYSTEM, FOR DAF	7
	\	THICKENING PROCESS	
545003	6/26/2014	ODOR CONTROL UNIT, BIOFILTER	10
545004	10/17/2013, will supersede	BOILER, 10.2 MMBTU/HR, DIGESTER GAS	13
	R-D94235	AND NATURAL GAS	
545005	10/17/2013, will supersede	BOILER, 10.2 MMBTU/HR, DIGESTER GAS	16
	R-D94232	AND NATURAL GAS	
546364	4/16/2014	ICE CG-1, 4166 HP, DG/NG WITH DG FUEL	19
		PRETREATMENT	
546365	4/16/2014	ICE CG-2, 4166 HP, DG/NG WITH DG FUEL	23
		PRETREATMENT	
546366	4/16/2014	ICE CG-3, 4166 HP, DG/NG WITH DG FUEL	27
		PRETREATMENT	
546367	4/16/2014	ICE CG-4, 4166 HP, DG/NG WITH DG FUEL	31
		PRETREATMENT	
546368	4/16/2014	ICE CG-5, 4166 HP, DG/NG WITH DG FUEL	35
	_	PRETREATMENT	
556626	6/26/2014	SEWAGE TREATMENT (>5 MG/D)	39
		ANAEROBIC	
556627	6/26/2014	AIR POLLUTION CONTROL SYSTEM, WET	43
		SCRUBBER AND BIOFILTER	
557229	4/16/2014	STORAGE TANK, AQUEOUS UREA	46
		SOLUTION	
557230	4/16/2014	STORAGE TANK, AQUEOUS UREA	47
		SOLUTION	
559228	4/16/2014	APC SYSTEM 1, SCR/CO CATALYST	48
559229	4/16/2014	APC SYSTEM 2, SCR/CO CATALYST	51
559230	4/16/2014	APC SYSTEM 3, SCR/CO CATALYST	54
559231	4/16/2014	APC SYSTEM 4, SCR/CO CATALYST	57
559232	4/16/2014	APC SYSTEM 4, SCR/CO CATALYST	60
565930	11/12/2014	AIR POLLUTION CONTROL SYSTEM,	63
		CHEM. SCRUBBERS FOR TRICKLING	
		FILTERS	

NOTE: EQUIPMENT LISTED ABOVE THAT HAVE NO CORRESPONDING PERMITS TO OPERATE NUMBER ARE ISSUED PERMITS TO CONSTRUCT. THE ISSUANCE OR DENIAL OF THEIR PERMITS TO OPERATE IS SUBJECT TO ENGINEERING FINAL REVIEW. ANY OTHER APPLICATIONS THAT ARE STILL BEING PROCESSED AND HAVE NOT BEEN ISSUED PERMITS TO CONSTRUCT OR PERMITS TO OPERATE WILL NOT BE FOUND IN THIS TITLE V PERMIT.



Section H Page 3 Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

FACILITY WIDE CONDITION (S)

Condition(s):

- 1. EXCEPT FOR OPEN ABRASIVE BLASTING OPERATIONS, THE OPERATOR SHALL NOT DISCHARGE INTO THE ATMOSPHERE FROM ANY SINGLE SOURCE OF EMISSIONS WHATSOEVER ANY AIR CONTAMINANT FOR A PERIOD OR PERIODS AGGREGATING MORE THAN THREE MINUTES IN ANY ONE HOUR WHICH IS:
 - A. AS DARK OR DARKER IN SHADE AS THAT DESIGNATED NO. 1 ON THE RINGLEMANN CHART. AS PUBLISHED BY THE UNITED STATES BUREAU OF MINES; OR
 - B. OF SUCH OPACITY AS TO OBSCURE AN OBSERVER'S VIEW TO A DEGREE EQUAL TO OR GREATER THAN DOES SMOKE DESCRIBED IN SUBPARAGRAPH (A) OF THIS CONDITION. [RULE 401]
- 2. THE OPERATOR SHALL NOT COMBUST DIGESTER GAS CONTAINING SULFUR COMPOUNDS IN EXCESS OF 40 PPMV CALCULATED AS HYDROGEN SULFIDE AVERAGED DAILY.
 [RULE 431.1]
- 3. THE OPERATOR SHALL NOT USE FUEL OIL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 0.05 PERCENT BY WEIGHT. ON OR AFTER JUNE 1, 2004, A PERSON SHALL NOT PURCHASE ANY DIESEL FUEL FOR STATIONARY SOURCE APPLICATION IN THE DISTRICT, UNLESS THE FUEL IS LOW SULFUR DIESEL FOR WHICH THE SULFUR CONTENT SHALL NOT EXCEED 15 PPM BY WEIGHT AS SUPPLIED BY THE SUPPLIER.
 [RULE 431.2]
- 4. THE OWNER/OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF 40 CFR 63 SUBPART VVV NON-INDUSTRIAL POTW PLANT NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS (NESHAP) AND ALL APPLICABLE REQUIREMENTS OF 40 CFR 63 SUBPART ZZZZ STATIONARY RECIPROCATING INTERNAL COMBUSTION ENGINES NESHAP. [40 CFR 63 SUBPART VVV, AND 40 CFR 63 SUBPART ZZZZ]
- 5. THE OPERATOR SHALL MEASURE THE SULFUR CONTENT OF THE DIGESTER GAS ACCORDING TO THE FOLLOWING:
 - A. FOR READINGS UP TO 36 PPM AS H2S, DAILY ANALYSIS OF THE DIGESTER GAS FOR H2S, USING COLORIMETRIC TUBES, AND WEEKLY ANALYSIS OF THE DIGESTER GAS BY AQMD METHOD 307 TOTAL SULFUR COMPOUNDS IN FUEL GAS BY GAS CHROMATOGRAPHY AND SULFUR CHEMILUMINESCENCE DETECTOR.
 - B. FOR READINGS ABOVE 36 PPM AS H2S, DAILY ANALYSIS OF THE DIGESTER GAS FOR H2S BY AQMD METHOD 307 TOTAL SULFUR COMPOUNDS IN FUEL GAS BY GAS CHROMATOGRAPHY AND SULFUR CHEMILUMINESCENCE DETECTOR. A MINIMUM OF THREE CONSECUTIVE DAILY SAMPLES ARE REQUIRED TO DEMONSTRATE THE TOTAL SULFUR CONTENT IS BELOW 36 PPM.

 [RULE 431.1]



Section H Page 4
Facility I.D. #: 029110
Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

6. A COMPLETE APPLICATION FOR COMPLIANCE ASSURANCE MONITORING (CAM, 40 CFR PART 64) SHALL BE SUBMITTED WHENEVER THE ANNUAL MASS OF VOC OF THE DIGESTER GAS EXCEEDS 19,999 LBS/YR. THE VOC CONTENT OF THE DIGESTER GAS SHALL BE ANALYZED IN CONJUNCTION WITH THE ANNUAL SOURCE TESTING OF THE CGS ENGINES USING THE APPROVED METHODS. FOR EACH CALENDAR YEAR, THE VOC EMISSIONS SHALL BE CALCULATED BY MARCH 31ST OF THE SUBSEQUENT CALENDAR YEAR, OR WITHIN 30 DAYS OF SOURCE TEST REPORT DATE, WHICHEVER IS LATER, BASED ON THE DIGESTER GAS CONCENTRATION DATA FROM ANNUAL RULE 1110.2 SOURCE TESTING OF THE ENGINES. IF THE VOC EMISSIONS EXCEED 19,999 LBS/YR, THE CAM APPLICATION SHALL BE SUBMITTED BY MARCH 31ST, OR WITHIN 60 DAYS AFTER THE CALCULATION DUE DATE, WHICHEVER IS LATER.

[40 CFR PART 64, CAM]

Section H Page 5 Facility I.D. #: 029110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 519422 Granted as of 6/07/2012

Equipment Description:

ODOR CONTROL SYSTEM FOR THE BIOSOLIDS TRUCK LOADING STATION, CONSISTING OF;

- EXHAUST BLOWER, MAXIMUM 3000 CFM, 15 H. P., VENTING TWO (2) BIOSOLIDS STORAGE 1. SILOS (PART OF THE SLUDGE PROCESSING STATION, PC 453240).
- ADSORBER, BAY PRODUCTS, SPARROW 3000, 8' DIA. X 7'- 3" H. OVERALL, CONTAINING 2. MINIMUM OF 3800 LBS OF ACTIVATED CARBON (BOTTOM LAYER) AND 1500 LBS OF POTASSIUM PERMANGANATE (KMNO4) IMPREGNATED MEDIA (TOP LAYER). EQUIPPED WITH DIFFERENTIAL PRESSURE GAUGE AND A DEMISTER.
- EXHAUST STACK, 1' 6" DIA. X 13' 6" HIGH ABOVE GROUND. 3.

Conditions:

- OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA 1. AND SPECIFICATIONS SUBMITTED WITH THE APPLICATIONS UNDER WHICH THIS PERMIT IS ISSUED. [RULE 204]
- THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING 2. CONDITIONS AT ALL TIMES. [RULE 204]
- THE OPERATOR MAY USE ALTERNATE MEDIA AND AMOUNTS IN ORDER TO OPTIMIZE THE 3. ODOR CONTROL SYSTEM, PROVIDED SUCH ALTERNATE MEDIA AND AMOUNTS ARE GUARANTEED BY THE VENDOR TO MEET THE EMISSION LIMITS IN THIS PERMIT. [RULE 204]
- THIS PERMIT SHALL EXPIRE IF CONSTRUCTION OF THE EQUIPMENT IS NOT COMPLETED 4. WITHIN ONE YEAR FROM THE DATE OF ISSUANCE OF THIS PERMIT UNLESS AN EXTENSION IS GRANTED BY THE EXECUTIVE OFFICER. **IRULE 2051**
- SAMPLING PORTS SHALL BE PROVIDED AT THE INLET AND OUTLET OF THE ODOR CONTROL 5. SYSTEM TO ALLOW COLLECTION/ANALYSIS OF THE INLET FOUL AIR AND TREATED EXHAUST STREAM. [RULE 204]
- THE OPERATOR SHALL INSTALL AND MAINTAIN A DIFFERENTIAL PRESSURE GAUGE TO 6. ACCURATELY INDICATE THE DIFFERENTIAL PRESSURE, IN INCHES OF WATER COLUMN, ACROSS THE MEDIA BED. [RULE 204]

Section H Page 6 Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 7. THE OPERATOR SHALL, ON A WEEKLY BASIS, MEASURE AND RECORD THE DIFFERENTIAL PRESSURE DROP, IN INCHES OF WATER COLUMN, ACROSS THE MEDIA BED.
 [RULE 204]
- 8. IN OPERATION, THE PRESSURE DROP MEASURED ACROSS THE MEDIA BED SHALL BE MAINTAINED BETWEEN 4.8 AND 8.4 INCHES OF WATER COLUMN, OR ANOTHER RANGE SPECIFIED BY THE MANUFACTURER. MANUFACTURER'S PRESSURE DROP RANGE SPECIFICATIONS FOR THIS EQUIPMENT SHALL BE KEPT ON FILE AND SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.

 [RULE 204]
- 9. THE HYDROGEN SULFIDE (H2S) CONCENTRATION (PPMV) AT THE INLET TO ODOR CONTROL SYSTEM SHALL BE MONITORED AND RECORDED ON A WEEKLY BASIS FOR THE FIRST MONTH OF OPERATION, AND MONTHLY THEREAFTER USING COLORIMETRIC H2S TUBES OR ANY OTHER DISTRICT APPROVED METHOD.

 [RULE 204]
- 10. THE HYDROGEN SULFIDE (H2S) CONCENTRATION (PPMV) IN THE EXHAUST OF THE ODOR CONTROL SYSTEM SHALL BE MEASURED AND RECORDED AT LEAST ONCE A WEEK USING COLORIMETRIC H2S TUBES, HANDHELD H2S ANALYZER, OR ANY OTHER DISTRICT APPROVED METHOD.

 [RULE 204]
- 11. IN OPERATION, THE HYDROGEN SULFIDE (H2S) CONCENTRATION IN THE EXHAUST OF THE ODOR CONTROL SYSTEM SHALL NOT EXCEED 1.0 PPMV.
 [RULE 402, 1401]
- 12. THE MEDIA IN THE ADSORBER SHALL BE REPLACED WITH MINIMUM AMOUNT (LBS) OF FRESH CARBON MEDIA, AS DESCRIBED UNDER EQUIPMENT DESCRIPTION OR CONDITION NO. 3, WHENEVER NECESSARY TO COMPLY WITH THE CONDITIONS OF THIS PERMIT.

 [RULE 204]
- 13. SPENT MEDIA REMOVED FROM THIS SYSTEM SHALL BE MAINTAINED OR STORED IN CLOSED CONTAINERS PRIOR TO REMOVAL FROM SITE.
 [RULE 402]
- 14. RECORDS SHALL BE MAINTAINED AS REQUIRED BY THIS PERMIT INCLUDING MEDIA CHANGE OVER DATE(S), QUANTITY, AND VENDOR GUARANTEES FOR COMPLIANCE. THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.

 [RULE 204]

Section H Page 7 Facility I.D. #: 029110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 518276 Granted as of 6/07/2012

Equipment Description:

ODOR CONTROL SYSTEM, TREATING EXHAUST FROM DISSOLVED AIR FLOATATION THICKENERS (DAFTS), CONSISTING OF:

- EXHAUST HEADER FROM FOUR (4) DISSOLVED AIR FLOATATION THICKENERS (DAFTS) AND 1. TWO (2) POLYMER MIX TANKS.
- THREE (3) FOUL-AIR EXHAUST FANS (ONE STANDBY), EACH 100 H.P., MAXIMUM 35,000 CFM 2. CAPACITY.
- HUMIDIFICATION, IN-DUCT, WITH TWELVE (12) SPRAY NOZZLES, AND EQUIPPED WITH 3. HYDROGEN SULFIDE (H2S) ANALYZER.
- THREE (3) BIOFILTER CELLS, CONCRETE WALLED, CUSTOM DESIGNED, EACH BIOFILTER CELL 4. 20' W. X 33' L. X 9' D., CONTAINING PROPRIETARY INORGANIC MINERAL BASED MEDIA, EQUIPPED WITH INLET FOUL-AIR FLOW METERS, SAMPLING PORTS AND SURFACE IRRIGATION SYSTEM.

Conditions:

- CONSTRUCTION AND OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN 1. COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT TO CONSTRUCT IS ISSUED UNLESS OTHERWISE NOTED BELOW. [RULE 204]
- THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING 2. CONDITION AT ALL TIMES. [RULE 204]
- 3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION. [RULE 204]
- THIS PERMIT SHALL EXPIRE IF CONSTRUCTION OF THE EQUIPMENT IS NOT COMPLETED 4. WITHIN ONE YEAR FROM THE DATE OF ISSUANCE OF THIS PERMIT UNLESS AN EXTENSION IS GRANTED BY THE EXECUTIVE OFFICER. [RULE 205]
- A TEMPERATURE INDICATOR SHALL BE INSTALLED AND MAINTAINED IN THE MAIN FOUL-AIR 5. HEADER PRIOR TO FOUL-AIR DISTRIBUTION TO THE BIOFILTERS. THE INLET FOUL AIR TEMPERATURE READINGS, TAKEN ON A MONTHLY BASIS, SHALL BE MAINTAINED IN THE



Section H Page 8 Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

RANGE OF EQUIPMENT DESIGN SPECIFICATIONS OR AS PER MANUFACTURER'S RECOMMENDATION, AND WRITTEN SPECIFICATIONS SHALL BE KEPT ON FILE. [RULE 204]

- 6. A HYDROGEN SULFIDE (H2S) ANALYZER SHALL BE INSTALLED AND MAINTAINED IN THE MAIN FOUL-AIR HEADER PRIOR TO FOUL-AIR DISTRIBUTION TO THE BIOFILTERS. FOUL-AIR H2S CONCENTRATION (PPMV) SHALL BE MONITORED ON A MONTHLY BASIS AND RESULTS RECORDED. WHEN H2S ANALYZER IS NOT OPERATING, COLORIMETRIC H2S TUBES, HAND HELD H2S ANALYZERS OR ANY OTHER DISTRICT APPROVED METHODS SHALL BE USED FOR H2S MONITORING.

 [RULE 204]
- 7. FOUL-AIR FLOW RATE (SCFM) MONITORING AND INDICATING DEVICE OR SYSTEM SHALL BE INSTALLED AND MAINTAINED IN THE FOUL AIR INLET DUCT TO EACH BIOFILTER.
 [RULE 204]
- 8. FOUL-AIR FLOW RATE SHALL BE MONITORED AND RECORDED ON A DAILY BASIS. TOTAL FLOW RATE READING FOR INLET FOUL-AIR TO THREE (3) BIOFILTER CELLS SHALL NOT EXCEED 35, 000 SCFM.
 [RULE 402, 1401]
- 9. THE INCOMING FOUL AIR HUMIDIFICATION AND SURFACE IRRIGATION SYSTEMS SHALL BE MAINTAINED IN GOOD OPERATING CONDITION, AT ALL TIMES, AND SHALL BE UTILIZED TO MAINTAIN THE DESIRED MOISTURE CONTENT FOR THE BIOFILTER MEDIA.

 [RULE 204]
- 10. HYDROGEN SULFIDE (H2S) AND AMMONIA (NH₃) EMISSIONS FROM EACH BIOFILTER SURFACE (MULTI-POINT) SHALL BE MONITORED AT LEAST ONCE A MONTH USING PORTABLE ANALYZERS. THE MULTI-POINT SURFACE READINGS (PPMV) SHALL BE AVERAGED AND RECORDED. [RULE 204]
- 11. EMISSIONS OF H2S FROM THE BIOFILTER SHALL NOT EXCEED 0.0175 LB/HR (93 PPBV AT THE SURFACE AT 35,000 CFM).
 [RULE 204]
- 12. THE OWNER OR OPERATOR OF THE EQUIPMENT SHALL CONDUCT SOURCE PERFORMANCE TESTS UNDER THE FOLLOWING CONDITIONS:
 - I. A TEST PROTOCOL SHALL BE SUBMITTED TO AQMD NO LATER THAN 45 DAYS BEFORE THE PROPOSED TEST DATE AND SHALL BE APPROVED BY THE EXECUTIVE OFFICER BEFORE THE TEST COMMENCES. AT A MINIMUM, THE TEST PROTOCOL SHOULD INCLUDE THE FOLLOWING:
 - a. A DESCRIPTION OF THE EQUIPMENT TESTED. INCLUDE A PROCESS SCHEMATIC INDICATING SAMPLING LOCATIONS/PORTS; SAMPLING DUCT/STACK DIMENSIONS ALONG WITH UPSTREAM AND DOWNSTREAM FLOW DISTURBANCES (E.G. ELBOWS, TEES AND FANS).
 - b. A BRIEF PROCESS DESCRIPTION.



Section H Page 9 Facility I.D. #: 029110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- OPERATING CONDITIONS UNDER WHICH THE TEST WILL BE PERFORMED. c. INCLUDING INLET AIR FLOW RATE (SCFM), TEMPERATURE, AND % MOISTURE.
- A DESCRIPTION OF THE SAMPLING AND ANALYTICAL METHODS FOR EACH d. CONSTITUENT MEASURED.
- COMPLETE CALCULATIONS FOR FLOW RATES, CONCENTRATIONS (PPMV), e. EMISSION RATES AND CONTROL EFFICIENCIES.
- A DESCRIPTION OF THE CALIBRATION AND QUALITY ASSURANCE f. PROCEDURES.
- SAMPLING FACILITIES SHALL COMPLY WITH THE DISTRICT GUIDELINES FOR g. CONSTRUCTION OF SAMPLING AND TESTING FACILITIES, PURSUANT TO RULE 217.
- A STATEMENT DETERMINING THAT THE TESTING LABORATORY QUALIFIES AS h. AN "INDEPENDENT TESTING LABORATORY" UNDER RULE 304 (NO CONFLICT OF INTEREST) AND SIGNED BY THE RESPONSIBLE AUTHORITY.
- H. THE TESTS SHALL DETERMINE BIOFILTER'S INLET AND OUTLET EMISSIONS FOR TOTAL NON-METHANE ORGANIC COMPOUNDS (TNMOC), H2S AND AMMONIA TO DETERMINE BIOFILTER'S CONTROL EFFICIENCY, IN WEIGHT PERCENT. TEST RESULTS SHOULD INCLUDE INLET AND OUTLET THMOC AND AMMONIA CONCENTRATIONS (PPMV), AND EMISSIONS (LBS/HR), AND SPECIATED ANALYSIS FOR TNMOCS,
- THE TESTS SHALL BE CONDUCTED AND A WRITTEN REPORT SUBMITTED TO THE III. SCAOMD WITHIN 60 DAYS AT MAXIMUM FOUL-AIR INLET FLOW RATE AT WHICH THE EQUIPMENT WILL BE OPERATED, BUT NOT LATER THAN 180 DAYS AFTER INITIAL START-UP.

[RULE 204, 217, 402, 1401]

- SMOKE BOMB TESTS SHALL BE CONDUCTED INITIALLY AND, THEREAFTER, EVERY THREE (3) 13. YEARS TO DEMONSTRATE UNIFORM DISTRIBUTION OF AIR FLOWS, AREA OF COMPACTION AND/OR CHANNELING THAT NEEDS REPAIR. [RULE 204]
- ANY BREAKDOWN OR MALFUNCTION OF THIS EQUIPMENT RESULTING IN EXCESSIVE ODOR 14. EMISSIONS INTO THE ATMOSPHERE SHALL BE REPORTED TO THE SCAQMD WITHIN TWENTY FOUR HOURS AFTER OCCURRENCE, AND IMMEDIATE REMEDIAL MEASURES SHALL BE UNDERTAKEN TO CORRECT THE PROBLEM AND PREVENT FURTHER EMISSIONS INTO THE ATMOSPHERE. [RULE 430, 402]
- ALL RECORDS REQUIRED BY THIS PERMIT SHALL BE KEPT AND MAINTAINED FOR AT LEAST 15. FIVE YEARS, AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST. [RULE 204]

Section H Page 10 Facility I.D. #: 029110 Revision #: 09 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 545003 Granted as of 6-26-2014

Equipment Description:

ODOR CONTROL SYSTEM CONSISTING OF:

- 1. EXHAUST HEADER FROM FOUR (4) DISSOLVED AIR FLOATATION THICKENERS (DAFTS).
- 2. OPTIONAL EXHAUST FROM TWO (2) POLYMER MIX TANKS.
- 3. THREE (3) FOUL-AIR EXHAUST FANS (ONE STANDBY), EACH APPROXIMATELY 100 HP, TOTAL MAXIMUM 35,000 CFM CAPACITY.
- 4. IN-DUCT INLET AIR HUMIDIFICATION SYSTEM WITH APPROXIMATELY TWELVE (12) WATER SPRAY NOZZLES.
- 5. THREE (3) BIOFILTERS, CONCRETE WALLED, CUSTOM DESIGNED, EACH BIOFILTER APPROXIMATELY 20' W. X 33' L. X 9' D., CONTAINING PROPRIETARY INORGANIC MINERAL BASED MEDIA, EQUIPPED WITH A SURFACE IRRIGATION SYSTEM.

Conditions:

- 1. CONSTRUCTION AND OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT TO CONSTRUCT IS ISSUED UNLESS OTHERWISE NOTED BELOW. [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.

 [RULE 204]
- 3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
 [RULE 204]
- 4. THIS PERMIT SHALL EXPIRE IF CONSTRUCTION OF THE EQUIPMENT IS NOT COMPLETED WITHIN ONE YEAR FROM THE DATE OF ISSUANCE OF THIS PERMIT UNLESS AN EXTENSION IS GRANTED BY THE EXECUTIVE OFFICER.

 [RULE 205]
- 5. FOUL-AIR INLET FLOW RATE (SCFM) MONITORING AND INDICATING DEVICE OR RECORDING SYSTEM SHALL BE INSTALLED AND MAINTAINED IN THE FOUL AIR INLET DUCT TO THE BIOFILTERS.
 [RULE 204]

Section H Page 11 Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 6. FOUL-AIR INLET FLOW RATE TO THE BIOFILTERS SHALL BE MONITORED AND RECORDED AT LEAST ONCE EACH DAY. TOTAL AIR FLOW RATE MEASURED SHALL NOT EXCEED 35,000 SCFM, DAILY AVERAGE.

 [RULE 402, 1401]
- 7. THE INCOMING FOUL AIR HUMIDIFICATION AND SURFACE IRRIGATION SYSTEMS SHALL BE MAINTAINED IN GOOD OPERATING CONDITION, AT ALL TIMES, AND SHALL BE UTILIZED TO MAINTAIN THE DESIRED MOISTURE CONTENT FOR THE BIOFILTER MEDIA.

 [RULE 204]
- 8. WHEN IN OPERATION, HYDROGEN SULFIDE (H2S) EMISSIONS FROM EACH BIOFILTER SURFACE (MULTI-POINT) SHALL BE MONITORED AT LEAST ONCE A MONTH USING PORTABLE ANALYZERS. THE MULTI-POINT SURFACE READINGS (PPMV) SHALL BE AVERAGED AND RECORDED.

 [RULE 204]
- 9. H2S EMISSIONS MEASURED FROM THE BIOFILTERS' SURFACES SHALL NOT EXCEED 1 PPMV. [RULE 402, 1401]
- 10. THE OWNER OR OPERATOR OF THE EQUIPMENT SHALL CONDUCT SOURCE PERFORMANCE TESTS UNDER THE FOLLOWING CONDITIONS:
 - I. A TEST PROTOCOL SHALL BE SUBMITTED TO AQMD NO LATER THAN 45 DAYS BEFORE THE PROPOSED TEST DATE AND SHALL BE APPROVED BY THE EXECUTIVE OFFICER BEFORE THE TEST COMMENCES. AT A MINIMUM, THE TEST PROTOCOL SHOULD INCLUDE THE FOLLOWING:
 - a. A DESCRIPTION OF THE EQUIPMENT TESTED. INCLUDE A PROCESS SCHEMATIC INDICATING SAMPLING LOCATIONS/PORTS; SAMPLING DUCT/STACK DIMENSIONS ALONG WITH UPSTREAM AND DOWNSTREAM FLOW DISTURBANCES (E.G. ELBOWS, TEES AND FANS).
 - b. A BRIEF PROCESS DESCRIPTION.
 - c. OPERATING CONDITIONS UNDER WHICH THE TEST WILL BE PERFORMED, INCLUDING INLET AIR FLOW RATE (SCFM), TEMPERATURE, AND % MOISTURE.
 - d. A DESCRIPTION OF THE SAMPLING AND ANALYTICAL METHODS FOR EACH CONSTITUENT MEASURED.
 - e. COMPLETE CALCULATIONS FOR FLOW RATES, CONCENTRATIONS (PPMV), EMISSION RATES AND CONTROL EFFICIENCIES.
 - f. A DESCRIPTION OF THE CALIBRATION AND QUALITY ASSURANCE PROCEDURES.
 - g. SAMPLING FACILITIES SHALL COMPLY WITH THE DISTRICT GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES, PURSUANT TO RULE 217.



Section H Page 12 Facility I.D. #: 029110 Revision #:

February 5, 2015 Date:

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- A STATEMENT DETERMINING THAT THE TESTING LABORATORY QUALIFIES AS h. AN "INDEPENDENT TESTING LABORATORY" UNDER RULE 304 (NO CONFLICT OF INTEREST) AND SIGNED BY THE RESPONSIBLE AUTHORITY.
- II. THE TESTS SHALL DETERMINE BIOFILTER'S INLET AND OUTLET EMISSIONS FOR TOTAL NON-METHANE ORGANIC COMPOUNDS (TNMOC) AND AMMONIA (AT LEAST FOR ONE BIOFILTER), AND H2S (FROM EACH BIOFILTER) TO DETERMINE BIOFILTER'S CONTROL EFFICIENCY, IN WEIGHT PERCENT. TEST RESULTS SHOULD INCLUDE INLET AND OUTLET H2S, TNMOC AND AMMONIA CONCENTRATIONS (PPMV), AND EMISSIONS (LBS/HR), AND SPECIATED ANALYSIS FOR ORGANIC COMPOUNDS (EXHAUST FROM ONE BIOFILTER).
- III. THE TESTS SHALL BE CONDUCTED AFTER EQUIPMENT INITIAL START-UP, BUT NOT LATER THAN 180 DAYS, AT A MAXIMUM ACHIEVABLE INLET FOUL-AIR FLOW RATE AT WHICH THE EQUIPMENT WILL BE OPERATED. A WRITTEN REPORT SHALL BE SUBMITTED TO THE SCAOMD WITHIN 60 DAYS UPON SOURCE TESTS COMPLETION. [RULE 204, 217, 402, 1401]
- 11. SMOKE BOMB TESTS SHALL BE CONDUCTED INITIALLY AND, THEREAFTER, EVERY THREE (3) YEARS TO DEMONSTRATE UNIFORM DISTRIBUTION OF AIR FLOWS OR IDENTIFY RESTRICTED OR CHANNELED AIR FLOW THAT NEEDS IMPROVEMENT. **[RULE 204]**
- 12. ANY BREAKDOWN OR MALFUNCTION OF THIS EQUIPMENT RESULTING IN EXCESSIVE ODOR EMISSIONS INTO THE ATMOSPHERE SHALL BE REPORTED TO THE SCAOMD WITHIN TWENTY FOUR HOURS AFTER OCCURRENCE, AND IMMEDIATE REMEDIAL MEASURES SHALL BE UNDERTAKEN TO CORRECT THE PROBLEM AND PREVENT FURTHER EMISSIONS INTO THE ATMOSPHERE. [RULE 430, 402]
- 13. ALL RECORDS REQUIRED BY THIS PERMIT SHALL BE KEPT AND MAINTAINED FOR AT LEAST FIVE YEARS, AND SHALL BE MADE AVAILABLE TO AOMD PERSONNEL UPON REQUEST. [RULE 204]



Section H Page 13 Facility I.D. #: 029110 Revision #: 09 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 545004 Granted as of 10/17/2013

Equipment Description:

MODIFICATION TO BOILER, NO. 1, WITH PERMIT TO OPERATE D94235, BY THE REMOVAL OF THE EXISTING BURNER AND THE ADDITION OF A NEW BURNER, AMERICAN COMBUSTION TECHNOLOGY OR EQUAL, MODEL SLE-05-250 OR EQUAL, 10,205,800 BTU PER HOUR MAXIMUM, DIGESTER GAS AND NATURAL GAS (AS SECONDARY FUEL), AND REHABILITATION OF ANCILLARY EQUIPMENT

Conditions:

- 1. CONSTRUCTION AND OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS BOILER SHALL BE FIRED ON DIGESTER GAS AND OR NATURAL GAS ONLY. EXCEPT FOR PILOT GAS, NATURAL GAS SHALL ONLY BE USED IF DIGESTER GAS IS NOT AVAILABLE IN SUFFICIENT AMOUNT.

 [RULE 204]
- 4. A FUEL METER SHALL BE INSTALLED AND MAINTAINED IN THE FUEL SUPPLY LINE(S) TO MEASURE, INDICATE AND RECORD THE AMOUNT OF FUEL(S) (SCFM) BURNED IN THIS EQUIPMENT.

 [RULE 1303 (b) (1) & 1303 (b) (2) MODELING & OFFSET]
- 5. WHEN IN OPERATION, TOTAL HEAT INPUT FOR THIS EQUIPMENT SHALL NOT EXCEED 10, 205, 800 BTU/HR. A DAILY LOG SHALL BE KEPT, INDICATING THE TOTAL HEATING VALUE (BTU/SCF) OF FUEL BURNED IN THIS EQUIPMENT, BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING.
 [RULE 1303 (b) (1) & 1303 (b) (2) MODELING & OFFSET]
- 6. THIS EQUIPMENT SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE THE COMBUSTION AIR AND FUEL RATE AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED PERIODICALLY, ACCORDING TO THE MANUFACTURER'S SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME BURNER FIRING RATE.

 [RULE 1146]
- 7. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
 [RULE 1303(a) (1)-BACT]

Section H Page 14
Facility I.D. #: 029110
Revision #: 09
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 8. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT AN INITIAL PERFORMANCE SOURCE TESTS, FOR EACH FUEL, UNDER THE FOLLOWING CONDITIONS:
 - A. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THIS TEST.
 - B. A SOURCE TEST PROTOCOL SHALL BE SUBMITTED TO AQMD WITHIN 30 DAYS OF INITIAL START UP AND SHALL BE APPROVED BY AQMD BEFORE THE TEST COMMENCES. THE PROTOCOL SHALL INCLUDE PROPOSED OPERATING CONDITIONS OF THE EQUIPMENT DURING THE TEST, AND A DESCRIPTION OF ALL SAMPLING AND ANALYTICAL PROCEDURES TO BE USED.
 - C. SOURCE TESTING SHALL BE CONDUCTED WITHIN 60 CALENDAR DAYS AFTER NORMAL OPERATION OF THE EQUIPMENT HAS BEEN ESTABLISHED, BUT NO LATER THAN 180 DAYS AFTER INITIAL START UP.
 - D. THE INITIAL PERFORMANCE SOURCE TESTS SHALL BE PERFORMED WHEN THE BOILER IS OPERATING AT MAXIMUM, MINIMUM AND AVERAGE LOAD FOR EACH FUEL (DIGESTER GAS AND NATURAL GAS) TO BE BURNED. THE SAMPLING TIME AT EACH LOAD SHALL BE FOR A MINIMUM OF 15 CONSECUTIVE MINUTES.
 - E. TWO COPIES OF THE SOURCE TEST RESULTS SHALL BE SUBMITTED TO AQMD, ATTN. GAURANG RAWAL, WITHIN 60 DAYS OF THE TESTS COMPLETION. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO, THE FOLLOWING:

FUEL FLOW RATE (EACH FUEL)
FLUE GAS FLOW RATE (EACH FUEL)
TOTAL HEAT INPUT RATE, BTU/HR
TOTAL NON-METHANE ORGANICS (EXHAUST)
SPECIATED TRACE ORGANICS (EXHAUST, DIGESTER GAS)
TOTAL PARTICULATES (EXHAUST)
OXIDES OF NITROGEN (EXHAUST)
CARBON MONOXIDE (EXHAUST)
OXYGEN
DIGESTER GAS BTU (HHV), AND TOTAL SULFUR CONTENT (AS H2S, PPMV)

THE REPORT SHALL PRESENT THE EMISSIONS DATA IN PARTS PER MILLION (PPMV) ON A DRY BASIS, POUNDS PER HOUR, AND LBS/MMBTU. [RULE 217, RULE 404, RULE 1146, RULE 1303(A) (1), 1303 (B) (1), 1303(B) (2) - BACT, MODELING AND OFFSET, 1401]

9. THE SOURCE TEST PROTOCOL AND REPORT, PER CONDITION NO. 8, SHALL BE SUBMITTED TO, SCAQMD – ATTN. GAURANG RAWAL

ENERGY/ PUBLIC SERVICES/WASTE MGMT. / TERMINALS - PERMITTING ENGINEERING AND COMPLIANCE DIVISION 21865 COPLEY DRIVE DIAMOND BAR, CA 91765



Section H Page 15 Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

10. EMISSIONS RESULTING FROM THIS EQUIPMENT SHALL NOT EXCEED THE FOLLOWING:

POLLUTANT	POUNDS PER DAY			
CO	90.6			
NOx	5.52 (3.1 WITH NATURAL GAS)			
PM10	3.1			
ROG	2.6			
SOx	1.4			
[RULE 1146, RULE 1303(a) (1), 1303(b) (2) - OFFSET]				

Periodic Monitoring:

11. THE OPERATOR, AT LEAST ONCE EVERY FIVE YEARS, SHALL DETERMINE COMPLIANCE WITH THE EMISSION LIMITS IN CONDITION NO. 10 OF THIS PERMIT USING AQMD-APPROVED TEST METHODS. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS. RULE 1146 COMPLIANCE TESTS MAY BE USED TO SATISFY PART OF THIS REQUIREMENT PROVIDED THAT MASS RATES ARE ALSO REPORTED. TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATIONS LIMITS THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

[RULE 1146, RULE 1303(a)(1) – BACT, 1303(b) (2) - OFFSET, RULE 3004 (a) (4) – PERIODIC

[RULE 1146, RULE 1303(a)(1) – BACT, 1303(b) (2) - OFFSET, RULE 3004 (a) (4) – PERIODIC MONITORING]

Emissions and Requirements:

- 12. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
 - CO: 2000 PPMV, RULE 407
 - CO: 400 PPMV, @ 3% O2, DRY BASIS, RULE 1146
 - NOx: 30 PPMV, @ 3% O2, DRY BASIS, RULE 1146 (UNTIL 1/1/2015)
 - NOx: 15 PPMV, @ 3% O2, DRY BASIS, ON AND AFTER JANUARY 1, 2015, DIGESTER GAS,
 - **RULE 1146**
 - NOx: 9 PPMV, @ 3% O2, DRY BASIS, ON AND AFTER JANUARY 1, 2015, NATURAL GAS, RULE
 - PM: RULE 404, SEE APPENDIX B.
 - PM: 0.1 gr/scf, RULE 409
 - SO2: 500 PPMV AS SO2, ORANGE COUNTY, RULE 53
 - H2S: 40 PPMV TOTAL SULFUR, DIGESTER GAS



Section H Page 16
Facility I.D. #: 029110
Revision #: 09
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 545005 Granted as of 10/17/2013

Equipment Description:

MODIFICATION TO BOILER, NO. 2, WITH PERMIT TO OPERATE D94232, BY THE REMOVAL OF THE EXISTING BURNER AND THE ADDITION OF A NEW BURNER, AMERICAN COMBUSTION TECHNOLOGY OR EQUAL, MODEL SLE-05-250 OR EQUAL, 10,205,800 BTU PER HOUR MAXIMUM, DIGESTER GAS AND NATURAL GAS (AS SECONDARY FUEL), AND REHABILITATION OF ANCILLARY EQUIPMENT

Conditions:

- 1. CONSTRUCTION AND OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS BOILER SHALL BE FIRED ON DIGESTER GAS AND OR NATURAL GAS ONLY. EXCEPT FOR PILOT GAS, NATURAL GAS SHALL ONLY BE USED IF DIGESTER GAS IS NOT AVAILABLE IN SUFFICIENT AMOUNT.

 [RULE 204]
- 4. A FUEL METER SHALL BE INSTALLED AND MAINTAINED IN THE FUEL SUPPLY LINE(S) TO MEASURE, INDICATE AND RECORD THE AMOUNT OF FUEL(S) (SCFM) BURNED IN THIS EQUIPMENT.

 [RULE 1303 (b) (1) & 1303 (b) (2) MODELING & OFFSET]
- 5. WHEN IN OPERATION, TOTAL HEAT INPUT FOR THIS EQUIPMENT SHALL NOT EXCEED 10, 205, 800 BTU/HR. A DAILY LOG SHALL BE KEPT, INDICATING THE TOTAL HEATING VALUE (BTU/SCF) OF FUEL BURNED IN THIS EQUIPMENT, BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING.
 [RULE 1303 (b) (1) & 1303 (b) (2) MODELING & OFFSET]
- 6. THIS EQUIPMENT SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE THE COMBUSTION AIR AND FUEL RATE AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED PERIODICALLY, ACCORDING TO THE MANUFACTURER'S SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME BURNER FIRING RATE.

 [RULE 1146]

Section H Page 17 Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

7. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.

[RULE 1303(a) (1)-BACT]

- 8. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT AN INITIAL PERFORMANCE SOURCE TESTS, FOR EACH FUEL, UNDER THE FOLLOWING CONDITIONS:
 - A. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THIS TEST.
 - B. A SOURCE TEST PROTOCOL SHALL BE SUBMITTED TO AQMD WITHIN 30 DAYS OF INITIAL START UP AND SHALL BE APPROVED BY AQMD BEFORE THE TEST COMMENCES. THE PROTOCOL SHALL INCLUDE PROPOSED OPERATING CONDITIONS OF THE EQUIPMENT DURING THE TEST, AND A DESCRIPTION OF ALL SAMPLING AND ANALYTICAL PROCEDURES TO BE USED.
 - C. SOURCE TESTING SHALL BE CONDUCTED WITHIN 60 CALENDAR DAYS AFTER NORMAL OPERATION OF THE EQUIPMENT HAS BEEN ESTABLISHED, BUT NO LATER THAN 180 DAYS AFTER INITIAL START UP.
 - D. THE INITIAL PERFORMANCE SOURCE TESTS SHALL BE PERFORMED WHEN THE BOILER IS OPERATING AT MAXIMUM, MINIMUM AND AVERAGE LOAD FOR EACH FUEL (DIGESTER GAS AND NATURAL GAS) TO BE BURNED. THE SAMPLING TIME AT EACH LOAD SHALL BE FOR A MINIMUM OF 15 CONSECUTIVE MINUTES.
 - E. TWO COPIES OF THE SOURCE TEST RESULTS SHALL BE SUBMITTED TO AQMD, ATTN. GAURANG RAWAL, WITHIN 60 DAYS OF THE TESTS COMPLETION. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO, THE FOLLOWING:

FUEL FLOW RATE (EACH FUEL)
FLUE GAS FLOW RATE (EACH FUEL)
TOTAL HEAT INPUT RATE, BTU/HR
TOTAL NON-METHANE ORGANICS (EXHAUST)
SPECIATED TRACE ORGANICS (EXHAUST, DIGESTER GAS)
TOTAL PARTICULATES (EXHAUST)
OXIDES OF NITROGEN (EXHAUST)
CARBON MONOXIDE (EXHAUST)
OXYGEN
DIGESTER GAS BTU (HHV), AND TOTAL SULFUR CONTENT (AS H2S, PPMV)

THE REPORT SHALL PRESENT THE EMISSIONS DATA IN PARTS PER MILLION (PPMV) ON A DRY BASIS, POUNDS PER HOUR, AND LBS/MMBTU. [RULE 217, RULE 404, RULE 1146, RULE 1303(A) (1), 1303 (B) (1), 1303(B) (2) - BACT, MODELING AND OFFSET, 1401]

9. THE SOURCE TEST PROTOCOL AND REPORT, PER CONDITION NO. 8, SHALL BE SUBMITTED TO, SCAQMD – ATTN. GAURANG RAWAL

ENERGY/ PUBLIC SERVICES/WASTE MGMT. / TERMINALS - PERMITTING

ENGINEERING AND COMPLIANCE DIVISION

21865 COPLEY DRIVE

DIAMOND BAR, CA 91765



Section H Page 18 Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

10. EMISSIONS RESULTING FROM THIS EQUIPMENT SHALL NOT EXCEED THE FOLLOWING:

<u>POLLUTANT</u>	POUNDS PER DAY
CO	90.6
NOx	5.52 (3.1 WITH NATURAL GAS)
PM10	3.1
ROG	2.6
SOx	1.4
[RULE 1146, RULE 1303(a) (1),	1303(b) (2) - OFFSET]

Periodic Monitoring:

11. THE OPERATOR, AT LEAST ONCE EVERY FIVE YEARS, SHALL DETERMINE COMPLIANCE WITH THE EMISSION LIMITS IN CONDITION NO. 10 OF THIS PERMIT USING AQMD-APPROVED TEST METHODS. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS. RULE 1146 COMPLIANCE TESTS MAY BE USED TO SATISFY PART OF THIS REQUIREMENT PROVIDED THAT MASS RATES ARE ALSO REPORTED. TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATIONS LIMITS THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

[RULE 1146, RULE 1303(a)(1) – BACT, 1303(b) (2) - OFFSET, RULE 3004 (a) (4) – PERIODIC MONITORING]

Emissions and Requirements:

12. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407

CO: 400 PPMV, @ 3% O2, DRY BASIS, RULE 1146

NOx: 30 PPMV, @ 3% O2, DRY BASIS, RULE 1146 (UNTIL 1/1/2015)

NOx: 15 PPMV, @ 3% O2, DRY BASIS, ON AND AFTER JANUARY 1, 2015, DIGESTER GAS,

RULE 1146

NOx: 9 PPMV, @ 3% O2, DRY BASIS, ON AND AFTER JANUARY 1, 2015, NATURAL GAS, RULE

1146

PM: RULE 404, SEE APPENDIX B.

PM: 0.1 gr/scf, RULE 409

SO2: 500 PPMV AS SO2, ORANGE COUNTY, RULE 53

H2S: 40 PPMV TOTAL SULFUR, DIGESTER GAS

Section H Page 19 Facility I.D. #: 029110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 546364 Granted as of 4/16/2014

Equipment Description:

MODIFICATIONS TO THE RESOURCE RECOVERY SYSTEM NO. 1 (G27394) CONSISTING OF:

INTERNAL COMBUSTION ENGINE (CG1-HB), COOPER BESSMER, SPARK IGNITION, FOUR 1. STROKE, WITH A MODIFIED TURBOCHARGED-INTERCOOLED V-16 TYPE, MODEL NO. LSVB-16-SGC, 4166 HP, NATURAL GAS AND/OR DIGESTER GAS FIRED, DRIVING A 3000 KW ELECTRIC GENERATOR, WITH AN EXHAUST HEAT RECOVERY STEAM GENERATOR, 6,010,200 BTU/HR CAPACITY, UNFIRED.

BY THE ADDITION OF;

DIGESTER GAS CLEANING SYSTEM (DGCS), THREE VESSELS, EACH CONTAINING MINIMUM OF 2. 9,900 LBS OF MEDIA, TOTAL 2100 CFM CAPACITY, WITH ASSOCIATED PIPING AND VALVES.

COMMON TO FIVE ENGINES (CG1-HB, CG2-HB, CG3-HB, CG4-HB AND CG5-HB)

Conditions:

- OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW. [RULE 204]
- THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING 2. CONDITION AT ALL TIMES. [RULE 204]
- THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION. 3. [RULE 204]
- AT LEAST 30 DAYS PRIOR TO INSTALLATION OF THE EQUIPMENT, ORANGE COUNTY SANITATION DISTRICT (OCSD) SHALL PROVIDE TO SCAQMD FINAL DESIGN DRAWINGS, PROCESS AND FLOW DIAGRAM, CONTROLS, EQUIPMENT SPECIFICATIONS (MAKE, MODEL, SIZE AND MAXIMUM CAPACITY). [RULE 204]
- EFFECTIVE JANUARY 1, 2016, THIS EQUIPMENT SHALL ONLY BE VENTED TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND HAS A VALID PERMIT TO CONSTRUCT OR OPERATE ISSUED BY THE SCAQMD. [RULE 1110.2]
- THIS ENGINE SHALL HAVE AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER TO 6. DETERMINE THE ENGINE ELAPSED OPERATING TIME. [RULE 1110.2]



Section H Page 20 Facility I.D. #: 029110 Revision #: 09 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 7. A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE DIGESTER GAS SUPPLY LINE TO THE ENGINE TO MEASURE AND RECORD THE QUANTITY OF DIGESTER GAS (IN SCFM) BURNED.

 [RULE 204]
- 8. SAMPLING PORT SHALL BE INSTALLED FOR THE INLET GAS LINE TO THE ENGINE TO ALLOW THE COLLECTION OF A FUEL GAS SAMPLE.
 [RULE 204]
- 9. MONTHLY READINGS OF THE BTU CONTENT OF DIGESTER GAS (BTU/SCF) SUPPLIED TO THE ENGINE SHALL BE TAKEN USING AN INSTRUMENT APPROVED BY THE SCAQMD. ALL RESULTS SHALL BE RECORDED.
 [RULE 204]
- 10. ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF THE DAY. [RULE 204]
- 11. THE TOTAL HEAT INPUT OF GASEOUS FUEL BURNED IN THIS ENGINE SHALL NOT EXCEED 33 MM BTU PER HOUR. A LOG SHALL BE KEPT INDICATING THE TOTAL HEATING VALUE OF FUEL GAS BURNED IN THIS ENGINE BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING.

 [RULE 1303 (b) (1) AND 1303 (b) (2)-MODELING AND EMISSIONS OFFSET]
- 12. THIS EQUIPMENT SHALL BE OPERATED IN SUCH A MANNER THAT THE FOLLOWING EMISSION RATES ARE NOT EXCEEDED.

AIR CONTAMINANT

CARBON MONOXIDE 600 PPMV AT 15% O2
PARTICULATES (PM10) 0.0058 GRAINS/ DSCF
ROG OR TNMHC (AS CARBON) 115 PPMV AT 15% O2

[BLUE 1202 (a) (1) 1202(b) (1) AND 1202 (b) (2) PACT MODEL INC. AND 1202 (b) (c) PMV AT 15% O2

[RULE 1303 (a) (1), 1303(b) (1) AND 1303 (b) (2)-BACT, MODELING AND EMISSIONS OFFSET]

- 13. EFFECTIVE JANUARY 1, 2016, THIS EQUIPMENT SHALL MEET THE EMISSIONS LIMITS (EXHAUST) OF TABLE III-B IN RULE 1110.2 (d) (1) (C), UNLESS THE OPERATOR DEMONSTRATES COMPLIANCE WITH THE LIMITS AND SCHEDULE IN RULE 1110.2 (d) (1) (H). [RULE 1110.2]
- 14. THE COMBINED EMISSIONS FROM THE FOUR (4) CGS ENGINES, USING CALENDAR MONTHLY EMISSIONS DIVIDED BY 30, SHALL NOT EXCEED THE FOLLOWING (UNTIL JANUARY 1, 2016):

AIR CONTAMINANT	LBS/DAY
CARBON MONOXIDE	2,644
NITROGEN OXIDES (AS NO2)	828
PARTICULATES (PM10)	72
ROG OR TNMHC (AS CH4)	372
SULFUR DIOXIDE	84
IRULE 1303 (b) (2)-EMISSIONS OFFSI	ETI



Section H Page 21 Facility I.D. #: 029110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

15. POST-COMBUSTION CONTROLLED EMISSIONS, INTO THE ATMOSPHERE, FROM THIS EQUIPMENT SHALL NOT EXCEED THE FOLLOWING:

AIR CONTAMINANT	LBS/DAY	
CARBON MONOXIDE	497.6	
NITROGEN OXIDES (AS NO2)	36.0	
PARTICULATES (PM10)	18.0	
ROG OR TNMHC (AS CH4)	25.60	
SULFUR DIOXIDE	21.0	
[RULE 204]		

- THE OPERATOR SHALL INSTALL AND MAINTAIN A CONTINUOUS EMISSION MONITORING SYSTEM (CEMS), OR AN ALTERNATIVE SYSTEM, AS APPROVED BY THE EXECUTIVE OFFICER, TO MEASURE THE ENGINE EXHAUST FOR CO, NOx AND O2 CONCENTRATIONS ON A DRY BASIS. EXCEPT DURING SHUTDOWN FOR MAINTENANCE OF THE SYSTEM. IN ADDITION, THE CEMS SHALL CONVERT THE ACTUAL CO AND NOx TO MASS EMISSION RATES; AND RECORD THE ACTUAL AND CORRECTED ENGINE NOx CONCENTRATION AT 15% O2 AND MASS EMISSION RATES ON AN HOURLY AND DAILY BASIS. [RULE 203, 218, RULE 1110.2]
- WITHIN 180 DAYS AFTER INITIAL START-UP, (POST- MODIFICATION OF FIVE ENGINES; CG1-HB, 17. CG2-HB, CG3-HB, CG4-HB AND CG5-HB), THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS, AT MAXIMUM ACHIEVABLE LOAD, IN ACCORDANCE WITH THE APPROVED TEST PROCEDURES AND, FURNISH THE SCAOMD WRITTEN RESULTS OF SUCH PERFORMANCE TESTS WITHIN 45 DAYS AFTER TESTING. ALL SOURCE TESTING AND ANALYTICAL METHODS SHALL BE SUBMITTED FOR APPROVAL, AT LEAST 30 DAYS PRIOR TO START OF THE TESTS TO THE SCAQMD, ENERGY/PUBLIC SERVICES/WASTE MANAGEMENT/TERMINAL PERMITTING, 21865 COPLEY DRIVE, DIAMOND BAR, CA 91765. THE SUBMITTAL SHALL INCLUDE A COPY OF THE ACTIVE PERMIT. WRITTEN RESULTS OF SUCH PERFORMANCE TESTS SHALL BE SUBMITTED WITHIN 60 DAYS AFTER TESTING. NOTICE SHALL BE PROVIDED TO THE SCAOMD 10 DAYS PRIOR TO THE TESTING SO THAT AN OBSERVER MAY BE PRESENT. THE TESTS SHALL INCLUDE, BUT MAY NOT BE LIMITED TO:
 - TOTAL NON-METHANE HYDROCARBONS (EXHAUST ONLY). A.
 - B. CARBON MONOXIDE (EXHAUST ONLY)
 - C. TOTAL PARTICULATE MATTER (EXHAUST ONLY).
 - OXIDES OF NITROGEN (EXHAUST ONLY). D.
 - E. OXYGEN (EXHAUST ONLY)
 - F. **FLOW RATE**
 - G. MOISTURE (EXHAUST ONLY)
 - TOXIC AIR CONTAMINANTS (EXHAUST ONLY), FOR ONE ENGINE PER YEAR H.
 - ALDEHYDES (EXHAUST ONLY), FOR ONE ENGINE PER YEAR I.
 - TOTAL REDUCED SULFUR COMPOUNDS (DIGESTER GAS ONLY) J.
 - K. NITROGEN AND CARBON DIOXIDE
 - BTU CONTENTS (DIGESTER GAS ONLY) L.
 - M. **POWER OUTPUT**



Section H Page 22
Facility I.D. #: 029110
Revision #: 09
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

THE ROUTINE COMPLIANCE SOURCE TESTING SHALL BE CONDUCTED IN ACCORDANCE WITH RULE 1110.2 REQUIREMENTS AND ABOVE REQUIREMENTS. APPROPRIATE SCAQMD STAFF SHALL BE NOTIFIED A MINIMUM OF 45 DAYS IN ADVANCE OF COMPLIANCE SOURCE TESTING TO DETERMINE IF PREVIOUSLY APPROVED SOURCE TEST PROTOCOL MAY BE USED IF NO EQUIPMENT AND PROCESS CHANGES HAVE BEEN MADE. [RULE 404], [RULE 1110.2], [RULE 1303(b) (1) AND 1303(b) (2) - MODELING AND EMISSION

OFFSET]

18. RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 204]

Emissions and Requirements:

19. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: RULE 1110.2 LIMIT NOx: RULE 1110.2 LIMIT

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS.

VOC (TNMHC): RULE 1110.2 LIMIT

H2S: RULE 431.1

Section H Page 23 Facility I.D. #: 029110 Revision #: 09 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 546365 Granted as of 4/16/2014

Equipment Description:

MODIFICATIONS TO THE RESOURCE RECOVERY SYSTEM NO. 2 (G27395) CONSISTING OF:

1. INTERNAL COMBUSTION ENGINE (CG2-HB), COOPER BESSMER, SPARK IGNITION, FOUR STROKES, WITH A MODIFIED TURBOCHARGED-INTERCOOLED V-16 TYPE, MODEL NO. LSVB-16-SGC, 4166 HP, NATURAL GAS AND/OR DIGESTER GAS FIRED, DRIVING A 3000 KW ELECTRIC GENERATOR, WITH AN EXHAUST HEAT RECOVERY STEAM GENERATOR, 6,010,200 BTU/HR CAPACITY, UNFIRED.

BY THE ADDITION OF;

3. DIGESTER GAS CLEANING SYSTEM (DGCS), THREE VESSELS, EACH CONTAINING MINIMUM OF 9,900 LBS OF MEDIA, TOTAL 2100 CFM CAPACITY, WITH ASSOCIATED PIPING AND VALVES.

COMMON TO FIVE ENGINES (CG1-HB, CG2-HB, CG3-HB, CG4-HB AND CG5-HB)

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION. [RULE 204]
- 4. AT LEAST 30 DAYS PRIOR TO INSTALLATION OF THE EQUIPMENT, ORANGE COUNTY SANITATION DISTRICT (OCSD) SHALL PROVIDE TO SCAQMD FINAL DESIGN DRAWINGS, PROCESS AND FLOW DIAGRAM, CONTROLS, EQUIPMENT SPECIFICATIONS (MAKE, MODEL, SIZE AND MAXIMUM CAPACITY).

 [RULE 204]
- 5. EFFECTIVE JANUARY 1, 2016, THIS EQUIPMENT SHALL ONLY BE VENTED TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND HAS A VALID PERMIT TO CONSTRUCT OR OPERATE ISSUED BY THE SCAQMD.
 [RULE 1110.2]
- 6. THIS ENGINE SHALL HAVE AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER TO DETERMINE THE ENGINE ELAPSED OPERATING TIME.
 [RULE 1110.2]



Section H Page 24 Facility I.D. #: 029110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

7. A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE DIGESTER GAS SUPPLY LINE TO THE ENGINE TO MEASURE AND RECORD THE QUANTITY OF DIGESTER GAS (IN SCFM) BURNED. [RULE 204]

- SAMPLING PORT SHALL BE INSTALLED FOR THE INLET GAS LINE TO THE ENGINE TO ALLOW 8. THE COLLECTION OF A FUEL GAS SAMPLE. [RULE 204]
- MONTHLY READINGS OF THE BTU CONTENT OF DIGESTER GAS (BTU/SCF) SUPPLIED TO THE 9. ENGINE SHALL BE TAKEN USING AN INSTRUMENT APPROVED BY THE SCAOMD. ALL RESULTS SHALL BE RECORDED. [RULE 204]
- ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF THE DAY. 10. **IRULE 2041**
- THE TOTAL HEAT INPUT OF GASEOUS FUEL BURNED IN THIS ENGINE SHALL NOT EXCEED 33 11. MM BTU PER HOUR. A LOG SHALL BE KEPT INDICATING THE TOTAL HEATING VALUE OF FUEL GAS BURNED IN THIS ENGINE BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING. [RULE 1303 (b) (1) AND 1303 (b) (2)-MODELING AND EMISSIONS OFFSET]
- THIS EQUIPMENT SHALL BE OPERATED IN SUCH A MANNER THAT THE FOLLOWING EMISSION 12. RATES ARE NOT EXCEEDED.

AIR CONTAMINANT

CARBON MONOXIDE 600 PPMV AT 15% O2 0.0058 GRAINS/ DSCF PARTICULATES (PM10) ROG OR TNMHC (AS CARBON) 115 PPMV AT 15% O2 [RULE 1303 (a) (1), 1303(b) (1) AND 1303 (b) (2)-BACT, MODELING AND EMISSIONS OFFSET]

EFFECTIVE JANUARY 1, 2016, THIS EQUIPMENT SHALL MEET THE EMISSIONS LIMITS (EXHAUST) 13.

OF TABLE III-B IN RULE 1110.2 (d) (1) (C), UNLESS THE OPERATOR DEMONSTRATES COMPLIANCE WITH THE LIMITS AND SCHEDULE IN RULE 1110.2 (d) (1) (H).

[RULE 1110.2]

THE COMBINED EMISSIONS FROM THE FOUR (4) CGS ENGINES, USING CALENDAR MONTHLY EMISSIONS DIVIDED BY 30, SHALL NOT EXCEED THE FOLLOWING (UNTIL JANUARY 1, 2016):

AIR CONTAMINANT	LBS/DAY
CARBON MONOXIDE	2,644
NITROGEN OXIDES (AS NO2)	828
PARTICULATES (PM10)	72
ROG OR TNMHC (AS CH4)	372
SULFUR DIOXIDE	84
[RULE 1303 (b) (2)-EMISSIONS OFFSET]	



Section H Page 25 Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

15. POST-COMBUSTION CONTROLLED EMISSIONS, INTO THE ATMOSPHERE, FROM THIS EQUIPMENT SHALL NOT EXCEED THE FOLLOWING:

AIR CONTAMINANT	LBS/DAY
CARBON MONOXIDE	497.6
NITROGEN OXIDES (AS NO2)	36.0
PARTICULATES (PM10)	18.0
ROG OR TNMHC (AS CH4)	25.60
SULFUR DIOXIDE	21.0
[RULE 204]	

- 16. THE OPERATOR SHALL INSTALL AND MAINTAIN A CONTINUOUS EMISSION MONITORING SYSTEM (CEMS), OR AN ALTERNATIVE SYSTEM, AS APPROVED BY THE EXECUTIVE OFFICER, TO MEASURE THE ENGINE EXHAUST FOR CO, NOx AND O2 CONCENTRATIONS ON A DRY BASIS, EXCEPT DURING SHUTDOWN FOR MAINTENANCE OF THE SYSTEM. IN ADDITION, THE CEMS SHALL CONVERT THE ACTUAL CO AND NOX TO MASS EMISSION RATES; AND RECORD THE ACTUAL AND CORRECTED ENGINE NOX CONCENTRATION AT 15% O2 AND MASS EMISSION RATES ON AN HOURLY AND DAILY BASIS.

 [RULE 203, 218, RULE 1110.2]
- 17. WITHIN 180 DAYS AFTER INITIAL START-UP, (POST- MODIFICATION OF FIVE ENGINES; CG1-HB, CG2-HB, CG3-HB, CG4-HB AND CG5-HB), THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS, AT MAXIMUM ACHIEVABLE LOAD, IN ACCORDANCE WITH THE APPROVED TEST PROCEDURES AND, FURNISH THE SCAQMD WRITTEN RESULTS OF SUCH PERFORMANCE TESTS WITHIN 45 DAYS AFTER TESTING. ALL SOURCE TESTING AND ANALYTICAL METHODS SHALL BE SUBMITTED FOR APPROVAL, AT LEAST 30 DAYS PRIOR TO START OF THE TESTS TO THE SCAQMD, ENERGY/PUBLIC SERVICES/WASTE MANAGEMENT/TERMINAL PERMITTING, 21865 COPLEY DRIVE, DIAMOND BAR, CA 91765. THE SUBMITTAL SHALL INCLUDE A COPY OF THE ACTIVE PERMIT. WRITTEN RESULTS OF SUCH PERFORMANCE TESTS SHALL BE SUBMITTED WITHIN 60 DAYS AFTER TESTING. NOTICE SHALL BE PROVIDED TO THE SCAQMD 10 DAYS PRIOR TO THE TESTING SO THAT AN OBSERVER MAY BE PRESENT. THE TESTS SHALL INCLUDE, BUT MAY NOT BE LIMITED TO:
 - A. TOTAL NON-METHANE HYDROCARBONS (EXHAUST ONLY).
 - B. CARBON MONOXIDE (EXHAUST ONLY)
 - C. TOTAL PARTICULATE MATTER (EXHAUST ONLY).
 - D. OXIDES OF NITROGEN (EXHAUST ONLY).
 - E. OXYGEN (EXHAUST ONLY)
 - F. FLOW RATE
 - G. MOISTURE (EXHAUST ONLY)
 - H. TOXIC AIR CONTAMINANTS (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
 - I. ALDEHYDES (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
 - J. TOTAL REDUCED SULFUR COMPOUNDS (DIGESTER GAS ONLY)
 - K. NITROGEN AND CARBON DIOXIDE
 - L. BTU CONTENTS (DIGESTER GAS ONLY)
 - M. POWER OUTPUT



Section H Page 26 Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

THE ROUTINE COMPLIANCE SOURCE TESTING SHALL BE CONDUCTED IN ACCORDANCE WITH RULE 1110.2 REQUIREMENTS AND ABOVE REQUIREMENTS. APPROPRIATE SCAQMD STAFF SHALL BE NOTIFIED A MINIMUM OF 45 DAYS IN ADVANCE OF COMPLIANCE SOURCE TESTING TO DETERMINE IF PREVIOUSLY APPROVED SOURCE TEST PROTOCOL MAY BE USED IF NO EQUIPMENT AND PROCESS CHANGES HAVE BEEN MADE.
[RULE 404], [RULE 1110.2], [RULE 1303(b) (1) AND 1303(b) (2) - MODELING AND EMISSION

[RULE 404], [RULE 1110.2], [RULE 1303(b) (1) AND 1303(b) (2) - MODELING AND EMISSION OFFSET]

18. RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 204]

Emissions and Requirements:

19. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: RULE 1110.2 LIMIT NOx: RULE 1110.2 LIMIT

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS.

VOC (TNMHC): RULE 1110.2 LIMIT

H2S: RULE 431.1



Section H Page 27 Facility 1.D. #: 029110 Revision #: 09 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 546366 Granted as of 4/16/2014

Equipment Description:

MODIFICATIONS TO THE RESOURCE RECOVERY SYSTEM NO. 3 (G27396) CONSISTING OF:

1. INTERNAL COMBUSTION ENGINE (CG3-HB), COOPER BESSMER, SPARK IGNITION, FOUR STROKES, WITH A MODIFIED TURBOCHARGED-INTERCOOLED V-16 TYPE, MODEL NO. LSVB-16-SGC, 4166 HP, NATURAL GAS AND/OR DIGESTER GAS FIRED, DRIVING A 3000 KW ELECTRIC GENERATOR, WITH AN EXHAUST HEAT RECOVERY STEAM GENERATOR, 6,010,200 BTU/HR CAPACITY, UNFIRED.

BY THE ADDITION OF:

4. DIGESTER GAS CLEANING SYSTEM (DGCS), THREE VESSELS, EACH CONTAINING MINIMUM OF 9,900 LBS OF MEDIA, TOTAL 2100 CFM CAPACITY, WITH ASSOCIATED PIPING AND VALVES.

COMMON TO FIVE ENGINES (CG1-HB, CG2-HB, CG3-HB, CG4-HB AND CG5-HB)

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION. [RULE 204]
- 4. AT LEAST 30 DAYS PRIOR TO INSTALLATION OF THE EQUIPMENT, ORANGE COUNTY SANITATION DISTRICT (OCSD) SHALL PROVIDE TO SCAQMD FINAL DESIGN DRAWINGS, PROCESS AND FLOW DIAGRAM, CONTROLS, EQUIPMENT SPECIFICATIONS (MAKE, MODEL, SIZE AND MAXIMUM CAPACITY).

 [RULE 204]
- 5. EFFECTIVE JANUARY 1, 2016, THIS EQUIPMENT SHALL ONLY BE VENTED TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND HAS A VALID PERMIT TO CONSTRUCT OR OPERATE ISSUED BY THE SCAQMD.

 [RULE 1110.2]
- 6. THIS ENGINE SHALL HAVE AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER TO DETERMINE THE ENGINE ELAPSED OPERATING TIME.
 [RULE 1110.2]



Section H Page 28 Facility I.D. #: 029110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE DIGESTER GAS 7. SUPPLY LINE TO THE ENGINE TO MEASURE AND RECORD THE OUANTITY OF DIGESTER GAS (IN SCFM) BURNED. [RULE 204]
- SAMPLING PORT SHALL BE INSTALLED FOR THE INLET GAS LINE TO THE ENGINE TO ALLOW 8. THE COLLECTION OF A FUEL GAS SAMPLE. [RULE 204]
- MONTHLY READINGS OF THE BTU CONTENT OF DIGESTER GAS (BTU/SCF) SUPPLIED TO THE 9. ENGINE SHALL BE TAKEN USING AN INSTRUMENT APPROVED BY THE SCAQMD. ALL RESULTS SHALL BE RECORDED. [RULE 204]
- 10. ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF THE DAY. [RULE 204]
- THE TOTAL HEAT INPUT OF GASEOUS FUEL BURNED IN THIS ENGINE SHALL NOT EXCEED 33 11. MM BTU PER HOUR. A LOG SHALL BE KEPT INDICATING THE TOTAL HEATING VALUE OF FUEL GAS BURNED IN THIS ENGINE BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING. [RULE 1303 (b) (1) AND 1303 (b) (2)-MODELING AND EMISSIONS OFFSET]
- THIS EQUIPMENT SHALL BE OPERATED IN SUCH A MANNER THAT THE FOLLOWING EMISSION 12. RATES ARE NOT EXCEEDED.

AIR CONTAMINANT

600 PPMV AT 15% O2 CARBON MONOXIDE PARTICULATES (PM10) 0.0058 GRAINS/ DSCF ROG OR TNMHC (AS CARBON) 115 PPMV AT 15% O2 [RULE 1303 (a) (1), 1303(b) (1) AND 1303 (b) (2)-BACT, MODELING AND EMISSIONS OFFSET]

- 13. EFFECTIVE JANUARY 1, 2016, THIS EQUIPMENT SHALL MEET THE EMISSIONS LIMITS (EXHAUST) OF TABLE III-B IN RULE 1110.2 (d) (1) (C), UNLESS THE OPERATOR DEMONSTRATES COMPLIANCE WITH THE LIMITS AND SCHEDULE IN RULE 1110.2 (d) (1) (H). [RULE 1110.2]
- THE COMBINED EMISSIONS FROM THE FOUR (4) CGS ENGINES, USING CALENDAR MONTHLY 14. EMISSIONS DIVIDED BY 30, SHALL NOT EXCEED THE FOLLOWING (UNTIL JANUARY 1, 2016):

AIR CONTAMINANT	LBS/DAY
CARBON MONOXIDE	2,644
NITROGEN OXIDES (AS NO2)	828
PARTICULATES (PM10)	72
ROG OR TNMHC (AS CH4)	372
SULFUR DIOXIDE	84
TRULE 1303 (b) (2)-EMISSIONS OFFSI	ETI



Section H Page 29 Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

15. POST-COMBUSTION CONTROLLED EMISSIONS, INTO THE ATMOSPHERE, FROM THIS EQUIPMENT SHALL NOT EXCEED THE FOLLOWING:

AIR CONTAMINANT	LBS/DAY
CARBON MONOXIDE	497.6
NITROGEN OXIDES (AS NO2)	36.0
PARTICULATES (PM10)	18.0
ROG OR TNMHC (AS CH4)	25.60
SULFUR DIOXIDE	21.0
[RULE 204]	

- 16. THE OPERATOR SHALL INSTALL AND MAINTAIN A CONTINUOUS EMISSION MONITORING SYSTEM (CEMS), OR AN ALTERNATIVE SYSTEM, AS APPROVED BY THE EXECUTIVE OFFICER, TO MEASURE THE ENGINE EXHAUST FOR CO, NOx AND O2 CONCENTRATIONS ON A DRY BASIS, EXCEPT DURING SHUTDOWN FOR MAINTENANCE OF THE SYSTEM. IN ADDITION, THE CEMS SHALL CONVERT THE ACTUAL CO AND NOX TO MASS EMISSION RATES; AND RECORD THE ACTUAL AND CORRECTED ENGINE NOX CONCENTRATION AT 15% O2 AND MASS EMISSION RATES ON AN HOURLY AND DAILY BASIS.

 [RULE 203, 218, RULE 1110.2]
- 17. WITHIN 180 DAYS AFTER INITIAL START-UP, (POST- MODIFICATION OF FIVE ENGINES; CG1-HB, CG2-HB, CG3-HB, CG4-HB AND CG5-HB), THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS, AT MAXIMUM ACHIEVABLE LOAD, IN ACCORDANCE WITH THE APPROVED TEST PROCEDURES AND, FURNISH THE SCAQMD WRITTEN RESULTS OF SUCH PERFORMANCE TESTS WITHIN 45 DAYS AFTER TESTING. ALL SOURCE TESTING AND ANALYTICAL METHODS SHALL BE SUBMITTED FOR APPROVAL, AT LEAST 30 DAYS PRIOR TO START OF THE TESTS TO THE SCAQMD, ENERGY/PUBLIC SERVICES/WASTE MANAGEMENT/TERMINAL PERMITTING, 21865 COPLEY DRIVE, DIAMOND BAR, CA 91765. THE SUBMITTAL SHALL INCLUDE A COPY OF THE ACTIVE PERMIT. WRITTEN RESULTS OF SUCH PERFORMANCE TESTS SHALL BE SUBMITTED WITHIN 60 DAYS AFTER TESTING. NOTICE SHALL BE PROVIDED TO THE SCAQMD 10 DAYS PRIOR TO THE TESTING SO THAT AN OBSERVER MAY BE PRESENT. THE TESTS SHALL INCLUDE, BUT MAY NOT BE LIMITED TO:
 - A. TOTAL NON-METHANE HYDROCARBONS (EXHAUST ONLY).
 - B. CARBON MONOXIDE (EXHAUST ONLY)
 - C. TOTAL PARTICULATE MATTER (EXHAUST ONLY).
 - D. OXIDES OF NITROGEN (EXHAUST ONLY).
 - E. OXYGEN (EXHAUST ONLY)
 - F. FLOW RATE
 - G. MOISTURE (EXHAUST ONLY)
 - H. TOXIC AIR CONTAMINANTS (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
 - I. ALDEHYDES (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
 - J. TOTAL REDUCED SULFUR COMPOUNDS (DIGESTER GAS ONLY)
 - K. NITROGEN AND CARBON DIOXIDE
 - L. BTU CONTENTS (DIGESTER GAS ONLY)
 - M. POWER OUTPUT



Section H Page 30 Facility I.D. #: 029110 Revision #: 09 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

THE ROUTINE COMPLIANCE SOURCE TESTING SHALL BE CONDUCTED IN ACCORDANCE WITH RULE 1110.2 REQUIREMENTS AND ABOVE REQUIREMENTS. APPROPRIATE SCAQMD STAFF SHALL BE NOTIFIED A MINIMUM OF 45 DAYS IN ADVANCE OF COMPLIANCE SOURCE TESTING TO DETERMINE IF PREVIOUSLY APPROVED SOURCE TEST PROTOCOL MAY BE USED IF NO EQUIPMENT AND PROCESS CHANGES HAVE BEEN MADE.

[RULE 404], [RULE 1110.2], [RULE 1303(b) (1) AND 1303(b) (2) - MODELING AND EMISSION OFFSET]

18. RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 204]

Emissions and Requirements:

19. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: RULE 1110.2 LIMIT NOX: RULE 1110.2 LIMIT

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS.

VOC (TNMHC): RULE 1110.2 LIMIT

H2S: RULE 431.1



Section H Page 31 Facility I.D. #: 029110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 546367 Granted as of 4/16/2014

Equipment Description:

MODIFICATIONS TO THE RESOURCE RECOVERY SYSTEM NO. 4 (G27397) CONSISTING OF:

INTERNAL COMBUSTION ENGINE (CG4-HB), COOPER BESSMER, SPARK IGNITION, FOUR 1. STROKES, WITH A MODIFIED TURBOCHARGED-INTERCOOLED V-16 TYPE, MODEL NO. LSVB-16-SGC, 4166 HP, NATURAL GAS AND/OR DIGESTER GAS FIRED, DRIVING A 3000 KW ELECTRIC GENERATOR, WITH AN EXHAUST HEAT RECOVERY STEAM GENERATOR, 6,010,200 BTU/HR CAPACITY, UNFIRED.

BY THE ADDITION OF;

DIGESTER GAS CLEANING SYSTEM (DGCS), THREE VESSELS, EACH CONTAINING MINIMUM OF 5. 9,900 LBS OF MEDIA, TOTAL 2100 CFM CAPACITY, WITH ASSOCIATED PIPING AND VALVES.

COMMON TO FIVE ENGINES (CG1-HB, CG2-HB, CG3-HB, CG4-HB AND CG5-HB)

- OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND 1. SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW. [RULE 204]
- THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING 2. CONDITION AT ALL TIMES. [RULE 204]
- THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION. 3. [RULE 204]
- AT LEAST 30 DAYS PRIOR TO INSTALLATION OF THE EQUIPMENT, ORANGE COUNTY SANITATION DISTRICT (OCSD) SHALL PROVIDE TO SCAQMD FINAL DESIGN DRAWINGS, PROCESS AND FLOW DIAGRAM, CONTROLS, EQUIPMENT SPECIFICATIONS (MAKE, MODEL, SIZE AND MAXIMUM CAPACITY). [RULE 204]
- EFFECTIVE JANUARY 1, 2016, THIS EQUIPMENT SHALL ONLY BE VENTED TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND HAS A VALID PERMIT TO CONSTRUCT OR OPERATE ISSUED BY THE SCAQMD. [RULE 1110.2]
- THIS ENGINE SHALL HAVE AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER TO DETERMINE THE ENGINE ELAPSED OPERATING TIME. [RULE 1110.2]



Section H Page 32 Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 7. A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE DIGESTER GAS SUPPLY LINE TO THE ENGINE TO MEASURE AND RECORD THE QUANTITY OF DIGESTER GAS (IN SCFM) BURNED.

 [RULE 204]
- 8. SAMPLING PORT SHALL BE INSTALLED FOR THE INLET GAS LINE TO THE ENGINE TO ALLOW THE COLLECTION OF A FUEL GAS SAMPLE.
 [RULE 204]
- 9. MONTHLY READINGS OF THE BTU CONTENT OF DIGESTER GAS (BTU/SCF) SUPPLIED TO THE ENGINE SHALL BE TAKEN USING AN INSTRUMENT APPROVED BY THE SCAQMD. ALL RESULTS SHALL BE RECORDED.
 [RULE 204]
- 10. ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF THE DAY. [RULE 204]
- 11. THE TOTAL HEAT INPUT OF GASEOUS FUEL BURNED IN THIS ENGINE SHALL NOT EXCEED 33 MM BTU PER HOUR. A LOG SHALL BE KEPT INDICATING THE TOTAL HEATING VALUE OF FUEL GAS BURNED IN THIS ENGINE BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING.
 [RULE 1303 (b) (1) AND 1303 (b) (2)-MODELING AND EMISSIONS OFFSET]
- 12. THIS EQUIPMENT SHALL BE OPERATED IN SUCH A MANNER THAT THE FOLLOWING EMISSION RATES ARE NOT EXCEEDED.

AIR CONTAMINANT

CARBON MONOXIDE 600 PPMV AT 15% O2
PARTICULATES (PM10) 0.0058 GRAINS/ DSCF
ROG OR TNMHC (AS CARBON) 115 PPMV AT 15% O2
[RULE 1303 (a) (1), 1303(b) (1) AND 1303 (b) (2)-BACT, MODELING AND EMISSIONS OFFSET]

- 13. EFFECTIVE JANUARY 1, 2016, THIS EQUIPMENT SHALL MEET THE EMISSIONS LIMITS (EXHAUST) OF TABLE III-B IN RULE 1110.2 (d) (1) (C), UNLESS THE OPERATOR DEMONSTRATES COMPLIANCE WITH THE LIMITS AND SCHEDULE IN RULE 1110.2 (d) (1) (H).

 [RULE 1110.2]
- 14. THE COMBINED EMISSIONS FROM THE FOUR (4) CGS ENGINES, USING CALENDAR MONTHLY EMISSIONS DIVIDED BY 30, SHALL NOT EXCEED THE FOLLOWING (UNTIL JANUARY 1, 2016):

AIR CONTAMINANT	LBS/DAY
CARBON MONOXIDE	2,644
NITROGEN OXIDES (AS NO2)	828
PARTICULATES (PM10)	72
ROG OR TNMHC (AS CH4)	372
SULFUR DIOXIDE	84
[RULE 1303 (b) (2)-EMISSIONS OFFSET]	



Section H Page 33 Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

15. POST-COMBUSTION CONTROLLED EMISSIONS, INTO THE ATMOSPHERE, FROM THIS EQUIPMENT SHALL NOT EXCEED THE FOLLOWING:

AIR CONTAMINANT	LBS/DAY	
CARBON MONOXIDE	497.6	
NITROGEN OXIDES (AS NO2)	36.0	
PARTICULATES (PM10)	18.0	
ROG OR TNMHC (AS CH4)	25.60	
SULFUR DIOXIDE	21.0	
[RULE 204]		

- 16. THE OPERATOR SHALL INSTALL AND MAINTAIN A CONTINUOUS EMISSION MONITORING SYSTEM (CEMS), OR AN ALTERNATIVE SYSTEM, AS APPROVED BY THE EXECUTIVE OFFICER, TO MEASURE THE ENGINE EXHAUST FOR CO, NOx AND O2 CONCENTRATIONS ON A DRY BASIS, EXCEPT DURING SHUTDOWN FOR MAINTENANCE OF THE SYSTEM. IN ADDITION, THE CEMS SHALL CONVERT THE ACTUAL CO AND NOX TO MASS EMISSION RATES; AND RECORD THE ACTUAL AND CORRECTED ENGINE NOX CONCENTRATION AT 15% O2 AND MASS EMISSION RATES ON AN HOURLY AND DAILY BASIS.

 [RULE 203, 218, RULE 1110.2]
- 17. WITHIN 180 DAYS AFTER INITIAL START-UP, (POST- MODIFICATION OF FIVE ENGINES; CG1-HB, CG2-HB, CG3-HB, CG4-HB AND CG5-HB), THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS, AT MAXIMUM ACHIEVABLE LOAD, IN ACCORDANCE WITH THE APPROVED TEST PROCEDURES AND, FURNISH THE SCAQMD WRITTEN RESULTS OF SUCH PERFORMANCE TESTS WITHIN 45 DAYS AFTER TESTING. ALL SOURCE TESTING AND ANALYTICAL METHODS SHALL BE SUBMITTED FOR APPROVAL, AT LEAST 30 DAYS PRIOR TO START OF THE TESTS TO THE SCAQMD, ENERGY/PUBLIC SERVICES/WASTE MANAGEMENT/TERMINAL PERMITTING, 21865 COPLEY DRIVE, DIAMOND BAR, CA 91765. THE SUBMITTAL SHALL INCLUDE A COPY OF THE ACTIVE PERMIT. WRITTEN RESULTS OF SUCH PERFORMANCE TESTS SHALL BE SUBMITTED WITHIN 60 DAYS AFTER TESTING. NOTICE SHALL BE PROVIDED TO THE SCAQMD 10 DAYS PRIOR TO THE TESTING SO THAT AN OBSERVER MAY BE PRESENT. THE TESTS SHALL INCLUDE, BUT MAY NOT BE LIMITED TO:
 - A. TOTAL NON-METHANE HYDROCARBONS (EXHAUST ONLY).
 - B. CARBON MONOXIDE (EXHAUST ONLY)
 - C. TOTAL PARTICULATE MATTER (EXHAUST ONLY).
 - D. OXIDES OF NITROGEN (EXHAUST ONLY).
 - E. OXYGEN (EXHAUST ONLY)
 - F. FLOW RATE
 - G. MOISTURE (EXHAUST ONLY)
 - H. TOXIC AIR CONTAMINANTS (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
 - I. ALDEHYDES (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
 - TOTAL REDUCED SULFUR COMPOUNDS (DIGESTER GAS ONLY)
 - K. NITROGEN AND CARBON DIOXIDE
 - L. BTU CONTENTS (DIGESTER GAS ONLY)
 - M. POWER OUTPUT



Section H Page 34 Facility I.D. #: 029110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

THE ROUTINE COMPLIANCE SOURCE TESTING SHALL BE CONDUCTED IN ACCORDANCE WITH RULE 1110.2 REQUIREMENTS AND ABOVE REQUIREMENTS. APPROPRIATE SCAQMD STAFF SHALL BE NOTIFIED A MINIMUM OF 45 DAYS IN ADVANCE OF COMPLIANCE SOURCE TESTING TO DETERMINE IF PREVIOUSLY APPROVED SOURCE TEST PROTOCOL MAY BE USED IF NO EQUIPMENT AND PROCESS CHANGES HAVE BEEN MADE.

[RULE 404], [RULE 1110.2], [RULE 1303(b) (1) AND 1303(b) (2) - MODELING AND EMISSION OFFSET1

18. RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST. [RULE 204]

Emissions and Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES 19. AND REGULATIONS:

CO: **RULE 1110.2 LIMIT RULE 1110.2 LIMIT** NOx:

RULE 404, SEE APPENDIX B FOR EMISSION LIMITS.

VOC (TNMHC): RULE 1110.2 LIMIT

H2S: **RULE 431.1**

Section H Page 35
Facility I.D. #: 029110
Revision #: 09
Date: February 5, 2015

FACILITY PERMIT TO OPERATE
ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 546368 Granted as of 4/16/2014

Equipment Description:

MODIFICATIONS TO THE RESOURCE RECOVERY SYSTEM NO. 5 (G27397) CONSISTING OF:

1. INTERNAL COMBUSTION ENGINE (CG5-HB), COOPER BESSMER, SPARK IGNITION, FOUR STROKES, WITH A MODIFIED TURBOCHARGED-INTERCOOLED V-16 TYPE, MODEL NO. LSVB-16-SGC, 4166 HP, NATURAL GAS AND/OR DIGESTER GAS FIRED, DRIVING A 3000 KW ELECTRIC GENERATOR, WITH AN EXHAUST HEAT RECOVERY STEAM GENERATOR, 6,010,200 BTU/HR CAPACITY, UNFIRED.

BY THE ADDITION OF:

6. DIGESTER GAS CLEANING SYSTEM (DGCS), THREE VESSELS, EACH CONTAINING MINIMUM OF 9,900 LBS OF MEDIA, TOTAL 2100 CFM CAPACITY, WITH ASSOCIATED PIPING AND VALVES.

COMMON TO FIVE ENGINES (CG1-HB, CG2-HB, CG3-HB, CG4-HB AND CG5-HB)

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION. [RULE 204]
- 4. AT LEAST 30 DAYS PRIOR TO INSTALLATION OF THE EQUIPMENT, ORANGE COUNTY SANITATION DISTRICT (OCSD) SHALL PROVIDE TO SCAQMD FINAL DESIGN DRAWINGS, PROCESS AND FLOW DIAGRAM, CONTROLS, EQUIPMENT SPECIFICATIONS (MAKE, MODEL, SIZE AND MAXIMUM CAPACITY).

 [RULE 204]
- 5. EFFECTIVE JANUARY 1, 2016, THIS EQUIPMENT SHALL ONLY BE VENTED TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND HAS A VALID PERMIT TO CONSTRUCT OR OPERATE ISSUED BY THE SCAQMD.

 [RULE 1!10.2]
- 6. THIS ENGINE SHALL HAVE AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER TO DETERMINE THE ENGINE ELAPSED OPERATING TIME.
 [RULE 1110.2]



Section H Page 36 Facility I.D. #: 029110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE DIGESTER GAS SUPPLY LINE TO THE ENGINE TO MEASURE AND RECORD THE OUANTITY OF DIGESTER GAS (IN SCFM) BURNED. [RULE 204]
- SAMPLING PORT SHALL BE INSTALLED FOR THE INLET GAS LINE TO THE ENGINE TO ALLOW THE COLLECTION OF A FUEL GAS SAMPLE. [RULE 204]
- 9. MONTHLY READINGS OF THE BTU CONTENT OF DIGESTER GAS (BTU/SCF) SUPPLIED TO THE ENGINE SHALL BE TAKEN USING AN INSTRUMENT APPROVED BY THE SCAOMD. ALL RESULTS SHALL BE RECORDED. [RULE 204]
- 10. ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF THE DAY. [RULE 204]
- 11. THE TOTAL HEAT INPUT OF GASEOUS FUEL BURNED IN THIS ENGINE SHALL NOT EXCEED 33 MM BTU PER HOUR. A LOG SHALL BE KEPT INDICATING THE TOTAL HEATING VALUE OF FUEL GAS BURNED IN THIS ENGINE BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING. [RULE 1303 (b) (1) AND 1303 (b) (2)-MODELING AND EMISSIONS OFFSET]
- 12. THIS EQUIPMENT SHALL BE OPERATED IN SUCH A MANNER THAT THE FOLLOWING EMISSION RATES ARE NOT EXCEEDED.

AIR CONTAMINANT

600 PPMV AT 15% O2 CARBON MONOXIDE PARTICULATES (PM10) 0.0058 GRAINS/ DSCF ROG OR TNMHC (AS CARBON) 115 PPMV AT 15% O2 [RULE 1303 (a) (1), 1303(b) (1) AND 1303 (b) (2)-BACT, MODELING AND EMISSIONS OFFSET]

- 13. EFFECTIVE JANUARY 1, 2016, THIS EQUIPMENT SHALL MEET THE EMISSIONS LIMITS (EXHAUST) OF TABLE III-B IN RULE 1110.2 (d) (1) (C), UNLESS THE OPERATOR DEMONSTRATES COMPLIANCE WITH THE LIMITS AND SCHEDULE IN RULE 1110.2 (d) (1) (H). [RULE 1110.2]
- THE COMBINED EMISSIONS FROM THE FOUR (4) CGS ENGINES, USING CALENDAR MONTHLY 14. EMISSIONS DIVIDED BY 30, SHALL NOT EXCEED THE FOLLOWING (UNTIL JANUARY 1, 2016):

AIR CONTAMINANT	LBS/DAY
CARBON MONOXIDE	2,644
NITROGEN OXIDES (AS NO2)	828
PARTICULATES (PM10)	72
ROG OR TNMHC (AS CH4)	372
SULFUR DIOXIDE	84
[RULE 1303 (b) (2)-EMISSIONS OFFS	ET]



Section H Page 37 Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

15. POST-COMBUSTION CONTROLLED EMISSIONS, INTO THE ATMOSPHERE, FROM THIS EQUIPMENT SHALL NOT EXCEED THE FOLLOWING:

AIR CONTAMINANT	LBS/DAY
CARBON MONOXIDE	497.6
NITROGEN OXIDES (AS NO2)	36.0
PARTICULATES (PM10)	18.0
ROG OR TNMHC (AS CH4)	25.60
SULFUR DIOXIDE	21.0
[RULE 204]	

- 16. THE OPERATOR SHALL INSTALL AND MAINTAIN A CONTINUOUS EMISSION MONITORING SYSTEM (CEMS), OR AN ALTERNATIVE SYSTEM, AS APPROVED BY THE EXECUTIVE OFFICER, TO MEASURE THE ENGINE EXHAUST FOR CO, NOX AND O2 CONCENTRATIONS ON A DRY BASIS, EXCEPT DURING SHUTDOWN FOR MAINTENANCE OF THE SYSTEM. IN ADDITION, THE CEMS SHALL CONVERT THE ACTUAL CO AND NOX TO MASS EMISSION RATES; AND RECORD THE ACTUAL AND CORRECTED ENGINE NOX CONCENTRATION AT 15% O2 AND MASS EMISSION RATES ON AN HOURLY AND DAILY BASIS.

 [RULE 203, 218, RULE 1110.2]
- 17. WITHIN 180 DAYS AFTER INITIAL START-UP, (POST- MODIFICATION OF FIVE ENGINES; CG1-HB, CG2-HB, CG3-HB, CG4-HB AND CG5-HB), THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS, AT MAXIMUM ACHIEVABLE LOAD, IN ACCORDANCE WITH THE APPROVED TEST PROCEDURES AND, FURNISH THE SCAQMD WRITTEN RESULTS OF SUCH PERFORMANCE TESTS WITHIN 45 DAYS AFTER TESTING. ALL SOURCE TESTING AND ANALYTICAL METHODS SHALL BE SUBMITTED FOR APPROVAL, AT LEAST 30 DAYS PRIOR TO START OF THE TESTS TO THE SCAQMD, ENERGY/PUBLIC SERVICES/WASTE MANAGEMENT/TERMINAL PERMITTING, 21865 COPLEY DRIVE, DIAMOND BAR, CA 91765. THE SUBMITTAL SHALL INCLUDE A COPY OF THE ACTIVE PERMIT. WRITTEN RESULTS OF SUCH PERFORMANCE TESTS SHALL BE SUBMITTED WITHIN 60 DAYS AFTER TESTING. NOTICE SHALL BE PROVIDED TO THE SCAQMD 10 DAYS PRIOR TO THE TESTING SO THAT AN OBSERVER MAY BE PRESENT. THE TESTS SHALL INCLUDE, BUT MAY NOT BE LIMITED TO:
 - A. TOTAL NON-METHANE HYDROCARBONS (EXHAUST ONLY).
 - B. CARBON MONOXIDE (EXHAUST ONLY)
 - C. TOTAL PARTICULATE MATTER (EXHAUST ONLY).
 - D. OXIDES OF NITROGEN (EXHAUST ONLY).
 - E. OXYGEN (EXHAUST ONLY)
 - F. FLOW RATE
 - G. MOISTURE (EXHAUST ONLY)
 - H. TOXIC AIR CONTAMINANTS (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
 - I. ALDEHYDES (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
 - J. TOTAL REDUCED SULFUR COMPOUNDS (DIGESTER GAS ONLY)
 - K. NITROGEN AND CARBON DIOXIDE
 - L. BTU CONTENTS (DIGESTER GAS ONLY)
 - M. POWER OUTPUT



Section H Page 38 Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

THE ROUTINE COMPLIANCE SOURCE TESTING SHALL BE CONDUCTED IN ACCORDANCE WITH RULE 1110.2 REQUIREMENTS AND ABOVE REQUIREMENTS. APPROPRIATE SCAQMD STAFF SHALL BE NOTIFIED A MINIMUM OF 45 DAYS IN ADVANCE OF COMPLIANCE SOURCE TESTING TO DETERMINE IF PREVIOUSLY APPROVED SOURCE TEST PROTOCOL MAY BE USED IF NO EQUIPMENT AND PROCESS CHANGES HAVE BEEN MADE.

[RULE 404], [RULE 1110.2], [RULE 1303(b) (1) AND 1303(b) (2) - MODELING AND EMISSION OFFSET]

18. RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.

[RULE 204]

Emissions and Requirements:

19. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: RULE 1110.2 LIMIT NOx: RULE 1110.2 LIMIT

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS.

VOC (TNMHC): RULE 1110.2 LIMIT

H2S: RULE 431.1



Section H Page 39 Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 556626 Granted as of 6-26-2014

Equipment Description:

ALTERATION OF THE EXISTING SEWAGE TREATMENT PLANT (250 MGD), P/O G25942, CONSISTING OF:

- 1. INFLUENT STATION (HEADWORKS "D") CONSISTING OF INFLUENT TRUNKLINES, INFLUENT DIVERSION AND METERING, SIX (5 DUTY + 1 STANDBY) BARSCREENS, SCREENING HANDLING, INFLUENT PUMPS, GRIT REMOVAL AND HANDLING, PRIMARY INFLUENT SPLITTER AND METERING, AND FERRIC CHLORIDE FACILITY.
- 2. WETWELL (WASTE SIDE STREAM PUMP STATION) WITH ASSOCIATED PUMPS.
- 3. SEVENTEEN PRIMARY BASINS, THREE 41'-0" W. X 179'-0" L. X 8'-0" D., WITH ALUMINUM COVERS, FOURTEEN 140'-0" DIA. X 9'-0" D., WITH ALUMINUM GEODESIC DOME COVERS, AND ASSOCIATED SLUDGE AND SCUM COLLECTORS AND PUMPS.
- 4. EIGHT ACTIVATED SLUDGE OXYGEN REACTORS, 139,656 CUBIC FEET CAPACITY, 46'-0" W. X 184'-0" L. X 16'-6" D., WITH ASSOCIATED MIXERS.
- 5. TWO PURE OXYGEN GENERATION UNITS, 40,000 GALLON CAPACITY EACH, WITH TWO STORAGE TANKS AND ASSOCIATED COMPRESSORS.
- 6. TWELVE SECONDARY CLARIFIERS, 61'-0" W. X 171'-0" L. X 14'-0" D., WITH ASSOCIATED SLUDGE COLLECTORS.
- EAST SECONDARY SLUDGE PUMP STATION WITH ASSOCIATED PUMPS.
- 8. WEST SECONDARY SLUDGE PUMP STATION WITH ASSOCIATED PUMPS.
- 9. FOUR DISSOLVED AIR FLOATATION THICKENERS, EACH 55'-0" DIA. X 8'-6" D., WITH ASSOCIATED COLLECTOR DRIVES AND PUMPS.
- 10. TWENTY DIGESTER TANKS, TWO 90'-0" DIA. X 30'-0" D., EACH 190,800 CUBIC FEET CAPACITY, SIX 80'-0" DIA. X 33'-0" D., EACH 164,120 CUBIC FEET CAPACITY, THREE 80'-0" DIA. X 33'-0" D., EACH 166,630 CUBIC FEET CAPACITY, FOUR 105'-0" DIA. X 30'-0" D., EACH 293,680 CUBIC FEET CAPACITY, FIVE 80'-0" DIA. X 18'-0" H., WITH ASSOCIATED PUMPS AND GRINDERS. EQUIPPED WITH OPTIONAL PASSIVE CARBON ADSORBERS.
- 11. LOW PRESSURE DIGESTER GAS STORAGE TANK, 25,000 CUBIC FEET CAPACITY, 42'-0" DIA. X 30'-0" H., WITH ASSOCIATED COMPRESSORS.
- 12. FERROUS AND/OR FERRIC CHLORIDE INJECTION STATION WITH TWO STORAGE TANKS, EACH 12'-0" DIA. X 18'-0" H., AND ASSOCIATED PUMPS.

Page 40 Section H Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 13. SLUDGE PROCESSING STATION WITH ASSOCIATED GRINDERS, BELT FILTER PRESSES, DEWATERED BIOSOLIDS STORAGE SILOS (OR CAKE STORAGE BINS), AND TRUCK LOADING BAY..
- TWO POLYMER STORAGE TANKS, EACH 20,000 GALLON CAPACITY, WITH ASSOCIATED PUMPS. 14.
- FOUR POLYMER MIX TANKS, EACH 8,500 GALLON CAPACITY, WITH ASSOCIATED MIXERS AND 15. PUMPS.
- 16. PRIMARY EFFLUENT DIVERSION STRUCTURE.
- THREE TRICKLING FILTERS, COVERED, PRIMARY EFFLUENT TREATMENT (TOTAL 60 MGD 17. AVERAGE CAPACITY AND 182 MGD PEAK FLOW), EACH 150' DIA. X 28' H., OVERALL, WITH MODULAR PLASTIC CROSS - FLOW FILTER MEDIA, SPRAY NOZZLES, AND ASSOCIATED PUMPS.
- FOUR SOLIDS CONTACT (SC) REACTORS, FOUR SLUDGE RE-AERATION (SR) REACTORS, 18. UNCOVERED, TWO MIXED LIQUOR CHANNELS (TOTAL 1.68 MG VOLUME), AND WITH ASSOCIATED AIR BLOWERS.
- 19. SIX TRICKLING FILTER CLARIFIERS, UNCOVERED, EACH 135' DIA. X 19' SIDEWATER DEPTH. WITH FLOCCULATING CENTER WELLS, HYDRAULIC SLUDGE COLLECTORS, AND INBOARD LAUNDERS.
- SLUDGE BLENDING FACILITY WITH TWO SLUDGE BLENDING TANKS (SBTs), EACH 26,000 20. GALLON CAPACITY, WITH ASSOCIATED PIPING AND PUMPS.

BY THE REMOVAL OF:

- 13. SLUDGE PROCESSING STATION WITH ASSOCIATED GRINDERS AND BELT FILTER PRESSES.
- 14. TWO POLYMER STORAGE TANKS, EACH 20,000 GALLON CAPACITY, WITH ASSOCIATED PUMPS.
- 15. FOUR POLYMER MIX TANKS, EACH 8,500 GALLON CAPACITY, WITH ASSOCIATED MIXERS AND PUMPS.

AND BY THE ADDITION OF: DIGESTED SLUDGE DEWATERING FACILITY, LOCATED IN A BUILDING, (OCSD PROJECT P2-92)

- 21. CENTRATE WET WELL.
- 22. **BIOSOLIDS LOADING SLUDGE PUMPS (5)** CENTRIFUGES (5): ANDRITZ SEPARATION, TYPE D7LL OR SIMILAR CENTRATE PUMPS (2): FAIRBANKS MORSE, MAXIMUM 1474 GPM, 18.5 H.P. OR SIMILAR CAKE PUMPS (5) - SCHWING BIOSET, MODEL KSP25 V (HD) L, 39 GPM, 150 H.P. OR SIMILAR
- TWO POLYMER STORAGE TANKS, EACH APPROXIMATELY 7,500 GALLON CAPACITY, WITH 23. ASSOCIATED PUMPS.
- 24. TWO POLYMER AGING TANKS, EACH APPROXIMATELY 5,000 GALLON CAPACITY, WITH ASSOCIATED PUMPS.



Section H Page 41 Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW. [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.

 [RULE 204]
- 3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
 [RULE 204]
- 4. THIS PERMIT SHALL EXPIRE IF CONSTRUCTION OF THE EQUIPMENT IS NOT COMPLETED WITHIN ONE YEAR FROM THE DATE OF ISSUANCE OF THIS PERMIT UNLESS AN EXTENSION IS GRANTED BY THE EXECUTIVE OFFICER.

 [RULE 205]
- 5. ORANGE COUNTY SANITATION DISTRICT (OCSD) SHALL COMPLY WITH ALL APPLICABLE MITIGATION MEASURES STIPULATED IN THE STATEMENT OF FINDINGS, STATEMENT OF OVERRIDING CONSIDERATION, AND MITIGATION OR MONITORING PLAN DOCUMENT (THAT APPLIES TO PROJECT P2-92), WHICH IS PART OF THE CERTIFIED FINAL SUBSEQUENT ENVIRONMENTAL IMPACT REPORT (SEIR) FOR THIS FACILITY AS APPROVED BY THE LEAD AGENCY.

 [CA PRC CEQA, 11-23-1970]
- 6. HEADWORKS FACILITY, PRIMARY BASINS, SLUDGE BLENDING FACILITY, DISSOLVED AIR FLOATATION THICKENERS, TRICKLING FILTER FACILITY AND NEW SLUDGE DEWATERING FACILITY (PROJECT P2-92) SHALL BE VENTED TO THEIR DESIGNATED AIR POLLUTION CONTROL SYSTEMS WHICH ARE IN OPERATION PER ITS' VALID PERMITS TO CONSTRUCT OR OPERATE ISSUED BY THE SCAQMD. IN THE EVENT AN AIR POLLUTION CONTROL SYSTEM IS REMOVED FROM OPERATION DURING CONSTRUCTION OR MAINTENANCE WORK, THE H2S CONCENTRATION IN EXHAUST AIR SHALL BE BELOW THE LIMITS SPECIFIED IN THE REMOVED AIR POLLUTION CONTROL SYSTEM'S PERMIT. EACH SUCH CONSTRUCTION OR MAINTENANCE EVENT SHALL BE RECORDED IN A DAILY LOG.

 [RULE 402, 1303(a) (1)-BACT, 1401]
- 7. AFTER COMPLETION OF CONSTRUCTION OF P2-92, THE BUILDING ENCLOSING THE DIGESTED SLUDGE DEWATERING FACILITY SHALL REMAIN CLOSED AT ALL TIMES, EXCEPT TO ALLOW PERSONNEL TO ENTER OR EXIT; AFTER COMPLETION OF CONSTRUCTION OF P2-92, THE BUILDING ENCLOSING THE DIGESTED SLUDGE DEWATERING FACILITY SHALL REMAIN CLOSED AT ALL TIMES, EXCEPT TO ALLOW PERSONNEL TO ENTER OR EXIT; FACILITATE OPERATIONS/MAINTENANCE ACTIVITIES OR TO ALLEVIATE SAFETY ISSUES. [RULE 204, 402]
- 8. THE FERROUS AND/OR FERRIC CHLORIDE INJECTION STATION SHALL BE IN USE TO THE EXTENT NECESSARY TO MAINTAIN THE H2S CONCENTRATION IN THE DIGESTER GAS TO THE PERMITTED LIMIT.

 [RULE 431.1]



Section H Page 42 Facility I.D. #: 029110 Revision #: 09 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 9. RAW DIGESTER GAS PRODUCED AT THIS FACILITY SHALL NOT BE RELEASED INTO THE ATMOSPHERE, EXCEPT DURING MOMENTARY AUTOMATIC ACTIVATION OF PRESSURE RELIEF SAFETY DEVICES. ALL COLLECTED DIGESTER GAS SHALL BE EITHER COMBUSTED IN DIGESTER GAS FLARES, INTERNAL COMBUSTION ENGINES, OR BOILERS WITH VALID AQMD PERMIT, OR SHALL BE TREATED THROUGH OPTIONAL PASSIVE CARBON ADSORBERS. EACH SUCH PRESSURE RELIEF ACTIVATION SHALL BE MAINTAINED IN A DAILY LOG. [RULE 402, RULE 1401]
- 10. RAW DIGESTER GAS RELEASES DUE TO EQUIPMENT FAILURE SHALL BE REPORTED IN ACCORDANCE WITH RULE 430. UPON DISCOVERY OF SUCH EMISSIONS, IMMEDIATE REMEDIAL MEASURES SHALL BE PUT INTO ACTION TO CORRECT THE PROBLEM AND PREVENT FURTHER EMISSIONS INTO THE ATMOSPHERE.

 [RULE 402, RULE 430]
- 11. THE CALENDAR MONTHLY AVERAGE DAILY PRIMARY EFFLUENT FLOW RATE, TO THE SECONDARY TREATMENT PROCESS, SHALL NOT EXCEED 150 MILLIONS GALLONS PER DAY, EXCEPT DURING WET WEATHER PERIODS AND EMERGENCY PERIODS INVOLVING PUBLIC HEALTH SAFETY. THE RECORDS FOR THE PRIMARY EFFLUENT AVERAGE DAILY FLOW RATE (MGD), TREATED BY THE SECONDARY PROCESS, SHALL BE KEPT ON FILE. [RULE 1303(b) (2) –OFFSETS, 402, 1401]
- 12. THE CALENDAR MONTHLY AVERAGE DAILY FLOW RATE OF WASTEWATER TREATED AT THIS FACILITY SHALL NOT EXCEED 250 MILLION GALLONS PER DAY (MGD) EXCEPT DURING WET WEATHER PERIODS. THE RECORDS FOR THE WASTEWATER FLOW RATE (MGD) MEASURED SHALL BE RECORDED AND KEPT ON FILE.

 [RULE 1303(b) (2) –OFFSETS, 402, 1401]

Section H Page 43 Facility I.D. #: 029110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 556627 Granted as of 6-26-2014

Equipment Description:

AIR POLLUTION CONTROL SYSTEM FOR THE NEW SLUDGE DEWATERING FACILITY (P2-92). CONSISTING OF:

- FOUL-AIR DUCT(S) FROM THE CENTRIFUGES, CAKE (BIOSOLIDS) BINS AND CENTRATE WET 1. WELL.
- TWO BLOWERS, ONE STANDBY, HARTZELL SERIES 41 TYPE FA, OR SIMILAR, CAPABLE OF 2. APPROXIMATELY 7500 CFM AT 12" STATIC PRESSURE.
- WET SCRUBBER, PACKED BED, APPROXIMATELY 4' DIA. X 8' H., WITH 4' H. POLYPROPYLENE 3. PACKING MATERIAL, SPRAY NOZZLES, WATER RECIRCULATION, MAKE-UP WATER AND ACID SUPPLY (AS BACK-UP) LINES, SUMP WITH PH PROBE, AND ASSOCIATED PUMPS.
- BIOFILTER, CELL A, B AND C, CUSTOM MADE, APPROXIMATELY 20' W. X 43' L. X 22' H., 4. OVERALL DIMENSIONS, WITH APPROXIMATELY 8' H. INORGANIC ENGINEERED MEDIA, AND AN IRRIGATION SPRAY(S) SYSTEM.
- TREATED AIR EXHAUST STACK, 2' DIA. X 47' 6" H. ABOVE GRADE. 5.

- OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA 1. AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW. [RULE 204]
- THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING 2. CONDITION AT ALL TIMES. [RULE 204]
- THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS 3. OPERATION. [RULE 204]
- THIS PERMIT SHALL EXPIRE IF CONSTRUCTION OF THE EQUIPMENT IS NOT COMPLETED 4. WITHIN ONE YEAR FROM THE DATE OF ISSUANCE OF THIS PERMIT UNLESS AN EXTENSION IS GRANTED BY THE EXECUTIVE OFFICER. [RULE 205]



Section H Page 44 Facility I.D. #: 029110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

ORANGE COUNTY SANITATION DISTRICT (OCSD) SHALL COMPLY WITH ALL APPLICABLE 5. MITIGATION MEASURES STIPULATED IN THE STATEMENT OF FINDINGS, STATEMENT OF OVERRIDING CONSIDERATION, AND MITIGATION OR MONITORING PLAN DOCUMENT (THAT APPLIES TO PROJECT P2-92), WHICH IS PART OF THE CERTIFIED FINAL SUBSEQUENT ENVIRONMENTAL IMPACT REPORT (SEIR) FOR THIS FACILITY AS APPROVED BY THE LEAD AGENCY.

[CA PRC CEQA, 11-23-1970]

- A FLOW METER SHALL BE INSTALLED AND MAINTAINED AT THE INLET STREAM TO THE WET 6. SCRUBBER TO INDICATE THE TOTAL AIR FLOW RATE IN CUBIC FEET PER MINUTE (CFM). THE TOTAL AIR FLOW RATE SHALL NOT EXCEED 7,500 CFM, DAILY AVERAGE. IN CASE A PRESSURE SENSOR DEVICE IS USED IN PLACE OF THE FLOW METER, A CONVERSION CHART SHALL BE MAINTAINED TO INDICATE THE CORRESPONDING FLOW RATE, IN CFM, TO THE PRESSURE READING. [RULE 203]
- 7. A PRESSURE DIFFERENTIAL GAUGE INDICATING THE PRESSURE DROP ACROSS THE SCRUBBER PACKING BED SHALL BE INSTALLED AND MAINTAINED. THE PRESSURE DROP ACROSS THE PACKING BED SHALL BE MAINTAINED BELOW 2 INCHES OF WATER COLUMN, WHEN THE SCRUBBER IS IN OPERATION. [RULE 203]
- 8. A PH METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE PH OF THE SCRUBBING SOLUTION (SUMP), WHENEVER SULFURIC ACID IS USED. THE PH OF THE SCRUBBING SOLUTION SHALL BE MAINTAINED BETWEEN 1 TO 8. [RULE 203]
- WHEN THE EQUIPMENT IS IN OPERATION, THE INLET FLOW RATE, SCRUBBING SOLUTION 9. FLOW RATE, PH OF THE SCRUBBING SOLUTION, PRESSURE DIFFERENTIAL ACROSS THE SCRUBBER PACKING BED SHALL BE MONITORED AND RECORDED AT LEAST ONCE A DAY FOR THE FIRST MONTH OF OPERATION AND WEEKLY THEREAFTER. [RULE 203]
- 10. WHEN BIOFILTER IS IN OPERATION, THE CONCENTRATION, PPMV, OF HYDROGEN SULFIDE (H2S), IN EXHAUST AIR (STACK) SHALL BE MONITORED AND RECORDED, AT LEAST DAILY. THE BIOFILTER SURFACE IRRIGATION SYSTEM SHALL BE MAINTAINED IN GOOD OPERATING CONDITION AT ALL TIMES AND SHALL BE UTILIZED TO MAINTAIN THE DESIRED MOISTURE CONTENT FOR THE BIOFILTER MEDIA. [RULE 402, 1401]
- 11. EMISSIONS FROM THIS EQUIPMENT MEASURED IN THE EXHAUST STACK SHALL NOT EXCEED THE FOLLOWING:

HYDROGEN SULFIDE (H2S) AMMONIA (NH3)

1 PPMV- DAILY AVERAGE **5 PPMV- DAILY AVERAGE**

[RULE 402, 1401]

IF THE OPERATION OF THIS EQUIPMENT RESULTS IN CONSIDERABLE NUMBER OF ODOR 12. COMPLAINTS, MITIGATION MEASURES SHALL BE IMPLEMENTED IMMEDIATELY. [RULE 402]



Section H Page 45
Facility I.D. #: 029110
Revision #: 09
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

13. ALL RECORDS REQUIRED BY THIS PERMIT SHALL BE KEPT AND MAINTAINED FOR AT LEAST FIVE YEARS, AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 203]



Section H Page 46 Facility I.D. #: 029110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 557229 Granted as of 4/16/2014

Equipment Description:

STORAGE TANK, NO. 26KTNK001, AQUEOUS UREA SOLUTION (32.5% v), ABOVE GROUND, 2,000 GALLON CAPACITY, VENTING TO ATMOSPHERE.

- OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA 1. AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
- THIS EQUIPMENT SHALL ONLY BE USED FOR STORAGE OF AQUEOUS UREA SOLUTION. 3.



Section H Page 47 Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 557230 Granted as of 4/16/2014

Equipment Description:

STORAGE TANK, NO. 26KTNK005, AQUEOUS UREA SOLUTION (32.5% ν), ABOVE GROUND, 2,000 GALLON CAPACITY, VENTING TO ATMOSPHERE.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
- 3. THIS EQUIPMENT SHALL ONLY BE USED FOR STORAGE OF AQUEOUS UREA SOLUTION.

Section H Page 48
Facility I.D. #: 029110
Revision #: 09
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 559228 Granted as of 4/16/2014

Equipment Description:

AIR POLLUTION CONTROL SYSTEM NO. 1 CONSISTING OF:

- 1. CATALYTIC OXIDIZER, JOHNSON MATTHEY INC. OR EQUAL, MODEL NO. 91449 OR EQUAL, ALUMINUM OXIDE OR PLATINUM CATALYST ACTIVE MATERIAL, WITH 200 CPSI OXIDATION CATALYST OR EQUAL, 18.67 CUBIC FEET TOTAL VOLUME, WITH ASSOCIATED AUTOMATIC TEMPERATURE AND PRESSURE MONITORING DEVICES AND CONTROLS, AND WITH PROVISIONS FOR ADDING TWO LAYERS OF CATALYST.
- 2. SELECTIVE CATALYTIC REDUCTION, JOHNSON MATTHEY INC. OR EQUAL, MODEL NO. 79449 OR EQUAL, METALLIC SUBSTRATE, 37.33 CUBIC FOOT TOTAL VOLUME AND WITH PROVISIONS FOR ADDING TWO LAYERS OF CATALYST.
- 3 AQUEOUS UREA SOLUTION DOSING UNIT, INJECTORS, AND WITH ASSOCIATED AUTOMATIC TEMPERATURE, PRESSURE MONITORING AND CONTROL DEVICES.
- 4. EXHAUST STACK, 2'-6" DIA. X 59' H., ABOVE GROUND.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.

 [RULE 204]
- 3. AT LEAST 30 DAYS PRIOR TO INSTALLATION OF THE EQUIPMENT, ORANGE COUNTY SANITATION DISTRICT (OCSD) SHALL PROVIDE TO SCAQMD FINAL DESIGN DRAWINGS, PROCESS AND FLOW DIAGRAM, CONTROLS, EQUIPMENT SPECIFICATIONS (MAKE, MODEL, SIZE AND MAXIMUM CAPACITY).

 [RULE 204]
- 4. THE OPERATOR SHALL INSTALL AND MAINTAIN TEMPERATURE MEASURING AND RECORDING SYSTEMS TO MEASURE AND RECORD THE INLET AND OUTLET TEMPERATURES OF THE OXIDATION CATALYST AND THE SELECTIVE REDUCTION CATALYST. THE TEMPERATURES SHALL BE CONTINUOUSLY MEASURED AND RECORDED. THE TEMPERATURE GAUGES SHALL BE ACCURATE TO PLUS OR MINUS 5 PERCENT, AND BE CALIBRATED ONCE EVERY TWELVE MONTHS.

 [RULE 204]



Section H Page 49 Facility I.D. #: 029110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 5. THE OPERATOR SHALL INSTALL AND MAINTAIN DIFFERENTIAL PRESSURE AND RECORDING SYSTEMS TO MEASURE AND RECORD THE INLET AND OUTLET PRESSURES ACROSS THE OXIDATION CATALYST AND THE SELECTIVE REDUCTION CATALYST. HE DIFFERENTIAL PRESSURES SHALL BE CONTINUOUSLY MEASURED AND RECORDED. [RULE 204]
- BASED ON THE OPERATING PARAMETERS' MEASURED AND MONITORED RESULTS OVER THE TWO-YEAR PERIOD (PER CONDITION #4 AND #5), OPERATING PARAMETERS' RANGE SHALL BE ESTABLISHED FOR THE PERMIT TO OPERATE. [RULE 204]
- EXCEPT DURING STARTUP AND SHUTDOWN OF THE SCR SYSTEM, THE UREA FEED CONTROL 7. SYSTEM SHALL BE IN OPERATION. [RULE 204]
- THE OPERATOR SHALL INSTALL AND MAINTAIN A UREA FLOW RATE MEASURING AND RECORDING SYSTEM TO ACCURATELY INDICATE AND RECORD THE UREA INJECTION RATE TO THE SELECTIVE CATALYTIC REDUCTION SYSTEM. [RULE 204]
- THE OPERATOR SHALL INSTALL AND MAINTAIN A NOx ANALYZER TO MEASURE SCR INLET NOx CONCENTRATION AND CALIBRATED ANNUALLY IN ACCORDANCE THE MANUFACTURER'S SPECIFICATIONS. [RULE 204]
- WHEN SCR IS IN OPERATION, THE OPERATOR SHALL ANALYZE THE UREA INJECTION RATE, AND 10. THE SCR INLET AND OUTLET NOX EMISSION RATE TO ESTIMATE THE AMMONIA CONCENTRATION IN THE SCR OUTLET, BASED ON ONE HOUR AVERAGE. [RULE 204]
- SAMPLING PORTS SHALL BE INSTALLED AT THE INLET AND OUTLET OF THE AIR POLLUTION 11. CONTROL SYSTEM. [RULE 204]
- THE AMMONIA SLIP SHALL BE TESTED WITHIN 180 DAYS AFTER INITIAL START-UP (POST 12. MODIFICATION), AND ANNUALLY THEREAFTER. THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS IN ACCORDANCE WITH THE APPROVED TEST PROCEDURES AND. FURNISH THE SCAOMD WRITTEN RESULTS OF SUCH PERFORMANCE TESTS WITHIN 45 DAYS AFTER TESTING. [RULE 1303(b) (1)], [RULE 1401]
- RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AOMD PERSONNEL UPON REQUEST. [RULE 204]



Section H Page 50 Facility I.D. #: 029110 Revision #: 09 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

Emissions and Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES 14. AND REGULATIONS:

NH3 (AMMONIA SLIP): 5 PPMV AT 15% O2, 60 MINUTE AVERAGE, AFTER SCR START UP.

[RULE 1303(b) (1)], [RULE 1402]

Section H Page 51 Facility I.D. #: 029110 Revision #: 09 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 559229 Granted as of 4/16/2014

Equipment Description:

AIR POLLUTION CONTROL SYSTEM NO. 2 CONSISTING OF:

- 1. CATALYTIC OXIDIZER, JOHNSON MATTHEY INC. OR EQUAL, MODEL NO. 91449 OR EQUAL, ALUMINUM OXIDE OR PLATINUM CATALYST ACTIVE MATERIAL, WITH 200 CPSI OXIDATION CATALYST OR EQUAL, 18.67 CUBIC FEET TOTAL VOLUME, WITH ASSOCIATED AUTOMATIC TEMPERATURE AND PRESSURE MONITORING DEVICES AND CONTROLS, AND WITH PROVISIONS FOR ADDING TWO LAYERS OF CATALYST.
- 2. SELECTIVE CATALYTIC REDUCTION, JOHNSON MATTHEY INC. OR EQUAL, MODEL NO. 79449 OR EQUAL, METALLIC SUBSTRATE, 37.33 CUBIC FOOT TOTAL VOLUME AND WITH PROVISIONS FOR ADDING TWO LAYERS OF CATALYST.
- 3 AQUEOUS UREA SOLUTION DOSING UNIT, INJECTORS, AND WITH ASSOCIATED AUTOMATIC TEMPERATURE, PRESSURE MONITORING AND CONTROL DEVICES.
- 4. EXHAUST STACK, 2'-6" DIA, X 59' H., ABOVE GROUND.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. AT LEAST 30 DAYS PRIOR TO INSTALLATION OF THE EQUIPMENT, ORANGE COUNTY SANITATION DISTRICT (OCSD) SHALL PROVIDE TO SCAQMD FINAL DESIGN DRAWINGS, PROCESS AND FLOW DIAGRAM, CONTROLS, EQUIPMENT SPECIFICATIONS (MAKE, MODEL, SIZE AND MAXIMUM CAPACITY).
 [RULE 204]
- 4. THE OPERATOR SHALL INSTALL AND MAINTAIN TEMPERATURE MEASURING AND RECORDING SYSTEMS TO MEASURE AND RECORD THE INLET AND OUTLET TEMPERATURES OF THE OXIDATION CATALYST AND THE SELECTIVE REDUCTION CATALYST. THE TEMPERATURES SHALL BE CONTINUOUSLY MEASURED AND RECORDED. THE TEMPERATURE GAUGES SHALL BE ACCURATE TO PLUS OR MINUS 5 PERCENT, AND BE CALIBRATED ONCE EVERY TWELVE MONTHS.

 [RULE 204]

Section H Page 52 Facility I.D. #: 029110 Revision #: 09 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 5. THE OPERATOR SHALL INSTALL AND MAINTAIN DIFFERENTIAL PRESSURE AND RECORDING SYSTEMS TO MEASURE AND RECORD THE INLET AND OUTLET PRESSURES ACROSS THE OXIDATION CATALYST AND THE SELECTIVE REDUCTION CATALYST. HE DIFFERENTIAL PRESSURES SHALL BE CONTINUOUSLY MEASURED AND RECORDED.

 [RULE 204]
- 6. BASED ON THE OPERATING PARAMETERS' MEASURED AND MONITORED RESULTS OVER THE TWO-YEAR PERIOD (PER CONDITION #4 AND #5), OPERATING PARAMETERS' RANGE SHALL BE ESTABLISHED FOR THE PERMIT TO OPERATE.

 [RULE 204]
- 7. EXCEPT DURING STARTUP AND SHUTDOWN OF THE SCR SYSTEM, THE UREA FEED CONTROL SYSTEM SHALL BE IN OPERATION.

 [RULE 204]
- 8. THE OPERATOR SHALL INSTALL AND MAINTAIN A UREA FLOW RATE MEASURING AND RECORDING SYSTEM TO ACCURATELY INDICATE AND RECORD THE UREA INJECTION RATE TO THE SELECTIVE CATALYTIC REDUCTION SYSTEM.

 [RULE 204]
- 9. THE OPERATOR SHALL INSTALL AND MAINTAIN A NOX ANALYZER TO MEASURE SCR INLET NOX CONCENTRATION AND CALIBRATED ANNUALLY IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATIONS.
 [RULE 204]
- 10. WHEN SCR IS IN OPERATION, THE OPERATOR SHALL ANALYZE THE UREA INJECTION RATE, AND THE SCR INLET AND OUTLET NOX EMISSION RATE TO ESTIMATE THE AMMONIA CONCENTRATION IN THE SCR OUTLET, BASED ON ONE HOUR AVERAGE.

 [RULE 204]
- 11. SAMPLING PORTS SHALL BE INSTALLED AT THE INLET AND OUTLET OF THE AIR POLLUTION CONTROL SYSTEM.
 [RULE 204]
- 12. THE AMMONIA SLIP SHALL BE TESTED WITHIN 180 DAYS AFTER INITIAL START-UP (POST MODIFICATION), AND ANNUALLY THEREAFTER. THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS IN ACCORDANCE WITH THE APPROVED TEST PROCEDURES AND, FURNISH THE SCAQMD WRITTEN RESULTS OF SUCH PERFORMANCE TESTS WITHIN 45 DAYS AFTER TESTING.
 [RULE 1303(b) (1)], [RULE 1401]
- 13. RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
 [RULE 204]



Section H Page 53 Facility I.D. #: 029110 Revision #: 09 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

Emissions and Requirements:

14. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NH3 (AMMONIA SLIP): 5 PPMV AT 15% O2, 60 MINUTE AVERAGE, AFTER SCR START UP.

[RULE 1303(b) (1)], [RULE 1402]

Section H Page 54
Facility I.D. #: 029110
Revision #: 09
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 559230 Granted as of 4/16/2014

Equipment Description:

AIR POLLUTION CONTROL SYSTEM NO. 3 CONSISTING OF:

- 1. CATALYTIC OXIDIZER, JOHNSON MATTHEY INC. OR EQUAL, MODEL NO. 91449 OR EQUAL, ALUMINUM OXIDE OR PLATINUM CATALYST ACTIVE MATERIAL, WITH 200 CPSI OXIDATION CATALYST OR EQUAL, 18.67 CUBIC FEET TOTAL VOLUME, WITH ASSOCIATED AUTOMATIC TEMPERATURE AND PRESSURE MONITORING DEVICES AND CONTROLS, AND WITH PROVISIONS FOR ADDING TWO LAYERS OF CATALYST.
- 2. SELECTIVE CATALYTIC REDUCTION, JOHNSON MATTHEY INC. OR EQUAL, MODEL NO. 79449 OR EQUAL, METALLIC SUBSTRATE, 37.33 CUBIC FOOT TOTAL VOLUME AND WITH PROVISIONS FOR ADDING TWO LAYERS OF CATALYST.
- 3 AQUEOUS UREA SOLUTION DOSING UNIT, INJECTORS, AND WITH ASSOCIATED AUTOMATIC TEMPERATURE, PRESSURE MONITORING AND CONTROL DEVICES.
- 4. EXHAUST STACK, 2'-6" DIA. X 59' H., ABOVE GROUND.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. AT LEAST 30 DAYS PRIOR TO INSTALLATION OF THE EQUIPMENT, ORANGE COUNTY SANITATION DISTRICT (OCSD) SHALL PROVIDE TO SCAQMD FINAL DESIGN DRAWINGS, PROCESS AND FLOW DIAGRAM, CONTROLS, EQUIPMENT SPECIFICATIONS (MAKE, MODEL, SIZE AND MAXIMUM CAPACITY).
 [RULE 204]
- 4. THE OPERATOR SHALL INSTALL AND MAINTAIN TEMPERATURE MEASURING AND RECORDING SYSTEMS TO MEASURE AND RECORD THE INLET AND OUTLET TEMPERATURES OF THE OXIDATION CATALYST AND THE SELECTIVE REDUCTION CATALYST. THE TEMPERATURES SHALL BE CONTINUOUSLY MEASURED AND RECORDED. THE TEMPERATURE GAUGES SHALL BE ACCURATE TO PLUS OR MINUS 5 PERCENT, AND BE CALIBRATED ONCE EVERY TWELVE MONTHS.

 [RULE 204]
- 5. THE OPERATOR SHALL INSTALL AND MAINTAIN DIFFERENTIAL PRESSURE AND RECORDING SYSTEMS TO MEASURE AND RECORD THE INLET AND OUTLET PRESSURES ACROSS THE



Section H Page 55 Facility I.D. #: 029110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

OXIDATION CATALYST AND THE SELECTIVE REDUCTION CATALYST. HE DIFFERENTIAL PRESSURES SHALL BE CONTINUOUSLY MEASURED AND RECORDED. [RULE 204]

- BASED ON THE OPERATING PARAMETERS' MEASURED AND MONITORED RESULTS OVER THE TWO-YEAR PERIOD (PER CONDITION #4 AND #5), OPERATING PARAMETERS' RANGE SHALL BE ESTABLISHED FOR THE PERMIT TO OPERATE. [RULE 204]
- EXCEPT DURING STARTUP AND SHUTDOWN OF THE SCR SYSTEM, THE UREA FEED CONTROL 7. SYSTEM SHALL BE IN OPERATION. [RULE 204]
- THE OPERATOR SHALL INSTALL AND MAINTAIN A UREA FLOW RATE MEASURING AND RECORDING SYSTEM TO ACCURATELY INDICATE AND RECORD THE UREA INJECTION RATE TO THE SELECTIVE CATALYTIC REDUCTION SYSTEM. [RULE 204]
- THE OPERATOR SHALL INSTALL AND MAINTAIN A NOX ANALYZER TO MEASURE SCR INLET NOX 9. CALIBRATED ANNUALLY IN ACCORDANCE WITH CONCENTRATION AND MANUFACTURER'S SPECIFICATIONS. [RULE 204]
- WHEN SCR IS IN OPERATION, THE OPERATOR SHALL ANALYZE THE UREA INJECTION RATE, AND 10. THE SCR INLET AND OUTLET NOX EMISSION RATE TO ESTIMATE THE AMMONIA CONCENTRATION IN THE SCR OUTLET, BASED ON ONE HOUR AVERAGE. [RULE 204]
- SAMPLING PORTS SHALL BE INSTALLED AT THE INLET AND OUTLET OF THE AIR POLLUTION 11. CONTROL SYSTEM. [RULE 204]
- THE AMMONIA SLIP SHALL BE TESTED WITHIN 180 DAYS AFTER INITIAL START-UP (POST 12. MODIFICATION), AND ANNUALLY THEREAFTER. THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS IN ACCORDANCE WITH THE APPROVED TEST PROCEDURES AND, FURNISH THE SCAQMD WRITTEN RESULTS OF SUCH PERFORMANCE TESTS WITHIN 45 DAYS AFTER TESTING. [RULE 1303(b) (1)], [RULE 1401]
- RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS 13. FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST. [RULE 204]



Page 56 Section H Facility I.D. #: 029110 Revision #: 09 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

Emissions and Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES 14. AND REGULATIONS: NH3 (AMMONIA SLIP): 5 PPMV AT 15% O2, 60 MINUTE AVERAGE, AFTER SCR START UP.

[RULE 1303(b) (1)], [RULE 1402]

Section H Page 57 Facility I.D. #: 029110 Revision #: 09 Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 559231 Granted as of 4/16/2014

Equipment Description:

AIR POLLUTION CONTROL SYSTEM NO. 4 CONSISTING OF:

- 1. CATALYTIC OXIDIZER, JOHNSON MATTHEY INC. OR EQUAL, MODEL NO. 91449 OR EQUAL, ALUMINUM OXIDE OR PLATINUM CATALYST ACTIVE MATERIAL, WITH 200 CPSI OXIDATION CATALYST OR EQUAL, 18.67 CUBIC FEET TOTAL VOLUME, WITH ASSOCIATED AUTOMATIC TEMPERATURE AND PRESSURE MONITORING DEVICES AND CONTROLS, AND WITH PROVISIONS FOR ADDING TWO LAYERS OF CATALYST.
- 2. SELECTIVE CATALYTIC REDUCTION, JOHNSON MATTHEY INC. OR EQUAL, MODEL NO. 79449 OR EQUAL, METALLIC SUBSTRATE, 37.33 CUBIC FOOT TOTAL VOLUME AND WITH PROVISIONS FOR ADDING TWO LAYERS OF CATALYST.
- 3 AQUEOUS UREA SOLUTION DOSING UNIT, INJECTORS, AND WITH ASSOCIATED AUTOMATIC TEMPERATURE, PRESSURE MONITORING AND CONTROL DEVICES.
- 4. EXHAUST STACK, 2'-6" DIA. X 59' H., ABOVE GROUND.

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
 [RULE 204]
- 3. AT LEAST 30 DAYS PRIOR TO INSTALLATION OF THE EQUIPMENT, ORANGE COUNTY SANITATION DISTRICT (OCSD) SHALL PROVIDE TO SCAQMD FINAL DESIGN DRAWINGS, PROCESS AND FLOW DIAGRAM, CONTROLS, EQUIPMENT SPECIFICATIONS (MAKE, MODEL, SIZE AND MAXIMUM CAPACITY).

 [RULE 204]
- 4. THE OPERATOR SHALL INSTALL AND MAINTAIN TEMPERATURE MEASURING AND RECORDING SYSTEMS TO MEASURE AND RECORD THE INLET AND OUTLET TEMPERATURES OF THE OXIDATION CATALYST AND THE SELECTIVE REDUCTION CATALYST. THE TEMPERATURES SHALL BE CONTINUOUSLY MEASURED AND RECORDED. THE TEMPERATURE GAUGES SHALL BE ACCURATE TO PLUS OR MINUS 5 PERCENT, AND BE CALIBRATED ONCE EVERY TWELVE MONTHS.

 [RULE 204]
- 5. THE OPERATOR SHALL INSTALL AND MAINTAIN DIFFERENTIAL PRESSURE AND RECORDING SYSTEMS TO MEASURE AND RECORD THE INLET AND OUTLET PRESSURES ACROSS THE

Section H Page 58
Facility I.D. #: 029110
Revision #: 09
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

OXIDATION CATALYST AND THE SELECTIVE REDUCTION CATALYST. HE DIFFERENTIAL PRESSURES SHALL BE CONTINUOUSLY MEASURED AND RECORDED. [RULE 204]

- 6. BASED ON THE OPERATING PARAMETERS' MEASURED AND MONITORED RESULTS OVER THE TWO-YEAR PERIOD (PER CONDITION #4 AND #5), OPERATING PARAMETERS' RANGE SHALL BE ESTABLISHED FOR THE PERMIT TO OPERATE.

 [RULE 204]
- 7. EXCEPT DURING STARTUP AND SHUTDOWN OF THE SCR SYSTEM, THE UREA FEED CONTROL SYSTEM SHALL BE IN OPERATION.
 [RULE 204]
- 8. THE OPERATOR SHALL INSTALL AND MAINTAIN A UREA FLOW RATE MEASURING AND RECORDING SYSTEM TO ACCURATELY INDICATE AND RECORD THE UREA INJECTION RATE TO THE SELECTIVE CATALYTIC REDUCTION SYSTEM.

 [RULE 204]
- 9. THE OPERATOR SHALL INSTALL AND MAINTAIN A NOX ANALYZER TO MEASURE SCR INLET NOX CONCENTRATION AND CALIBRATED ANNUALLY IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATIONS.
 [RULE 204]
- 10. WHEN SCR IS IN OPERATION, THE OPERATOR SHALL ANALYZE THE UREA INJECTION RATE, AND THE SCR INLET AND OUTLET NOX EMISSION RATE TO ESTIMATE THE AMMONIA CONCENTRATION IN THE SCR OUTLET, BASED ON ONE HOUR AVERAGE.

 [RULE 204]
- 11. SAMPLING PORTS SHALL BE INSTALLED AT THE INLET AND OUTLET OF THE AIR POLLUTION CONTROL SYSTEM.
 [RULE 204]
- 12. THE AMMONIA SLIP SHALL BE TESTED WITHIN 180 DAYS AFTER INITIAL START-UP (POST MODIFICATION), AND ANNUALLY THEREAFTER. THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS IN ACCORDANCE WITH THE APPROVED TEST PROCEDURES AND, FURNISH THE SCAQMD WRITTEN RESULTS OF SUCH PERFORMANCE TESTS WITHIN 45 DAYS AFTER TESTING.
 [RULE 1303(b) (1)], [RULE 1401]
- 13. RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.

 [RULE 204]



Section H Page 59
Facility I.D. #: 029110
Revision #: 09
Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

Emissions and Requirements:

14. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
NH3 (AMMONIA SLIP): 5 PPMV AT 15% O2, 60 MINUTE AVERAGE, AFTER SCR START UP.
[RULE 1303(b) (1)], [RULE 1402]

Section H Page 60 Facility I.D. #: 029110 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 559232 Granted as of 4/16/2014

Equipment Description:

AIR POLLUTION CONTROL SYSTEM NO. 5 CONSISTING OF:

- CATALYTIC OXIDIZER, JOHNSON MATTHEY INC. OR EQUAL, MODEL NO. 91449 OR EQUAL, 1. ALUMINUM OXIDE OR PLATINUM CATALYST ACTIVE MATERIAL, WITH 200 CPSI OXIDATION CATALYST OR EQUAL, 18.67 CUBIC FEET TOTAL VOLUME, WITH ASSOCIATED AUTOMATIC TEMPERATURE AND PRESSURE MONITORING DEVICES AND CONTROLS, AND WITH PROVISIONS FOR ADDING TWO LAYERS OF CATALYST.
- SELECTIVE CATALYTIC REDUCTION, JOHNSON MATTHEY INC. OR EQUAL, MODEL NO. 79449 OR 2. EQUAL, METALLIC SUBSTRATE, 37.33 CUBIC FOOT TOTAL VOLUME AND WITH PROVISIONS FOR ADDING TWO LAYERS OF CATALYST.
- 3 AQUEOUS UREA SOLUTION DOSING UNIT, INJECTORS, AND WITH ASSOCIATED AUTOMATIC TEMPERATURE, PRESSURE MONITORING AND CONTROL DEVICES.
- 4. EXHAUST STACK, 2'-6" DIA. X 59' H., ABOVE GROUND.

Conditions:

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW. [RULE 204]
- THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING 2. CONDITION AT ALL TIMES. [RULE 204]
- AT LEAST 30 DAYS PRIOR TO INSTALLATION OF THE EQUIPMENT, ORANGE COUNTY SANITATION DISTRICT (OCSD) SHALL PROVIDE TO SCAOMD FINAL DESIGN DRAWINGS, PROCESS AND FLOW DIAGRAM, CONTROLS, EQUIPMENT SPECIFICATIONS (MAKE, MODEL, SIZE AND MAXIMUM CAPACITY). [RULE 204]
- THE OPERATOR SHALL INSTALL AND MAINTAIN TEMPERATURE MEASURING AND RECORDING 4. SYSTEMS TO MEASURE AND RECORD THE INLET AND OUTLET TEMPERATURES OF THE OXIDATION CATALYST AND THE SELECTIVE REDUCTION CATALYST. THE TEMPERATURES SHALL BE CONTINUOUSLY MEASURED AND RECORDED. THE TEMPERATURE GAUGES SHALL BE ACCURATE TO PLUS OR MINUS 5 PERCENT, AND BE CALIBRATED ONCE EVERY TWELVE MONTHS. [RULE 204]
- THE OPERATOR SHALL INSTALL AND MAINTAIN DIFFERENTIAL PRESSURE AND RECORDING 5. SYSTEMS TO MEASURE AND RECORD THE INLET AND OUTLET PRESSURES ACROSS THE



Section H Page 61 Facility I.D. #: 029110 Revision #: nο

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

OXIDATION CATALYST AND THE SELECTIVE REDUCTION CATALYST. HE DIFFERENTIAL PRESSURES SHALL BE CONTINUOUSLY MEASURED AND RECORDED. [RULE 204]

- BASED ON THE OPERATING PARAMETERS' MEASURED AND MONITORED RESULTS OVER THE 6. TWO-YEAR PERIOD (PER CONDITION #4 AND #5), OPERATING PARAMETERS' RANGE SHALL BE ESTABLISHED FOR THE PERMIT TO OPERATE. [RULE 204]
- EXCEPT DURING STARTUP AND SHUTDOWN OF THE SCR SYSTEM, THE UREA FEED CONTROL 7. SYSTEM SHALL BE IN OPERATION. [RULE 204]
- THE OPERATOR SHALL INSTALL AND MAINTAIN A UREA FLOW RATE MEASURING AND 8. RECORDING SYSTEM TO ACCURATELY INDICATE AND RECORD THE UREA INJECTION RATE TO THE SELECTIVE CATALYTIC REDUCTION SYSTEM. [RULE 204]
- 9. THE OPERATOR SHALL INSTALL AND MAINTAIN A NOx ANALYZER TO MEASURE SCR INLET NOx CONCENTRATION AND CALIBRATED ANNUALLY IN ACCORDANCE WITH MANUFACTURER'S SPECIFICATIONS. [RULE 204]
- WHEN SCR IS IN OPERATION, THE OPERATOR SHALL ANALYZE THE UREA INJECTION RATE, AND 10. THE SCR INLET AND OUTLET NOX EMISSION RATE TO ESTIMATE THE AMMONIA CONCENTRATION IN THE SCR OUTLET, BASED ON ONE HOUR AVERAGE. [RULE 204]
- SAMPLING PORTS SHALL BE INSTALLED AT THE INLET AND OUTLET OF THE AIR POLLUTION 11. CONTROL SYSTEM. [RULE 204]
- THE AMMONIA SLIP SHALL BE TESTED WITHIN 180 DAYS AFTER INITIAL START-UP (POST 12. MODIFICATION), AND ANNUALLY THEREAFTER. THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS IN ACCORDANCE WITH THE APPROVED TEST PROCEDURES AND, FURNISH THE SCAOMD WRITTEN RESULTS OF SUCH PERFORMANCE TESTS WITHIN 45 DAYS AFTER TESTING. [RULE 1303(b) (1)], [RULE 1401]
- RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AOMD PERSONNEL UPON REQUEST. [RULE 204]



Page 62 Section H Facility I.D. #: 029110 09 Revision #:

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

Emissions and Requirements:

THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES 14. AND REGULATIONS:

NH3 (AMMONIA SLIP): 5 PPMV AT 15% O2, 60 MINUTE AVERAGE, AFTER SCR START UP.

[RULE 1303(b) (1)], [RULE 1402]



Section H Page 63 Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 565930 Granted as of 11/12/2014

Equipment Description:

MODIFICATIONS TO AIR POLLUTION CONTROL SYSTEM (G27920) CONSISTING OF;

- 1. FOUL AIR EXHAUST DUCTS FROM THREE (3) TRICKLING FILTERS, TRICKLING FILTER FACILITY'S (JOB NO. P2-90), IN PARALLEL.
- 2. THREE (3) EXHAUST BLOWERS, IN PARALLEL, EACH 11,000 SCFM, 25 H.P.
- 3. THREE (3) CAUSTIC IMPREGNATED ACTIVATED CARBON UNITS, IN PARALLEL, EACH CONTAINING MINIMUM OF 10,600 LBS OF ACTIVATED CARBON BY NORIT AMERICAS OR WESTATES OR EQUIVALENT, EACH VENTING A SINGLE TRICKLING FILTER.
- 4. THREE (3) EXHAUST STACKS, EACH 2.0'- 3" DIA. X 28' HIGH.

BY THE ADDITION OF:

- 5. THREE (3) CHEMICAL SCRUBBERS (JOB NO. FE13-04), EACH SINGLE STAGE, SIEMENS OR EQUIVALENT, APPROXIMATELY 20' H. X 6' D., JAEGER 7'-10' H. PACKING MATERIAL OR EQUAL, SCRUBBING SOLUTION RECIRCULATION LINE, ASSOCIATED PUMPS, METERS AND AUTOMATIC CONTROLS, MIST ELIMINATOR AND CONTINUOUS H2S MONITORING SYSTEM (OPTIONAL).
- ASSOCIATED SODIUM HYDROXIDE AND SODIUM HYPOCHLORITE STORAGE TANKS.
- 7. ITEM NO. 3 ABOVE, USED AS OPTIONAL POLISHING UNIT CONTAINING GRANULAR ACTIVATED CARBON, IF NEEDED, OR EMPTY VESSEL USED AS EXHAUST FOR THE CHEMICAL SCRUBBERS.

PERMIT CONDITIONS:

- I. CONSTRUCTION AND OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATIONS UNDER WHICH THIS PERMIT IS ISSUED.

 [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.

 [RULE 204]
- 3. THIS PERMIT TO CONSTRUCT IS VALID FOR ONE YEAR FROM ITS' ISSUANCE DATE. AN EXTENSION MAY BE GRANTED UPON WRITTEN REQUEST. SUCH A REQUEST SHALL INCLUDE THE REASONS THE EXTENSION IS REQUIRED, THE LENGTH OF THE EXTENSION, AND THE STATUS OF THE CONSTRUCTION ACTIVITIES COMPLETED TO DATE.

 [RULE 204]



Section H Page 64
Facility I.D. #: 029110
Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 4. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
 [RULE 204]
- 5. A FLOW METER SHALL BE INSTALLED AND MAINTAINED AT EACH OF THE ODOR CONTROL SYSTEM EXHAUST TO INDICATE THE TOTAL FOUL AIR FROM EACH OF THE TRICKLING FILTER TREATED, IN STANDARD CUBIC FEET PER MINUTE (SCFM). IN CASE A PRESSURE SENSOR DEVICE IS USED TO DETERMINE FLOW RATE, IN PLACE OF THE FLOW METER, A CONVERSION CHART SHALL BE MAINTAINED TO INDICATE THE CORRESPONDENT FLOW RATE, IN SCFM, TO THE PRESSURE READING.
 [RULE 204]
- 6. MAXIMUM FOUL AIR FLOW RATE FROM EACH TRICKLING FILTER TO BE TREATED SHALL NOT EXCEED 11,000 SCFM, AVERAGED OVER CALENDAR MONTH.

 [RULE 204]
- 7. SCRUBBER SYSTEM SHALL BE EQUIPPED WITH DIFFERENTIAL PRESSURE GAUGE, PH METER AND FLOW METER TO INDICATE AND MEASURE (GPM) FOR SCRUBBING LIQUID RECIRCULATION RATE.

 [RULE 204]
- 8. WHEN THE SCRUBBERS ARE IN OPERATION, AUTOMATIC HYDROGEN SULFIDE (H2S) MONITORING SYSTEM SHALL BE IN OPERATION AND MAINTAINED TO RECORD THE OUTLET H2S CONCENTRATION, IN PPMV. THE H2S MONITORING SYSTEM SHALL BE CALIBRATED PURSUANT TO MANUFACTURER'S RECOMMENDATIONS AND SPECIFICATIONS. [RULE 204]
- 9. WHEN THE AUTOMATIC H2S MONITORING SYSTEM IS NOT OPERATING, THE OPERATOR SHALL, ON A DAILY BASIS, MONITOR, RECORD AND MAINTAIN THE FOLLOWING PARAMETERS PER MANUFACTURER'S RECOMMENDATIONS.
 - DIFFERENTIAL PRESSURE ACROSS THE SCRUBBER, INCHES OF WATER COLUMN
 - SCRUBBING SOLUTION RECIRCULATION RATE, GPM
 - PH OF THE SCRUBBING SOLUTION
 - HYDROGEN SULFIDE (H2S) CONCENTRATION, PPMV, IN THE SCRUBBER EXHAUST. [RULE 204]
- 10. THE PH OF THE SCRUBBING SOLUTION SHALL BE MAINTAINED BETWEEN 8 AND 12 ON A DAILY AVERAGE.

 [RULE 204]
- 11. CONCENTRATION MEASURED AT EXHAUST SHALL NOT EXCEED THE FOLLOWING:

CONSTITUENT

CONCENTRATION

H2S

1.0 PPMV, DAILY AVERAGE

[RULE 402, 1401]



Section H Page 65 Facility I.D. #: 029110 Revision #: 09

Date: February 5, 2015

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 12. IN CASE, WHEN AN OPTIONAL POLISHING UNIT (GRANULAR ACTIVATED CARBON) IS PUT IN SERVICE, THE UNIT SHALL BE OPERATED AS PER MANUFACTURER'S RECOMMENDATIONS AND SPECIFICATIONS AND, IN COMPLIANCE WITH ABOVE CONDITION NO. 11. [RULE 204]
- 13. RECORDS SHALL BE MAINTAINED AS REQUIRED BY THIS PERMIT FOR COMPLIANCE. THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO SCAQMD PERSONNEL UPON REQUEST.
 [RULE 204]

Section I Facility ID: Revision #: Page: 1 029110

Date:

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION I: PLANS AND SCHEDULES

This section lists all plans approved by AQMD for the purposes of meeting the requirements of applicable AQMD rules specified below. The operator shall comply with all conditions specified in the approval of these plans.

Documents pertaining to the plan applications listed below are available for public review at AQMD Headquarters. Any changes to plan applications will require permit modification in accordance with Title V permit revision procedures.

List of approved plans:

Application	Rule
267656	431.1

NOTE: This section does not list compliance schedules pursuant to the requirements of Regulation XXX - Title V Permits; Rule 3004(a)(10)(C). For equipment subject to a variance, order for abatement, or alternative operating condition granted pursuant to Rule 518.2, equipment specific conditions are added to the equipment in Section D or H of the permit.



Section J Facility ID: Revision #:

Page: 1 029110

Date: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION J: AIR TOXICS [40CFR 63 Subpart VVV 03-23-2001]

NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS: PUBLICLY OWNED TREATMENT WORKS (NON-INDUSTRIAL PLANT)

- (1) The owner/operator of a Publicly Owned Treatment Works (POTW) shall comply with all applicable requirements of 40 CFR Subpart VVV and general requirements applicable to Non-Industrial POTW Plant (emission points and control point requirements) as listed under § 63.1586 including covers on all emission points up to the secondary influent pumping station or secondary treatment unit. Covers shall be tightly fitted and designed and operated to minimize exposure of wastewater to the atmosphere. Each opening in a treatment unit shall be maintained in a closed, sealed position unless wastewater is not present or except when plant personnel are present and conducting wastewater or sludge sampling, or equipment inspection, maintenance or repair.
- (2) The owner/operator of a Publicly Owned Treatment Works (POTW) shall comply with all applicable requirements of inspections listed under 40 CFR Subpart VVV, § 63.1588 including a visual inspection of all covers and their closure devices for defects that could results in air emissions. Inspections shall be conducted initially follow-up inspections at least once per year. Defects that are found on treatment units in use shall be repaired within 45 days. The owner/operator shall follow the notification and reporting requirements in § 63.1588 for repairs that cannot be completed in 45 days. Defects that are found on treatment units that are not in use shall be repaired prior to putting the treatment unit back in service.
- (3) The owner/operator of a Publicly Owned Treatment Works (POTW) shall comply with all applicable requirements to prepare and maintain the records for each treatment unit inspection, each defect detected during inspection, date of detection, corrective actions taken to repair the defect, the date the repair is completed, and all other requirements listed under 40 CFR Subpart VVV, § 63.1589
- (4) The owner/operator of a Publicly Owned Treatment Works (POTW) shall comply with all applicable requirements and notification of compliance status, as applicable, and other reports submittal as listed under 40 CFR Subpart VVV, § 63.1590



Section J Facility ID: Revision #:

Date:

Page: 2 029110 1

ion #: 1 April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION J: AIR TOXICS [40CFR 63 Subpart ZZZZ, #1 03-09-2011]

NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS: STATIONARY RECIPROCATING INTERNAL COMBUSTION ENGINES

The owner/operator of stationary Reciprocating Internal Combustion Engines (RICE) located at an area source of hazardous air pollutant (HAP) emissions shall comply with the applicable requirements of 40 CFR 63 Subpart ZZZZ including but not limited to the following:

1. The owner/operator shall comply with the applicable requirements as specified in 63.6603 including but not limited to the following:

Table 2d to Subpart ZZZZ of Part 63—Requirements for Existing Stationary RICE Located at Area Sources of HAP Emissions

As stated in §§63.6603 and 63.6640, you must comply with the following requirements for existing stationary RICE located at area sources of HAP emissions:

For each	You must meet the following requirement, except during periods of startup	During periods of startup you must.
landfill or digester gas-fired	a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first; b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first; and c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary.	

¹Sources have the option to utilize an oil analysis program as described in §63.6625(i) in order to extend the specified oil change requirement in Table 2d of this subpart.

- 2. The owner/operator shall comply with the applicable general requirements as specified in 63.6605.
- 3. The owner/operator shall comply with the applicable monitoring, installation, collection, operation, and maintenance requirements specified in 63.6625.
- 4. The owner/operator shall demonstrate continuous compliance with the applicable emission limitations and operating limitations specified in 63.6640 including but not limited to the following:
 - (a) You must demonstrate continuous compliance with each emission limitation and operating limitation according to methods specified in Table 6 to this subpart.



Section J Facility ID: Revision #: Page: 3 029110

Date:

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION J: AIR TOXICS
[40CFR 63 Subpart ZZZZ, #1 03-09-2011]

Table 6 to Subpart ZZZZ of Part 63—Continuous Compliance With Emission Limitations, Operating Limitations, Work Practices, and Management Practices

As stated in §63,6640, you must continuously comply with the emissions and operating limitations and work or management practices as required by the following:

For each	Complying with the requirement to	You must demonstrate continuous compliance by
existing non-emergency landfill or digester gas stationary SI RICE located at an area source of HAP	practices	i. Operating and maintaining the stationary RICE according to the manufacturer's emission-related operation and maintenance instructions; or ii. Develop and follow your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.

- (b) You must report each instance in which you did not meet each emission limitation or operating limitation in Table 2d to this subpart that apply to you. These instances are deviations from the emission and operating limitations in this subpart. These deviations must be reported according to the requirements in §63.6650.
- 5. The owner/operator shall comply with the applicable record keeping requirements specified in 63.6655 and 63.6660.



Section J Facility ID: Revision #: Page: 4 029110

Date:

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION J: AIR TOXICS [40CFR 63SubpartZZZZ 03-09-2011]

NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS: STATIONARY RECIPROCATING INTERNAL COMBUSTION ENGINES

The owner/operator of existing emergency stationary Reciprocating Internal Combustion Engines (RICE) located at an area source of hazardous air pollutant (HAP) emissions shall comply with the applicable requirements of 40 CFR 63 Subpart ZZZZ including but not limited to the following:

1. The owner/operator shall comply with the applicable requirements as specified in 63.6603 including but not limited to the following:

Table 2d to Subpart ZZZZ of Part 63—Requirements for Existing Stationary RICE Located at Area Sources of HAP Emissions

As stated in §§63.6603 and 63.6640, you must comply with the following requirements for existing stationary RICE located at area sources of HAP emissions:

For each	You must meet the following requirement, except during periods of startup	During periods of startup you must.
4. Emergency stationary CI RICE and black start stationary CI RICE. ²	a. Change oil and filter every 500 hours of operation or annually, whichever comes first; ¹	
	b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; and	
	c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	
5. Emergency stationary SI RICE; black start stationary SI RICE. ²	a. Change oil and filter every 500 hours of operation or annually, whichever comes first; b. Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first; and c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	ļ

¹Sources have the option to utilize an oil analysis program as described in §63.6625(i) in order to extend the specified oil change requirement in Table 2d of this subpart.

²If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in Table 2d of this subpart, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under Federal, State, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under Federal, State, or local law



Section J Facility ID: Revision #: ge: 5 029110

Date: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION J: AIR TOXICS [40CFR 63SubpartZZZZ 03-09-2011]

has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, State, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable.

- 2. The owner/operator shall comply with the applicable general requirements as specified in 63.6605.
- 3. The owner/operator shall comply with the applicable monitoring, installation, collection, operation, and maintenance requirements specified in 63.6625.
- 4. The owner/operator shall demonstrate continuous compliance with the applicable emission limitations and operating limitations specified in 63.6640 including but not limited to the following:
 - (a) You must demonstrate continuous compliance with each emission limitation and operating limitation according to methods specified in Table 6 to this subpart.

Table 6 to Subpart ZZZZ of Part 63—Continuous Compliance With Emission Limitations, Operating Limitations, Work Practices, and Management Practices

As stated in §63.6640, you must continuously comply with the emissions and operating limitations and work or management practices as required by the following:

For each	Complying with the requirement to	You must demonstrate continuous compliance by
existing emergency and black start stationary RICE located at an area source of HAP	a. Work or Management practices	i. Operating and maintaining the stationary RICE according to the manufacturer's emission-related operation and maintenance instructions; or ii. Develop and follow your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.

- (b) You must report each instance in which you did not meet each emission limitation or operating limitation in Table 2d to this subpart that apply to you. These instances are deviations from the emission and operating limitations in this subpart. These deviations must be reported according to the requirements in §63.6650.
- (c) you must operate the emergency stationary RICE according to the requirements in paragraphs
- (i) through (iii) of this section. Any operation other than emergency operation, maintenance and



Section J Facility ID; Revision #; Page: 6 029110

Date:

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION J: AIR TOXICS [40CFR 63SubpartZZZZ 03-09-2011]

testing, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (i) through (iii) of this section, is prohibited. If you do not operate the engine according to the requirements in paragraphs (i) through (iii) of this section, the engine will not be considered an emergency engine under this subpart and will need to meet all requirements for non-emergency engines.

- (i) There is no time limit on the use of emergency stationary RICE in emergency situations.
- (ii) You may operate your emergency stationary RICE for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of such units is limited to 100 hours per year. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency RICE beyond 100 hours per year.
- (iii) You may operate your emergency stationary RICE up to 50 hours per year in nonemergency situations, but those 50 hours are counted towards the 100 hours per year provided for maintenance and testing. The 50 hours per year for non-emergency situations cannot be used for peak shaving or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity; except that owners and operators may operate the emergency engine for a maximum of 15 hours per year as part of a demand response program if the regional transmission organization or equivalent balancing authority and transmission operator has determined there are emergency conditions that could lead to a potential electrical blackout, such as unusually low frequency, equipment overload, capacity or energy deficiency, or unacceptable voltage level. The engine may not be operated for more than 30 minutes prior to the time when the emergency condition is expected to occur, and the engine operation must be terminated immediately after the facility is notified that the emergency condition is no longer imminent. The 15 hours per year of demand response operation are counted as part of the 50 hours of operation per year provided for nonemergency situations. The supply of emergency power to another entity or entities pursuant to financial arrangement is not limited by this paragraph (iii), as long as the power provided by the financial arrangement is limited to emergency power.
- 5. The owner/operator shall comply with the applicable record keeping requirements specified in 63,6655 and 63,6660.

Section K Facility ID: Revision #: Page: 1 029110

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION K: TITLE V Administration

GENERAL PROVISIONS

- 1. This permit may be revised, revoked, reopened and reissued, or terminated for cause, or for failure to comply with regulatory requirements, permit terms, or conditions. [3004(a)(7)(C)]
- 2. This permit does not convey any property rights of any sort or any exclusive privilege. [3004(a)(7)(E)]

Permit Renewal and Expiration

- 3. (A) Except for solid waste incineration facilities subject to standards under section 129(e) of the Clean Air Act, this permit shall expire five years from the date that this Title V permit is issued. The operator's right to operate under this permit terminates at midnight on this date, unless the facility is protected by an application shield in accordance with Rule 3002(b), due to the filing of a timely and complete application for a Title V permit renewal, consistent with Rule 3003. [3004(a)(2), 3004(f)]
 - (B) A Title V permit for a solid waste incineration facility combusting municipal waste subject to standards under Section 129(e) of the Clean Air Act shall expire 12 years from the date of issuance unless such permit has been renewed pursuant to this regulation. These permits shall be reviewed by the Executive Officer at least every five years from the date of issuance. [3004(f)(2)]
- 4. To renew this permit, the operator shall submit to the Executive Officer an application for renewal at least 180 days, but not more than 545 days, prior to the expiration date of this permit. [3003(a)(6)]

Duty to Provide Information

5. The applicant for, or holder of, a Title V permit shall furnish, pursuant to Rule 3002(d) and (e), timely information and records to the Executive Officer or designee within a reasonable time as specified in writing by the Executive Officer or designee. [3004(a)(7)(F)]

Payment of Fees

6. The operator shall pay all required fees specified in Regulation III - Fees. [3004(a)(7)(G)]

Section K Facility ID: Revision #: Page: 2 029110

Date:

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION K: TITLE V Administration

Reopening for Cause

- 7. The Executive Officer will reopen and revise this permit if any of the following circumstances occur:
 - (A) Additional regulatory requirements become applicable with a remaining permit term of three or more years. Reopening is not required if the effective date of the requirement is later than the expiration date of this permit, unless the permit or any of its terms and conditions has been extended pursuant to paragraph (f)(4) of Rule 3004.
 - (B) The Executive Officer or EPA Administrator determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.
 - (C) The Executive Officer or EPA Administrator determines that the permit must be revised or revoked to assure compliance with the applicable requirements. [3005(g)(1)]

COMPLIANCE PROVISIONS

- 8. The operator shall comply with all regulatory requirements, and all permit terms and conditions, except:
 - (A) As provided for by the emergency provisions of condition no. 17 or condition no. 18, or
 - (B) As provided by an alternative operating condition granted pursuant to a federally approved (SIP-approved) Rule 518.2.

Any non-compliance with any federally enforceable permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or denial of a permit renewal application. Non-compliance may also be grounds for civil or criminal penalties under the California State Health and Safety Code. [3004(a)(7)(A)]

Section K Facility ID; Revision #; Page: 3 029110

Date: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION K: TITLE V Administration

- 9. The operator shall allow the Executive Officer or authorized representative, upon presentation of appropriate credentials to:
 - (A) Enter the operator's premises where emission-related activities are conducted, or records are kept under the conditions of this permit;
 - (B) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
 - (C) Inspect at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
 - (D) Sample or monitor at reasonable times, substances or parameters for the purpose of assuring compliance with the facility permit or regulatory requirements. [3004(a)(10)(B)]
- 10. All terms and conditions in this permit, including any provisions designed to limit a facility's potential to emit, are enforceable by the EPA Administrator and citizens under the federal Clean Air Act, unless the term or condition is designated as not federally enforceable. Each day during any portion of which a violation occurs is a separate offense. [3004(g)]
- 11. A challenge to any permit condition or requirement raised by EPA, the operator, or any other person, shall not invalidate or otherwise affect the remaining portions of this permit. [3007(b)]
- 12. The filing of any application for a permit revision, revocation, or termination, or a notification of planned changes or anticipated non-compliance does not stay any permit condition. [3004(a)(7)(D)]
- 13. It shall not be a defense for a person in an enforcement action, including those listed in Rule 3002(c)(2), that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit, except as provided for in "Emergency Provisions" of this section. [3004(a)(7)(H)]

Section K Facility ID: Revision #: Page: 4 029110

Date:

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION K: TITLE V Administration

- 14. The operator shall not build, erect, install, or use any equipment, the use of which, without resulting in a reduction in the total release of air contaminants to atmosphere, reduces or conceals an emission which would otherwise constitute a violation of Chapter 3 (commencing with Section 41700) of Part 4, of Division 26 of the California Health and Safety Code or of AQMD rules. This rule shall not apply to cases in which the only violation involved is of Section 41700 of the California Health and Safety Code, or Rule 402 of AQMD Rules. [408]
- 15. Nothing in this permit or in any permit shield can alter or affect:
 - (A) Under Section 303 of the federal Clean Air Act, the provisions for emergency orders;
 - (B) The liability of the operator for any violation of applicable requirements prior to or at the time of permit issuance;
 - (C) The applicable requirements of the Acid Rain Program, Regulation XXXI;
 - (D) The ability of EPA to obtain information from the operator pursuant to Section 114 of the federal Clean Air Act;
 - (E) The applicability of state or local requirements that are not "applicable requirements", as defined in Rule 3000, at the time of permit issuance but which do apply to the facility, such as toxics requirements unique to the State; and
 - (F) The applicability of regulatory requirements with compliance dates after the permit issuance date. [3004(c)(3)]
- 16. For any portable equipment that requires an AQMD or state permit or registration, excluding a) portable engines, b) military tactical support equipment and c) AQMD-permitted portable equipment that are not a major source, are not located at the facility for more than 12 consecutive months after commencing operation, and whose operation does not conflict with the terms or conditions of this Title V permit: 1) the facility operator shall keep a copy of the AQMD or state permit or registration; 2) the equipment operator shall comply with the conditions on the permit or registration and all other regulatory requirements; and 3) the facility operator shall treat the permit or registration as a part of its Title V permit, subject to recordkeeping, reporting and certification requirements. [3004(a)(1)]

Section K Facility ID: Revision #:

Date:

Page: 5 029110 1

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION K: TITLE V Administration **EMERGENCY PROVISIONS**

- 17. An emergency¹ constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limit only if:
 - (A) Properly signed, contemporaneous operating records or other credible evidence demonstrate that:
 - (1) An emergency occurred and the operator can identify the cause(s) of the emergency;
 - (2) The facility was operated properly (i.e. operated and maintained in accordance with the manufacturer's specifications, and in compliance with all regulatory requirements or a compliance plan), before the emergency occurred;
 - (3) The operator took all reasonable steps to minimize levels of emissions that exceeded emissions standard, or other requirements in the permit; and,
 - (4) The operator submitted a written notice of the emergency to the AQMD within two working days of the time when the emissions limitations were exceeded due to the emergency. The notice shall contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and
 - (B) The operator complies with the breakdown provisions of Rule 430 Breakdown Provisions, or subdivision (i) of Rule 2004 Requirements, whichever is applicable. [3002(g), 430, 2004(i)]
- 18. The operator is excused from complying with any regulatory requirement that is suspended by the Executive Officer during a state of emergency or state of war emergency, in accordance with Rule 118 Emergencies. [118]

^{1 &}quot;Emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the operator, including acts of God, which: (A) requires immediate corrective action to restore normal operation; and (B) causes the facility to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency; and (C) is not caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.

Section K Facility ID: Revision #:

Page: 6 029110 1

Date:

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION K: TITLE V Administration RECORDKEEPING PROVISIONS

- 19. In addition to any other recordkeeping requirements specified elsewhere in this permit, the operator shall keep records of required monitoring information, where applicable, that include:
 - (A) The date, place as defined in the Title V permit, and time of sampling or measurements;
 - (B) The date(s) analyses were performed;
 - (C) The company or entity that performed the analyses;
 - (D) The analytical techniques or methods used;
 - (E) The results of such analyses; and
 - (F) The operating conditions as existing at the time of sampling or measurement. [3004(a)(4)(B)]
- 20. The operator shall maintain records pursuant to Rule 109 and any applicable material safety data sheet (MSDS) for any equipment claimed to be exempt from a written permit by Rule 219 based on the information in those records. [219(t)]
- 21. The operator shall keep all records of monitoring data required by this permit or by regulatory requirements for a period of at least five years from the date of the monitoring sample, measurement, report, or application. [3004(a)(4)(E)]

REPORTING PROVISIONS

- 22. The operator shall comply with the following requirements for prompt reporting of deviations:
 - (A) Breakdowns shall be reported as required by Rule 430 Breakdown Provisions or subdivision (i) of Rule 2004 Requirements, whichever is applicable.

Section K Facility ID: Revision #: Page: 7 029110

Revision #; April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION K: TITLE V Administration

- (B) Other deviations from permit or applicable rule emission limitations, equipment operating conditions, or work practice standards, determined by observation or by any monitoring or testing required by the permit or applicable rules that result in emissions greater than those allowed by the permit or applicable rules shall be reported within 72 hours (unless a shorter reporting period is specified in an applicable State or Federal Regulation) of discovery of the deviation by contacting AQMD enforcement personnel assigned to this facility or otherwise calling (800) CUT-SMOG.
- (C) A written report of such deviations reported pursuant to (B), and any corrective actions or preventative measures taken, shall be submitted to AQMD, in an AQMD approved format, within 14 days of discovery of the deviation.
- (D) All other deviations shall be reported with the monitoring report required by condition no. 23. [3004(a)(5)]
- 23. Unless more frequent reporting of monitoring results are specified in other permit conditions or in regulatory requirements, the operator shall submit reports of any required monitoring to the AQMD at least twice per year. The report shall include a) a statement whether all monitoring required by the permit was conducted; and b) identification of all instances of deviations from permit or regulatory requirements. A report for the first six calendar months of the year is due by August 31 and a report for the last six calendar months of the year is due by February 28. [3004(a)(4)(F)]
- 24. The operator shall submit to the Executive Officer and to the Environmental Protection Agency (EPA), an annual compliance certification. For RECLAIM facilities, the certification is due when the Annual Permit Emissions Program (APEP) report is due and shall cover the same reporting period. For other facilities, the certification is due on March 1 for the previous calendar year. The certification need not include the period preceding the date the initial Title V permit was issued. Each compliance certification shall include:
 - (A) Identification of each permit term or condition that is the basis of the certification;

Section K Facility ID: Revision #: Date: Page: 8 029110 1 April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION K: TITLE V Administration

- (B) The compliance status during the reporting period;
- (C) Whether compliance was continuous or intermittent;
- (D) The method(s) used to determine compliance over the reporting period and currently, and
- (E) Any other facts specifically required by the Executive Officer to determine compliance.

The EPA copy of the certification shall be sent to: Director of the Air Division Attn: Air-3 USEPA, Region IX 75 Hawthorne St. San Francisco, CA 94105 [3004(a)(10)(E)]

25. All records, reports, and documents required to be submitted by a Title V operator to AQMD or EPA shall contain a certification of accuracy consistent with Rule 3003(c)(7) by a responsible official (as defined in Rule 3000). [3004(a)(12)]

PERIODIC MONITORING

26. All periodic monitoring required by this permit pursuant to Rule 3004(a)(4)(c) is based on the requirements and justifications in the AQMD document "Periodic Monitoring Guidelines for Title V Facilities" or in case-by-case determinations documented in the TitleV application file. [3004(a)(4)]

Section K Facility ID: Revision #: Page: 9 029110

Date: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION K: TITLE V Administration

FACILITY RULES

This facility is subject to the following rules and regulations

With the exception of Rule 402, 473, 477, 1118 and Rules 1401 through 1420, the following rules that are designated as non-federally enforceable are pending EPA approval as part of the state implementation plan. Upon the effective date of that approval, the approved rule(s) will become federally enforceable, and any earlier versions of those rules will no longer be federally enforceable.

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 104	1-9-1976	Federally enforceable
RULE 109	5-2-2003	Federally enforceable
RULE 1107	1-6-2006	Federally enforceable
RULE 1110.1	10-4-1985	Non federally enforceable
RULE 1110.2	11-14-1997	Non federally enforceable
RULE 1110.2	9-7-2012	Non federally enforceable
RULE 1113	7-13-2007	Federally enforceable
RULE 1113	9-6-2013	Non federally enforceable
RULE 1122	7-11-1997	Federally enforceable
RULE 1140	2-1-1980	Federally enforceable
RULE 1140	8-2-1985	Non federally enforceable
RULE 1146	11-17-2000	Federally enforceable
RULE 1146	5-13-1994	Federally enforceable
RULE 1146	9-5-2008	Non federally enforceable
RULE 1168	1-7-2005	Federally enforceable
RULE 1171	2-1-2008	Federally enforceable
RULE 1171	5-1-2009	Non federally enforceable
RULE 1303(a)(1)-BACT	12-6-2002	Non federally enforceable
RULE 1303(a)(1)-BACT	5-10-1996	Federally enforceable
RULE 1303(b)(1)	10-20-2000	Non federally enforceable
RULE 1303(b)(1)-Modeling	5-10-1996	Federally enforceable
RULE 1303(b)(2)-Offset	12-6-2002	Non federally enforceable

Section K Facility ID: Revision #: Page: 10 029110 1

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION K: TITLE V Administration

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 1303(b)(2)-Offset	5-10-1996	Federally enforceable
RULE 1304(a)-Modeling and	6-14-1996	Federally enforceable
Offset Exemption	1	
RULE 1309.1	5-3-2002	Federally enforceable
RULE 1309.1	8-3-2007	Non federally enforceable
RULE 1401	9-10-2010	Non federally enforceable
RULE 1402	3-4-2005	Non federally enforceable
RULE 1415	12-3-2010	Non federally enforceable
RULE 1418	9-10-1999	Non federally enforceable
RULE 1470	5-4-2012	Non federally enforceable
RULE 1472	3-7-2008	Non federally enforceable
RULE 204	10-8-1993	Federally enforceable
RULE 217	1-5-1990	Federally enforceable
RULE 218	5-14-1999	Federally enforceable
RULE 218.1	5-14-1999	Federally enforceable
RULE 219	5-3-2013	Non federally enforceable
RULE 3002	11-14-1997	Federally enforceable
RULE 3002	11-5-2010	Non federally enforceable
RULE 3003	11-14-1997	Federally enforceable
RULE 3003	11-5-2010	Non federally enforceable
RULE 3004	12-12-1997	Federally enforceable
RULE 3004(a)(4)-Periodic	12-12-1997	Federally enforceable
Monitoring		
RULE 3005	11-14-1997	Federally enforceable
RULE 3005	11-5-2010	Non federally enforceable
RULE 3006	11-14-1997	Federally enforceable
RULE 3006	11-5-2010	Non federally enforceable
RULE 3007	10-8-1993	Federally enforceable
RULE 301	6-1-2012	Non federally enforceable
RULE 304	6-1-2012	Non federally enforceable
RULE 306	6-1-2012	Non federally enforceable
RULE 401	11-9-2001	Non federally enforceable
RULE 401	3-2-1984	Federally enforceable

Section K Facility ID: Revision #: Page: 11 029110 1

Date: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

SECTION K: TITLE V Administration

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 402	5-7-1976	Non federally enforceable
RULE 403.1	1-15-1993	Federally enforceable
RULE 403.1	6-16-2000	Non federally enforceable
RULE 404	2-7-1986	Federally enforceable
RULE 407	4-2-1982	Federally enforceable
RULE 408	5-7-1976	Federally enforceable
RULE 409	8-7-1981	Federally enforceable
RULE 430	7-12-1996	Non federally enforceable
RULE 431.1	6-12-1998	Federally enforceable
RULE 431.2	5-4-1990	Federally enforceable
RULE 431.2	9-15-2000	Non federally enforceable
RULE 461	4-21-2000	Federally enforceable
RULE 461	6-15-2001	Non federally enforceable
RULE 701	6-13-1997	Federally enforceable
40CFR 63 Subpart VVV	3-23-2001	Federally enforceable
40CFR 63SubpartZZZZ	3-9-2011	Federally enforceable
40CFR 63SubpartZZZZ_01	3-9-2011	Federally enforceable
40CFR 82 Subpart B	7-14-1992	Federally enforceable
40CFR 82 Subpart F	5-14-1993	Federally enforceable



Appendix A Facility ID: Revision #: Date: Page: 1 029110 1 April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX A: NOX AND SOX EMITTING EQUIPMENT EXEMPT FROM WRITTEN PERMIT PURSUANT TO RULE 219

NONE

1.



Appendix B Facility ID: Revision #; Page: 1 029110 1

Revision #: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1107 01-06-2006]

Except as otherwise provided in Rule 1107

(1) VOC Content of Coatings

A person shall not apply to metal parts and products subject to the provisions of this rule any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below:

VOC LIMITS Less Water and Less Exempt Compounds Effective Dates									
Coating		<u>Air</u>	Dried			В	aked		
	gr	n/l	lb/	gal	gı	n/l	lb	/gal	
	Current	7/1/07	Current	7/1/07	Current	7/1/07	Current	7/1/07	
General One- Component	275	275	2.3	2.3	275	275	2.3	2.3	
General Multi- Component	340	340	2.8	2.8	275	275	2.3	2.3	
Military Specification	340	340	2.8	2.8	275	275	2.3	2.3	
Etching Filler	420	420	3.5	3.5	420	420	3.5	3.5	
Solar- Absorbent	420	420	3.5	3.5	360	360	3.0	3.0	
Heat-Resistant	420	420	3.5	3.5	360	360	3.0	3.0	
Extreme High- Gloss	420	340	3.5	2.8	360	360	3.0	3.0	
Metallic	420	420	3.5	3.5	420	420	3.5	3.5	

Appendix B Facility ID; Revision #: Page: 2 029110

Date: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1107 01-06-2006]

VOC LIMITS Less Water and Less Exempt Compounds Effective Dates, cont.

			Effective I	Jates, co	ont.			
Coating		Air-]	Dried			E	aked	
	gm	gm/l		lb/gal		gm/l		/gal
•	Current	7/1/07	Current	7/1/07	Current	7/1/07	Current	7/1/07
Extreme	420	420	3.5	3.5	360	360	3.0	3.0
Performance			İ		il			
Prefabricated	420	275	3.5	2.3	275	275	2.3	2.3
Architectural	ļ	}]]]			}
One-Component					<u> </u>			
Prefabricated	420	340	3.5	2.8	275	275	2.3	2.3
Architectural		}	Ì	<u>.</u>				<u> </u>
Multi-	·					-		1
Component		<u> </u>			 	<u> </u>		
Touch Up	420	420	3.5	3.5	360	360	3.0	3.0
Repair	420	420	3.5	3.5	360	360	3.0	3.0
Silicone Release	420	420	3.5	3.5	420	420	3.5	3.5
High-	420	420	3.5	3.5	420	420	3.5	3.5
Performance							:	
Architectural	<u> </u>				<u> </u>	<u> </u>		
Camouflage	420	420	3.5	3.5	420	420	3.5	3.5
Vacuum-	420	420	3.5	3.5	420	420	3.5	3.5
Metalizing	<u> </u>				<u> </u>			
Mold-Seal	420	420	3.5	3.5	420	420	3.5	3.5
High-	420	420	3.5	3.5	420	420	3.5	3.5
Temperature	<u> </u>				<u> </u>			
Electric-	420	420	3.5	3.5	420	420	3.5	3.5
Insulating								
Varnish	<u> </u>							
Pan Backing	420	420	3.5	3.5	420	420	3.5	3.5
Pretreatment	420	420	3.5	3.5	420	420	3.5	3.5
Coatings					. <u> </u>			



Appendix B Facility ID: Revision #: Page: 3 029110

Date: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1107 01-06-2006]

(2) A person shall not use VOC-containing materials which have a VOC content of more than 200 grams per liter of material for stripping any coating governed by this rule.

Appendix B Facility ID: Revision #:

Date:

Page: 4 029110

on #: 1 April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 07-13-2007]

- (1) Except as provided in paragraphs (c)(2), (c)(3), (c)(4), and specified coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage any architectural coating for use in the District which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, and no person shall apply or solicit the application of any architectural coating within the District that exceeds 250 grams of VOC per liter of coating as calculated in this paragraph.
- (2) Except as provided in paragraphs (c)(3), (c)(4), and designated coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified, and no person shall apply or solicit the application of any architectural coating within the District that exceeds the VOC limit as specified in this paragraph. No person shall apply or solicit the application within the District of any industrial maintenance coatings, except anti-graffiti coatings, for residential use or for use in areas such as office space and meeting rooms of industrial, commercial or institutional facilities not exposed to such extreme environmental conditions described in the definition of industrial maintenance coatings; or of any rust-preventative coating for industrial use, unless such a rust preventative coating complies with the Industrial Maintenance Coating VOC limit specified in the Table of Standards.



Appendix B Facility ID: Revision #: age: 5 029110

Date: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 07-13-2007] TABLE OF STANDARDS VOC LIMITS

Grams of VOC Per Liter of Coating, Less Water and Less Exempt Compounds

COATING CATEGORY	Ceiling Limit	Current Limit			Effect	ive Date		
	Lanut	Duint_	1/1/03	1/1/04	-1/1/05	7/1/06	7/1/07	7/1/08
Bond Breakers	350							
Clear Wood Finishes	350					275		
Varnish	350					275		
Sanding Sealers	350					275		
Lacquer	680	550			275			ļ
Clear Brushing Lacquer	680				275			
Concrete-Curing Compounds	350						100	
Concrete-Curing Compounds	350							
For Roadways and Bridges**								
Dry-Fog Coatings	400					<u> </u>	150	
Fire-Proofing Exterior Coatings	450	350						
Fire-Retardant Coatings***		-	 			-		
Clear	650					ľ		
Pigmented	350							
Flats	250	100		1.				50
Floor Coatings	420		100			50		
Graphic Arts (Sign) Coatings	500		-					
Industrial Maintenance (IM)	420			250		100		
Coatings								
High Temperature IM			420					
Coatings	Į.		ļ	Į į		l	ļ	
Zinc-Rich IM Primers	420		340			100		
Japans/Faux Finishing Coatings	700	350						
Magnesite Cement Coatings	600	450						
Mastic Coatings	300							
Metallic Pigmented Coatings	500							
Multi-Color Coatings	420	250						
Nonflat Coatings	250		150			50		

Appendix B Facility ID: Revision #: Date: Page: 6 029110 1

on #: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 07-13-2007]

	[KOLE 1115 07-15-2007]							
COATING CATEGORY	Ceiling Limit*	Current Limit	her experien	5 (5 54 SH 5 (44 SH)	a Alujera	ive Date		
			1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Nonflat High Gloss	250		150				50	
Pigmented Lacquer	680	550			275			
Pre-Treatment Wash Primers	780		420					
Primers, Sealers, and Undercoaters	350		200			100		
Quick-Dry Enamels	400		250			150	-50	
Quick-Dry Primers, Sealers, and Undercoaters	350		200			100		
Recycled Coatings	†		250					
Roof Coatings	300		250	-	50			
Roof Coatings, Aluminum	500				100]		
Roof Primers, Bituminous	350		350					
Rust Preventative Coatings	420		400			100		<u> </u>
Shellac								
Clear	730							
Pigmented	550							1
Specialty Primers	350					250	100	
Stains	350		250				100	
Stains, Interior	250							
Swimming Pool Coatings								
Repair	650		340					
Other	340							
Traffic Coatings	250	150					100	
Waterproofing Sealers	400		250			100		
Waterproofing	400					100		
Concrete/Masonry Sealers								
Wood Preservatives								
Below-Ground	350							
Other	.350						<u> </u>	

^{*} The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards.

^{**} Does not include compounds used for curbs and gutters, sidewalks, islands, driveways and other miscellaneous concrete areas.

^{***} The Fire-Retardant Coating category will be eliminated on January 1, 2007 and subsumed by the coating category for which they are formulated.



Appendix B Facility ID: Revision #: Page: 7 029110

Date: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 07-13-2007]

TABLE OF STANDARDS (cont.) VOC LIMITS

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120

Appendix B Facility ID: Revision #: Page: 8 029110

Date: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 09-06-2013]

- (1) Except as provided in paragraphs (c)(3), (c)(4), and designated coatings averaged under (c)(6), no person shall supply, sell, offer for sale, market, manufacture, blend, repackage, apply, store at a worksite, or solid the application of any architectural coating within in the District:
 - (A) That is listed in the Table of Standards 1 and contains VOC (exclusing any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified; or
 - (B) That is not listed in the Table of Standards 1, and contains VOC (excluding any colorant added to tint bases) in excess of 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, until January 1, 2014, at which time the limit drops to 50 grams of VOC per liter of coating, less water, less exempt compounds (0.42 pounds per gallon).
- (2) No person within the District shall add colorant at the point of sale that is listed in the Table of Standards 2 and contains VOC in excess of the corresponding VOC limit specified in the Table of Standards 2, after the effective date specified.

Appendix B Facility ID: Revision #: Date: Page: 9 029110 1 April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 09-06-2013]

TABLE OF STANDARDS I VOC LIMITS

Grams of VOC Per Liter of Coating, Less Water and Less Exempt Compounds

COATING CATEGORY	Ceiling Limit ¹	Current Limit ²	Effective Date 7/1/08 1/1/12 1/1/14		
Bond Breakers			7/1/00	1/1/12	1/1/14
Clear Wood Finishes		275			
Varnish	350	275			
Sanding Sealers	350	275			
Lacquer		275			
Concrete-Curing Compounds		100			
Concrete-Curing Compounds For Roadways and Bridges ³		350			
Concrete Surface Retarder		250	6.0000000000000000000000000000000000000		50
Driveway Sealer		100		50	
Dry-Fog Coatings		150			50
Faux Finishing Coatings					
Clear Topcoat	1	350		200	100
Decorative Coatings		350			
Glazes		350			
Japan		350			
Trowel Applied Coatings		350		150	50
Fire-Proofing Coatings		350			150
Flats	250	50	50		
Floor Coatings	100	50			
Form Release Compound		250			100
Graphic Arts (Sign) Coatings		500			150
Industrial Maintenance (IM) Coatings	420	100			
High Temperature IM Coatings		420			
Non-Sacrificial Anti-Graffiti Coatings		100			
Zinc-Rich IM Primers		100			
Magnesite Cement Contings		450	Esta process		
Mastic Coatings		300		<u></u>	100
Metallic Pigmented Coatings	500	500			150
Multi-Color Coatings		250			
Nonflat Coatings	150	50			
Pre-Treatment Wash Primers		420			
Primers, Sealers, and Undercoaters		100			
Reactive Penetrating Sealers		350			



Appendix B Facility ID: Revision #: Page: 10 029110

Date:

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 09-06-2013]

[KULE 1115 07-00-2015]					
Recycled Coatings		250			
Roof Coatings		50		10000000000000000000000000000000000000	
Roof Coatings, Aluminum		100		0.000.000.000	
Roof Primers, Bituminous		350			
Rust Preventative Coatings	400	100			
Sacrificial Anti-Graffiti Coatings		100		50	and the control of th
Shellac					
Clear		730			



Appendix B Facility ID: Revision #:

age; 11 029110

Revision #: Date:

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 09-06-2013]

			Effective Date	
COATING CATEGORY	Ceiling Limit'	Current Limit ²	7/1/08 1/1/12 1/1/14	
Pigmented		550		
Specialty Primers		100		
Stains	350	100		
Stains, Interior	250	250		
Stone Consolidant		450		
Swimming Pool Coatings				
Repair		340		
Other		340		
Traffic Coatings		100		
Waterproofing Sealers		100		
Waterproofing Concrete/Masonry Sealers		100		
Wood Preservatives		350		

- The specified ceiling limits are applicable to products sold under the Averaging Compliance Option.
- The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards.
- 3. Does not include compounds used for curbs and gutters, sidewalks, islands, driveways and other miscellaneous concrete areas.

TABLE OF STANDARDS 1 (cont.) VOC LIMITS

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120

TABLE OF STANDARDS 2 VOC LIMITS FOR COLORANTS

Grams of VOC Per Liter of Colorant Less Water and Less Exempt Compounds

- New Control of the	
COLORANT ADDED TO	Limit ⁴
Architectural Coatings, excluding IM Coatings	50
Solvent-Based IM	600
Waterborne IM	50

4. Effective January 1, 2014.

Appendix B Facility ID: Revision #: Page: 12 029110 1

sion #: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1168 01-07-2005]

- (1) Unless otherwise specified in paragraph (c)(2), a person shall not apply any adhesives, adhesive bonding primers, adhesive primers, or any other primer which have a VOC content in excess of 250 g/L less water and less exempt compounds.
- (2) A person shall not apply adhesives, adhesive bonding primers, adhesive primers, sealants, sealant primers, or any other primer which have a VOC content in excess of the limits specified below:

VOC Limit*, Less Water and Less Exempt Compounds in Grams per Liter

Architectural Applications	Current VOC Limit*
Indoor Carpet Adhesives	50
Carpet Pad Adhesives	50
Outdoor Carpet Adhesives	150
Wood Flooring Adhesive	100
Rubber Floor Adhesives	60
Subfloor Adhesives	50
Ceramic Tile Adhesives	65
VCT and Asphalt Tile Adhesives	50
Dry Wall and Panel Adhesives	50
Cove Base Adhesives	50
Multipurpose Construction Adhesives	70
Structural Glazing Adhesives	100
Single Ply Roof Membrane Adhesives	250



Appendix B Facility ID; Revision #:

029110 1

Date: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1168 01-07-2005]

Specialty Applications	VOC Limits and Effective Dates**			
	Current VOC Limit*	1-1-05	7-1-05	1-1-07
PVC Welding	510			
CPVC Welding	490			
ABS Welding	400		325	
Plastic Cement Welding	350	250		
Adhesive Primer for Plastic	650		550	
Computer Diskette Manufacturing	350		·	
Contact Adhesive	80	,		
Special Purpose Contact Adhesive	250			
Tire Retread	100			
Adhesive Primer for Traffic Marking Tape	150			
Structural Wood Member Adhesive	140			
Sheet Applied Rubber Lining Operations	850			
Top and Trim Adhesive	540			250

^{**} The specified limits remain in effect unless revised limits are listed in subsequent columns.



Appendix B Facility ID: Revision #:

Page: 14 029110

Date: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1168 01-07-2005]

For adhesives, adhesive bonding primers, or any other primer not regulated by the above two tables and applied to the following substrates, the following limits shall apply:

Substrate Specific Applications	Current VOC Limit*
Metal to Metal	30
Plastic Foams	50
Porous Material (except wood)	50
Wood	30
Fiberglass	80

If an adhesive is used to bond dissimilar substrates together the adhesive with the highest VOC content shall be allowed.

Sealants	Current VOC Limit*
Architectural	250
Marine Deck	760
Nonmembrane Roof	300
Roadway	250
Single-Ply Roof Membrane	450
Other	420



Appendix B Facility ID: Revision #: Date: Page: 15 029110 1

1 April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1168 01-07-2005]

Sealant Primers	Current VOC Limit*
Architectural	
Non Porous	250
Porous_	775
Modified Bituminous	500
Marine Deck	760
Other	750

^{*}For low-solid adhesives or sealants the VOC limit is expressed in grams per liter of material as determined in paragraph (b)(32); for all other adhesives and sealants, VOC limits are expressed as grams of VOC per liter of adhesive or sealant less water and less exempt compounds as determined in paragraph (b)(31).

Appendix B Facility ID: Revision #:

Page: 16 029110 1

Date: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 02-01-2008]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	CHRRENT LIMITS* VOC g/l (lb/gal)	EFFECTIVE 1/1/2008* VOC g/l (lb/gal)	EFFECTIV 1/1/2009 VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application		Annie Carma Visiento Carriera Annie a lacela	Confessional Assistant - Accordance
(i) General	25 (0.21)		
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)		
(iii) Medical Devices & Pharmaceuticals	800 (6.7)		
(B) Repair and Maintenance Cleaning			
(i) General	25 (0.21)		
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)		

Appendix B Facility ID: Revision #: Page: 17 029110 1

Revision #: 1
Date: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 02-01-2008]

	CURRENT LIMITS* VOC	EFFECTIVE 1/1/2008* VOC	1/1/2009 VOC
SOLVENT CLEANING ACTIVITY (cont.)	g/l (lb/gal)	g/l (Ib/gal)	g/l (Ib/gal)
(iii) Medical Devices & Pharmaceuticals			
(A) Tools, Equipment, &	800		
Machinery	(6.7)		·
(B) General Work Surfaces	600 (5.0)		
(C) Cleaning of Coatings or Adhesives Application Equipment	25 (0.21)		
(D) Cleaning of Ink Application Equipment			
(i) General	25 (0.21)		,
(ii) Flexographic Printing	25 (0.21)		
(iii) Gravure Printing			-
(A) Publication	100 (0.83)		
(B) Packaging	25 (0.21)		
(iv) Lithographic (Offset) or Letter Press Printing			
(A) Roller Wash, Blanket Wash, & On-Press Components			
(I) Newsprint	100 (0.83)		

Appendix B Facility ID: Revision #: Page: 18 029110

Date: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 02-01-2008]

	CURRENT LIMITS*	EFFECTIVE 1/1/2008* VOC	EFFECTIVE 1/1/2009 VOC
SOLVENT CLEANING ACTIVITY (cont.)	g/l (lb/gal)	g/l (lb/gal)	g/l (lb/gal)
(II) Other Substrates	500 (4.2)	100 (0.83)	
(B) Removable Press Components	25 (0.21)		
(v) Screen Printing	500 (4.2)	100 (0.83)	
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	650 (5.4)	650 (5.4)	100 (0.83)
(vii) Specialty Flexographic Printing	100 (0.83)		
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)		

^{*} The specified limits remain in effect unless revised limits are listed in subsequent columns.

Appendix B Facility ID: Revision #:

Page; 1 02911

Date: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 05-01-2009]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS* VOC g/l (lb/gal)	EFFECTIVE 1/1/2010 VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	
(iii) Medical Devices & Pharmaceuticals	800 (6.7)	
(B) Repair and Maintenance Cleaning		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	

Appendix B Facility ID: Revision #;

Date:

Page: 20 029110

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 05-01-2009]

	-	
SOLVENT CLEANING ACTIVITY (cont.)	CURRENT LIMITS* VOC g/l (lb/gal)	EFFECTIVE 1/1/2010 VOC g/l (lb/gal)
(iii) Medical Devices & Pharmaceuticals		
(A) Tools, Equipment, & Machinery	800 (6.7)	
(B) General Work Surfaces	600 (5.0)	
(C) Cleaning of Coatings or Adhesives Application Equipment	25 (0.21)	
(D) Cleaning of Ink Application Equipment		
(i) General	25 (0.21)	
(ii) Flexographic Printing	25 (0.21)	
(iii) Gravure Printing		
(A) Publication	100 (0.83)	
(B) Packaging	25 (0.21)	
(iv) Lithographic (Offset) or Letter Press Printing		
(A) Roller Wash, Blanket Wash, & On-Press Components	100 (0.83)	

Appendix B Facility ID: Revision #:

Page: 2: 02911

Date:

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 05-01-2009]

	CURRENT	EFFECTIVE
	LIMITS*	1/1/2010
SOLVENT CLEANING ACTIVITY	VOC g/l	VOC g/l
(cont.)	(lb/gal)	(lb/gal)
(B) Removable Press Components	25	
	(0.21)	
(v) Screen Printing	100	
	(0.83)	
(vi) Ultraviolet Ink/Electron Beam Ink	650	100
Application Equipment (except screen printing)	(5.4)	(0.83)
(vii) Specialty Flexographic Printing	100	
	(0.83)	
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)	

^{*} The specified limits remain in effect unless revised limits are listed in subsequent columns.

Appendix B Facility ID: Revision #:

029110 1

Date: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 404 02-07-1986]

The operator shall not discharge into the atmosphere from this equipment, particulate matter in excess of the concentration at standard conditions, shown in Table 404(a). Where the volume discharged is between figures listed in the Table, the exact concentration permitted to be discharged shall be determined by linear interpolation.

For the purposes of this rule, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

TABLE 404(a)

			•	•	ıı		•	
				oncentration			Maximum Co	
1			of Part	iculate			of Particular	te Matter
	Volume Di	scharged	Matter"A	llowed in	Volume Di	ischarged	Allowed in D	Pischarged
	Calculated	l as Dry	Dischar	ged Gas	Calculated a	ıs Dry Gas	Gas Calculated	l as Dry Gas
	Gas	3	Calculate	ed as Dry	At Standard	Conditions	at	
	At Stan	dard	Gas at S	Standard			Standard Co	onditions
1	Condit	ions	Cond	itions				
	Cubic	Cubic	Milligrams	Grains per	Cubic	Cubic	Milligrams	Grains per
	meters	feet	per	Cubic Foot	meters	feet	per	Cubic
	Per	Per	Cubic		Per Minute	Per	Cubic Meter	Foot
	Minute	Minute	Meter			Minute		
	25 or	883	450	0.196	900	31780	118	0.0515
		or						
	less	less						
	30	1059	420	.183	1000	35310	113	.0493
	35	1236	397	.173	1100	38850	109	.0476
	40	1413	377	.165	1200	42380	106	.0463
	45	1589	361	.158	1300	45910	102	.0445

Appendix B Facility ID: Revision #: Page: 23 029110

Date: April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 404 02-07-1986]

[KULL 404 02-07-1700]							
			oncentration			Maximum Co	ncentration
		of Part	iculate			of Particula	te Matter
Volume Di	scharged	Matter"A	Ilowed in	Volume D	ischarged	Allowed in I	Discharged
Calculated	l as Dry	Dischar	ged Gas	Calculated a	as Dry Gas	Gas Calculated	l as Dry Gas
Ga	S	Calculate	ed as Dry	At Standard	Conditions	at	
At Stan	ıdard	Gas at S	Standard			Standard Co	onditions
Condit			itions				
Cubic	Cubic	Milligrams	Grains per	Cubic	Cubic	Milligrams	Grains per
meters	feet	per	Cubic Foot	meters	feet	per	Cubic
Per	Per	Cubic		Per Minute	Per	Cubic Meter	Foot
Minute	Minute	Meter			Minute		_
50	1766	347	.152	1400	49440	100	.0437
60	2119	324	.141	1500	52970	97	.0424
70	2472	306	.134	1750	61800	92	.0402
80	2825	291	.127	2000	70630	87	.0380
90	3178	279	.122	2250	79460	83	.0362
100	3531	267	.117	2500	88290	80	.0349
125	4414	246	.107	3000	105900	75	.0327
150	5297	230	.100	4000	141300	67	.0293
175	6180	217	.0947	5000	176600	62	.0271
200	7063	206	.0900	6000	211900	58	.0253
250	8829	190	.0830	8000	282500	52	.0227
300	10590	177	.0773	10000	353100	48	.0210
350	12360	167 ⁻	.0730	15000	529700	41	.0179
400	14130	159	.0694	20000	706300	37	•
1							.0162
450	15890	152	.0664	25000	882900	34	.0148

Appendix B Facility ID: Revision #: Date:

029110 1

April 16, 2014

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

APPENDIX B: RULE EMISSION LIMITS [RULE 404 02-07-1986]

		L-					
Volume Di Calculated Ga At Star Condit	l as Dry s ndard	of Part	ed as Dry Standard	Volume D Calculated a At Standard	as Dry Gas	Maximum Co of Particula Allowed in D Gas Calculated at Standard Co	te Matter Discharged Las Dry Gas
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
500 600 700 800	17660 21190 24720 28250	146 137 129 123	.0637 .0598 .0563 .0537	30000 40000 50000 70000 or more	1059000 1413000 1766000 2472000 or more	32 28 26 23	.0140 .0122 .0114 .0100

ROUTING RECORD						
DATE	FROM	το	ACTION			
SEP 01 2015	GL	DS	To Assign			
9/2/15	DS	MW	Evaluate			
PH/3/15	MW	AU	Proof			
12/9/15	AV	MAC	Review			
12-9-15	MAC	MW	TYPOS			
12/10/15	MW	MC	Revesión			
12-10-15	MAC	DS	REVIEWED			
12/22/15	DS	MW	QUESTIONS			
12/22/15	mu	DS.	Revised			
REFERENCE TO OTHER RECORDS INCI UDING VARIANCES						

12/22/15 DS MW EDIT 12/23/15 DS GL Legorit

DATE	FROM	10	ACTION
DEC 2 3 2015	GL	MW	Bill/memo sent
1-13-16	MU	GL	Bill
2-1-16	GL		Scanned
		<u> </u>	
		 -	ļ <u></u>
		 	
			



South Coast Air Quality Mangement District

Source Test Engineering

PERFORMANCE TEST DATABASE

STID: P 15308	8	PRIORITY PROTOCOL	PRIORITY REPORT
CO EQUIPMEI APP EQUIPMENT ADDRE EQUIPMENT CI	NY: Orange County Sanitation In DID: 29110 NT: Boiler (Reclamation Plant Number	√o. 2)	5
REQUESTO	OR: Gaurang Rawal	Phone: 2543	
	RM: Accurate Environmental Se	Phone 714-379-920	0
DATECOND: Prot. Rec'd Date: Rept. Rec'd Date: Prot Requested by: Rept Requested by:	Protocol Repor	rs _	eck one of the following: Upload e-file to Onbase instead of hardcopy Scan hardcopy, discard e-file N/A, No e-file attached
Pollutant(s) To Be Tested: CO NOx, NO/NO2 Organics Other PM PM10 SOx	Applicable Rule/Permit Condition Cond. 10, 12 Cond. 10, 12 HHV, Cond. 8 Cond.12 Cond. 10 Cond. 10	Confirm ppmv, @3%O2 90.6 Confirm ppmv, @3%O2 5.52 PPMV (DG) gr/scf 3.1 lb	
Total Sulfur (TS) VOC	R 431.1, Cond. 12 Cond. 10	Confirm reported results 2.6 lb	os/day

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

<u>MEMORANDUM</u>

DATE:

December 4, 2015

TO:

Andrew Lee

FROM:

Rudy Eden D. S. for Rudy Eden

SUBJECT:

Evaluation of Source Test Protocol:

(Requested by Gaurang Rawal, August 26, 2015)

IDENTIFICATION:

(Application No. 545004, 545005)

(Facility ID No. 29110)

COMPANY:

EOUIPMENT:

Orange County Sanitation District

Boiler, 10,2 MM Btu/hr, Model SLE-05-250

TEST LOCATION:

22212 Brookhurst Street, Huntington Beach, CA 92646

TEST DATE:

10 Day Notice Required

REFERENCE: P15308 (STE Source Test File)

Source Test Engineering has completed the evaluation of the subject source test protocol for testing and has concluded that it is:

CONDITIONALLY ACCEPTABLE

Some of the applicable Rules and/or Permit Conditions may not have been acceptably addressed, and/or the proposed sampling locations, and/or the proposed sampling and analytical methods will need to be modified before testing can commence. Refer to the attached evaluation for a complete discussion concerning the modifications that must be implemented into this existing source test protocol.

The attached evaluation has not been forwarded to the facility or the source testing firm. It is the responsibility of the requestor to review the attached evaluation and forward it to the parties involved, if you concur with our findings. If there are any questions, please contact Mike Wickson at Ext. 2258.

DS:MDW

Attachment

cc: Dipankar Sarkar Gaurang Rawal

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT MONITORING & ANALYSIS DIVISION * SOURCE TEST ENGINEERING BRANCH SOURCE TEST PROTOCOL EVALUATION

S/T ID:	P15308
SCAQMD ID: COMPANY: EQUIPMENT:	FACILITY ID NO. 29110 Orange County Sanitation District Boiler, 10.2 MM Btu/hr, Model SLE-05-250
TEST LOCATION: TEST DATE:	22212 Brookhurst Street, Huntington Beach, CA 92646 10 Day Notice Required
REQUESTED BY: TYPE OF TEST: REASON FOR TEST:	Gaurang Rawal (Memo Dated August 26, 2015) PERFORMANCE/COMPLIANCE PROTOCOL CTESTING SUBJECT TO THE FOLLOWING RULE, PERMIT, OR SPECIFIED CONDITIONS): - Conditions 8, 10, 12 - Rule 431.1
REQUESTED EVAL: TEST FIRM:	NOx, CO, VOC, PM, SOx/TRS, Speciated Organics Accurate Environmental Services, Inc.
STE.EVALUATOR:	Mike Wickson EXT: 2258 REVIEW DATE: December 4, 2015
OVERVIEW O	F EVALUATION:
OVERALL CONFIDENCE IN SOURCE TEST PROTOCOL:	□ ACCEPTABLE ⊠ CONDITIONALLY ACCEPTABLE □ UNACCEPTABLE □ NOT REVIEWED
	• Deficiency noted concerning proposed NOx, CO, PM, H ₂ S/TRS, Speciated Organics, VOC emission testing.
DEFICIENCIES IDENTIFIED:	 Deficiency noted concerning proposed sampling location(s) and/or representativeness with respect to process and required testing.
	 Deficiency noted concerning proposed stack velocity and/or fuel flow measurements.
MODIFICATIONS OR REMEDIAL MEASURES REQUIRED:	 This source test protocol must be modified to address the deficiencies described in the following section of this evaluation; the source testing which incorporates these modifications may proceed without further discussion.

(REFER TO NEXT SECTION FOR COMPLETE DISCUSSION OF THESE DEFICIENCIES)

PROTOCOL REVIEW PAGE 2

S P E C I F I C R E Q U I R E M E N T S

This source test protocol has been reviewed by the Source Test Engineering Branch staff. The following item(s) specifically explain the required modifications to the existing source test protocol which must be implemented, or items requiring further discussion or explanation, before testing can proceed:

Completeness of Application/Protocol/Rep
--

Representativeness of Data & Process

Rule/Permit Fulfillment

Sampling & Analytical Methods

Quality Assurance

Calculations

COMPLETENESS OF PROTOCOL

- Mike Wickson shall be notified of the scheduled test dates and changes by email to mwickson@aqmd.gov or telephone at 909-396-2258 at least 10 days in advance.
- Each page of the final test report (including raw analytical and field data, as well as other third party reports) must have a unique and sequential <u>page number</u> which can be referenced in future correspondences.
- The percentage of Digester gas (DG) and Natural Gas (NG) during each run shall be reported in the final report and a statement provided on how these ratios compare to normal operations.
- Field data sheets shall be provided for fuel consumption of both DG and NG. A diagram showing the fuel routing and meter test locations is desirable to ensure the tester is sampling DG lines as well as NG lines separately.
- Permit condition number 10 lists concentration and mass emission limits for SOx.
 The tester does not propose to sample SOx for either NG or DG firing. The permit engineer may wish to require the additional testing for SOx.

REPRESENTATIVENESS OF DATA & PROCESS

- PM₁₀ emissions are to be estimated using total PM Methods. Actual PM₁₀ emissions
 may be overstated. Therefore, these emission data should not be used for banking or
 offset purposes in the future.
- SCAQMD Method 5.2 shall be used in place of the proposed Method 5.1.
- Individual fuel rates shall be provided where multiple fuels are combusted as well as total heat input rates.

SPECIFIC REQUIREMENTS

 As per permit condition 8, maximum, minimum, and average load testing is also required for PM and VOC testing and must be documented and explained in the final report. Normal load testing is appropriate where the permit conditions are silent for other pollutants and tests.

RULE/PERMIT FULFILLMENT

Testing must be conducted pursuant to the following Rule/Permit Conditions:

- P/C conditions 8, 10, 12
- Rule 431.1

All of the above requirements have been addressed in this protocol and are satisfactory as proposed, or as modified and discussed in this review. The source test report emission information must also be formatted to satisfy the above Rule/Permit Conditions.

SAMPLING & ANALYTICAL METHODS

- Fuel usage is to be taken for calculating inlet-based emissions. The following information must be recorded during testing and provided in the final source test report:
 - The fuel meter must be dedicated exclusively to that source or verified that only that source is operating during testing.
 - The fuel meter must be clearly identified and documented as to type (turbine, orifice, volumetric, etc.), make, model, serial no., min/max flow.
 - A current meter calibration certificate or "meter proof" relative to a NIST traceable standard, or SCAQMD equivalent, or District Method 1-4 Reference Method Velocity/Flowrate comparison (3-Run RAA).
 - Fuel meter corrections to standard temperature and pressure, and other corrections, if applicable, must be clearly shown.
 - If the fuel meter is also going to be used for stack velocity/flowrate determination by standard F-Factor calculation, then the fuel source must be of constant heating value and only standard HHV (1050 Btu/scf) and Fd_{O2} (8710 dscf/mmBtu) may be applied.
- Samples for total sulfur compounds using SCAQMD Method 307-91 are to be collected in Tedlar bags with plastic (non-metal) fittings. Analysis must be completed within 24 hours of sampling. This may be increased to 7 days when using treated canisters.
- Total PM using Method 5.2 is required and may also be used as a substitute for the Method 4.1 moisture data. The one hour standard run length may not be enough to

collect 5 mg of sample and a four hour test is recommended. Lab analysis should not dilute the sample to under the 5 mg confidence level.

- All particulate sampling analyses must include analysis of entire sample not aliquots
 or fractions of the total sample. Particulate analysis samples may not be split for
 other analyses of soluble substances, etc.
- CARB Method 430 is an approved method for aldehydes and shall be used. However there are known interferences associated with **nitrogen oxides** present in combustion equipment that may make this method inappropriate for this boiler. This may be an issue if the NO_x emissions exceed 50 ppm and the test company must address this concern by providing adequate and detailed proof via appropriate QA tests (spiking) showing that the reported results were not detrimentally affected. If the NO_x levels are very high, the use of <u>EPA Method 323</u> may be considered as the best method available substitute for Method 430. However, prior to its use, the SCAQMD shall be consulted.
- A cyclonic flow check is required at each load tested.
- Multi-pollutant stratification tests must be done at the stack outlet where NO_x is to be measured. This is especially important downstream of a catalytic device and in horizontal ducts. If stratified, the complete set of traverse points (per Method 1.1) shall be used to acquire a representative sample during the Method 100.1 testing. Copies or original DAS/SC readings for the reference method are to be included with the range values and trace lines of the analyzers clearly presented. All tests must be clearly documented, including delineation.
- Oxygen levels shall not be used for a stratification check. This is inappropriate for trace ppm levels pollutants. NO_x or other similar trace pollutant must be checked directly.
- VOC analysis must include assay for CO, CO₂, and oxygen as a QA measure.
- A Standard pitot tube may be required instead of a S-type pitot tube if outlet velocities fall below 0.05 in. W.C., and may be used provided it meets the specifications stated in SCAQMD Method 2.1. Whenever a standard pitot tube is used to perform a traverse, adequate proof must be furnished that the openings of the Pitot tube have not plugged up during the traverse period. The recording device must also be of increased precision. Use of electronic manometers is allowed subject to calibration reports and test procedures being provided, and proof of following such procedures, is supplied in the final report.
- Particulate sampling in exhaust streams with appreciable amounts of sulfur compounds (e.g., sulfuric acid) may require additional procedures/analyses to assure accurate reporting of total and solid particulates, since some forms of sulfur are

S P E C I F I C R E O U I R E M E N T S

defined as particulates. In this case, the preferred sampling protocol is a District Method 5.2¹ particulate sampling train with a heated probe/heated filter and a companion Method 6.1 SOx train. The filter/probe temperature influences total/solid particulate determination, depending upon the rule application:

- For District Rule 404/405 compliance, the probe/filter temperature is maintained between 180-200°F and liquid sulfuric acid (defined as particulate) and solid particulates are collected in the front half (probe+filter) of the sampling train with appropriate adjustments for total/solid particulate reporting. The back-half impinger train catch is also counted for total/solid particulate reporting after appropriate adjustments. If the probe/filter temperatures are maintained above 200°F, adjustments to certain particulate fractions are not allowed which can bias particulate reporting high, unless used in conjunction with the Method 6.1 SOx train results.
- For EPA/District REG IX New Source Compliance Standards (NSPS) particulate testing, the filter temperature is maintained at about 250°F and only the front-half particulate collection (probe and filter) are counted. If the probe/filter temperatures are maintained between 180-200°F, adjustments to front-half particulate fractions are not allowed which can bias particulate reporting high.
- Flow rate and concentration testing shall be performed simultaneously. Alternatively a reference point velocity may be used to establish the temporal flow changes, if the stack composition and velocity profile can be shown as stable.
- The following attachments highlight what the District requires whenever District Method 100.1 testing is specified or utilized:

ATTACHMENT A ATTACHMENT B ATTACHMENT C GENERAL CONTINUOUS GAS MONITORING REQUIREMENTS
SAMPLE CONDITIONING REQUIREMENTS FOR METHOD 100.1
NO2 TO NO CONVERSION TEST PROCEDURE

QUALITY ASSURANCE

- A copy of this test protocol evaluation shall be included in the final report.
- All applicable pieces of source test and process equipment used directly or indirectly for measurement of source test emission data must be calibrated, and the calibrations included in the final report (this includes gas meters, Pitot tubes, pressure gages, nozzles, temperature devices, calibration gases, fuel usage meters, totalizers, etc.).

¹ Use of District Method 5.1 particulate sampling train ("wet impingement" without upfront heated filter) is not recommended in high sulfur situations unless used in conjunction with a Method 6.1 SOx train.

SPECIFIC REQUIREMENTS

- Where appropriate, field blanks, reagent blanks and recovery spikes must be performed and the information submitted with the source test report. Only reagent blanks may be deducted for emission calculations.
- All raw data field data sheets, as well as recorder strip charts, must accompany the certification test report.
- Where laboratory instrument analysis is required, instrument raw stripcharts, calibrations and standards, and limit of detection must be included in the source test report. This also includes equipment transfer and "chain-of-custody" form clearly describing all equipment and laboratory ID numbers, dates and times, required analysis, and the signature/initials of persons involved in transfers. TCA analyses must also include trap burn-outs from previous test, if applicable.

CALCULATIONS

All calculations concerning intermediate process, emission, and/or flow information
must be shown and included in the final report. This also applies to calculations
concerning laboratory analyses emission calculations.

GENERAL TEST GUIDELINES

FINAL TEST REPORT

The final Source Test Report must include the following information:

- 1. Signed "Statement of Non-Conflict as an Independent Laboratory" (District Rule 304(k)) and CARB Lab Approval or District Lab Approval Program (LAP) document (if applicable).
- 2. A brief opening statement identifying the Facility I.D., the equipment A/N, P/O, or Device I.D. and the reason(s) for testing (applicable rules permit conditions, etc.). Include a copy of the Permit-to-Construct, Permit-to-Operate, or Facility Permit. Also identify the test dates, the personnel on hand for the test, names, titles and phone numbers of responsible test firm and facility personnel.
- 3. A summary of the Source Test results, including applicable rules and permit conditions (show allowable standards) and source test data properly formatted to satisfy these requirements.
- 4. A brief process description. Indicate equipment operation during testing; as well as any other information which may influence the final report.
- 5. A "self-critique" of anything that transpired during the test which you feel is useful in the interpretation of the test results.
- 6. A simple schematic diagram of the process, showing the sampling location, with respect to the upstream and downstream flow disturbances. Also include a cross-sectional diagram of the stack or duct at the sampling location, depicting the sampling points with respect to compass direction.
- 7. The sampling and analytical procedures. Be specific about all aspects of sampling and analysis. Include diagrams of test equipment and methods.
- 8. Complete raw field data, including production data indicative of the testing interval, lab analyses, and the test results (show all calculations).
- Current calibration data regarding all sampling and measuring equipment utilized during testing. This also includes all laboratory calibrations, as well as facility fuel meter calibrations. (see <u>District Source Testing Manual, Chapter III</u> or "<u>Quality Assurance Handbook For Air Pollution Measurement Systems</u>", Vol. III, U.S. EPA-600/4-77-0276).

GENERAL CONTINUOUS GAS MONITORING REQUIREMENTS

(600perf pro: REV 12/10/2015 1:36.00 PM)

The District requires continuous gas monitoring equipment employing sample extraction and conditioning, and electronic detection, to be conducted strictly according to District Method 100.1, with the emphasis upon representativeness, documentation, and quality assurance. This includes, in part:

- 1. Gas analyzers must meet minimum acceptable standards for method of detection, sensitivity, noise, precision, linearity, and interference (see TABLE 100.1-1 for details). Also, the gas sample extraction and conditioning equipment (probe, filter, pump, conditioner, connective plumbing, etc., and data acquisition and logging equipment shall meet minimum acceptable specifications, as described in Method 100.1.
- 2. It is recommended that the entire sampling system for continuous gas monitoring instruments should be leak checked before and after each test run by evacuating the system to a minimum of 20 in. Hg vacuum, and plugging for a period of 5 minutes. The resultant loss of vacuum can not exceed 1 in. Hg during this period.
- 3. Calibration of all analyzers must be accomplished at zero, mid span (40-60% of full scale range), and high span (80-95% of full scale range). The lowest practicable range should be selected for monitoring, so that the measured emission values are within 20-95% of the range. If a significant amount of the data are outside of this range, the data may be rejected, depending upon the application.
- 4. The calibration gases must be certified according to EPA Protocol Number 1, or certified to an analytical accuracy of ±1% and be NIST traceable (except cal gases used for system bias check), following EPA-600/R93/224, "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards", TABLE 2-2. Superblend or multi-component blend gas recertifications are based upon the individual component(s) with the shortest recertification date.
- 5. Field calibrations employing gas dilution systems (mass flow or critical orifice) must be performed in accordance with <u>EPA Method 205</u>, "Gas Dilution Verification <u>Protocol"</u>, or available "<u>Draft</u>" <u>SCAQMD Method</u>, and supported with appropriate documentation. A 5-point check is required.
- 6. A calibration error check, and zero/span drift check must be performed before and after each test run. Calibration error must be less than ±2% of the range of measurement for zero, mid, and high range calibration gases. Zero/span drift must be less than ±3% of the range of measurement.
- 7. A system bias check must be performed before and after each test run by alternately introducing cal gases to the entire sampling system, then to the gas analyzer(s), for comparison. The difference can not exceed ±5% of the analyzer range.
- 8. Semi-annual analyzer certifications consisting of linearity plot, calibration curve, response time, and interference response must be furnished with the other calibrations to satisfy O/A documentational requirements.

ATTACHMENT A (GENERAL CONTINUOUS GAS MONITORING REQUIREMENTS)

- 9. NO_X measurement must be performed in the NO_X mode of the analyzer. An NO₂ to NO converter is required if NO₂ constitutes 5% or more of the total NO_X in the sample stream, or the rule or permit condition requires "NO_X" monitoring. The NO₂ to NO converter must be at least 90% efficient (use the NO₂ to NO converter efficiency procedure). The converter should be high temperature (650°C) stainless steel, if no NH₃ is present. If NH₃ is present in the sample stream, then a low temperature (350°C) molybdenum catalyst must be used in the converter. This check must be done at the beginning of the test.
- 10. The connective tubing from the probe to the sample conditioner must be heated above the dewpoint and the dewpoint reported. The sample conditioner must be able to maintain a dewpoint temperature of 37°F or less. (Refer to the "Sample Conditioning Requirements for Method 100.1" Addendum, for details)
- 11. Data recorder resolution must be at least 0.5% of the range of measurement. A data point for each contaminant/diluent monitored must be recorded at least once/minute. Analog chart recorders must have a minimum 10-inch chart width, with 100 minor divisions.
- 12. All facets of testing must be <u>continuously</u> recorded. This includes the 3-point calibration, system bias, calibration error, and zero/span drift checks, which must precede and conclude each test run.
- 13. All chart traces, or digital printouts, must be included in the final report and must be clearly identified as to:
 - location/source
 - operator initials
 - date/running times
 - actual test interval
 - contaminant/diluent

- range changes
- range of measurement
- calibrations
- cal gas concentration/cyl. no.
- range of calibration
- 14. When more than one gas trace is shown on a chart, the individual traces must be distinguishable by color coding or some other means (original charts may be submitted, and returned following evaluation). If a gas measurement range has been "offset" from zero, or zero has been "transposed to the right side of the recorder chart, it must be clearly identified. this offset should not be more than 5-small divisions of the chart. This data must be corrected using the ratio of the offset.
- 15. Gaseous measurements must be conducted a minimum of 15 continuous minutes at each load or specified condition, after the readings have stabilized (RECLAIM reference method sampling requires a minimum of 30 continuous minutes at each load for RATAs). Processes having multiple exhausts exhibiting non-cyclic (i.e. steady-state) characteristics may alternatively be monitored using the above criteria. Otherwise, simultaneous sampling may be required.
- 16. Sampling locations not meeting the minimum site selection standards for District Method 1 must be tested for absence of stratification. (A gaseous constituent concentration profile differing more than 10% between any two monitoring points within the same cross-sectional plane of a stack or duct indicates stratification.) If stratification is present, and alternate approved site selection or modification is not possible, then special monitoring (see Chapter X of the District Source Testing Manual) will be required.

ADDENDUM TO "General Continuous Gas Monitoring Requirements"

SAMPLE CONDITIONING REQUIREMENTS FOR METHOD 100.1

For Method 100.1 tests, proper sample conditioning is essential for representative sampling. Sample conditioning includes removal of particulate matter and moisture present in the sample gas stream. The design of the sample conditioning system must be such that during the process of particulate and moisture removal, the pollutants of interest are not also removed from the gas stream. Method 100.1 requires that the tester select a system which will have a minimum "scrubbing" effect. In particular, NO₂ and SO₂ are more susceptible to scrubbing than, for example NO or CO, because of their high solubility in water. Since Method 100.1 is a reference method, it is required that a sample conditioning system cause only minimum loss of these pollutants.

The District recommends a gas sampling system which can be used universally. (i.e. under all testing conditions). The set-up includes a heated 1/4-inch stainless steel probe with a 50-80 micron size, sintered 316 stainless steel or ceramic filter at the tip; and a short (not more than 6 feet) heated Teflon line to the sample conditioning system. The temperature of the probe and the Teflon line should be maintained at about 250°F. The conditioning system consists of a pair of standard Greenburg-Smith impingers with the stems cut to about 1-inch length from the top, immersed in a bath containing water and dry ice pellets, and immediately followed by a thermo-electric cooler or permeation drier. The gas temperature at the outlet of the impinger shall be less than 60°F and the gas at the drier outlet shall be maintained at a dew point less than 37°F. If the drier can not be directly connected to the impinger outlet, then a Teflon line heated to 10°F above the impinger outlet gas temperature can be used for connection. Another particulate filter (about 5 microns) should be in the line right after the cooler/drier. All the temperatures should be measured and recorded, preferably on a strip chart recorder. If the moisture content of the exhaust gas is below 5% and the sample gas flow rate is less than 10 liters/minute, the impinger set-up need not be used, as long as no moisture condensation occurs in the system and the conditioned sample is maintained at the required dew point.

PRECAUTIONS: Never allow the water in the impingers to accumulate more than 1/4 of the impinger height. Don't allow the water bath to become frozen around the impingers, or cracking of the glassware may result. Assure that the thermo-electric cooler/permeation drier has adequate design capacity. Follow a good maintenance schedule for the cooler/drier gas conditioning system.

Other systems may be used, upon District approval, emphasizing the requirements that water is removed immediately after separation from the gas stream, and minimal water contact with the gas stream is assured.

1. An example of a <u>non-universally</u> applicable water removal system is based on the refrigerated cooling coil principle. A refrigerated cooling coil system can scrub out a high percentage of water soluble pollutants due to a comparatively long residence time, and intimate contact between the sample gases and the water droplets collected on the inside of the coil. Consequently, it will show a high bias for the CEMS being tested if the sample gas contains a significant amount of NO₂, compared to NO_x or SO₂, and therefore it may not be suitable in all cases.

600perf_pro: REV 12/10/15

NO2 TO NO CONVERSION TEST PROCEDURE

(Alternative to O₃ Titration Method-40 CFR 50.1, Appendix F)

1. NO_x Analyzer Requirements

- a. Full span range 0-20 ppm or 0-25 ppm
- b. Equipped with NO and NO_x modes

2. Auditing Gas Requirements

a. NO_2 in air (or N_2): Use NO_2 in air for a stainless steel converter.

b. Concentration of NO_2 : 15 to 18 ppm (C_0, ppm)

c. Recertification: An audit gas should be recertified after six months.

3. Calibration Gas Requirements

a. Concentration: NO (17 to 19 ppm) with less than 0.1 ppm NO₂ – High Span

NO (10 to 13 ppm) with less than 0.1 ppm NO₂ – Mid Span

b. Zero Gas: High purity N₂

4. Calibration of Analyzer:

- a. Calibrate NO mode with the NO calibration gases.
- b. Calibrate NO_x mode with the same gases without any gain adjustment.
- b1. If the analyzer is equipped with two independent gain adjusting circuits, skip 4.b., then repeat 4.a. for the NO_x mode.

5. Conversion Efficiency (CE) Test

- a. Analyze the audit gas with NO mode. Read and standardize concentration. (C_1, ppm)
- b. Analyze the audit gas with NO_x mode. Read and standardize concentration. (C_2 , ppm)

6. Calculation for Conversion Efficiency:

$$\%CE = \frac{|C_2 - C_1|}{C_0} x100$$

7. Criteria for Acceptability of CE

- a. %CE must be larger than 90%.
- b. C_1 must be less than 5% of total NO_x (NO + NO₂) in the NO₂ audit gas (Section 2b).

NOTE: NO_2 audit gas concentration of higher value than what is specified in Section 2. may be required where NO_2 present in the exhaust gas being measured is greater than 30 ppm. Select the NO_2 gas within 10% of the expected NO_2 concentration in the exhaust.

Serving:

Anaheim

Brea

Buena Park

Cypress

Fountain Valley

Fullerton

Garden Grove

Huntington Beach

Irvine

La Habra

La Palma

Los Alamitos

Newport Beach

Orange:

Placentia

Santa Ana

Seal Beach

Stanton

Tustin

Villa Park

County of Orange

Costa Mesa Sanitary District

Midway City Sanitary District

> Irvine Ranch Water District

Yorba Linda Water District



Orange County Sanitation District

10844 Ellis Avenue, Fountain Valley, CA 92708 714.962.2411 • www.ocsewers.com

August 24, 2015

Charles Tupac, Air Quality Analysis & Compliance Supervisor Toxics and Waste Management South Coast Air Quality Management District 21865 E. Copley Drive Diamond Bar, CA 91765-4182

SUBJECT: Submittal of Source Test Protocol for Modified Cleaver Brooks

Boilers (A/Nos. 545004 and 545005) located at Orange County Sanitation Districts (OCSD) Treatment Plant No. 2 (Facility ID

No. 29110)

In accordance with Permit Condition No. 8(B) of the above referenced Permits-to-Construct application numbers, we hereby submit for your review and approval one (1) original copy of the test protocol including a description of all sampling and analytical procedures to be used on a single representative boiler. Following SCAQMD evaluation and approval of the proposed testing procedures, OCSD will proceed with scheduling testing activities.

Should you have any questions and/or comments with regards to the enclosed material, please contact me at (714) 593–7405 or Vlad Kogan of our staff at (714) 593–7085.

Lisa Rothbart, P.E.

Environmental Supervisor

in Rull

LR:RA:jb

H:\dept\eng\790\Groups\Air Quality\Letters\Rothbart\2015\P2-106 Protocol Submittal CovLttr.doc

Enclosure

cc: V. Kogan

R. AbuShaban



COMPLIANCE SOURCE TEST PROTOCOL FOR THE DETERMINATION OF NO_X, CO, VOCs, PM, AND TRS FROM DIGESTER GAS AND NATURAL GAS AS A STANDBY FUEL-FIRED TWO CLEAVER BROOKS BOILERS OPERATED AT ORANGE COUNTY SANITATION DISTRICT TREATMENT PLANT NO. 2

FACILITY ID 29110, APPLICATIONS NO. 545004 OR 545005

Prepa	red	for
rrepa	ı cu	IUI

Orange County Sanitation District Treatment Plant No. 2

10844 Ellis Ave.

Fountain Valley, CA 92708

Facility Representative:	Randa AbuShaban
Equipment Description:	Two Cleaver Brooks Boilers
Application No.:	545004 or 545005
Proposed Test Date(s):	TBD
Issue Date:	July 20, 2015

Prepared by:

Reviewed by:

Wally Moe

Source Testing Manager

Source Testing Firm:

Hassan Amin

Project Manager

AUG 28 2015

STA RECEIVED

M&STE BRANCH

Accurate Environmental Services, Inc.

8200 Katella Ave, Suite D Stanton, California 90680 (714) 379-9200

Protocol Identification Number: TP 03322 OCSD

tion		<u>Page</u>
In	troduction	1.0-1
Pr	ocess and Equipment Description	2.0-1
Pr	ocess Conditions During the Test	3.0-1
Sa	mpling and analytical Techniques	4.0-1
4.1	SCAQMD Method 1.1	
4.2	SCAQMD Method 2.1 (Velocity)	4.0-2
4.3	SCAQMD Method 4.1 (Moisture)	4.0-3
4.4		
4.5		
4.6		
4.7		
4.8		
4.9		
4.10		
4.11		
Te		
7.2		
7.3		
Ar		
8.1		
8.2		
8.3	Permit to Construct	
	Pr Pr Sa 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9 4.10 4.11 Te Ca Ve 7.2 7.3 AI 8.1 8.2	Introduction Process and Equipment Description Process Conditions During the Test Sampling and analytical Techniques 4.1 SCAQMD Method 1.1 4.2 SCAQMD Method 2.1 (Velocity) 4.3 SCAQMD Method 4.1 (Moisture) 4.4 SCAQMD Method 100.1 (Continuous Emission Monitoring System) 4.5 SCAQMD Method 25.3, (Reactive Organic Compounds) 4.6 EPA Method 323, (Formaldehyde Emission) 4.7 EPA Method 15, (Toxic Compounds list) 4.8 EPA Method 19 (Fuel Flow Rate and Firing Rate Calculations) 4.9 SCAQMD Method 5.1, (Total Particulates) 4.10 SCAQMD Method 307.91, (Total Reduced Sulfur as H2S) 4.11 Reference Method QA/QC Program Summary Test Critique Calculations Verification Forms 7.2 SCAQMD LAP Certificate 7.3 Statement of No Conflict of Interest Appendices 8.1 Reference Method Field and Laboratory Data 8.2 Quality Assurance/Quality Control

1.0 Introduction

Accurate Environmental Services, Inc. (AES) has been contracted by Orange County Sanitation District Treatment Plant No. 2. The primary objective in executing the source test is to obtain reliable and representative data on the composition of the effluent gasses and the rate of emissions from a single process boiler at Orange County Sanitation District Treatment Plant No. 2 in Huntington Beach, California. The source testing is to be conducted on the Digester Gas and Natural Gas as a standby fuel fired one Cleaver Brooks Boiler at maximum, minimum, and normal operational loads in order to determine the emissions of oxides of nitrogen (NO_x), carbon monoxide (CO), oxygen (O₂), carbon dioxide (CO₂), and Stack gas flow rates in one Cleaver Brooks Boiler exhaust. (In addition the Normal load will include a Total non-methane organics (TNMHC's), Particulate Matter (PM), Total Reduced Sulfur as H₂S, and speciated trace organics. The source test matrix is detailed in the protocol.

In addition, Stratification checks will also be conducted at the sampling locations.

Accurate Inc. is an independent test contractor with no conflict of interest as defined by SCAQMD Rule 304(k) (4).

Contact Summary

Contracting Firm

Orange County Sanitation District 10844 Ellis Ave. Fountain Valley, CA 92708

Contact: Randa AbuShaban

(714) 593-7413

Site and Equipment Location:

Orange County Sanitation District Treatment Plant No. 2 22212 Brookhurst St. Huntington Beach, CA 92646 Contact: Randa AbuShaban

(714) 593-7413

Source Testing Firm:

Accurate Environmental Services, Inc. 8200 Katella Avenue, Suite D Stanton, California 90680 Contact: Wally Moe

(714) 379-9200

Regulatory Agency:


South Coast Air Quality Management District 21865 East Copley Drive Diamond Bar, California 91765 Contact: Gaurang Rawal

(909) 396-2543

The two Cleaver Brooks Boilers, with American Combustion Technology or equal, model No SLE-05-250, rated at 10.205,800 Btu/hr on Digester Gas as primary fuel, and Natural Gas as a standby fuel.

A block flow diagram is presented as Figure 3-1.

Figure 3-1 Process Diagram



3.0 Process Conditions during the Test

Documentation of operating parameters and process conditions will be performed using existing monitoring instruments. These conditions and parameters will be included in the final source test report. A single representative Cleaver Brooks Boiler will be tested at maximum (16 minutes), minimum (16 minutes), and normal (one hour) operating loads for natural gas and digester gas.

The following operating parameters will be included in the source test report:

- 1. Fuel flow at each load.
- 2. The exhaust flow rate (see Methods 1.1 thru 4.1).
- 3. The exhaust Temperature in degree F
- 4. The Oxygen content of the exhaust gases in percent.
- 5. The firing rate in BTU per hour.
- 6. Emission data in Pounds Per Hour

4.0 Sampling and Analytical Techniques

The compliance source testing will be performed at the exhaust of a single representative Cleaver Brooks Boilers. This compliance test will be conducted in accordance with the applicable SCAQMD and EPA test methodologies. Table 4.1 and 4.2 summarizes the test methods, locations, duration, and number of tests.

TABLE 4-1									
INLET SOURCE TEST REQUIREMENTS									
CONSTITUENTS	Fuel Type	REQUIRED UNITS	ANALYTICAL METHOD(S)	# OF SAMPLES					
Total Heat Input Rate	Digester & Natural	BTU/Hr	SCAQMD 19	1					
Digester Gas Btu Content (HHV)	Digester Gas	BTU/SCF	ASTM D3588	1					
Digester Gas Sulfur Content (as H2S)	Digester Gas /	PPMV	SCAQMD 307-91)	2					
Fuel Flow Rate	Digester & Natural	DSCFM	SCAQMD 1.1,2.1,3.1	1					

				ABLE 4-2				
CONSTITUENTS	OUTLET SOURCE TEST REQUIREMI Fuel Type REQUIRED UNI					ANALYTICAL METHOD(S)	# OF SAMPLES	
Total Non-Methane Hydrocarbons (TNMHC)	Diges	Digester Gas		Lbs/Hr	&	lb/mmcf	SCAQMD 25.3	2 Sample Trays
Toxic Air Contaminants:				•	•			•
Formaldehyde/ Acetaldehyde	Dig	ester (3as	Lbs/Hr	Lb/mmcf	PPMV	EPA 323	2
Acrolein	_							2
Benzene]					!		2
Carbon Tetrachloride								2
Chlorobenzene							2	
Chloroform							2	
,4(p)-Dichlorobenzene							2	
Ethylene Dichloride (1,2 -								2
Dichloroethane) Methylene Chloride	Dig	ester (Gas	Lbs/Hr	Lb/mmcf	PPMV	SCAQMD 207.1	2
Styrene								2
Tetrachloroethylene				1				2
oluene								2
,1,1-Trichloroethane								2
Frichloroethylene								2
Vinyl Chloride								2
Kylenes								2
Ammonia								2
Total Particulate	Dig	ester	Gas .		11 / 6	7000		
Matter (PM10)		r		Lbs/Hr	lb/mmcf	gr/DSCF	SCAQMD 5.1	I
Oxides of Nitrogen (As NO2)	Digester Gas	Æ	Natural Gas	Lbs/Hr	lb/mmcf	PPMV @ 3% O2	SCAQMD 100.1	1
Carbon Monoxide	Digester Gas	&	Natural Gas	Lbs/Hr	lb/mmcf	PPMV @ 3% O2	SCAQMD 100.1	1
Oxygen	Digester Gas	&	Natural Gas		%		SCAQMD 100.1	1
Nitrogen	Digester Gas	&	Natural Gas		%		SCAQMD 100.1	1
Moisture Content	Digester Gas	&	Natural Gas		%		SCAQMD 4.1	1
Temperature	Digester Gas	&	Natural Gas		°F		N/A	1
Flue Gas Flow Rate	Digester Gas	/&c	Natural Gas		DSCFM	•	SCAQMD 1.1,2.1,3.1	1

VOC

PM

,,,,

thud BTU's

4.1 SCAQMD Method 1.1

The reference method measurements will be made from sample ports accessible from the stack-sampling platform on the unit, roof, or from a man lift. The stack inside dimensions at the sample plane is, 20.0 inches. The sample ports are located 115.0 inches (5.75 diameters) downstream of the nearest flow disturbance and 63.0 inches (3.15 diameters) from the stack exit. Prior to the source test, the test location will be checked for cyclonic flow by rotating the Pitot tube until a null reading is obtained and the angle will be recorded by using a protractor. All gaseous samples will be collected by using multiple sampling points to show that no significant stratification exists at this location. A 16-point traverse for the flow rate and 8 points for the CEMS will be performed. A schematic of the Sampling and points locations are presented in Figures 4-1.

4.2 SCAQMD Method 2.1 (Velocity)

The stack gas velocity will be measured using SCAQMD Method 2.1. A 16-point traverse will be conducted during each test. The velocity will be measured by aligning the S-type pitot tube parallel to the stack axis and recording the differential pressure indicated on the Incline manometer and temperature. A schematic of the velocity equipment is presented in Figure 4-2.

Flue gas temperature will be measured using a thermocouple. Flue gas molecular weight is calculated from independently measured O₂, CO₂, and H₂O concentrations. Absolute pressure of the flue gas is determined from the barometric pressure at the sample location and the measured static pressure inside the duct or stack. Axial velocity is calculated using the following equations:

$$V_s = 2.9 * C_p * \sqrt{\Delta P * Ts * \frac{29.92 * 28.95}{P_s * MW_{wet}}}$$

Where:

 C_p = Pitot flow coefficient, dimensionless

 ΔP = Velocity head, inches of water

 $T_s = Gas temperature, {}^{\circ}R$

 P_s = Absolute stack pressure, inches Hg.

MW = Molecular weight of gas, lb/lb-mole

The flue gas flow rate is calculated from the measured stack gas velocity, and area of the measurement plane. The flow rate is then corrected to standard conditions using the gas temperature and gas pressure. The flow rate can be presented on a wet or dry basis by including or removing the moisture content of the gas. These calculations are presented below.

 $Q = V_s * Area * 60$, Wet actual cubic feet per minute

$$Q_{ws} = Q * \frac{T_{ref}}{T_s} * \frac{P_s}{29.92}$$
, Wet standard cubic feet per minute

$$Q_{sd} = Q_{ws} * (1 - \frac{\%H_2O}{100})$$
, Dry standard cubic feet per minute

4.3 SCAQMD Method 4.1 (Moisture)

For the Normal Load the moisture content will be determined using a sampling train consisting of a stainless steel probe, Teflon line, four impingers in an ice-water bath, a leak-free pump, a vacuum gauge, and a temperature compensated dry gas meter. Prior to sampling, a leak check of the sampling train will be performed to ensure system integrity. Additionally, tare weights of the charged individual impingers will be recorded using an electronic balance capable of weighing to the nearest 0.1 grams. The sample rate will be adjusted to approximately 0.75 cubic feet per minute and sampled for the duration of 30 minutes. A schematic of the moisture sample equipment is presented in Figure 4-3.

Following the test, the impingers are weighed and the moisture content of the flue gas is calculated from the measured moisture volume and dry gas volume.

For the maximum and minimum loads the moisture will be calculated using the following formula:

O2 Formula
$$y_{w} = 1 - \frac{20.9 (1-B_{wa})}{\frac{F_{w}}{F_{d}} (20.9-\%O_{2d}) + \%O_{2d}}$$

Where:

 $B_{ws} = 0.01$ $F_{w} = 10,610$

 $F_d = 8,710$

 O_{2d} = Dry Stack Oxygen concentration

4.4 SCAQMD Method 100.1 (Continuous Emission Monitoring System)

Accurate Inc. utilizes a mobile emission measurement laboratory for the measurements of NO_x, CO, O₂, and CO₂ using SCAQMD Method 100.1. The laboratory is housed in a clean, quiet, environmentally controlled base. The laboratory has air conditioning and heating to support the test instruments performance. A diagram of Accurate Inc.'s mobile emission monitoring system is presented in Figure 4-4.

Prior to beginning of testing, a system leak check, calibration error, and system bias check will be performed. The leak check will be accomplished by plugging the probe tip and drawing at least 22" Hg vacuum on the entire sampling system. When all flow meters indicate 0.0 SCFH flow and holds for five minutes, the system is proven to be free of any leaks.


The calibration error check will be performed as follows: After zeroing all analyzers, EPA Protocol No. 1 gases are used to calibrate each analyzer within 80-100% of full scale of the selected range. Then a 40%-60% of the selected range gas is introduced to each analyzer. Additionally, a system bias calibration check is performed by passing EPA protocol I zero and calibration gases through the entire sampling system using a three-way valve located at the probe tip. Sampling system bias checks are determined by comparing the external calibration values to that of the values when introduced directly to each instrument.

NO_x, CO, O₂, and CO₂ concentrations are measured using an extractive sampling system consisting of a heated probe, a heat traced Teflon sample line connected to a thermo-electrically cooled sample dryer. Following the dryer, the sample is drawn into a Teflon lined pump where it is pressurized and then filtered for delivery to the gas analysis portion of the system. Table 4-2 summarizes the reference method analyzers, which will be used for this test program.

Table 4-2 Reference Method Analyzers

Analyzer	Make	Model	S/N	Range	Comments
NO _x	Rosemount	NG 2000	45099259898	0-10 ppm 0-50 ppm	NO _x mode with Molly NO ₂ converter
\mathbf{O}_2	Rosemount	NG 2000	45099259898	0-10% 0-25%	-
CO ₂	Rosemount	NG 2000	45099259898	0-10% 0-20%	-
CO	Rosemount	NG 2000	_45099259898	0-10 ppm 0-500 ppm	-
Chart Recorder	Yokogawa	DR 241	42VF0687	n/a	-
DAS	Omega	MF 5500	n/a	n/a	-


Figure 4-1
Stack Diagram and Sampling Points Location



Port Length: 2.00

	CEMS Sar	mple Points		Velocity Sample Points			
	% of	Inches from	Inches Include	% of	Inches from	Inches Include	
Point	Diameter	Wall	Port L.	Diameter	Wall	Port L	
1				3.2	1.0	3.0	
. 2	10.5	2.1	4. I	10.5	2.1	4.1	
3				19.4	3.9	5.9	
4	32.3	6.5	8.5	32.3	6.5	8.5	
5				67.7	13.5	15.5	
6	80.6	16.1	18.1	80.6	16.1	18.1	
7				89.5	17.9	19.9	
8	96.8	19.4	21.4	96.8	19.0	21.0	

Figure 4-2 SCAQMD Method 2.1 Equipment







Figure 4-3 SCAQMD Method 5.2/4.1 Equipment



Rotometers Probe SO₂ Analyzer CO Analyzer NO_x Analyzer CO₂ Analyzer Strip chart/DAS O₂ Analyzer Sample Line 4 way Primary Water valves Knockout Electronic Chiller Regulator Filter Teflon Head Pump Bias Line

Figure 4-4
Reference Method CEMS Diagram (SCAQMD Method 100.1)

4.5 SCAQMD Method 25.3, Reactive Organic Gases

Reactive organic gases will be measured using SCAQMD Method 25.3. Duplicate samples will be simultaneously extracted using co-located stainless steel probes. The probes are connected to water condensate traps immersed in an ice bath. Evacuated tanks with metering valves and flow meters are connected to the water traps. The metering valves are opened at the beginning of the test period and adjusted to achieve a constant sample rate as indicated on the flow meter. Sampling is stopped when the vacuum in the tank reaches 1 to 5 inches high. Heavy organic components condense as liquids and solids in the water traps and lighter components pass through as gases into the tanks. Volatile organic compounds (VOC) as total non-methane organics (TGNMO) are determined by combining results from independent analyses of condensate in the traps and gases in the tanks.

CO₂, CO, CH₄, non-volatile organics, and non-methane volatile organics are separated prior to the TGNMO oxidation to CO₂ and measurement by non-dispersive infrared (NDIR) detector. The contents of the trap and tank are analyzed separately for methane, ethane, and total carbon. Results are reported as total gaseous non-methane (non-ethane) organic compounds.

I. Pretest preparation

A) Determine site specific sample approach as necessary

- 1. Access
- 2. Utilities
- 3. Safety
- 4. Process operation, type
- 5. Stack or duct dimensions including upstream and downstream diameters from flow disturbances. The diameter should be measured carefully and the location inspected for the width of insulation or other obstructions that will affect the diameter measurement
- 6. Port connections for monorail support
- 7. Flue gas temperature
- 8. Flue gas pressure
- 9. Flue gas velocity
- 10. Flue gas content
- 11. Limits of quantification
- 12. Compliance limit or other data objective
- 13. Acceptability limits for normal process and sampling parameters

B) Get sampling system components (from Approved Lab)

- 1. Tanks supplied by analytical lab (Quantum Analytical), precleaned with QA/QC audit.
- 2. Water traps supplied by analytical lab (Quantum Analytical), precleaned with QA/QC audit.
- 3. Sample flow controllers (Variflow), supplied by analytical lab (Quantum Analytical)
- 4. Water traps bucket
- 5. Stainless Steel Probes with nut (nut is used as a quartz glass wool holder used as filter)
- 6. Probe to impinger connection (glass or teflon tubing w/glass connectors)
- 7. Mobile laboratory supplies and equipment

- a) Distilled water
 - (1) Water used shall be distilled deionized water, ASTM specification D1193-77 Type 3. Distilled H₂O is obtained from an outside vendor (i.e., VWR).
- b) Aluminum foil
- c) Labels
- d) Prepared filters
 - (1) Precleaned Quartz Glass wool
- e) Tweezers, spatula
- f) Data sheets
- g) Nalgene wash bottles
- h) Paper towels

C) Collect sampling support equipment

- 1. Power cords
- 2. Multiple power outlet adapter
- 3. Port rags or seal
- 4. Gloves
- 5. Hot gloves if necessary
- 6. Rope and pulley system
- 7. Tools
- 8. Digital volt meter
- 9. Calculator
- 10. Clipboard
- 11. Pens

D) Collect data handling equipment and supplies

- 1. Portable computer with Method 25.3 sampling workbook
- 2. Data sheets
 - a) Method 1
 - b) Sampling
 - c) Chain of custody
- 3. Project Notebook
 - a) Protocol
 - b) Correspondence and protocol modifications
 - c) Space for test data

II. Mobilization and setup

- A) Load equipment securely into mobile laboratory vehicle and prepare for transport
- B) Transport mobile laboratory and all equipment to test site
- C) Check in with host site representatives
- D) Locate mobile laboratory in a clean, quiet, safe, level, location on site as close as practical to sample location area
- E) Establish radio communication between test team members

- F) Connect power and energize illumination and temperature control systems
- G) Remove all equipment and supplies stowed for transport in work areas
- H) Set up sample recovery area in mobile laboratory
 - 1. Clean counter top
 - 2. Place new aluminum foil on counter as blotter
 - 3. Fill wash bottles with distilled water
- I) Determine barometric pressure by calling nearest National Weather Service station and making appropriate corrections for differences in elevation
- J) Arrange sampling equipment at sample location
- K) Set up portable computer, start Excel[™] program, open appropriate workbook (25_1_calcs.xls) file containing method 1 worksheet, isokinetic setup worksheet, and data summary worksheets
- L) Prepare sampling equipment
 - 1. Inspect tanks, traps, and rotometer with critical flow limiting valve. Note tanks and traps number on data sheet. Label tanks and traps with test number, project number, and date
 - 2. Assemble train
 - a) Use two ranches to connect traps to rotometer with critical flow limiting valve and then to tanks and tighten all connecting fittings.

III. Sampling

- A) Perform sample system leak check
 - 1. Using an 1/8" male plugs, assure that each probe tip is tightly plugged
 - 2. Record the tank Vacuum as indicated by the vacuum gage.
 - 3. Open the sample flow valves and wait for 10 minutes.
 - 4. Recheck the indicated Vacuum
 - 5. If vacuum did not change, the system is acceptable
 - 6. Correct if not within limits
- B) Add ice to traps in traps holder 5 minutes prior to sampling.
- C) Put glass wool into nut at tip of probe.
- D) Using a high temperature wire connect the two probe ends together.
- E) Verify with Team Leader that process conditions are proper and that sampling can begin
- F) Insert probe into port and locate nozzle at test point oriented away from flow stream being careful not to touch port wall with nozzle tip.
- G) Allow time for probe temperature to equilibrate with stack temperature. Plug port with flame retardant cloth
- H) Begin sampling as follows. Record time and open the sample flow valve on one line of data sheet.
 - 1. Record other required information on data sheet
 - 2. Add ice to traps bucket if needed
- I) End sampling when the sample time period has been reached or vacuum on any tank is 5 in. Hg. whichever occurs first.
- J) Close samples flow valves and record the final clock and vacuum.
- K) Remove sample probes from port being careful not to touch the port wall.

- 1. Check sample systems for leaks by sealing probes inlet (when probes is cool enough)
- Open the sample flow valves and wait for 10 minutes.
- 3. Recheck the indicated Vacuum
- 4. If vacuum did not change, the system is acceptable
- L) Complete any notes on the testing on the sample data sheet and attach sample data sheet securely to sampling system for transport to sample recovery area
- M) Close the sample flow valve.
- N) Disconnect the condensate traps and tightly cap the vials, place in ice.
- O) Add ice to condensate traps to the top until returned to lab.

IV. Sample Analysis

Analysis of samples will be performed by an SCAQMD Approved Lab

4.6 EPA Methods 323 (Formaldehyde Emission)

An emission sample from the combustion exhaust is drawn through a midget impinger train containing chilled reagent water to absorb formaldehyde. The formaldehyde concentration in the impinger is determined by reaction with acetyl acetone to form a colored derivative which is measured colorimetrically.

4.7 EPA Methods 15 (Volatile Organic Compounds)

Two Samples of hydrocarbons will be collected in an evacuated Summa Canister. The sample will be analyzed for C₁-C₆ and C₆₊ using gas chromatography/FID. Data is reported as hexane.

4.8 EPA Method 19

The fuel meter reading will be taken at the start, during and at the end of each test run (Maximum, Minimum and Normal loads). The fuel flow will be corrected to standard conditions (pressure (29.92") and temperature (60°F)). The stack gas flowrate will then be calculated stochiometrically based on the Digester Gas and Natural Gas as a standby fuel higher heating value (HHV) of 1,050 BTU/scf and an F factor of 8,710 dscf/MBTU. The HHV and the fuel F factor for the Digester Gas and Natural Gas as a standby fuel will be used in accordance with EPA Method 19 protocol. A fuel meter calibration certificate will be included in the final report.

4.9 SCAQMD Method 5.1 Total Particulate Matter (PM) with Condensable Analysis

Particulate testing using SCAQMD Method 5.1. Particulate matter will be collected in the sampling probe, impinger train containing DI water and on a back-up filter. In this method, metered flue gas is collected isokinetically

The flue gas is collected isokinetically through a Stainless Steel nozzle, and a probe. This followed by a Teflon sample line, two Smith-Greenburg impingers, which contain 100 ml of distilled water, an empty impinger as a knockout, a back-up filter and an impinger containing silica gel. The impingers collect condensable particulate species while the filter collects any species existing the impingers.

Following testing, the impingers are weighed for moisture determination and the following sample fractions are recovered:

- 1. Probe, nozzle water washing and brushing;
- 2. Impingers and connecting glassware water wash;
- 3. Filter.

The probe wash, impinger contents are extracted with methylene chloride to determine condensable hydrocarbons that are considered particulate under SCAQMD requirements.

Filter and the impinger catch are dried at 105°C or evaporated, desiccated, and weighed to constant weight.

Each sample train fraction will be analyzed by acid-base titration for its acid content according to SCAQMD procedures, and for sulfate content also by barium thorn titration.

4.10 SCAQMD Method 307.91 (Total Reduced Sulfur as H₂S)

AES will use flow-through "silica lined fuel bombs" during the test. The fuel bomb will be attached to a 1/4 inch teflon tube at the sample location and then opened on both ends so fuel gas can purge through the fuel bomb for about five minute. The tester first close the outlet side of the fuel bomb and then the inlet side to ensure that the sample is collected inside the fuel bomb.

The samples were analyzed within forty-eight hours by Quantum Laboratory.

4.11 Reference Method QA/QC Program Summary

Accurate Environmental Services, Inc. is committed to providing emission related data, which is complete, precise, accurate, representative, and comparable. Accurate Inc.'s quality assurance program and procedures are designed to ensure that the data meet or exceed the requirements set forth by the EPA, CARB, SCAQMD, and SDAPCD of each test method for each of these items. The quality assurance program consists of the following items:

- Assignment of an Internal QA Officer
- Development and use of an internal QA Manual
- Personnel training
- Equipment maintenance and calibration
- Knowledge of current test methods
- Chain-of-custody
- QA reviews of test programs

Generally, Accurate Inc. QA/QC procedures follow guidelines in *Quality Assurance Handbook for Air Pollution Measurement Systems*, Volumes I through III. These procedures outline pretest preparation and calibrations of sampling equipment, post-test sample handling, and post-test calibrations. Standardized, written procedures, calculator programs, and spreadsheets are used for test planning, pre-surveys,

equipment checklists, preliminary calculations, data and sample collection, sample tracking, data analysis, and reporting. Pre-test preparations and maintenance.

Assignment of an Internal QA Officer: Accurate Inc. has assigned an internal QA Officer who is responsible for administering all aspects of the QA program.

Internal Quality Assurance Manual: Accurate Inc. has prepared a QA Manual according to the guidelines issued by EPA. The manual documents and formalizes all of Accurate Inc.'s QA efforts. The manual is a "living" document, which is revised as Accurate Inc. adds capabilities and procedures. The QA manual provides details on the items provided in this summary.

Personnel Training: Personnel training is essential to the production of high quality test results. Accurate Inc.'s training programs include:

- requirement for all technical personnel to read and understand the test methods performed
- requirement for all technical personnel to read and understand the Accurate Inc. QA manual
- In-house training
- Quality Assurance meetings
- Attendance at EPA sponsored training courses
- Maintenance of training records.

Equipment Maintenance and Calibration: All laboratory and field equipment used as a part of Accurate Inc.'s emission measurement programs is maintained according to manufacturer's recommendations. A summary of the major equipment maintenance schedules is summarized in Table 4-3. In addition to routine maintenance, calibrations are performed on all sampling equipment according to the procedures outlined in the applicable test method. The calibration intervals and techniques for major equipment components are summarized in Table 4-4.

Knowledge of Current Test Methods: Accurate Inc. maintains current copies of EPA, ARB, and SCAQMD Source Test Manuals and Rules and Regulations. Accurate Inc. personnel coordinate, attend, and present papers at emission testing related conferences. Accurate Inc. personnel maintain memberships in the Air and Waste Management Association and Source Evaluation Society. Accurate Inc. personnel continually work with industry and regulatory agencies in monitoring and developing new methods and rules.

Chain-of-Custody: Accurate Inc. maintains chain-of-custody documentation on all data sheets and samples. Samples are stored in a locked area accessible only to Accurate Inc. source test personnel. Data sheets are kept in the custody of the originator, program manager, or in locked storage until return to Accurate Inc.'s office. Upon return to the office, copies are made and stored in a locking file. The original data sheets are used for report preparation and any additions are initialed and dated.

QA Reviews: Every Accurate Inc. report is reviewed by someone separate from the report author. The reviewer is selected based on knowledge of the test methods used and the source tested. Periodic field, laboratory, and report reviews are performed by the QA Officer. Test plans are reviewed to ensure proper test methods are selected and reports are reviewed to ensure that the methods will be followed and any deviations from the methods are justified and documented.

Generally, Accurate Inc.'s QA/QC procedures follow guidelines in *Quality Assurance Handbook for Air Pollution Measurement Systems*, Volumes I through III. These procedures outline pretest preparation and calibrations of sampling equipment, post-test sample handling, and post-test calibrations. Standardized, written procedures, calculator programs, and spreadsheets are used for test planning, pre-surveys,

equipment checklists, preliminary calculations, data and sample collection, sample tracking, data analysis, and reporting. Pre-test preparations and maintenance include organization of the following equipment:

Table 4-3
Equipment Maintenance Schedule

Equipment National Sense are							
Equipment	Acceptance Limits	Frequency of Service	Methods of Service				
Pumps	Absence of leaks Ability to draw manufacturers required vacuum and flow	Every 500 hours of operation or 6 months, whichever is less	Visual inspection Clean Replace parts Leak check				
Flow Meters	Free mechanical movement	Every 500 hours of operation or 6 months, whichever is less	Visual inspection Clean Calibrate				
Sampling Instruments	Absence of malfunction Proper response to zero, span gas	As recommended by manufacturer	As recommended by manufacturer				
Integrated Sampling Tanks	1. Absence of leaks	Depends on nature of use	Steam clean Leak check				
Mobile Lab Sampling System	1. Absence of leaks	Depends on nature of use	Change filters Change gas dryer Leak check Check for system contamination				
Sampling lines	1. Sample degradation less than 2%	After each test series	1. Blow dry, inert gas through line until dry.				

Table 4-4
Sampling Equipment Calibration Requirements

Sampling Equipment Calibration Requirements									
Sampling Equipment	Calibration Frequency	Calibration Procedure	Acceptable Calibration Criteria						
Continuous Analyzers	Before and after each test day	3-point calibration error test	< 2% of analyzer range						
Continuous Analyzers	Before and after each test run	2-point sample system bias check	< 5% of analyzer range						
Continuous Analyzers	After each test run	2-point analyzer drift determination	< 3% of analyzer range						
CEMS System	Beginning of each day	leak check	< 1 in. Hg decrease in 5 min. at > 20 in. Hg						
Continuous Analyzers	Before and after each test day	3-point linearity	< 1% of analyzer range						
NO _x analyzer	Before or after each test day	NO ₂ -> NO converter efficiency	>90%						
S-type pitot tube	Semi-annually	Dimensional calibration	Meet dimensional criteria of Method 2						
S-type pitot tube	Annually	Wind tunnel calibration	Defined in Method 2						
S-type pitot tube	Prior to each project	Visual inspection	Meet dimensional criteria of Method 2						
Differential Pressure Gauges (except for manometers)	Semi-annually	Correction factor based on 5- point comparison to standard	+/- 5%						
Differential Pressure Gauges (except for manometers)	Bi-monthly	3-point comparison to standard, no correction factor	+/- 5%						
Manometer	Semi-annually	Clean and replace fluid							
Barometer	Semi-annually	Adjusted to mercury-in-glass or National Weather Service Station	+/- 0.1 inches Hg						
Dry gas meter	Semi-annually	Calibration check at 4 flow rates using a NIST traceable standard	+/- 2%						
Dry gas meter	Bi-monthly	Calibration check at 2 flow rates using a NIST traceable standard	+/- 2% of semi-annual factor						
Dry gas meter orifice	Annually	4-point calibration for ΔH@							
Temperature sensors	Semi-annually	3-point calibration vs. NIST traceable standard	+/- 1.5%						

The information in the Final Emissions Source Test Report will be formatted as follows:

- I. Table of Contents
- II. Executive Summary
- III. Results Table
- IV. Introduction/Test Description
 - a. Test Conditions
 - b. Sample Locations
- V. Equipment/Process Description including fuel meters(s), if applicable. This section shall include a statement that verifies acceptability of the method test location and the operating condition during the test.
 - a. List Legal Facility Owner and Address
 - b. Facility Contact Person and Information
 - c. Equipment Location and Address
- VI. Discussion of Results
- VII. List of Sampling and Analytical Methods Used. This section shall include a list of the test methods used. Do not include copies or descriptions of the source test methods if the methods were adhered to as written. If exceptions were made to the methods, submit only an explanation of the exceptions.
 - a. Test Procedures/Methods
 - b. Sampling Procedures & Equations
- VIII. Appendices
 - a. SCAQMD Method Results
 - b. Portable Analyzer Results
 - c. Schematic of Stack Sampling Locations
 - d. Field Data Sheets testing method and process data sheets shall be compiled in separate sections
 - e. QA/QC
 - f. Laboratory Analytical Data
 - g. Calibration Data and Calculations
 - h. Calibration Gas Certificates
 - i. Chain of Custody Information (as necessary)
 - j. Process Operating Data
 - k. Certifications (AQMD LAP or CARB Approval)
 - I. SCAQMD Permit(s)

General Emission Calculations

I. Stack Gas Velocity

A. Stack gas molecular weight, lb/lb-mole

$$MW_{dry} = 0.44 * \%CO_2 + 0.32 * \%O_2 + 0.28 * \%N_2$$

 $MW_{wet} = MW_{dry} * (1-B_{wo}) + 18 * B_{wo}$

B. Absolute stack pressure, iwg

$$Ps = Pbar + \frac{Psg}{13.6}$$

C. Stack gas velocity, ft/sec

$$V_s = 2.9 * C_p * \sqrt{\Delta P} * \sqrt{T_s} * \sqrt{\frac{29.92 * 28.95}{P_s * MW_{wet}}}$$

II. Moisture

A. Sample gas volume, dscf

$$V_{mstd} = 0.03342 * V_{m} * (P_{bar} + \frac{\Delta H}{13.6}) * \frac{T_{ref}}{T_{m}} * Y_{d}$$

B. Water vapor volume, scf

$$V_{wstd} = 0.0472 * V_{lc} * \frac{T_{ref}}{528 \text{ }^{\circ}R}$$

C. Moisture content, dimensionless

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

III. Stack gas flow rate

A. Actual stack gas volumetric flow rate, wacfm
$$Q = V_s * A_s * 60$$

B. Standard stack gas flow rate, dscfm

$$Q_{sd} = Q * (1-B_{wo}) * \frac{T_{ref}}{T_s} * \frac{P_s}{29.92}$$

- IV. Gaseous Mass Emission Rates, lb/hr $M = \frac{ppm * MW_i * Q_{sd} * 60}{SV * 10^6}$
- V. Emission Rates, lb/MMBtu $\frac{lb}{MMBtu} = \frac{ppm *MW_i *F}{SV * 10^6} * \frac{20.9 \%O_2}{20.9 \%O_2}$

Nomenclature:

 A_s = stack area, ft² B_{wo} = flue gas moisture content, dimensionless C_p = pitot calibration factor, dimensionless F = fuel F-Factor, dscf/MMBtu @ 0% O₂ Η = orifice differential pressure, iwg = mass of collected particulate, mg M_n M_1 = mass emission rate of specie i, lb/hr MW = molecular weight of flue gas, lb/lb-mole = molecular weight of specie i: M_{ix} SO₂: 64 NO_x: 46 CO: 28 HC: 16 0 = sample time, min. = average velocity head, iwg = $(\sqrt{\Delta P})^2$ ΔΡ Pbar = barometric pressure, inches Hg P_s = stack absolute pressure, inches Hg P_{sg} = stack static pressure, iwb Q = wet stack flow rate at actual conditions, wacfm Qsd = dry standard stack flow rate, dscfm SV = specific molar volume of an ideal gas at standard conditions, ft³/lb-mole $T_{\mathfrak{m}}$ = meter temperature, °R Tref = reference temperature, °R T_{s} = stack temperature, °R V_s = stack gas velocity, ft/sec V_{lc} = volume of liquid collected in impingers, ml V_{m} = uncorrected dry meter volume, dcf V_{mstd} = dry meter volume at standard conditions, dscf V_{wstd} = volume of water vapor at standard conditions, sef Y_d = meter calibration coefficient

7.0 Verification Forms

The following forms are presented in this section:

- Statement of No Conflict of Interest
- Accurate Inc.'s current SCAQMD Laboratory Approval Program (LAP) certificate

December 3, 2014

Mr. Walid Mohamed Accurate Environmental Services 8200 Katella Ave., Suite D Stanton, CA 90680

Subject: LAP Approval Notice Reference # 01LA0921

Dear Mr. Mohamed:

We completed our review of the renewal application you submitted for approval under the South Coast Air Quality Management District's Laboratory Approval Program (SCAQMD LAP). We are pleased to inform you that your firm is approved for the period beginning December 31, 2014, and ending December 31, 2015 for the following methods:

SCAQMD Methods 1-4 SCAQMD Method 25.1 (Sampling) SCAQMD Method 25.3 (Sampling) SCAQMD Rule 1121/1146.2 Protocols SCAQMD Method 100.1 (CO, CO₂, NOx, O₂, SO₂) SCAQMD Methods 5.1, 5.2, and 5.3 (Sampling) SCAQMD Method 6.1 (Sampling)

Your LAP approval to perform nitrogen oxide emissions compliance testing for SCAQMD Rule 1121/ 1146.2 Protocols includes a satellite facility located at:

Union Pacific Railroad 2000 S. Sycamore Avenue Bloomington, CA 92316

Thank you for participating in the SCAQMD LAP. Your cooperation helps us to achieve the goal of the LAP: to maintain high standards of quality in the sampling and analysis of source emissions. You may direct any questions or information to LAP Coordinator, Glenn Kasai. He may be reached by telephone at (909) 396-2271, or via e-mail at gkasai@aqmd.gov.

Sincerel

Rudy Eden, Senior Manager Laboratory Services & Source Test Engineering

Attachment

RE:GK/gk

Dipankar Sarkar

141203 LapRenewal.doc

7.2 Statement of No Conflict of Interest

(To be completed by authorized source testing firm representative and included in source test report)

The following facility and equipment will be tested by my source-testing firm, and are the subjects of this Statement:

Facility ID:	29110
Date(s) Tested:	TBD
Facility Name:	Orange County Sanitation District Treatment Plant No. 2
Equipment Address:	22212 Brookhurst St.
	Huntington Beach, CA 92646
Equipment to be Tested:	A Single Cleaver Brooks Boiler
Application No.:	545004 or 545005

I state, as its legally authorized representative, that the source testing firm of:

Source Test Firm: Accurate Environmental Services, Inc.

Business Address: 8200 Katella Ave, Suite D

Stanton, California 90680

is an "Independent Testing Laboratory" as defined in District Rule 304(k):

For the purposes of this Rule, when an independent testing laboratory is used for the purposes of establishing compliance with District rules or to obtain a District permit to operate, it must meet all of the following criteria:

- (1) The testing laboratory shall have no financial interest in the company or facility being tested. or in the parent company or any subsidiary thereof-
- (2) The company or facility being tested, or parent company or any subsidiary thereof, shall have no financial interest in the testing laboratory;
- (3) Any company or facility responsible for the emission of significant quantities of pollutants to the atmosphere, or parent company or any subsidiary thereof shall have no financial interest in the testing laboratory; and
- (4) The testing laboratory shall not be in partnership with, own or be owned by, in part or in full, the contractor who has provided or installed equipment (basic or control), or monitoring systems, or is providing maintenance for installed equipment or monitoring systems, for the company being tested

Furthermore, I state that any contracts or agreements entered into by my source testing firm and the facility referenced above, or its designated contractor(s), either verbal or written, are not contingent upon the outcome of the source testing, or the source testing information provided to the SCAQMD.

Signature:	Wally Mol	Date:	7/20/2015
Wally Moe	Source Testing Manager	714-379-9200	7/20/2015
(Name)	(Title)	(Phone)	(Date)
FORM ST-110			

Summary of Results

Facility:
Equipment:
Test Date:

Parameter	Units	High Load	Low Load	Normal Load	Allowable Limit
NOx, Concentration	ppm				
NO _x , @ 3% O ₂	ppm				
NO _{x,} Emission Rate	lb/hr				
CO, Concentration	ppm				1
CO, @ 3% O ₂	ppm			ļ	
CO Emission Rate	lb/hr				
Total Stack Flow Rate, measured	dscfm				
Total Stack Flow Rate, calculated	dscfm				
% Difference	%				
Stack Gas Flow Rate, Actual	acfm				
Fuel Flow Rate	scfm				
Stack Temperature	°F			_	
Air/Fuel Ratio	N/A	_			
O_2	%				
Firing Rate	MMBtu/hr				
% of Full Load	%				

Summary of Results

Facility:		
Source:		
Date:		
Parameter		
Stack Gas Velocity (ft/sec)		
Stack Temp (F)		
Moisture Fraction		
Fuel Flow Rate (scfin)		
Stack Flow, Dry		
Stack Flow, Actual		
O ₂ , (%)		
CO ₂ , (%)		
	Nitrogen Oxides (NOx)	
NOx Concentration, ppmv		_
Concentration ppmv @ 3%O ₂		
Concentration, ppmv @ 3%CO ₁		
Mass Emissions, Normal, lb/hr		
	Carbon Monoxide (CO)	
CO Concentration, ppmv		
Concentration, ppmv @ 3%O ₂		
Mass Emissions 1h/hr		

Run Number: 1

Facility: Source: Load: Date: Start Time: End Time: Operator:		Absolute Psi Stack Gas M Stack Area Bws				Barometrio Meter Gan Pitot Facto Static Pres Stack Dian Stack widt Stack lengt	nma: or: sure (Pg), n.(in.) (Eq: h (if rectar	in. H ₂ O: uivalent): ngular):		
Species	O_2	CO2	NO _x	co		Stack leng	in (ii recia	ngular).		
High-Range Gas Fraction of Span		1					Met	hod 2,1 Da	ta	
Span				1	i	đР		Temp	Vel.	Dry Flowrate
Span Gas Concentration, Cma HIGH					Point	(in. H ₂ O)	Angle	۰F	(fps)	(Qsd)
MID		1								
ZÉRO]]					
Initial Analyzer Calibration Check, Cai HIGH					1					
MID										·
ZERO					ŀ					ŀ
Response Time (seconds)										
Initial Analyzer Calibration Error, Ei HIGH				ŀ					'	
Ei = ((Cma - Cai)/Span)x100% MID ZERO				Į.						
Initial Bias Check, Chi Upscale High (H) or Mid (M)?		1			-					
UPSCALE		,								
(Select Calibration Gas Closest to Stack Gas Conc.) ZERO				ł	i					
Initial System Calibration Bias, Bi UPSCALE	-	 			i					
Bi = ((Cbi-Cai)/Span)x100% ZERO				1	į					
Final Bias Check, Cbf UPSCALE		1	-	1	1	*				
(Select Calibration Gas Closest to Stack Gas Conc.) ZERO		!		ļ	ļ					l
Final System Calibration Bias, Bf UPSCALE					1					ļ <u></u>
Bf = ((Cbf - Cai)/(Span))x100% ZERO					Average					
Drift Check, D UPSCALE										
D = ((Cbf - Cbi)/(Span))x100% ZERO]			1					
Average Bias Response, zero Gas, Co=(Cbi,zero+Cbf,zero)/2					1					
Average Bias Response, Upscale Gas, Cm=(Cbi,upscale+Cbf,upscale)/2]					
Average Measured Concentration, Cavg Drift Corrected Concentration, Cgas=(Cavg-Co)xCma/(Cm-Co)]					
Drift Corrected Concentration, Cgas=(Cavg-Co)xCma/(Cm-Co)		1]					
SCAQMD Method 4.1		7								
Orifice Pres. Meter Vol. Dry Gas Meter Tem	ıp.	4								
Point dH (in. H2O) Vm (cu. ft.) Inlet (⁰ F)		-								
		Inon No	1 1	1 2	1 1]			
		lmp, No. Final (g)	1	2	3	4				
final		កពេល (g) Initial (g)								
Total/Average		Net (g)		 	1					
		Total (g)								

VELOCITY AND MOISTURE DATA, CALCULATION

Facility: Source: Date:

Parameter Raw	Symbol	Units			
Round Stack, Diameter	ds	in,			
Rectangular Stack, Length	L	in.			
Width	w	in.			
Fuel Flow Rate	Ff	scfm			
Average Stack Temperature	Fs,f	deg. F			
Average Meter Temperature	Tm	deg. F			
Barometric Pressure	Pbar	in. Hg			
Stack Static Pressure	Pg	in. H20			
Avg. Delta H	dН	in. H20			
Avg. Velocity Head (mean square root)	dP	in. H20			
Pitot Coefficient	Ср	N/A			
Cas Sample Volume	Vm	cu ft.			
Meter Calibration Factor	Y	N/A			
%O2 in Stack Gas	C, O2	%, dry			
%CO2 in Stack Gas	C, CO2	%, dry			
Stack Gas Nitrogen Oxide Content, drift/bias corr.	C, NOx	ppmv,dry			
Total Impingers Gain (H2O)	Ww	grams			

VELOCITY AND MOISTURE DATA, CALCULATION

Facility: Source:

Parameter Calculated	Symbol	Units				
Stack Area, As = 3.14*(ds)**2/576 (Round)						
□ L * W/144 (Rectangular)	As	sq feet				
Avg. Stack Temperature, Ts,f = Fs,f + 460	Ts,f	degrees R				
Avg. Meter Temperature, Tm = Fm + 460	Tm	degrees R				
Gas Sample Volume @ Standard Conditions,						k.
VmStd = 17.64*Vm * Y *Tm (Pbar + dH/13.6)	VmStd	cubic ft.				
Volume of Water Vapor, VwStd = 0.04707*Ww	VwStd	cubic ft,				
Moisture Fraction, Bws = 1-((20.9-(1-Bws)/((Fw/Fd*(20.9-O2stack))-O2stack))	Bws	none				
Moisture Fraction, Bws = VwStd/(VmStd + VwStd)	Bws	none				
Dry Stack Gas Mol. Weight, Md = 0.32(Co2,m)+						
0.44(Cco2,m)+0.28{100-(C02,m)-(Cco2,m)}	Md	g/g-mole				
Wet Stack Gas Molecular Weight,						
Mw = Md(1-Bws)+18.0(Bws)	Mw	g/g-mole			ļ	
Nitrogen volume fraction in the stack gas,						
l – mole fraction of O2 in stack gas – mole fraction of CO2 in stack gas	N2f	mole		,		
Absolute Stack Pressure, Ps = Pbar + Pg/13.6	Ps	in. Hg				
Stack Gas Velocity						
vs = 85.49*Cp*[sqtt (dP)]avg * sqtt [Ts,avg /(Ps*Mw)]	vs	fVs	 			
Actual Stack Gas Flowrate, Q = 60*vs*As	Q	acfin				
Standard Stack Gas Flowrate						
Qsd = 528/29.92*Q*(Ps/Ts)	Qs	scfm				
Dry Standard Stack Gas Flowrate						
Qsd = 528/29.92*Q*(Ps/Ts)*(1-Bws)	Qsd	dscfm				
Volume Flow Rate of Combustion Air						
DSCFM x N2f)/0 791 (0.791 nitrogen volume fraction in ambient air)	Qsd	vdscfm				1
Air-to-Fuel Ratio, Volume Flow Rate of Combustion Air / Fuel Usage	NA	NA				
NOx Emissions, MNOx = 1.558e-7 * CNOx,m * Qsd * 46	MNOx	lb/hr				

Accurate Environmental Services Data Acquisition

Date & Time	O ₂ (%)	CO ₂ (%)	NOx (ppm)	CO (ppm)
-------------	--------------------	---------------------	-----------	----------

Page 38 of 78

EPA Method 19, Stack Gas Flowrate Calculation

Facility: Fuel Meter Model: Source: Fuel Meter S/N:

Date: Fuel Manufacturer:

Run	Tim	ıe	O_2	Fuel Flow	HHV	F	System Flow	Firing
	Start	End	(%)	Corr. (scfm)	(btu/scf)	Factor	(scfm)	Rate
					-			
		_					<u> </u>	

Fuel Flow Corrected (SCFM) = Fuel Used x Cal Factor / minutes
Flow Rate = Fuel Flow Rate x F Factor x HHV/1000000 x 20.95/(20.95 - O2 conc)

Page 39 of 78

Fuel Flow correction to STD Conditions

Facility: Source: Date:

	Run	Time		F. Flow	Time	Fuel Flow	Pres	Pressure	Temp	Corr. Fuel
		Start	End	Uncorr	(min)	per min	psig_	Factor	F	Flow
١.										
								<u> </u>		

Corr. Fuel Flow

Fuel Flow per min * (528/(Temp F+460)) * Pressure Factor (from Table)




SCAQMD Velocity and Moisture Data Sheet

Start Date: TC Readout ID: TC ID: D. G. Meter ID dP Indicator Type: D. G. Meter ID Zero: Level: dH @ Pitot Tube ID: Pbar: Pitot Cp: Pstatic: Pitot Leak Check Pre: Stack Diam: Post: Port Length: Port Dia. Method 4.1 Data, Run Through Impingers Dry Gas Meter	Facility: Unit:			_	-		Meter Y:	J D				- 1	4
A					_		TC Peade	u by: out ID:				- _	╮┟┪
D. G. Meter ID Heave December Decemb					-			Jul 117.				- '	' FT
			:		-			er ID			-	- լ	
Pitot Unbe Discription Pitot Cip P			<u> </u>	Level:	_						-	-	7
Nethod 4.1 Data, Run	Pitot Tube	m:			-							•	
Post					<u>-</u>							_	
Method 4.1 Data, Run	Pitot Leak				_							_	
##Matl. End Start Diff. Time dH Vol. T _m (in) T _m (out) Ti _{mp} Vac 1-H ₂ O		Po	st:		-		Port Leng	th:		_Port Di	a	- \	\Box
#/Matl. End Start Diff. Time dH Vol. T _m (in) T _m (out) Ti _{mp} Vac					Method	4.1 Dat	a, Run_	Thro	ugh				
1-H ₂ O		I	mpingers						Dry G	as Meter			
2-H ₂ O 3-Empty 4-SilicaGel Total Method 4.1 Leak Check: Pre: cfm@ in.Hg, Post: cfm@ in.Hg Method 2.1 Data Run #: Start - End Time: Start - End Time: Point Angle (in. H ₂ O) 1-1 1-2 1-2 1-3 1-3 1-4 1-4 1-4 1-4 1-5 1-5 1-6 1-6 1-7 1-7 1-8 1-8 1-8 1-8 1-8 1-8 1-8 1-8 1-8 1-8			End	Start	Diff.		Time	dH	Vol.	T _m (in)	T _m (out)	Timp	Vac.
3-Empty 4-SilicaGel Total Total Total			<u> </u>				ļ			<u> </u>		ļ	
A-SilicaGe Total Total Total Total In.Hg., Post: cfm@ in.Hg., Post: cfm@ in.Hg.			_		 		<u> </u>			ļ		ļ	
Total Method 4.1 Leak Check: Pre: Cfm@ in.Hg, Post: Cfm@ in.Hg										<u> </u>		<u> </u>	
Method 4.1 Leak Check: Pre: cfm@ in.Hg. Post: cfm@ in.Hg. Method 2.1 Data Run #: Run #: Run #: Start - End Time: Of Point Angle (in. H₂O) o°F Point Angle (in. H₂O) O°F Point Angle (in. H₂O) O°F Point Angle (in. H₂O) O°F					<u> </u>			<u>-</u>		 		ļ	
Nethod 2.1 Data Run #: Run #: Start - End Time: Start -			<u> </u>				Total					<u> </u>	
Run #: Start - End Time: Start - End Tim	Method 4.1	Leak C	heck:	Pre:					Post:		cfm@		in.Hg
Start - End Time: End Time: End Time: Start - End Time:					T		od 2.1 Dat	<u>a</u>					
Point Angle dP (in. H ₂ O) °F Point Angle (in. H ₂ O) °F Point (
Point Angle (in. H ₂ O) °F Point Angle (in. H ₂ O) °F Point Angle (in. H ₂ O) °F 1-1 <	Start - End	Time:			Start -	End Tir			Start - En	d Time:			
1-1		-		-		1	t l	_					_
1-2 1-2 1-2 1-3 1-3 1-3 1-4 1-4 1-4 1-5 1-5 1-5 1-6 1-6 1-6 1-7 1-7 1-7 1-8 1-8 1-8 2-1 2-1 2-1 2-2 2-2 2-2 2-3 2-3 2-3 2-4 2-4 2-4 2-5 2-5 2-5 2-6 2-6 2-6 2-7 2-7 2-7 2-8 2-8 2-8 Chiller Temp. °F Probe Temp. °F Probe Temp. °F		Angle	(in. H ₂ O)	°F		Angle	(in. H ₂ O)	°F_	 	Angle	(in. H ₂ O)	٥	F
1-3					-				+				
1-4 1-4 1-4 1-4 1-5 1-5 1-5 1-5 1-6 1-6 1-6 1-7 1-7 1-7 1-7 1-8 1-8 1-8 1-8 1-8 2-1 2-1 2-1 2-1 2-2 2-2 2-2 2-2 2-3 2-3 2-3 2-3 2-4 2-4 2-4 2-4 2-5 2-5 2-5 2-5 2-6 2-6 2-6 2-7 2-8 2-8 2-8 2-8 Chiller Temp. °F Probe Temp. °F Probe Temp. °F		ļ				<u> </u>				<u> </u>			
1-5 1-5 1-5 1-6 1-6 1-6 1-6 1-7 1-7 1-7 1-7 1-8 1-8 1-8 1-8 1-8 2-1 2-1 2-1 2-1 2-2 2-2 2-2 2-2 2-3 2-3 2-3 2-3 2-4 2-4 2-4 2-4 2-5 2-5 2-5 2-5 2-6 2-6 2-7 2-7 2-8 2-8 2-8 2-8 Chiller Temp. °F Probe Temp. °F Probe Temp. °F Probe Temp. °F					1-3	<u> </u>			1-3				
1-6 1-6 1-6 1-6 1-7 1-7 1-7 1-7 1-7 1-8 1		<u> </u>										<u> </u>	
1-7 1-8 1					+				1-5				
1-8		ļ	_						1-6				
2-1 2-1 2-1 2-1 2-1 2-1 2-1 2-2 2-2 2-2		ļ	_						1-7				
2-2 2-2 2-3 2-3 2-3 2-3 2-4 2-4 2-4 2-5 2-5 2-5 2-6 2-6 2-7 2-7 2-7 2-7 2-8 2-8 2-8 Chiller Temp. °F Probe Temp. °F Probe Temp. °F Probe Temp. °F	1-8				1-8				1-8				
2-2 2-2 2-3 2-3 2-3 2-3 2-4 2-4 2-4 2-5 2-5 2-5 2-6 2-6 2-7 2-7 2-7 2-7 2-8 2-8 2-8 Chiller Temp. °F Probe Temp. °F Probe Temp. °F Probe Temp. °F					<u> </u>		<u> </u>						
2-3 2-3 2-3 2-4 2-4 2-4 2-5 2-5 2-5 2-6 2-6 2-7 2-7 2-7 2-7 2-8 2-8 2-8 Chiller Temp. °F Chiller Temp. °F Probe Temp. °F Probe Temp. °F		<u> </u>								ļ <u>. </u>			
2-4 2-4 2-4 2-5 2-5 2-5 2-6 2-6 2-6 2-7 2-7 2-7 2-8 2-8 2-8 Chiller Temp. °F Chiller Temp. °F Chiller Temp. °F Probe Temp. °F Probe Temp. °F Probe Temp. °F						<u> </u>			+	<u> </u>		<u> </u>	
2-5 2-5 2-6 2-6 2-6 2-6 2-7 2-7 2-7 2-8 2-8 2-8 Chiller Temp. °F Chiller Temp. °F Chiller Temp. °F Probe Temp. °F Probe Temp. °F Probe Temp. °F						<u> </u>							
2-6 2-6 2-6 2-7 2-7 2-7 2-8 2-8 2-8 Chiller Temp. °F Chiller Temp. °F Chiller Temp. °F Probe Temp. °F Probe Temp. °F Probe Temp. °F		ļ	<u> </u>									<u> </u>	
2-7 2-7 2-7 2-8 2-8 2-8 Chiller Temp. °F Chiller Temp. °F Chiller Temp. °F Probe Temp. °F Probe Temp. °F Probe Temp. °F	-	1							+				
2-8 2-8 2-8 Chiller Temp. °F Chiller Temp. °F Chiller Temp. °F Probe Temp. °F Probe Temp. °F		ļ	ļļ				<u></u>		,	ļ			
Chiller Temp. °F Chiller Temp. °F Chiller Temp. °F Probe Temp. °F Probe Temp. °F Probe Temp. °F		 	ļļ							_		<u> </u>	
Probe Temp. °F Probe Temp. °F Probe Temp. °F	2-8				2-8		 		2-8	ļ			
Probe Temp. °F Probe Temp. °F Probe Temp. °F	Chitte- (T)	<u> </u>			CI-:	T	373		OL III	013			
		-							I	-			
Hagted Line Lamp VV Hagted Line Tome VV Weeted Line Tome VV			<u>or</u>								OE:		



SCAQMD Method 100.1 Temps. Data Sheet

Facility: Unit: Test Date:			Performed By: Leak Check Pre: Pbar:	
Time	Probe Temp.	Heated Line Temp.	Primary Knockout Temp.	Thermo Electrical Chiller Temp
			<u> </u>	
	<u> </u>			
		ļ		
	 	<u> </u>	 	
	 			
	-	-	<u> </u>	
	<u> </u>		 	
<u></u>			-	
				
		_		
			<u></u>	
	<u> </u>			
_				
				i
		_		
	-			
	 			<u> </u>
	1	1	1	





Total/Average

Accurate Environmental services, Inc. EPA Method 19, Stack Gas Flow rate Calculations

Facility: Unit: Start Date Pbar: Steam Pre Steam Tei Fuel Mete	essure: mp.;				Fuel Meter Mar Fuel Meter S/N FGR: Stack Dia.: Port Length: Port Dia.:		Yes() No()
Time	Time/Rev.	Readings per Rev.	Pressure	Temp.	Raw Readings	Corrected Readings	Comments
	(sec.)	(cf)	(psi)	(°F)	(cf)	(ccf)	
						_	
	<u> </u>						
	ļ <u>.</u>						
	<u> </u>		<u> </u>				<u> </u>
	ļ	 					
		ļ			-		<u> </u>
	<u> </u>				-		
							
					 		
	 		ļ <u></u>			-	
	 -	<u> </u>	<u> </u>	 	 		
				1		1	

Analog Instrument/ DPM Calibration

Wor	k Order Number	Proces		Loop Tag Number			
	110017	Boiler #1 Nat	ural Gas Flow	25FFIT031			
,	·	Γest Equipmer	nt Informatio	n'		,	
	Vlanufacturer	Model I	lumber	S	erial Numbe	er	
	FLUKE	718-3	100G		2541131		
Calibratio	on Certificate Number	Calibrati			pration Due		
	120937	12/12			12/12/2015		
	Vlanufacturer	Model	lumber	<u> </u>	erial Numbe	er	
Calibratio	on Certificate Number	Calibrati	on Date	Calib	oration Due	Date	
		L Calibration Ga	s Informatio	n .			
	/lanufacturer	Lot Nu			Gas Type		
_				1			
N	Manufacturer	Lot Nu	mber		Gas Type		
	A PART OF THE STATE OF THE STAT	Instrument	nformation		· * · · * · ·		
	/lanufacturer	Model N	Serial Number				
	FOXBORO	IDP10-A22	*				
- / ,		Instrume	ent Type	,	•	•	
	mitter X ducer	Controller Indicator	x	-	a tor her		
Range	54	Eng Units INCH,	/H20 Input	PRESS.	Output	MA	
	0/ of Dance	Simulated Val	.a. T. Outmite	As Faund	Outmut	As Lafe	
Point 1	% of Range 0%	0.0		As Found . I.0	Output As Left 4.0		
Point 2	25%	3.4		3.0	8.		
Point 3	50%	13.6		2.0 12			
Point 4	75%	30.4		6.0			
Point 5	100%	54.0		0.0	20.		
Comn		oan from 125" to s ved from McCrom	-				
Techr	nician	Carl Herrigsta	d	Date	4/22/	2015	

Analog Instrument/ DPM Calibration

· Process Area

Loop Tag Number

Work Order Number

88016	Cidel Mailinei	Lincess Wied	•	Luc	th tag rantime	•
	110017	Boiler #2 Digester G	ias Flow	25FFIT071		
		Test Equipment Inf	ormatio	n .	•	
- M	lanufacturer	Model Numbe	 er	Serial Number		
	FLUKE	718-100G			2541131	
Calibration	n Certificate Number	Calibration Da	-		ration Due D	ate
	120937	12/12/2014			12/12/2015	
M	lanufacturer	Model Numbe	er	Se	erial Number	
Calibration	n Certificate Number	Calibration Da	te	Calib	ration Due Da	ate
1 1 1 1 2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	* .	 Calibration Gas Inf	ormatio	<u> </u>	<u> </u>	-, ',
n/	lanufacturer	Lot Number	-		Gas Type	
100	ianuiacturei	LOC (VOILIBE)		1	das rype	
M	lanufacturer	Lot Number			Gas Type	
		Instrument Infor	mation	<u> </u>		
	lanufacturer	Model Number	•	<u>' </u>	erial Number	,
	FOXBORO	IDP10-A22B21F-	*			
-, -, -	·	Instrument T		'		
Transo Transo		Controller Indicator	Isolator Other			
Range	0-69.2	Eng Units INCH/H20	Input	PRESS.	Output	MA
	0/ 25 Daine	Communication of Males of Males	Contract	A. F	Outual A	
Point 1	% of Range	Simulated Value 0.0		As Found	Output A:	Leit.
Point 2	25%	4.4		.0	8.0	
Point 3	50%	17.3		2.0	12.0	
Point 4	75%	38.9		5.0	16.0	
Point 5	100%	69.2		0.0	20.0	
Comm		pan from 125" to 69.2" ved from McCrometer.				
Techn	ician	Carl Herrigstad		Date	4/22/20)15

Test Equipment Information Manufacturer Model Number Serial Number FLUKE 718-100G 2541131 On Certificate Number Calibration Date 12/12/2014 12/12/2015 Manufacturer Model Number Serial Number FLUKE 718-100G 2541131 On Certificate Number Calibration Date Calibration Due Date 120937 12/12/2014 12/12/2015 Manufacturer Model Number Serial Number On Certificate Number Calibration Date Calibration Due Date Calibration Gas Information Manufacturer Lot Number Gas Type Manufacturer Lot Number Gas Type Instrument Information Manufacturer Model Number Serial Number FOXBORO IDP10-A22821F-M1 * Instrument Type Serial Number Isolator Serial Number Serial Number FOXBORO IDP10-A22821F-M1 * Instrument Type Serial Number Serial Number Serial Number Serial Number Serial Number Information Instrument Type Serial Number Serial Number Serial Number Serial Number Serial Number Information Informat							
Test Equipment Information Manufacturer FLUKE FLUKE On Certificate Number Calibration Date	Wor	k Order Number	Process Area		. Lo	op Tag Num	ber
Manufacturer Model Number Serial Number FLUKE 718-100G 2541131 on Certificate Number Calibration Date Calibration Due Date 120937 12/12/2014 12/12/2015 Manufacturer Model Number Serial Number on Certificate Number Calibration Date Calibration Due Date Calibration Gas Information Manufacturer Lot Number Gas Type Manufacturer Lot Number Gas Type Instrument Information Manufacturer Model Number Serial Number FOXBORO IDP10-A22821F-M1 * Instrument Type Smitter X Controller Isolator Sducer Indicator X Other S5.4 Eng Units INCH/H20 Input PRESS. Output MA		110017	Boiler #2 Natural G	as Flow		25FFIT081	
FLUKE 718-100G 2541131 on Certificate Number Calibration Date Calibration Due Date 120937 12/12/2014 12/12/2015 Manufacturer Model Number Serial Number on Certificate Number Calibration Date Calibration Due Date Calibration Gas Information Manufacturer Lot Number Gas Type Manufacturer Lot Number Gas Type Instrument Information Manufacturer Model Number Serial Number FOXBORO IDP10-A22821F-M1 * Instrument Type Smitter X Controller Isolator Seducer Indicator X Other	,	- 1	Test Equipment Inf	ormatio	n:		•
Calibration Date 120937 12/12/2014 12/12/2015 Manufacturer Model Number Calibration Date Calibration Due Date Calibration Date Calibration Date Calibration Date Calibration Date Calibration Date Calibration Date Calibration Due Date Calibration Gas Information Manufacturer Lot Number Gas Type Instrument Information Manufacturer Model Number FOXBORO IDP10-A22821F-M1 Instrument Type Calibration Date Calibration Due Date Calibration Due Date Calibration Due Date Calibration Due Date Calibration Date Calibration Due Date Calib	٨	/lanufacturer	Model Numbe	er	S	erial Numbe	r
12/12/2014 12/12/2015		FLUKE	718-100G			2541131	
Manufacturer Model Number Serial Number Calibration Date Calibration Due Date Calibration Gas Information Manufacturer Lot Number Gas Type Manufacturer Lot Number Gas Type Instrument Information Manufacturer Model Number Serial Number FOXBORO IDP10-A22821F-M1 * Instrument Type Indicator X Controller Isolator Serial Number Other Indicator X Other Serial Number Other Instrument Type	Calibratio	on Certificate Number	Calibration Da	te	Calil	ration Due	Date
Calibration Date Calibration Gas Information Manufacturer Lot Number Gas Type Manufacturer Lot Number Gas Type Instrument Information Manufacturer Model Number FOXBORO IDP10-A22821F-M1 Instrument Type Semitter X Controller Indicator X Other Selial Number Isolator Seducer Indicator X Other		120937	12/12/2014			12/12/2015	
Calibration Gas Information Manufacturer Lot Number Gas Type Manufacturer Lot Number Gas Type Instrument Information Manufacturer Model Number Serial Number FOXBORO IDP10-A22821F-M1 * Instrument Type Smitter X Controller Isolator Sducer Indicator X Other 55.4 Eng Units INCH/H20 Input PRESS Output MA	٨	/lanufacturer	Model Numbe	er	S	erial Numbe	r
Calibration Gas Information Manufacturer Lot Number Gas Type Manufacturer Lot Number Gas Type Instrument Information Manufacturer Model Number Serial Number FOXBORO IDP10-A22821F-M1 * Instrument Type Smitter X Controller Isolator Sducer Indicator X Other 55.4 Eng Units INCH/H20 Input PRESS. Output MA				_	- 111		
Manufacturer Lot Number Gas Type Manufacturer Lot Number Gas Type	Calibratio	n Certificate Number	Calibration Da	te	Calik	oration Due	Date
Manufacturer Lot Number Gas Type Instrument Information Manufacturer Model Number Serial Number FOXBORO IDP10-A22821F-M1 * Instrument Type	,		Calibration Gas Inf	ormatio	n	· **; - /*,	
Instrument Information Manufacturer	N	/lanufacturer	Lot Number			Gas Type	
Instrument Information Manufacturer							
Manufacturer Model Number Serial Number FOXBORO IDP10-A22821F-M1 * Instrument Type smitter X Controller Isolator sducer Indicator X Other 55.4 Eng Units INCH/H20 Input PRESS. Output MA	N	/lanufacturer	Lot Number			Gas Type	
Manufacturer Model Number Serial Number FOXBORO IDP10-A22821F-M1 * Instrument Type smitter X Controller Isolator sducer Indicator X Other 55.4 Eng Units INCH/H20 Input PRESS. Output MA	•• •	And Agent Control	Instrument Infor	mation	.,		. ,
Instrument Type Smitter X Controller Isolator Sducer Indicator X Other 55.4 Eng Units INCH/H20 Input PRESS. Output MA				er .	S	erial Numbe	r
smitter X Controller Isolator sducer Indicator X Other 55.4 Eng Units INCH/H20 Input PRESS. Output MA		FOXBORO	IDP10-A22821F-	M1		*	
smitter X Controller Isolator sducer Indicator X Other 55.4 Eng Units INCH/H20 Input PRESS. Output MA			Instrument T	ype		: • •	
55.4 Eng Units INCH/H20 Input PRESS. Output MA		mitter X	-		•	-	
	Trans	ducer	Indicator _	<u> </u>	. Ot	her -	
% of Range Simulated Value Output As Found Output As Left	Range	55.4	Eng Units INCH/H20	Input	PRESS.	Output	MA
% of Range Simulated Value Output As Found Output As Leπ		0/ 50			4 = 1 *		
				-		_	
 			<u> </u>			•	
25% 3.5 8.0 8.0				 			
120							
50% 13.9 12.0 12.0			 				
75% 31.2 16.0 16.0	roint 5	100%	33.4	2(J.U	20.	.U
0% 0.0 4.0 4.0 25% 3.5 8.0 8.0	Trans	55.4 % of Range 0% 25% 50%	Indicator Eng Units INCH/H20 Simulated Value 0.0 3.5 13.9	Output 4	PRESS. As Found .0 .0 .0	Output Output 4. 8.	0
	;						
			 				
75% 31.2 16.0 16.0	Point 5	100%	55.4	20	J.U	20.	.U
	_		f annii		: · ·		_
75% 31.2 16.0 16.0 100% 55.4 20.0 20.0	Comn						<u>/ </u>
75% 31.2 16.0 16.0 100% 55.4 20.0 20.0 ments Changed span from 125" to 55.4" per calibration sheet from primary		V-cone recei	ved from McCrometer.	Calibrated	l transmitte	r.	
75% 31.2 16.0 16.0 100% 55.4 20.0 20.0							
75% 31.2 16.0 16.0 100% 55.4 20.0 20.0 ments Changed span from 125" to 55.4" per calibration sheet from primary							
75% 31.2 16.0 16.0 100% 55.4 20.0 20.0 ments Changed span from 125" to 55.4" per calibration sheet from primary							
75% 31.2 16.0 16.0 100% 55.4 20.0 20.0 ments Changed span from 125" to 55.4" per calibration sheet from primary							.
75% 31.2 16.0 16.0 100% 55.4 20.0 20.0 ments Changed span from 125" to 55.4" per calibration sheet from primary		- •					
75% 31.2 16.0 16.0 100% 55.4 20.0 20.0 ments Changed span from 125" to 55.4" per calibration sheet from primary	Techr	nician	Carl Herrigstad		Date	4/22/	2015
75% 31.2 16.0 16.0 100% 55.4 20.0 20.0 ments Changed span from 125" to 55.4" per calibration sheet from primary V-cone received from McCrometer. Calibrated transmitter.	16011		- Carrielingstau		- Late	7/ 44/	

Wor	k Order Number	P	rocess Are	a ·	Lo	op Tag Nun	ber
	110017	Boiler #1 E	igester Ga	s Totalizer		25FFQ1021	
		Test Equip	ment In	formatio	n		
N	lanufacturer	M	odel Numi	per	5	erial Numb	
TR	RANSMATION	CA	LMATE 11	.43		10656017	
Calibratio	n Certificate Number	Cal	ibration D	ate	Cali	bration Due	Date
	117293		6/10/2014	1		6/10/2015	•
IV.	lanufacturer	M	odel Numb	er	S	Serial Numb	er
					· · ·		
Calibratio	n Certificate Number	Cal	ibration D	ate	Calil	bration Due	Date
, ,		Calibratio	n Gas In	formatio	<u> </u>		
N	lanufacturer		ot Numbe	r		Gas Type	
IV.	lanufacturer	L	ot Numbe	r		Gas Type	
		Instrum	ent Info	rmation	* .		F
N	lanufacturer		odel Numb		S	erial Numb	er
PRE	CISION DIGITAL		PD6200			*	
		Instr	ument 1	Гуре			
Transr Trans		Contr		x		lator :her	
Range	0-350	Eng Units	SCFM	Input	MA	Output	DISPLAY
, ,	% of Range .	Simulate	d Value	Output A	As Found	Qutnut	As Left ,
Point 1	0%	4.0		0.		· ·	.0
Point 2	25%	8.0		17		<u> </u>	5.0
Point 3	50%	12.		24			7.5
Point 4	75%	16.	.0	30	3.0	30	3.0
Point 5	100%	20.	0	350	0.0	350	0.0
Comm	nents Changed sp	oan from 35 Calibi	to 350. Ch		uare root i	input from l	near.
Techn	ician	Carl Heri	rigstad		Date	4/22/	2015

Work	Order Number	P	rocess Are	a l	Lo	op Tag Number
	110017	Boiler #1	Natural Ga	s Totalizer		25FFQI031
		rest Equip	ment In	formatio	n , .	
M	anufacturer		odel Numb			Serial Number
TRA	ANSMATION	CA	LMATE 11	43		10656017
Calibration	Certificate Number	Ca	libration D	ate	Cali	bration Due Date
	117293		6/10/2014			6/10/2015
M	anufacturer	M	odel Numb	er		Serial Number
Calibration	Certificate Number	Cal	libration D	ate	Cali	bration Due Date
	·	Calibratio	n Gas In	formation) ·	
M	anufacturer	<u>l</u>	ot Numbe	r		Gas Type
M	anufacturer		ot Numbe	r		Gas Type
47. 4		Instrum	ent Info	rmation	7,3	
	anufacturer		odel Numb	 -	S	erial Number
_	ISION DIGITAL		PD6200			*
n	······································	Inst	rument 1	vpe		-, ,
Transm Transd		Contr Indic		Х		her
Range	0-201.9	Eng Units	SCFM	Input	MA	Output DISPLAY
	% of Range	Simulate	d Value	Output A	s Found	Output As Left
Point 1	0%	4.	0	0.		0.0
Point 2	25%	8.0	0	100),9	100.9
Point 3	50%	12.	.0	142	2.8	142.8
Point 4	75%	16.	.0	174	1.8	174.8
Point 5	100%	20	.0	201	L.9	201.9
Comm	ents Changed sp		to 201.9. (square roo	t input from linear.
Techni	cian	Carl Her	rigstad		Date	4/22/2015

Worl	c Order Number	 	rocess Are			op Tag Number
	110017	Boiler #2 D	Digester Ga	s Totalizer		25FFQ1071
		Test Equip	ment In	formatio	n _	
IV	lanufacturer	Me	odel Numb	er	S	erial Number
TR	ANSMATION	CA	LMATE 11	43		10656017
Calibratio	n Certificate Number	·}	ibration D		Calil	oration Due Date
	117293		6/10/2014			6/10/2015
<u> </u>	lanufacturer	Me	odel Numb	er	S	erial Number
Calibratio	n Certificate Number	Cal	ibration D	ate	Calil	pration Due Date
, , , ,		Calibratio	n Gas In	formatio	ղ.	
IV	lanufacturer	L	ot Numbe	r		Gas Type
N	lanufacturer	Į L	ot Numbe	<u></u>		Gas Type
,		. Instrum	ent Info	rmation		·
M	lanufacturer	Mo	odel Numb	er	S	erial Number
PREC	CISION DIGITAL		PD6200		_	*
		Instr	ument 1	уре	* , , *	
Transr Transc		Contro Indica		х		ator her
Range	0-350	Eng Units	SCFM	Input	MA	Output DISPLAY
	% of Range	Simulate	d Value	Output A	As Found	Output As Left
Point 1	0%	4.0		0.		0.0
Point 2	25%	8.0		179	5.0	175.0
Point 3	50%	12.	0	24	7.4	247.4
Point 4	75%	16.	0	303	3.1	303.1
Point 5	100%	20.	0	350	0.0	350.0
Comm	ents Changed sp		to 350. Ch		uare root i	nput from linear.
-						
Techn	ician	Carl Herr	rigstad		Date	4/22/2015

		,					
Work	Order Number		rocess Are		Lo	op Tag Nun	
	110017			s Totalizer		25FFQI08:	<u> </u>
	. 1	Test Equip	ment In	formatio	n		
	anufacturer	M	odel Numi	per	S	erial Numb	er
	ANSMATION		LMATE 11			10656017	
Calibration	Certificate Number		libration D		Calil	bration Due	
	117293		6/10/2014			6/10/2015	
M	anufacturer	M	odel Numi	er	S	erial Numb	er
Calibration	Certificate Number	Cal	ibration D	ate	Calil	bration Due	Date
		<u>Calibratio</u>	n Gas ln	formation	1		
M	anufacturer	L	ot Numbe	r		Gas Type	•
M:	anufacturer	1	ot Numbe	r		Gas Type	
		Instrum	ent Info	rmation			
M:	anufacturer	M	odel Numb	er	S	erial Numb	er
PREC	ISION DIGITAL		PD6200			*	
		Insti	rument l	Гуре			
Transm Transd		Contr Indic		x		ator her	
Range	0-201.9	Eng Units	SCFM	Input	MA	Output	DISPLAY
	% of Range	Simulate	d Value .	Output A	s Found	Outnu	t As Left
Point 1	0%	4.1		0.			1.0
Point 2	25%	8.0		101		-	1.0
Point 3	50%	12.		142			2.8
Point 4	75%	16.	.0	174	1.8	17	4.8
Point 5	100%	20.	.0	201	L.9	20	1.9
Comm	ents <u>Changed sp</u>	oan from 20 Calib	to 201.9. rated indic		square roo	t input fron	n linear.
Techni	cian	Carl Her	rigstad		Date	4/22	/2015

Work	c Order Number	Pı	ocess Are	ea .	Lo.	op Tag Numl	ber
	110017	Boiler#	1 Digeste	r Gas I/I		25FFY021	
,		Test Equip	ment in	formatio	n	* * ₂ **	•
M	lanufacturer		del Numi			erial Numbe	·r
TR	ANSMATION	CA	LMATE 11	.43		10656017	
Calibration	n Certificate Number	Cali	bration D	ate	Calil	bration Due	Date
	117293	6	/10/2014	I		6/10/2015	
M	lanufacturer	Mo	del Numi	per	S	erial Numbe	r
	FLUKE		87-V			95840449	
Calibration	n Certificate Number	Cali	bration D	ate	Calil	bration Due I	Date
	123129	3	/25/2015	<u> </u>		3/25/2016	
		Calibration	n Gas In	formatio	1 ·	t	
	lanufacturer	Lo	ot Numbe	r		Gas Type	
M	lanufacturer	Le	ot Numbe	r		Gas Type	
		Instrume					
M	lanufacturer	<u></u>	del Numi		S	erial Numbe	r
	MOORE	ECT/4-20M	A/4-20M	A/12-42DC	· 	* 	
	<u> </u>	Instr	ument]	Гуре			•
Transn	nitter	Contro	iller		Isol	ator	х
Transc		Indica				her _	
Range	4-20	Eng Units	MA	Input	MA	Output	MA
· · · · · · · · · · · · · · · · · · ·	% of Range	Simulated	l Value	Outnut 4	As Found	Output	Δs Left
Point 1	0%	4.0		4.		4.0	
oint 2	25%	8.0		8.		8.0	
oint 3	50%	12.0		12		12.	
Point 4	75%	16.0		16		16.	
oint 5	100%	20.0)	20	.0	20.	0
Comm	ents Calibrated	isolator.					
				-			
Techni	ician	Carl Herr	igstad		Date	4/22/:	2015

Man TRAN Calibration Co Man Falibration Co	ufacturer ISMATION ertificate Number 17293	Boiler # Test Equip Mo	rocess Are 1 Natural ment In		, Lo	op Tag Num	ber
Man TRAN Calibration Co 1: Man F Calibration Co	ufacturer ISMATION ertificate Number 17293	Test Equip		Gas I/I		05550004	
Man TRAN Calibration Co 1: Man F Calibration Co	ufacturer ISMATION ertificate Number 17293	Mo	ment in			25FFY031	
TRAN Calibration Co Man F Calibration Co	ISMATION ertificate Number 17293	+		formation	'n '		,
Calibration Co Man F Calibration Co	ertificate Number 17293	CA	del Numi	er	S	erial Numbe	er
1 Man F Calibration C	17293		LMATE 11	.43		10656017	
Man F Calibration Co		Cali	bration D	ate	Calil	oration Due	Date
F Calibration Co	ufacturer	6	6/10/2014	l		6/10/2015	
Calibration Co		Mo	del Numi	per	S	erial Numbe	₽ Г
	LUKE		87-V			95840449	
1:	ertificate Number	Cali	bration D	ate	Calil	oration Due	Date
	23129	3	3/25/2015	j		3/25/2016	
		Calibration	ı Gas In	formation	1	* * * * * * * * * * * * * * * * * * * *	*
Man	ufacturer	L	ot Numbe	r		Gas Type	
Man	ufacturer	L	ot Numbe	r		Gas Type	
* *		 Instrume	ent Info	rmation	, ,	·	
Man	ufacturer	Mo	del Numb	er	S	erial Numbe	r
M	IOORE	ECT/4-20M	A/4-20M	A/12-42DC		*	
• •	** * *	Instr				,	•
Transmitt Transduc		Contro Indica				ator her	х
		_		Input		-	X
Transduc Range	4-20	Indica	MA	,	Ot MA	her	MA
Transduc Range	er	Indica Eng Units	MA J Value	,	MA s Found	her Output	MA As Left
Transduc Range oint 1	4-20 % of Range	Eng Units Simulated	MA d Value	Output A	MA s Found	Output Output	MA As Left
Range oint 1	4-20 % of Range 0%	Eng Units 'Simulated 4.0	MA Value	Output A	MA AS Found 0	Output Output 4.	MA As Left 0
Transduc	4-20 % of Range 0% 25%	Eng Units Simulated 4.0	MA Value	Output A	MA ss Found 0 0 0 0	Output Output 4.	MA As Left 0 0

. Worl	k Order Number .	Pi	rocess Are	ea	Lo	op Tag Num	ber
	110017	Boiler #	2 Digeste	r Gas I/I		25FFY071	
		Test Equip			n	,	
N	lanufacturer		del Numi			erial Numb	 er
TR	ANSMATION	CA	LMATE 11	.43		10656017	
Calibratio	n Certificate Number	Cal	ibration D	ate	Cali	bration Due	Date
	117293		5/10/2014	1		6/10/2015	
IV	lanufacturer	Mo	del Numi	oer	S	erial Numbo	er
-	FLUKE		87-V			95840449	
Calibratio	n Certificate Number	Cali	bration D	ate	Calil	bration Due	Date
	123129		3/25/2015	5		3/25/2016	
		Calibratio	n Gás In	formation	1		*, *
	lanufacturer	L	ot Numbe	r		Gas Type	
IV	lanufacturer	L	ot Numbe	r		Gas Type	
و ادر		Instrum	ent Info	rmation			* .
N	lanufacturer	Mo	del Numi	per	S	erial Numbe	er
	MOORE	ECT/4-20M	A/4-20M	A/12-42DC		*	
·	·	Instr	ument	Гуре			<u> </u>
T		Cantus	-11		la-d	l=&	v
Transr Transc		. Contro Indica				lator her	X
Transe		. indica	itor		Ot	ner .	
Range	4-20	Eng Units	MA	Input	МА	Output	MA
	% of Range	Simulated	- Value	Output A	le Found	Output	Δs I oft
Point 1	0%	4.0		4.		4.	
Point 2	25%	8.0		8.		8.	
Point 3	50%	12.0		12		12	
Point 4	75%	16.	_	16		16	
Point 5	100%	20.		20		20	

Technician	Carl Herrigstad	Date	4/22/2015

Test Equipmer Manufacturer Mode TRANSMATION Calibration Certificate Number 117293 Manufacturer Mode FLUKE Calibration Certificate Number Lot I Manufacturer Manufacturer Mode PR Instrument Instrument Mode PR Instrument Controlle Indicator Indicator	Loop Tag Number 25FFY081 nent Information lel Number MATE 1143 ration Date 10/2014 1el Number 87-V ration Date 25/2015 Gas Information 1 Number 1 Serial Number 25/2015 3/25/2016 Gas Information 1 Number 1 Serial Number 25/2016 Gas Type 1 Number 2 Gas Type 2 Serial Number 3 Serial Number 4 Serial Number 4 Serial Number 5 Serial Number 6 Serial Number 1 Serial Number
Manufacturer Mode TRANSMATION CALM Calibration Certificate Number Calibra 117293 6/1 Manufacturer Mode FLUKE SCALIBRATION CALIBRATION Calibration Certificate Number Calibration Certific	nent Information lel Number Serial Number MATE 1143 10656017 cration Date Calibration Due Date 10/2014 6/10/2015 lel Number Serial Number 87-V 95840449 cration Date Calibration Due Date 125/2015 3/25/2016 Gas Information t Number Gas Type t Number Gas Type nt Information lel Number Serial Number 4116 * ment Type
Manufacturer Mode TRANSMATION CALM Calibration Certificate Number Calibra 117293 6/1 Manufacturer Mode FLUKE Calibration Certificate Number Calibra 123129 3/2 Calibration Certificate Number Calibra Manufacturer Lot I Manufacturer Lot I Manufacturer Mode PR Instrumen Transmitter Controlle Transducer Indicator	Serial Number Serial Number MATE 1143
TRANSMATION CALM Calibration Certificate Number Calibra 117293 6/1 Manufacturer Mode FLUKE Calibration Certificate Number Calibra 123129 3/2 Calibration Calibration Calibra Manufacturer Lot I Manufacturer Lot I Manufacturer Mode PR Instrumen Transmitter Controlle Transducer Indicator	MATE 1143 ration Date Calibration Due Date (10/2014 6/10/2015 Rel Number 87-V 95840449 ration Date Calibration Due Date (25/2015 3/25/2016 Gas Information Number Gas Type The Information Rel Number Serial Number Serial Number Gas Type The Information Rel Number Serial Number Serial Number 4116 * ment Type
Calibration Certificate Number 6/1 117293 6/1 Manufacturer Mode FLUKE Calibration Certificate Number Calibration	ration Date 10/2014 6/10/2015 lel Number 87-V 95840449 ration Date 25/2015 Gas Information Number Ration Ra
Manufacturer Mode FLUKE Calibration Certificate Number Calibration Certificate Number 123129 3/2 Calibration Certificate Number Calibration Certificate Number Calibration Certificate Number 123129 3/2 Manufacturer Lot Instrumen Manufacturer Mode PR Instrumen Indicator Indica	10/2014
Manufacturer Mode FLUKE Calibration Certificate Number Calibration Celibration	lel Number Serial Number 87-V 95840449 ration Date Calibration Due Date 25/2015 3/25/2016 Gas Information t Number Gas Type t Number Gas Type nt Information lel Number Serial Number 4116 * ment Type
FLUKE Calibration Certificate Number 123129 3/2 Calibration C Manufacturer Lot I Manufacturer Instrumen Manufacturer Mode PR Instrum Transmitter Transducer Indicator	87-V 95840449 ration Date Calibration Due Date 25/2015 3/25/2016 Gas Information t Number Gas Type Number Gas Type nt Information lel Number Serial Number 4116 * Iment Type
Calibration Certificate Number Calibration Certificate Number 3/2 3/2 Calibration Certificate Number Calibration Certificate Calibration Certificate Calibration Certificate Calibration Certificate Certificat	ration Date Calibration Due Date 3/25/2015 Gas Information Number Gas Type Number Gas Type The Information Serial Number 4116 ment Type
Calibration G Manufacturer Lot I Manufacturer Lot I Instrumen Manufacturer Mode PR Instrum Instrumen Controlle Transmitter Controlle Indicator	25/2015 3/25/2016 Gas Information t Number Gas Type Number Gas Type nt Information lel Number Serial Number 4116 * ment Type
Manufacturer Lot I Manufacturer Lot I Instrumen Manufacturer Mode PR Instrum Instrumen Controlle Transmitter Controlle Indicator	Gas Information Number Gas Type Number Gas Type It Number Gas Type Int Information Iel Number Serial Number 4116 * Iment Type
Manufacturer Lot I Manufacturer Lot I Instrumen Manufacturer Mode PR Instrum Instrumen Controlle Transmitter Controlle Indicator	Number Gas Type Number Gas Type It Number Gas Type It Information Itel Number Serial Number 4116 * Iment Type
Manufacturer Lot I Instrumen Manufacturer Mode PR Instrum Instrum Controlle Transducer Indicator	nt Information lel Number Serial Number 4116 * ment Type
Instrumen Manufacturer Mode PR Instrum Instrum Controlle Transmitter Indicator	nt Information lel Number Serial Number 4116 * Iment Type
Instrumen Manufacturer Mode PR Instrum Instrum Controlle Transducer Indicator	nt Information lel Number Serial Number 4116 * Iment Type
Manufacturer Mode PR Instrum Transmitter Controlle Transducer Indicator	lel Number Serial Number 4116 * ment Type
PR Instrum Transmitter Controlle Transducer Indicator	# ment Type
Transmitter Controlle Transducer Indicator	ment Type
Transmitter Controlle Transducer Indicator	
Transmitter Controlle Transducer Indicato	
Range 20-Apr Eng Units	
	MA Input MA Output M
% of Pange Simulated V	Value Quinut As Found Quinut As Le
70 01 1101180	
Point 5 100% 20.0	0.0 20.0
% of Range Simulated V Point 1 0% 4.0 Point 2 25% 8.0 Point 3 50% 12.0 Point 4 75% 16.0	0.0 4.0 0.0 8.0 0.0 12.0

NO₂ Converter Efficiency Test

Client:

NOx Gas Value:

CEMS I.D.:

Cylinder #

By:

NO₂ Gas Value:

 $\mathbf{C_0}$

Date:

Cylinder #

Gas	Analyzer Mode	Analyzer	Cal. Corrected	Label
7) I O			
Zero	NOx			
Zero	NO			
NO	NO			;
NO	NOx		i	
NO ₂	NO			
NO ₂	NOx			

Label

Requirement

 $CE = (C_a C_b)/C_a * 100\%$

- > 90%

RM Calibration Data

Client:		
CEMS I.D.:		

Thermal Oxidizer

Date: By:

	High Span C		al Oxidize	<u> </u>	Mid Spa	n Cylinde	<u> </u>
	Cylinder No.		ntration	Cylind	ler No.	Concentration	
Zero							
02							
CO ₂		-					
NO _x							
co							
Parameter				Analyzer		_	Status
		O ₂	CO ₂	NO _x	CO		
Analyzer R							
Zero Gas C	Concentration						
High Gas (Concentration						
Mid Gas C	oncentration						
Initial Rest	ponse, Zero			,			
Initial Resp	ponse, High		!				
Initial Resp	oonse, Mid						
Final Resp	onse, Zero						
Final Resp	onse, High			i l			
Final Resp	onse, Mid			,			
Initial Erro	or (% of scale), Zero						<2%F.S.
Initial Erro	or (% of scale), High						<2%F.S.
Initial Erro	or (% of scale), Mid						<2%F.S.
Final Erro	r (% of scale), Zero						<2%F.S.
Final Erro	r (% of scale), High						<2%F.S.
Final Error	r (% of scale), Mid			<u> </u>			<2%F.S.
Linearity a	t Mid Point, Pre-test						<1%F.S.
Linearity a	t Mid Point, Post-test						<1%F.S.

Error Calculation:

(Analyzer Response - Actual Span Value)/Range * 100%

Analyzers Semi-Annual Calibration Check


Analyzer S/N:

45099259898

Test Date:

3/14/2015

O ₂ \	/alue:	22.50		
	of Full Scale	Expected Value	Actual Value	% Deviation
	100	22.50	22.53	0.13
	80	18.00	18.02	0.11
	60 `	13.50	13.53	0.22
	40	9.00	9.01	0.11
Pag	20	4.50	4.52	0.44



Page 58 of 78

Analyzers Semi-Annual Calibration Check


Analyzer S/N:

45099259898

Test Date:

3/14/2015

CO2 Value:	8.36		
% of Full Scale	Expected Value	Actual Value	% Deviation
100	8.36	8.35	0.12
80	6.69	6.70	0.18
60	5.02	5.05	0.68
40	3.34	3.33	0.42
20	1.67	1.68	0.48



Page 59 of 78

Analyzers Semi-Annual Calibration Check

Analyzer S/N:

45099259898


Test Date:

3/14/2015

NOx Value:

22,2

% of Full Scale	Expected Value	Actual Value	% Deviation
100	22.20	22.24	0.18
80	17.76	17.80	0.23
60	13,32	13.36	0.30
40	8.88	8.90	0.23
20	4.44	4.48	0.90



Analyzers Semi-Annual Calibration Check


Analyzer S/N:

45099259898

Test Date:

3/14/2015

85	5	
Expected		
Value	Actual Value	% Deviation
85.0	85.01	0.01
68.0	68.14	0.21
51.0	51.20	0.39
34.0	34.15	0.44
17.0	17.06	0.35
	Expected Value 85.0 68.0 51.0 34.0	Value Actual Value 85.0 85.01 68.0 68.14 51.0 51.20 34.0 34.15



Dry Gas Meter Calibration

Dry Gas Meter Coefficient Calculations

Standard Meter Identification (S/N).
Standard Dry Gas Meter Coefficient (Y--);
Dry Gas Meter Identification (I.D.);
Dry Gas Meter Identification (S/N);

1,0033 Apex-4 Date: Calib. by: Barometric Pressure (Pbar): Ambient Temperature (oF): 5/21/15 Walid M 29.93

64

Semiannual Bimonthly Other

х

ny Cas			` '					Temperature			
Арргох,	Total		l	Refere	nce Dry Ga	s Meter	Fic	ld Dry Gas	Meter		
CFM	CF		dH		Moter Read	Time	Temp. Out	Meter Read	Timo	9H@	Yím
Project.			in. H2O	(deg F)	(CF)	(min sec)	63	(CF)	(min:sec)		
		Start	0 27	76	17618	00	80	932.361	0,0		
0 25		End	0 26	76	23,748	22.0	82	938.577	22.0	1.953	0.9977
		Avg/Total	0 27	76	6.130	22 0	81	6,216	22.0		
		Start	0.27	77	23,748	0.0	83	938.577	00		
0,25		End	0.26	78	29 878	22 0	84	944.804	22 0	1.955	0,9977
		Avg/Total	0 27	78	6.130	22 0	84	6,227	22 0		
		Start	0 27	77	29 87B	00	84	944.804	0.0		
0.25	1	En4	0.26	78	36,008	22.0	85	951,042	22.0	1.951	0,9978
_		Avg/Total	0.27	78	6.130	22.0	85	6 238	22.0		
		Start	0.78	83	36.008	0.0	85	951.042	00		
0.5	Ĺ	End	0.78	84	43 283	15.0	86	958 370	15.0	1.940	0.9975
		Avg/Total	0.78	84	7.275	150	86	7.327	15.0		
a		Start	0.78	84	43 283	0.0	87	958,3695	00		
Page 61	1	End	0,78	85	51.528	17.0	88	966,6876	17.0	1.940	0.9977
		Avg/Total	0.78	85	8,245	17.0	88	8,318	17.0	1.7.0	•
of	 	Start	0.78	85	51.528	0.0	89	966 6876	00		
		End	0.78	86	59,773	170	89	975,0142	17.0	1.942	0.9976
≱։	ļ	Avg/Total	0,78	86	8.245	17.0	89	8,327	17.0	1.942	0.997
		 		 							
		Start	188	87	59.773	0.0	90	975.0142	0.0		i
0.75		End	1 88	88	67,333	10.0	91	982,6222	100	1.945	0.997
	\vdash	Avg/Total	1.88	88	7,560	100	91	7 608	10,0		
		Start	1 88	89	67.333	0.0	91	982 6222	0.0	_	
0 75		End	1 88	90	74.913	10.0	92	990.2352	10.0	1.946	0.997
	 -	Avg/Total	1.88	90	7.580	10,0	92	7.613	10.0		
	1	Start	1.88	90	74.913	0.0	92	990.2352	0.0		
0.75		End	1 88	91	82,503	10.0	92	997 8522	100	1.946	0.997
	├	Avg/Total	1.88	91	7.590	10,0	92	7.617	10,0		
	1	Start	3.75	92	82.503	0.0	93	997.8522	0.0		
1.00		End	3,75	93	90,063	7.0	94	1005,3982	7.0	1.944	0,997
		Avg/Total	3.75	93	7.560	7.0	94	7 546	7.0		<u> </u>
		Start	3.75	94	90 063	00	94	1005.3982	0.0		
1.00	1	End	3.75	95	97.643	7.0	95	1012.9498	7,0	1.944	0.997
	<u>L</u>	Avg/Total	3.75	95	7.580	7.0	95	7.552	7.0		<u></u>
	1	Start	3.75	95	97.643	00	95	1012.9498	0.0		
1.00	1	End	3.75	96	105,238	7.0	96	1020,5098	7.0	1.940	0 998
	1	Avg/Total	3.75	96	7.595	70	96	7 56	7.0]	1

Approx.			Reference	Dry Gas	Meter]						
Flow Rate	RUN	Flow Rate	Average Me	ter	Corr. Flow	1. For Non	Temperature C	compensated	Dry Gas Meter:			
Projected	Ю	Qrm	Temp.		Rate Q'rm	Q'ma = Qma [5	20/(460+T)] (Pbar	/29.92)	•			
(cfm)		(cfm)	(oF)		(scfm)	or						
	1	0 2786	76 0		0.2713	Q'fm = Qfm [520/(460+T)] {[Pbar+(dP/13.6)]/29,92}						
0 25	2	0 2786	77 5		0.2705	2. For Temperature Compensated Dry Gas Meter:						
	3	0 2786	77.5		0.2705							
	1	0.4850	83,5	-	0,4657		Q'std = Qds{Pbar	+(dP/13.6)]/29.9:	2)			
0.5	2	2 0 4850 84,5			0.4649	, , , , , , , , , , , , , , , , , , , ,						
	3	0.4850	85,5		0,4640	3. Yds = Q'rm/Q'fm						
		0,7560	87.5		0.7207	207 Criteria * and ** must be satisfied before caculating						
0.75	2	0.7580	89.5		0.7199	Yds and Y ds						
	3	0 7590	90.5		0.7196							
	1	1.0800	92 5		1 0202							
1.00	2	1.0829	94.5		1.0192]						
	3	1,0850	95.5		1.0194	İ						
Approx.		Field Dry Gas Meter										
Flow Rate	RUN	Flow Rate	Average M	eter	Corr. Flow	Coefficient	oufficient (Yds max Average dH@<					
Projected	NO.	Qím	Temp.	ďН	Rate Q'fin	Yfm<	Yds min.) <	Coefficient	(dH@+	0.98 < (Yds/Yds) <		
_(cfm)		(cfm)	(oF)	(in. H2O)	(scfm)	(1+0.05)*	0 010 **	Yds	0.15)	1,02		
	ı	0.2825	81.0	0 27	0 2719	0.9977						
0.25	2	0 2830	83 5	0 27	0,2712	0.9977	0.0001	0.998	1.953	1,000		
	3	0.2835	84.5	0.27	0.2711	0.9978						
	1	0 4885	85 5	0,78	0.4669	0.9975			•			
0.50	2	0 4893	87.5	0.78	0 4659	0 9977	0.0002	0.998	1.940	1.000		
1	3	0.4898	89.0	0.78	0.4651	0 9976				·		
	1	0.7608	90.5	1.88	0.7225	0.9975						
0.75	2	0.7613	91.5	1.88	0.7216	0.9976	0.0002	0.998	1.946	1.000		
	3	0 7617	92 0	1.88	0.7214	0 9975				ļ		
	1	1,0780	93.5	3.75	1.0228	0,9975						
1.00	2	1 0788	94.5	3.75	1 0217	0 9975	0.0010	0.998	1.943	1.000		
	3	1.0800	95.5	3.75	1.0210	0.9984						

Average dH @= 1.95 Yds =0.998

S-Type Pitot Calibration, Wind Tunnel

Date:

5/21/15

Amb. Temperature:

64 degrees F

Pitot ID:

PT-4

Barometric Pressure:

29.93

Calibrated by: Wally M

	SIDE "A" CALIBRATION									
Run	Std. Pitot dP	S-Type dP	Ср	Deviation						
#	(in H ₂ O)	(in H ₂ O)	(S)	Cp(S) - Cp(A)						
1a	0.024	0.034	0.840	-0.001						
1b	0.024	0.034	0.840	-0.001						
1c	0.024	0.034	0.840	-0.001						
2a	0.051	0.072	0.842	0.000						
2b	0.051	0.072	0.842	0.000						
2c	0.051	0.072	0.842	0.000						
3a	0.110	0.155	0.842	0.001						
3b	0.110	0.155	0.842	0.001						
3c	0.110	0.155	0.842	0.001						

Side "A" average, Cp(A) =

0.84

Average deviation, d=

0.001

Is $d \le 0.01$?

Yes

	SIDE "B" CALIBRATION									
Run	Std. Pitot dP	S-Type dP	Ср	Deviation						
#	(in H ₂ O)	(in H ₂ O)	(S)	Cp(S) - Cp(B)						
1a	0.024	0.034	0.840	-0.002						
1b	0.024	0.034	0.840	-0.002						
1c	0.024	0.034	0.840	-0.002						
2a	0.046	0.065	0.844	0.002						
2b	0.046	0.065	0.844	0.002						
2c	0.046	0.065	0.844	0.002						
3a	0.060	0.085	0.840	-0.002						
3b	0.060	0.084	0.845	0.003						
3c	0.060	0.085	0.840	-0.002						

Side "B" average, Cp(B) =

0.84

Average deviation, d=

0.002

Is $d \le 0.01$?

Yes

Actual Calculated Pitot Coefficient (Cp) =

0.84

Difference between "A" and "B", d = |Cp(A) - Cp(B)| =

0.001

Is $d \le 0.01$?

Yes

Note: Triplicate runs at 3 flow rates are required.

Thermocouple Calibration Sheet

Semi Annual

Date: 5/21/2015
I.D. Number: TC-4
Performed by: Wally M

	Hg. in Glass Thermometer, °F				Temp. Sensor °F				Difference	
	0 min	1 min	2 min	avg.	0 min	1 min	2 min	avg.	Absolute Diff	%
Ice	32.1	32.2	32.1	32.1	32.3	32.3	32.3	32.3	0.2	0.52
Ice	32.1	32.2	32.1	32.1	32.3	32.3	32.3	32.3	0.2	0.52
Ice	32.1	32.2	32.1	32.1	32.3	32.3	32.3	32.3	0.2	0.52
Boiling Water	211.3	212.3	212.3	212.0	211.6	212.1	212	211.9	0.1	0.03
Boiling Water	211.3	212.3	212.3	212.0	211.6	212.1	212	212.1	0.1	0.06
Boiling Water	212.3	212.3	212.3	212.3	212.6	212.2	212	212.3	0.0	0.02
Boiling Oil	386	387	387	386.7	386	387	387	386.7	0.0	0.00
Boiling Oil	386	387	387	386.7	386	387	387	386.7	0.0	0.00
Boiling Oil	386	387	387	386.7	386	387	387	386.7	0.0	0.00



Praxair 5700 South Alameda Street Los Angeles, CA 90058

Tel: (323) 585-2154 Fax:(714) 542-6689

PGVPID: F22014

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR WHSE SANTA ANA CA 1545 E EDINGER AVE

SANTA ANA

CA 927050

Praxair Order Number: 28611425

Customer P. O. Number: 05123138

Customer Reference Number:

Fill Date: Pari Number:

9/20/2014 NI CD8.504E-AS

Lot Number:

109426305

Cylinder Style & Ontlet: Cylinder Pressure & Volume:

CGA 590 AS 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date: Cylinder Number:			9/24/2022 CC50182	NIST Traceable Analytical Uncertainty:		
*	8.36	%	CARBON DIOXIDE	± 0.4 %		
	22.5	%	OXYGEN	± 0.3 %		
		Balance	NITROGEN			

Certification Information:

Certification Date: 9/24/2014

Term: 96 Months

Expiration Date: 9/24/2022

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

O2 responses have been corrected for CO2 interference.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON DIOXIDE

Requested Concentration: Certified Concentration: 8 36 %

Instrument Used: Honba VIA-510 S/N 2807014

Analytical Method: NDIR Last Multipoint Calibration: 9/3/2014

Firs	t Analys	la Dat	a:			Date:	9/24/2014	
Z:	0	R:	9.87	C:	8.36	Conc:	8 363	
R:	9 86	Z:	0	C:	8.36	Conce	8.353	
Z:	986 0	C:	0 8.36	R:	9 87	Conc:	8.383	
UOM				Mea	o Test	Agsav:	8 363 %	

2. Component: OXYGEN

Requested Concentration: 225% Certified Concentration: 225% Instrument Used:

Analytical Method: Last Multipoint Calibration:

OXYMAT 5E PARAMAGNETIC 9/19/2014

First Analysis Data: 9/24/2014 Û R; 20.9 22.531 Z: C: 22,52 Conc: 20.9 22,52 22.531 Z: 0 C; 22.52 R; 20.9 Conc: 22,531 % 22.531 % UOM: Mean Test Assay:

Analyzed by:

Reference Standard Type: GMIS SA17695 Ref. Std. Cylinder # : Ref. Std. Conc. 9 87% Ref Std. Traceable to SRM #: 16745 SRM Sample #

SRM Cylinder # ; FF10631

Seco	nd Ana	dysia D	ata;			Date:	· · · · · · · · · · · · · · · · · · ·
Z:	0	R:	C	C:	٥	Conc;	0
Z: R:	0	Z;	0	C;	O	Conc:	0
Z:	D	C:	Q	R:	0	Conc:	a
UOM	: %			Mean	n Test	Assay:	0 %

Reference Standard Type: GMIS Ref. Std. Cylinder#: SA18070 Ref. Std. Conc: 20.91 % Ref. Std. Traceable to SRM # : 2659a SRM Sample #; 71-E-19

SRM Cylinder # :

Second Analysis Data: Date: R: 0 C: a Conc: Conc: 0 G: 0 R: 0 Conc: цом: % Mean Test Assay: 0 %

FF22331

Certified by:



information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical dehods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information con tained herein exceed the fee established for providing such information.



Praxair 5700 South Alameda Street Los Angeles, CA 90058 Tel: (323) 585-2154 Fax:(714) 542-6689 PGVPID: F22014

CERTIFICATE OF ANALYSIS/EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR WHSE SANTA ANA CA

1545 E EDINGER AVE

SANTA ANA

CA 927050

Praxair Order Number: 29103057 Customer P. O. Number: 05197636

Customer Reference Number:

Fill Date: Part Number:

11/3/2014 EV NICDOXE78-AS

Lot Number: Cylinder Style & Outlet: AS

109430702 CGA 590

Cylinder Pressure & Volume: 2000 psig 140 cu.ft.

Certified Concentration:

Expiration Date Cylinder Number		11/10/2022 CC333865	NIST Traceable Analytical Uncertainty:
5.01	%	CARBON DIOXIDE	± 0.6 %
10.01	% Balance	OXYGEN NITROGEN	± 0.4 %

Certification Information:

Certification Date: 11/10/2014

Term: 96 Months

Expiration Date: 11/10/2022

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

O2 responses have been corrected for CO2 interference.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARSON DIOXIDE

Requested Concentration: Certified Concentration: 5.01 %

testrument Used:

Horiba VIA-510 S/N 2807014 Analytical Method:

Last Multipoint Calibration:

	Date:	11/10/2
10/31/2014		
NDIR		

First	t Analys	s Dat	a;			Date:	11/10/2014
Z:	0	R:	9.87	C:	5.01	Conc:	5.013
R:	0 9.86	Z:	0	C:	5 0 1	Conc:	5.013
Z:	0	C:	5.01	R:	9.86	Conc;	5.013
uon	A: %			Hea	n Test	Assay:	5.013 %

2. Component: OXYGEN

Requested Concentration: Certified Concentration: Instrument Used: Analytical Method: Last Multipoint Calibration:

10.01 % OXYMAT SE PARAMAGNETIC 10/17/2014

l	First /	Inalysi	s Dat	2:		-	Date:	11/10/2014
Ì	Z:	0	R:	5	C:	10.01	Conc	10.01
ļ	R:	5	Z:	٥	C;	10.01	Conc	10.01
ı	Z:	0	C:	10.01	R:	5	Cone:	10,01
Į	UOM:	%			Mea	n Test /	lssay:	10.01 %

Analyzed by:

Reference Standard Type: Ref. Std. Cylinder #: GMIS SA17695 Ref. Std. Conc. 9.87% Ref. Std. Tracsable to SRM # : 16745 SRM Sample #: 7-H-07 SRM Cylinder #: FF10631

Seco	nd Ana	dysia D	ala:			Date:	
Z:	0	R:	0	C:	ā	Conc:	0
R:	0	Z:	0	C:	0	Conc:	0
Z:	0	C:	0	R:	0	Conc:	0
HON	: %			Mean	Test	Assay:	0%

Reference Standard Type: **GMIS** Ref. Std. Cylinder #: CC240877 Ref. Std. Conc: 5,00% Ref. Std. Traceable to SRM#: 2658a SRM Sample # : 72-D-28 SRM Cylinder # : CAL016862

Seco	nd Ana	iyais Q	ata:			Date:	
Z:	0	R:	0	C:	0	Conc:	a
R:	O	Z:	0	C:	0	Conet	0
Z:	0	C:	0	R:	0	Conc:	0
UOM	: %			Mear	Test	Assay:	0%

Certified by:





Praxair 5700 South Alameda Street Los Angeles, CA 90058 Tel: (323) 585-2154 Fax:(714) 542-6689

PGVPID: F22014

CERTIFICATE OF ANALYSIS/EPA PROTOCOL

Customer & Order Information:

PRAXAIR WHSE SANTA ANA CA 1545 E EDINGER AVE

SANTA ANA

CA 927050

Proxair Order Number: 27364804

Customer P. O. Number: 04935077

Customer Reference Number:

Fill Date: Part Number:

3/17/2012 NI NOS SME-AS

Lot Number: Cylinder Style & Ontlet:

109207704 AS

Cylinder Pressure & Volume:

CGA 660 1000 psig 70 cu ft.

Certified Concentration:

Expiration Date: Cylinder Number:

5/20/2017 CC169749

NIST Traceable Analytical Uncertainty:

ppm

NITRIC OXIDE

± 1.1 %

Balance NITROGEN

NO× = 8,20

NOx for Reference Only

Certification Information:

Certification Date: 5/20/2014

Term: 36 Months

Expiration Date: 5/20/2017

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: NITRIC OXIDE

Requested Concentration: Certified Concentration: Instrument Used:

8.5 ppm 6.16 ppm

Therivo Electron 42i-LS S/N 1030645077

Analytical Method: Last Multinoint Calibr

Chemiluminescence 4/21/2014

Reference Standard Type: GMIS Ref. Std. Cylinder # . CC335945 10,07 ppm Ref. Std. Conc. Ref. Std. Traceable to SRM #: 2629a SRM Sample #:

SRM Cylinder#:

50-G-109 FF31631

Fire	t Analysi	is Dat	2;			Date:	5/20/2014
Z:	0	R:	10.07	C:	8,16	Conc:	8.16
R:	10.07	Z:	0	C:	8.16	Conc:	8,16
Z:	0	C:	8.17	R:	10.07	Conc:	8.17
UOI	å: por	0		Mes	n Test /	LEBBY:	8.163 ppm

Analyzed by:

Second Analysis Data: Date: 0 R: 0 C: 0 Conc: 0 R; a Z: ٥ C: n Conce Ω 0 0 Z: ٥ C: R: Conc 0 UOM: ррт Mean Test Assay: 0 ррт

Certified by



Praxair 5700 South Alameda Street

Los Angeles, CA 90058 Tel: (323) 585-2154 Fax:(714) 542-6689

PGVPID: F22014

CERTIFICATE OF ANALYSIS/EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR WHSE SANTA ANA CA 1545 E EDINGER AVE

SANTA ANA

CA 927050

Praxair Order Number: 26792886

Customer P. O. Number: 04850910

Customer Reference Number:

Fill Date:

Cylinder Pressure & Volume:

12/29/2011 Part Number: NI NO4ME-AS

Lot Number: Cylinder Style & Outlet: AS

109136306

CGA 660 1000 psig 70 cu. ft.

Certified Concentration:

Expiration Date):	3/31/2017	NIST Traceable
Cylinder Number:		CC331147	Analytical Uncertainty:
3.98	ppm	NITRIC OXIDE	± 1.2 %
Balance		NITROGEN	

NOx ≈ 4.02 ppm

NOx for Reference Only

Certification Information:

Certification Date: 3/31/2014

Term: 36 Months

Expiration Date: 3/31/2017

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

Last certified concentration was 3.98 ppm Nitric Oxide on 01/23/2012

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: NITRIC OXIDE

Requested Concentration: Certified Concentration:

3.98 ppm

Instrument Used: Analytical Method Themo Electron 42i-LS S/N 1030645077

Chemiluminescence

	mostopou i			-	L 112017		
Fire	t Analys	s Dat	a :			Date:	3/31/2014
Z:	٥	R:	10,07	C:	3,98	Conc:	3.98
R:	10 07	Z:	a	C:	3.97	Conc:	3.97
Z:	a	C;	3.98	R:	10 07	Conc;	3.98
1101	it non			Mas	o Toet A		3 977 mm

Analyzed by(

Reference Standard Type GMIS Ref. Std. Cytinder #; CC335945 10.07 ppm Ref. Std. Conc. Ref. Std. Traceable to SRM#: 2629a

SRM Sample #: 50-G-109 SRM Cylinder #: FF31631

Second Analysis Data: Date: Z: 0 R: 0 C: Conc: R: ۵ Z: 0 C: a Conc: a 2: 0 C: R: ٥ Conc: UOM: ρрπ Mean Test Assay: Оррга

Certified by:



Praxeir 5700 South Alameda Street Los Angeles, CA 90058 Tel: (323) 585-2154 Fax: (714) 542-6689

PGVPID: F22014

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR WHSE SANTA ANA CA

1545 E EDINGER AVE

SANTA ANA

CA 927050

Praxair Order Number: 28667509

Customer P. O. Number: 05132093

Customer Reference Number:

Fill Date:

9/18/2014 NI NO22ME-AS

Part Number: Los Number:

109426103

A\$

Cylinder Style & Outlet: Cylinder Pressure & Volume:

2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date: Cylinder Number: 10/1/2017 CC204933

NIST Traceable Analytical Uncertainty:

NITRIC OXIDE 21.9 ppm Balance NITROGEN

NOx = 22.0 ppm

NOx for Reference Only

GMIS CC363337

Certifcation Information:

Certification Date: 10/1/2014

Term: 36 Months

Expiration Date: 10/1/2017

±1%

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

Z: 0

R:

Z; 0

UOM: ppm (R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: NITRIC OXIDE

19.9

Requested Concentration: **Certified Concentration:**

21 9 ppm

Mean Test Assay:

Instrument Used:

Analytical Method: Last Multipoint Calibration: 22 ppm

Themo Electron 42I-LS S/N 1030645077 Chemituminescence

First Analysis Data:

R: 19.9

Z: 0

9/16/2014 Date: 9/24/2014 C: 219 Conc: 21.9 C: 219 21.9 Conc: R: 19,9 21,9 Conc:

Analyzed by:

adeles

21.9 ppm

Reference Standard Type: Ref. Std. Cylinder # : Ref. Std. Conc.

19,9 ppm Ref. Std. Traceable to SRM #: 2629a SRM Sample #: 50-G-109 SRM Cylinder #: FF31631

10/1/2014 Second Analysis Data: Date: 21,9 Conca 21.9 R: 19.9 19.9 Z: O C: 21.8 21.8 R: Conc: Z: 0 21 9 R: 19.9 Conc: 21.9 UOM: ppm Mean Test Assay: 21,867 ppm

Certified by:



Praxair 5700 South Alameda Street Los Angeles, CA 90058 Tel: (323) 585-2154 Fax:(714) 542-6689

PGVPID: F22014

CERTIFICATE OF ANALYSIS/EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR WHSE SANTA ANA CA

1545 E EDINGER AVE

SANTA ANA

CA 927050

Praxair Order Number: 26621241

Customer P. O. Number: 04824911

Customer Reference Number:

Fill Date: Part Number:

3/27/2014 AI NX16ME-AS

Lot Number: Cylinder Style & Outlet: AS

109408605

Cylinder Pressure & Volume:

CGA 660 2000 psig 140 cu, ft.

Certified Concentration:

Expiration Date:	4/7/2017	NIST Traceable		
Cylinder Number:	CC2188	Analytical Uncertainty		
16.1 ppm Balance	NITROGEN DIOXIDE (as NOx)	± 1.8 %		

NO = 0.1 ppm

NO for Reference Only

Certification Information:

Certification Date: 4/7/2014

Term: 36 Months

Expiration Date: 4/7/2017

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: NITROGEN DIOXIDE (as NOx)

Requested Concentration: 16 ppm Certified Concentration

16.1 ppm Instrument Used: Thermo Env. 42:-HL Analytical Method: Chamiliuminescence

Last Multipoint Calibration:

3/21/2014

First Analysis Date: Date: 3/31/2014 Z: 0 R: 947 C: 15.88 Conc: 18,132 Z: 0 C: 15.98 94.6 Conc: 16.213 R: R: 948 Conc: 16.172 Z: 0 UOM: Mean Test Assay: 16.172 ppm рρπ

Analyzed by:

Reference Standard Type: GMIS CC163565 Ref. Std. Cylinder#: Ref. Std. Conc: 96.2 ppm Ref. Std. Traceable to SRM#:

2660a SRM Sample #: 2660-C-45 SRM Cylinder # : CAL016162

Second Analysis Data: 4/7/2014 Z: 0 R: 94.6 C: 15 84 Conc: 16.097 Z: 0 R: 94.8 C: 15.86 16.117 Conc: a C; 15.83 94.6 Z: R± 16,086 Conc: UOM: 16.1 ppm ppm

Certified

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information con tained herein exceed the (see established for providing such information.



Praxair

5700 South Alameda Street Los Angeles, CA 90058

Tel: (323) 585-2154 Fax:(714) 542-6689

PGVPID: F22014

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR WHSE SANTA ANA CA 1545 E EDINGER AVE

SANTA ANA

927050

Praxair Order Number: 28425785

Customer P. O. Number: 05094198

Customer Reference Number:

FIII Date: Part Number:

9/11/2014 NI CO42.5ME-AS

Lot Number:

109425403 AS

Cylinder Style & Ontlet: Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

CGA 350

Certified Concentration:

Expiration Date: Cylinder Number:	9/15/2022 CC15365	NIST Traceable Analytical Uncertainty:
•	pm CARBON MONOXIDE ance NITROGEN	± 0.4 %

Certification Information:

Certification Date: 9/15/2014

Term: 96 Months

Expiration Date: 9/15/2022

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON MONOXIDE

Requested Concentration: 42 5 ppm

Certified Concentration: 42.1 ppm

Instrument Used:


Honba VIA-510, S/N 577172043

Analytical Method: Last Multipoint Calibration:

NDIR 8/20/2014

First	Analys	is Dat	a:			Date:	9/15/2014	
Z:	0	R:	49.9	C:	42	Conc:	42.056	
R:	50	Z:	0	C:	421	Conc:	42.156	
Z:	Q	C:	42.1	R:	49.9	Conc:	42,156	
מחוו	l: no	m		Mea	n Test	Вавли:	42 123 ppm	

Analyzed by:



Reference Standard Type. GMIS Ref. Std. Cylinder #: CC243411 Ref. Std. Conc. 50.0 ppm 1678c Ref. Std. Traceable to SRM #:

SRM Sample #: 04-L-41 SRM Cylinder #; FF18402

	Seco							
į	Z: R: Z:	0	R:	0	C:	0	Conc:	0
	R:	0	Z: C:	0	C:	0	Conc:	0
	Z:	0	C:	0	R:	0	Conc: -	0
	UOM:				Mear	ı Test	Assay:	0 ррт

Certified by:



CA 927050

Pravair

5700 South Alameda Street Los Angeles, CA 90058 Tel: (323) 585-2154 Fax:(714) 542-6689

PGVPID: F22014

CERTIFICATE OF ANALYSIS/EPA PROTOCO

Customer & Order Information:

PRAXAIR WHSE SANTA ANA CA

1545 E EDINGER AVE

SANTA ANA

Praxair Order Number: 26525703

Customer P. O. Number: 04811777

Customer Reference Number:

Fill Date: Part Number:

3/5/2014 NI CO22ME-AS Lot Number: 109405708

Cylinder Style & Outlet: AS Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

CGA 350

Certified Concentration:

NIST Traceable Analytical Uncertainty:		
Analytical Uncertainty.		
± 0.7 %		

Certification Information: Certification Date: 3/10/2014

Term: 96 Months

Expiration Date: 3/10/2022

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON MONOXIDE

Requested Concentration: Certified Concentration:

22.4 ppm Honba VIA-510, S/N 577172043 Instrument Used: Analytical Method:

Last Multipoint Calibration:

NOIR 2/20/2014

First Analysis Data: 3/10/2014 Date: 0 R: 24.7 C: 22.4 22.461 Conc: 24 6 22,3 Conc 22.38 C; Z: 0 C: 22.3 R: 24.6 22,36 HOM: ppm Mean Test Assay: 22.394 ppm

Analyzed by:

Reference Standard Type: Ref. Std. Cylinder #: CC147286 Ref. Std. Conc. 24.7 ppm Ref. Std. Traceable to SRM #: 2635a SRM Sample ≇: 58-C-32 SRM Cylinder#: CAL011907

Second Analysis Date: Date:								
Z:	0	R:	0	C:	0	Conc	0	
R:	0	Z;	0	C:	0	Conc:	a	
Z:	0	C:	0	R:	0	Conc:	0	
UOM:	: PP	m		Mear	Test	Assay:	0 ppm	

Jacquelyné Figra

GMIS

Certified by:

information contained herein has been prepared at your request by qualified experts within Praxelr Distribution, Inc. While we believe that the information is accurate within the limits of the analytical in nethods employed and is complete to the extent of the specific analyses performed, we make no warrantly or representation as to the suitability of the use of the information for any purpose. The information the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxeir Distribution, Inc., arising out of the use of the information con tained herein exceed the fee established for providing such information.



Section H Page 15 Facility I.D. #: 029110 Revision #: 05

Date: October 17, 2013

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 545004 Granted as of 10/17/2013

Equipment Description:

MODIFICATION TO BOILER, NO. 1 WITH PERMIT TO OPERATE D94235, BY THE REMOVAL OF THE EXISTING BURNER AND THE ADDITION OF A NEW BURNER, AMERICAN COMBUSTION TECHNOLOGY OR EQUAL, MODEL SLE-05-250 OR EQUAL, 10,205,800 BTU PER HOUR MAXIMUM, DIGESTER GAS AND NATURAL GAS (AS SECONDARY FUEL), AND REHABILITATION OF ANCILLARY EQUIPMENT.

Conditions:

- I. CONSTRUCTION AND OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.

 [RULE 204]
- THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES. [RULE 204]
- 3. THIS BOILER SHALL BE FIRED ON DIGESTER GAS AND OR NATURAL GAS ONLY. EXCEPT FOR PILOT GAS, NATURAL GAS SHALL ONLY BE USED IF DIGESTER GAS IS NOT AVAILABLE IN SUFFICIENT AMOUNT.

 [RULE 204]
- 4. A FUEL METER SHALL BE INSTALLED AND MAINTAINED IN THE FUEL SUPPLY LINE(S) TO MEASURE, INDICATE AND RECORD THE AMOUNT OF FUEL(S) (SCFM) BURNED IN THIS EQUIPMENT.

 [RULE 1146, RULE 1303 (b) (2) OFFSET]
- 5. WHEN IN OPERATION, TOTAL HEAT INPUT FOR THIS EQUIPMENT SHALL NOT EXCEED 10, 205, 800 BTU/HR. A DAILY LOG SHALL BE KEPT FOR FUEL USAGE, AND INDICATING FOR DIGESTER GAS THE TOTAL HEATING VALUE (BTU/SCF) OF FUEL BURNED IN THIS EQUIPMENT BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING. [RULE 1303 (b) (2) OFFSET]
- 6. THIS EQUIPMENT SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE THE COMBUSTION AIR AND FUEL RATE AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED PERIODICALLY, ACCORDING TO THE MANUFACTURER'S SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME BURNER FIRING RATE.

 [RULE 204]
- 7. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.

 [RULE 204]



Section H Page 16 Facility I.D. #: 029110 Revision #: 05

Date: October 17, 2013

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 8. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT AN INITIAL PERFORMANCE SOURCE TESTS, UNLESS OTHERWISE APPROVED, UNDER THE FOLLOWING CONDITIONS:
 - A. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THIS TEST.
 - B. A SOURCE TEST PROTOCOL SHALL BE SUBMITTED TO AQMD WITHIN 30 DAYS OF INITIAL START UP AND SHALL BE APPROVED BY AQMD BEFORE THE TEST COMMENCES. THE PROTOCOL SHALL INCLUDE PROPOSED OPERATING CONDITIONS OF THE EQUIPMENT DURING THE TEST, AND A DESCRIPTION OF ALL SAMPLING AND ANALYTICAL PROCEDURES TO BE USED.
 - C. SOURCE TESTING SHALL BE CONDUCTED WITHIN 60 CALENDAR DAYS AFTER NORMAL OPERATION OF THE EQUIPMENT HAS BEEN ESTABLISHED, BUT NO LATER THAN 180 DAYS AFTER INITIAL START UP.
 - D. THE INITIAL PERFORMANCE SOURCE TESTS SHALL BE PERFORMED WHEN THE BOILER IS OPERATING AT MAXIMUM, MINIMUM AND AVERAGE LOAD FOR EACH FUEL (DIGESTER GAS AND NATURAL GAS) TO BE BURNED. THE SAMPLING TIME AT EACH LOAD SHALL BE FOR A MINIMUM OF 15 CONSECUTIVE MINUTES.
 - E. TWO COPIES OF THE SOURCE TEST RESULTS SHALL BE SUBMITTED WITHIN 60 DAYS OF THE TESTS COMPLETION. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO, THE FOLLOWING:

FUEL FLOW RATE (EACH FUEL)

FLUE GAS FLOW RATE (EACH FUEL)

TOTAL HEAT INPUT RATE, BTU/HR (EACH FUEL)

TOTAL NON-METHANE ORGANICS (EXHAUST) (DIGESTER GAS)

TOTAL PARTICULATES (PM10) (EXHAUST) (DIGESTER GAS)

OXIDES OF NITROGEN (EXHAUST) (EACH FUEL)

CARBON MONOXIDE (EXHAUST) (EACH FUEL)

OXYGEN (EACH FUEL)

DIGESTER GAS BTU (HHV) AND TOTAL SULFUR CONTENT (AS H2S, PPMV)

THE REPORT SHALL PRESENT THE EMISSIONS DATA IN PARTS PER MILLION (PPMV) ON A DRY BASIS, POUNDS PER HOUR, AND LBS/MMBTU. [RULE 217, RULE 404, RULE 1146, RULE 1303(A) (1), 1303 (B) (1), 1303(B) (2) - BACT, MODELING AND OFFSET, 1401]

9. THE SOURCE TEST PROTOCOL AND REPORT, PER CONDITION NO. 8, SHALL BE SUBMITTED TO, SCAQMD – ATTN. GAURANG RAWAL ENERGY/ PUBLIC SERVICES/WASTE MGMT. / TERMINALS - PERMITTING ENGINEERING AND COMPLIANCE DIVISION 21865 COPLEY DRIVE DIAMOND BAR, CA 91765

EMISSIONS RESULTING FROM THIS EQUIPMENT SHALL NOT EXCEED THE FOLLOWING:

POLLUTANT	POUNDS PER DAY
CO	90.6
NOx	5.52 (3.1 WITH NATURAL GAS)
PM10	3.1



Section H Page 17 Facility LD. #: 029110 Revision #: 05

Date: October 17, 2013

Normal 7

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

ROG SOx 2.6

1.4

[RULE 1146, RULE 1303(a) (1) - BACT, 1303(b) (2) - OFFSET]

Periodic Monitoring:

THE OPERATOR, AT LEAST ONCE EVERY FIVE YEARS, SHALL DETERMINE COMPLIANCE WITH THE EMISSION LIMITS IN CONDITION NO. 10 OF THIS PERMIT USING AQMD-APPROVED TEST METHODS. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS. RULE 1146 COMPLIANCE TESTS MAY BE USED TO SATISFY PART OF THIS REQUIREMENT PROVIDED THAT MASS RATES ARE ALSO REPORTED. TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATIONS LIMITS. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

[RULE 1146, RULE 1303(a) (1) - BACT, 1303(b) (2) - OFFSET, RULE 3004 (a)(4)- PERIODIC MONITORING]

Emissions And Requirements:

12. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407

CO: 400 PPMV, @ 3% O2, DRY BASIS, RULE 1146

NOx: 30 PPMV, @ 3% O2, DRY BASIS, RULE 1146 (UNTIL 1/1/2015)

NOx: 15 PPMV, @ 3% O2, DRY BASIS, ON AND AFTER JANUARY 1, 2015, DIGESTER GAS,

RULE 1146

NOx: 9 PPMV, @ 3% O2, DRY BASIS, ON AND AFTER JANUARY 1, 2015, NATURAL GAS-RULE

1146

PM: RULE 404, SEE APPENDIX B.

PM: 0.1 gr/scf, RULE 409

SO2: 500 PPMV AS SO2, ORANGE COUNTY, RULE 53

40 PPMV TOTAL SULFUR, DIGESTER GAS

Page 75 of 78



Section H Page 18 Facility I.D. #: 029110 Revision #: 05

Date: October 17, 2013

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 545005 Granted as of 10/17/2013

Equipment Description:

MODIFICATION TO BOILER, NO. 2 WITH PERMIT TO OPERATE D94232, BY THE REMOVAL OF THE EXISTING BURNER AND THE ADDITION OF A NEW BURNER, AMERICAN COMBUSTION TECHNOLOGY OR EQUAL, MODEL SLE-05-250 OR EQUAL, 10,205,800 BTU PER HOUR MAXIMUM, DIGESTER GAS AND NATURAL GAS (AS SECONDARY FUEL), AND REHABILITATION OF ANCILLARY EQUIPMENT.

Conditions:

- CONSTRUCTION AND OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW. [RULE 204]
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.

 [RULE 204]
- 3. THIS BOILER SHALL BE FIRED ON DIGESTER GAS AND OR NATURAL GAS ONLY. EXCEPT FOR PILOT GAS, NATURAL GAS SHALL ONLY BE USED IF DIGESTER GAS IS NOT AVAILABLE IN SUFFICIENT AMOUNT.
 [RULE 204]
- 4. A FUEL METER SHALL BE INSTALLED AND MAINTAINED IN THE FUEL SUPPLY LINE(S) TO MEASURE, INDICATE AND RECORD THE AMOUNT OF FUEL(S) (SCFM) BURNED IN THIS EQUIPMENT.

 [RULE 1146, RULE 1303 (b) (2) OFFSET]
- 5. WHEN IN OPERATION, TOTAL HEAT INPUT FOR THIS EQUIPMENT SHALL NOT EXCEED 10, 205, 800 BTU/HR. A DAILY LOG SHALL BE KEPT FOR FUEL USAGE, AND INDICATING FOR DIGESTER GAS THE TOTAL HEATING VALUE (BTU/SCF) OF FUEL BURNED IN THIS EQUIPMENT BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING. [RULE 1303 (b) (2) OFFSET]
- 6. THIS EQUIPMENT SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE THE COMBUSTION AIR AND FUEL RATE AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED PERIODICALLY, ACCORDING TO THE MANUFACTURER'S SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME BURNER FIRING RATE.

 [RULE 204]
- 7. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.
 [RULE 204]



Section H Page 19 Facility I.D. #: 029110 Revision #: 05

Date: October 17, 2013

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- 8. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT AN INITIAL PERFORMANCE SOURCE TESTS, UNLESS OTHERWISE APPROVED, UNDER THE FOLLOWING CONDITIONS:
 - A. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THIS TEST.
 - B. A SOURCE TEST PROTOCOL SHALL BE SUBMITTED TO AQMD WITHIN 30 DAYS OF INITIAL START UP AND SHALL BE APPROVED BY AQMD BEFORE THE TEST COMMENCES. THE PROTOCOL SHALL INCLUDE PROPOSED OPERATING CONDITIONS OF THE EQUIPMENT DURING THE TEST, AND A DESCRIPTION OF ALL SAMPLING AND ANALYTICAL PROCEDURES TO BE USED.
 - C. SOURCE TESTING SHALL BE CONDUCTED WITHIN 60 CALENDAR DAYS AFTER NORMAL OPERATION OF THE EQUIPMENT HAS BEEN ESTABLISHED, BUT NO LATER THAN 180 DAYS AFTER INITIAL START UP.
 - D. THE INITIAL PERFORMANCE SOURCE TESTS SHALL BE PERFORMED WHEN THE BOILER IS OPERATING AT MAXIMUM, MINIMUM AND AVERAGE LOAD FOR EACH FUEL (DIGESTER GAS AND NATURAL GAS) TO BE BURNED. THE SAMPLING TIME AT EACH LOAD SHALL BE FOR A MINIMUM OF 15 CONSECUTIVE MINUTES.
 - E. TWO COPIES OF THE SOURCE TEST RESULTS SHALL BE SUBMITTED WITHIN 60 DAYS OF THE TESTS COMPLETION. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO, THE FOLLOWING:

FUEL FLOW RATE (EACH FUEL)
FLUE GAS FLOW RATE (EACH FUEL)
TOTAL HEAT INPUT RATE, BTU/HR (EACH FUEL)
TOTAL NON-METHANE ORGANICS (EXHAUST) (DIGESTER GAS)
TOTAL PARTICULATES (PM10) (EXHAUST) (DIGESTER GAS)
OXIDES OF NITROGEN (EXHAUST) (EACH FUEL)
CARBON MONOXIDE (EXHAUST) (EACH FUEL)
OXYGEN (EACH FUEL)
DIGESTER GAS BTU (HHV) AND TOTAL SULFUR CONTENT (AS H2S, PPMV)

THE REPORT SHALL PRESENT THE EMISSIONS DATA IN PARTS PER MILLION (PPMV) ON A DRY BASIS, POUNDS PER HOUR, AND LBS/MMBTU. [RULE 217, RULE 404, RULE 1146, RULE 1303(A) (1), 1303 (B) (1), 1303(B) (2) - BACT, MODELING AND OFFSET, 1401]

9. THE SOURCE TEST PROTOCOL AND REPORT, PER CONDITION NO. 8, SHALL BE SUBMITTED TO, SCAQMD – ATTN. GAURANG RAWAL

ENERGY/ PUBLIC SERVICES/WASTE MGMT. / TERMINALS - PERMITTING

ENGINEERING AND COMPLIANCE DIVISION

21865 COPLEY DRIVE

DIAMOND BAR, CA 91765

EMISSIONS RESULTING FROM THIS EQUIPMENT SHALL NOT EXCEED THE FOLLOWING:

<u>POLLUTANT</u>	<u>POUNDS PER DAY</u>				
	•				
CO	90.6				
NOx	5.52 (3.1 WITH NATURAL GAS)				



Section H Page 20 Facility I.D. #: 029110 Revision #: 05

Date: October 17, 2013

FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PM10 3.1 ROG 2.6 SOx 1.4

[RULE 1146, RULE 1303(a) (1) - BACT, 1303(b) (2) - OFFSET]

Periodic Monitoring:

THE OPERATOR, AT LEAST ONCE EVERY FIVE YEARS, SHALL DETERMINE COMPLIANCE WITH THE EMISSION LIMITS IN CONDITION NO. 10 OF THIS PERMIT USING AQMD-APPROVED TEST METHODS. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS. RULE 1146 COMPLIANCE TESTS MAY BE USED TO SATISFY PART OF THIS REQUIREMENT PROVIDED THAT MASS RATES ARE ALSO REPORTED. TO DEMONSTRATE COMPLIANCE WITH RULE 1146 CONCENTRATIONS LIMITS. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.

[RULE 1146, RULE 1303(a) (1) - BACT, 1303(b) (2) - OFFSET, RULE 3004 (a)(4)- PERIODIC MONITORING]

Emissions And Requirements:

12. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407

CO: 400 PPMV, @ 3% O2, DRY BASIS, RULE 1146 NOx: 30 PPMV, @ 3% O2, DRY BASIS, RULE 1146

NOx: 15 PPMV, @ 3% O2, DRY BASIS, ON AND AFTER JANUARY 1, 2015, DIGESTER GAS,

RULE 1146

NOx: 9 PPMV, @ 3% O2, DRY BASIS, ON AND AFTER JANUARY 1, 2015, NATURAL GAS-RULE

1146

PM: RULE 404, SEE APPENDIX B.

PM: 0.1 gr/scf, RULE 409

SO2: 500 PPMV AS SO2, ORANGE COUNTY, RULE 53 H2s: 40 PPMV TOTAL SULFUR, DIGESTER GAS

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

MEMORANDUM

DATE:	August 26, 2015	S/T ID: P15 308
TO:	Rudy Eden, Manager-Monitoring & Source Testing	STA RECEIVED
FROM:	Andrew Lee, Manager-Energy/Public Services/ Waste Mgmt/Terminals-Permitting	Assigned: Assigned To: AUG 28 2015
SUBJECT:	Review Request (Included are FORMS ST-1 & ST-21)	Completed:
DOCUMEN'	Γ ATTACHED FOR EVALUATION:	
☐ CEMS	☐ Test Protocol ☐ Other:	
Test Repo	rt: (Test Protocol already approved – memo attached Test Prot	tocol NOT approved by M&STE)
	Additional Documentation (Required as of Marc	:h 2002):
disclosure unles secret". If such	Public Records Act, part or all of the above document attached for s the company claims that the information contained within is "pro a statement was included when this document was submitted to you it ment was not included:	prietary", "confidential", or a "trade
Document co	ontaining a "Statement of Confidentiality" or similar statement, is include	ded with this request for evaluation.
	ent of Confidentiality" or similar document was included when this d	ocument was submitted to me by the
SIGNED:	Gaung Ranal TITLE:	AO Engineer II
	v v	
	document id submitted for your evaluation. We would a ovide comments or approval by the indicated date. Thank you	
REQUESTE	D RESPONSE DATE: September 30, 2015	PRIORITY EVALUATION (explain under "COMMENTS" below)
COMPANY	NAME: OCSD, Reclamation Plant No. 2	FAC.ID: 29110
EQUIP. ADI	DRESS: 22212 Brookhurst St., Huntington Beach, CA 92	<u>.646</u>
BASIC EQU	IP: Boiler, Clever Brooks, American combustion Tec	ch, Model SLE-05-250, DG
fired, NG as s	tand by fuel, 10.2 MM Btu/hr.	
EQUIP IDE	NT: <u>A/N 545004 OR 545005</u> RECLAIM USE ONLY: (NOx: \[MAJ \[LGE \[PRC \]	(□DevID⊠A/N□P/N) SOx: □MAJ□LGE)
-	S ² : Testing Company: Accurate Environmental Service t Date: July 20, 2015 Date Received: August 24, 2105 e Test (Initial or Annual): Initial source test	
This S/T prot	ocol (ID TP 03322 OCSD, attached) is for performance and	compliance determination for
criteria pollut	ants' emissions concentrations and rates; as applicable.	
PROCESSIN	IG ENGINEER: Gaurang Rawal	EXT. <u>2543</u>

¹ Forms ST-1 and ST-2 must be completed and attached to this request, or your submittal will be returned. ² Explain reason for Priority Review, time constraints, Hearing Board action, clarify testing requirements, etc.

, a rorrer to

CHECKLIST FOR REQUEST TO REVIEW: SOURCE TEST PROTOCOL, REPORT, OR SPECIAL PROJECT

This Checklist (FORM ST-1) must accompany any request to evaluate a source test protocol, report, or special project. It may be completed by the requesting AQMD Engineer or Inspector, or a representative of the Source Testing Firm/Laboratory/Contractor. Verify, by checking each item below, that all the requested information has been provided with the attached source test protocol, report, or special project. (An incomplete submittal will be returned, and will ultimately delay the evaluation process):

	All Source Test Protocols and Reports Must Include:
\boxtimes	Completed Review Request Memorandum. (A request for a "Priority Review" involves Hearing Board, Abatement Order, or similar critical action, and must be authorized by a manager).
\boxtimes	Information Request FORM ST-2 with those applicable parts filled out completely.
\boxtimes	Reason for test, including proposed operating test loads, reference to applicable rules/permit conditions, and key facility, test firm and AQMD personnel.
\boxtimes	Complete Permit to Construct or Permit to Operate, including all conditions.
\boxtimes	Brief process description, including maximum and normal operating temperatures, pressures, through-put, etc.
\boxtimes	Brief description of sampling and analytical methods for each constituent to be measured. If a standard District, EPA, or ARB method "without any deviation" will be used, reference it by method number.
	TBD- Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts/stacks at the sampling locations, along with upstream and downstream distances to flow disturbances, (e.g. elbows, tees, fans) from the sampling locations.
\boxtimes	Calibration and quality assurance (QA) procedures identified.
\boxtimes	Statement that source test firm/laboratory qualifies as an "independent testing laboratory" under Rule 304 (no conflict of interest), and is approved by AQMD or ARB, if required.
\boxtimes	Attached test firm AQMD-LAP or CARB approval, if required.
	All Source Test Reports Must Also Include:
	Field raw data sheets and laboratory data forms, where applicable.
	Gas monitoring stripcharts and/or DAS printouts, legible and properly annotated, where applicable.
	Complete calculations for volumetric flowrates and emissions rates, where applicable.
	Complete QA supporting documentation (sampling equipment, cal gases, lab analyses, custodies).
	(<u>CEMS & Fuel Meters</u>): Full identification/documentation for CEMS components and fuel meters (analyzer/fuel meter make, model, s/n, range, calibrations, etc.).
	(<u>RECLAIM/Large Source</u>): "Certificate of No Exceptions for testing RECLAIM Large Sources" completed and signed.
	Applicable Source Specific Protocols / Reports Must Also Include:
	(VOC Efficiency): VOC overall efficiency (capture/collection plus control efficiencies), or transfer
	efficiency describes all sample collection points, verifies total collection, and shows all calculations and documentation, according to specified requirements.
	(Organics Loading): Organic (VOC) liquid loading testing describes all sample collection/monitoring
	points (both liquid and vapor), verifies representative start/stop time, and shows all calculations and documentation, according to specified requirements.
	(Particulates/sulfur): Particulate testing of effluent gas streams with high amounts of sulfur compounds addresses additional test preparation, equipment, calculations, and documentation.

INFORMATION REQUEST FOR PROTOCOL, REPORT, OR SPECIAL PROJECT REVIEW

This Information Request (FORM ST-2) must accompany any request to evaluate a source test protocol, report, or special project, and it can only be completed by the requesting AQMD Engineer or Inspector. Please mark the appropriate items and provide the requested information. The sampling and analytical methods will be reviewed only for those constituents identified on this form, so be sure to provide as much information as possible.

Constituent(s) to be measured		Allowable Limit		Rule or Permit	Sampling Location(s)	Other Requirements
	ppm as CI	ration (specify H₄, @ 3% O₂, etc.)	Mass Emission (specify lb/hr, etc.)	Condition(s)	(SCR inlet, outlet, exhaust, etc.)	(test parameters, BACT, Rule Development, etc.)
⊠ co	Confirm ppmv, @ 3% O2.	☑ Compliance Only☑ Mass Emissionsor Factors	90.6 lbs/day (DG)	Cond. 10 & 12	Exhaust	
□ CO ₂		☐ Compliance Only ☐ Mass Emissions or Factors				
\boxtimes O ₂		☐ Compliance Only ☐ Mass Emissions or Factors			Exhaust	
NOx, as NO₂	Confirm ppmv, @ 3% O2	☐ Compliance Only ☐ Mass Emissions or Factors	5.52 lbs/day (DG), 3.1 lbs/day (NG)	Cond. 10 & 12	Exhaust	
SOx, as SO ₂		☐ Compliance Only ☐ Mass Emissions or Factors	1.4 lbs/dáy	Cond. 10	Exhaust	
☐ SO ₃		☐ Compliance Only ☐ Mass Emissions or Factors				
☐ H ₂ S		☐ Compliance Only ☐ Mass Emissions or Factors			_	
☐ Total Reduced Sulfur, as H2S	Confirm reported results	☐ Compliance Only ☐ Mass Emissions or Factors		Rule 431.1, Cond 12	Inlet	
□ NH₃ Slip		Compliance Only Mass Emissions				
Aldehydes		☐ Compliance Only ☐ Mass Emissions or Factors				

^{1.} Concentration must include correction to standard point-of-reference (NOx @ 3%O₂, ROG as CH₄, etc.). If there is no "Mass Emission" compliance limit specified, please specify if concentration will be used only for compliance determination or whether it will <u>also</u> be calculated to a mass emission or factor (this will affect how we interpret the reported concentrations).

INFORMATION REQUEST FOR SOURCE TEST PROTOCOL, REPORT, OR SPECIAL PROJECT REVIEW

			·			<u> </u>
Constituent(s) to be measured		Allowable Limit(s) ^{1.}			Sampling Location(s)	Other Requirements
to be measured	Concentration (specify		Mass Emission	Permit Condition(s)	(SCR inlet, outlet,	(test parameters, BACT,
		H ₄ , @ 3% O ₂ , etc.)	(specify lb/hr,		exhaust, etc.)	Rule Development, etc.)
	<u> </u>	<u> </u>	etc.) 2.6 lbs/day	Cond. 10	Exhaust	
⊠ TGNMO		☐ Compliance Only ☐ Mass Emissions	(DG)	Cond. 10	Extiausi	
		or Factors				
☐ TGNMO,						
Efficiency		^ ,				
(check all that apply):						
☐Capture/Collect						
☐Control/Destruct☐Overall						
Speciated	PPMV	☐ Compliance Only ☐ Mass Emissions			Exhaust	
Organics	(DG)	or Factors				
(specify):				,		
PM (total)	gr/scf	☐ Compliance Only Mass Emissions		Cond. 12		
		or Factors			•	
Mag 1		Compliance Only		HHV,	Inlet	
DG Fuel		☐ Mass Emissions or Factors]	Cond. 8		
		Compliance Only	3.1 lbs/day	Cond. 10	Exhaust	· ·
\square PM=PM ₁₀		Mass Emissions				-
		or Factors				
☐ Toxics		☐ Compliance Only ☐ Mass Emissions				
(specify):		or Factors				
		<u> </u>			·	

FORM ST-2: 545004 or 05, OCSD, Plant 2, Boiler ST Protocol

Concentration must include correction to standard point-of-reference (NOx @ 3%O₂, ROG as CH₄, etc.). If there is no "Mass Emission" compliance limit specified, please specify if concentration will be used only for compliance determination or whether it will also be calculated to a mass emission or factor (this will affect how we interpret the reported concentrations).



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

MONITORING ANALYSIS DIVISION * MONITORING ENGINEERING BRANCH

PERFORMANCE TEST PLAN EVALUATION WORKSHEET

SOURCE TEST ID #: P

15308

FACILITY ID #:

29110

COMPANY: Orange County Sanitation District

COMPANY CONTACT: Vlad Kogan

MAILING ADDRESS: 10844 Ellis Ave. ATTN: Randa Abushaban

MAILING CITY / ZIP: Fountain Valley, CA 92708-7018

BASIC EQUIPMENT: Boiler, 10.2 MMBtu/Hr, Model SLE-05-250

PROTOCOL DATE:

7/20/2015

TEST DATE:

EQUIPMENT ADDRESS: 22212 BROOKHURST ST

EQUIPMENT CITY: HUNTINGTON BEACH

PERFORMANCE TEST EVALUATION

TRXN TYPE	TYPE OF EVALUATION		NO. OF HOURS	SUBTOTAL
36	MINIMUM FEE			\$348.82
	PROTOCOL		7.00	
	BASIC WORK HOURS		5	
	ADDITIONAL CHARGE IN EXCESS OF THE BASIC HOURS	*(See below)	2.00	\$265.44

TOTAL:

\$614.26

AUTHORIZED FOR BILLING

^{*} A minimum fee of \$348.82 will be charged for the evaluation of source test protocols and reports. Additional fees for time spent in the evaluation in excess of 5 hours will be assessed at the hourly rate of \$132.72 per hour.

Dunavent, Andrew/SDO

From: Lisa Ramos < lramos1@aqmd.gov>
Sent: Wednesday, April 06, 2016 10:32 AM

To: Dunavent, Andrew/SDO
Cc: OB PR Support NA Docs

Subject: Public Records Request #84579,

Attachments: STE - Source Test Protocol & Report - 3/25/2016 - TestID: 14076- R - Fac ID: 94967 -

Name: MESA WATER DISTRICT - Notes:.pdf; STE - Form 131 Public Request Evaluations - 3/25/2016 - 84579 - - - ANDREW DUNAVENT.doc; - PR - PR Supporting Docs - 4/6/2016 - 84579 - - - COMPLETION LETTER - ANDREW DUNAVENT.pdf; - PR - PR

Review Docs - 7/24/2009 - 84579 - - 499283 APPLICATON - - - ANDREW

DUNAVENT.pdf

Andrew Dunavent

I have attached the available requested information for this request.

Lisa Ramos South Coast A.QM.D Public Records Unit 909.396.3211

Information Management Public Records Unit

Direct Dial (909) 396-3700 Fax:(909) 396-3330

COMPLETION LETTER

April 06, 2016

ANDREW DUNAVENT CH2M HILL 402W. BROADWAY # SUITE 1450 SAN DIEGO, CA 92101

Ref.: CONTROL NO. 84579

Received 1/21/2016

Re: APPL'S, P/O'S & S/T RPTS FOR MESA WATER DISTRICT, FAC ID #94967, AT 3596 CADILLAC AVENUE, COSTA MESA, CA 92626, APPL #499283.

After a thorough search of this agency's records, the following records were found: APPL'S, P/O'S & ST RPTS FOR MESA WATER DISTRICT, FAC ID #94967, AT 3596 CADILLAC AVENUE, COSTA MESA, CA 92626, APPL #499283.

YOUR REQUESTED RECORDS WERE PROVIDED ELECTRONICALLY ON 04/06/2016

If you have any questions, please do not hesitate to contact me, Tuesday through Friday, 8:00 a.m. to 4:30 p.m.

Sincerely,

LISA RAMOS x3211 For Colleen Paine Public Records Coordinator

Restrictions Concerning the Release and Interpretation of Source Testing Emission Information (Please Read Carefully)

The South Coast Air Quality Management District • Source Test Engineering Branch

Request		
Concerns:	Mesa Water District	84579
		(AQMD Control No.)

The SCAQMD Source Test Engineering (STE) Branch has provided the following source testing reports pursuant to your Public Records Request. STE is obligated under AQMD's Guidelines for Implementing the California Public Records Request, to remove information which is regarded as proprietary, confidential, or information which contains trade secrets. Also, "data used to calculate emission data" must be removed, prior to dissemination. This includes, but is not limited to:

- 1. Intermediate stack information (stack dimensions, velocity/flowrate, temperature, gaseous composition other than reported contaminant emissions, etc.).
- 2. Intermediate emission information (emissions/losses to control devices, raw emission data, laboratory analyses, etc.).
- 3. Process information (process/product throughput, fuel usage, firing rates and burner/control adjustments unless rule/permit conditions specify emissions to be formatted according to this information, photos or drawings of process, etc.).
- 4. Quality Assurance concerning the above information (calibrations, corrections, etc.).

Most source test reports received by STE are formally evaluated for accuracy and other factors pertinent to the accuracy of reported emissions. The attached source test reports have been rated as follows:

Source Test I.D.	Document Su	bject/Date	Accuracy Rating*
R 14076	☐ Protocol ☐ Report ☐ other:	☐ Test Date ☐ Document Date September 20, 2013	(I) (A) (CA) (U) (NR)

*STE's Accuracy Rating Explanations:

In-House (I) – Source testing and report were conducted "in-house" by AQMD Source Testing staff and reported emission information is considered accurate.

ACCEPTABLE (A) – Source test document was conducted/submitted by independent source testing firm, has been evaluated by STE staff, and reported emission information is considered accurate and well documented.

CONDITIONALLY ACCEPTABLE (CA) – Source test document was conducted/submitted by independent source testing firm, has been evaluated by STE staff, and reported emission information may have limited use. For further details, contact STE at (909) 396-2265.

UNACCEPTABLE (U) – Source test document was conducted/submitted by independent source testing firm, has been evaluated by STE staff, and emission information is <u>not</u> considered accurate. <u>Unacceptable source test reports will not be provided unless the requestor requests their release after being notified of their Accuracy Rating. For further details, contact STE at (909) 396-2265.</u>

Not RATED (NR) – Source test report has <u>not</u> been formally evaluated or status is unknown. STE assumes no responsibility for the accuracy of the reported emission information.

131PUBLIC_Records Request Evaluation.doc (Revised 11/08/12)

R14076

AIR GAS TESTING & CONSULTING SERVICES

AIR POLLUTION ENGINEERING, TESTING, PERMITTING, RISK ASSESSMENT, EMISSIONS REPORT

SOURCE TEST REPORT

MESA CONSOLIDATED WATER DISTRICT RULE 1110.2 TESTING FOR NOx, CO & VOC

WELL #5 ENGINE
SCAQMD FACILITY ID: 94967
3596 CADILLAC AVENUE, COSTA MESA, CA 92628

PREPARED FOR:

MESA CONSOLIDATED WATER DISTRICT 1965 PLACENTIA AVENUE COSTA MESA, CALIFORNIA 92627

PREPARED BY:

AIR GAS TESTING & CONSULTING SERVICES 7111 GARDEN GROVE BLVD., SUITE 118 GARDEN GROVE, CALIFORNIA 92841

> TIMOTHY T. DINH ENGINEERNING MANAGER

STA RECEIVED

FEB 25 2014

M&STE BRANCH

REPORT NO. 92013RP TEST DATE: AUGUST 26, 2013 REPORT DATE: SEPTEMBER 20, 2013

TABLE 1.2

SUMMARY OF SOURCE TEST RESULTS – ENGINE WELL #5

Test Date: August 26, 2013 Client: Mesa Consolidated Water District

POLLUTANTS	NORMAL LOAD
Oxides of Nitrogen (NOx)	,
PPM at 15% O₂:	6.85
Compliance Limit (ppm @15% O ₂):	11
Pass/Fail Status: Compliance with Permit to Operate Conditions:	Passed 7 & 9
Compliance with remit to operate conditions.	7 0.0
Carbon Monoxide (CO)	
PPM at 15% O₂:	56.8 ^{56.78}
Compliance Limit (ppm @15% O ₂):	70
Pass/Fail Status:	Passed 7 & 9
Compliance with Permit to Operate Conditions:	7 & 9
Volatile Organic Compounds (VOC)	/
PPM at 15% O₂:	3.07
Compliance Limit (ppm @15% O ₂):	30
Pass/Fail Status:	Passed
Compliance with Permit to Operate Conditions:	7 & 9

Note: Refer to Section 3.0 for Detailed Test Results

Dunavent, Andrew/SDO

From: Lisa Ramos < lramos1@aqmd.gov>
Sent: Wednesday, April 06, 2016 10:40 AM

To: Dunavent, Andrew/SDO
Cc: OB PR Support NA Docs

Subject: FW: Public Records Request #85112,

Attachments: STE - Source Test Protocol & Report - 3/25/2016 - TestID: 08026- R - Fac ID: 95212 -

Name: FABRICA - Notes:.pdf; STE - Source Test Protocol & Report - 3/25/2016 - TestID: 08025- R - Fac ID: 95212 - Name: FABRICA - Notes:.pdf; STE - Form 131 Public

Request Evaluations - 3/25/2016 - 84580 - - - ANDREW DUNAVENT.doc

This is for PRR 85112.

Lisa Ramos South Coast A.QM.D Public Records Unit 909.396.3211

From: Lisa Ramos

Sent: Wednesday, April 6, 2016 10:39 AM

To: 'Andrew.Dunavent@ch2m.com' <Andrew.Dunavent@ch2m.com> **Cc:** OB PR Support NA Docs <ob_pr_support_na_docs@aqmd.gov>

Subject: Public Records Request #85113,

Andrew Dunavent

I have attached some of the documents for this request. I am still waiting for any additional documents.

Lisa Ramos South Coast A.Q.M.D Public Records Unit 909.396.3211

Dunavent, Andrew/SDO

From: Lisa Ramos < lramos1@aqmd.gov>
Sent: Tuesday, April 19, 2016 7:18 AM

To: Dunavent, Andrew/SDO
Cc: OB PR Support NA Docs

Subject: Public Records Request #85112,

Attachments: - PR - PR Supporting Docs - 4/19/2016 - 85112 - - - COMPLETION LETTER - ANDREW

DUNAVENT.pdf; - PR - PR Review Docs - 4/19/2016 - 85112 - - - ANS 581335-337.PDF

- - ANDREW DUNAVENT.pdf

Andrew Dunavent

I have attached the available requested information for this request.

Lisa Ramos South Coast A.QM.D Public Records Unit 909.396.3211

Information Management Public Records Unit

Direct Dial (909) 396-3700 Fax:(909) 396-3330

COMPLETION LETTER

April 19, 2016

ANDREW DUNAVENT CH2M HILL 402W. BROADWAY # SUITE 1450 SAN DIEGO, CA 92101

Ref.: CONTROL NO. 85112

Received 3/1/2016

Re: APPL'S, P/O'S & S/T RPTS FOR LA CITY, DWP HAYNES GENERATING STATION, FAC ID #800074, APPL #'S 581335, 581336 & 581337.

After a thorough search of this agency's records, the following records were found: APPL'S (STILL UNDER REVIEW) FOR LA CITY, DWP HAYNES GENERATING STATION, FAC ID #800074, APPL #'S 581335, 581336 & 581337.

The following records were not found:

P/O'S & S/T RPTS FOR LA CITY, DWP HAYNES GENERATING STATION, FAC ID #800074, APPL #'S 581335, 581336 & 581337.

YOUR REQUESTED RECORDS WERE PROVIDED ELECTRONICALLY ON 04/19/2016

If you have any questions, please do not hesitate to contact me, Tuesday through Friday, 8:00 a.m. to 4:30 p.m.

Sincerely,

LISA RAMOS x3211
For Colleen Paine
Public Records Coordinator



South Coast Air Quality Management District

Form 400-A

Application Form for Permit or Plan Approval List only one piece of equipment or process per form.



Mail To: SCAQMD P.O. Box 4944 Diamond Bar, CA 91765-0944

Tel: (909) 396-3385

		www.aqmd.go	
Section A - Operator Information			
Facility Name (Business Name of Operator to Appear on the Permit):		2. Valid AQMD Facility ID (Available On	
LA City DWP, Haynes Generating Station		Permit Or Invaice Issued By AQMD):	
3. Owner's Business Name (If different from Business Name of Operator):		800074	
Section B • Equipment Location Address	Section C - Permit Mailing Address		
4. Equipment Location is: Fixed Location C Various Location		1:	
(For equipment operated at various locations, provide address of initial site.)	Check here if same as equipment local	ation address	
6801 East 2nd Street	111 N. Hope Street, Room 1050		
Street Address	Address	0.4 00040	
Long Beach , CA 90803 Zip	Los Angeles City	, CA 90012 State Zip	
Edward Kim Env. Coordinator	Dat M. Quach	Air Quality Manager	
Contact Name Title	Contact Name	Title	
(310) 522-7512 Phone # Ext. Fax #	(213) 367-4697 Ext.	(213) 367-4710 Fax #	
E-Mail: edward.kim@ladwp.com	E-Mail: dat.quach@ladwp.com	I GA T	
	E-mail: data-gadon (endata-proofin		
Section D - Application Type 6. The Facility Is: Not In RECLAIM or Title V In RECLAIM	In Title V • In RECLAIM 8	& Title V Programs	
	III TILLE V - III RECEAMIN	s title v Plograms	
7. Reason for Submitting Application (Select only ONE):	Drange with an Existing President Section 1	en os Dosmit.	
	Process with an Existing/Previous Application	an or Permit:	
New Construction (Permit to Construct) Administrative	•	Existing or Previous	
Equipment On-Site But Not Constructed or Operational Alteration/Mod		Permit/Application	
· · · · · · ·	dification without Prior Approval	If you checked any of the items in	
Compliance Plan © Change of Co	1 - 1	7c., you MUST provide an existing	
	ondition without Prior Approval *	Permit or Application Number:	
Streamlined Standard Permit Change of Lo			
70. rgenty remus:	cation without Prior Approval * perating with an Expired/Inactive Permit *		
Title V Application or Amendment (Refer to Title V Matrix)	peraung with an expireumacave remit		
TREAD BY LOUIS LOUIS AND L	ocessing Fee and additional Annual Operating Fees (up		
Ba. Estimated Start Date of Construction (mm/dd/yyyy): 8b. Estimated End Date of	Construction (mm/dd/yyyy): 8c. Estimated	Start Date of Operation (mm/dd/yyyy):	
9. Description of Equipment or Reason for Compliance Plan (list applicable rule):	10. For Identical equipment, how many ad	lditional	
Permit application for minor permit modification and change in	applications are being submitted with	this application?	
condition. T5 Revision	(Form 400-A required for each equipmen	t / process)	
11. Are you a Small Business as per AQMD's Rule 102 definition?	12. Has a Notice of Violation (NOV) or a		
(10 employees or less and total gross receipts are \$500,000 or less <u>OR</u> a not-for-profit training center) • No • Yes	Comply (NC) been issued for this eq If Yes, provide N	erpriser.	
Section E - Facility Business Information			
13. What type of business is being conducted at this equipment location?	14. What is your business primary NAICS	Code?	
Electric Generation	(North American Industrial Classification	System) 221112	
15. Are there other facilities in the SCAQMD jurisdiction operated by the same operator? No Section 15.	16. Are there any schools (K-12) within 1000 feet of the facility property line?	€ No C Yes	
	ontained herein and information submitted with th	is application are true and correct.	
17. Signature of Responsible Official: 18. Title of Respons	ible Official: 19. I wish to review	the permit prior to issuance.	
Dir. of Power	r Supply and Op. (This may cause	a delay in the	
20. Print Name: 21. Date: /	/ application proc	,635.)	
Kenneth A, Silver	2016 data? (If Yes, s		
23. Check List: Authorized Signature/Date Form 400-CEQA	Supplemental Form(s) (ie., Form 4		
AOMO APPLICATION TRACKING # CHECK # AMOUNT RECEIVED	PAYMENT TRACKING #	VALIDATION A	
USE ONLY 5 1/335 700100834 25,592	16	1/19/160	
DATE APP DATE APP CLASS BASIC ' EQUIPMENT CATEGOR REJ REJ I III CONTROL	Y CODE TEAM ENGINEER REASON/ACTION	IAKEN (

@ South Coast Air Quality Management District, Form 400-A (2014.07)

cm 126073



South Coast Air Quality Management District

Form 500-C1

Title V Compliance Status Report

To provide the compliance status of your facility with applicable federally enforceable requirements and identify other local-only requirements, complete this form and attach it to a completed compliance certification Form 500-A2. As appropriate, all submittals of Form 500-C2 as appropriate should also be attached to this form.

Mail To: SCAQMD P.O. Box 4944 Diamond Bar. CA 91765-0944

> Tel: (909) 396-3385 www.aqmd.gov

Section I - Operator Information

1. Facility Name (Business Name of Operator That Appears On Permit):

LA City DWP, Haynes Generating Station

Valid AQMD Facility ID (Available On Permit Or Invoice Issued By AQMD):

 800074

PROCEDURES FOR DETERMINING COMPLIANCE STATUS

- Equipment verification: Review the list of pending applications, and either the preliminary Title V facility permit or the list of current permits to operate that the AQMD provided you, to
 determine if they completely and accurately describe all equipment operating at the facility. Attach a statement to describe any discrepancies.
- Identify applicable requirements*: Use the checklist in Section II to identify all applicable and federally-enforceable local, state, and federal rules and regulations, test methods, and monitoring, recordkeeping and reporting (MRR) requirements that apply to any equipment or process (including equipment exempt from a permit by Rule 219) at your facility.
 The potential applicable requirements, test methods and MRR requirements are identified and listed adjacent to each given equipment/process description. Check off each box adjacent to the corresponding requirement as it applies to your particular equipment/process.
 Note: Even if there is only one piece of equipment that is subject to a particular requirement, the appropriate box should be checked.
- 3. Identify additional applicable requirements*: Use Section III to identify any additional requirements not found in Section II. Section II is not a complete list of all applicable requirements. It does not include recently adopted NESHAP regulations by EPA or recent amendments to AQMD rules. Do not add rules listed in Section V here.
- 4. Identify any requirements that do not apply to a specific piece of equipment or process: Also use Section III to identify any requirements that are listed in Section II but that do not apply to a specific piece of equipment or process. Fill out Section III of this form and attach a separate sheet to explain the reason(s) why the identified rules do not apply. Note: Listing any requirement that does not apply to a specific piece of equipment will not provide the facility with a permit shield unless one is specifically requested by completing Form 500-D and is approved by AQMD.
- 5. Identify SIP-approved rules that are not current AQMD rules: Use Section IV to identify older versions of current AQMD rules that are the EPA-approved versions in the State Implementation Plan (SIP), and that are still applicable requirements as defined by EPA. The facility is <u>not</u> required to certify compliance with the items checked in Section IV provided that the non-SIP approved rule in Section II is at least as stringent as the older SIP-approved version in Section IV. **
- 6. Identify Local-Only Enforceable Regulatory Requirements: Use Section V to identify AQMD rules that are not SIP-approved and are not federally enforceable.
- 7. Determine compliance: Determine if all equipment and processes are complying with all requirements identified in Sections II and III. If each piece of equipment complies with all applicable requirements, complete and attach Form 500-A2 to certify the compliance status of the facility. If any piece of equipment is not in compliance with any of the applicable requirements, complete and attach Form 500-C2 in addition to Form 500-A2.

^{*} The following AQMD rules and regulations are not required to be included in Section II and do not have to be added to Section III: Regulation I, List and Criteria in Regulation II, Rule 201, Rule 201, Rule 201, Rule 202, Rule 203, Rule 205, Rule 206, Rule 207, Rule 208, Rule 209, Rule 210, Rule 212, Rule 214, Rule 215, Rule 216, Rule 217, Rule 219, Rule 220, Rule 221, Regulation III, Regulation VIII, Regulation XII, Regulation XV, Regulation XV, Regulation XVI, Regulation XXI, Regulation XXII, and Regulation XXX.

^{**} Emission units adversely affected by the gap between current and SIP-approved versions of rules may initially be placed in a non-Title V portion of the permit

Section II - Applicable Requirements, Tes	st Methods, & MRR Requirements		and the state of the state of the state of the state of the state of the state of the state of the state of the
Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
All Air Pollution Control Equipment Using Combustion (RECLAIM & non-RECLAIM sources)	Rule 480 (10/07/77)	N/A	N/A
✓ All Coating Operations (12/15/00)	√ Rule 442	√ Rule 442(f)	✓ Rule 442(g)
All Combustion Equipment, ≥ 555 Mmbtu/Hr (except for NOx RECLAIM sources)	Rule 474 (12/04/81)	AQMD TM 7.1 or 100.1	
All Combustion Equipment Except Internal	Rule 407 (04/02/82)	AQMD TM 100.1 or 10.1, 307-91	
Combustion Engines (RECLAIM & non- RECLAIM sources)	√ Rule 409 (08/07/81)	✓ AQMD TM 5.1, 5.2, or 5.3	
All Combustion Equipment Using Gaseous Fuel (except SOx RECLAIM sources)	Rule 431.1 (06/12/98)	√ Rule 431.1(f)	Rule 431.1(d) & (e)
All Combustion Equipment Using Liquid Fuel (except SOx RECLAIM sources)	√ Rule 431.2 (09/15/00)	√ Rule 431.2(g)	√ Rule 431.2(f)
All Combustion Equipment Using Fossil Fuel (except SOx RECLAIM sources)	Rule 431.3 (05/07/76)		
All Equipment	Rule 401 (11/09/01)	California Air Resources Board Visible Emission Evaluation	
	✓ Rule 405 (02/07/86)	AQMD TM 5.1, 5.2, or 5.3	
	Rule 408 (05/07/76)	N/A	Rule 430(b)
	✓ Rule 430 (07/12/96)	NA	
	Rule 701 (06/13/97)		
	New Source Review, BACT		
	Rule 1703 (10/07/88)		
	✓ 40 CFR68 - Accidental Release Prevention	See Applicable Subpart	See Applicable Subpart
All Equipment Processing Solid Materials	Rule 403 (06/03/05)	Rule 403(d)(3)	Rule 403(f)
All Equipment With Exhaust Stack (except cement kilns subject to Rule 1112.1)	√ Rule 404 (02/07/86)	✓ AQMD TM 5.1, 5.2, or 5.3	
All Facilities Using Solvents to Clean Various	√ Rule 109 (05/02/03)	√ Rule 109(g)	Rule 109(c)
Items or Equipment	√ Rule 1171 (05/01/09)	√ Rule 1171(e)	Rule 1171(c)(6)
	✓ 40 CFR63 SUBPART T	See Applicable Subpart	See Applicable Subpart
All RECLAIM Equipment (NOx & SOx)	Reg. XX - RECLAIM	Rule 2011, App. A (05/06/05)	Rule 2011, App. A (05/06/05)
		✓ Rule 2012, App. A (05/06/05)	✓ Rule 2012, App. A (05/06/05)
Abrasive Blasting	Rule 1140 (08/02/85)	Rule 1140(d) & (e), AQMD Visible Emission Method	

Rute = AQMD Rule AQMD TM = AQMD Test Method CCR = California Code of Regulations	KEY ABBREVIATIONS:	Reg. = AQMD Regulation Rule = AQMD Rule	App. = Appendix AQMD TM = AQMD Test Method	CFR = Code of Federal Regulations CCR = California Code of Regulations
--	--------------------	--	--	--

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
Aggregate and Related Operations	Rule 1157 (09/08/06)	Rule 1157(f)	Rule 1157(e)
Appliances Containing Ozone Depleting Substances (except Motor Vehicle Air Conditioners): Manufacturing, Repair, Maintenance, Service, & Disposal	40 CFR82 SUBPART F	See Applicable Subpart	See Applicable Subpart
Asphalt	See Manufacturing, Asphalt Processing & Aspl	halt Roofing	
Asphalt Concrete/Batch Plants	40 CFR60 SUBPART I	See Applicable Subpart	See Applicable Subpart
Benzene Emissions, Maleic Anhydride Plants, Ethylbenzene/Styrene Plants, Benzene Storage Vessels, Benzene Equipment Leaks, & Coke By-Product Recovery Plants	Rule 1173 (02/06/09) Rule 1176 (09/13/96) 40 CFR61 SUBPART L 40 CFR61 SUBPART Y 40 CFR63 SUBPART R 40 CFR63 SUBPART CC	Rule 1173(j) Rule 1176(h) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart	Rule 1173(i) Rule 1176(f) & (g) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart
Benzene Transfer Operations	Rule 1142 (07/19/91) 40 CFR61 SUBPART BB 40 CFR63 SUBPART Y	Rule 1142(e) See Applicable Subpart See Applicable Subpart	Rule 1142(h) See Applicable Subpart See Applicable Subpart
Benzene Waste Operations	Rule 1176 (09/13/96) 40 CFR61 SUBPART FF 40 CFR63 SUBPART CC	Rule 1176(h) See Applicable Subpart See Applicable Subpart	Rule 1176(f) & (g) See Applicable Subpart See Applicable Subpart
Beryllium Emissions	40 CFR61 SUBPART C	See Applicable Subpart	See Applicable Subpart
Beryllium Emissions, Rocket Motor Firing	40 CFR61 SUBPART D	See Applicable Subpart	See Applicable Subpart
Boiler, < 5 Mmbtu/Hr (non-RECLAIM sources)	Rule 1146.1 (09/05/08) Rule 1146.2 (05/05/06) 40 CFR63 SUBPART DDDDD	Rule 1146.1(d) N/A See Applicable Subpart	Rule 1146.1(c)(2) & (c)(3 N/A See Applicable Subpart
Boiler, < 5 Mmbtu/Hr (RECLAIM sources)	Rule 1146.1 (09/05/08) - excluding NOx requirements 40 CFR63 SUBPART DDDDD	Rule 1146.1(d) See Applicable Subpart	Rule 1146.1(c)(2) & (c)(3

Section II - Applicable Requirements, Tes	t Methods, & MRR Requirements		
Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
Boiler, ≥ 5 Mmbtw/Hr (non-RECLAIM sources)	Rule 218 (05/14/99) Rule 429 (12/21/90) Rule 475 (08/07/78) Rule 476 (10/08/76) Rule 1146 (09/05/08)	AQMD TM 100.1 N/A AQMD TM 5.1, 5.2, or 5.3 AQMD TM 7.1, 100.1, 5.1, 5.2, or 5.3 Rule 1146(d)	Rule 218(e) & (f) Rule 429(d) Rule 1146(c)(6) & (c)(7)
	40 CFR60 SUBPART D 40 CFR60 SUBPART Da 40 CFR60 SUBPART Dc 40 CFR63 SUBPART DDDDD	See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart
Boiler, ≥ 5 Mmbtu/Hr (RECLAIM sources)	Rule 475 (08/07/78) Rule 476 (10/08/76) - excluding NOx requirements Rule 1146 (09/05/08) - excluding NOx requirements Rule 2011 (05/06/05) Or Rule 2012 (05/06/05) 40 CFR60 SUBPART D 40 CFR60 SUBPART Dc 40 CFR63 SUBPART DDDDD	AQMD TM 5.1, 5.2, or 5.3 AQMD TM 7.1, 100.1, 5.1, 5.2, or 5.3 Rule 1146(d) Rule 2011, App. A (05/06/05) Or Rule 2012, App. A (05/06/05) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart	Rule 1146(c)(6) & (c)(7) Rule 2011, App. A (05/06/05) Rule 2012, App. A (05/06/05) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart
Boiler, Petroleum Refining (non-RECLAIM sources)	Rule 218 (05/14/99) Rule 429 (12/21/90) Rule 431.1 (06/12/98) Rule 475 (08/07/78) Rule 1146 (09/05/08) 40 CFR60 SUBBPART J 40 CFR63 SUBPART DDDDD	AQMD TM 100.1 N/A Rule 431.1(f) AQMD TM 5.1, 5.2, or 5.3 Rule 1146(d) See Applicable Subpart See Applicable Subpart	Rule 218(e) & (f) Rule 429(d) Rule 431.1(d) & (e) Rule 1146(c)(6) & (c)(7) See Applicable Subpart See Applicable Subpart

KEY ABBREVIATIONS:	Reg. = AQMD Regulation Rule = AQMD Rule	App. = Appendix AQMD TM = AQMD Test Method	CFR = Code of Federal Regulations CCR = California Code of Regulations

Section II - Applicable Requirements, Te	st Metrus, & MRR Requirements		
Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
Boiler, Petroleum Refining (RECLAIM sources)	Rule 1146 (09/05/08) - excluding NOx requirements	Rule 1146(d)	Rule 1146(c)(6) & (c)(7)
	Rule 2011 (05/06/05)	Rule 2011, App. A (05/06/05)	Rule 2011, App. A (05/06/05)
	Or Rule 2012 (05/06/05)	Rule 2012, App. A (05/06/05)	Rule 2012, App. A (05/06/05)
	40 CFR60 SUBPART J 40 CFR63 SUBPART DDDDD	See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart
Boilers, Electric Utility (non-RECLAIM	Rule 218 (05/14/99)	AQMD TM 100.1	Rule 218(e) & (f)
sources)	Rule 429 (12/21/90)	N/A I□	Rule 429(d)
	Rule 1135 (07/19/91)	Rule 1135(e) See Applicable Subpart	Rule 1135(e) See Applicable Subpart
	40 CFR60 SUBPART Db	See Applicable Subpart	See Applicable Subpart
Boilers, Electric Utility (RECLAIM sources)	✓ Rule 2012 (05/06/05)	✓ Rule 2012, App. A (05/06/05)	✓ Rule 2012, App. A (05/06/05)
	40 CFR60 SUBPART Db	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART DDDDD	See Applicable Subpart	See Applicable Subpart
Bulk Loading Of Organic Liquids	Rule 462 (05/14/99)	Rule 462(f)	Rule 462(g)
	40 CFR60 SUBPART XX	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART R	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART BBBBBB	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART EEEE	See Applicable Subpart	See Applicable Subpart
Cadmium Electroplating Operation	Rule 1426 (05/02/03)		Rule 1426(e)
Calciner, Mineral Industries	40 CFR60 SUBPART UUU	See Applicable Subpart	See Applicable Subpart
Calciner, Petroleum Coke	Rule 477 (04/03/81)	AQMD Visible Emissions, AQMD TM 5.1, 5.2, or 5.3	
	Rule 1119 (03/02/79)	AQMD TM 6.1 or 100.1	
	40 CFR63 SUBPART L	See Applicable Subpart	See Applicable Subpart
Charbroilers	Rule 1174 (10/05/90)	AQMD Test Protocol	П
	Rule 1138 (11/14/97)	Rule 1138(g)	Rule 1138(d)
Chrome Plating & Chromic Acid Anodizing	Rule 1426 (05/02/03)		Rule 1426(e)
Operation	Rule 1469 (12/05/08)	☐ Rule 1469(e)	Rule 1469(g), (j) & (k)

				
KEY ABBREVIATIONS:	Reg. = AQMD Regulation Rule = AQMD Rule	App. = Appendix AQMD TM = AQMD Test Method	CFR = Code of Federal Regulations CCR = California Code of Regulations	

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
Coating Operation, Adhesive Application	Rule 109 (05/02/03)	Rule 109(g)	Rule 109(c)
Operation	Rule 481 (01/11/02)	Rule 481(d)	
	Rule 1132 (05/05/06)	Rule 1132(f)	Rule 1132(g)
	Rule 1168 (01/07/05)	Rule 1168(f) & (e)	Rule 1168(d)
	Rule 1171 (05/01/09)	Rule 1171(e)	Rule 1171(c)(6)
	40 CFR60 SUBPART RR	See Applicable Subpart	See Applicable Subpart
Coating Operation, Aerospace Assembly &	Rule 109 (05/02/03)	Rule 109(g)	Rule 109(c)
Component Manufacturing	Rule 481 (01/11/02)	Rule 481(d)	
	Rule 1124 (09/21/01)	Rule 1124(e) & (f)	Rule 1124(j) & (d)
	Rule 1132 (05/05/06)	Rule 1132(f)	Rule 1132(g)
	Rule 1171 (05/01/09)	Rule 1171(e)	Rule 1171(c)(6)
	40 CFR63 SUBPART GG	See Applicable Subpart	See Applicable Subpart
Coating Operation, Graphic Arts (Gravure,	Rule 109 (05/02/03)	Rule 109(g)	Rule 109(c)
Letter Press, Flexographic & Lithographic	Rule 481 (01/11/02)	Rule 481(d)	
Printing Process, Etc.)	Rule 1130 (10/08/99)	Rule 1130(h)	Rule 1130(e)
	Rule 1132 (05/05/06)	Rule 1132(f)	Rule 1132(g)
	Rule 1171 (05/01/09)	Rule 1171(e)	Rule 1171(c)(6)
	40 CFR60 SUBPART QQ	See Applicable Subpart	See Applicable Subpart
	40 CFR60 SUBPART RR	See Applicable Subpart	See Applicable Subpart
	40 CFR60 SUBPART FFF	See Applicable Subpart	See Applicable Subpart
	40 CFR60 SUBPART VVV	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART KK	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART JJJJ	See Applicable Subpart	See Applicable Subpart
Coating Operation, Magnet Wire Coating	Rule 109 (05/02/03)	Rule 109(g)	Rule 109(c)
	Rule 481 (01/11/02)	Rule 481(d)	
	Rule 1126 (01/13/95)	Rule 1126(d)	Rule 1126(c)(4)
	Rule 1132 (05/05/06)	Rule 1132(f)	Rule 1132(g)
	Rule 1171 (05/01/09)	Rule 1171(e)	Rule 1171(c)(6)

KEY ABBREVIATIONS: Reg. = AQMD Reg Rule = AQMD Rul	• • • • • • • • • • • • • • • • • • • •	CFR = Code of Federal Regulations CCR = California Code of Regulations	_		
---	---	--	---	--	--

Rule 109 (05/02/03) Rule 481 (01/11/02) Rule 1106 (01/13/95) Rule 1132 (05/05/06) Rule 1171 (05/01/09) 40 CFR63 SUBPART II Rule 109 (05/02/03) Rule 481 (01/11/02) Rule 1107 (01/06/06) Rule 1132 (05/05/06)	Rule 109(g) Rule 481(d) Rule 1106(e) Rule 1132(f) Rule 1171(e) See Applicable Subpart Rule 109(g) Rule 481(d)	Rule 109(c) Rule 1106(c)(5) Rule 1132(g) Rule 1171(c)(6) See Applicable Subpart Rule 109(c)
Rule 1106 (01/13/95) Rule 1132 (05/05/06) Rule 1171 (05/01/09) 40 CFR63 SUBPART II Rule 109 (05/02/03) Rule 481 (01/11/02) Rule 1107 (01/06/06)	Rule 1106(e) Rule 1132(f) Rule 1171(e) See Applicable Subpart Rule 109(g) Rule 481(d)	Rule 1132(g) Rule 1171(c)(6) See Applicable Subpart
Rule 1132 (05/05/06) Rule 1171 (05/01/09) 40 CFR63 SUBPART II Rule 109 (05/02/03) Rule 481 (01/11/02) Rule 1107 (01/06/06)	Rule 1132(f) Rule 1171(e) See Applicable Subpart Rule 109(g) Rule 481(d)	Rule 1132(g) Rule 1171(c)(6) See Applicable Subpart
Rule 1171 (05/01/09) 40 CFR63 SUBPART II Rule 109 (05/02/03) Rule 481 (01/11/02) Rule 1107 (01/06/06)	Rule 1171(e) See Applicable Subpart Rule 109(g) Rule 481(d)	Rule 1171(c)(6) See Applicable Subpart
40 CFR63 SUBPART II ✓ Rule 109 (05/02/03) ✓ Rule 481 (01/11/02) ✓ Rule 1107 (01/06/06)	See Applicable Subpart Rule 109(g) Rule 481(d)	See Applicable Subpart
Rule 109 (05/02/03) Rule 481 (01/11/02) Rule 1107 (01/06/06)	✓ Rule 109(g) ✓ Rule 481(d)	
Rule 481 (01/11/02) Rule 1107 (01/06/06)	Rule 481(d)	✓ Rule 109(c)
Rule 1107 (01/06/06)	Rule 481(d)	
Rule 1107 (01/06/06)	17	
Rule 1132 (05/05/06)	 ✓ Rule 1107(e)	✓ Rule 1107(j)
	Rule 1132(f)	Rule 1132(g)
Rule 1171 (05/01/09)	Rule 1171(e)	✓ Rule 1171(c)(6)
40 CFR60 SUBPART EE	See Applicable Subpart	See Applicable Subpart
40 CFR60 SUBPART SS	See Applicable Subpart	See Applicable Subpart
40 CFR63 SUBPART NNNN	See Applicable Subpart	See Applicable Subpart
40 CFR63 SUBPART MMMM	See Applicable Subpart	See Applicable Subpart
☐40 CFR63 SUBPART RRRR	See Applicable Subpart	See Applicable Subpart
Rule 109 (05/02/03)	Rule 109(g)	Rule 109(c)
Rule 481 (01/11/02)	Rule 481(d)	
Rule 1125 (03/07/08)	Rule 1125(e)	Rule 1125(c)(6)
Rule 1132 (05/05/06)	Rule 1132(f)	Rule 1132(g)
Rule 1171 (05/01/09)	Rule 1171(e)	Rule 1171(c)(6)
40 CFR60 SUBPART TT	See Applicable Subpart	See Applicable Subpart
40 CFR60 SUBPART WW	See Applicable Subpart	See Applicable Subpart
40 CFR63 SUBPART KKKK	See Applicable Subpart	See Applicable Subpart
40 CFR63 SUBPART SSSS	See Applicable Subpart	See Applicable Subpart
Rule 109 (05/02/03)	Rule 109(g)	Rule 109©
Rule 481 (01/11/02)	Rule 481(d)	
Rule 1132 (05/05/06)	Rule 1132(f)	☐Rule 1132(g)
Rule 1151 (12/02/05)	Rule 1151(h)	Rule 1151(f)
Rule 1171 (05/01/09)	Rule 1171(e)	Rule 1171(c)(6)
	40 CFR60 SUBPART SS 40 CFR63 SUBPART NNNN 40 CFR63 SUBPART MMMM 40 CFR63 SUBPART RRRR Rule 109 (05/02/03) Rule 481 (01/11/02) Rule 1125 (03/07/08) Rule 1132 (05/05/06) Rule 1171 (05/01/09) 40 CFR60 SUBPART TT 40 CFR60 SUBPART WW 40 CFR63 SUBPART KKKK 40 CFR63 SUBPART SSSS Rule 109 (05/02/03) Rule 481 (01/11/02) Rule 1132 (05/05/06) Rule 1151 (12/02/05)	40 CFR60 SUBPART SS

Section II - Applicable Requirements, Tes	st Methods, & MRR Requirements		
Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
Coating Operation, Motor Vehicle Assembly	Rule 109 (05/02/03)	Rule 109(g)	Rule 109(c)
Line	Rule 481 (01/11/02)	Rule 481(d)	
	Rule 1115 (05/12/95)	Rule 1115(e)	Rule 1115(g)
	Rule 1132 (05/05/06)	Rule 1132(f)	Rule 1132(g)
	Rule 1171 (05/01/09)	Rule 1171(e)	Rule 1171(c)(6)
	40 CFR60 SUBPART MM	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART IIII	See Applicable Subpart	See Applicable Subpart
Coating Operation, Paper, Fabric, & Film	Rule 109 (05/02/03)	Rule 109(g)	Rule 109(c)
Coating Operations	Rule 481 (01/11/02)	Rule 481(d)	<u> </u>
	Rule 1128 (03/08/96)	Rule 1128(f)	Rule 1128(e)
	Rule 1132 (05/05/06)	Rule 1132(f)	Rule 1132(g)
	Rule 1171 (05/01/09)	Rule 1171(e)	Rule 1171(c)(6)
	40 CFR60 SUBPART VVV	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART OOOO	See Applicable Subpart	See Applicable Subpart
Coating Operation, Plastic, Rubber, & Glass	Rule 109 (05/02/03)	Rule 109(g)	Rule 109(c)
	Rule 481 (01/11/02)	<u></u> Rule 481(d)	
	Rule 1145 (12/04/09)	Rule 1145(e)	Rule 1145(d)
	Rule 1132 (05/05/06)	Rule 1132(f)	Rule 1132(g)
	Rule 1171 (05/01/09)	Rule 1171(e)	Rule 1171(c)(6)
	40 CFR60 SUBPART TTT	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART NNNN	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART PPPP	See Applicable Subpart	See Applicable Subpart
Coating Operation, Pleasure Craft	Rule 109 (05/02/03)	Rule 109(g)	Rule 109(c)
	Rule 481 (01/11/02)	Rule 481(d)	
	Rule 1106.1 (02/12/99)	Rule 1106.1(e)	Rule 1106.1(d)
	Rule 1132 (05/05/06)	Rule 1132(f)	Rule 1132(g)
	Rule 1171 (05/01/09)	Rule 1171(e)	Rule 1171(c)(6)
	40 CFR63 SUBPART II	See Applicable Subpart	See Applicable Subpart

KEY ABBREVIATIONS: Reg. = AQMD Regulation Rule = AQMD Rule	App. = Appendix AQMD TM = AQMD Test Method	CFR = Code of Federal Regulations CCR = California Code of Regulations	
--	--	--	--

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
Coating Operation, Screen Printing	Rule 109 (05/02/03)	Rule 109(g)	Rule 109(c)
	Rule 1130.1 (12/13/96)	Rule 1130.1(g)	Rule 1130.1(c)(5)
	Rule 1132 (05/05/06)	Rule 1132(f)	Rule 1132(g)
	Rule 1171 (05/01/09)	Rule 1171(e)	Rule 1171(c)(6)
	40 CFR63 SUBPART KK	See Applicable Subpart	See Applicable Subpart
✓ Coating Operation, Use Of Architectural	Rule 109 (05/02/03)	✓ Rule 109(g)	√ Rule 109(c)
Coating (Stationary Structures)	√ Rule 481 (01/11/02)	▼ Rule 481(d)	Trule 105(c)
,			
	Rule 1113 (07/13/07)	Rule 1113(e)	Rule 1132(g)
	Rule 1132 (05/05/06)	Rule 1132(f)	
	▼ Rule 1171 (05/01/09)	✓ Rule 1171(e)	✓ Rule 1171(c)(6)
Coating Operation, Wood Flat Stock	Rule 109 (05/02/03)	Rule 109(g)	Rule 109(c)
	Rule 481 (01/11/02)	Rule 481(d)	<u> </u>
	Rule 1104 (08/13/99)	Rule 1104(e)	Rule 1104(d)
	Rule 1132 (05/05/06)	Rule 1132(f)	Rule 1132(g)
	Rule 1171 (05/01/09)	Rule 1171(e)	Rule 1171(c)(6)
	40 CFR63 SUBPART II	See Applicable Subpart	See Applicable Subpart
Coating Operation, Wood Products	Rule 109 (05/02/03)	Rule 109(g)	Rule 109(c)
(Commercial Furniture, Cabinets, Shutters,	Rule 481 (01/11/02)	Rule 481(d)	
Frames, Toys)	Rule 1132 (05/05/06)	Rule 1132(f)	Rule 1132(g)
	Rule 1136 (06/14/96)	Rule 1136(f)	Rule 1136(d) & (g)
	Rule 1171 (05/01/09)	Rule 1171(e)	Rule 1171(c)(6)
	40 CFR63 SUBPART JJ	See Applicable Subpart	See Applicable Subpart
Coater	See Coating Operations		<u> </u>
Columns	See Petroleum Refineries, Fugitive Emissio	ns	
Composting Operation	Rule 1133 (01/10/03)	· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·
Composting Operation	Rule 1133.1 (01/10/03)	Rule 1133.1(e)	Rule 1133.1(d)
		Rule 1133.2(g)	Rule 1133.2(h)
<u> </u>	Rule 1133.2 (01/10/03) See Fugitive Emissions or Petroleum Refine		
Compressors	See Nonmetallic Mineral Processing Plants		
Concrete Batch Plants	· ·		
Consumer Product Manufacturing	See Manufacturing, Consumer Product		
Cooling Tower, Hexavalent Chromium	40 CFR63 SUBPART Q	See Applicable Subpart	See Applicable Subpart
KEY ABBREVIATIONS: Reg. = AQMD Regulation Rule = AQMD Rule	App. = Appendix AQMD TM = AQMD Test Method	CFR = Code of Federal Regulations CCR = California Code of Regulations	

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
Copper Electroplating Operation	Rule 1426 (05/02/03)		Rule 1426(e)
Crude Oil Production	See Oil Well Operations		
Crusher	See Nonmetallic Mineral Processing Plan	nts	
Dairy Farms and Related Operations	Rule 1127 (08/06/04)	Rule 1127(h)	Rule 1127(g)
Degreasers	Rule 109 (05/02/03)	√ Rule 109(g)	Rule 109(c)
	Rule 1122 (05/01/09)	√ Rule 1122(h)	Rule 1122(i)
	√ Rule 1171 (05/01/09)	√ Rule 1171(e)	Rule 1171(c)(6)
	40 CFR63 SUBPART T	See Applicable Subpart	See Applicable Subpart
Dry Cleaning, Perchloroethlyene	Rule 1421 (12/06/02)	Rule 1421(e) & (i)	Rule 1421(g) & (h)
Dry Cleaning, Petroleum Solvent	Rule 109 (05/02/03)	Rule 109(g)	Rule 109(c)
	Rule 1102 (11/17/00)	Rule 1102(g)	Rule 1102(f)
	40 CFR60 SUBPART JJJ	See Applicable Subpart	See Applicable Subpart
Dryers, Mineral Industries	40 CFR60 SUBPART UUU	See Applicable Subpart	See Applicable Subpart
Ethylene Oxide Sterilizer	See Sterilizer, Ethylene Oxide		· · · · · · · · · · · · · · · · · · ·
Flanges	See Fugitive Emissions or Petroleum Re	fineries, Fugitive Emissions	
Fluid Catalytic Cracking Unit	Rule 218 (05/14/99)	AQMD TM 100.1	Rule 218(e) & (f)
_	Rule 1105 (09/01/84)	Rule 1105(c)(1)	Rule 1105(c)(2)
	Rule 1105.1 (11/07/03)	Rule 1105.1(f)	Rule 1105.1(e)
Foundries, Iron and Steel	40 CFR63 SUBPART EEEEE	See Applicable Subpart	See Applicable Subpart
Friction Materials Manufacturing	See Manufacturing, Friction Materials	<u> </u>	
Fugitive Emissions, Benzene	Rule 1173 (12/06/02)	Rule 1173(j)	Rule 1173(i)
- -	40 CFR61 SUBPART L	See Applicable Subpart	See Applicable Subpart
	40 CFR61 SUBPART V	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART R	See Applicable Subpart	See Applicable Subpart
200000	40 CFR63 SUBPART CC	See Applicable Subpart	See Applicable Subpart
KEY ABBREVIATIONS: Reg. = AQMD Regulat Rule = AQMD Rule	ion App. = Appendix AQMD TM = AQMD Test Method	CFR = Code of Federal Regulations CCR = California Code of Regulations	

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
Fugitive Emissions, Chemical Plant	Rule 466 (10/07/83)	Rule 466(f)	Rule 466(e)
	Rule 466.1 (03/16/84)	Rule 466.1(g)	Rule 466.1(h)
	Rule 467 (03/05/82)	Rule 467(f)	Rule 467(e)
	Rule 1173 (02/06/09)	Rule 1173(j)	Rule 1173(i)
	40 CFR60 SUBPART VV	See Applicable Subpart	See Applicable Subpart
	40 CFR61 SUBPART V	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART F	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART G	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART H	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART I	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART R	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART CC	See Applicable Subpart	See Applicable Subpart
Fugitive Emissions, Natural Gas Processing	Rule 466 (10/07/83)	Rule 466(f)	Rule 466(e)
Plant	Rule 466.1 (03/16/84)	Rule 466.1(g)	Rule 466.1(h)
	Rule 467 (03/05/82)	Rule 467(f)	Rule 467(e)
	Rule 1173 (02/06/09)	Rule 1173(j)	Rule 1173(i)
	40 CFR60 SUBPART KKK	See Applicable Subpart	See Applicable Subpart
	40 CFR61 SUBPART V	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART F	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART G	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART H	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART I	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART R	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART CC	See Applicable Subpart	See Applicable Subpart

KEY ABBREVIATIONS:	Reg. = AQMD Regulation Rule = AQMD Rule	App. = Appendix AQMD TM = AQMD Test Method	CFR = Code of Federal Regulations CCR = California Code of Regulations	
	tento i mino			

Section II - Applicable Requirements, Te	st Methods, & MRR Requirements		9 <u> </u>
Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
Fugitive Emissions, Oil & Gas Production	Rule 466 (10/07/83)	Rule 466(f)	Rule 466(e)
Facility	Rule 466.1 (03/16/84)	Rule 466,1(g)	Rule 466.1(h)
	Rule 467 (03/05/82)	Rule 467(f)	Rule 467(e)
	Rule 1173 (02/06/09)	Rule 1173(j)	Rule 1173(i)
	40 CFR61 SUBPART V	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART F	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART G	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART H	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART I	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART R	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART CC	See Applicable Subpart	See Applicable Subpart
Fugitive Emissions, Pipeline Transfer Station	Rule 466 (10/07/83)	Rule 466(f)	Rule 466(e)
_	Rule 466.1 (03/16/84)	Rule 466.1(g)	Rule 466.1(h)
	Rule 467 (03/05/82)	Rule 467(f)	Rule 467(e)
	Rule 1173 (02/06/09)	Rule 1173(j)	Rule 1173(i)
	40 CFR61 SUBPART V	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART F	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART G	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART H	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART I	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART R	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART CC	See Applicable Subpart	See Applicable Subpart
Furnace, Basic Oxygen Process	40 CFR60 SUBPART Na	See Applicable Subpart	See Applicable Subpart
Furnace, Electric Arc, For Steel Plants: Constructed After August 17, 1983	40 CFR60 SUBPART AAa	See Applicable Subpart	See Applicable Subpart
Furnace, Electric Arc, For Steel Plants: Constructed After Oct. 21, 1974, & On Or Before Aug. 17, 1983	40 CFR60 SUBPART AA	See Applicable Subpart	See Applicable Subpart
Furnace, Glass Melting	Rule 1117 (01/06/84)	Rule 1117(c), AQMD TM 7.1 or 100.1	
	40 CFR60 SUBPART CC	See Applicable Subpart	See Applicable Subpart
Furnace, Lead Melting, Automotive Batteries	Rule 1101 (10/07/77)	AQMD TM 6.1	
	40 CFR63 SUBPART X	See Applicable Subpart	See Applicable Subpart
KEY ABBREVIATIONS: Reg. = AQMD Regulation Rule = AQMD Rule	App. = Appendix AQMD TM = AQMD Test Method	CFR = Code of Federal Regulations CCR = California Code of Regulations	

Section II - Applicable Requirements, Tes	t Metrus, & MRR Requirements		
Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
Gasoline Transfer & Dispensing Operation	Rule 461 (06/03/05)	Rule 461(f)	Rule 461(e)(6) & (e)(7)
Glass Manufacturing	See Manufacturing, Glass		
Grain Elevators	40 CFR60 SUBPART DD	See Applicable Subpart	See Applicable Subpart
Halon-containing Equipment, Use for Technician Training, Testing, Maintenance, Service, Repair, or Disposal	40 CFR82 SUBPART H	See Applicable Subpart	See Applicable Subpart
Hazardous Waste Combustors	40 CFR63 SUBPART EEE	See Applicable Subpart	See Applicable Subpart
Heater, Asphalt Pavement	Rule 1120 (08/04/78)	AQMD Visible Emissions, AQMD TM 6.2	Rule 1120(f)
Heaters, Petroleum Refinery Process	Rule 429 (12/21/90) Rule 431.1 (06/12/98) Rule 1146 (09/05/08) 40 CFR60 SUBPART J 40 CFR63 SUBPART DDDDD	N/A Rule 431.1(f) Rule 1146(d) See Applicable Subpart See Applicable Subpart	Rule 429(d) Rule 431.1(d) & (e) Rule 1146(c)(6) & (c)(7) See Applicable Subpart See Applicable Subpart
Heaters, Process	See Boilers		
Incinerators -	40 CFR60 SUBPART E	See Applicable Subpart	See Applicable Subpart
	40 CFR60 SUBPART CCCC	See Applicable Subpart	See Applicable Subpart
Inorganic Arsenic Emissions, Arsenic Trioxide & Metallic Arsenic Production Facilities	40 CFR61 SUBPART P	See Applicable Subpart	See Applicable Subpart
Internal Combustion Engines, Reciprocating	Rule 1110.2 (07/09/10)	Rule 1110.2(g)	Rule 1110.2(f)
_	40 CFR60 SUBPART IIII and JJJJ	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART ZZZZ	See Applicable Subpart	See Applicable Subpart
Kiln, Cement Plant	Rule 1112 (06/06/86)	N/A	N/A
 ·	Rule 1112.1 (12/04/09)	N/A	N/A
· · · · · · · · · · · · · · · · · · ·	40 CFR60 SUBPART F	See Applicable Subpart	See Applicable Subpart

KEY ABBREVIATIONS: Reg. = AQMD Regulation App. = Appendix CFR = Code of Federal Regulations Rule = AQMD Rule AQMD TM = AQMD Test Method CCR = California Code of Regulations	
--	--

Section II - Applicable Requirements, Tes	t Methods, & MRR Requirements		
Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
Landfills	Rule 1150 (10/15/82)		
	Rule 1150.1 (03/17/00)	Rule 1150.1(j)	Rule 1150.1(e) & (f)
	40 CFR60 SUBPART WWW	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART AAAA	See Applicable Subpart	See Applicable Subpart
Lead Acid Battery Manufacturing Plants	See Manufacturing, Lead Acid Battery		
Lead Electroplating Operation	Rule 1426 (05/02/03)		Rule 1426(e)
Manufacturing, Asphalt Processing & Asphalt	Rule 470 (05/07/76)	N/A	See Applicable Subpart
Roofing	Rule 1108 (02/01/85)	Rule 1108(b)	See Applicable Subpart
	Rule 1108.1 (11/04/83)	Rule 1108.1 (b)	
	40 CFR60 SUBPART UU	See Applicable Subpart	
	40 CFR63 SUBPART LLLLL	See Applicable Subpart	_
Manufacturing, Brick & Structural Clay Products	40 CFR63 SUBPART JJJJJ	See Applicable Subpart	See Applicable Subpart
Manufacturing, Cement	Rule 1156 (03/06/09)	Rule 1156(g)	Rule 1156(f)
Manufacturing, Clay Ceramics	40 CFR63 SUBPART KKKKK	See Applicable Subpart	See Applicable Subpart
Manufacturing, Coatings & Ink	Rule 1141.1 (11/17/00)	N/A	Rule 1141.1(c)
(SIC Code 2851)	40 CFR63 SUBPART HHHHH	See Applicable Subpart	See Applicable Subpart
Manufacturing, Consumer Product	Title 17 CCR 94500		
Manufacturing, Food Product	Rule 1131 (06/06/03)	Rule 1131(e)	Rule 1131(d)
Manufacturing, Friction Materials	40 CFR63 SUBPART QQQQQ	See Applicable Subpart	See Applicable Subpart
Manufacturing, Glass	Rule 1117 (01/06/84)	Rule 1117(c), AQMD TM 7.1 or 100.1	
	40 CFR60 SUBPART CC	See Applicable Subpart	See Applicable Subpart
	40 CFR61 SUBPART N	See Applicable Subpart	See Applicable Subpart
Manufacturing, Hydrochloric Acid	40 CFR63 SUBPART NNNNN	See Applicable Subpart	See Applicable Subpart
Manufacturing, Lead-Acid Battery	40 CFR60 SUBPART KK	See Applicable Subpart	See Applicable Subpart
KEY ABBREVIATIONS: Reg. = AQMD Regulation Rule = AQMD Rule	App. = Appendix AQMD TM = AQMD Test Method	CFR = Code of Federal Regulations CCR = California Code of Regulations	

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
Manufacturing, Lime	40 CFR63 SUBPART AAAAA	See Applicable Subpart	See Applicable Subpart
Manufacturing, Magnetic Tape Industry	40 CFR60 SUBPART SSS	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART EE	See Applicable Subpart	See Applicable Subpart
Manufacturing, Miscellaneous Organic Chemical	40 CFR63 SUBPART FFFF	See Applicable Subpart	See Applicable Subpart
Manufacturing, Nitric Acid	Rule 218 (05/14/99)	AQMD TM 100.1	Rule 218(e) & (f)
-	Rule 1159 (12/06/85)	AQMD TM 7.1 or 100.1	
	40 CFR60 SUBPART G	See Applicable Subpart	See Applicable Subpart
Manufacturing, Plywood & Composite Wood	Rule 1137 (02/01/02)	N/A	Rule 1137(e)
Products	40 CFR63 SUBPART DDDD	See Applicable Subpart	See Applicable Subpart
Manufacturing, Polymer Industry	40 CFR60 SUBPART DDD	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART W	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART J	See Applicable Subpart	See Applicable Subpart
Manufacturing Delumenia Cellular Form	Rule 1175 (09/07/07)	Rule 1175(f)	Rule 1175(e)
Manufacturing, Polymeric Cellular Foam		See Applicable Subpart	See Applicable Subpart
1.	40 CFR63 SUBPART UUUU		
Manufacturing, Products Containing Halon Blends	40 CFR82 SUBPART H	See Applicable Subpart	See Applicable Subpart
Manufacturing, Products Containing Organic Solvents	Rule 443.1 (12/05/86)	N/A	N/A
Manufacturing, Products Containing Ozone	40 CFR82 SUBPART A	See Applicable Subpart	See Applicable Subpart
Depleting Substances (ODS)	40 CFR82 SUBPART E	See Applicable Subpart	See Applicable Subpart
Manufacturing, Reinforced Plastic Composites	 	See Applicable Subpart	See Applicable Subpart
Manufacturing, Refractory Products	40 CFR63 SUBPART SSSSS	See Applicable Subpart	See Applicable Subpart
Manufacturing, Resin	Rule 1141 (11/17/00)	Rule 1141(d)	Rule 1141(c)
	40 CFR63 SUBPART W	See Applicable Subpart	See Applicable Subpart
Manufacturing, Rubber Tire	40 CFR63 SUBPART XXXX	See Applicable Subpart	See Applicable Subpart
Manufacturing, Semiconductors	Rule 109 (05/02/03)	Rule 109(g)	Rule 109(c)
	Rule 1164 (01/13/95)	Rule 1164(e)	Rule 109(c)
			Rule 1171(c)(6)
	Rule 1171 (05/01/09)	Rule 1171(e) See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART BBBBB	N/A	N/A
Manufacturing, Solvent	Rule 443 (05/07/76)	· *** ·	1 *** 1

quipment/Process	Applicable Requirement	Test Method	MRR Requirement
Manufacturing, Sulfuric Acid	Rule 469 (02/13/81) 40 CFR60 SUBPART H	AQMD TM 6.1 or 6.2 See Applicable Subpart	See Applicable Subpart
	40 CFR60 SUBPART Cd	See Applicable Subpart	See Applicable Subpart
Manufacturing, Surfactant	Rule 1141.2 (01/11/02)	Rule 1141.2(e) AQMD TM 25.1	
Manufacturing, Synthetic Organic Chemical Manufacturing Industry (SOCMI) Air Oxidation Unit Processes	40 CFR60 SUBPART III 40 CFR60 SUBPART NNN	See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart
Manufacturing, Synthetic Organic Chemical Manufacturing Industry (SOCMI) Reactor Processes	40 CFR60 SUBPART RRR	See Applicable Subpart	See Applicable Subpart
Manufacturing, Vinyl Chloride	40 CFR61 SUBPART F	See Applicable Subpart	See Applicable Subpart
Manufacturing, Water Heaters	Rule 1121 (09/03/04)	N/A	N/A
Manufacturing, Wool Fiberglass Insulation	40 CFR60 SUBPART PPP	See Applicable Subpart	See Applicable Subpart
Manure Processing Operations	Rule 1127 (08/06/04)	Rule 1127(h)	Rule 1127(g)
Marine Tank Vessel Operations	Rule 1142 (07/19/91)	Rule 1142(e)	Rule 1142(h)
	Rule 1173 (02/06/09) 40 CFR63 SUBPART Y	Rule 1173(j) See Applicable Subpart	See Applicable Subpart
Mercury Emissions	40 CFR61 SUBPART E 40 CFR63 SUBPART IIII	See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart
Motor Vehicle Air Conditioners with Ozone Depleting Substances (ODS): Repair, Service, Manufacturing, Maintenance, or Disposal	40 CFR82 SUBPART B 40 CFR82 SUBPART F	See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart
Municipal Waste Combustors	40 CFR60 SUBPART Cb 40 CFR60 SUBPART Ea 40 CFR60 SUBPART Eb	See Applicable Subpart See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart See Applicable Subpart
Negative Air Machines/HEPA, Asbestos	√ 40 CFR61 SUBPART M	See Applicable Subpart	See Applicable Subpart
Nickel Electroplating Operation	Rule 1426 (05/02/03)		Rule 1426(e)
Nonmetallic Mineral Processing Plants	Rule 404 (02/07/86) Rule 405 (02/07/86) 40 CFR60 SUBPART OOO	AQMD TM 5.1, 5.2, or 5.3 AQMD TM 5.1, 5.2, or 5.3 See Applicable Subpart	See Applicable Subpart
Off-site Waste and Recovery Operation	40 CFR63 SUBPART DD	See Applicable Subpart	See Applicable Subpart

KEY ABBREVIATIONS:	Reg. = AQMD Regulation Rule = AQMD Rule	App. = Appendix AQMD TM = AQMD Test Method	CFR = Code of Federal Regulations CCR = California Code of Regulations	
	Rule = AQIVID Rule	ACINID I III - ACIVID Test Method	CCR - California Code of Regulations	

Section II - Applicable Requirements, Test Methods, & MRR Requirements				
Equipment/Process	Applicable Requirement	Test Method	MRR Requirement	
Oil and Gas Well Operation	Rule 1148 (11/05/82) Rule 1148.1 (03/05/04)	AQMD TM 25.1 Rule 1148.1 (g)	Rule 1148.1 (f)	
Onshore Natural Gas Processing, SO2 Emissions	40 CFR60 SUBPART LLL	See Applicable Subpart	See Applicable Subpart	
Open Fires	Rule 444 (11/07/08)			
Open Storage, Petroleum Coke	Rule 403 (06/03/05) Rule 403.1 (04/02/04) Rule 1158 (06/11/99)	Rule 403(d)(4) Rule 1158(h)	Rule 403(f) Rule 403.1(h) Rule 1158(j)	
Open Storage	Rule 403 (06/03/05) Rule 403.1 (04/02/04)	Rule 403(d)(4)	Rule 403(f) Rule 403.1(h)	
Outer Continental Shelf Platform	Rule 1183 (03/12/93) 40 CFR55	40 CFR55 See Applicable Subpart	40 CFR55 See Applicable Subpart	
Oven, Commercial Bakery	Rule 1153 (01/13/95)	Rule 1153(h)	Rule 1153(g)	
Oven, Petroleum Coke	Rule 477 (04/03/81) 40 CFR63 SUBPART L 40 CFR63 SUBPART CCCCC	AQMD Visible Emissions, AQMD TM 5.1, 5.2, or 5.3 See Applicable Subpart See Applicable Subpart	See Applicable Subpart See Applicable Subpart	
Ozone Depleting Substances (ODS) or Alternative ODS, Use	40 CFR82 Subpart G	See Applicable Subpart	See Applicable Subpart	

 KEY ABBREVIATIONS:
 Reg. = AQMD Regulation
 App. = Appendix
 CFR = Code of Federal Regulations

 Rule = AQMD Rule
 AQMD TM = AQMD Test Method
 CCR = California Code of Regulations

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement
Petroleum Refineries	Rule 218 (05/14/99)	AQMD TM 100.1	Rule 218(e) & (f)
	Rule 465 (08/13/99)		
	Rule 468 (10/08/76)	AQMD TM 6.1 or 6.2	
	Rule 469 (02/13/81)	AQMD TM 6.1 or 6.2	
	Rule 1118 (11/04/05)	Rule 1118(j)	Rule 1118(f), (g), (h), & (i)
	Rule 1123 (12/07/90)	N/A	Rule 1123(c)
	Rule 1189 (01/21/00)	Rule 1189(f)	Rule 1189(e)
	40 CFR60 SUBPART J	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART F	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART G	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART H	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART I	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART CC	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART EEEE	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART GGGGG	See Applicable Subpart	See Applicable Subpart
	Title 13 CCR 2250		
Petroleum Refineries, Fugitive Emissions	Rule 1173 (02/06/09)	Rule 1173(j)	Rule 1173(i)
	Rule 466 (10/07/83)	Rule 466(f)	Rule 466(e)
	Rule 466.1 (03/16/84)	Rule 466.1(g)	Rule 466.1(h)
	Rule 467 (03/05/82)	Rule 467(f)	Rule 467(e)
	40 CFR60 SUBPART GGG	See Applicable Subpart	See Applicable Subpart
	40 CFR61 SUBPART V	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART F	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART G	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART H	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART I	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART R	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART CC	See Applicable Subpart	See Applicable Subpart

KEY ABBREVIATIONS:	Reg. = AQMD Regulation Rule = AQMD Rule	App. = Appendix AQMD TM = AQMD Test Method	CFR = Code of Federal Regulations CCR = California Code of Regulations	

quipment/Process	Applicable Requirement	Test Method	MRR Requirement
Petroleum Refineries, Storage Tanks	Rule 463 (05/06/05)	Rule 463(g)	Rule 463(e)(5)
	Rule 1178 (04/07/06)	Rule 1178(i)	Rule 1178(f) & (h)
	☐40 CFR60 SUBPART K	See Applicable Subpart	See Applicable Subpart
	40 CFR60 SUBPART Ka	See Applicable Subpart	See Applicable Subpart
	☐40 CFR60 SUBPART Kb	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART F	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART G	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART H	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART I	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART R	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART CC	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART EEEE	See Applicable Subpart	See Applicable Subpart
Petroleum Refineries, Wastewater Systems	Rule 1176 (09/13/96)	Rule 1176(h)	Rule 1176(f) & (g)
•	Rule 464 (12/07/90)	N/A	
	40 CFR60 SUBPART QQQ	See Applicable Subpart	See Applicable Subpart
	40 CFR63 SUBPART CC	See Applicable Subpart	See Applicable Subpart
Pharmaceuticals & Cosmetics Manufacturing	Rule 1103 (03/12/99)	Rule 1103(f)	Rule 1103(e)
,	40 CFR63 SUBPART GGG	See Applicable Subpart	See Applicable Subpart
Polyester Resin Operation	Rule 109 (05/02/03)	Rule 109(g)	Rule 109(c)
	Rule 1162 (07/08/05)	Rule 1 162(f)	Rule 1162(e)
	Rule 1171 (05/01/09)	Rule 1171(e)	Rule 1171(c)(6)
Primary Magnesium Refining	40 CFR63 SUBPART TTTTT	See Applicable Subpart	See Applicable Subpart
4			
Printing Press	See Coating Operations	<u>. </u>	
Publicly Owned Treatment Works Operations	Rule 1179 (03/06/92)	Rule 1179(e)	Rule 1179(c) & (d)
·	40 CFR60 SUBPART O	See Applicable Subpart	See Applicable Subpart
Pumps	See Fugitive Emissions or Petroleum Refi	neries, Fugitive Emissions	

KEY ABBREVIATIONS:	Reg. = AQMD Regulation Rule = AQMD Rule	App. = Appendix AQMD TM = AQMD Test Method	CFR = Code of Federal Regulations CCR = California Code of Regulations	

Equipment/Process	Applicable Requirement	Test Method	MRR Requirement	
Recycling & Recovery Equipment for Ozone Depleting Substances (ODS),	40 CFR82 SUBPART F	See Applicable Subpart	See Applicable Subpart	
Refrigerant Reclaimers for Ozone Depleting Substances (ODS)	40 CFR82 SUBPART F	See Applicable Subpart	See Applicable Subpart	
Rendering Plant	Rule 472 (05/07/76)	N/A	Rule 472(b)	
Rock Crushing	See Nonmetallic Mineral Processing Plant			
Secondary Aluminum Production	40 CFR63 SUBPART LL	See Applicable Subpart	See Applicable Subpart	
Semiconductor Manufacturing	See Manufacturing, Semiconductors			
Sewage Treatment Plants	See Publicly Owned Treatment Works Operation			
Site Remediation	40 CFR63 SUBPART GGGGG	See Applicable Subpart	See Applicable Subpart	
Smelting, Primary Copper	40 CFR63 SUBPART QQQ	See Applicable Subpart	See Applicable Subpart	
Smelting, Secondary Lead	40 CFR60 SUBPART L	See Applicable Subpart	See Applicable Subpart	
	40 CFR63 SUBPART X	See Applicable Subpart	See Applicable Subpart	
Soil Decontamination / Excavation	Rule 1166 (05/11/01)	Rule 1166(e)	Rule 1166(c)(1)(C)	
	40 CFR63 SUBPART GGGGG	See Applicable Subpart	See Applicable Subpart	
Spray Booth	See Coating Operations		<u> </u>	
Sterilizer, Ethylene Oxide	40 CFR63 SUBPART O	See Applicable Subpart	See Applicable Subpart	
Storage Tank, Degassing Operation	Rule 1149 (07/14/95) 40 CFR63 SUBPART CC	See Applicable Subpart	See Applicable Subpart	

KEY ABBREVIATIONS:
Reg. = AQMD Regulation
Rule = AQMD Rule
App. = Appendix
App. = Appendix
AQMD TM = AQMD Test Method
CFR = Code of Federal Regulations
CCR = California Code of Regulations

Section II - Applicable Requirements, Test Methods, & MRR Requirements					
Equipment/Process	Applicable Requirement	Test Method	MRR Requirement		
Storage Tank, Greater Than 19,815 Gallon Capacity	Rule 463 (05/06/05) Rule 1178 (04/07/06) 40 CFR63 SUBPART F 40 CFR63 SUBPART H 40 CFR63 SUBPART I 40 CFR60 SUBPART K 40 CFR60 SUBPART K 40 CFR60 SUBPART Kb 40 CFR63 SUBPART R 40 CFR63 SUBPART R 40 CFR63 SUBPART BBBBBB 40 CFR63 SUBPART CC	Rule 463(g) Rule 1178(i) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart	Rule 463(e)(5) Rule 1178(h) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart		
Synthetic Fiber Production Facilities	40 CFR60 SUBPART HHH	See Applicable Subpart	See Applicable Subpart		
Taconite Iron Ore Processing Facilities	40 CFR63 SUBPART RRRRR	See Applicable Subpart	See Applicable Subpart		
▼Turbine, Stationary Gas-Fired	Rule 1134 (08/08/97) Rule 475 (08/07/78) 40 CFR60 SUBPART GG 40 CFR60 SUBPART KKKK 40 CFR63 SUBPART YYYY	Rule 1134(e) & (g) AQMD TM 5.1, 5.2, or 5.3 See Applicable Subpart See Applicable Subpart See Applicable Subpart	Rule 1134(d) & (f) See Applicable Subpart See Applicable Subpart See Applicable Subpart		
Turbine, Stationary Oil-Fired	40 CFR63 SUBPART YYYY	See Applicable Subpart	See Applicable Subpart		
Valves	See Fugitive Emissions or Petroleum Refi	See Fugitive Emissions or Petroleum Refineries, Fugitive Emissions			
Vessel, Refinery Process	Rule 1123 (12/07/90)	N/A	Rule 1123(c)		
Vessels	See Petroleum Refineries, Fugitive Emiss	ions			

KEY ABBREVIATIONS:	Reg. = AQMD Regulation Rule = AQMD Rule	App. = Appendix AQMD TM = AQMD Test Method	CFR = Code of Federal Regulations CCR = California Code of Regulations	

Section II - Applicable Requirements, Test Methods, & MRR Requirements						
Equipment/Process	Applicable Requirement	Test Method	MRR Requirement			
Wastewater, Chemical Plant	Rule 464 (12/07/90) Rule 1176 (09/13/96) 40 CFR63 SUBPART F 40 CFR63 SUBPART H 40 CFR63 SUBPART I 40 CFR63 SUBPART CC	N/A Rule 1176(h) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart	Rule 1176(f) & (g) See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart See Applicable Subpart			
Wastewater Treatment, Other	Rule 464 (12/07/90) Rule 1176 (09/13/96)	N/A Rule 1176(h)	Rule 1176(f) & (g)			
Woodworking Operations	Rule 1137 (02/01/02)	N/A	Rule 1137(e)			

KEY ABBREVIATIONS:
Reg. = AQMD Regulation
Rule = AQMD Rule

App. = Appendix
AQMD TM = AQMD Test Method

CFR = Code of Federal Regulations
CCR = California Code of Regulations

Section III - Supplemental Identification of Specific Requirements

Complete this section only if there is a specific requirement (i.e., rule reference, test method, or MRR requirement) that is:

- 1. Listed for a specific type of equipment or process in Section II of this form & DOES NOT pertain to a specific device at your facility*: OR.
- 2. Is NOT Listed for a specific type of equipment or process in Section II of this form but it IS applicable to a specific device at your facility.

NOTES:

- 1. For any specific requirement, test method, or MRR requirement that is identified as "Remove," attach additional sheets to explain the reasons why the specific requirement does not pertain to the device listed.
- All boxes that are checked in Section II and any additional requirements identified in this section as "Add" will be used to determine the facility's compliance status. This information will be used to verify the certification statements made on Form 500-A2.
- Do not use this section to identify equipment that is exempt from specific rule requirements. Your equipment is automatically considered to be in compliance with the rule that specifically exempts the equipment from those requirements.
- Listing any requirement that does not apply to a specific piece of equipment in this section will not provide the facility with a permit shield unless one is specifically requested by completing Form 500-D and approved by the AQMD.
- * If this section is completed as part of the initial Title V application & there is no device number assigned, refer to the existing permit or application number in this column.

Device No.*	Specific Requirement (Rule Number & Date)	Add (A) or Remove (R) (Check one)	Test Method	Add (A) or Remove (R) (Check one)	MRR Requirement	Add (A) or Remove (R) (Check one)
		OAOR		OAOR		OAOR
		OAOR		OAOR		OAOR
		OAOR		OAOR		OAOR
		OAOR		OAOR		OAOR
		OAOR		OAOR		OAOR
		OAOR		OAOR	1	OAOR
		OAOR		OAOR		OAOR
		OAOR		OAOR		OAOR
		OAOR		OAOR		OAOR
		OAOR	-	OAOR		OAOR
		OAOR		OAOR		OAOR
		OAOR		OAOR		OAOR
		OAOR		OAOR		OAOR
		OAOR		OAOR		OAOR
		OAOR		OAOR		OAOR
		OAOR		OAOR		OAOR
		OAOR		OAOR		OAOR
		OAOR		OAOR		OAOR
		OAOR		OAOR		OAOR
		OAOR		OAOR		OAOR
		OAOR		OAOR		OAOR
		OAOR		OAOR		OAOR

Check off each SIP-Approved	Rule as it applies to th	ie racility. Use the bia	anks at the end of this form to fill	-in new items.	
SIP - Approved Rule	Adoptioni Amendment Date	Check (√) If Applies	SiP - Approved Rule	Adoption/ Amendment Date	Check (🗸)
401	03/02/84	√			
431.2	05/04/90		<u> </u>		
461	6/3/05				
466.1	05/02/80				
469	04/07/76				
475	10/08/76	/			
1112	01/06/84				
1112.1	2/7/86				
1113	11/08/96	<u> </u>	·-		
1117	1/6/83				
1122	07/11/97	<u> </u>			
1132	03/05/04				
1140	02/01/80	7			
1146	11/17/00			-	
1146.1	5/13/94				
1151	12/11/98				
1158	6/11/99				
1162	11/17/00				
1166	07/14/95				
1171	11/07/03	<u> </u>			
1175	05/13/94				
1186	09/10/99				

ERIC GARCETTI Mayor Commission
MEL LEVINE, President
WILLIAM W. FUNDERBURK JR., Vice President
JILL BANKS BARAD
MICHAEL F. FLEMING
CHRISTINA E. NOONAN
BARBARA E. MOSCHOS, Secretary

MARCIE L. EDWARDS

General Manager

January 13, 2016

Mr. Li Chen Air Quality Engineer South Coast Air Quality Management District 21865 East Copley Drive Diamond Bar, CA 91765

Dear Mr. Chen:

Subject: Permit Application for Change of Condition and Minor Permit Revision Los Angeles Department of Water and Power (LADWP) Haynes Generating Station (Haynes)

The LADWP is submitting the enclosed permit application for Change of Condition and Minor Permit Revision for the Haynes (Facility ID 800074) Title V Permit. Since Haynes Unit 1 (Device ID D1) and Unit 2 (Device ID D4) only burn natural gas, the LADWP is requesting the removal of the following Title V permit conditions pertaining to fuel oil firing:

- D182.1
- E371.1
- E202.1
- E204.1
- E204.2
- K171.1

The following forms are enclosed:

- AQMD Form 400-A
- AQMD Form 400-A2
- AQMD Form 400-CEQA
- AQMD Form 500-C1

Mr. Li Chen Page 2 January 13, 2016

• Check No. R100837 in the amount of \$25,592.54 for the Change of Condition and Minor Permit Revision fees. Please refer to Enclosure 1 for the explanation of fees.

If you have questions, please contact Ms. Leizl Lontok at (213) 367-3779.

Sincerely,

Dat M. Quach

Manager of Air Quality

Davach

LL:rs

Enclosures

c: Ms. Leizl Lontok

Section V - AQMD Rules That Are Not SIP-Approved (Continued on Following Page) Check off each AQMD Rule as it applies to the facility. Use the blanks at the end of this form to fill-in new items. Adoption/ Adoption/ Check (✓) Check (√) Amendment Non SIP - Approved Rule Non SIP - Approved Rule Amendment If Applies If Applies Date Date N/A 53 Los Angeles Co. 1192 06/16/00 **7** 53 Orange Co. 1193 N/A 07/09/10 53 Riverside Co. N/A 1194 10/20/00 53 San Bernardino Co. N/A 1195 05/05/06 53A San Bernardino Co. N/A 1196 06/06/08 402 05/07/76 1401 09/10/10 429 12/21/90 1401.1 11/04/05 430 07/12/96 1402 03/04/05 441 05/07/76 1403 10/05/07 473 05/07/76 1404 04/06/90 477 04/03/81 1405 01/04/91 480 1406 07/08/94 10/07/77 1407 1109 08/05/88 07/08/94 1411 1110.2 07/09/10 03/01/91 1414 1116.1 10/20/78 05/03/91 1127 08/06/04 1415 10/14/94 1143 07/09/10 1418 09/10/99 1147 12/05/08 1420 09/11/92 1148.1 03/05/04 1420.1 11/05/10 1150 10/15/82 1421 12/06/02 1155 12/04/09 1425 03/16/01 1156 03/06/09 1426 05/02/03 1157 09/08/06 1163 06/07/85 1170 05/06/88 1183 03/12/93 1186.1 01/09/09 1191 06/16/00

Non SIP - Approved Rule	Adoption/ Amendment Date	Check (√) If Applies	Non SIP - Approved Rule	Adoption/ Amendment Date	Check (√) if Applies
1469	12/05/08		2009.1	05/11/01	
1469.1	03/04/05		2501	05/09/97	
1470	06/01/07		2506	12/10/99	
1472	03/07/08				
2009	01/07/05	✓			
				- "	



South Coast Air Quality Management District

Form 400-A

Application Form for Permit or Plan Approval

Coast List only one piece of equipment or process per form.

Mail To: SCAQMD P.O. Box 4944 Diamond Bar, CA 91765-0944

Tel: (909) 396-3385 www.agmd.gov

AQMD	www.aqmd.gov			
Section A - Operator Information				
Facility Name (Business Name of Operator to Appear on the Permit):	2. Valid AQMD Facility ID (Available On			
LA City DWP, Haynes Generating Station	Permit Or Invoice Issued By AQMD):			
3. Owner's Business Name (If different from Business Name of Operator):	800074			
Section B - Equipment Location Address	Section C - Permit Mailing Address			
4. Equipment Location Is: Fixed Location Various Location (For equipment operated at various locations, provide address of initial site.)	Permit and Correspondence Information: Check here if same as equipment location address			
6801 East 2nd Street	111 N. Hope Street, Room 1050			
Street Address	Address			
Long Beach , CA 90803 Zip	Los Angeles , CA 90012 State Zip			
Edward Kim Env. Coordinator	Dat M. Quach Air Quality Manager			
Contact Name Title	Contact Name Title			
(310) 522-7512 Phone # Ext Fax #	(213) 367-4697 (213) 367-4710 Ext. Fax #			
E-Mail: edward.kim@ladwp.com	E-Mail: dat.quach@ladwp.com			
Section D - Application Type				
6. The Facility Is: Not In RECLAIM or Title V In RECLAIM	☐ In Title V ☐ In RECLAIM & Title V Programs			
7. Reason for Submitting Application (Select only ONE):				
	rocess with an Existing/Previous Application or Permit:			
New Construction (Permit to Construct) Administrative Construction				
C Equipment On-Site But Not Constructed or Operational Alteration/Modifi	e total angle to a			
	ication without Prior Approval *			
Compliance Plan Change of Conc	If you checked any of the items in			
•	7c., you MUST provide an existing dittion without Prior Approval Permit or Application Number:			
Change of Code Streamlined Standard Permit Change of Loca				
Change of Loop	ition without Prior Approval • 410730			
M. Facility Petrius:	rating with an Expired/Inactive Permit *			
Title V Application or Amendment (Refer to Title V Matrix)				
	assing Fee and additional Annual Operating Fees (up to 3 full years) may apply (Rule 301(c)(1)(D)(i)).			
8a. Estimated Start Date of Construction (mm/dd/yyyy): 8b. Estimated End Date of C	construction (mm/dd/yyyy): 8c. Estimated Start Date of Operation (mm/dd/yyyy):			
9. Description of Equipment or Reason for Compliance Plan (list applicable rule):	10. For identical equipment, how many additional			
Permit application for minor permit modification and change in condition.	applications are being submitted with this application? (Form 400-A required for each equipment / process) 1			
11. Are you a Small Business as per AQMD's Rule 102 definition?	12. Has a Notice of Violation (NOV) or a Notice to Comply (NC) been issued for this equipment?			
(10 employees or less and total gross receipts are \$500,000 or less OR a not-for-profit training center) Po No Yes	Comply (NC) been issued for this equipment? If Yes, provide NOV/NC#:			
13. What type of business is being conducted at this equipment location? Electric Generation	14. What is your business primary NAICS Code? (North American Industrial Classification System) 221112			
15. Are there other facilities in the SCAQMD jurisdiction operated by the same operator? No	16. Are there any schools (K-12) within 1000 feet of the facility property line? No Yes			
Section F - Authorization/Signature / hereby certify that all information cont	tained herein and information submitted with this application are true and correct.			
17. Signature of Responsible Official: Dir. of Power S	Cupally and Op (This may cause a delay in the			
20. Print Name: 21. Date: / /	application process.) 22. Do you claim confidentiality of			
Kenneth A. Silver	data? (If Yes, see instructions.) • No Yes			
23. Check List: Authorized Signature/Date	Supplemental Form(s) (ie., Form 400-E-xx)			
AOMO S 3 1336 TOBLO 837 25 392	SUPAYMENT TRACKING # VALIDATION / 9/16 OF			
DATE APP DATE APP CLASS BASIC EQUIPMENT CATEGORY REJ I III CONTROL	CODE TEAM ENGINEER REASON/ACTION TAKEN			



South Coast Air Quality Management District

Form 400-A

Application Form for Permit or Plan Approval List only one piece of equipment or process per form.

Mail To: SCAQMD P.O. Box 4944 Diamond Bar, CA 91765-0944

Tel: (909) 396-3385

ACIVID		p.bmps.www
Section A - Operator Information		
Facility Name (Business Name of Operator to Appear on the Permit):		2. Valid AQMD Facility ID (Available On
LA City DWP, Haynes Generating Station		Permit Or Invoice Issued By AQMD):
3. Owner's Business Name (If different from Business Name of Operator):		800074
Section B - Equipment Location Address	Section C - Permit Mailing Address	<u> </u>
4. Equipment Location Is: Fixed Location Various Loca (For equipment operated at various locations, provide address of initial site.)	stion 5. Permit and Correspondence Information Check here if same as equipment le	
6801 East 2nd Street Street Address	111 N. Hope Street, Room 105 Address	
Long Beach , CA 90803	Los Angeles City	, CA 90012 State Zip
Edward Kim Env. Coordinator Contact Name Title	Dat M. Quach Contact Name	Air Quality Manager
(310) 522-7512 Phone # Ext Fax #	(213) 367-4697 Phone # Ext.	(213) 367-4710 Fax #
E-Mail: edward.kim@ladwp.com	E-Mail: dat.quach@ladwp.com	
Section D - Application Type		
6. The Facility Is: Not In RECLAIM or Title V In RECLA	AIM In Title V • In RECLAIN	A & Title V Programs
7. Reason for Submitting Application (Select only ONE):		
7a. New Equipment or Process Application: 7c. Equipmen	nt or Process with an Existing/Previous Applica	tion or Permit:
New Construction (Permit to Construct) Administr	rative Change	
	√Modification	Existing or Previous
Equipment Operating Without A Permit * Alteration	v/Modification without Prior Approval *	Permit/Application
• •	of Condition	If you checked any of the items in 7c., you MUST provide an existing
Registration/Certification Change of	of Condition without Prior Approval	Permit or Application Number:
Streamlined Standard Permit Change of	of Location	410732
Pb. Facility Permits:	of Location without Prior Approval *	
Title V Application or Amendment (Refer to Title V Matrix)	nt Operating with an Expired/Inactive Permit *	
· · · · · · · · · · · · · · · · · · ·	nit Processing Fee and additional Annual Operating Fees (up to 3 full years) may apply (Rule 301(c)(1)(D)(i)).
14EOC diff. Builty 1 or not 7 or official to		ed Start Date of Operation (mm/dd/yyyy):
9. Description of Equipment or Reason for Compliance Plan (list applicable rule	b): 10. For Identical equipment, how many	
Permit application for minor permit modification and change in condition. Boiler Modification	applications are being submitted wit (Form 400-A required for each equipment	ent / process) 1
11. Are you a Small Business as per AQMD's Rule 102 definition? (10 employees or less and total gross receipts are	12. Has a Notice of Violation (NOV) or Comply (NC) been issued for this e	
\$500,000 or less OR a not-for-profit training center) • No C Y		
Section E - Facility Business Information		
13. What type of business is being conducted at this equipment location? Electric Generation	14. What is your business primary NAIC (North American Industrial Classification	
15. Are there other facilities in the SCAQMD	16. Are there any schools (K-12) within	2 © No C Yes
jurisdiction operated by the same operator:	1000 feet of the facility property line	
Section F - Authorization/Signature I hereby certify that all information 17. Signature of Responsible Official: 18. Title Official: 18	on contained herein and information submitted with	ew the permit prior to issuance.
		se a delay in the No
20. Print Name: 21. Date: /// Kenneth A. Silver		confidentiality of , see instructions.) • No Yes
23. Check List: Authorized Signature/Date Form 400-CE	QA Supplemental Form(s) (ie., Form	1 400-E-xx) X Fees Enclosed
AGMD APPLICATION TRACKING # CHECK # AMOUNT RECEIVED USE ONLY 531337 700100837 2559	PAYMENT TRACKING #	VALIDATION 9/16
DATE APP DATE APP CLASS BASIC EQUIPMENT CATE	GORY CODE TOM ENGINEER REASON/ACTIO	

© South Coast Air Quality Management District, Form 400-A (2014.07)

U 126073

South Coast

South Coast Air Quality Management District

Form 400-CEQA

Section A - Facility Information

California Environmental Quality Act (CEQA) Applicability

Mail To: SCAQMD P.O. Box 4944 Diamond Bar, CA 91765-0944

> Tel: (909) 396-3385 www.aqmd.gov

The SCAQMD is required by state law, the California Environmental Quality Act (CEQA), to review discretionary permit project applications for potential air quality and other environmental impacts. This form is a screening tool to assist the SCAQMD in clarifying whether or not the project has the potential to generate significant adverse environmental impacts that might require preparation of a CEQA document [CEQA Guidelines §15060(a)]. Refer to the attached instructions for guidance in completing this form. For each Form 400-A application, also complete and submit one Form 400-CEQA. If submitting multiple Form 400-A applications for the same project at the same time, only one 400-CEQA form is necessary for the entire project. If you need assistance completing this form, contact Permit Services at (909) 396-3385 or (909) 396-2668.

			en was a warm of the control of the								
1. Fac	ility Na	me (Bus	iness Name of Operator To Appear On The Permit):	Valid AQMD Facility ID (Available On Permit Or Invoice Issued ACMD):							
L/	A City	DWP	, Haynes Generating Station	By AQMD):	800074						
3. Pro	ject Des	scriptio	on:	_	_						
Pe	ermit a	applica	ation for minor permit revision and change of condition	ons pertaining to fu	iel oil firing of Boiler Unit 1						
(D	evice	ID D	1) and Boiler Unit 2 (Device ID D4)		•						
Section	n B - I	Review	For Exemption From Further CEQA Action								
Check	"Yes" o	r "No" a	as applicable								
	Yes	No	Is this application for:	·							
1.	ر	•	A CEQA and/or NEPA document previously or currently prepared signed Notice of Determination to this form.	I that specifically evalua	ates this project? If yes, attach a copy of the						
2.											
3.	ر	(e	A functionally identical permit unit replacement with no increase in rating or emissions?								
4.	ر	•	A change of daily VOC permit limit to a monthly VOC permit limit?								
5.	ر	6	Equipment damaged as a result of a disaster during state of eme	• ,							
6.	ر ((A Title V (i.e., Regulation XXX) permit renewal (without equipment	modifications)?							
7.	ر ,	•	A Title V administrative permit revision?								
8.	ر	6	The conversion of an existing permit into an initial Title V permit?								
			r any question in Section B, your application does not require additional date this form.	evaluation for CEQA app	plicability. Skip to Section D - Signatures on						
Sectio	nC - I	Review	of Impacts Which May Trigger CEQA								
	lete Part tach it to		y checking "Yes" or "No" as applicable. To avoid delays in processing rm.	your application(s), expla	in all "Yes" responses on a separate sheet						
	Yes	No	Part I - General								
1.	C	•	Has this project generated any known public controversy regarding potential adverse impacts that may be generated by the project? Controversy may be construed as concerns raised by local groups at public meetings; adverse media attention such as negative articles in newspapers or other periodical publications, local news programs, environmental justice issues, etc.								
2.		©	Is this project part of a larger project? If yes, attach a separate she	et to briefly describe the l	arger project.						
			Part II - Air Quality								
3.	\subset	•	Will there be any demolition, excavating, and/or grading construction feet?	tion activities that enco	ompass an area exceeding 20,000 square						
4.	(•	Does this project include the open outdoor storage of dry bulk so with the application package.	olid materials that could	generate dust? If Yes, include a plot plan						

¹A "project" means the whole of an action which has a potential for resulting in physical change to the environment, including construction activities, clearing or grading of land, improvements to existing structures, and activities or equipment involving the issuance of a permit. For example, a project might include installation of a new, or modification of an existing internal combustion engine, dry-cleaning facility, boiler, gas turbine, spray coating booth, solvent cleaning tank, etc.

² To download the CEQA guidelines, visit http://ceres.ca.gov/env_law/state.html.

³ To download this form and the instructions, visit http://www.aqmd.gov/ceqa or http://www.aqmd.gov/permit

	nÇ-	renay	allings supple	Lance of Archive 1995								
	Yes	No	Part II - Air Quality	(cont.)								
5.	0	•	For example, comp	t result in noticeable off-site odors fro lost materials or other types of greenwar to Rule 402 – Nuisance.	om activities that may not be subject to SCAQMD permit requirements? ste (i.e., lawn clippings, tree trimmings, etc.) have the potential to generate odor							
6.	C	•	Does this project	cause an increase of emissions from	marine vessels, trains and/or airplanes?							
7.	C	•	Will the proposed vehicle to or from	ill the proposed project increase the QUANTITY of hazardous materials stored aboveground onsite or transported by mobile chicle to or from the site by greater than or equal to the amounts associated with each compound on the attached Table 1?4								
			Part III - Water Re	SOURCES								
8.	ر	(e)	The following exam generate steam; 2) production process	ples identify some, but not all, types of in projects that use water as part of the air	y by more than 5,000,000 gallons per day? projects that may result in a "yes" answer to this question: 1) projects that repolition control equipment; 3) projects that require water as part of the on of existing sewage treatment facilities; 5) projects where water demand sufficient water for the project; and 6) projects that require new or expansion of							
9.	C	•	Examples of such p	If the project require construction of new water conveyance infrastructure? amples of such projects are when water demands exceed the capacity of the local water purveyor to supply sufficient water for the local water purveyor to supply supply sufficient water for the local water purveyor to supply sufficient water for the local water purveyor to supply su								
			Part IV - Transpor	tation/Circulation								
10.				sult in (Check all that apply):								
	ر	•		ore than 350 new employees?								
	ر	ē		an increase in heavy-duty transport truck traffic to and/or from the facility by more than 350 truck round-trips per day?								
		•	c. increase customer traffic by more than 700 visits per day?									
]	Part V - Noise	Services of the service of the servi								
11.	Ċ	Ē	Will the project inc	clude equipment that will generate no	ise GREATER THAN 90 decibels (dB) at the property line?							
			Part VI - Public Se	rvices								
12.			Will the project cre	eate a permanent need for new or add	litional public services in any of the following areas (Check all that apply):							
	رَ	•			ential amount of wastes generated by the project is less than five tons per day.							
	C	b. Hazardous waste disposal? Check "No" if the projected potential amount of hazardous wastes generated by the project is less than 42 cubic yards per day (or equivalent in pounds).										
"REMI	NDER: F	or each	"Yes" response in Sect	tion C, attach all pertinent information includir	ng but not limited to estimated quantities, volumes, weights, etc.**							
Sectio	nD - \$	ignatu	res :									
CORR RIGHT	TO CO) THE E	BEST OF MY KNOV R OTHER PERTINE									
1. Sign	ature of	Respon	sible Official of Firm:	2 1/1	2. Title of Responsible Official of Firm:							
<u></u>	1	2	m	Silver	Director of Power Supply and Operations							
	Name o nneth	•	nsible Official of Firm ver	i:	4. Date Signed: 1/14/2016							
5. Phor	ne#ofR	esponsi	ble Official of Firm:	6. Fax # of Responsible Official of Firm:	7. Email of Responsible Official of Firm:							
(21	3) 067	7-437	4	(213) 367-0210	kenneth.silver@ladwp.com							
	•		7)	on other than responsible official of firm):	9. Title of Preparer:							
/	^	\mathcal{V}		-	Environmental Specialist							
10. Prir	nt Name	of Prepa	rer:		11. Date Signed:							
	zl Lon				1/5/16							
	ne # of I	•		13. Fax # of Preparer:	14. Email of Preparer:							
(21	3) 26	7-377	9	(213) 367-4710	leizl.lontok@ladwp.com							

THIS CONCLUDES FORM 400-CEQA. INCLUDE THIS FORM AND ANY ATTACHMENTS WITH FORM 400-A.

⁴ Table 1 – Regulated Substances List and Threshold Quantities for Accidental Release Prevention can be found in the Instructions for Form 400-CEQA.

Restrictions Concerning the Release and Interpretation of Source Testing Emission Information (Please Read Carefully)

The South Coast Air Quality Management District • Source Test Engineering Branch

Request		
Concerns:	Chroma Systems	84580
		(AQMD Control No.)

The SCAQMD Source Test Engineering (STE) Branch has provided the following source testing reports pursuant to your Public Records Request. STE is obligated under AQMD's Guidelines for Implementing the California Public Records Request, to remove information which is regarded as proprietary, confidential, or information which contains trade secrets. Also, "data used to calculate emission data" must be removed, prior to dissemination. This includes, but is not limited to:

- 1. Intermediate stack information (stack dimensions, velocity/flowrate, temperature, gaseous composition other than reported contaminant emissions, etc.).
- 2. Intermediate emission information (emissions/losses to control devices, raw emission data, laboratory analyses, etc.).
- 3. Process information (process/product throughput, fuel usage, firing rates and burner/control adjustments unless rule/permit conditions specify emissions to be formatted according to this information, photos or drawings of process, etc.).
- 4. Quality Assurance concerning the above information (calibrations, corrections, etc.).

Most source test reports received by STE are formally evaluated for accuracy and other factors pertinent to the accuracy of reported emissions. The attached source test reports have been rated as follows:

Source Test I.D.	Document Su	ubject/Date	Accuracy Rating*
R 08025	☐ Protocol ☐ Report ☐ other:	☐ Test Date ☐ Document Date May 8, 2006	(I) (A) (CA) (U) (NR)
R 08026	☐ Protocol ☐ Report ☐ other:	☐ Test Date ☐ Document Date May 8, 2006	(I) (A) (CA) (U) (NR)

*STE's Accuracy Rating Explanations:

In-House (I) – Source testing and report were conducted "in-house" by AQMD Source Testing staff and reported emission information is considered accurate.

ACCEPTABLE (A) – Source test document was conducted/submitted by independent source testing firm, has been evaluated by STE staff, and reported emission information is considered accurate and well documented.

CONDITIONALLY ACCEPTABLE (CA) – Source test document was conducted/submitted by independent source testing firm, has been evaluated by STE staff, and reported emission information may have limited use. For further details, contact STE at (909) 396-2265.

UNACCEPTABLE (U) – Source test document was conducted/submitted by independent source testing firm, has been evaluated by STE staff, and emission information is <u>not</u> considered accurate. <u>Unacceptable source test reports will not be provided unless the requestor requests their release after being notified of their Accuracy Rating.</u> For further details, contact STE at (909) 396-2265.

NOT RATED (NR) – Source test report has \underline{not} been formally evaluated or status is unknown. STE assumes no responsibility for the accuracy of the reported emission information.

131PUBLIC_Records Request Evaluation.doc (Revised 11/08/12)





RECLAIM LARGE SOURCE TEST REPORT

PREPARED FOR:

Chroma Systems 3201 South Susan Street Santa Ana, CA 92704

EQUIPMENT LOCATION:

Chroma Systems
3201 South Susan Street
Santa Ana, CA 92704
(SCAQMD Facility I.D. #095212)

EQUIPMENT I.D:

Boiler (SCAQMD Device ID #: D8)

TEST DATES:

March 30, 2006

ISSUE DATE:

May 8, 2006

PARAMETERS MEASURED:

NO_x and O₂ Emissions

TESTED BY:

World Environmental 20321 Lake Forest Drive, Suite D6 Lake Forest, CA 92630

World Environmental Report No: WER1723 Revision: 0

Prepared By:

Mr. Thomas Cheng,

Project Manager

Reviewed By:

Mr. Keith Shannon,

President of World Environmental

2.0 SUMMARY OF RESULTS

Facility: Chroma Systems
Date Tested: March 30, 2006

Unit:


Project #:

Boiler (D8) WER1723

A. Boiler (Device ID: D8)

A. Boller (Device	1D: Do)		
Emissions	Test Run	Emission Limit	Applicable Rule
Fuel Type:	Natural Gas		
DSCFM:			
O ₂ %:			
NO _x ppm (drift corr) ppm @ 3% O ₂ lb/hr	15.84 0.48	20 ppm @ 3% O ₂	RECLAIM Large Source
CO ppm (drift corr) ppm @ 3% O ₂ lb/hr	85.10 1.57	400 ppm @ 3% O ₂	





RECLAIM LARGE SOURCE TEST REPORT

PREPARED FOR:

Chroma Systems 3201 South Susan Street Santa Ana, CA 92704

EQUIPMENT LOCATION:

Chroma Systems
3201 South Susan Street
Santa Ana, CA 92704
(SCAQMD Facility I.D. #095212)

EQUIPMENT I.D:

Boiler (SCAQMD Device ID #: D9)

TEST DATES:

March 14, 2006

ISSUE DATE:

May 8, 2006

PARAMETERS MEASURED:

NO_x and O₂ Emissions

TESTED BY:

World Environmental 20321 Lake Forest Drive, Suite D6 Lake Forest, CA 92630

World Environmental Report No: WER1723
Revision: 0_____

Prepared By:

Mr. Thomas Cheng,

Project Manager

Reviewed By:

Mr. Keith Shannon,

President of World Environmental

2.0 SUMMARY OF RESULTS

Facility: Chroma Systems

Date Tested: March 14, 2006

Unit: Boiler (D9)

Project #: WER1723

A. Boiler (Device ID: D9)

A. Doner (Device	10.07)		
Emissions	Test Run	Emission Limit	Applicable Rule
Fuel Type:	Natural Gas		
DSCFM:			
O ₂ %:			
NO _X ppm (drift corr) ppm @ 3% O ₂ lb/hr	10.42 0.31	15 ppm @ 3% O ₂	RECLAIM Large Source
CO ppm (drift corr) ppm @ 3% O ₂ lb/hr	< 20.71 <0.37	400 ppm @ 3% O ₂	

^{*} CO concentration was less than the quantifiable limit, 20% of full scale was used as the concentration measured. Testing for CO was performed at 0-100 ppm range, therefore 20 ppm was used as the default value.

Dunavent, Andrew/SDO

From: Lisa Ramos < lramos1@aqmd.gov>
Sent: Thursday, March 17, 2016 8:00 AM

To: Dunavent, Andrew/SDO
Cc: OB PR Support NA Docs
Subject: Public Reords Request #84582,

Attachments: - PR - PR Supporting Docs - 3/17/2016 - 84582 - - - COMPLETION LETTER - ANDREW

DUNAVENT.pdf

Andrew Dunavent

No other documents were available for this request. I have attached the completion letter.

Lisa Ramos South Coast A.QM.D Public Records Unit 909.396.3211

Information Management Public Records Unit

Direct Dial (909) 396-3700 Fax:(909) 396-3330

COMPLETION LETTER

March 17, 2016

ANDREW DUNAVENT CH2M HILL 402W. BROADWAY # SUITE 1450 SAN DIEGO, CA 92101

Ref.: CONTROL NO. 84582

Received 1/21/2016

Re: APPL'S, P/O'S & S/T RPTS FOR BETA OFFSHORE, FAC ID #166073, AT OCS LEASE PARCELS P300/P301, HUNTINGTON BEACH, CA 92648, APPL #'S 533629, 533630, 533631, 533632, 533634, 533635 & 533636.

After a thorough search of this agency's records, the following records were found: APPL'S & P/O'S FOR BETA OFFSHORE, FAC ID #166073, AT OCS LEASE PARCELS P300/P301, HUNTINGTON BEACH, CA 92648, APPL #'S 533629, 533630, 533631, 533632, 533634, 533635 & 533636.

The following records were not found:

S/T RPTS FOR BETA OFFSHORE, FAC ID #166073, AT OCS LEASE PARCELS P300/P301, HUNTINGTON BEACH, CA 92648, APPL #'S 533629, 533630, 533631, 533632, 533634, 533635 & 533636.

YOUR REQUESTED RECORDS WERE PROVIDED ELECTRONICALLY ON 03/17/2016

If you have any questions, please do not hesitate to contact me, Tuesday through Friday, 8:00 a.m. to 4:30 p.m.

Sincerely,

LISA RAMOS x3211 For Colleen Paine Public Records Coordinator

Dunavent, Andrew/SDO

From: Jacob Allen <jallen2@aqmd.gov>
Sent: Friday, April 22, 2016 3:41 PM
To: Dunavent, Andrew/SDO
Cc: OB PR Support NA Docs

Subject: Public Records Request #84573, partial

Attachments: ENG - Application Folder - 7/2/2014 - Fac ID: 169754 - Appl# 555370 - Permit# G31830

- Name: OXY USA INC -.pdf; - PR - PR Review Docs - 1/22/2016 - 84573 - EQL - 4FD40F621BD37B438F14E5A944066C9D.TIF - - ANDREW DUNAVENT.pdf

Attached is a partial delivery of your requested records. This is everything that is currently available. Your request is still routed out for Complete Engrg Appl File 572641, the Facility Permit and Source Testsrelated to your requested Applications. I have sent these departments a reminder and let them know that you are asking for your requested records

Jacob Allen Public Records, SCAQMD (909) 396-2282



SCAQMD Facility Equipment List Report

Run Date: 01/22/2016 10:19 AM

Team: I

Page 1 of 5

Facility: 169754 SO CAL HOLDING, LLC

Status: Active

Last Inspection: 05/12/2015

On Hold: N Contact: DIANA LANG (562) 6243314

Suspended: N RECLAIM: Y

TS: TS-01 Cycle I RECLAIM/Title V Facility TITLE V: Y

AIRS ID: 0605900025

Location Address: 20101 GOLDENWEST ST, HUNTINGTON BEACH 92648-2628 Sector:OH

Mailing Address: 111 W OCEAN BLVD, LONG BEACH 90802 Sector:LB

Instruction:

MR: 0103 SIC: 1311

Quarter: 0010 - inspect in 3rd quarter, every year

Assignment: 1324313

Inspector: VJ01 VICTOR JUAN JR

Inspection Date: 08/01/2012 Disposition: Notice To Comply

Date: _____

Application No.	Permit No.	Permit Issue Date	Permit Status	Equipme Category		BCAT/CCAT Description	Application Date	Application Status
529221				555010	BCAT	FACILITY PERMIT AMEND- RECLAIM ONLY	11/08/2011	BANKING/ PLAN GRANTED, NON BILLABLE
529222	G16868	02/17/2012	ACTIVE	288900	BCAT	STORAGE TANK OTHER SOLVENTS N.E.C.	11/08/2011	PERMIT TO OPERATE GRANTED
529223	G16837	02/16/2012	ACTIVE	043901	BCAT	I C E (50-500 HP) EM ELEC GEN-DIESEL	11/08/2011	PERMIT TO OPERATE GRANTED
529224	G16840	02/16/2012	ACTIVE	044901	BCAT	I C E (50-500 HP) EM FIRE FGHT-DIESEL	11/08/2011	PERMIT TO OPERATE GRANTED
529225	G16839	02/16/2012	ACTIVE	044901	BCAT	I C E (50-500 HP) EM FIRE FGHT-DIESEL	11/08/2011	PERMIT TO OPERATE GRANTED
529226	G16845	02/16/2012	ACTIVE	048901	BCAT	I C E (50-500 HP) EMERG OTHER, DIESEL	11/08/2011	PERMIT TO OPERATE GRANTED
529227	G16870	02/17/2012	ACTIVE	231809	BCAT	Crude Oil/Gas/Water Separation >=400 BPD	11/08/2011	PERMIT TO OPERATE GRANTED
529228	G16869	02/17/2012	ACTIVE	294957	BCAT	WASTE WATER TREATING (>50000 GAL/DAY)	11/08/2011	PERMIT TO OPERATE GRANTED
529229	G16853	02/16/2012	ACTIVE	320349	BCAT	NATURAL GAS DRYING	11/08/2011	PERMIT TO OPERATE GRANTED
529230	G16850	02/16/2012	ACTIVE	42	CCAT	SCRUBBER CHEMICAL M.S.	11/08/2011	PERMIT TO OPERATE GRANTED
529231	G16843	02/16/2012	ACTIVE	320709	BCAT	NATURAL GAS STABILIZATION UNIT	11/08/2011	PERMIT TO OPERATE GRANTED
529232	G16849	02/16/2012	ACTIVE	320349	BCAT	NATURAL GAS DRYING	11/08/2011	PERMIT TO OPERATE GRANTED
529233	G16848	02/16/2012	ACTIVE	000533	BCAT	GAS PLANT	11/08/2011	PERMIT TO OPERATE GRANTED
529234	G16847	02/16/2012	INACTIVE	019001	BCAT	HEATER/FURNACE (<5 MMBTU/HR) NAT GAS	11/08/2011	PERMIT TO OPERATE GRANTED
529235	G16846	02/16/2012	ACTIVE	96	CCAT	TAIL GAS INCINERATOR	11/08/2011	PERMIT TO OPERATE GRANTED
529236	G16836	02/16/2012	ACTIVE	80	CCAT	FLARE, OTHER	11/08/2011	PERMIT TO OPERATE GRANTED
529237	G16873	02/17/2012	ACTIVE	19	CCAT	Activated Carbon Adsorber Drum Vent s.s.	11/08/2011	PERMIT TO OPERATE GRANTED
529238	G16874	02/17/2012	ACTIVE	19	CCAT	Activated Carbon Adsorber Drum Vent s.s.	11/08/2011	PERMIT TO OPERATE GRANTED
529239	G16871	02/17/2012	INACTIVE	231106	BCAT	BULK LOAD TERMINAL REC PIPELINE CRUDE	11/08/2011	PERMIT TO OPERATE GRANTED
529240	G16838	02/16/2012	ACTIVE	040901	BCAT	I C E (50-500 HP) N-EM STAT DIESEL	11/08/2011	PERMIT TO OPERATE GRANTED
529242				000992	BCAT	ERC - CHANGE OF TITLE	11/08/2011	BANKING/ PLAN GRANTED, NON BILLABLE
529243				000992	BCAT	ERC - CHANGE OF TITLE	11/08/2011	BANKING/ PLAN GRANTED, NON BILLABLE
529244				000992	BCAT	ERC - CHANGE OF TITLE	11/08/2011	BANKING/ PLAN GRANTED, NON BILLABLE
529245				000992	BCAT	ERC - CHANGE OF TITLE	11/08/2011	BANKING/ PLAN GRANTED, NON BILLABLE
529246				000992	BCAT	ERC - CHANGE OF TITLE	11/08/2011	BANKING/ PLAN GRANTED, NON BILLABLE
529247				000992	BCAT	ERC - CHANGE OF TITLE	11/08/2011	BANKING/ PLAN GRANTED, NON BILLABLE
532242				555010	BCAT	FACILITY PERMIT AMEND- RECLAIM ONLY	01/20/2012	ASSIGNED TO ENGINEER - CLASS III
532245				666049	BCAT	PLAN RULE 1110.2- Inspection & Monitoring Plan	01/20/2012	BANKING/ PLAN GRANTED, NON BILLABLE
533145				555010	BCAT	FACILITY PERMIT AMEND- RECLAIM ONLY	03/06/2012	BANKING/ PLAN GRANTED, NON BILLABLE
533146				011003	BCAT	BOILER (5-20 MMBTU/HR) NAT GAS ONLY	03/06/2012	APPLICATION CHANGED FROM CLASS I - III
534354	G21271	11/01/2012	ACTIVE	013608	BCAT	TURBINE ENGINE (<=50 MW) PROCESS GAS	03/27/2012	PERMIT TO OPERATE GRANTED
534355				555010	BCAT	FACILITY PERMIT AMEND- RECLAIM ONLY	03/27/2012	BANKING/ PLAN GRANTED, NON BILLABLE
538851	G22427	01/15/2013	ACTIVE	019001	BCAT	HEATER/FURNACE (<5 MMBTU/HR) NAT GAS	06/19/2012	PERMIT TO OPERATE GRANTED
538852				555010	BCAT	FACILITY PERMIT AMEND- RECLAIM ONLY	06/19/2012	BANKING/ PLAN GRANTED, NON BILLABLE
555370	G31830	07/02/2014	ACTIVE	043902	BCAT	I C E (>500 HP) EM ELEC GEN DIESEL	08/20/2013	PERMIT TO OPERATE GRANTED

Reviewed By:

SCAQMD Facility Equipment List Report

Run Date: 01/22/2016 10:19 AM

Team: I

Facility: 169754 SO CAL HOLDING, LLC

Contact: DIANA LANG (562) 6243314

Status: Active

Last Inspection: 05/12/2015

On Hold: N

Suspended: N RECLAIM: Y

TS: TS-01 Cycle I RECLAIM/Title V Facility TITLE V: Y

AIRS ID: 0605900025

Assignment: 1324313

MR: 0103

SIC: 1311

Quarter: 0010 - inspect in 3rd quarter, every year

Location Address: 20101 GOLDENWEST ST, HUNTINGTON BEACH 92648-2628 Sector:OH

Mailing Address: 111 W OCEAN BLVD, LONG BEACH 90802 Sector:LB

Instruction:

Inspector: VJ01 VICTOR JUAN JR

Inspection Date: 08/01/2012 Disposition: Notice To Comply

Application No	Permit No.	Permit Issue Date	Permit Status	Equipmer Category		BCAT/CCAT Description	Application Date	Application Status
555402				555010	BCAT	FACILITY PERMIT AMEND- RECLAIM ONLY	08/20/2013	BANKING/ PLAN GRANTED, NON BILLABLE
556388				666116	BCAT	PLAN RULE 1166 (CONTAMINATED SOIL HAND.)	09/20/2013	BANKING/ PLAN GRANTED, NON BILLABLE
557681				666415	BCAT	RULE 1415 PLAN NOTIFICATIONS	10/29/2013	BANKING/ PLAN GRANTED, NON BILLABLE
560466				051504	BCAT	BOILER (>20=50 MMBTU/HR) NG/PG & LPG	02/04/2014	APPLICATION CANCELLED, KEEP ALL FEES
560467				555010	BCAT	FACILITY PERMIT AMEND- RECLAIM ONLY	02/04/2014	APPLICATION CANCELLED, KEEP FILING FEES
567796				320709	BCAT	NATURAL GAS STABILIZATION UNIT	08/26/2014	APPLICATION CANCELLED, KEEP FILING FEES
567798				555010	BCAT	FACILITY PERMIT AMEND- RECLAIM ONLY	08/26/2014	APPLICATION CANCELLED, KEEP FILING FEES
567799				666416	BCAT	RULE 1415.1 PLAN NOTIFICATIONS	08/26/2014	BANKING/ PLAN GRANTED, NON BILLABLE
569440	G34501	02/11/2015	ACTIVE	231106	BCAT	BULK LOAD TERMINAL REC PIPELINE CRUDE	10/23/2014	PERMIT TO OPERATE GRANTED
570166				320709	BCAT	NATURAL GAS STABILIZATION UNIT	12/02/2014	APPLICATION CHANGED FROM CLASS I - III
570167				555010	BCAT	FACILITY PERMIT AMEND- RECLAIM ONLY	12/02/2014	BANKING/ PLAN GRANTED, NON BILLABLE
572641				555003	BCAT	TIERED (1-20 DEVICES) INITIAL TITLE V PERMIT APP	L 02/24/2015	ASSIGNED TO ENGINEER - CLASS III

Inspector:	Date:	Reviewed By:	Date:	Page 2 of 5
------------	-------	--------------	-------	-------------

SCAQMD Facility Equipment List Report

Run Date: 01/22/2016 10:19 AM

Team: I

SIC: 1311

Quarter: 0010 - inspect in 3rd quarter, every year

Facility: 169754 SO CAL HOLDING, LLC

Status: Active

Last Inspection: 05/12/2015

On Hold: N

Suspended: N

TS: TS-01 Cycle I RECLAIM/Title V Facility

Contact: DIANA LANG (562) 6243314

Location Address: 20101 GOLDENWEST ST, HUNTINGTON BEACH 92648-2628 Sector:OH

AIRS ID: 0605900025 RECLAIM: Y TITLE V: Y

Inspector: VJ01 VICTOR JUAN JR Inspection Date: 08/01/2012 Disposition: Notice To Comply

Assignment: 1324313

MR: 0103

Mailing Address: 111 W OCEAN BLVD, LONG BEACH 90802 Sector:LB

Instruction:

BCAT/CCAT Application Application Permit Permit Permit Equipment Application No. No. Issue Date Status Category Description Date Status

Inspector:	Date:	Reviewed By:	Date:	Page 3 of 5
------------	-------	--------------	-------	-------------

SCAQMD Facility Equipment List Report

Run Date: 01/22/2016 10:19 AM

Facility: 169754 SO CAL HOLDING, LLC

Contact: DIANA LANG (562) 6243314

Status: Active

Last Inspection: 05/12/2015

On Hold: N

Suspended: N

TS: TS-01 Cycle I RECLAIM/Title V Facility

RECLAIM: Y AIRS ID: 0605900025 TITLE V: Y

Location Address: 20101 GOLDENWEST ST, HUNTINGTON BEACH 92648-2628 Sector:OH

Mailing Address: 111 W OCEAN BLVD, LONG BEACH 90802 Sector:LB

Instruction:

MR: 0103 Quarter: 0010 - inspect in 3rd quarter, every year

SIC: 1311

Team: I

Assignment: 1324313

Inspector: VJ01 VICTOR JUAN JR

Inspection Date: 08/01/2012 Disposition: Notice To Comply

Application Equipment BCAT/CCAT Application Permit Permit Permit Application Status No. No. Issue Date Status Category Description Date

T	Data	Reviewed By:	Data	Page 4 of 5
Inspector:	Date:	Reviewed by.	Date:	1 age 4 01 3

SCAQMD Facility Equipment List Report

Run Date: 01/22/2016 10:19 AM

Facility: 169754 SO CAL HOLDING, LLC

Contact: DIANA LANG (562) 6243314

Status: Active

Last Inspection: 05/12/2015

On Hold: N

Suspended: N RECLAIM: Y TS: TS-01 Cycle I RECLAIM/Title V Facility

TITLE V: Y AIRS ID: 0605900025

Location Address: 20101 GOLDENWEST ST, HUNTINGTON BEACH 92648-2628 Sector:OH

Mailing Address: 111 W OCEAN BLVD, LONG BEACH 90802 Sector:LB

Instruction:

SIC: 1311

Team: I Quarter: 0010 - inspect in 3rd quarter, every year

MR: 0103 Assignment: 1324313

Inspector: VJ01 VICTOR JUAN JR

Inspection Date: 08/01/2012

Disposition: Notice To Comply

BCAT/CCAT Application Application Permit Permit Permit Equipment Application No. Issue Date Status Category Description Date Status

ROUTING RECORD					
AUG 2 1 2013	FROM	ŢÛ	ACTION		
ADG 2 1 2013	Us	450	I-XRC		
6/25/2014	H SA		Plo RECOMMENDED		
7-1-14	111405	PS	ISS-L PID		
					
REFERENCE TO (THER APO	D RECORD	S INCLUDING VARIANCES		

epolis - PRESCREENES 15

APPL# 555370 1.D.# 169754

OXY USAINC 28101 GOLDENWEST ST HUNTINGTON BEACH EMERGENCY I C E

Date: 08/20/13



South Coast Air Quality Management District

Form 400-A

Application Form for Permit or Plan Approval List only one piece of equipment or process per form.

Mail To: SCAQMD P.O. Box 4944 Diamond Bar, CA 91765-0944

Tel: (909) 396-3385

AGMU				www.aqmd.gov
Section A - Operator Information		_	-	
1. Facility Name (Business Name of Operator to Appear on the Pe	emit):			2. Valid AQMD Facility ID (Available On
OXY USA Inc.			Permit Or Invoice Issued By AQMD):	
3. Owner's Business Name (If different from Business Name of C	operator):			169754
Section B - Equipment Location Address		Section C - Permit	Malling Address	
Equipment Location is:	Various Location ress of initial site.)	5. Permit and Corresp Check here if s	ondence information ame as equipment loca	
20101 Goldenwest St.		111 W. Ocean B	lvd. #800	
Street Address Huntington Beach , CA 926	4R-	Address Long Beach		, CA 90802
City Zip		City		State Zip
Diana Lang Env. Coom	dinator	Diana Lang Contact Name		Env. Coordinator
Contact Name Title (562) 624-3314 (562) 624-3	3224	(562) 624-3314		(562) 624-3224
Phone # Ext. Fax #	<u> </u>	Phone #	Ext.	Fax #
E-Mail: diana_lang@oxy.com		E-Mail: <u>diana_lang</u>	@oxy.com	
Section D - Application Type			<u> </u>	h g
6. The Facility is: O Not in RECLAIM or Title V	(9) In RECLAIM	O In Title V	O In RECLAIM &	Title V Programs
7. Reason for Submitting Application (Select only ONE):				
7a. New Equipment or Process Application	7c. Equipment or F	rocess with an Existin	/Previous Application	n or Permit:
New Construction (Permit to Construct) ([])	Administrative (Change		\
C Equipment On-Site But Not Constructed or Operational		fication		Existing or Previous Permit/Application
C Equipment Operating Without A Permit *	○ Alteration/Modif	fication without Prior App	roval *	If you checked any of the items in
Compliance Plan	Change of Con-			7c., you MUST provide an existing
	1	ondition without Prior Approval * Permit or Application Number:		
C Streamlined Standard Permit	Change of Loca			1
7b. Facility Permits:	4 -	ation without Prior Approv		1
C) Title V Application or Amendment (Also submit Form 500-A1)	() Equipment Ope	rating with an Expired/In	active Permit*	
C RECLAIM Facility Permit Amendment	* A Higher Permit Proc	essing Fee and additional A	nnual Operating Fees (up t	to 3 full years) may apply (Rule 301(c)(1)(D)(i)).
8a. Estimated Start Date of Construction (mm/dd/yyyy): 8b. I	Estimated End Date of C	Construction (mm/dd/yy)	y): 8c. Estimated	Start Date of Operation (mm/dd/yyyy):
9. Description of Equipment or Reason for Compliance Plan	(list applicable rule):	10. For Identical equi		
Emergency IC Engine			eing submitted with t red for each equipment	
11. Are you a Small Business as per AQMD's Rule 102 definiti	lon?	12. Has a Notice of	Violation (NOV) or a N	lotice to
(10 employees or less and total gross receipts are	⊕ No <u>C</u> Yes		en issued for this equ If Yes, provide N	ipment? No Yes
Section E - Facility Business Information				
 What type of business is being conducted at this equipme Oil and Gas Production 	ent location?	14. What is your busi (North American In	ness primary NAICS (dustrial Classification S	
Janagrana photograph at aging aborators	O No	16. Are there any sch 1000 feet of the fa	ools (K-12) within cility property line?	⑥ No
<u></u>				s application are true and correct.
17. Signature of Responsible Official:	18. Title of Responsib VP - Eng and		(This may cause a	· ~ Vnc !
20. Print Name:	21. Date: 0 /10	 -	application proce 22. Do you claim co	nfidentiality of
Mark Kapelke	8//3	12013	data? (If Yes, se	
23. Check List: X Authorized Signature/Date	Form 400-CEQA		l Form(s) (le., Form 4	10-E-xx) 🗵 Fees Enclosed
AGMO SE ONLY SOPPLIES TON TRACKING # CHECK# 103 AM	5130.62	PAYMENT TRAC	KING #	VALIDATION 20 17
DATE APP DATE APP CLASS BASIC REJ I III CONTROL	EQUIPMENT CATEGORY	CODE TRÂN ENGINE		AKEN

© South Coast Air Quality Management District, Form 400-A (2009.04)

(111033)

\$2218.39

13 AUG 20 P2:46

PERMIT PROCESSING

SC NO PERMIT PROCESSING SYSTEM (PPS)

FEE DATA - SUMMARY SHEET

Application No	555370				IRS/SS No:	
Previous Application	No:			Previous Permit No:		
Company Name: Equipment Street: Equipment Desc: Equipment Type: B-CAT NO.: Facility Zone:	OXY USA INC 20101 GOLDENWES I C E (>500 HP) EM I BASIC 043902 18		N BEACH CA S C-CAT NO: Compl. Date:	92648 00 8/28/2	Facility ID: Pee Charged by: Fee Schedule: Public Notice:	В
Evaluation Type,:	PERMIT TO OPERATE	(PO NO PC)			Small B	usiness:
Disposition : A	Approve PO, Recomm	ended by Engineer			Higher Fees fo to Obtain a Identical Perr	Permit:
•	Approve PO, Recomm	ended by Engineer	·	\$0.00	to Obtain a	Permit:
Lead Appl. No Air quality Analysis E.I.R Health Risk Assessn	nent	ended by Engineer		\$0.00 \$0.00	to Obtain a Identical Perr	Permit:
Lead Appl. No Air quality Analysis E.I.R	nent ration Fee		·	\$0.00	Filing Fee Paid: Permit Processing Fee Paid: Permit Processing Fee	Permit:
Lead Appl. No Air quality Analysis E.I.R Health Risk Assessn Public Notice Prepar Public Notice Public Expedited Processin	nent ration Fee ation Fee	ended by Engineer	0.00	\$0.00 \$0.00 \$0.00 \$0.00 \$0.00	Filing Fee Paid: Permit Processing Fee Paid: Permit Processing Fee Calculated*: Permit Processing	Permit:
Air quality Analysis E.I.R Health Risk Assessn Public Notice Prepai Public Notice Public Expedited Processin Source Test Review	nent ration Fee ation Fee		0.00	\$0.00 \$0.00 \$0.00 \$0.00 \$0.00	Filing Fee Paid: Permit Processing Fee Paid: Permit Processing Fee Calculated*: Permit Processing	Permit:
Lead Appl. No Air quality Analysis E.I.R Health Risk Assessn Public Notice Prepar	nent ration Fee ation Fee	Hours:		\$0.00 \$0.00 \$0.00 \$0.00 \$0.00	Filing Fee Paid: Permit Processing Fee Paid: Permit Processing Fee Calculated*: Permit Processing	Permit:
Air quality Analysis E.I.R Health Risk Assessn Public Notice Prepair Public Notice Public Expedited Processin Source Test Review	nent ration Fee ation Fee	Hours: Hours:	0.00	\$0.00 \$0.00 \$0.00 \$0.00 \$0.00	Filing Fee Paid: Permit Processing Fee Paid: Permit Processing Fee Calculated*: Permit Processing	Permit:

COMMENTS:

RECOMMENDED BY: HAMILTON A STODDARD DATE: 06/21/2014 REVIEWED BY:

^{*} ADJUSTED FOR SMALL BUSINESS, IDENTICAL EQUIPMENT AND P/O NO P/C PENALTY

June 27, 2014

Mark Kapelpke
Vice President, Engineering and Operations
OXY USA, Inc
111 West Ocean Blvd. #800
Long Beach, CA 90802

Dear Mr. Kapelpke,

Attached is your revised RECLAIM Facility Permit for the facility that is located at 20101 Goldenwest Street, Huntington Beach, CA. The Facility Permit reflects your request to add an emergeny ice/generator to the Platform Emmy site.

The following applications are approved for permit to operate and are summarized in the table below.

Application	Equipment Description	Device	Process	System	Section
number		number	number	l	
555370	Emergency ICE/Generator	D228		2	D
555402	RECLAIM Amendment				

Please review the attached Section D of the Facility Permit carefully. Any questions pertaining to items in your Facility Permit should be directed to Mr. Hamilton Stoddard at (909) 396-2482.

Sincerely,

William C. Thompson, P.E.

Senior Enforcement Manager Engineering and Compliance

WT:MH:hs



Title Page Facility ID Revision #:

Date

169754 6

June 27, 2014

FACILITY PERMIT TO OPERATE

OXY USA INC 20101 GOLDENWEST ST HUNTINGTON BEACH, CA 92648

NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE—THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Barry R. Wallerstein, D. Env. EXECUTIVE OFFICER

Mohsen Nazemi, P.E. Deputy Executive Officer Engineering & Compliance



Table of Content

Facility ID: Revision #:

169754

ate

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
Α	Facility Information	0	02/17/2012
В	RECLAIM Annual Emission Allocation	1,	02/11/2013
C	Facility Plot Plan	TO BE DEVE	LOPED
D	Facility Description and Equipment Specific Conditions	3	06/27/2014
E	Administrative Conditions	0	02/17/2012
F	RECLAIM Monitoring and Source Testing Requirements	0	02/17/2012
·G .	Recordkeeping and Reporting Requirements for RECLAIM Sources	0	02/17/2012
Н	Permit To Construct and Temporary Permit to Operate	3	12/13/2012
I	Compliance Plans & Schedules	0	02/17/2012
J.	Air Toxics	0	02/17/2012
Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	0	02/17/2012
В	Rule Emission Limits	0	02/17/2012



Section D	Page
Facility ID.	169754
Revision#	3
Date ⁻	June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 1: CRUDE OIL/GA	AS PROI	DUCTION			
System 1: CRUDE OIL/GA	AS/WAT	ER SEPARA	TION		
VESSEL, V-104, FREE WATER OCK OUT, LENGTH: 40 FT; DIAMETER: 10 FT A/N: 529227	DI				
VESSEL, V-107, FREE WATER KNOCK OUT, LENGTH: 60 FT; DIAMETER: 12 FT A/N: 529227	D2				
VESSEL, V-108, FREE WATER KNOCK OUT, LENGTH: 60 FT; DIAMETER: 12 FT A/N: 529227	D3				
VESSEL, V-109, FREE WATER KNOCK OUT, LENGTH: 60 FT; DIAMETER: 12 FT A/N: 529227	D4				
OCK OUT, LENGTH. 60 FT; DIAMETER: 12 FT A/N: 529227	D5				
VESSEL, V-111, FREE WATER KNOCK OUT, LENGTH: 60 FT; DIAMETER: 12 FT A/N: 529227	D6				
VESSEL, V-114, FREEWATER KNOCKOUT, LENGTH: 60 FT; DIAMETER: 12 FT A/N: 529227	D7				
VESSEL, V-115, FREE WATER KNOCK OUT, LENGTH: 60 FT; DIAMETER: 12 FT A/N: 529227	D8				

*	(I)(IA)(IB)	Denotes RECLAIM emission factor	(2) (2A) (2B)	Denotes RECLAIM emission rate
	(3)	Denotes RECLAIM concentration limit	(4)	Denotes BACT emission limit
	(5) (5A) (5B)	Denotes command and control emission limit	(6)	Denotes air toxic control rule limi

toxic control rule limit

Denotes NSR applicability limit (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.) (7) See App B for Emission Limits (10)See section J for NESHAP/MACT requirements

Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



Section D Facility ID: Revision #:

Date:

Page: 169754

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 1: CRUDE OIL/GA	AS PROI	DUCTION		मैन्डिक्ट वेड क्या । वेट । व	
TANK, HOLDING, T-101, CRUDE OIL, VENTED TO VAPOR RECOVERY COMPRESSOR, 2000 BBL; DIAMETER: 29 FT 9 IN; HEIGHT: 16 FT AN: 529227	DIO				E57.1, E127.1, H23.5
TANK, HOLDING, T-102, CRUDE OIL, VENTED TO VAPOR RECOVERY COMPRESSOR, 2000 BBL; DIAMETER: 29 FT 9 IN; HEIGHT: 16 FT A/N: 529227	DII				E57.1, E127.1, H23.5
TANK, HOLDING, T-103, WET OIL DIVERT, VENTED TO VAPOR RECOVERY COMPRESSOR, 2000	D12				E57.1, E127.1, H23.5
BBL; DIAMETER: 29 FT 9 IN; HEIGHT: 16 FT A/N: 529227					
TANK, HOLDING, T-104, WET OIL DIVERT, VENTED TO VAPOR RECOVERY COMPRESSOR, 2000 BBL; DIAMETER: 29 FT 9 IN; HEIGHT: 16 FT A/N: 529227	D13				E57.1, E127.1, H23.5
TANK, HOLDING, T-318, SKIM OIL, VENTED TO VAPOR RECOVERY COMPRESSOR, 5000 BBL; DIAMETER: 38 FT 8 IN; HEIGHT: 24 FT A/N: 529227	D15				E57.1, E127.1, H23.5
VESSEL, SEPARATOR, V-150, RELIEF KNOCKOUT DRUM, LENGTH: 15 FT ; DIAMETER: 8 FT A/N: 529227	D41			>	H23.3

•	(1) (1A) (1B) Denotes RECL	.AIM emission factor

(3) Denotes RECLAIM concentration limit

(5) (5A) (5B) Denotes command and control emission limit

See App B for Emission Limits

Denotes NSR applicability limit

(9)

(2) (2A) (2B) Denotes RECLAIM emission rate

(4) Denotes BACT emission limit

Denotes air toxic control rule limit

(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)

(10)See section J for NESHAP/MACT requirements

Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



Section D Page: Facility ID: Revision #:

June 27, 2014

169754

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 1: CRUDE OIL/GA	S PROI	UCTION	ा हेर्नुकार कुला कुला कुला है।	7.1.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.	:
TANK, T-317, SURGE/SKIM OIL TANK, SKIM OIL/WASTEWATER, ENTED TO VAPOR RECOVERY OMPRESSOR, 5000 BBL; DIAMETER: 38 FT 8 IN; HEIGHT: 24 FT A/N: 529227	D14				E57.1, E127.1, H23.5
System 2: WASTE WATE	R TREA	TMENT			<u> </u>
FLOATATION UNIT, WEMCO, T-337, VENTED TO VAPOR RECOVERY COMPRESSOR, 550 BBL A/N: 529228	D23				E127.1, H23.4
FLOATATION UNIT, WEMCO, T-338, VENTED TO VAPOR RECOVERY-COMPRESSOR; -550-BBL A/N: 529228	D24				E127.1, H23.4
TANK, SURGE, T-350, INJECTION WATER, VENTED TO VAPOR COVERY COMPRESSOR, 5000 BBL; DIAMETER: 38 FT 8 IN; HEIGHT: 24 FT A/N: 529228	D215	į			E57.1, E127.1, H23.5
TANK, SURGE, T-360, RAINWATER, 2000 BBL; DIAMETER: 29 FT 9 IN; HEIGHT: 16 FT A/N: 529228	D34				
OIL WATER SEPARATOR, T-339, 1000 BBL CAPACITY,, VENTED TO THE VAPOR RECOVERY COMPRESSOR, LENGTH: 60 FT; DIAMETER: 12 FT A/N: 529228	D36				E57.1, E127.1, H23.7

•	(1) (1A) (1B) Denotes	RECLAIM emission factor

Denotes RECLAIM concentration limit

(5) (5A) (5B) Denotes command and control emission limit

See App B for Emission Limits

(7)

Denotes NSR applicability limit (9)

(2) (2A) (2B) Denotes RECLAIM emission rate

Denotes BACT emission limit

Denotes air toxic control rule limit (6)

(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)

(10)See section J for NESHAP/MACT requirements

Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



Page: Section D 169754 Facility ID: Revision #: June 27, 2014 Date:

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 1: CRUDE OIL/GA	AS PROI	DUCTION 🔠	Compared the designation of	A CAMPAGE AND STATE	
PIT, NO. 3, COVERED, SKIM OIL, VENTED TO THE VAPOR RECOVERY COMPRESSOR A/N: 529228	D40				E57.1, H23.4
TANK, HOLDING, T-340, OILY WATER, VACUUM TRUCK OFFLOADING, VENTED TO VAPOR RECOVERY COMPRESSOR, 180 BBL; DIAMETER: 12 FT; HEIGHT: 15 FT 1 IN A/N: 529228	D216				E57.1, E127.1, H23.3
TANK, HOLDING, T-341, OILY WATER, VACUUM TRUCK OFFLOADING, VENTED TO VAPOR RECOVERY COMPRESSOR, 180 BBL;	D217				E57.1, E127.1, H23.3
DIAMETER: 12 FT; HEIGHT: 15 FT 1 IN A/N: 529228					
TANK, HOLDING, T-342, OILY WATER, VENTED TO VAPOR RECOVERY COMPRESSOR, 1000 BBL; DIAMETER: 29 FT 9 IN; HEIGHT: 8 FT A/N: 529228	D218				E57.1, E127.1, H23.5
TANK, HOLDING, T-343, OILY WATER, VENTED TO VAPOR RECOVERY COMPRESSOR, 1000 BBL; DIAMETER: 29 FT 9 IN; HEIGHT: 8 FT A/N: 529228	D219				E57.1, E127.1, H23.5

*	(I) (IA) (IB)	Denotes RECLAIM	emission factor
---	---------------	-----------------	-----------------

(3) Denotes RECLAIM concentration limit

(5) (5A) (5B) Denotes command and control emission limit

Denotes NSR applicability limit (9)See App B for Emission Limits

(2) (2A) (2B) Denotes RECLAIM emission rate

Denotes BACT emission limit (4)

Denotes air toxic control rule limit

(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.) (10)See section J for NESHAP/MACT requirements

Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



Section D Facility ID: Revision #:

169754

Date:

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 1: CRUDE OIL/G	AS PRO	DUCTION			
TANK, HOLDING, T-345, PROCESS DRAIN/RAIN WATER, SUMP RAIN, VENTED TO VAPORECOVERY COMPRESSOR, 53 BBL; WIDTH: 5 FT; HEIGHT: 5 FT; LENGTH: 12 FT A/N: 529228	D220				E57.1, E127.1
System 3: GAS GATHER	ING	·, · · · · · · · · · · · · · · · · · ·		. <u></u>	
SCRUBBER, WET GAS, V-323, LENGTH: 10 FT; DIAMETER: 4 FT 2 IN A/N: 529229	D120				
GAS SEPARATOR, V-100, (NORTH BOLSA), VENTING TO THE HUNTINGTON-BEACH GAS PLANT, HEIGHT: 10 FT; DIAMETER: 4 FT A/N: 529229	D19				
SCRUBBER, SOUTH BOLSA, EIGHT: 8 FT; DIAMETER: 3 FT JA/N: 529229	D145				
SCRUBBER, LEASE 425 A/N: 529229	D147			_	
SCRUBBER, LEASE 426 A/N: 529229	D148				
SCRUBBER, HIGH PRESSURE, HEIGHT: 8 FT; DIAMETER: 4 FT A/N: 529229	D128				
SCRUBBER, LOW PRESSURE, HEIGHT: 12 FT; DIAMETER: 5 FT A/N: 529229	D130				

*	(1)	(1A)	(1B)	Denotes	RECLAI	M	emission	factor
---	-----	------	------	---------	--------	---	----------	--------

Denotes RECLAIM concentration limit (3)

(5) (5A) (5B) Denotes command and control emission limit

See App B for Emission Limits

(7)

(9)

Denotes NSR applicability limit

(2) (2A) (2B) Denotes RECLAIM emission rate

Denotes BACT emission limit (4)

Denotes air toxic control rule limit (6)

(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.) See section J for NESHAP/MACT requirements

Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



Section D	Page: 6
Facility ID:	169754
Revision #:	3
Date:	June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions [*] And Requirements	Conditions
Process 1: CRUDE OIL/GA	S PROI	DUCTION			
SCRUBBER, SUCTION, EMMY HIGH PRESSURE GAS, HEIGHT: 6 FT; DIAMETER: 2 FT 6 IN A/N: 529229	D170				
SCRUBBER, DISCHARGE, EMMY HIGH PRESSURE GAS, HEIGHT: 6 FT ; DIAMETER: 1 FT 4 IN A/N: 529229	D171				
SCRUBBER, EMMY LOW PRESSURE CASING GAS, HEIGHT: 12 FT; DIAMETER: 5 FT A/N: 529229	D221				
System 4: GAS DESULFU	RIZATI	ON (STRETF	ORD UNIT)		
SCRUBBER, V-I, WET GAS, HEIGHT: 13-FT 7-IN; DIAMETER: 6-FT A/N: 529230	D42				
ABSORBER, V-2 (STRETFORD UNIT FOR H2S ABSORPTION), HEIGHT: 25 FT; DIAMETER: 3 FT 6 IN A/N: 529230	D20				
ABSORBER, V-3 (STRETFORD UNIT FOR H2S ABSORPTION), HEIGHT: 25 FT; DIAMETER: 3 FT 6 IN A/N: 529230	D43				
ABSORBER, V-5 (STRETFORD UNIT FOR H2S ABSORPTION), (STANDBY), HEIGHT: 25 FT; DIAMETER: 3 FT 6 IN A/N: 529230	D45				
SCRUBBER, V-4, HEIGHT: 13 FT 7 IN; DIAMETER: 6 FT A/N: 529230	D46				

(1)(IA)(IB)	Denotes RECLAIM emission factor	(2)(2A)(2B)	Denotes RECLAIM emission rate
(3)	Denotes RECLAIM concentration limit	(4)	Denotes BACT emission limit
(5) (5A) (5B)	Denotes command and control emission limit	(6)	Denotes air toxic control rule limit
(7)	Denotes NSR applicability limit	(8) (8A) (8B)	Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9)	See App B for Emission Limits	(10)	See section J for NESHAP/MACT requirements

^{**} Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



Section D Facility ID: Revision #:

Date:

Page: 7 169754 3

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected	RECLAIM Source Type/	Emissions* And Requirements	Conditions
			Monitoring Unit		
Process 1: CRUDE OIL/G	AS PROI	DUCTION		FINE PROPERTY OF THE PARTY OF T	,
PROCESS TANK, T-2, REACTION TANK, HEIGHT: 9 FT 6 IN; PIAMETER: 12 FT /N: 529230	D47				
PROCESS TANK, UNHEATED, BACKUP, SULFUR SLURRY, OPEN TOP, 470 BBL; WIDTH: 8 FT; HEIGHT: 11 FT; LENGTH: 30 FT A/N: 529230	D172				
PROCESS TANK, T-3, OXIDIZER TANK, HEIGHT: 20 FT 9 IN; DIAMETER: 12 FT A/N: 529230	D48				
PROCESS TANK, UNHEATED, T-1, SULFUR-SLURRY-HOLDING-TANK,— HEIGHT: 8 FT; DIAMETER: 8 FT A/N: 529230	D83				
PROCESS TANK, MIXING TANK, SIGHT: 4 FT; DIAMETER: 4 FT	D85				
STORAGE TANK, STRETFORD SOLUTION, HEIGHT: 10 FT; DIAMETER: 10 FT A/N: 529230	D86				
System 6: NATURAL GA	S STABI	LIZATION			S13.1, S13.2
KNOCK OUT POT, V-601, COMPRESSOR SUCTION A/N: 529231	D64				
KNOCK OUT POT, V-602, COMPRESSOR 1ST STAGE DISCHARGE A/N: 529231	D65				

•	(I)(IA)(IB)	Denotes RECLAIM	emission factor
---	-------------	-----------------	-----------------

(3) Denotes RECLAIM concentration limit

(5) (5A) (5B) Denotes command and control emission limit

(7) Denotes NSR applicability limit

(9) See App B for Emission Limits

(2) (2A) (2B) Denotes RECLAIM emission rate

(4) Denotes BACT emission limit

(6) Denotes air toxic control rule limit

(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)

(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	D	Connected	RECLAIM	Emissions*	Conditions
	No.	То	Source Type/	And Requirements	
			Monitoring		
	L		Unit		
Process 1: CRUDE OIL/GAS	S PROI	DUCTION	The first of the second section	全国的	
KNOCK OUT POT, V-606, COMPRESSOR 2ND STAGE DISCHARGE A/N: 529231	D133				
VESSEL, V-604, H2S REMOVAL TOWER (PACKED WITH SULFATREAT OR EQUIVALENT MATERIAL), HEIGHT: 20 FT; DIAMETER: 6 FT A/N: 529231	D80				
VESSEL, V-605, H2S REMOVAL TOWER (PACKED WITH SULFATREAT OR EQUIVALENT MATERIAL), HEIGHT: 20 FT; DIAMETER: 6 FT	D101				
A/N: 529231	D#0	<u> </u>			
VESSEL, SEPARATOR, V-603, GLYCOL, LENGTH: 8 FT; DIAMETER: 3 FT A/N: 529231	D79				
KNOCK OUT POT, V-607, LIQUID KNOCKOUT A/N: 529231	D134				
VESSEL, V-701, GLYCOL FLASH DRUM A/N: 529231	D136				
VESSEL, V-801, REFRIGERANT COMPRESSOR SUCTION DRUM A/N: 529231	D137				
VESSEL, V-802, REFRIGERANT SURGE DRUM A/N: 529231	D138				

•	(1) (1A) (1B)	Denotes RECLAIM emission factor	(2) (2A) (2B) Denotes RECLAIM emission rate		
	(3)	Denotes RECLAIM concentration limit	(4)	Denotes BACT emission limit	
	(5) (5A) (5B)	Denotes command and control emission limit	(6)	Denotes air toxic control rule limit	
	(7)	Denotes NSR applicability limit	(8) (8A) (8B)	Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)	
	(9)	See App B for Emission Limits	(10)	See section J for NESHAP/MACT requirements	

^{**} Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



Section D Facility ID: Revision #:

Page: 169754

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID	Connected	RECLAIM	Emissions*	Conditions
	No.	То	Source Type/ Monitoring Unit	And Requirements	
Process 1: CRUDE OIL/GA	AS PROI	DUCTION			
VESSEL, V-803, GAS/LUBE OIL SEPARATOR '/N: 529231	D139				
STORAGE TANK, T-703, GLYCOL STORAGE A/N: 529231	D141				
SUMP, T-704, GLYCOL COLLECTION A/N: 529231	D142				
SUMP, T-705, OPEN DRAIN A/N: 529231	D143				
COLUMN, GLYCOL STILL, HEIGHT: 8 FT; DIAMETER: 1 FT A/N: 529231	D173				
HEAT EXCHANGER, COMPRESSOR IST STAGE DISCHARGE COOLER,	D174				
E-601 A/N: 529231					
"EAT EXCHANGER, COMPRESSOR ID STAGE DISCHARGE COOLER, E-602, AIR COOLED A/N: 529231	D175				
HEAT EXCHANGER, GAS TO GAS, E-603 A/N: 529231	D176				
HEAT EXCHANGER, GAS CHILLER, E-604 A/N: 529231	D177				
HEAT EXCHANGER, RICH-LEAN GLYCOL, E-701 A/N: 529231	D178				

+	(1)(1	A) (IE) Denotes	RECLAIM	emission	factor
---	-------	--------	-----------	---------	----------	--------

Denotes RECLAIM concentration limit

(5) (5A) (5B) Denotes command and control emission limit

Denotes NSR applicability limit

(9)

See App B for Emission Limits

(2) (2A) (2B) Denotes RECLAIM emission rate

(4) Denotes BACT emission limit

Denotes air toxic control rule limit

(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)

(10)See section J for NESHAP/MACT requirements

Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



Section D
Facility ID:
Revision #:
Date:

169754 3

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID	Connected	RECLAIM	Emissions*	Conditions
	No.	To	Source Type/	And Requirements	
		le le	Monitoring	•	
			Unit		
Process 1: CRUDE OIL/GA	S PROI	DUCTION	The property of		
REGENERATOR, GLYCOL REGENERATOR, E-702, ELECTRICAL, 142 KW A/N: 529231	D179				
HEAT EXCHANGER, GLYCOL REGENERATOR OFF-GAS COOLER, E-703, AIR COOLED A/N: 529231	D180				
HEAT EXCHANGER, REFRIGERANT CONDENSER, E-801, AIR COOLED A/N: 529231	D181				
HEAT EXCHANGER, LUBE OIL COOLER, E-802, AIR COOLED A/N: 529231	D182				
FILTER, F-901, INLET GAS	D183				
COALESCING FILTER, HEIGHT: 4 FT ; DIAMETER: 2 FT A/N: 529231					
TOWER, T-901, GLYCOL CONTACT, PACKED COLUMN WITH INTEGRAL BOTTOM SCRUBBER/WIRE MESH SCREEN, HEIGHT: 29 FT; DIAMETER: 1 FT 2 IN A/N: 529231	D184				
	D105	-		<u> </u>	
COLUMN, T-902, GLYCOL REGENERATION A/N: 529231	D185				
DRUM, V-900, RICH GLYCOL A/N: 529231	D186				

(I) (IA)) (1B) Denotes RECLAIM emission factor	(2) (2A) (2B) Denotes RECLAIM emission rate			
(3)	Denotes RECLAIM concentration limit	(4)	Denotes BACT emission limit		
(5) (5A)) (5B) Denotes command and control emission limit	(6)	Denotes air toxic control rule limit		
(7)	Denotes NSR applicability limit	(8) (8A) (8B)	Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.		
(9)	See Ann B for Emission Limits	(10)	See section I for NESHAP/MACT requirements		

^{**} Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



Section D Facility ID: Revision #:

Date:

Page: 11 169754 3

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	Ш	Connected	RECLAIM	Emissions*	Conditions
	No.	To	Source Type/	And Requirements	
			Monitoring Unit		
Process 1: CRUDE OIL/GA	S PROI	DUCTION	Unit	Land of the state	-
FILTER, F-902, RICH GLYCOL PARTICULATE FILTER, HEIGHT: 4 T; DIAMETER: 2 FT /N: 529231	D187				
FILTER, F-903, RICH GLYCOL CARBON FILTER, HEIGHT: 4 FT; DIAMETER: 2 FT A/N: 529231	D188				
HEAT EXCHANGER, LEAN-RICH GLYCOL EXCHANGER, E-901 A/N: 529231	D189				
REGENERATOR, GLYCOL RE-BOILER, V-901, ELECTRICAL, 40 KW A/N:-529231	D190				
COLUMN, T-903, GLYCOL STRIPING, HEIGHT: 8 FT; DIAMETER: 1 FT A/N: 529231	D191				
UM, V-902, GLYCOLSURGE A/N: 529231	D192				
HEAT EXCHANGER, LEAN GLYCOL FIN-FAN COOLER, E-900, AIR COOLED A/N: 529231	D193				
DRUM, V-904, VAPOR RECOVERY KNOCKOUT, VENTED TO VAPOR RECOVERY SYSTEM A/N: 529231	D194				E57.1
	DEHYI	PRATION UN	NT (Platform Emr	ny Gas)	\$13.1, \$13.2
FILTER, F-900, INLET GAS COALESCING FILTER, HEIGHT: 4 FT ; DIAMETER: 2 FT A/N: 529232	D195				

*	(1) (1A) (1B)	Denotes RECL	.AIM emission factor	

- (3) Denotes RECLAIM concentration limit
- (5) (5A) (5B) Denotes command and control emission limit
- (7) Denotes NSR applicability limit
- (9) See App B for Emission Limits

- (2) (2A) (2B) Denotes RECLAIM emission rate
- (4) Denotes BACT emission limit
- (6) Denotes air toxic control rule limit
- (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
- (10) See section J for NESHAP/MACT requirements
- ** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



 Section D
 Page: 12

 Facility ID:
 169754

 Revision #:
 3

 Date:
 June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/	Emissions* And Requirements	Conditions
			Monitoring Unit	And Requirements	
Process 1: CRUDE OIL/G	AS PRO	DUCTION	心思维·朗·纳特·奇	· 中国 · · · · · · · · · · · · · · · · · ·	r!-
TOWER, T-900, GLYCOL CONTACT, PACKED COLUMN WITH AN INTEGRAL BOTTOM SCRUBBER AND WIRE MESH SCREEN, HEIGHT: 29 FT; DIAMETER: 1 FT 2 IN A/N: 529232	D196				
FILTER, F-904, EMMY GAS COALESCING FILTER, HEIGHT: 8 FT ; DIAMETER: 2 FT A/N: 529232	D197				
System 8: FUGITIVE EM	ISSION	DEVICES .		e de la companya de la companya de la companya de la companya de la companya de la companya de la companya de	
FUGITIVE EMISSIONS, PUMPS A/N: 529227	D76				H23.1
FUGITIVE EMISSIONS, COMPRESSORS	D77				H23.1
A/N: 529229 FUGITIVE EMISSIONS, VALVES A/N: 529227	D78				H23.1
FUGITIVE EMISSIONS, FLANGES A/N: 529227	D108				H23.1
FUGITIVE EMISSIONS, DRAINS A/N: 529228	D112				H23.3
FUGITIVE EMISSIONS, PRV A/N: 529227	D113				H23.1
System 9: Di-Ethanol Amir	ne Unit (CO2 Removal)		
FILTER, F-1001, INLET GAS COALESCING FILTER, WITH PRV SET AT 350 PSIG, VENTING TO APC SYSTEM, HEIGHT: 6 FT 9 IN; DIAMETER: 9 IN A/N: 529233	D199	D131			

*	(1) (1A) (1B)	Denotes RECLAIM emission factor	(2) (2A) (2B)	Denotes RECLAIM emission rate
	(3)	Denotes RECLAIM concentration limit	(4)	Denotes BACT emission limit
	(5) (5A) (5B)	Denotes command and control emission limit	(6)	Denotes air toxic control rule limit
	(7)	Denotes NSR applicability limit	(8) (8A) (8B)	Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)

(7) Denotes NSR applicability limit (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc. (9) See App B for Emission Limits (10) See section J for NESHAP/MACT requirements

^{**} Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



Section D Facility ID: Revision #:

Page: 13 169754 3

Date:

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 1: CRUDE OIL/GA	AS PRO	DUCTION 🥬		to decimal program of the contract of the cont	
TOWER, T-1006, AMINE CONTACTOR, PACKED COLUMN, VITH PRV SET AT 350 PSIG, VENTING TO APC SYSTEM, HEIGHT: 20 FT; DIAMETER: 2 FT A/N: 529233	D201	D131			D12.2, D90.1
VESSEL, V-1003, AMINE FLASH TANK, WITH PRV SET AT 100 PSIG, VENTING TO APC SYSTEM, HEIGHT: 10 FT; DIAMETER: 3 FT 6 IN A/N: 529233	D204				D12.8, D90.2
FILTER, F-1003, PARTICULATE FILTER, WITH PRV SET AT 100 PSIG, VENTING TO CLOSED DRAIN HEADER, HEIGHT: 4 FT; DIAMETER: 3 FT	D205				
A/N: 529233					
FILTER, F-1004, CHARCOAL FILTER ',030 LBS CHARCOAL), WITH PRV SET AT 250 PSIG, VENTING TO CLOSED DRAIN HEADER, HEIGHT: 8 FT; DIAMETER: 2 FT 6 IN A/N: 529233	D206				
HEAT EXCHANGER, E-1002, LEAN/RICH AMINE EXCHANGER, SHELL AND TUBE TYPE, 0.74 MMBTU/HR A/N: 529233	D207				
TOWER, T-1007, AMINE REGENERATOR, WITH PRV SET AT 50 PSIG, VENTING TO ATMOSPHERE, HEIGHT: 28 FT; DIAMETER: 2 FT A/N: 529233	D208				

•	(1)(1A	(IB) Denotes	RECLAIM	emission	factor
---	--------	-----	-----------	---------	----------	--------

(3) Denotes RECLAIM concentration limit

(5) (5A) (5B) Denotes command and control emission limit

(7) Denotes NSR applicability limit

(9) See App B for Emission Limits

(2) (2A) (2B) Denotes RECLAIM emission rate

(4) Denotes BACT emission limit

(6) Denotes air toxic control rule limit

(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)

(10) See section J for NESHAP/MACT requirements

^{**} Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



Section D
Facility ID:
Revision #:

Page: 14 169754 3

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	m	Connected	RECLAIM	Emissions*	Conditions
	No.	То	Source Type/ Monitoring Unit	And Requirements	
Process 1: CRUDE OIL/GA	AS PRO	DUCTION	dayin si hakiyi		
HEATER, V-1007, AMINE RE-BOILER, NATURAL GAS, MAXON, MODEL XPO3PB41B3NNY, 2.7 MMBTU/HR A/N: 538851	D227		NOX: PROCESS UNIT**	CO: 50 PPMV NATURAL GAS (4); NOX: 12 PPMV NATURAL GAS (4); NOX: 38.46 LBS/MMSCF NATURAL GAS (1)	A195.8, A195.9, E448.4, I297.2
HEAT EXCHANGER, E-1003, AMINE REGENERATOR OVERHEAD CONDENSER, AIR COOLED, 0.68 MMBTU/HR, VENTING ACID GAS TO V-1005 A/N: 529233	D210	D211			
VESSEL, V-1005, REGENERATOR OVERHEAD REFLUX ACCUMULATOR, HEIGHT: 7 FT; DIAMETER: I FT I N	D211	D210			D12.4
HEAT EXCHANGER, E-1001, LEAN AMINE COOLER, AIR COOLED, 0.95 MMBTU/HR A/N: 529233	D212				
OXIDIZER, THERMAL, HT-1000, NATURAL GAS, F. I. COMBUSTION SYSTEMS, MODEL NO. FIRECAT #2.2.1, 2 MMBTU/HR A/N: 529233	C213		NOX: PROCESS UNIT**	NOX: 130 LBS/MMSCF NATURAL GAS (I)	A195.3, C6.3, C8.4, 1297.3
TANK, T-1000, AMINE MAKE-UP SOLUTION, AMINE, CAPACITY 1000 GALLONS, WITH PRV VENTING TO ATMOSPHERE A/N: 529233	D214				
Process 2: INTERNAL CO	MBUST	ION			
System 1: EMERGENCY I	ENGINE	S			

٠	(1)(IA)	(1B) Denotes	RECLAIM	emission	factor
---	---------	--------------	---------	----------	--------

(3)

Denotes RECLAIM concentration limit

(5) (5A) (5B) Denotes command and control emission limit

(7) Denotes NSR applicability limit

See App B for Emission Limits

(2) (2A) (2B) Denotes RECLAIM emission rate

(4) Denotes BACT emission limit

(6) Denotes air toxic control rule limit

(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)

(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



Section D Page: 15
Facility ID: 169754
Revision #: 3
Date: June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Condition
Process 2: INTERNAL CO	MBUST	ION	和海岸	用为外部	
INTERNAL COMBUSTION ENGINE, EMERGENCY FIRE, DIESEL FUEL, CLARKE DETROIT DIESEL, MODEL DFP-4AT, WITH TURBOCHARGER, 235 BHP WITH A/N: 529224	D149		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1)	C1.2, D12.1, D135.1
PUMP, FIRE WATER System 2: PLATFORM E	MMY- E	NGINES			
INTERNAL COMBUSTION ENGINE, EMERGENCY FIRE, DIESEL FUEL, DETROIT DIESEL, MODEL 671RC, 241 HP WITH A/N: 529225	D44		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1)	C1.2, D12.1, D135.1
PUMP, FIRE WATER					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, AUKESHA, MODEL F674DS, 300 HP WITH A/N: 529223	D103		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1)	D12.1, D135.1, E116.1, E162.1
GENERATOR INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CUMMINS, MODEL QST30-G5-NR2, 1490 BHP WITH A/N:	D228		NOX: PROCESS UNIT**	CO: 2.6 GRAM/BHP-HR DIESEL (4); NOX: 469 LBS/1000 GAL DIESEL (1); NOX + ROG: 4.8 GRAM/BHP-HR DIESEL (4); PM: 0.15 GRAM/BHP-HR DIESEL (4)	C1.6, D12.9, E116.1, H23.11, K67.1
GENERATOR					

*	(1)(1A)	(1B)	Denotes	RECLAIM	emission facto	ī
---	---------	------	---------	---------	----------------	---

(3) Denotes RECLAIM concentration limit

(5) (5A) (5B) Denotes command and control emission limit

(7) Denotes NSR applicability limit

(9) See App B for Emission Limits

(2) (2A) (2B) Denotes RECLAIM emission rate

(4) Denotes BACT emission limit

(6) Denotes air toxic control rule limit

(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)

(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



Section D Page: 169754 Facility ID: Revision #:

June 27, 2014 Date:

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: INTERNAL CO	DMBUST	ION	the second	The state of the s	
INTERNAL COMBUSTION ENGINE, DIESEL FUEL, DEUTZ, MODEL TCD2012L042V, DRIVING A CRANE, 131 HP A/N: 529240	D223		NOX: PROCESS UNIT**	CO: 3.73 GRAM/BHP-HR DIESEL (4); CO: 2000 PPMV (5) ; NOX: 116.3 LBS/1000 GAL DIESEL (1); NOX + ROG: 2.98 GRAM/BHP-HR DIESEL (4); PM: 0.22 GRAM/BHP-HR DIESEL (4); ROG: 250 PPMV (5)	C1.1, D12.1, H23.10
System 3: EMERGENCY	INSTRU	MENT AIR O	COMPRESSOR		
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CUMMINS, MODEL 6BTA5.9, INSTRUMENT AIR COMPRESSOR DRIVER, WITH AFTERCOOLER, TURBOCHARGER, 174 HP WITH A/N: 529226	D168		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR DIESEL (4); NOX: 6.9 GRAM/BHP-HR DIESEL (4); NOX: 469 LBS/1000 GAL DIESEL (1); PM10: 0.38 GRAM/BHP-HR DIESEL (4); VOC: I GRAM/BHP-HR DIESEL (4)	C1.6, D12.1, D135.1, E116.1, E162.1
COMPRESSOR, INSTRUMENT AIR					
System 4: POWER GENE	RATION	[-	
GAS TURBINE, 1.0 MW (FIVE-200 KW MICROTURBINES POWER MODULES) NATURAL GAS, CAPSTONE TURBINE COMPANY, MODEL C1000, 11.4 MMBTU/HR A/N: 534354	D225		NOX: LARGE SOURCE**	CO: 10 PPMV NATURAL GAS (4); NOX: 9 PPMV NATURAL GAS (3); NOX: 9 PPMV NATURAL GAS (4)	A195.5, D12.6, D29.1, D29.2, E448.1, I297.1
Process 3: PETROLEUM	STORAG	E/DISPENSI	NG		
STORAGE TANK, UNDERGROUND, JET FUEL (JPA), 4000 GALS; DIAMETER: 6 FT 3 IN; HEIGHT: 19 FT 11.5 IN A/N: 529222	D68				

- (1) (1A) (1B) Denotes RECLAIM emission factor
 - Denotes RECLAIM concentration limit
 - (5) (5A) (5B) Denotes command and control emission limit
 - Denotes NSR applicability limit
 - See App B for Emission Limits

- (2) (2A) (2B) Denotes RECLAIM emission rate
- Denotes BACT emission limit (4)
- Denotes air toxic control rule limit
- (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
- (10)See section J for NESHAP/MACT requirements
- Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



Section D	Page: 17
Facility ID:	169754
Revision #:	3
Date:	June 27 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring	Emissions * And Requirements	Conditions
			Unit		
Process 3: PETROLEUM S	STORA	GE/DISPENSI	NG	· ,	
FUEL DISPENSING NOZZLE, JET FUEL (JPA) 'N: 529222	D63				
rocess 5: FLARE					
KNOCK OUT POT, V-1, FLARE KNOCKOUT DRUM (PRESSURE VESSEL) A/N: 529236	D131	D199 D201			
VESSEL, V-2, WATER SEAL DRUM A/N: 529236	D132	C81			
FLARE, GROUND FLARE, H-1, PROCESS GAS, HEIGHT: 40 FT; DIAMETER: 20 FT 10 IN A/N: 529236	C81	D132		CO: 2000 PPMV (5); PM: 0.1 GRAINS/SCF (5)	D12.5
Process 7: Platform Emmy	Vent Sc	rubber	_	· · ·	
CARBON FILTER, T-210A, CAMERON ENVIRONMENTAL, KOH PREGNATED ACIVATED _ARBON, MODEL 1500R, VENTING TO ATMOSPHERIC VENT POLE, HEIGHT: 7 FT 7 IN; DIAMETER: 4 FT A/N: 529237	C164				E224.1
CARBON FILTER, T-210B, CAMERON ENVIRONMENTAL, KOH IMPREGNATED ACIVATED CARBON, MODEL 1500R, VENTING TO ATMOSPHERIC VENT POLE, HEIGHT: 7 FT 7 IN; DIAMETER: 4 FT A/N: 529238 Process 8: Petroleum Mark	C165	and Turnels La	adin a		E224.1
Process 8: Petroleum Mark	ering (1	ank I ruck £0	ading)	_	

•	(1) (1A) (1B)	Denotes RECLAIM emission factor	(2) (2A) (2B)	Denotes RECLAIM emission rate
	(3)	Denotes RECLAIM concentration limit	(4)	Denotes BACT emission limit
	(5) (5A) (5B)	Denotes command and control emission limit	(6)	Denotes air toxic control rule limit
	(7)	Denotes NSR applicability limit	(8) (8A) (8B)	Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
	(9)	See App B for Emission Limits	(10)	See section J for NESHAP/MACT requirements

^{**} Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



Section D	Page: 18
Facility ID:	169754
Revision #:	3
Date:	Јиле 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment Process 8: Petroleum Mar	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
LOADING ARM, BOTTOM, CRUDE OIL, WITH 2 HOSES, EACH. 3" DIA. AND WITH 3" DRIP-DRY SHUT-OFF VALVE A/N: 529239	D166		5).	ROG: 0.08 LBS/1000 GAL (5)	C1.3, C1.4, E71.1, E147.1, H23.9
VAPOR RETURN LINE, TWO 3" HOSES WITH QUICK DISCONNECT, VENTING TO VAPOR RECOVERY SYSTEM A/N: 529239	D167				C6.4, E57.2

3) Denotes RECLAIM concentration limit

(5) (5A) (5B) Denotes command and control emission limit

(7) Denotes NSR applicability limit

9) See App B for Emission Limits

(2) (2A) (2B) Denotes RECLAIM emission rate

(4) Denotes BACT emission limit

(6) Denotes air toxic control rule limit

(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)

(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

^{(1) (1}A) (1B) Denotes RECLAIM emission factor



Section D Facility ID: Revision #: Page: 19 169754

June 2

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: DEVICE ID INDEX

The following sub-section provides an index to the devices that make up the facility description sorted by device ID.



Section D Facility ID: Revision #:

Page: 20 169754

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

Device Index For Section D			
Device ID	Section D Page No.	Process	System
D1	1	1	1
D2	1	1_	1
' D3	1	1	1
D4	1	1	1
_ D5	. 1	1	1
D6	1	11	1
D7	1 \	11	1
D8	1	<u> </u>	I
D10		1	1
D11	2	1	1
D12	2	11	1
D13	2	1	1
_ D14	3	11	1
D15	2		1
_ D19	5	1	3
D20	6	1	4
D23	3	1	2
D24	3	1	2
D34	3	1	2
D36	3	1	2
D40	4	·1	2 .
D41	2	<u>1</u> .	`, 1
D42	6	11	4
D43	6	1	4
. D44	15	2	2
D45	6	1	4
D46	6	1	4
_ D47	7	1	4
D48	7	1	4
D63	17	3	0
D64	7	1	6
D65		· 1	6
D68	16	3	0
_ D76	12	1	. 8
D77	12	1	8



Section D Facility ID: Revision #:

Date:

Page: 21 169754

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

Device Index For Section D			
Device ID	Section D Page No.	Process	System
D78	12	1	8
D79	8	1	6 .
D80	8	1	6
C81	17	5	0
D83	7	1	4
D85	7 .	1	4
D86	7	1	4
D101	8	1	6
D103	. 15	2	2
D108	12	1	8
D112	12	1	8
D113	12	1	8
D120	5	1	3
D128	5		3
D130	5	1	3
D131	17	5	0
D132	17	. 5	0
D133	8	1	6
D134	8	1	6
D136	8	1	6
D137	8	1	6
D138	8 .	1	6
D139	9	1	6
D141	9	1	6
D142	9	I	6
D143	9	1 .	6
D145	5	1	3
D147	5	1.	3
D148	_ 5	1	3
D149	15	2	1
C164	17	7	0
C165	17	7	0
D166	18	8	0
D167	18	8	0
D168_	16	2	3



Section D Facility ID: Revision #: Date:

Page: 22 169754

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

Device Index For Section D			
Device ID	Section D Page No.	Process	System
D170	6	1	3
D171	6	1	3
D172	7	1	4
D173	9	1	6
D174	9	1	6
D175	9	1	6
D176	9	1	6
D177	9	1	6
D178	9		6
D179	. 10	<u> </u>	6
D180	10	1	6
D181	10		6
D182	10	1	6
D183	10	1	6
D184	10	1	6
D185	10	<u> </u>	6
D186	10	1	6
D187	. 11	1	6
D188			6
D189	11	<u></u> 1	6
D190	11	1 .	6
D191	11	1	6
D192	11	1	6
D193	11	1	6
D194	11	1	6
D195	11	1	7
D196	12	1	7
D197	12	1	7
D199	12	1	9
D201	13	1	9
D204	13	1	9
D205	13	1	9
D206	13	1	9
D207	13	1	9
D208	. 13		9



Section D Facility ID: Revision #:

Date:

Page: 23 169754 3

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

	Device Inde	ex For Section D	
Device ID	Section D Page No.	Process	System
D210	14	1	9
D211	14	1	9
D212	14	1	9
C213	14	1	. 9
D214	14	1	9
D215	3	1	2
D216	4	<u>l</u>	2
D217	4	1	2
D218	4	· I	2
D219	4	1	2
D220	5	_ 1	2
D221	6	1	3
D223	16	2	2
D225	16	2	4
D227	14	1	9
D228	15	2	2



Section D Facility ID: Revision #: Page: 24 169754 3

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

FACILITY CONDITIONS

- F14.1 The operator shall not use fuel oil containing sulfur compounds in excess of 0.05 percent by weight.
- F14.2 The operator shall not purchase diesel fuel containing sulfur compounds in excess of 15 ppm by weight as supplied by the supplier.
- F30.1 For the purpose of exemption from Title V requirements, the total emissions from this facility shall not equal or exceed the following specified amounts:

Pollutant	Emission Limit (Tons in any 12 consecutive calendar-month
	period)
NOx	10
VOC	10



Section D Facility ID: Revision #: Page: 25 169754

Date:

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

- a). If the total facility emissions for any of the specified pollutant amounts are in exceedance in any 12 consecutive calendar-month period, or if the facility operator fails to comply with the following requirements, the Facility Permit holder shall submit a Title V Permit application package and obtain a Title V permit pursuant to the requirements specified in Rule 3003. To ensure compliance with the emission limit(s) of this condition, the facility operator shall:
- i). determine emissions according to the requirements of Rule 2011 for SOx emissions and Rule 2012 for NOx emissions, as applicable;
- ii). in addition to complying with all applicable monitoring, recordkeeping and reporting requirements of Regulation XX, monitor and record on a monthly basis the total facility emissions, excluding emissions identified in Rule 3000(b)(28)(D) and (E), for each 12 consecutive month period, and
- iii). for any 12 consecutive month period in which emissions do not comply with an emission limit in this condition, submit to AQMD within 15 days a report of noncompliance and the total subject emissions from the facility for the preceding 12 consecutive calendar-month period.
- b). For the purpose of determining compliance with the emission limit(s), the total emissions from this facility shall be equal to the emissions recorded each month by the facility, including any corrections as allowed by Rule 2004, and including any corrections resulting from an AQMD audit of this facility.
- c). The provisions of this condition are the sole method of determining compliance with the facility emission limit(s) of this condition.
- F52.1 This facility is subject to the applicable requirements of the following rules or regulation(s):

SYSTEM CONDITIONS



Section D
Facility ID:
Revision #:
Date:

169754

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

S13.1 All devices under this system are subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
VOC	40CFR60, SUBPART	KKK .

[Systems subject to this condition: Process 1, System 6, 7]

S13.2 All devices under this system are subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
Sulfur	District Rule	431.1
compounds	'	'

[Systems subject to this condition: Process 1, System 6, 7]

DEVICE CONDITIONS

A. Emission Limits

A195.3 The 30 PPMV NOX emission limit(s) is averaged over 60 minutes at 3 percent oxygen, dry.

[Devices subject to this condition: C213]

A195.5 The 10 PPMV CO emission limit(s) is averaged over 60 minutes at 15% oxygen, dry.



C1.2

South Coast Air Quality Management District 21865 Copley Drive, Diamond Bar, CA 91765-4178

Section D Facility ID: Revision #:

Page: 27 169754

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition: D225]

A195.8 The 50 PPMV CO emission limit(s) is averaged over 60 minutes at 3 percent oxygen, dry.

[Devices subject to this condition: D227]

A195.9 The 12 PPMV NOX emission limit(s) is averaged over 60 minutes at 3 percent oxygen, dry.

[Devices subject to this condition: D227]

C. Throughput or Operating Parameter Limits

C1.1 The operator shall limit the operating time to no more than 2190 hour(s) in any one year.

The purpose(s) of this condition is to ensure that this equipment qualifies as a process unit.

[Devices subject to this condition: D223]

The operator shall limit the operating time to no more than 200 hour(s) in any one year.

Which includes no more than 34 hours hours in any one year for maintenance and testing.

[Devices subject to this condition : D44, D149]

C1.3 The operator shall limit the loading rate to no more than 9000 barrel(s) in any one day.



Section D Page: Facility ID: Revision #-Date:

169754

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

The operator shall use the existing LACT unit to monitor the daily tank truck loading volume and keep records of the daily loading during tank truck loading operation.

[Devices subject to this condition: D166]

C1.4 The operator shall limit the loading rate to no more than 270.000 barrel(s) in any one month.

[Devices subject to this condition: D166]

C1.6 The operator shall limit the operating time to no more than 200 hour(s) in any one year.

> Which includes no more than 50 hours in any one year for maintenance and testing purposes.

> The operation of the engine beyond the 50 hours per year allotted for engine maintenance and testing shall be allowed only in the event of a loss of grid power or up to 30 minutes prior to a rotating outage, provided that the electrical grid operator or electric utility has ordered rotating outages in the control area where the engine is located or has indicated that it expects to issue such an order at a certain time, and the engine is located in a utility service block that is subject to the rotating outage. Engine operation shall be terminated immediately after the utility distribution company advises that a rotating outage is no longer imminent or in effect.

[Devices subject to this condition: D168, D228]

C6.3 The operator shall use this equipment in such a manner that the flow being monitored, as indicated below, does not exceed 570 CFM.



Section D Facility ID: Revision # Page: 29 169754

ate:

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

To comply with this condition, the operator shall install and maintain a(n) flow meter to accurately indicate the flow rate at the inlet of the thermal oxidizer.

The measuring device or gauge shall be accurate to within +/- 5 percent. The accuracy of the device shall be verified once every 6 months.

The operator shall maintain records in a manner approved by the District, to demonstrate compliance with this condition.

[Devices subject to this condition: C213]

C6.4 The operator shall use this equipment in such a manner that the backpressure being monitored, as indicated below, does not exceed 18 inches water column.

To comply with this condition, the operator shall install and maintain a(n) differential pressure gauge to accurately indicate the differential pressure in the vapor return line.

[Devices subject to this condition: D167]

C8.4 The operator shall use this equipment in such a manner that the temperature being monitored, as indicated below, is not less than 1400 Deg F.

To comply with this condition, the operator shall install and maintain a(n) temperature gauge to accurately indicate the temperature at the point at least 8 feet down stream of the combustion box..

The measuring device or gauge shall be accurate to within +/- 30 degrees Fahrenheit. It shall be calibrated once every 12 months.

The operator shall install and maintain a device to continuously record the parameter being monitored.

[Devices subject to this condition: C213]



Section D Facility ID: Revision #:

Page: 30 169754

June

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

D. Monitoring/Testing Requirements

D12.I The operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the engine.

[Devices subject to this condition: D44, D103, D149, D168, D223]

D12.2 The operator shall install and maintain a(n) temperature gauge to accurately indicate the temperature of the 1) inlet gas stream to the amine contact tower and 2) inlet amine stream to the amine contact tower.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. The accuracy of the device shall be verified once a month.

The operator shall also install and maintain an automatic temperature controller to monitor—the—DEA—absorber—approach—temperature.—This—monitoring—device—shall—be—inoperation at all times while the amine gas treating unit is in operation

The operator shall monitor and record daily, the inlet gas and amine stream temperatures. if the absorber approach temperature is below 10 degrees Fahrenheit, the operator shall make necessary corrective actions to bring the absorber approach temperature within the specified range within 4 hours of the exceedance

The absorber approach temperature is defined as the temperature differential between the amine solution (higher temperature) and the inlet gas (lower temperature)

[Devices subject to this condition: D201]

D12.4 The operator shall install and maintain a(n) temperature gauge to accurately indicate the temperature of the amine inlet line to reflux accumulator, V1003.



Section D Facility ID: Revision #:

Date:

Page: 31 169754

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

This monitoring device shall be in operation at all times while the amine gas tracting unit is in operation.

The operator shall monitor and record daily, the temperature of the reflux accumulator, V-1005.

The operator shall maintain a temperature in Vessel V-1005 of 120 degrees Fahrenheit or lower.

If the temperature in Vessel V-1005 is outside the range specified above, the operator shall make necessary corrective actions to bring the temperature within 4 hours of the exceedance.

[Devices subject to this condition: D211]

D12.5 The operator shall install and maintain a(n) thermocouple or any other equivalent device to accurately indicate the presence of a flame at the pilot.

The operator shall also install and maintain a device to continuously record the parameter being measured.

[Devices subject to this condition: C81]

D12.6 The operator shall install and maintain a(n) non-resettable totalizing fuel meter to accurately indicate the flow rate in the fuel supply line.

[Devices subject to this condition: D225]

D12.8 The operator shall install and maintain a(n) pressure gauge to accurately indicate the pressure of the amine flash tank, V-1003.



Section D Facility ID: Revision #: Date:

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

The pressure gauge shall be in good operating condition at all times to indicate the back pressure of the flash tank in psig while the amine treating unit is in operation.

The operator shall monitor and record daily for the first 30 days of operation and weekly thereafter, the operating back pressure of vessel V-1003.

[Devices subject to this condition : D204]

The operator shall install and maintain a(n) non-resettable elapsed time D12.9 accurately indicate the elapsed operating time of the engine.

> The operator shall keep a log of the engine's operation, documenting the total time the engine is operated each month and specify the reasons for operation, such as:

- A. Emergency use
- B. Maintenance and testing
- C. Other(Describe reason for operating)

In addition, each time the engine is manually started, the log shall include the date of operation and shall include the total total hour meter reading (in hours and tenths of hours) at the beginning and end of the operation.

[Devices subject to this condition: D228]

The operator shall conduct source test(s) for the pollutant(s) identified below. D29.1

Averaging Time Required Test Method(s) Test Location Pollutant(s) to be tested



Section D Facility ID: Revision #:

Date:

Page: 33 169754

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

NOX emissions	District method 100.1	1 hour	Outlet
CO emissions	District method 100.1	1 hour	Outlet
VOC emissions	District Method 25.3	1 hour	Outlet
PM10	District method 5.2	l hour	Outlet
emissions			
SOX emissions	AQMD Laboratory	Not Applicable	Outlet
	Method 307-91	ı	ı

The test(s) shall be conducted within 60 days after achieving maximum production rate, but no later than 180 days after initial start-up.

The test shall be conducted to measure the Nitrous Oxide (NOx), Carbon Monoxide (CO), the total Non-Methane Hydrocarbons, Total Particulate Matter, Total reduced Sulfur as H2S, percent oxygen of the exhaust, moisture content, temperature of the exhaust, exhaust flow rate, and the toxic air contaminants in accordance with EPA Method TO-15.

The test shall be conducted in accordance with a District approved source test protocol. The protocol shall be submitted to the District engineer no later than 45 days prior to the proposed test date and shall be approved by the District before the test comences.

The test protocol shall include the proposed operating conditions of the microturbine during the test, the identity of the testing lab, a statement from the testing lab certifying that it meets the criteria of Rule 304, and a description of all sampling and analytical procedures.

The report shall present the emissions data in units of pounds per hour (lbs/hr), pounds per million Btu (lbs/MMBtu), and parts per million (ppmv) on a dry basis at 15% Oxygen.

The District shall be notified of the date and time of the test at least 10 days prior to the test.



Section D Facility ID: Revision #: Date: Page: 30 169754 3

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Once per operating day for the first month of operation and weekly thereafter

A sample of circulating amine solution shall be obtained from V-1003 using a clean, dry, standard sample container

Using a timer, the sample shall be allowed to cool to room conditions for a period of 30 minutes

Using a standardized, clean, dry, laminated, cloud point test strip, the operator shall visually check sample cloudiness and/or turbidity by placing the test strip behind the sample container and record the relative sample visibility

In addition, the amine solution shall be sampled and analytically tested by an independent laboratory to determine VOC and benzene levels at least once every 60 operating days for the first year and yearly thereafter

[Devices subject to this condition: D204]

D135.1 The operator shall inspect, adjust, and certify the ignition or fuel injection timing of this engine a minimum of once every 1 years of operation. Inspections, adjustments, and certifications shall be performed by a qualified mechanic and performed in accordance with the engine manufacturer's specifications and procedures.

[Devices subject to this condition: D44, D103, D149, D168]

E. Equipment Operation/Construction Requirements

E57.1 The operator shall vent this equipment to vapor recovery compressor whenever this equipment is operating.

[Devices subject to this condition: D10, D11, D12, D13, D14, D15, D36, D40, D194, D215, D216, D217, D218, D219, D220]

Section D Facility ID: Revision #:

Date:

Page: 37 169754 3

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

E57.2 The operator shall vent this equipment to the plant vapor recovery system which is in full use and which has been permitted by the Executive officer whenever the tank truck loading is in operation.

[Devices subject to this condition: D167]

E71.1 The operator shall not use this equipment if there are overfills, fugitive liquid/vapor leaks or organic liquid leak during disconnect.

[Devices subject to this condition: D166]

E116.1 This engine shall not be used as part of a demand response program using interruptible service contract in which a facility receives a payment or reduced rates in return for reducing its electric load on the grid when requested to do so by the utility or the grid operator.

[Devices subject to this condition: D103, D168, D228]

E127.1 The operator shall keep gauge/sample hatches closed except during actual gauging/sampling operations.

[Devices subject to this condition : D10, D11, D12, D13, D14, D15, D23, D24, D36, D215, D216, D217, D218, D219, D220]

E147.1 The operator shall only conduct crude oil loading in this equipment.

[Devices subject to this condition: D166]

Line All Quality Management District 21865 Copley Drive, Diamond Bar, CA 91765-4178

Section D 169754 Facility ID: Revision #: June 27, 2014 Date:

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

The operator shall use this equipment only during utility failure periods, except for E162.1 maintenance purposes.

[Devices subject to this condition: D103, D168]

The operator shall replace the operating carbon canister by the spare carbon canister when H2S is detected in the effluent gas by the H2S monitor.

[Devices subject to this condition: C164, C165]

E448.1 The operator shall comply with the following requirements:

The microturbine shall only be operated with natural gas or process gas that has been treated to pipeline quality gas specifications.

[Devices subject to this condition: D225]

E448.4 The operator shall comply with the following requirements:

The Amine Re-Boiler shall only be operated with natural gas.

[Devices subject to this condition: D227]

H. Applicable Rules

This equipment is subject to the applicable requirements of the following rules or H23.1 regulations:

Rule/Subpart Contaminant Rule



Section D Facility ID: Revision #;

Date

Page: 39 169754 3

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comp	ly with the terms and	conditions set forth below:
-------------------------	-----------------------	-----------------------------

VOC

District Rule

1173

[Devices subject to this condition: D76, D77, D78, D108, D113]

H23.3 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart	
VOC	District Rule	1176	

[Devices subject to this condition: D41, D112, D216, D217]

H23.4 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant Rule		Rule/Subpart	
VOC	District Rule	1176	
VOC	District Rule	1149	

[Devices subject to this condition: D23, D24, D40]

H23.5 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart	
VOC	District Rule	463	
VOC	District Rule	1149	



Section D Facility ID: Revision #: Page: 40 169754 3

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition : D10, D11, D12, D13, D14, D15, D215, D218, D219]

H23.7 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart	
VOC	District Rule	464	
VOC	District Rule	1176	

[Devices subject to this condition: D36]

H23.9 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
VOC	District Rule	462

[Devices subject to this condition: D166]

H23.10 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
CO	District Rule	1110.2
NOX	District Rule	1110.2
VOC	District Rule	1110.2

Section D Facility ID: Revision #:

Page: 41 169754

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition: D223]

H23.11 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
PM10	District Rule	1470
H2S	District Rule	431.2

[Devices subject to this condition: D228]

I. Administrative

in its allocation account to offset the annual emissions increase for the first year of operation. RTCs held to satisfy this condition may be transferred only after one year from the initial start of operation. If the hold amount is partially satisfied by holding RTCs that expire midway through the hold period, those RTCs may be transferred upon their respective expiration dates. This hold amount is in addition to any other amount of RTCs required to be held under other condition(s) stated in this permit.

[Devices subject to this condition: D225]

This equipment shall not be operated unless the facility holds 350 pounds of NOx RTCs in its allocation account to offset the annual emissions increase for the first year of operation. RTCs held to satisfy this condition may be transferred only after one year from the initial start of operation. If the hold amount is partially satisfied by holding RTCs that expire midway through the hold period, those RTCs may be transferred upon their respective expiration dates. This hold amount is in addition to any other amount of RTCs required to be held under other condition(s) stated in this permit.



Section D Facility ID: Revision #:

Page: -42 169754

June 27, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition: D227]

This equipment shall not be operated unless the facility holds 613 pounds of NOx RTCs in its allocation account to offset the annual emissions increase for the first year of operation. RTCs held to satisfy this condition may be transferred only after one year from the initial start of operation. If the hold amount is partially satisfied by holding RTCs that expire midway through the hold period, those RTCs may be transferred upon their respective expiration dates. This hold amount is in addition to any other amount of RTCs required to be held under other condition(s) stated in this permit.

[Devices subject to this condition: C213]

K. Record Keeping/Reporting

K67.1 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

On or before January 15 th of each year, the operator shall record in the engine's operating log, the following:

- A. The total hours of operation for the previous calendar year, and
- B. The total hours of the engine operation for maintenance and testing for the previous calendar year.

The engine operating log shall be retained on site for a minimum of five calendar years and shall be made available to the executive officer or representative upon request.

[Devices subject to this condition: D228]

Section D
Facility ID:
Revision #:
Date: J

Page: 1 169754 DRAFT June 25, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 2: INTERNAL CO			\$.,		
System 1: EMERGENCY I	ENGINE	<u> </u>			<u> </u>
INTERNAL COMBUSTION ENGINE, EMERGENCY FIRE, DIESEL FUEL, CLARKE DETROIT DIESEL, MODEL DDFP-4AT, WITH TURBOCHARGER, 235 BHP WITH A/N: 529224	D149		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1)	C1.2, D12.1, D135.1
PUMP, FIRE WATER System 2: PLATFORM EM	IMY- E	NGINES			
INTERNAL COMBUSTION ENGINE, EMERGENCY FIRE, DIESEL FUEL, DETROIT DIESEL, MODEL 67 IRC, 241 HP WITH A/N: 529225	D44		NOX: PROCESS: UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1)	C1.2, D12.1, D135.1
PUMP, FIRE WATER				<u> </u>	
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, WAUKESHA, MODEL F674DS, 300 HP WITH A/N: 529223	D103		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1)	D12.1, D135.1, E116.1, E162.1
, GENERATOR		www.igh			
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CUMMINS, MODEL QST30-G5-NR2, 1490 BHP WITH	5228 A	Called Carps	NOX: PROCESS	CO: 2.6 GRAM/BHP-HR DIESEL (4); NOX: 469 LBS/1000 GAL DIESEL (1); NOX + ROG: 4.8 GRAM/BHP-HR DIESEL (4); PM: 0.15 GRAM/BHP-HR DIESEL (4)	C1.6, D12.9, E116.1, H23.11, K67.1
GENERATOR					

⁽³⁾ Denotes RECLAIM concentration limit

^{(5) (5}A) (5B) Denotes command and control emission limit

⁽⁷⁾ Denotes NSR applicability limit

⁽⁹⁾ See App B for Emission Limits

^{(2) (2}A) (2B) Denotes RECLAIM emission rate

⁽⁴⁾ Denotes BACT emission limit

⁽⁶⁾ Denotes air toxic control rule limit

^{(8) (8}A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)

⁽¹⁰⁾ See section J for NESHAP/MACT requirements

Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

 Section D
 Page: 2

 Facility ID: 169754
 169754

 Revision #: DRAFT
 Date: June 25, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	1D No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: INTERNAL CO	MBUST	ION	•		
INTERNAL COMBUSTION ENGINE, DIESEL FUEL, DEUTZ, MODEL TCD2012L042V, DRIVING A CRANE, 131 HP A/N: 529240	D223		NOX: PROCESS UNIT**	CO: 3.73 GRAM/BHP-HR DIESEL (4); CO: 2000 PPMV (5); NOX: 116.3 LBS/1000 GAL DIESEL (1); NOX + ROG: 2.98 GRAM/BHP-HR DIESEL (4); PM: 0.22 GRAM/BHP-HR DIESEL (4); ROG: 250 PPMV (5)	C1.1, D12.1, H23.10
System 3: EMERGENCY	INSTRU	MENT AIR (COMPRESSOR		
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CUMMINS, MODEL 6BTA5.9, INSTRUMENT AIR COMPRESSOR DRIVER, WITH AFTERCOOLER, TURBOCHARGER, 174 HP WITH A/N: 529226 COMPRESSOR, INSTRUMENT	D168		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR DIESEL (4); NOX: 6.9 GRAM/BHP-HR DIESEL (4); NOX: 469 LBS/1000 GAL DIESEL (1); PM10: 0.38 GRAM/BHP-HR DIESEL (4); VOC: I GRAM/BHP-HR DIESEL (4)	C1.6, D12.1, D135.1, E116.1, E162.1
System 4: POWER GENE	 RATION	1	J		
GAS TURBINE, 1.0 MW (FIVE-200 KW MICROTURBINES POWER MODULES) NATURAL GAS, CAPSTONE TURBINE COMPANY, MODEL C1000, 11.4 MMBTU/HR A/N: 534354	D225		NOX: LARGE SOURCE**	CO: 10 PPMV NATURAL GAS (4); NOX: 9 PPMV NATURAL GAS (3); NOX: 9 PPMV NATURAL GAS (4)	A195.5, D12.6, D29.1, D29.2, E448.1, 1297.1

+	(1) (1A) (1B)	Denotes RECLAIM emission factor	(2) (2A) (2B)	Denotes RECLAIM emission rate
	(3)	Denotes RECLAIM concentration limit	(4)	Denotes BACT emission limit
	(5) (5A) (5B)	Denotes command and control emission limit	(6)	Denotes air toxic control rule limit
	(7)	Denotes NSR applicability limit	(8) (8A) (8B)	Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
	(9)	See App B for Emission Limits	(10)	See section J for NESHAP/MACT requirements

^{**} Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

| Section D | Page: 3 | 169754 | Revision #: DRAFT | June 25, 2014 |

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: DEVICE ID INDEX

The following sub-section provides an index to the devices that make up the facility description sorted by device ID.

Section D Page: 4
Facility ID: 169754
Revision #: DRAFT
Date: June 25, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

Device Index For Section D			
Device ID	Section D Page No.	Process	System
D44	<u></u>	2	2
D103	1	2	2
D149	1	2	1
D168	2	2	3
D223	2	2	2
D225	2	2	4
D228	1	2	2

| Section D | Page: 5 | Facility ID: 169754 | Revision #: DRAFT | Date: June 25, 2014 |

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

FACILITY CONDITIONS

- F14.1 The operator shall not use fuel oil containing sulfur compounds in excess of 0.05 percent by weight.
- F14.2 The operator shall not purchase diesel fuel containing sulfur compounds in excess of 15 ppm by weight as supplied by the supplier.
- F30.1 For the purpose of exemption from Title V requirements, the total emissions from this facility shall not equal or exceed the following specified amounts:

Pollutant	Emission Limit (Tons in any 12 consecutive calendar-month period)
NOx	10
VOC	10

 Section D
 Page: 6

 Facility ID: Revision #: Date:
 DRAFT

 June 25, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

- a). If the total facility emissions for any of the specified pollutant amounts are in exceedance in any 12 consecutive calendar-month period, or if the facility operator fails to comply with the following requirements, the Facility Permit holder shall submit a Title V Permit application package and obtain a Title V permit pursuant to the requirements specified in Rule 3003. To ensure compliance with the emission limit(s) of this condition, the facility operator shall:
- i). determine emissions according to the requirements of Rule 2011 for SOx emissions and Rule 2012 for NOx emissions, as applicable;
- ii). in addition to complying with all applicable monitoring, recordkeeping and reporting requirements of Regulation XX, monitor and record on a monthly basis the total facility emissions, excluding emissions identified in Rule 3000(b)(28)(D) and (E), for each 12 consecutive month period, and
- iii). for any 12 consecutive month period in which emissions do not comply with an emission limit in this condition, submit to AQMD within 15 days a report of noncompliance and the total subject emissions from the facility for the preceding 12 consecutive calendar-month period.
- b). For the purpose of determining compliance with the emission limit(s), the total emissions from this facility shall be equal to the emissions recorded each month by the facility, including any corrections as allowed by Rule 2004, and including any corrections resulting from an AQMD audit of this facility.
- c). The provisions of this condition are the sole method of determining compliance with the facility emission limit(s) of this condition.
- F52.1 This facility is subject to the applicable requirements of the following rules or regulation(s):

SYSTEM CONDITIONS

Section D Facility ID: DRAFT June 25, 2014

Revision #:

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

All devices under this system are subject to the applicable requirements of the following S13.1 rules or regulations:

Contaminant	Rule	Rule/Subpart
VOC	40CFR60, SUBPART	KKK

[Systems subject to this condition: Process 1, System 6, 7]

S13.2 All devices under this system are subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
Sulfur	District Rule	431.1
compounds	•	•

[Systems subject to this condition: Process 1, System 6, 7]

DEVICE CONDITIONS

A. Emission Limits

A195.3 The 30 PPMV NOX emission limit(s) is averaged over 60 minutes at 3 percent oxygen, dry.

[Devices subject to this condition: C213]

A195.5 The 10 PPMV CO emission limit(s) is averaged over 60 minutes at 15% oxygen, dry.

Page: 8 169754 DRAFT June 25, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition: D225]

A195.8 The 50 PPMV CO emission limit(s) is averaged over 60 minutes at 3 percent oxygen, dry.

[Devices subject to this condition: D227]

A195.9 The 12 PPMV NOX emission limit(s) is averaged over 60 minutes at 3 percent oxygen, dry.

[Devices subject to this condition: D227]

C. Throughput or Operating Parameter Limits

C1.1 The operator shall limit the operating time to no more than 2190 hour(s) in any one year.

The purpose(s) of this condition is to ensure that this equipment qualifies as a process unit.

[Devices subject to this condition: D223]

C1.2 The operator shall limit the operating time to no more than 200 hour(s) in any one year.

Which includes no more than 34 hours hours in any one year for maintenance and testing.

[Devices subject to this condition: D44, D149]

C1.3 The operator shall limit the loading rate to no more than 9000 barrel(s) in any one day.

 Section D
 Page: 9

 Facility ID:
 169754

 Revision #:
 DRAFT

 Date:
 June 25, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

The operator shall use the existing LACT unit to monitor the daily tank truck loading volume and keep records of the daily loading during tank truck loading operation.

[Devices subject to this condition : D166]

C1.4 The operator shall limit the loading rate to no more than 270.000 barrel(s) in any one month.

[Devices subject to this condition: D166]



The operator shall limit the operating time to no more than 200 hour(s) in any one year.

Which includes no more than 50 hours in any one year for maintenance and testing purposes.

The operation of the engine beyond the 50 hours per year allotted for engine maintenance and testing shall be allowed only in the event of a loss of grid power or up to 30 minutes prior to a rotating outage, provided that the electrical grid operator or electric utility has ordered rotating outages in the control area where the engine is located or has indicated that it expects to issue such an order at a certain time, and the engine is located in a utility service block that is subject to the rotating outage. Engine operation shall be terminated immediately after the utility distribution company advises that a rotating outage is no longer imminent or in effect.

[Devices subject to this condition : D168, D168,

C6.3 The operator shall use this equipment in such a manner that the flow being monitored, as indicated below, does not exceed 570 CFM.

| Section D | Page: 10 | 169754 | Revision #: DRAFT | June 25, 2014 |

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

To comply with this condition, the operator shall install and maintain a(n) flow meter to accurately indicate the flow rate at the inlet of the thermal oxidizer.

The measuring device or gauge shall be accurate to within +/- 5 percent. The accuracy of the device shall be verified once every 6 months.

The operator shall maintain records in a manner approved by the District, to demonstrate compliance with this condition.

[Devices subject to this condition: C213]

C6.4 The operator shall use this equipment in such a manner that the backpressure being monitored, as indicated below, does not exceed 18 inches water column.

To comply with this condition, the operator shall install and maintain a(n) differential pressure gauge to accurately indicate the differential pressure in the vapor return line.

[Devices subject to this condition: D167]

C8.4 The operator shall use this equipment in such a manner that the temperature being monitored, as indicated below, is not less than 1400 Deg F.

To comply with this condition, the operator shall install and maintain a(n) temperature gauge to accurately indicate the temperature at the point at least 8 feet down stream of the combustion box..

The measuring device or gauge shall be accurate to within \pm 30 degrees Fahrenheit. It shall be calibrated once every 12 months.

The operator shall install and maintain a device to continuously record the parameter being monitored.

[Devices subject to this condition: C213]

ì

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

D. Monitoring/Testing Requirements

D12.1 The operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the engine.

[Devices subject to this condition: D44, D103, D149, D168, D223]

D12.2 The operator shall install and maintain a(n) temperature gauge to accurately indicate the temperature of the 1) inlet gas stream to the amine contact tower and 2) inlet amine stream to the amine contact tower.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. The accuracy of the device shall be verified once a month.

The operator shall also install and maintain an automatic temperature controller to monitor the DEA absorber approach temperature. This monitoring device shall be in operation at all times while the amine gas treating unit is in operation

The operator shall monitor and record daily, the inlet gas and amine stream temperatures if the absorber approach temperature is below 10 degrees Fahrenheit, the operator shall make necessary corrective actions to bring the absorber approach temperature within the specified range within 4 hours of the exceedance

The absorber approach temperature is defined as the temperature differential between the amine solution (higher temperature) and the inlet gas (lower temperature)

[Devices subject to this condition: D201]

D12.4 The operator shall install and maintain a(n) temperature gauge to accurately indicate the temperature of the amine inlet line to reflux accumulator, V1003.

Section D Page: 12 169754 Facility ID: DRAFT Revision #: June 25, 2014

Date:

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

This monitoring device shall be in operation at all times while the amine gas tracting unit is in operation.

The operator shall monitor and record daily. the temperature of the reflux accumulator, V-1005.

operator maintain temperature in Vessel V-1005 of 120 degrees shall а Fahrenheit or lower.

If the temperature in Vessel V-1005 is outside the range specified above, the operator shall make necessary corrective actions to bring the temperature within 4 hours of the exceedance.

[Devices subject to this condition: D211]

The operator shall install and maintain a(n) thermocouple or any other equivalent device to D12.5 accurately indicate the presence of a flame at the pilot.

> The operator shall also install and maintain a device to continuously record the parameter being measured.

[Devices subject to this condition: C81]

D12.6 The operator shall install and maintain a(n) non-resettable totalizing fuel meter to accurately indicate the flow rate in the fuel supply line.

[Devices subject to this condition : D225]

The operator shall install and maintain a(n) pressure gauge to accurately indicate the D12.8 pressure of the amine flash tank, V-1003.

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

The pressure gauge shall be in good operating condition at all times to indicate the back pressure of the flash tank in psig while the amine treating unit is in operation.

The operator shall monitor and record daily for the first 30 days of operation and weekly thereafter, the operating back pressure of vessel V-1003.

[Devices subject to this condition: D204]



The operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the engine.

The operator shall keep a log of the engine's operation, documenting the total time the engine is operated each month and specify the reasons for operation, such as:

- A. Emergency use
- B. Maintenance and testing
- C. Other(Describe reason for operating)

In addition, each time the engine is manually started, the log shall include the date of operation and shall include the total total hour meter reading (in hours and tenths of hours) at the beginning and end of the operation.

[Devices subject to this condition : 0228]

D29.1 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to Required Test Method(s) Averaging Time Test Location be tested

Page: 14 169754 DRAFT June 25, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

NOX emissions	District method 100.1	1 hour	Outlet
CO emissions	District method 100.1	1 hour	Outlet
VOC emissions	District Method 25.3	1 hour	Outlet
PM10	District method 5.2	1 hour	Outlet
emissions			· ·
SOX emissions	AQMD Laboratory	Not Applicable	Outlet
	Method 307-91	•	•

The test(s) shall be conducted within 60 days after achieving maximum production rate, but no later than 180 days after initial start-up.

The test shall be conducted to measure the Nitrous Oxide (NOx), Carbon Monoxide (CO), the total Non-Methane Hydrocarbons, Total Particulate Matter, Total reduced Sulfur as H2S, percent oxygen of the exhaust, moisture content, temperature of the exhaust, exhaust flow rate, and the toxic air contaminants in accordance with EPA Method TO-15.

The test shall be conducted in accordance with a District approved source test protocol. The protocol shall be submitted to the District engineer no later than 45 days prior to the proposed test date and shall be approved by the District before the test comences.

The test protocol shall include the proposed operating conditions of the microturbine during the test, the identity of the testing lab, a statement from the testing lab certifying that it meets the criteria of Rule 304, and a description of all sampling and analytical procedures.

The report shall present the emissions data in units of pounds per hour (lbs/hr), pounds per million Btu (lbs/MMBtu), and parts per million (ppmv) on a dry basis at 15% Oxygen.

The District shall be notified of the date and time of the test at least 10 days prior to the test.

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition: D225]

D29.2 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
NOX emissions	District method 100.1	1 hour	Outlet
CO emissions	District method 100.1	1 hour	Outlet:

The test shall be conducted once every three years as per Rule 2012, Chapter 5, Section (B)(2)(a) and for compliance with BACT.

The test shall be conducted to measure Nitrous Oxide (NOx) and Carbon Monoxide (CO) at 15% Oxygen..

[Devices subject to this condition : D225]

D90.1 The operator shall monitor and record the amount of the process gas treated in the amine conatct tower, T-1006, according to the following specifications:

 Section D
 Page: 16

 Facility ID: 169754
 169754

 Revision #: DRAFT
 Date: June 25, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

The volume of gas processed by this unit shall not exceed monthly average of 4.0 mmscfd

The volume of gas recorded by the gas sales meter can be used to determine compliance with this requirement

If the volume of gas measured by the gas sales meter, which includes the gas treated in the amine treating unit plus additional gas that bypasses the amine treating unit, is 4.0 mmscfd or higher, the applicant shall install a dedicated gas meter at the inlet of the amine gas treating system to indicate in scf per day, the inlet flow rate of process gas to the amine system. The operator shall install the gas meter within 90 days of exceeding the specified limit above

The operator shall notify the AQMD in writing within 7 days of exceeding 4.0 mmscfd level

[Devices subject to this condition: D201]

D90.2 The operator shall monitor and record the level of cloudiness and/or turbidity of the amine solution in the amine flash tank, V-1003, according to the following specifications:

 Section D
 Page: 17

 Facility ID:
 169754

 Revision #:
 DRAFT

 Date:
 June 25, 2014

Revi Date

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Once per operating day for the first month of operation and weekly thereafter

A sample of circulating amine solution shall be obtained from V-1003 using a clean, dry, standard sample container

Using a timer, the sample shall be allowed to cool to room conditions for a period of 30 minutes

Using a standardized, clean, dry, laminated, cloud point test strip, the operator shall visually check sample cloudiness and/or turbidity by placing the test strip behind the sample container and record the relative sample visibility

In addition, the amine solution shall be sampled and analytically tested by an independent laboratory to determine VOC and benzene levels at least once every 60 operating days for the first year and yearly thereafter

[Devices subject to this condition: D204]

D135.1 The operator shall inspect, adjust, and certify the ignition or fuel injection timing of this engine a minimum of once every 1 years of operation. Inspections, adjustments, and certifications shall be performed by a qualified mechanic and performed in accordance with the engine manufacturer's specifications and procedures.

[Devices subject to this condition: D44, D103, D149, D168]

E. Equipment Operation/Construction Requirements

E57.1 The operator shall vent this equipment to vapor recovery compressor whenever this equipment is operating.

[Devices subject to this condition: D10, D11, D12, D13, D14, D15, D36, D40, D194, D215, D216, D217, D218, D219, D220]

Page: 15 169754 Section D Facility ID: DRAFT Revision #: June 25, 2014 Date:

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

E57.2 The operator shall vent this equipment to the plant vapor recovery system which is in full use and which has been permitted by the Executive officer whenever the tank truck loading is in operation.

[Devices subject to this condition: D167]

E71.1 The operator shall not use this equipment if there are overfills, fugitive liquid/vapor leaks or organic liquid leak during disconnect.

[Devices subject to this condition: D166]

This engine shall not be used as part of a demand response program using interruptible service contract in which a facility receives a payment or reduced rates in return for reducing its electric load on the grid when requested to do so by the utility or the grid operator.

[Devices subject to this condition: D103, D168, D228]

E127.1 The operator shall keep gauge/sample hatches closed except during actual gauging/sampling operations.

> [Devices subject to this condition: D10, D11, D12, D13, D14, D15, D23, D24, D36, D215, D216, D217, D218, D219, D220]

E147.1 The operator shall only conduct crude oil loading in this equipment.

[Devices subject to this condition: D166]

Page: 19 169754 DRAFT June 25, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D. FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

E162.1 The operator shall use this equipment only during utility failure periods, except for maintenance purposes.

[Devices subject to this condition: D103, D168]

E224.1 The operator shall replace the operating carbon canister by the spare carbon canister when H2S is detected in the effluent gas by the H2S monitor.

[Devices subject to this condition: C164, C165]

E448.1 The operator shall comply with the following requirements:

The microturbine shall only be operated with natural gas or process gas that has been treated to pipeline quality gas specifications.

[Devices subject to this condition: D225]

E448.4 The operator shall comply with the following requirements:

The Amine Re-Boiler shall only be operated with natural gas.

[Devices subject to this condition: D227]

H. Applicable Rules

H23.1 This equipment is subject to the applicable requirements of the following rules of regulations:

Contaminant

Rule

Rule/Subpart

Page: 20 169754 DRAFT June 25, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comp	ply with the terms and conditions :	set forth below:
VOC	District Rule	1173
[Devices subj	ect to this condition: D76, D77, D78, 1	D108, D113]
H23.3 This equipmen regulations:	nt is subject to the applicable	requirements of the following rules or
Contaminant	Rule	Rulc/Subpart
VOC	District Rule	1176
-	ect to this condition: D41, D112, D216 nt is subject to the applicable	6, D217] requirements of the following rules or
Contaminant	Rule	Rule/Subpart
VOC	District Rule	1176
VOC	District Rule	1149
	ect to this condition: D23, D24, D40] nt is subject to the applicable	requirements of the following rules or
Contaminant	Rule	Rule/Subpart
VOC	District Rule	463
VOC	District Rule	1149

Page: 21 169754 DRAFT June 25, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition : D10, D11, D12, D13, D14, D15, D215, D218, D219]

H23.7 This equipment is subject to the applicable requirements of the following rules or regulations:

Rule	Rule/Subpart
District Rule	464
District Rule	1176
	District Rule

[Devices subject to this condition : D36]

H23.9 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
VOC	District Rule	462

[Devices subject to this condition : D166]

H23.10 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
CO	District Rule	1110.2
NOX	District Rule	1110.2
VOC	District Rule	1410.2

Page: 22 169754 DRAFT June 25, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition: D223]

H233

This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rulc	Rule/Subpart
PM10	District Rule	1470
H2S	District Rule	431.2

[Devices subject to this condition: 0228]

I. Administrative

This equipment shall not be operated unless the facility holds 3366 pounds of NOx RTCs in its allocation account to offset the annual emissions increase for the first year of operation. RTCs held to satisfy this condition may be transferred only after one year from the initial start of operation. If the hold amount is partially satisfied by holding RTCs that expire midway through the hold period, those RTCs may be transferred upon their respective expiration dates. This hold amount is in addition to any other amount of RTCs required to be held under other condition(s) stated in this permit.

[Devices subject to this condition: D225]

1297.2 This equipment shall not be operated unless the facility holds 350 pounds of NOx RTCs in its allocation account to offset the annual emissions increase for the first year of operation. RTCs held to satisfy this condition may be transferred only after one year from the initial start of operation. If the hold amount is partially satisfied by holding RTCs that expire midway through the hold period, those RTCs may be transferred upon their respective expiration dates. This hold amount is in addition to any other amount of RTCs required to be held under other condition(s) stated in this permit.

Page: 23 169754 DRAFT June 25, 2014

FACILITY PERMIT TO OPERATE OXY USA INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition: D227]

This equipment shall not be operated unless the facility holds 613 pounds of NOx RTCs in its allocation account to offset the annual emissions increase for the first year of operation. RTCs held to satisfy this condition may be transferred only after one year from the initial start of operation. If the hold amount is partially satisfied by holding RTCs that expire midway through the hold period, those RTCs may be transferred upon their respective expiration dates. This hold amount is in addition to any other amount of RTCs required to be held under other condition(s) stated in this permit.

[Devices subject to this condition: C213]

K. Record Keeping/Reporting



The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

On or before January 15th of each year, the operator shall record in the engine's operating log, the following:

- A. The total hours of operation for the previous calendar year, and
- B. The total hours of the engine operation for maintenance and testing for the previous calendar year.

The engine operating log shall be retained on site for a minimum of five calendar years and shall be made available to the executive officer or representative upon request.

[Devices subject to this condition : D228]

NSR DATA SUMMARY SHEET

Application No Application Type Application status Previous Apps, Dev

555370 10

PENDAPPRV

Company Name Company ID Address

OXY USA INC 169754

20101 GOLDENWEST ST.

HUNTINGTON BEACH, CA 92648-2628

Reclaim NOX Reclaim Zone 01 Air Basin SC 18 Zone Title V NO

Device ID

Estimated Completion Date

Heat Input Capacity

02-28-2014

Priority Reserve Recommended Disposition

Millions BTU/Hr NONE - No Priority Access Requested 31 - PERMIT TO OPERATE GRANTED

PR Expiration

12-31-9999 NO

0 -

School within 1,000 feet Operating Weeks per year Operating Days per week

50 1

Operating Hours

Monday 08:00 to 09:00 Tuesday 00:00 to 00:00 Wednesday 00:00 to 00:00 Thursday 00:00 to 00:00 Friday 00:00 to 00:00 Saturday 00:00 to 00:00 Sunday 00:00 to 00:00

Application No 555370		Company ID	169754
Emittant	со		
BACT			
Cost effectiveness	NO		
Source Type	MINOR		
Emis Increase	0.3		
Modelling	N/A		
Public Notice	N		
Controlled Emission			
Max Hourly	2.16	Lbs/Hr	
Max Daily	2.16	Lbs/day	
Uncontrolled Emission		•	
Max Hourly	2.16	Lbs/Hr	
Max Daily	2.16	Lbs/day	
Current Emission		•	
BACT 30 Day Avg	0.30	Lbs/day	
Annual Emission	108.00	Lbs/year	
District Emission	1304(a)(4) - 10-12-1	•	
Emittant	CO2		
BACT			
Cost effectiveness	NO		
Source Type	MINOR		
Emis Increase	80614.63		
Modelling	N/A		
Public Notice	N		
Controlled Emission	• •		
Max Hourly	1,612.29	Lbs/Hr	
Max Daily	1,612.29	Lbs/day	
Uncontrolled Emission	1,012.23	Loaduy	
Max Hourly	1,612.29	Lbs/Hr	
Max Hourly Max Daily	1,612.29	Lbs/day	
Current Emission	1,012.23	Logiday	
BACT 30 Day Avg		Lbs/day	
Annual Emission	90 614 62	Lbs/year	
District Emission	80,614.63	LD3/yCal	
· · · · · · · · · · · · · · · · · · ·			
Emittant BACT	CO2e		
Cost effectiveness	NO		
*			
Source Type	MINOR		
Emis Increase	80890.002999999 N/A		
Modelling Public Notice	N/A		
	N		
Controlled Emission		l bo/Lle	
Max Hourly		Lbs/Hr	
Max Daily		Lbs/day	
Uncontrolled Emission		h=/ l=	
Max Hourly		Lbs/Hr	
Max Daily		Lbs/day	
Current Emission		11 72	
BACT 30 Day Avg	00.000.00	Lbs/day	
Annual Emission	80,890.00	Lbs/year	
District Emission			

Application No 555370		Company ID	169754
Emittant	GHG		
BACT			
Cost effectiveness	NO		
Source Type	MINOR		
· Emis Increase	80618.607		
Modelling	N/A		
Public Notice	N		
Controlled Emission			
Max Hourly		Lbs/Hr	
Max Daily		Lbs/day	
Uncontrolled Emission			
Max Hourly		Lbs/Hr	
Max Daily		Lbs/day	
Current Emission			
BACT 30 Day Avg		Lbs/day	
Annual Emission	80,618.61	Lbs/year	
District Emission			
Emittant	METHANE		
BACT			
Cost effectiveness	NO		
Source Type	MINOR		
Emis Increase	3.31		
Modelling	N/A		
Public Notice	N		
Controlled Emission			
Max Hourly	0.07	Lbs/Hr	
Max Daily	0.07	Lbs/day	
Uncontrolled Emission			
Max Hourly	0.07	Lbs/Hr	
Max Daily	0.07	Lbs/day	
Current Emission			
BACT 30 Day Avg		Lbs/day	
Annual Emission	3.31	Lbs/year	
District Emission	_		
Emittant	N2O		
BACT			
Cost effectiveness	NO		
Source Type	MINOR		
Emis Increase	0.66		
Modelling	N/A		
Public Notice	N		
Controlled Emission			
Max Hourly	0.01	Lbs/Hr	
Max Daily	0.01	Lbs/day	
Uncontrolled Emission			,
Max Hourly	0.01	Lbs/Hr	
Max Daily	0.01	Lbs/day	
Current Emission			
BACT 30 Day Avg		Lbs/day	
Annual Emission	0.66	Lbs/year	
District Emission			

Emittant BACT Cost effectiveness NO Source Type MA_UOR Emis Increase 1.8 Modelling N/A Public Notice N Controlled Emission Max Hourly 12.98 Lbs/Hr Max Daily 12.98 Lbs/Hr Max Daily 12.98 Lbs/Hr Max Daily 12.98 Lbs/day Uncontrolled Emission BACT 30 Day Avg Annual Emission District Emission Max Hourly N/A Public Notice N Controlled Emission BACT 30 Day Avg Annual Emission Max Hourly N/A Public Notice N Controlled Emission Max Hourly 0.36 Lbs/Hr Max Daily 0.32 Lbs/Hr Max Daily 0.33 Lbs/Hr Max Daily 0.23 Lbs/Hr	Application	on No 555370		Company ID	169754
Cost effectiveness			NOX	· ·	
Source Type			110		
Emis Increase 1.8 Modelling N/A N/A Public Notice N Contrôlled Emission Max Hourly 12.98 Lbs/Hr Max Daily 12.98 Lbs/Hr Max Daily 12.98 Lbs/Hr Max Daily 12.98 Lbs/Hr Max Daily 12.98 Lbs/day	. (+			·	
Modelling				·	
Public Notice		· ·			
Contrölled Emission Max Hourly 12.98 Lbs/Hr Max Daily 12.98 Lbs/day Uncontrolled Emission Max Hourly 12.98 Lbs/day Uncontrolled Emission Max Hourly 12.98 Lbs/day Uncontrolled Emission Emistric Emission Emistric Emission Emistric Emission Emistric Emission Emistric Emission Emistric Emission Emistric Emission Emistric Emission Emistric Emission Emistric Emission Emistric Emission Emistric Emission Emistric Emission Emistric Emission Emistric Emission Emistric Emission Emission					
Max Daily 12.98 Lbs/Hr Max Daily 12.98 Lbs/day Uncontrolled Emission 12.98 Lbs/Hr Max Daily 12.98 Lbs/day Current Emission 1.80 Lbs/day Annual Emission 648.80 Lbs/year District Emission 1304(a)(4) - 10-12-1995 Emittant PM10 BACT Cost effectiveness NO Source Type MINOR Emis Increase 0.05 Modelling N/A Public Notice N Controlled Emission N Max Hourly 0.36 Lbs/Hr Max Daily 0.36 Lbs/Hr Max Hourly 0.36 Lbs/Hr Max Hourly 0.36 Lbs/Hr Max Daily 0.36 Lbs/day Current Emission 18.10 Lbs/day District Emission 18.10 Lbs/day Annual Emission 18.10 Lbs/day Emittant ROG Roc	-		N		
Max Daily	' '	•			
Uncontrolled Emission Max Hourly 12.98					
Max Hourly		•	12.98	Lbs/day	
Max Daily 12.98					
Current Emission					•
BACT 30 Day Avg	' H .		12.98	Lbs/day	
Annual Emission 648.80 Lbs/year District Emission 1304(a)(4) - 10-12-1995					
District Emission	, h			•	
Emittant		•			• ,
BACT Cost effectiveness NO Source Type MINOR Emis Increase 0.05 Modelling N/A Public Notice N Controlled Emission Max Hourly Max Daily Uncontrolled Emission BACT 30 Day Avg BACT Cost effectiveness NO Source Type MINOR Emis Increase 0.32 Modelling N/A Public Notice N Controlled Emission BACT 30 Day Avg Annual Emission BACT Cost effectiveness NO Source Type MINOR Emis Increase 0.32 Modelling N/A Public Notice N Controlled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/Hr	7.	District Emission	1304(a)(4) - 10	<u>-12-1995</u>	<u> </u>
Cost effectiveness			PM10		
Source Type					
Emis Increase No No No	•	Cost effectiveness	NO		
Modelling	, " · ·	Source Type	MINOR		
Public Notice Controlled Emission Max Hourly Max Daily Uncontrolled Emission Max Hourly Max Daily Uncontrolled Emission Max Hourly Max Daily Mix D	. *	Emis Increase	0.05		
Controlled Emission Max Hourly 0.36 Lbs/Hr Max Daily 0.36 Lbs/day		Modelling	N/A		
Max Hourly 0.36 Lbs/Hr Max Daily 0.36 Lbs/day Uncontrolled Emission 0.36 Lbs/Hr Max Daily 0.36 Lbs/day Current Emission 0.05 Lbs/day Annual Emission 18.10 Lbs/year District Emission 1304(a)(4) - 10-12-1995 Emittant ROG RACT Cost effectiveness NO Source Type MiNOR Emis Increase 0.32 Modelling N/A Nodelling Public Notice N Controlled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/Hr Max Daily 0.23 Lbs/Hr Max Daily 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Current Emission BACT 30 Day Avg 0.32 Lbs/day Annual Emission 11.50 Lbs/year		Public Notice	N	•	
Max Daily Uncontrolled Emission Max Hourly Max Daily O.36 Lbs/Hr Max Daily O.36 Lbs/day Current Emission BACT 30 Day Avg Annual Emission District Emission BACT Cost effectiveness NO Source Type MINOR Emis Increase O.32 Modelling N/A Public Notice N Controlled Emission Max Hourly Max Daily Uncontrolled Emission BACT Max Daily O.23 Lbs/Hr Max Daily Uncontrolled Emission Max Hourly Max Daily O.23 Lbs/Hr Max Daily Uncontrolled Emission Max Hourly Max Daily O.23 Lbs/Hr Max Daily O.23 Lbs/Hr Max Daily O.23 Lbs/Hr Max Daily O.23 Lbs/Hr Max Daily O.23 Lbs/Hr Max Daily O.23 Lbs/Hr Max Daily O.23 Lbs/day Uncontrolled Emission BACT 30 Day Avg Annual Emission BACT 30 Day Avg Annual Emission 11.50 Lbs/year		Controlled Emission		•	
Max Daily Uncontrolled Emission Max Hourly Max Daily O.36 Lbs/Hr Max Daily O.36 Lbs/day Current Emission BACT 30 Day Avg Annual Emission District Emission BACT Cost effectiveness NO Source Type MINOR Emis Increase O.32 Modelling N/A Public Notice N Controlled Emission Max Hourly Max Daily Uncontrolled Emission BACT Max Daily O.23 Lbs/Hr Max Daily Uncontrolled Emission Max Hourly Max Daily O.23 Lbs/Hr Max Daily Uncontrolled Emission Max Hourly Max Daily O.23 Lbs/Hr Max Daily O.23 Lbs/Hr Max Daily O.23 Lbs/Hr Max Daily O.23 Lbs/Hr Max Daily O.23 Lbs/Hr Max Daily O.23 Lbs/Hr Max Daily O.23 Lbs/day Uncontrolled Emission BACT 30 Day Avg Annual Emission BACT 30 Day Avg Annual Emission 11.50 Lbs/year	,	Max Hourly	0.36	Lbs/Hr	
Uncontrolled Emission	1		0.36	Lbs/day	
Max Hourly 0.36 Lbs/Hr Max Daily 0.36 Lbs/day Current Emission BACT 30 Day Avg 0.05 Lbs/day Annual Emission 18.10 Lbs/year District Emission 1304(a)(4) - 10-12-1995 Emittant ROG BACT Cost effectiveness NO Source Type Emis Increase 0.32 Modelling N/A Public Notice N Controlled Emission N Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Uncontrolled Emission Max Hourly 0.23 Lbs/day Max Daily 0.23 Lbs/day Current Emission BACT 30 Day Avg 0.32 Lbs/day Annual Emission 11.50 Lbs/year		•		•	
Max Daily		,	0.36	Lbs/Hr	
Current Emission BACT 30 Day Avg Annual Emission District Emission BACT Cost effectiveness NO Source Type MINOR Emis Increase 0.32 Modelling N/A Public Notice Controlled Emission Max Hourly Max Daily Uncontrolled Emission Max Hourly Max Daily Max Hourly Max Daily Current Emission BACT 30 Day Avg Annual Emission BACT 30 Day Avg Annual Emission 18.10 Lbs/day		-			
BACT 30 Day Avg Annual Emission District Emission 1304(a)(4) - 10-12-1995 Emittant BACT Cost effectiveness NO Source Type Minor Emis Increase 0.32 Modelling N/A Public Notice Controlled Emission Max Hourly Max Daily Uncontrolled Emission Max Hourly Max Daily 0.23 Lbs/Hr Max Daily 0.23 Lbs/Hr Max Daily 0.23 Lbs/Hr Max Daily 0.23 Lbs/Hr Max Daily 0.23 Lbs/Hr Max Daily 0.23 Lbs/Hr Max Daily 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Current Emission BACT 30 Day Avg Annual Emission 11.50 Lbs/year					
Annual Emission 18.10 Lbs/year District Emission 1304(a)(4) - 10-12-1995 Emittant ROG BACT Cost effectiveness NO Source Type MINOR Emis Increase 0.32 Modelling N/A Public Notice N Controlled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Uncontrolled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Current Emission BACT 30 Day Avg 0.32 Lbs/day Annual Emission 11.50 Lbs/year	•	· · · · · · · · · · · · · · · · · · ·	0.05	l bs/day	
District Emission 1304(a)(4) - 10-12-1995 Emittant ROG BACT Cost effectiveness NO Source Type MINOR Emis Increase 0.32 Modelling N/A Public Notice N Controlled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Uncontrolled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Current Emission BACT 30 Day Avg 0.32 Lbs/day Annual Emission 11.50 Lbs/year					
Emittant BACT Cost effectiveness NO Source Type MINOR Emis Increase 0.32 Modelling N/A Public Notice N Controlled Emission Max Hourly 0.23 Uncontrolled Emission BACT 30 Day Avg Annual Emission 11.50 NO BACT BACT BACT BACT BACT BACT BACT BACT				-	
BACT Cost effectiveness NO Source Type MINOR Emis Increase 0.32 Modelling N/A Public Notice N Controlled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Uncontrolled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/Hr Max Daily 0.23 Lbs/Hr Max Daily 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Current Emission BACT 30 Day Avg 0.32 Lbs/day Annual Emission 11.50 Lbs/year	•		-		
Cost effectiveness NO Source Type MINOR Emis Increase 0.32 Modelling N/A Public Notice N Controlled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Uncontrolled Emission Max Hourly 0.23 Lbs/Hr Controlled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Current Emission BACT 30 Day Avg 0.32 Lbs/day Annual Emission 11.50 Lbs/year			RUG		
Source Type MINOR Emis Increase 0.32 Modelling N/A Public Notice N Controlled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Uncontrolled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Current Emission BACT 30 Day Avg 0.32 Lbs/day Annual Emission 11.50 Lbs/year		_	NO		
Emis Increase 0.32 Modelling N/A Public Notice N Controlled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Uncontrolled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Current Emission BACT 30 Day Avg Annual Emission 11.50 Lbs/year	* :	· ·			
Modelling N/A Public Notice N Controlled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Uncontrolled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Current Emission BACT 30 Day Avg 0.32 Lbs/day Annual Emission 11.50 Lbs/year					
Public Notice N Controlled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Uncontrolled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Current Emission BACT 30 Day Avg 0.32 Lbs/day Annual Emission 11.50 Lbs/year					•
Controlled Emission Max Hourly Max Daily Uncontrolled Emission Max Hourly Max Daily O.23 Lbs/Hr Max Daily O.23 Lbs/Hr Max Daily Current Emission BACT 30 Day Avg Annual Emission 11.50 Lbs/year					
Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Uncontrolled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Current Emission BACT 30 Day Avg 0.32 Lbs/day Annual Emission 11.50 Lbs/year			N		
Max Daily 0.23 Lbs/day Uncontrolled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Current Emission BACT 30 Day Avg 0.32 Lbs/day Annual Emission 11.50 Lbs/year		- / -			
Uncontrolled Emission Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Current Emission BACT 30 Day Avg Annual Emission 11.50 Lbs/year	•				
Max Hourly 0.23 Lbs/Hr Max Daily 0.23 Lbs/day Current Emission BACT 30 Day Avg 0.32 Lbs/day Annual Emission 11.50 Lbs/year	•	<u>-</u>	0.23	Lbs/day	
Max Daily 0.23 Lbs/day Current Emission BACT 30 Day Avg 0.32 Lbs/day Annual Emission 11.50 Lbs/year	•				
Current Emission BACT 30 Day Avg 0.32 Lbs/day Annual Emission 11.50 Lbs/year	. 1				
BACT 30 Day Avg 0.32 Lbs/day Annual Emission 11.50 Lbs/year	٦.		0.23	Lbs/day	
Annual Emission 11.50 Lbs/year					
•					
District Emission 1304(a)(4) - 10-12-1995					
		District Emission	1304(a)(4) - 10)-12-1995	

Application No 555370		Company ID	169754
Emittant	sox	<u></u>	
BACT			
Cost effectiveness	NO		
Source Type	MINOR		
Emis Increase	0		
Modelling	N/A		
Public Notice	N		
Controlled Emission			
Max Hourly	0.02	Lbs/Hr	
Max Daily	0.02	Lbs/day	
Uncontrolled Emission			
Max Hourly	0.02	Lbs/Hr	,
Max Daily	0.02	Lbs/day	
Current Emission			
BACT 30 Day Avg	0.00	Lbs/day	
Annual Emission	0.80	Lbs/year	
District Emission	1304(a)(4) - 10	-12-1995	. 1

Supervisor's Approval

NVH

Supervisor's Review Date

SCAQMD PERMIT PROCESSING SYSTEM (PPS)

AEIS DATA SHEET

Company Name: OXY USA INC

Facility ID: 169754

Equipment Address: 20101 GOLDENWEST ST

HUNTINGTON BEACH CA 92648

Application Number: 555370

Equipment B-Cat: 043902

Estimated Completion Date: 06/25/14

Equipment C-Cat:

Equipment Type: Basic

Equipment Description: I C E (>500 HP) EM ELEC GEN DIESEL

	Emi	ssions .
Emittants	R1 LB/H _I R	R2 LB/HR
co	2.16	2.16
NOX	12.98	12.98
PM10	0.36	0.36
ROG	0.23	0.23
sox	0.02	0.02

Applicable Rules		
1401	09/10/2010	New Source Review of Toxic Air Contaminants
1470	05/04/2012	Requirements for Stationary Diesel-Fueled Internal Combustion and Other
1472	03/07/2008	Requirements for Facilities with Multiple Stationary Emergency Standby Diesel-Fu
2000	05/06/2005	General (RECLAIM)
3000	11/05/2010	General (Title V)
401	11/09/2001	Visible Emissions
402	05/07/1976	Nuisance
404	02/07/1986	Particulate Matter - Concentration
407	04/02/1982	Liquid and Gaseous Air Contaminants
431.2	09/15/2000	Sulfur Content of Liquid Fuels

	Mon	Tue	Wed	Thu	Fri	Sat	Sun	
Daily Start Times :	08:00	00:00	00:00	00:00	00:00	00:00	00:00	
Daily Stop Times :	09:00	00:00	00:00	00:00	00:00	00:00	00:00	

User's Initials : HS01

Date: 06/25/14

Supervisor's Name :

MKX

Review Date :

7/1/14

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT STATIONARY SOURCE COMPLIANCE APPL. NO. 555370 APPLICATION PROCESSING AND CALCULATIONS PROCESSED BY HS CHECKED BY HS

PERMIT TO CONSTRUCT/OPERATE

COMPANY NAME AND ADDRESS:

OXY USA, INC

MAILING ADDRESS: 11 West Ocean Blvd. #800 Long Beach, CA 90802

ID: 169754

EQUIPMENT LOCATION:

20101 Goldenwest Street Huntington Beach, CA 92648

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT	PAGES 9	PAGE 2
STATIONARY SOURCE COMPLIANCE	APPL. NO.	DATE
	555370	5/18/2014
APPLICATION PROCESSING AND CALCULATIONS	PROCESSED BY	CHECKED BY
	HS	

EQUIPMENT DESCRIPTION:

INTERNAL COMBUSTION ENGINE, CUMMINS, 12 CYLINDERS, TURBOCHARGED, AFTERCOOLED, LEAN BURN, MODEL NO. QST30-G5NR2, SERIAL NO. 37254511, 1490 BHP, DIESEL-FUELED, DRIVING AN EMERGENCY ENGINE.

Equipment	ID No.	Connected To	Source Type/ Monitoring Unit	Emissions And Requirements	Conditions
Process 2: INTERNAL COMB	USTIO	N			
System 2: PLATFORM EMM	Y ENG	INES	•		
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CUMMINS, MODEL OST30- G5-NR2, 1490 BHP A/N:55370	D228		INOX: PROCESS UNIT	CO:2.6 GM/BHP-HR. DIESEL(4): NOX: 469 LBS//1000 GAL DIESEL (1): NOX+ROG: 4.8 GM/BHP-HR DIESEL. (4): PM: 0.15 GM/BHP-HR DIESEL. HR DIESEL (4)	B61.1. C1.6. D12.9, E116.1. H23.11
<u>GENERATOR</u>					

BACKGROUND:

This application A/N 555370 was submitted on 08/20/2013 as a Class I equipment. The applicant indicated that the engine was manufactured on 5/10/2012. The application will be processed and the emissions of the engine will be compared with AQMD BACT emissions limit. The engine will be classified as a Tier 2 diesel engine, since the horsepower is greater than 750 horsepower.

This is a RECLAIM facility (ID 169754), located at 20101 Goldenwest Street, Huntington Beach, Ca. It is a typical Crude Oil/Gas/Water Separation facility. The emergency engine is not located within 1000 feet of a K-12 school (see map attached).

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT	PAGES 9	PAGE 3
STATIONARY SOURCE COMPLIANCE	APPL. NO.	DATE
	555370	5/18/2014
APPLICATION PROCESSING AND CALCULATIONS	PROCESSED BY	CHECKED BY
	HS	

PROCESS DESCRIPTION:

The internal combustion engine is diesel-fueled and drives a generator to produce electricity when there is an emergency. The engine will be allowed to operate at a maximum of 200 hours/year which includes 50 hours/yr for testing and maintenance.

The proposed engine will be located at its offshore operation referred to as Platform Emmy. It will provide emergency back-up power for upcoming drilling operation in the event that the drilling rig loses power.

EMISSIONS:

The emissions calculations will be based on 1 hr/day, 1 day/week and 50 weeks/yr.

The table shows the comparison emission factors for the same engine and AQMD BACT values:

Table – 1 BACT Requirements

	NOx+ROG gm/bhp-hr	CO gm/bhp-hr	PM10 gm/bhp-hr	SOx gm/bhp-hr
Cummins 1490	giii/onp-iii	guvonp-in	gill/onp-iii	gilvonp-iii
hp HP ICE (given)	4.02 NOx=3.95 ROG=0.07	0.66	0.11	0.0049
AQMD BACT Emissions Tier 2.	4.8	2.6	0.15	0.0049 Diesel fuel, sulfur content 0.0015 % by weight
Compliance?	Yes	Yes	Yes	Yes

NOx emissions (ex. cal.) = $3.95 \text{ gm/Bhp-hr} \times 1490 \text{ Bhp} \times 1 \text{ lb/453.593 gm} = 12.98 \text{ lbs/hr} 12.98 \text{ lbs/hr} \times 50 \text{ hrs/hr} = 648.8 \text{ lbs/yr}$

30 day Av. = (12.98 lbs/hr x 1 hr/week x 50 weeks/yr/12 months/yr)/(30 days/month)

 $^{12.98 \}text{ lbs/hr} \times 1 \text{ hr/day} = 12.98 \text{ lbs/day}$

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

STATIONARY SOURCE COMPLIANCE

APPLICATION PROCESSING AND CALCULATIONS

PAGES 9	PAGE 4
APPL, NO.	DATE
555370	5/18/2014
PROCESSED BY	CHECKED BY
l hs	

TT 11 A	\sim .	_		
Table – 2	Criteria	⊢m	1001AN	C
I UUIC Z	CITCLIA		1221611	J

Source	lbs/hr	Lbs/day	lbs/yr	30-Day Av.
NOx	12.98	12.98	648.8	2 (1.80)
ROG	0.230	0.230	11.5	0 (0.32)
СО	2.16	2.16	108	0 (0.30)
PM10	0.36	0.36	18.1	0 (0.05)
SOx	0.020	0.020	0.80	0 (0.002)

b) Greenhouse Gases (GHG)

 $E = FC \times HC \times EF$ [Greenhouse gas equation]

Where:

E = Emission of the given CHG for that type of fuel (grams)

FC = Amount of fuel combusted (gallons/hr)

HC = Heat content of the fuel type (BTU/gallon)

EF = Emission factor of given CHG by type of fuel (grams CHG/BTU)

FC = 20 gall/hr (estimated: 0.05 gal/hp-hr x 399 hp)

HC = 138690 BTU/gallon (diesel)

 $EF-CH_4 = 0.000003 \text{ gm GHG/BTU}$

 $EF-CO_2 = 0.0731 \text{ gm GHG/BTU}$

 $EF-N_2O = 0.0000006 \text{ gm GHG/BTU}$

 $E(CH_4) = (72.2 \text{ gal/hr x } 138690 \text{ BTU x } 0.000003 \text{ gm GHG/BTU})x \text{ lb/453.593 gm}$

= 0.066 lbs/hr

0.066 lbs/hr x 1 hr/day = 0.066 lbs/day

0.066 lbs hr x 50 hrs/yr = 3.311 lbs/yr

30 day ave. = $(0.066 \text{ lbs/hr} \times 50 \text{ hrs/}12 \text{ months})/30 \text{ days/month} = 0.009$

Table 3 - GHG

GHG	lbs/hr	lbs/day	lbs/yr	30-day ave.
CH ₄	0.066	0.066	3.311	0.009
CO ₂	1612.29	1612.29	80614.632	223.93
N ₂ O	0.013	0.013	0.662	0.0018

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT PAGES 9 5 STATIONARY SOURCE COMPLIANCE APPL. NO. 555370 DATE 555370 5/18/2014 APPLICATION PROCESSING AND CALCULATIONS PROCESSED BY HS

Toxic Analysis

Emergency Ice's are exempt from toxic analysis as per Rule 1401(g)(1)(F

RULES EVALUATION:

RULE 212: STANDARDS FOR APPROVING PERMITS

There are no K-12 schools within 1000 feet of the facility. A 30 day public notice is not required. (see map).

RULE 401: VISIBLE EMISSIONS

Based on experience with similar equipment, this engine is expected to comply with the visible emission limits.

RULE 402: NUISANCE

Based on experience with similar equipment, nuisance complaints are not expected.

RULE 404: PARTICULATE MATTER - CONCENTRATION

Based on experience with similar equipment, compliance with this rule is expected.

RULE 407: LIQUID AND GASEOUS AIR CONTAMINANTS

This engine is exempt from this rule as per (b)(1).

RULE 431.2: SULFUR CONTENT OF LIQUID FUELS

Compliance with the 15 PPM or less sulfur limit of the diesel fuel is expected.

RULE 1110.2: EMISSIONS FROM GASEOUS-AND LIQUID-FUELED ENGINES

This engine is exempt from this rule as per (i)(2).

REGULATION XIII: <u>NEW SOURCE REVIEW</u>

BACT:

As per 1303(a)(1), the engine must meet BACT. This engine has to meet the BACT requirements for the engine that was manufactured 1n 2012, Tier 2 (> 750 hp).

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT PAGES 9 6 STATIONARY SOURCE COMPLIANCE APPL. NO. DATE 555370 5/18/2014 APPLICATION PROCESSING AND CALCULATIONS PROCESSED BY HS

According to the "BACT Guidelines for Non-Major Polluting Facilities", the engine is in compliance with all criteria pollutants.

Modeling:

As per 1304(a)(4), this emergency engine is exempt.

Offsets:

Only the NOx criteria emission is greater than 1(lb/day). Regardless, offsets are not required as per Rule 1304(a)(4).

RULE 1401: <u>NEW SOURCE REVIEW OF TOXIC AIR CONTAMINANTS</u> This emergency engine is exempt from this rule as per (g)(1)(F

RULE 1470: REQUIREMENTS FOR STATIONARY DIESEL-FUELED INTERNAL COMBUSTION AND OTHER COMPRESSION IGNITION ENGINES

As an in-use engine, the engine will be allowed to operate 50 hrs/yr for maintenance and testing and 150 hrs/yr for emergency purposes.

RULE 1472: <u>REQUIREMENTS FOR FACILITIES WITH MULTIPLE</u> STATIONARY

EMERGENCY STANDBY DIESEL-FUELED INTERNAL

COMBUSTION

ENGINES

This engine (A/N 555370) is the only stationary emergency diesel-fueled engine at the facility. Based on the above, this rule is not applicable.

REG.XX: REGIONAL CLEAN AIR INCENTIVES MARKET -RECLAIM This is a RECLAIM facility.

REG.XXX: <u>TITLE V PERMITS</u> This is not a Title V facility.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT	PAGES 9	PAGE 7
STATIONARY SOURCE COMPLIANCE	APPL. NO.	DATE
<u>.</u>	<u>5553</u> 70	5/18/2014
APPLICATION PROCESSING AND CALCULATIONS	PROCESSED BY	CHECKED BY
	HS	

RECOMMENDATION:

This equipment is expected to comply with all applicable Rules and Regulations of the District. A Permit to Operate, subject to the following conditions, is recommended:

- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.

H23.11 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
PM10 H2S	District Rule District Rule	1470 431.2
1125	District Rule	131.2

See Facility Permit, Emissions and Requirements section:

NMHC + NOX:

4.80 gm/bhp-hr

CO:

2.6 gm/bhp-hr

PM:

0.15 gm/bhp-hr

C1.6

The operator shall limit the operating time to no more than 200 hour(s) in any one year.

Which includes no more than 50 hours in any one year for maintenance and testing purposes.

The operation of the engine beyond the 50 hours per year allotted for engine

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT PAGES 9 8 STATIONARY SOURCE COMPLIANCE APPL. NO. 555370 DATE 555370 5/18/2014 APPLICATION PROCESSING AND CALCULATIONS PROCESSED BY HS

maintenance and testing shall be allowed only in the event of a loss of grid power or up to 30 minutes prior to a rotating outage, provided that the electrical grid operator or electric utility has ordered rotating outages in the control area where the engine is located or has indicated that it expects to issue such an order at a certain time, and the engine is located in a utility service block that is subject to the rotating outage. Engine operation shall be terminated immediately after the utility distribution company advises that a rotating outage is no longer imminent or in effect.

E116.1

This engine shall not be used as part of a demand response program using interruptible service contract in which a facility receives a payment or reduced rates in return for reducing its electric load on the grid when requested to do so by the utility or the grid operator.

D12.9

The operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the engine

The operator shall keep a log of the engine's operation, documenting the total time the engine is operated each month and specific the reasons for operation, such as:

- A. Emergency use
- B. Maintenance and testing
- C. Other (Describe reason for operating)

In addition, each time the engine is manually started, the log shall include the date of operation, the specific reason for operation, and the totalizing hour meter reading (in hours and tenths of hours) at the beginning and end of operation.

K67.1

The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

On or before January 15 th of each year, the operator shall record in the engine's operating log, the following:

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT	PAGES 9	PAGE 9
STATIONARY SOURCE COMPLIANCE	APPL. NO.	DATE
	555370	5/18/2014
APPLICATION PROCESSING AND CALCULATIONS	PROCESSED BY	CHECKED BY
	HS	

- A. The total hours of operation for the previous calendar year, and
- B. The total hours of engine operation for maintenance and testing for the previous calendar year.

The engine operating log shall be retained on site for a minimum of five calendar years and shall be made available to the executive officer or representative upon request.

OXY USA, INC

ID.

169754

A/N

555370

E = FC * HC * EF

Where:

E = Emission of the given GHG for the type of fuel (grams of GHG)

FC = Amount of Fuel combusted (gallons/hr)


HC = Heat content of the fuel type (BTU/gallon)

EF = Emission Factor of the given GHG by type of fuel (grams GHG/BTU)

FC = 72.2	100% <mark>Ope</mark>	rating	Schedule
HC = 138690		1	hr/day
EF -CH4 = 0.000003		1	day/week
EF -CO2 = 0.0731		50	week/yr
EF -N2O = 0.0000006			

E	CH4	iron CO2	N2O
lb/hr	0.066	1612.29	0.013
lb/day	0.066	1612.29	0.013
30 day ave	0.009	223.93	- 0.0018
lb/γr	3.311	80614.632	0.662

GHG NSR CALCULATOR





General	Combust	ion	
	CHC	F	

GHG Emissions:

CO₂ CH₄ N₂O 0.0 lb/hr 0.00 lb/hr 0.00 lb/hr

Natural Gas Engine

GHG Emissions:

CO₂ CH₄ N₂O 0.0 lb/hr 0.00 lb/hr 0.00 lb/hr

Diesel Engine

GHG Emissions:


CO₂ CH₄ N₂O 1,682.0 lb/hr 0.03 lb/hr 0.02 lb/hr


			GHG Emission Factors				
	GHG	GENERAL CON	GENERAL COMBUSTION		INTERNAL COMBUSTION		
Fuel Type		kg/MMBtu	lb/MMBtu	kg/MMBtu	lb/MMBtu	lb/HP-hr*	
Natural Gas	CO ₂	53.02	116.89	53.02	116.89	0.818215	
	CH₄	0.0009	0.0020	0.0059	0.0130	0.000091	
	N ₂ O	0.0001	0.0002	0.001	0.0022	0.000015	
LPG	CO ₂	62.98	138.85			-	
	CH₄	0.001	0.0022				
	N ₂ O	0.0001	0.0002	i			
Diesel	CO2	73.1	161.16	73.15	161.27	1.12886543	
	CH₄	0.003	0.0066	0.0014	0.0031	0.000022	
	N₂O	0.0006	0.0013	0.001	0.0022	0.000015	
Landfill Gas	CO ₂	52.03	114.71				
	CH₄	0.0009	0.0020			•	
·	N₂O	0.0001	0.0002				

^{*} Average brake specific consumption of 7,000 Btu/hp-hr to convert from lb/MMBtu to lb/hp-hr (Source: Table 3.3-1 Emission Factors for Uncontrolled Gasoline & Diesel Industrial Engines, EPA)

1.61.16 16 +7000 Blee Willisten Tup-L

SOUTH COAS	T AIR QUALITY	MANAGEM	ENT DISTRICT		T			0.4
Certified ICE-	EMERGENCY GI	NERATOR	S (Updated July	3, 2012)	HC	NON	()0	PIVE
DIESEL FUEL EXC	EPT AS SPECIFIED							
QST30-G5	1490 BHP	1000 KW	455112 12/31/201	2 EPA-TIER 2	0.22	4.4	1 0.52	0.08
		-			0,07	3.45	.66	411
				BACT	1.30	(2.6)	2.6	0.07
					A = A		1: (
	Certified ICE- DIESEL FUEL EXC	Certified ICE-EMERGENCY GED DIESEL FUEL EXCEPT AS SPECIFIED	Certified ICE-EMERGENCY GENERATOR DIESEL FUEL EXCEPT AS SPECIFIED	DIESEL FUEL EXCEPT AS SPECIFIED	Certified ICE-EMERGENCY GENERATORS (Updated July 3, 2012) DIESEL FUEL EXCEPT AS SPECIFIED QST30-G5 1490 BHP 1000 KW 455112 12/31/2012 EPA-TIER 2	Certified ICE-EMERGENCY GENERATORS (Updated July 3, 2012) C DIESEL FUEL EXCEPT AS SPECIFIED	Certified ICE-EMERGENCY GENERATORS (Updated July 3, 2012) DIESEL FUEL EXCEPT AS SPECIFIED QST30-G5 1490 BHP 1000 KW 455112 12/31/2012 EPA-TIER 2 0.22 4.4 0.07 3.45	Certified ICE-EMERGENCY GENERATORS (Updated July 3, 2012) DIESEL FUEL EXCEPT AS SPECIFIED QST30-G5 1490 BHP 1000 KW 455112 12/31/2012 EPA-TIER 2 0.22 4.4 1. 0.52 0.01 3.45 6.66







P.O. Box 2900 111 W. Ocean Boulevard, 8TH FLOOR LONG BEACH, CALIFORNIA 90801-2900 TELEPHONE (562) 624-3400 FACSIMILE (562) 624-3299

August 13, 2013

Permit Services South Coast Air Quality Management District 21685 Copley Drive Diamond Bar, CA 91765

Subject:

Application for Permit to Construct/Operate an Emergency IC Engine

OXY USA Inc. / SCAQMD Facility ID 169754

Dear Sirs:

Please find enclosed an application package prepared by our consultant Yorke Engineering, LLC for an emergency internal combustion engine for OXY USA Inc.'s offshore facility (Platform Emmy) in Huntington Beach, CA.

If you have any questions, please feel free to contact me at the number below.

Sincerely,

Diana Lang

Regulatory/Environmental Coordinator

(562) 624-3314

Diana Lang@oxy.com

Enclosures



August 9, 2013

South Coast Air Quality Management District

Attention: Permit Services 21865 Copley Drive Diamond Bar, CA 91765

Subject: Application for Permit to Construct -

One (1) Emergency Internal Combustion Engine

OXY USA INC. - FACILITY ID 169754

To Whom It May Concern:

Attached is an application for Permit to Construct for one (1) emergency internal combustion engine. The application processing fee is shown in the table below.

Table 1: Application Processing Fee

Equipment/Item	Rule 301 Table IA/IB Description	Schedule	Proposed Change	Base Fee
Emergency Internal Combustion Engine	IC Engine, Emergency	В	Permit Processing	\$2,218.39
			Subtotals	\$2,218.39
RECLAIM Facility P	ermit Amendment			\$912.44
			Grand Total	\$3,130.83

The application forms, shown in the table below, can be found in Appendix A of the application.

Table 2: Application Forms

Device / Equipment	Form	Title	
	400-A	Application for Permit or Plan Approval	
Emergency IC Engine	400-E-13a	Emergency Internal Combustion Engine	
	400-PS	Plot Plan and Stack Information Form	
RECLAIM Permit	400-A	Application for Permit or Plan Approval	
Project	400-CEQA	California Environmental Quality Act (CEQA) Applicability	

South Coast Air Quality Management District

Attention: Permit Services

August 9, 2013

Page 2 of 2

Should you have any questions or concerns, please contact James Adams at (949) 248-8490 x231, or Ms. Diana Lang at (562) 331-0378.

Sincerely,

James Adams

Yorke Engineering, LLC

(949) 248-8490 x231

cc:

Diana Lang, OXY USA Inc.

Russ Kingsley, Yorke Engineering, LLC

Enclosures:

1. One (1) Check for \$3,130.83

2. One (1) Application for Permit to Construct for one (1) emergency internal combustion engine

OXY USA Inc. 20101 Goldenwest St. Huntington Beach, CA 92648

SCAQMD Facility ID: 169754

August 2013

Prepared by:



www.YorkeEngr.com

Office Locations: Los Angeles, Orange County, Riverside, Ventura, Fresno, Oakland, Bakersfield

> Tel: (949) 248-8490 Fax: (949) 248-8499

Application for Permit to Construct/ Operate an Emergency IC Engine

Prepared for:

OXY USA Inc. 20101 Goldenwest St. Huntington Beach, CA 92648

SCAQMD Facility ID: 169754

August 2013

Table of Contents

1.0	INTRODUCTION	1
1.1	Facility Information	1
1.2	Application Preparation	
1.3	Proposed Permit Actions	
2.0	EQUIPMENT AND PROCESS DESCRIPTION	4
3.0	EMISSIONS	5
3.1	Emission Factors	5
3.2	Emission Calculations	
4.0	RULE COMPLIANCE EVALUATION	7
4.1	Regulation II – Permits	
	4.1.1 Rule 212 – Standards for Approving Permits and Issuing Public Notice	
4.2	6	
_	4.2.1 Rule 301	
4.3		
	4.3.1 Rule 401 – Visible Emissions	
	4.3.2 Rule 402 – Nuisance	
	4.3.3 Rule 404 – Particulate Matter-Concentration	
	4.3.4 Rule 431.2 – Sulfur Content of Liquid Fuels	ŏ
4.4	6	
	4.4.1 Rule 1110.2 - Emissions from Gaseous - and Liquid-Fueled Engines	
4.5		
	4.5.1 Best Available Control Technology (BACT)	
	4.5.2 Modeling	
	4.5.3 Offsets	
4.6		
	4.6.1 Rule 1401 – New Source Review for Air Toxics	
4	1.6.2 Rule 1470 – Requirements for Stationary Diesel-Fueled Internal Combustion and Other Compression Ignition Engine	i Q
4	4.6.3 Rule 1472 – Requirements for Facilities with Multiple Stationary Emergency	
•	Standby Diesel-Fueled Internal Combustion Engines	9
4.7	Regulation XX – Regional Clean Air Incentives Market (RECLAIM)	
4.8	Regulation XXX – Title V Permits	
4.9	Federal Rules and Regulations	
	4.9.1 40 CFR Part 60, Subpart IIII – Standard of Performance for Stationary	
•	Compression Ignition Internal Combustion Engines	.10
4	4.9.2 Subpart ZZZZ—National Emissions Standards for Hazardous Air Pollutants for	_
·	Stationary Reciprocating Internal Combustion Engines	.11
4.10		

Application for Permit to Construct/Operate an Emergency IC Engine OXY USA Inc.

•	4.10.1	Airborne Toxic Control Measure (ATCM) for Stationary Comp	,
	4.10.2	California Environmental Quality Act (CEQA)	11
5.0	PRO	POSED PERMIT TERMS AND CONDITIONS	12
5.1	Equ	ıipment	12
		posed Conditions	12

List of Figures

Figure 1: O	XY USA Inc.	Huntington Be	each Facility and	Surrounding	Area 2	•
-------------	-------------	---------------	-------------------	-------------	--------	---

List of Tables

Table 1-1:	Facility Information	1
Table 1-2:	Application Preparers	2
	SCAQMD Forms Accompanying This Application	
Table 2-1:	Engine Specifications	4
	Criteria Pollutant Emission Factors	
	Criteria Pollutant Emissions	
Table 4-1:	Rule 212(g) Notification Thresholds	7
Table 4-2:	Permit Processing Fees	8

Appendices

Appendix A – Application Forms

Appendix B - Engine Data

Appendix C – Emission Calculations

Appendix D – Health Risk Assessment

Application for Permit to Construct/Operate an Emergency IC Engine

1.0 INTRODUCTION

OXY USA Inc. (OXY) is proposing to install an emergency IC engine at its Huntington Beach facility. This unit will be located on Platform Emmy and will provide emergency backup power for upcoming drilling operations in the event that the drilling rig loses power. This document contains a complete engineering evaluation for the emergency IC engine.

1.1 Facility Information

Facility contact information is provided in Table 1-1.

Table 1-1: Facility Information

Applicant's Name:	OXY USA Inc.
Facility ID:	169754
Mailing Address:	111 W. Ocean Blvd. Suite 800 Long Beach, CA 90802
Equipment Location 1:	20101 Goldenwest St. Huntington Beach, CA 92648

OXY's Huntington Beach facility is an oil and gas production facility. This facility also includes an off-shore operation, Platform Emmy. The emergency IC engine will be located on Platform Emmy. Figure 1 is a map showing the facility and the surrounding area. Platform Emmy is approximately 1 mile offshore.

MOPKE Engineering, LLC

1

¹ This is the address of the onshore production facility. Approximate geographic coordinates of Platform Emmy are: Lat: 33.3944° N Long: -118.0237 W



Figure 1: OXY USA Inc. Huntington Beach Facility and Surrounding Area

1.2 Application Preparation

This permit application was prepared by Carla Prasetyo Jo and James Adams of Yorke Engineering, LLC. If there are technical questions regarding this application, please contact:

Table 1-2: Application Preparers

Carla Prasetyo Jo, PE			
Yorke Eng	gineering, LLC		
Phone:	(559) 908-6979		
Fax:	(949) 248-8499		
Cellular:	(559) 908-6979		
Email:	cjo@YorkeEngr.com		
James Ad	James Adams, CPP #M6901		
Yorke Engineering, LLC			
Phone:	(949) 248-8490 x231		
Fax:	(949) 248-8499		
Cellular:	(949) 573-7924		
Email:	jadams@YorkeEngr.com		

1.3 Proposed Permit Actions

OXY is proposing to construct and operate an emergency IC engine on Platform Emmy. The proposed IC engine installation also requires a modification to the facility RECLAIM permit. A list of the application forms provided with this application is provided as Table 1-3. The application forms are included in Appendix A.

Table 1-3: SCAQMD Forms Accompanying This Application

Form	Title	Device/Equipment
400-A	Application Form for Permit or Plan Approval	Emergency IC Engine
400-E-13a	Emergency Internal Combustion Engine	Emergency IC Engine
400-PS	Plot Plan and Stack Information Form	Emergency IC Engine
400-A	Application Form for Permit or Plan Approval	RECLAIM Permit
400-CEQA	California Environmental Quality Act (CEQA) Applicability	Project
400-XPP	Expedited Permit Processing	Project-

2.0 EQUIPMENT AND PROCESS DESCRIPTION

The emergency IC engine will be used to provide emergency backup power to upcoming drilling operations on Platform Emmy in the event that the drill rig loses power. In addition, the emergency IC engine will be operated for maintenance and testing purposes. Engine specifications are listed in Table 2-1. Pictures of the engine nameplate are included in Appendix B. Appendix B also contains some general engine documentation.

Table 2-1: Engine Specifications

Parameter	Value
Manufacturer	Cummins
Model	QST30-G5 NR2
Serial No.	37254511
Engine Family Number	ACEXL060.AAD
Engine Output	1490 HP
Tier	2

OXY proposes to limit the maximum annual maintenance and testing operation to no more than 50 hours per calendar year per Rule 1470(c)(2)(C)(i) and no more than 2.7 hours per day in order for the MDC NOx emissions to remain below the Rule 212(g) threshold of 40 lb/day. In addition, OXY is proposing to limit the total hours of operation to no more than 200 hours per calendar year. These operating limits are reflected in the proposed permit conditions that are shown in Section 5.0.

3.0 EMISSIONS

3.1 Emission Factors

The emergency IC engine will combust diesel fuel, and will result in the emissions of VOC, NOx, CO, PM10, and SOx. The emergency IC engine is a certified tier 2 engine, rated at 1490 HP. The VOC, NOx, and CO, and PM10 emission factors for this unit will be based on the tier 2 standards for an engine greater than 750 HP. The SOx emissions were calculated based on 0.0015 percent sulfur by weight in the fuel. The criteria pollutant emission factors are shown in Table 3-1.

Table 3-1: Criteria Pollutant Emission Factors

Pollutant	Emission Factor (g/hp-hr)
Nitrogen Oxides (NOx) + Volatile Organic Compound (VOC)	4.8
Nitrogen Oxides (NOx)	4.5 ¹
Volatile Organic Compound (VOC)	0.301
Sulfur Oxides (SOx)	0.005 ²
Carbon Monoxide (CO)	2.6
Particulate Matter (PM10)	0:15

^{1.} Per the Carl Moyer program guidance, NOx is assumed to be 95% of the NOx + VOC emission factor, and VOC is assumed to be 5%.

The emergency IC engine will combust diesel fuel, and result in the emissions of toxic air contaminants (TAC). However, since subparagraph (g)(1)(F) of Rule 1401 exempts emergency internal combustion engines from new source review for TAC, TAC emission calculations are not provided with this application.

3.2 Emission Calculations

The emergency IC engine will combust diesel fuel, and result in the emissions of VOC, NOx, CO, PM10, and SOx. Pursuant to the SCAQMD's Policy and Procedures EC-02-09 ("Emergency Standby Diesel IC Engine Maintenance & Testing Hours", dated February 24, 2009), in determining an emergency engine's potential to emit under Regulation XIII, emissions are to be based on the annual testing and maintenance hours, in this case, 50 hours per year. Calculation details are included in Appendix C. A summary of emissions is shown in Table 3-2.

^{2.} The calculation from weight percent sulfur in the fuel to g/hp-hr is provided in Appendix C.

Table 3-2: Criteria Pollutant Emissions

Criteria Pollutant	AHU (lb/hr)	AHC (lb/hr)	MHU (lb/hr)	MHC (lb/hr)	MDU (lb/day)	MDC (lb/day)	AA (lb/yr)	30DA (lb/day)
NOx	14.769	14.769	14.769	14.769	39.88	39.88	738.5	2.05
VOC	0.985	0.985	0.985	0.985	2.66	2.66	49.3	0.14
SOx	0.016	0.016	0.016	0.016	0.04	0.04	0,8	0.00
СО	8.533	8.533	8.533	8.533	23.04	23.04	426.7	1.19
PM10	0.492	0.492	0.492	0.492	1.33	1.33	24.6	0.07

4.0 RULE COMPLIANCE EVALUATION

4.1 Regulation II - Permits

4.1.1 Rule 212 - Standards for Approving Permits and Issuing Public Notice

Rule 212 requires public notification for all new or modified permit units that may emit air contaminants located within 1,000 feet from the outer boundary of a school, all new or modified permit units that may emit air contaminants in excess of the limits shown in subdivision (g) of the rule or 3 pounds per day of lead, and all new or modified permit units that may emit TAC listed in Rule 1401 with an individual lifetime cancer risk greater than one in one million or greater than ten in one million with TBACT.

Table 4-1 compares the emission increases associated with the proposed unit to the thresholds from subdivision (g) of Rule 212. As shown, the emission increases associated with this project are less than the notification thresholds.

Table 4-1: Rule 212(g) Notification Thresholds

Permit Unit	Pollutant	Emissions (MDC) (lb/day)	Rule 212 Notification Threshold (lb/day)	Public Notice Required? (Yes/No)
_	NOx	39.88	40	No
F	SOx	0.04	60	No
Emergency IC Engine	СО	23.04	220	No
Engine	VOC	2.66	30	No
	PM10	1.33	30	No

Although the engine is exempt from Rule 1401 per subparagraph (g)(1)(F) of that rule, a tier 2 screening health risk assessment (HRA) was performed for the project using the SCAQMD risk calculator spreadsheet. Diesel particulate matter (DPM) emissions were assumed to be equal to PM10 emissions from the engine. The HRA demonstrates that the health risk from engine emissions will not exceed Rule 212 thresholds for notification. The HRA worksheets are provided in Appendix D. The engine will not be installed within 1000 feet of a school. Based on these factors, public notice is not required for this application.

4.2 Regulation III - Fees

4.2.1 Rule 301 - Permitting and Associated Fees

The processing fees were determined using Rule 301; fees are summarized in Table 4-2.

Table 4-2: Permit Processing Fees

Equipment/Item	Rule 301 Table IA/IB Description	Schedule	Permit Action	Base Fee			
Emergency IC Engine	IC Engine, Emergency	В	Permit Processing	\$2,218.39			
		<u>.</u>	Subtotal	\$2,218.39			
RECLAIM Facility Permit Amendment							
-	-	<u>-</u>	Total	\$3,130.83			

4.3 Regulation IV – Prohibitions

4.3.1 Rule 401 - Visible Emissions

No visible air contaminant with 20 percent opacity or greater is expected to be released to the atmosphere for a period or periods aggregating more than three minutes in any one hour from the operation of the emergency IC engine; therefore, compliance with this rule is expected.

4.3.2 Rule 402 - Nuisance

The proposed emergency IC engine is not expected to result in a nuisance, as defined in Rule 402, to the public; therefore, compliance with this rule is expected.

4.3.3 Rule 404 - Particulate Matter-Concentration

The operation of the emergency IC engine is expected to comply with this rule.

4.3.4 Rule 431.2 - Sulfur Content of Liquid Fuels

The emergency IC engine will be fueled with CARB diesel. Therefore, compliance with this rule is expected.

4.4 Regulation XI - Source Specific Standards

4.4.1 Rule 1110.2 - Emissions from Gaseous - and Liquid-Fueled Engines

This unit will be exempt from subdivision (d) of the rule per paragraph (i)(2). This provides an indirect exemption from the other requirements of the rule.

4.5 Regulation XIII - New Source Review

4.5.1 Best Available Control Technology (BACT)

BACT must be applied to all new and modified permit units when the net increase in emissions of any nonattainment air contaminant, ozone depleting compound or ammonia is equal to 1.0 pounds per day or higher.

The maximum daily emissions of VOC, PM10, CO and SO_X from the emergency IC engine are estimated to be greater than 1.0 pounds/day per pollutant, thus BACT is required. BACT for stationary emergency IC engine rated at greater than 750 HP is tier 2^2 . Since the emergency IC engine proposed is a certified tier 2 IC engine, compliance with BACT is demonstrated. [Note: Since Oxy is a RECLAIM facility, NOx BACT is discussed in Section 4.7 of this application.

² SCAQMD Best Available Control Technology (BACT) Guidelines for Non-Major Polluting Facilities, Part D, I.C. Engine, Stationary, Emergency, 10-3-2008, Rev. 4, page 69.

4.5.2 Modeling

The Executive Officer or designee shall, except as Rule 1304 applies, deny the permit to construct for any new or modified source which results in a net emission increase of any nonattainment air contaminant at a facility, unless the applicant substantiates with modeling that the modification will not cause a violation, or make significantly worse an existing violation according to Appendix A or other analysis approved by the Executive Officer or designee, of any state or national ambient air quality standards at any receptor location in the District.

Pursuant to Rule 1304(a)(4), an emergency IC engine is exempt from the modeling and offsets requirements. Since the unit is exclusively used as emergency standby equipment, and limited to no more than 200 hours per year for emergency, maintenance, and testing operations, this emergency IC engine is exempt from modeling.

4.5.3 Offsets

The Executive Officer or designee shall, except as Rule 1304 applies, deny the permit to construct for any new or modified source which results in a net emission increase of any nonattainment air contaminant at a facility, unless the applicant offsets the emission increases by either Emission Reduction Credits (ERCs) approved pursuant to Rule 1309, or by allocations from the Priority Reserve in accordance with provisions of Rule 1309.1 or allocations from the Offset Budget in accordance with the provisions of Rule 1309.2.

Pursuant to Rule 1304(a)(4), an emergency IC engine is exempt from the modeling and offsets requirements. Since the unit is exclusively used as emergency standby equipment, and limited to no more than 200 hours per year for emergency, maintenance, and testing operations, this emergency IC engine is exempt from offsets.

4.6 Regulation XIV - Toxics and Other Non-Criteria Pollutants

4.6.1 Rule 1401 - New Source Review for Air Toxics

Rule 1401 applies to new, relocated, and modified permit units. However, pursuant to subparagraph (g)(1)(F) of Rule 1401, emergency IC engines are exempt from new source review of toxic air contaminants. Therefore, no further assessment for Rule 1401 is included.

4.6.2 Rule 1470 – Requirements for Stationary Diesel-Fueled Internal Combustion and Other Compression Ignition Engine

Rule 1470 is applicable to any person who owns or operates a stationary compression ignition (CI) engine in the SCAQMD with a rated brake horsepower greater than 50. Pursuant to the definition of new and in-use IC engine, as stated in Paragraph (b)(37) and (b)(47) of this rule, the proposed emergency IC engine falls under the category of new engine. Subparagraph (c)(3)(C) of this rule limits the hours of operation for maintenance and testing purposes for new stationary emergency standby diesel-fueled CI engine (>50 bhp) to 50 hours/year.

OXY proposes to limit the maintenance and testing operation to no more than 50 hours/year. The emergency IC engine is a certified tier 2 engine rated at 1490 HP. This engine is expected to meet the requirements of this rule.

4.6.3 Rule 1472 – Requirements for Facilities with Multiple Stationary Emergency Standby Diesel-Fueled Internal Combustion Engines

There is currently one emergency generator on Platform Emmy. With one additional generator, Emmy will contain one less emergency generator than the minimum required to form an engine group. The proposed unit will not cause the facility to become subject to the requirements of Rule 1472.

4.7 Regulation XX – Regional Clean Air Incentives Market (RECLAIM)

OXY is a NOX RECLAIM facility. The proposed new emergency IC engine is considered emergency standby equipment. Therefore, it will be classified as a NOX process unit. This engine will be equipped with an hour meter to comply with the requirements of Rule 2012.

Pursuant to paragraph (k)(5) of Rule 2005, the requirements under subparagraphs (b)(1)(B) and (c)(1)(B), and clause (c)(4)(A)(ii) do not apply to equipment used exclusively on a standby basis for non-utility electrical power generation or any other equipment used on a standby basis in case of emergency, provided the source does not operate more than 200 hours per year as evidenced by an engine-hour meter or equivalent method and is listed as emergency equipment in the Facility Permit. The proposed emergency IC engine meets the requirements for exemption under paragraph (k)(5), and is exempt from modeling requirements under Rule 2005.

The maximum daily emissions of NOx from the emergency IC engine is estimated to be greater than 1.0 pounds/day, thus BACT is required. BACT for stationary emergency IC engine rated at greater than 750 HP is tier 2³. Since the emergency IC engine proposed is a certified tier 2 IC engine, compliance with BACT is demonstrated.

The expected NOx emission increase associated with the engine is 738 lb/year (maintenance and testing only). The facility holds sufficient RTCs to offset the emission increase for the first year of operation.

4.8 Regulation XXX - Title V Permits

OXY maintains exemption from the requirements of the Title V program by complying with Facility Condition F30.1, which limits the emissions of NOx and VOC from the relevant sources to no more than 10 tons in any rolling 12 calendar-month period. OXY proposes to maintain compliance with the NOx and VOC limits as required under Facility Condition F30.1. Therefore, OXY is expected to continue to be exempt from the requirements of the Title V program.

4.9 Federal Rules and Regulations

4.9.1 40 CFR Part 60, Subpart IIII – Standard of Performance for Stationary Compression Ignition Internal Combustion Engines

This Code of Federal Regulation (CFR) is applicable to owners and operators of stationary CI engine that commence construction after July 11, 2005. Since the proposed emergency IC engine was constructed in 2012, this rule applies to this emergency IC engine.

Pursuant to §60.4205 (b), owners and operators of 2007 model year and later emergency stationary CI ICE with a displacement of less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards for new non-road CI engines in §60.4202, for

³ SCAQMD Best Available Control Technology (BACT) Guidelines for Non-Major Polluting Facilities, Part D, I.C. Engine, Stationary, Emergency, 10-3-2008 Rev. 4, page 69.

all pollutants, for the same model year and maximum engine power for their 2007 model year and later emergency stationary CI IC engine. The proposed emergency IC engine is a certified tier 2 IC engine. Therefore, the emergency IC engine complies with the emission standards for new non-road CI engines in §60.4202.

Pursuant to § 60.4207 (b), beginning October 1, 2010, owners and operators of stationary CI IC engine subject to this subpart with a displacement of less than 30 liters per cylinder that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 80.510(b) for non-road diesel fuel. The proposed emergency IC engine will be fueled with CARB diesel fuel, which meets the requirements of 40 CFR 80.510(b) for non-road diesel fuel.

Pursuant to §60.4209 (b), emergency stationary CIIC engines is required to be equipped with a non-resettable hour meter prior to startup of the engine. The proposed emergency IC engine will be equipped with a non-resettable hour meter. Therefore, the proposed emergency IC engine is expected to be in compliance with this subpart.

4.9.2 Subpart ZZZZ—National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

An engine is subject to this subpart if it is a stationary reciprocating IC engine (RICE) at a major or area source of HAP emissions. Oxy Huntington Beach and Platform Emmy is an area source of HAP.

Pursuant to § 63.6590(c), a new or reconstructed stationary RICE located at an area source must meet the requirements of Subpart ZZZZ by meeting the requirements of 40 CFR part 60 subpart IIII. No further requirements apply for such engines under this part.

As shown in Section 4.9.1 of this application, the proposed emergency engine complies with Subpart IIII, thus compliance with Subpart ZZZZ is demonstrated.

4.10 California State Rules and Regulations

4.10.1 Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition (CI) Engines

This ATCM is a California regulation established by the California Air Resources Board (ARB) to reduce diesel PM and criteria pollutant emissions from stationary diesel-fueled CI engine and applies to any person who owns or operates a stationary CI engine in California with a brake horsepower (bhp) rating greater than 50. Since the proposed IC engine is rated at 1490 HP, the IC engine is subject to this ATCM.

The proposed IC engine is a tier 2 certified IC engine, which meets the ATCM standards. The emergency IC engine will be fueled with CARB diesel, which meets the fuel requirements of the ATCM. OXY proposes to limit the maintenance and testing operation to 50 hours annually to meet the ATCM requirements.

4.10.2 California Environmental Quality Act (CEQA)

The requested permit actions are ministerial in nature and, therefore, are not subject to additional review under CEQA. A completed form 400-CEQA is included in Appendix A.

5.0 PROPOSED PERMIT TERMS AND CONDITIONS

5.1 Equipment

We request that a permit to construct/ operate be issued with the following proposed wording.

Equipment	ID No.	Connected To	RECLAIM Source Type/Monitoring Unit	Emissions and Requirements	Conditions
EMERGENCY INTERNAL COMBUSTION ENGINE, CUMMINS, MODEL QST30-G5 NR2, SERIAL NO.: 37254511, DIESEL FUELED, 1490 HP, DRIVING AN EMERGENCY ELECTRICAL GENERATOR	Dxx		NOX: PROCESS UNIT	NOX: 14.77 LBS/HR ⁴ (1)	(1), (2), (3), (4) (as shown below)

5.2 Proposed Conditions

- 1. THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR.
- 2. THIS ENGINE SHALL NOT OPERATE MORE THAN 50 HOURS IN ANY ONE YEAR AND 2.7 HOURS IN ANY ONE DAY FOR MAINTENANCE AND TESTING PURPOSES.
- 3. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
- 4. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME, IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF TWO YEARS AND BE MADE AVAILABLE TO THE SCAQMD. PERSONNEL UPON REQUEST.

^{4 (4.5} g/bhp-hr) / (454 g/lb) x (1,490 bhp)

APPENDIX A – APPLICATION FORMS

Appendix A – Schedule of Forms

Device/Equipment	Form		
	400-A	Application Form for Permit or Plan Approval	
Emergency IC Engine	400-E-13a	Emergency Internal Combustion Engine	
	400-PS	Plot Plan and Stack Information Form	
RECLAIM Permit	400-A	Application Form for Permit or Plan Approval	
Project	400-CEQA	California Environmental Quality Act (CEQA) Applicability	

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT ENGINEERING AND COMPLIANCE WORKSHEET APPLICATION PROCESSING AND CALCULATIONS PAGE 2 of 3 CHECKED BY: A/N: PROCESSED BY: DATE:

CONDITIONS


- 1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
- 2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
- 3. THIS ENGINE SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 431.2 AND RULE 1470.
- 4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING AND NO MORE THAN 4.2 HOURS IN ANY ONE MONTH FOR MAINTENANCE AND TESTING.
- 5. OPERATING BEYOND THE 50 HOURS PER YEAR ALLOTED FOR MAINTENANCE AND TESTING PURPOSES SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
- 6. AN OPERATIONAL NON-RESERVABLE SCAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
- 7. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED, DOCUMENTING THE TOTAL TIME THE ENGINE'S OPERATED EACH MONTH AND SPECIFIC REASON FOR OPERATION AS:
 - A. EMERGENCY USE,
 - B. MAINTENANCE AND TESTING.
 - C. OTHER (DESCRIBE THE REASON FOR OPERATING).

IN ADDITION, EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND END OF OPERATION.

	PAGE	3 of 3	
SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT	CHECKED BY:		For
ENGINEERING AND COMPLIANCE	A/N:		Official
APPLICATION PROCESSING AND CALCULATIONS	PROCESSED BY:		Use Only
AT LICATION TROCESOING AND CALCODATIONS	DATE:		•

- 8. ON OR BEFORE JANUARY 15TH OF EACH YEAR, THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG THE FOLLOWING:
 - A. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
 - B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

THE ENGINE OPERATING LOG SHALL BE RETAINED ON SITE FOR A MINIMUM OF THREE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.



South Coast Air Quality Management District

Form 400-PS

Plot Plan And Stack Information Form

This form must be accompanied by a completed Application for a Permit to Construct/Operate - Form 400A and Form 400-CEQA.

Mail To: SCAQMD P.O. Box 4944 Diamond Bar, CA 91765-0944

> Tel: (909) 396-3385 www.aqmd.gov

Section A - Operator Info	rmation							
Facility Name (Business Name Oxy USA Inc.	of Operator To Appears On The Permit): Valid AQMD Facility ID (Available On Permit Or Invoice Issued By AQMD): 169754							
Address where the equipmen	t will be operated (for equipment which will be moved to various location in AQMD's jurisdiction, please list the initial location site):							
Piatform Emmy (offs	shore, Huntington Beach) © Fixed Location O Various Locations							
Section B - Location Date								
Plot Plan	Please attach a site map for the project with distances and scales. Identify and locate the proposed equipment on the map. A copy of the appropriate Thomas Brothers page, a web-based map, or a sketch that shows the major streets and location of the equipment is acceptable.							
	Is the facility located within a 1/4 mile radius (1,320 feet) of the outer boundary of a school? Yes No If yes, please provide name(s) of school(s) below: School Name: School Name:							
Location of Schools Nearby	School Address: School Address:							
Estation of California and	Distance from stack or equipment vent to the outer boundary of the school: CA Health & Safety Code 42301.9: "School" means any public or private school used for purposes of the education of more than 12 children in kindergarten or any of grades 1 to 12, inclusive, but does not include any private school in which education is primarily conducted in private homes.							
Population Density	O Urban Rural (<50% of land within 3 km radius accounted for by urban land use categories, i.e., multi-family dwelling or industrial.)							
Zoning Classification	○ Mixed Use Residential Commercial Zone (M-U) ○ Service and Professional Zone (C-S) ○ Medium Commercial (C-3) ○ Heavy Commercial (C-4) ⑤ Commercial Manufacturing (C-M)							
Section C - Emission Rel	ease Parameters - Stacks, Vents							
Stack Data	Stack Height: 75.00 feet (above ground level) What is the height of the closest building nearest the stack? 20 feet Stack Inside Diameter: inches: Stack Flow: 325,577 acfm Stack Temperature: 850 °F Rain Cap Present: ① Yes ② No Stack Orientation: ② Vertical ① Horizontal If the stack height is less than 2.5 times the closest building height (H), please provide information on any building within 5xH distance from the stack (altach additional sheet if necessary):							
	Building #/Name:							
Receptor Distance From Equipment Stack or Roof Vents/Openings	Building Length:feet							
Building Information	Are the emissions released from vents and/or openings from a building? Yes No If yes, please provide: Building #Name: Building Width: feet Building Height: feet (above ground level) Building Length: feet							

South Coast Air Quality Management District

Form 400-PS

Plot Plan And Stack Information Form

This form must be accompanied by a completed Application for a Permit to Construct/Operate - Form 400A and Form 400-CEQA.

I hereby certify that all information contained	herein and information submitted	d with this application is true and correct.	
Signature of Preparer:	Title of Preparer:	Preparer's Phone #: (805) 376-0088	
Russ Kingsley Off Control Regulation of Solid Control	Principal Engineer	Preparer's Email: RKingsley@	
Contact Person: Diana Lang	Contact's	Phone#: (562) 624-3314	Date Signed: 07/20/2013
Contact's Email: diana_lang@oxy.com	Contact's	Fax#: (562) 624-3224	
claim certain limited Information as exempt from Act, you must make such claim <u>at the time of sul</u>	our permit application and any suppli disclosure because it qualifies as a	IIS IS A PUBLIC DOCUMENT emental documentation are public records and ma trade secret, as defined in the District's Guidelines	y be disclosed to a third party. If you wish to for Implementing the California Public Recor



ڪ '..

South Coast Air Quality Management District Form 400 - XPP

Express Permit Processing Request
Form 400-A, Form 400-CEQA and one or more 400-E-xx form(s) must accompany all submittals.

Mail To: SCAQMD P.O Box 4944 Diamond Bar, CA 91765-0944

Tel: (909) 396-3385 www.aqmd.gov

Section A - Operator Information						
1. Facility Name (Business Name of Operati	or To Appear On The Permit):	2. Valid AQMD Facility ID AQMD):	(Available On Permit Or Invoice Issued By			
Oxy USA Inc.			169754			
Section B - Equipment Location Add	iress	Section C - Permit Mailing Address				
1 3 7.	Various Location (cations, provide address of initial site.)	4. Permit and Correspondence Information: Check here if same as equipment location address				
20101 Goldenwest St.		111 W. Ocean Blvd. #800				
#* 14	GA 92648	1	CA 90802			
Hüntington Beach	, CA	Long Beach	, <u>CA</u> <u>90802</u>			
ļ	Env. Coordinatir	Diana Lang	Env. Coordinatir			
Diana Lang	Title	Contact Name	Title			
(562) 624-3314	(562) 624-3224	(562) 624-3314	(562) 624-3224			
Phone # Ext.	Fax #	Phone # Ext.	Fax #			
diana_lang@oxy.com		diana_lang@oxy.com				
E-Mail		E-Mail				
Section D' - Authorization/Signature						
and that the application may Permit Processing neither g Express Permit Processing	y be subject to additional fe juarantees action by any sp is subject to availability of ited fees will not be refunde	must be submitted at the time ses per Rule 301. I understand to secific date nor does it guarante qualified staff; and that once Exed. I hereby certify that all information and correct.	hat requests for Express e permit approval; that press Permit Processing			
5. Signature of Responsible Official:		6. Title of Responsible Official:				
Mach S. Ka	pelhe	VP - Eng and Ops				
7. Print Name of Responsible Official:		8. Date:				
Mark Kapelke		8/13/201=	<u> </u>			
9. Phone #: (562) 495-9348		10. Fax #: (562) 495-1950				

AQMD USE ONLY		PLICAT	TION TRACKIN	IG#		TYPE B C	EQUIPMEN	NT CATEGORY CODE:	FEE SCHEDULE:	V	ALIDATION
ENG. A	4	R	ENG. DATE	A	R	CLASS I III	ASSIGNME Unit	NT Engineer	CHECK/MONEY ORDER	AMOUNT \$	TRACKING #

AQMIZA

South Coast Air Quality Management District

Form 400-CEQA

California Environmental Quality Act (CEQA) Applicability

Mail To: SCAQMD P.O. Box 4944 Diamond Bar, CA 91765-0944

> Tel: (909) 396-3385 www.agmd.gov

The SCAQMD is required by state law, the California Environmental Quality Act (CEQA), to review discretionary permit project applications for potential air quality and other environmental impacts. This form is a screening tool to assist the SCAQMD in clarifying whether or not the project has the potential to generate significant adverse environmental impacts that might require preparation of a CEQA document [CEQA Guidelines §15060(a)]. Refer to the attached instructions for guidance in completing this form. For each Form 400-A application, also complete and submit one Form 400-CEQA. If submitting multiple Form 400-A applications for the same project at the same time, only one 400-CEQA form is necessary for the entire project. If you need assistance completing this form, contact Permit Services at (909) 396-3385 or (909) 396-2668.

Section	n A - F	acility	ty Information							
1. Facility Name (Business Name of Operator To Appear On The Permit): 2. Valid AQMD Facility ID (Available On Permit Or Invoice										
OXY USA Inc. By AQMD); 169754										
3. Proi	ect Des	criptio	lon:							
		-	of a new emergency IC engine.							
1110	J.Canicati	011 01	A HOW CINCINGS TO CINGING.							
Section	n B - f	Review	w For Exemption From Further CEQA Action	==						
-			as applicable							
ĺ	Yes	No	Is this application for:							
1.	۲	•	A CEQA and/or NEPA document previously or currently prepared that specifically evaluates this project? If yes, attach a co signed Notice of Determination to this form.	A CEQA and/or NEPA document previously or currently prepared that specifically evaluates this project? If yes, attach a copy of the						
2.	C	•	A request for a change of permittee only (without equipment modifications)?							
3.	7	•	A functionally identical permit unit replacement with no increase in rating or emissions?							
4.	C	•	A change of dally VOC permit limit to a monthly VOC permit limit?	_						
5.	ر	•	Equipment damaged as a result of a disaster during state of emergency?	Equipment damaged as a result of a disaster during state of emergency?						
6.	٦	•	A Title V (i.e., Regulation XXX) permit renewal (without equipment modifications)?							
7.	С	•	A Title V administrative permit revision?							
8.	7	•	The conversion of an existing permit into an initial Title V permit?							
			for any question In Section B, your application does not require additional evaluation for CEQA applicability. Skip to Section D - Signati Id date this form.	ires on						
Sectio	n C - I	Review	w of Impacts Which May Trigger CEQA							
	ete Parl tach it to		by checking "Yes" or "No" as applicable. To avoid delays in processing your application(s), explain all "Yes" responses on a separate form.	sheet						
	Yes	No	Part I - General							
1.			Has this project generated any known public controversy regarding potential adverse impacts that may be generated by the	е						
	(•	project? Controversy may be construed as concerns raised by local groups at public meetings; adverse media attention such as negative arti	cles in						
			newspapers or other periodical publications, local news programs, environmental justice issues, etc.							
2.	ر	•	Is this project part of a larger project? If yes, attach a separate sheet to briefly describe the larger project.	Is this project part of a larger project? If yes, attach a separate sheet to briefly describe the larger project.						
			Part II - Air Quality							
3.	١	•	Will there be any demolition, excavating, and/or grading construction activities that encompass an area exceeding 20,000 s feet?	quare						
4.	C	•	Does this project include the open outdoor storage of dry bulk solid materials that could generate dust? If Yes, include a pl with the application package.	ot plan						
			·							

¹ A "project" means the whole of an action which has a potential for resulting in physical change to the environment, including construction activities, clearing or grading of land, improvements to existing structures, and activities or equipment. Involving the Issuance of a permit. For example, a project might include installation of a new, or modification of an existing internal combustion engine, dry-cleaning facility, boiler, gas turbine, spray coating booth, solvent cleaning tank, etc.

² To download the CEQA guidelines, visit http://ceres.ca.gov/env_law/state.html.

³ To download this form and the instructions, visit http://www.aqmd.gov/ceqa or http://www.aqmd.gov/permit

Section	on C -	Review	of Impacts Which	May Trigger CEQA (cont.)							
	Yes	No	Part II - Air Quality	y (cont.)							
5.	C	•	For example, comp	Nould this project result in noticeable off-site odors from activities that may not be subject to SCAQMD permit requirements? For example, compost materials or other types of greenwaste (i.e., lawn clippings, tree trimmings, etc.) have the potential to generate odor complaints subject to Rule 402 – Nuisance. Does this project cause an increase of emissions from marine vessels, trains and/or airplanes?							
6.	C	•	L								
7.	С	•		Will the proposed project increase the QUANTITY of hazardous materials stored aboveground onsite or transported by mobile vehicle to or from the site by greater than or equal to the amounts associated with each compound on the attached Table 1?4							
			Part III – Water Re	sources,							
8.	C	œ.	The following exam generate steam; 2) production process exceeds the capaci existing water supp	Will the project Increase demand for water at the facility by more than 5,000,000 gallons per day? The following examples identify some, but not all, types of projects that may result in a "yes" answer to this question: 1) projects that penerate steam; 2) projects that use water as part of the air pollution control equipment; 3) projects that require water as part of the production process; 4) projects that require new or expansion of existing sewage treatment facilities; 5) projects where water demand exceeds the capacity of the local water purveyor to supply sufficient water for the project; and 6) projects that require new or expansion of existing water supply facilities.							
9.	۲	•	Examples of such p		eyance Infrastructure? d the capacity of the local water purveyor to supply sufficient water for the les such that the project requires new water lines, sewage lines, sewage hook-						
			Part IV – Transpoi								
10.				sult in (Check all that apply):							
	۲	•	L	ore than 350 new employees?							
İ	<u>_</u>	6			ind/or from the facility by more than 350 truck round-trips per day?						
<u> </u>	٢	•		mer traffic by more than 700 visits pe	r day r						
44	-		Part V - Noise	aliida aasilamaas shasiiidda aaaaasa wa	olse GREATER THAN 90 decibels (dB) at the property line?						
11.	<u> </u>	(6)		• • •	700 ONEST TIME 30 decides (ab) at the property lines						
12.	Ι		Part VI - Public Se		ditional public services in any of the following areas (Check all that apply):						
12.	_	6		•	tential amount of wastes generated by the project is less than five tons per day.						
	r	(b. Hazardous was		ed potential amount of hazardous wastes generated by the project is less than 42						
REM	NDER:	or each	"Yes" response in Sec	tion C, attach all pertinent information includi	ng but not limited to estimated quantities, volumes, weights, etc.						
Section	n D -	Signati	ires								
CORR RIGH	ECT TO	THE CHISIDE	BEST OF MY KNOW R OTHER PERTINE	NLEDGE. I UNDERSTAND THAT THIS ENT INFORMATION IN DETERMINING	ID INFORMATION SUBMITTED WITH THIS APPLICATION IS TRUE AND S FORM IS A SCREENING TOOL AND THAT THE SCAQMD RESERVES THE CEQA APPLICABILITY.						
1. Sign			sible Official of Firm:		2. Title of Responsible Official of Firm:						
ے	ÜN	ack	2 8 Ka	pelha	VP - Eng and Ops						
	t Name o Irk Ka	of Respo	onsible Official of Firm	ń:	4. Date Signed: 8//3/2013						
5. Pho	ne#ofF	espons	ible Official of Firm:	6. Fax # of Responsible Official of Firm:	7. Email of Responsible Official of Firm:						
(56	32) 49	5-934	8	(562) 624-3224	mark_kapelke@oxy.com						
8. Sign	ature of	Prepare	or, (If prepared by perso	on other than responsible official of firm):	9. Title of Preparer:						
1	Parl	la F.	Prasetyo G) 8	Senior Engineer						
10. Pri	nt Name	of Prep	arer.		11. Date Signed:						
	rla Pr				03/28/2013						
12. Ph	one#of	Prepare	n.	13. Fax # of Preparer:	14. Email of Preparer:						
(55	9) 90	8-697	<u> </u>	(949) 248-8499	CJo@YorkeEngr.com						

THIS CONCLUDES FORM 400-CEQA. INCLUDE THIS FORM AND ANY ATTACHMENTS WITH FORM 400-A.

⁴ Table 1 – Regulated Substances List and Threshold Quantities for Accidental Release Prevention can be found in the Instructions for Form 400-CEQA.

South Coast Air Quality Management District

FORM 400-E-13a

Emergency Internal Combustion Engine

Mail Application To: SCAQMD P.O. Box 4944 Diamond Bar, CA 91765

Tel: (909) 396-3385

www.aqmd.gov

This form must be accompanied by a completed Application for a Permit to Construct/Operate -Form 400A Permit to be issued to (Business name of operator to appear on permit): Street location where the equipment will be operated (for equipment which will be moved to various location in AQMD's jurisdiction, please list the initial location site): 20101 Goldenwest Street, Huntington Beach, CA 92648 Section A: EQUIPMENT INFORMATION Manufacturer. Model No.: **CUMMINS** QST30 - G5 NR2 Serial No.: Date of Manufacture: Internal Combustion Engine 37254511 05/01/2012 (mm/dd/yyyy) Manufacturer Maximum Reting: Date of Installation: 1800 1490 _{BHP @} (mm/dd/yyyy) ICE Emergency Electrical Generator C Fire Pump C Flood Control Pump Driver Compressor Function How is This Type of Equipment Used? Type (2) Fixed site O Portable Within Facility Off- Site ☐ Rental (Check All That Apply) (Diesal Oil No. 2 O LPG Fuel O Natural Gas Other: Cycle Type C Two Cycle Four Cycle Combustion Type C Lean Burn O Rich Burn No. of Cylinders C) Four C) Six C Eight C Ten (Twelve C Sixteen Other C Turbocharged Turbocharged/Aftercooled **Aspiration Type** ☐ Timing Retarded > 4° (relative to standard timing) Naturally Aspirated Selective Catalytic Reduction (SCR)* No Controls Selective Non-catalytic Reduction (SNCR)* Air Fuel Ratio Controller Other (specify) Non-selective Catalytic Reduction (NSCR) Air Poliution Control Separate application is required. (if applicable) Manufacturer: Model No.: tf already permitted, indicate Permit No. Davice No. Section B: OPERATION INFORMATION **Fuel Consumption** Maximum Rated load: 72.200 gal./hr. OR 63.900 gal./hr. OR ____ _cu. ft_/hr Average Load:_ Normal: hours/day days/week Operating Maximum: Schedule hoursiday days/week 50 hours/year Testing & Maintenance (Emergency ICE only):

CONFIDENTIAL INFORMATION

Under the California Public Records Act, all information in your permit application will be considered a matter of public record and may be disclosed to a third party. If you wish to keep certain items as confidential, please complete the following steps:

- (a) Make a copy of any page containing confidential information blanked out. Label this page "public copy."
- (b) Label the original page "confidential." Circle all confidential items on the page.
- (c) Prepare a written justification for the confidentiality of each confidential item. Append this to the confidential copy.

Engine Data	 (1) Select year of manufacture and rated horsepower. (2) Provide actual emission figures from manufacturing specifications (if available) for the Rated Power selected. If engine fuel is LPG or Natural Gas, select Spark Ignition. (3) The compression ignited Internal combustion engine must meet the State of California or EPA's Non-Road Emission Standards as listed below (please provide manufacturer's specification and guarantee). 									
	Rated Power	Year	Figures	Carbon Monoxide (grams/bhp*hr)	Hydrocarbons (grams/bhp hr)	Oxides of Nitrogen (grams/bhp-hr)	Particulate Matter (grams/bhp*hr)			
om pressor Igni	tion									
	50 -<750 H.P.									
		50 -< 100 H.P.	Default	3.7	0.35 (0.56)*	3.15 (5.04)*	0.30			
	0		Actual							
		100-< 175	Default	3.7	0.3	2.7	0.22			
	0	H.P.	Actual				,			
		175 ← 750	Default	2.6	0.3	2.7	0.15			
		H.P.	Actual							
	750 and greater H.P									
		.754	Default	2.6	0.48	4.32	0,15			
	(6) ≥75	2/30	Actual	2.600	0.480	4.320	0.110			

		Figures	VOC	NOx	CO
Spark Ignition		For natural gas fired	or LPG. The ICE must me	et the requirements for	BACT as listed below
	0	Default	1.5 grams/bhp-hr	1.5 grams/bhp-hr	2.0 grams/bhp-hr
	k .:	Actual			

Section C: Applicant Certification Statement I hereby certify that all information contained herein and information st	bmitted with this application is true and correct	
SIGNATURE OF PREPARER:	TITLE OF PREPARER: Senior Engineer	~~~
CONTACT PERSON FOR INFORMATION ON THIS EQUIPMENT: Carla Prasetyo Jo	CONTACT PERSON'S TEL EPHONE NUMBER (559) 908-6979	DATE SIGNED:

Official Use Only

Engr. Int.

						Añ	- -		
						Ap	pin Date	:	
						Cia	89		
Data Input									
Applicant	OXY USA Inc.					ID			<u> </u>
Mailing Address									
Equipment Location	20101 Goldenwe	st Street,	Huntington Bea	ch, CA 9264		Equip Ty	oment rpe	Fixed s	ite
	Manufacturer:	CUMMIN	vs						
	Model No:	QST30 -	G5 NR2						
	Serial No.:	3725451	11		_				
Equipment Description	Manufacturer Date:	05/2012							
	Installation Date:								
	Cylinders:	Twelve							
	HP Rating:	1490							
· · · · · · · · · · · · · · · · · · ·	Turbocharge	٠	Turbanharandi	A December	No.				
Aspiration Type	O	20	Turbocharged/Aftercooled X			ally Aspirated			
.,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	Turbocharged/After								
			1						
Driving (ICE Emergency	Generator		Compressor		Pump				
Function)	X		0			0	_		;
	Electrical Generato	<u>r</u>	<u></u>		<u> </u>	<u> </u>			
	Voc		NOx	С	0	P	M		
Emission Factors, g/HP-hr	0.480		4.320	2.6	500	0.4	10		
<u> </u>	(Note: Emission factors	taken from e	ngine manufacturer s	pecs included wit	h application				<u></u>
	Yes		No	<u></u>					
Retard Timing									
	Hrs/Day Max.			Hrs/Month Max	·				
Operating Schedule	Hrs/Day Ave.			Wks/Yr					
, ,	Days/Wk.								
	Days/Mo								



Official Use Only

A/NI-	
7VIV.	····-

Given

Giveii						
HP	1490					
G to ib conversion factor	0.0022046					
	Hrs/Day Max.					
	Hre/Day Avg.					
	Days/Wk.					
Operating Schedule	Days.Mo.					
	Hrs/Month Max.					
	Wks/Yr.					
	VOC	NOx	SOx	co	PM	PM10
Emission Factors (grams/bhp -hr)	0.480	4.320	0.0049	2.600	0.110	0.106
	Yes	No		<u> </u>		-
Retard Timing						
	VOC	NOx	SOx	co	PM	PM10
Emission Correction Factor	1.000		1.000		1.000	1.000
			1	L	L	

Computations

Computations		voc	NOx	SOx	со	PM	PM10
	Emission factor, g/HP-hr	0.480		0.0049		0.110	0.106
	ib/hr.	1.577		0.016		0.361	0.348
	lb/day Max.						
	ib/day Avg.						
	lb/yr.						

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

ENGINEERING AND COMPLIANCE

APPLICATION PROCESSING AND CALCULATIONS

PAGE	1 of 3	
CHECKED BY:		For
A/N:		Official
PROCES SED BY		Use Only
DATE:		

Applicant's Name: OXY	USA Inc.	<u>ID:</u>
Equipment Location: 20	101 Goldenwest Street, Huntington Beach, CA	9264
Equipment Description:		
EQUIPMENT	INTERNAL COMBUSTION ENGINE	Per mitDescripti on;
MANUFACTURER:	CUMMINS	INTERNAL COMBUSTION ENGINE,
MODEL NO.:	QST30 - G5 NR2	Fixed site, CUMMINS, MODEL NO. QST30 - G5 NR2
FUELED WITH:	Diesel Oil No. 2	, SERIAL NO. 37254511
DRIVING:	Electrical Generator	, Diesel Oil No. 2 FUELED, Four CYCLES, Twelve CYLINDERS,
SERIAL NO.:	37254511	Turbocharged/Aftercooled, RATED AT
No. of CYLINDERS:	Twelve	1490 B.H.P., DRIVING AN EMERGENCY Electrical Generator.
ASPIRATION:	Turbocharged/Aftercooled	Digitival Continue.

CALCULATIONS See ATTACHMENT A

HP RATING:

EVALU ATION:

Rule 212: (Not Applicable if more than 1,000 feet from a school.)

1490

This is a not significant project as defined by this rule. Hence, public notice snot required.

Rule 401:

Based on experience with similar equipment, the engine is expected to comply with the visible emission limits.

Rule 402:

Based on experience with similar equipment and sance complaints are not expected.

Rule 404:

Based on experience with similar equipment compliance with this rule is expected.

Rule 431.2:

Diesel fuel supplied to this equipment must contain 0.0015% or less sulfur by weight. Compliance is expected.

Rule 1110.2:

Exempt per Rule 110.2 (h)(25)

REGULATION XIII

Rule 1303(a) meets BACT emission limits.

Rule 1303(b)(1) and (b)(2) - Exempt per Rule 1304(a)(4)

REGULATION XIV:

Exempt per Rule 1401(g)(1)(F).

APPENDIX B – ENGINE DATA



Exhaust Emission Data Sheet 1000DQFAD

60 Hz Diesel Generator Set

Engine Information:

Model:

Cummins Inc. QST30-G5 NR2

Bore:

5.51 in. (139 mm)

Type: Aspiration: 4 Cycle, 50°V, 12 Cylinder Diesel
Turbocharged and Low Temperature aftercooled

Stroke: Displacement: 6.5 in. (165 mm) 1860 cu. in. (30.4 liters)

Compression Ratio:

14.7:1

Emission Control Device:

Aftercooled (Air-to-Air)

	1/4	<u>1/2</u>	3/4	(<u>Full</u>)	Full	
PERFORMANCE DATA	Standby	Standby	Standby	(Standby)	Prime	
BHP @ 1800 RPM (60 Hz)	371	741	1112	1482	1322	
Fuel Consumption (gal/Hr))	19.1	35.8	54.1	(72.2)	63.9	
Exhaust Gas Flow (CFM)	2780	4500	6370	7540	6950	
Exhaust Gas Temperature (°F)	620	.760	814	890	873	
EXHAUST EMISSION DATA					-	
HC (Total Unburned Hydrocarbons)	0.12	0.10	0.08	0.07	0.08	
NOx (Oxides of Nitrogen as NO2)	4.17	5.20	3.87	3.95	4.00	
CO (carbon Monoxide)	0.66	0.36	0.48	0.66	0.58	
PM (Particular Matter)	0.19	0.15	0.12	0.11	0.11	
SO2 (Sulfur Dioxide)	0.11	0.10	0.10	0.11	0.10	
Smoke (Bosch)	0.88	0.80	0.79	0.73	0.75	

TEST CONDITIONS

Data was recorded during steady-state rated engine speed (\pm 25 RPM) with full load (\pm 2%). Pressures, temperatures, and emission rates were stabilized.

Fuel Specification:

46.5 Cetane Number, 0.035 Wt.% Sulfur; Reference ISO8178-5, 40CFR86.1313-98 Type 2-

D and ASTM D975 No. 2-D.

Fuel Temperature:

 99 ± 9 °F (at fuel pump inlet)

Intake Air Temperature:

77 ± 9 °F

Barometric Pressure.

 $29.6 \pm 1 \text{ in. Hg}$

Humidity:

NOx measurement corrected to 75 grains H2O/lb dry air

Reference Standard:

ISO 8178

The NOx, HC, CO and PM emission data tabulated here were taken from a single engine under the test conditions shown above. Data for the other components are estimated. These data are subjected to instrumentation and engine-to-engine variability. Field emission test data are not guaranteed to these levels. Actual field test results may vary due to test site conditions, installation, fuel specification, test procedures and instrumentation. Engine operation with excessive air intake or exhaust restriction beyond published maximum limits, or with improper maintenance, may results in elevated emission levels.

Home Programs 3 About Us 3 Help 3 Contact Us 3

Santa Barbara County Air Pollution Control District

Air Quality Today's Air Quality Pollutants & Health Monitoring Air Quality

> Attainment Class Planning

Clean Air Plans Land Use & CEQA Transportation Business

News/Notices/Meetings APCD Board Agendas Permits & Engineering Permit Applications Compliance/Breakdowns Download Documents Rules & Regulations Air Taxics Business Assistance Funding Programs

News/Natices/Meetings Students & Teachers Publications & Projects View Public Records Marine Shipping

Community Outreach

Contact Us 961-8800 Site Map

Diesel Internal Combustion Engine (DICE) Engine

Emission Factors

To determine an engine's emissions, an owner/operator may use:

- Default SBCAPCD Diesel Engine Emission Factors For use with older engines (see the first table presented below), or
 USEPA emission standards for Tier 1 3 engines (see the second table presented below)

Default SBCAPCD Diesel Engine Emission Factors

POLLUTANT	EMISSION FACTOR	UNITS	REF	
PM	1.0	g/bhp-hr	1	
NOx (as NO2)	14.1	g/bhp-hr	1	
NMHC	1.12	g/bhp-hr	1	
NMHC+NOx	15.22	g/bhp-hr	1	
co	3.0	g/bhp-hr	1	
SOx (as SO2)	3.67 * wt %S	g/bhp-hr	2	

besis: (1) USEPA AP-42, Table 3.3-1, (2) USEPA AP-42, Table 3.3-2, where S = wt % of suffur (eg. for S = 0.05 wt %. SOx = (3.67)*(0.05) = 0.183 gb/sp-fix. Assume NMHC = ROC

USEPA Emission Standards for Tier 1 - 3 engines

	Model Years	Regulation	Emission Standards (g/hp-hr)						Year the Std
Engine Power (hp)			HC 4 d	VHC b	NOx a, d	NMHC+NOx *	co*	PM *	Takes Effect
50 to <75	1998-2003	Tier 1			6.90				1998
	2004-2007	Tier 2	0.40	0.3996	5.20	5.60	3.70	0.30	2004
	2008-2012	Tier 3	0.20	0.1998	3.3	3.50	3.70	c	2008
75 to <100	1998-2003	Tier 1			6.90				1997
	2004-2007	Tier 2	0.40	0.3996	5.20	5.60	3.70	0.30	2004
	2008-2011	Tier 3	0.20	0.1998	3.3	3.50	3.70		2007
>100 to <175	1997-2002	Tier 1			6.90				1997
	2003-2006	Tier 2	0.40	0.3996	4.5	4.90	3.70	0.22	2003
	2007-2011	Tier 3	0.20	0.1998	2.8	3.00	3.70	6	2007
>175 to <300	1996-2002	Tier 1	1.00	0.9990	6.90		8.50	0.40	1996
	2003-2005	Tier 2	0.40	0.3996	4.5	4.90	2.60	0.15	2003
	2006-2010	Tier 3	0.20	0.1998	2.8	3.00	2.60	c	2006
>300 to <600	1996-2000	Tier 1	1.00	0.9990	6.90		8.50	0.40	1996
	2001-2005	Tier 2	0.30	0.2997	4.5	4.80	2.60	0.15	2001
	2006-2010	Tier 3	0.20	0.1998	2.8	3.00	2.60	c	2006
>600 to <750	1996-2001	Tier 1	1.00	0.9990	6.90		8.50	0.40	1996
	2002-2005	Tier 2	0.30	0.2997	4.5	4.80	2.60	0.15	2002
	2006-2010	Tier 3	0.20	0.1998	2.8	3.00	2.60	4	2006
>750 except generator sets	2000-2005	Tier 1	1.00	0.9990	6.90		8.50	0.40	2000
A CONTRACTOR OF THE PROPERTY O	2006-2010	Tier 2	0.30	0.2997	4.5	4.80	2.60	0.15	2006
Generator sets >750 to <1200	2000-2005	Tier 1	1.00	0.9990	6.90		8.50	0.40	2000
	2006-2010	Tier 2	0.30	0.2997	4.5	4.80	2.60	0.15	2006
Generator sets >1200	2000-2005	Tier 1	1.00	0.9990	8.90		8.50	0.40	2000
	2006-2010	Tier 2	0.30	0.2997	4.5	4.80	2.60	0.15	2006

For more information or assistance, call or email Mike Goldman at (805) 961-8821 or Kaitlin McNally at (805) 961-8855 (Engineering and Compliance Division).

◀ Return to DICE ATCM

Home | About Us | Air Quality | Planning | Business | Community | Regional | Help | Contact Us


Nonroad Ci Engine Emission Standards from Title 13, California Code of Regulations, Section 2423 (ARB Executive Order "Std").

b VHC = Total Hydrocarbons (THC) minus methane and ethane fractions. Equivalent APCD standard. (Highlighted in Drange) See Conversion Factors to Hydrocarbon Emission Components, Report No. NR-002a, US EPA. 5/2003 (VHC = ROC)


C Tier 3 PM standards have not yet been adopted. Tier 3 angines must meet the Tier 2 PM standard until the Tier 3 PM standard has been adopted.

d Tier 2 and Tier 3 HC and NOx equivalent standards used to determine the NMHC + NOx standard. (Highlighted in blue)

SUNBELT UNIT 486714



SUNBELT UNIT 486714



SUNBELL INIT 480714



APPENDIX C – EMISSION CALCULATIONS

OXY USA Inc. Facility ID 169754

Emergency IC Engine (Generator) Emission Calculations

Engine Data

Criteria Pollutant Emission Factors

http://www.sbcapcd.org/eng/atcm/dice/dice_efs.htm#USEPA_Emission_Standards_for_Tier_1 - 3_engines

Fuel Use Rate (gal/hr, Full Standby) 72.2

Diesel Data

Approximate Density (lb/gal) 6.943 Sulfur Content (wt.%) 0.0015% <- Calculated based on 15 ppmw

Pollutant	EF (g/bhp-hr):	_
KON	4.5	7
voc	0.3 .	7
NOx + VOC	4.8	<- Calculated
SOx*	0.005	<- Linked to calculation below
ά	2.6	7
PM10	0.15	
SOx CO	0.905 2.6	⊣

* SOx EF (g/bhp-hr) = Fuel Use Rate (gal/hr) x Approximate Density (lb/gal) x Sulfur Content (wt.%) x (64/32) (lb SOx/lb S) x 454 (g/lb) / bhp Rating

0.005

Operating Schedule

Hours per Year 50

Hours per Day 2.7 <- Maximum daily hours of operation to stay under Rule 212(g) limit for NOx.

Criteria Pollutant Emission Calculations

	AHU	AHC	MHU	MHC	MDU	MDC	AA	30DA
Pollutant	(lb/hr)	(lb/hr)	(lb/hr)	· (lb/hr)	(lb/day)	(lb/day)	(ib/yr)	(lb/day)
NOx	14.769	14.769	14.769	14.769	39.876	39.876	738.45	. 2.05
VÓC	0.985	0.985	0.985	0.985	2.66	2.66	49.25	0.14
·SOx	0.016	0.016	0.016	0.016	0.043	0.043	0.8	0.00
CO	8.533	8.533	8.533	8.533	23.039	23.039	426.65	1.19
PM10	0.492	0.492	0.492	0.492	1.328	1.328	24.6	0.07

AHU = AHC = MHU = MHC = EF (g/bhp-hr) x bhp Rating /454

MDU = MHU x 2.7 hours per day MDC = MHC x 2.7 hours per day AA = MHC x 50 hours per year

30DA = MHC x 50 hours per year / 12 months per year / 30 days per month

APPENDIX D - HEALTH RISK ASSESSMENT

TIER 1 / TIER 2 SCREENING RISK ASSESSMENT DATA INPUT

Applica	ition deemed complete date:[07/22/13			
	A/N:[Fac:				
Stack Data			Units		
Hour/Day		2.7	lm/day		
Day/Week			day/wk		
Weck/Year			wk/yr		
Emission Units		lb/hr			
			0		
Control Efficiency		0.00	fraction range 0-1		
Does source have TBACT?		NO			
Point or Volume Source ?		P	Por V		
Stack Height or Building Height		75	leet		
Area (For Volume Source Only)		900	ft ¹		
Distance-Residential		1609	meters		
Distance-Commercial		1609	meters		
Meteorological Station		Cos	sta Mesa .		
Source Type:		0	- Other		
Screening Mode (NO = Tier 1 or Tier 2; YES = 1	Tie <u>r 3)</u>	NO:			
Emission Units		lb/hr	ì		
Source output capacity		n/a	n/a		

FOR USER-DEFINED CHEMICALS AND EMISSIONS, FILL IN THE TABLE BELOW

USER DE	FINED CHEMICALS AND EMISSIONS	RI-	Efficiency	R2-		
	•			Uncontrolled	Factor	Controlled
Code Code	Compound	lb/hr	Molecular Weight	lbs/hr	Fraction range 0-	lbs/hr
DI4	Diesel PM from diesel-fueled internal combustion engine	4.92E-01	ne data	0.492		0.492
				0		
		10		0		
	•			0		
				0		
				0		
				0		
		-1,		0		
				0		
				0		
		1		Ö		
				0		
				0		
				0		
				0		
				0		
				Ó		
				0		
				0		
				0		
		i		0		
	<u> </u>			0		
	_					
		2 .		0		
		1		0		
		1		Ö		_
				Ö		
				. 0		
				0		
				Ö		
				0		
			_	0		
				0		-
				0		
				0		
				0	,	

TIER 2 SCREENING RISK ASSESSMENT REPORT

A/N:	 Application deemed complete date:	07/22/13
Fac:		

2. Tier 2 Data

MET Factor	0.69
4 hr	0.87
6 or 7 hrs	0.88

Dispersion Factors tables

2	For Chronic X/Q
6	For Acute X/Q

Dilution Factors (ug/m3)/(tons/yr)

Receptor	X/Q	X/Qmax
Residential	0.04	7.2
Commercial	0.04	7.2

Adjustment and Intake Factors

	AFann	DBR	EVF
Residential	1	302	0.96
Worker	4.2	149	0.38

Tier 2 Report

Page 1 of 9

7/22/2013

3. Rule 1401 Compound Data

Compound	R1 - uncontrolled	R2 - controlled	СР	MP MICR Resident	MP MICR Worker	Chronic	MP Chronic Worker	REL Chronic	REL Acute
!	(lbs/hr)	(lbs/hr)				Resident			
Diesel PM from diesel-fueled internal combustion eng	4.92E-01	4.92E-01	1.10E+00	1.0000	1,0000	1.0000	1.0000		
					_				
		_			_		_		
· ·									
		-	_		_		_		
	·]	J		J J		
	-			-					
	-				-				
							-		
		_			_				
							_		
							,		
		_							
			_		_				
				- .	_				
		_							
<u> </u>	-	_		_			_		
		The state of the s	_	·	- i				
				_					
							_		
			_	_					
							_		
							_		
	-						-		
	_								
				-					
				 				-	
			_	_	· -				
									I

4. Emission Calculations uncontrolled controlled Compound

Diesel PM from diesel-fueled internal combustion eng R2 (lb/yr) 69.0768 R2 (ton/yr) 0.0345384 R1 (lb/hr) R2 (lb/hr) 4.92E-01 4.92E-01

4.92E-01

4.92E-01 6.91E+01

Total

3.45E-02

/N:	Application deemed complete date: 07/22/13

TIER 2 RESULTS

5a. MICR

MICR = CP (mg/(kg-day))^-1 * Q (ton/yr) * (X/Q) * AFann * MET * DBR * EVF * 1E-6* MP

MICH - CF (Ing/(kg-day)) - 1 Q (IOIVYI) (A/Q)	APAIN WE	
Compound	Residential	Commercial
Diesel PM from diesel-fueled internal combustion eng	3.04E-07	2.49E-07
	'	
	}	}
	{	
	1 1	
	[
	ĺ [
	ļ <u>'</u>	
]]	1
}	})
	i I	
	1 1	
Total	3.04E-07	2.49E-07
	PASS	PASS
	1 499	I ALD 3

No Cancer Burden, MICR<1.0E-6

5b. Cancer Burden	NO
X/Q for one-in-a-million:	
Distance (meter)	#VALUE!
Area (km2):	#VALUE!
Population:	#VALUE!
Cancer Burden:	#VALUE!

6. Hazard Index

HIA = [Q(lb/hr) * (X/Q)max] * AF / Acute REL HIC = [Q(ton/yr) * (X/Q) * MET * MP] / Chronic REL

Target Organs	Acute	Chronic	Acute Pass/Fail	Chronic Pass/Fail
Alimentary system (liver) - AL		 	Pass	Pass
Bones and teeth - BN		1 - 1	Pass	Pass
Cardiovascular system - CV			Pass	Pass
Developmental'- DEV			Pass	Pass
Endocrine system - END			Pass	Pass
Eye	_		Pass	Pass
Hematopoietic system - HEM			Pass	Pass
Immune system - IMM			Pass	Pass
Kidney - KID			Pass	Pass
Nervous system - NS			Pass	Pass
Reproductive system - REP			Pass	Pass
Respiratory system - RES		1.91E-04	Pass	Pass
Skip			Pass	Pass

A/N:	Application deemed complete date:	07/22/13

6a. Hazard Index Acute

HIA = [Q(ib/hr) * (X/Q)max] *AF/ Acute REL

Γ				HIA - Residen	tial		•			
Compound Diesel PM from diesel-fueled internal combustion eng	AL.	CV	DEV	EYE	HEM	IMM	NS	REP.	RESP	SKIN
Diesel PM from diesel-fueled internal combustion eng				-					_	
										1
										ł
										ł
										1
										ł
										ł
										1
										1
										1
										1
										1
				·						1
										1
										1
										1
•				,						
										1
										1
										l
										l
										l
										l
										l
										l
										l
										l
										l
										l
							l			
							1			
							}			
							1			•
							J			
Total							ì			-

			l	HIA - Commercial	rcial					
Compound	AL	CV	DEV	EYE	HEM	IMM	SN	REP	RESP	SKIN
Diesel PM from diesel-fueled internal combustion eng		·								
Total										

8b. Hazard Index Chronic

HIC = [Q(ton/yr) * (X/Q) * MET * MP] / Chronic REL


6D. Hazaro index Chronic		HIC = [Q(ton/yr) - (AU) MEIN	IPJ / Chironic REL									
		,			HIC - Residen	tial							
Compound	AL	BN	CV	DEV	END	EYE	HEM	IMM	KID_	NS	REP	RESP	SKIN
Diesel PM from diesel-fueled internal combustion eng												1.91E-04	
												i l	
				,						ļ		i l	
												i l	
		j										i l	
			ſ	ĺ	}	} .))	J	1		í I	
								ľ		[[i l	
							Ì						
								ļ				ı	
												i l	
									1			i	
			}			l			1			i l	
						ļ						i I	
				1		1						i	
												i l	
												i l	
												í I	
										ļ		i l	
												i l	
		l.					!			1		i l	
												i l	
							ŀ					i l	
		J						ļ				i l	
			ĺ	İ	}	l)	j	J			i l	
										ĺ	[i i	
			1						ļ			; I	
												i	
				1		1						1	
												i 1	
												i l	
												i l	
							1			ļ		i l	
					i					Ì		i l	
					İ							i l	
								Į.				í I	
												i l	
					1			1				i l	
					1			1	ļ			i l	
				l		1		1				j	
					1			1				(
1		J	1		1			1				1 1	
			[ĺ	1	1	1	1	J	J	l	1 1	
T 4 1		1		 	<u> </u>	 			 			1.91E-04	1
Total		1					<u> </u>			l		1.91E-04	

A/N:	Application deemed complete date:	07/22/13

6b. Hazard Index Chronic (cont.)

	HIC - Commercial												
Compound	AL	BN	CV	DEV	END	EYE	HEM	IMM	KJD	NS	REP	RESP	SKIN
Compound Diesel PM from diesel-fueled internal combustion eng						_			, . <u></u>			1.91E-04	
· 1													
												\	
										Į.	\		
									\				
						1							
						1							
											1		
		Į)										
1													
i											1		
			!										
									Į.				
									1				
										<u> </u>			
Total						l		l				1.91E-04	

Tier 2 Report Page 9 of 9



SOUTH COAST AIR QUALITY MGMT DISTRICT 21865 E COPLEY DR DIAMOND BAR, CA 91765

 DATE
 CHECK NO.

 16-Aug-13
 10004103

30079

DATE	INVOICE CREDIT MEMO	• DESCRIPTION	PO NUMBER	COMPANY CODE	DISCOUNT	NET
3-Aug-13 69754 PERM	081313 T APPL FEE 'PLATFORM EMM	IY EMERGENCY GENERATOR PERMIT APP	LICATION CMA	008577		3,130.83
	,					
					i I	
ĺ				1		1
]
J]		}
]
				1 1		i
						1
· -		•				1
						}
-						
		, e - 8		J		
}					1	
				-	<u> </u>	1. 25 2 5 3
E ATTACHE	CHECK IS IN PAYMENT FOR	ITEMS DESCRIBED ABOVE	TOTAL >.			\$3,130.

TIER 1 SCREENING RISK ASSESSMENT REPORT

Receptor Distance (actual) (m)	1609
Receptor Distance (for X/Q LOOKUP) (m)	100

Tier 1 Results				
Cancer/Chronic ASI	Acute ASI			
4.97E+01				
FAILED	PASSED			

APPLICATION SCREENING INDEX CALCULATION

Compound	Average Annual Emission Rate (lbs/yr)	Max Hourly Emission Rate (lbs/hr)	Cancer / Chronic Pollutant Screening Level (lbs/yr)	Acute Pollutant Screening Level (lbs/hr)	Cancer / Chronic Pollutant Screening Index (PSI)	Acute Pollutant Screening Index (PSI)
Diesel PM from diesel-fueled internal combustion						
engine	6.91E+01	4.92E-01	1.39E+00		4.97E+01	
					• ,	

TOTAL (APPLICATION SCREENING INDEX)

4.97E+01

OXY USA Inc.

111 W. Ocean Blvd. #800 Long Beach, CA 90802



7012,0470 0001 5861 9801

SCAQMD 21865 E. COPLEY DRIVE DIAMOND BAR, CA 91765

Attn: Permit Services