

DOCKETED

Docket Number:	12-AFC-02C
Project Title:	Huntington Beach Energy Project - Compliance
TN #:	211747
Document Title:	South Coast Air Quality Management District - Preliminary Determination of Compliance (PDOC)
Description:	N/A
Filer:	Marichka Haws
Organization:	South Coast Air Quality Management District
Submitter Role:	Public Agency
Submission Date:	6/7/2016 5:29:29 PM
Docketed Date:	6/8/2016

Preliminary
Determination of Compliance

Huntington Beach Energy Project



South Coast Air Quality Management District

April 2016



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
2

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

APPLICANT:

AES Huntington Beach, LLC
21730 Newland St
Huntington Beach, CA 92646
SCAQMD ID# 115389

EQUIPMENT LOCATION:

21730 Newland St
Huntington Beach, CA 92646

EQUIPMENT DESCRIPTION:

Section H of the Facility Permit ID# 115389

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions and Requirements	Conditions
PROCESS 3: POWER GENERATION-GAS TURBINES					
GAS TURBINE, UNIT NO.1, COMBINED CYCLE, GE MODEL 7FA.05, NATURAL GAS, 2273 MMBTU AT 32 DEGREES F WITH DRY LOW NOX COMBUSTOR, GE DLN 2.6 A/N: 578073	D115	C120, C121, S123	NOX: MAJOR SOURCE SOX; PROCESS UNIT	CO: 2.0 PPM NATURAL GAS (4) [RULE 1703-PSD]; CO: 2000 PPM (5) [RULE 407] CO2: 1,000 LBS/GROSS MWH NATURAL GAS (8) [40 CFR60 SUBPART TTTT] NOX: 2.0 PPM NATURAL GAS (4) [RULE 2005, RULE 1703-PSD]; NOX: 15 PPM NATURAL GAS (8) [40 CFR60 SUBPART KKKK]; NOX: 19.09 LBS/MMCF NATURAL GAS (1) [RULE 2012] VOC: 2.0 PPM NATURAL GAS (4) [RULE 1303(a)(1)-BACT] PM: 0.1 GR/SCF (5) [RULE 409]; PM: 11 LBS/HR (5) [RULE 475]; PM: 0.01 GR/SCF (5A) [RULE 475]; SOX: 0.060 LBS/MMBTU (8) [40CFR 60 SUBPART KKKK]; SO2: (9) [40CFR 72 – ACID]	A63.6, A63.7, A99.4., A195.6, A195.7, A195.8 A195.9, A327.1, B61.1, C1.7, C1.8, C1.9, D29.5, D29.6, D29.7, D82.3 D82.4, E193.3, E193.4, E193.5, E193.6, E448.1, I297.1, I298.1, K40.3, K67.5
GENERATOR, 236.1 MW GROSS AT 32 DEGREES F	(B116)				
GENERATOR, HEAT RECOVERY STEAM	(B117)				
TURBINE, STEAM, COMMON WITH GAS TURBINE NO. 2, 221.4 MW GROSS AT 32 DEGREES F	(B118)				



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
3

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions and Requirements	Conditions
PROCESS 3: POWER GENERATION-GAS TURBINES					
				RAIN]; SOX: 0.71 LBS/MMCF NATURAL GAS (1) [RULE 2011]	
CO OXIDATION CATALYST, BASF, SERVING GAS TURBINE NO. 1, WITH 328.8 CU. FEET OF TOTAL CATALYST VOLUME A/N: 578075	C120	D115			D12.10, E193.4
SELECTIVE CATALYTIC REDUCTION, CORMETECH, TITANIUM./VANADIUM/TUNGSTEN, SERVING UNIT NO.1, 2761 CU. FEET OF TOTAL CATALYST VOLUME, 25.7' L X 1.5' W. X 71.6' H., WITH A/N: 578075	C121	D115		NH3: 5 PPM (4) [RULE 1303(a)(1)-BACT]	A195.10, D12.7, D12.8, D12.9, E193.4
AMMONIA INJECTION, INJECTION GRID	(B122)				
STACK SERVING UNIT NO. 1, 150' H. X 20' DIA. A/N: 578073	S123	D115			
GAS TURBINE, UNIT NO.2, COMBINED CYCLE, GE MODEL 7FA.05, NATURAL GAS, 2273 MMBTU AT 32 DEGREES F WITH DRY LOW NOX COMBUSTOR, GE DLN 2.6 A/N: 578074	D124	C129 C130 S132	NOX: MAJOR SOURCE SOX: PROCESS UNIT	CO: 2.0 PPM NATURAL GAS (4) [RULE 1703-PSD]; CO: 2000 PPM (5) [RULE 407] CO2: 1,000 LBS/GROSS MWH NATURAL GAS (8) [40 CFR60 SUBPART TTTT] NOX: 2.0 PPM NATURAL GAS (4) [RULE 2005, RULE 1703-PSD]; NOX: 15 PPM NATURAL GAS (8) [40 CFR60 SUBPART KKKK]; NOX: 19.09 LBS/MMCF NATURAL GAS (1) [RULE 2012] VOC: 2.0 PPM NATURAL GAS (4) [RULE 1303(a)(1)-BACT] PM: 0.1 GR/SCF (5) [RULE 409]; PM: 11 LBS/HR (5) [RULE 475]; PM: 0.01 GR/SCF (5A) [RULE 475];	A63.6, A63.7, A99.4., A195.6, A195.7, A195.8 A195.9, A327.1, B61.1, C1.7, C1.8, C1.9, D29.5, D29.6, D29.7, D82.3 D82.4, E193.3, E193.4, E193.5, E193.6, E448.1, I297.1,
GENERATOR, 236.1 MW GROSS AT 32 DEGREES F	(B125)				
GENERATOR, HEAT RECOVERY STEAM	(B126)				
TURBINE, STEAM, COMMON WITH GAS TURBINE NO. 1, 221.4 MW GROSS AT 32 DEGREES F	(B127)				



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
4

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions and Requirements	Conditions
PROCESS 3: POWER GENERATION-GAS TURBINES					
				SOX: 0.060 LBS/MMBTU (8) [40CFR 60 SUBPART KKKK] SO2: (9) [40CFR 72 – ACID RAIN]; SOX: 0.71 LBS/MMCF NATURAL GAS (1) [RULE 2011]	I298.1, K40.3, K67.5
CO OXIDATION CATALYST, BASF, SERVING GAS TURBINE NO. 2, WITH 328.8 CU. FEET OF TOTAL CATALYST VOLUME A/N: 578076	C129	D124			D12.10, E193.4
SELECTIVE CATALYTIC REDUCTION, CORMETECH, TITANIUM./VANADIUM/TUNGSTEN, SERVING UNIT NO.2, 2761 CU. FEET OF TOTAL CATALYST VOLUME, 25.7' L X 1.5' W. X 71.6' H., WITH A/N: 578076 AMMONIA INJECTION, INJECTION GRID	C130 (B131)	D124		NH3: 5 PPM (4) [RULE 1303(a)(1)-BACT]	A195.10, D12.7, D12.8, D12.9, E193.4
STACK SERVING UNIT NO. 2, 150' H. X 20' DIA. A/N: 578074	S132	D124			
GAS TURBINE, UNIT NO.3, SIMPLE CYCLE, GE MODEL LMS100PB, NATURAL GAS, 885 MMBTU AT 65.8 DEGREES F, INTERCOOLED, WITH DRY LOW NOX COMBUSTOR A/N: 578077 GENERATOR, 100.8 MW GROSS AT 65.8 DEGREES F	D133 (B134)	C135, C136, S138	NOX: MAJOR SOURCE SOX: PROCESS UNIT	CO: 4.0 PPM NATURAL GAS (4) [RULE 1703-PSD]; CO: 2000 PPM (5) [RULE 407] NOX: 2.5 PPM NATURAL GAS (4) [RULE 2005, RULE 1703-PSD]; NOX: 15 PPM NATURAL GAS (8) [40 CFR60 SUBPART KKKK]; NOX: 25.11 LBS/MMCF NATURAL GAS (1) [RULE 2012] VOC: 2.0 PPM NATURAL GAS (4) [RULE 1303(a)(1)-BACT] PM: 0.1 GR/SCF (5) [RULE 409]; PM: 11 LBS/HR (5) [RULE 475]; PM: 0.01 GR/SCF (5A) [RULE 475]; SOX: 0.060 LBS/MMBTU (8) [40CFR 60 SUBPART KKKK]	A63.8, A63.9, A99.5, A195.8, A195.11, A195.12, A327.1, B61.1, C1.10, C1.11, C1.12, D29.5, D29.6, D29.7, D82.3 D82.4, E193.3, E193.4, E193.7, E193.8, E448.1, E448.2,



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
5

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions and Requirements	Conditions
PROCESS 3: POWER GENERATION-GAS TURBINES					
				SO ₂ : (9) [40CFR 72 – ACID RAIN]; SO _X : 0.71 LBS/MMCF NATURAL GAS (1) [RULE 2011]	E448.3, I297.2, I298.2, K40.3, K67.5
CO OXIDATION CATALYST, BASF CAMEL, SERVING GAS TURBINE NO. 3, WITH 165.6 CU. FEET OF TOTAL CATALYST VOLUME A/N: 578079	C135	D133			D12.10, E193.4
SELECTIVE CATALYTIC REDUCTION, CORMETECH CMHT, TITANIUM./VANADIUM/TUNGSTEN, SERVING UNIT NO.3, WITH 622 CU. FEET OF TOTAL CATALYST VOLUME, 11' L. X 4.9' W. X 11.6' H, WITH A/N: 578079	C136	D133		NH ₃ : 5 PPM (4) [RULE 1303(a)(1)-BACT]	A195.10, D12.11, D12.12, D12.13, E193.4
AMMONIA INJECTION, INJECTION GRID	(B137)				
STACK SERVING UNIT NO. 3, 80' H. X 13.5' DIA. A/N: 578077	S138	D133			
GAS TURBINE, UNIT NO.4, SIMPLE CYCLE, GE MODEL LMS100PB, NATURAL GAS, 885 MMBTU AT 65.8 DEGREES F, INTERCOOLED, WITH DRY LOW NOX COMBUSTOR A/N: 578078	D139	C141, C142, S144	NOX: MAJOR SOURCE SOX: PROCESS UNIT	CO: 4.0 PPM NATURAL GAS (4) [RULE 1703-PSD]; CO: 2000 PPM (5) [RULE 407] NOX: 2.5 PPM NATURAL GAS (4) [RULE 2005, RULE 1703-PSD]; NOX: 15 PPM NATURAL GAS (8) [40 CFR60 SUBPART KKKK]; NOX: 25.11 LBS/MMCF NATURAL GAS (1) [RULE 2012] VOC: 2.0 PPM NATURAL GAS (4) [RULE 1303(a)(1)-BACT] PM: 0.1 GR/SCF (5) [RULE 409]; PM: 11 LBS/HR (5) [RULE 475]; PM: 0.01 GR/SCF (5A) [RULE 475]; SOX: 0.060 LBS/MMBTU (8) [40CFR 60 SUBPART KKKK]	A63.8, A63.9, A99.5, A195.8, A195.11, A195.12, A327.1, B61.1, C1.10, C1.11, C1.12, D29.5, D29.6, D29.7, D82.3 D82.4, E193.3, E193.4, E193.7, E193.8, E448.1, E448.2,
GENERATOR, 100.8 MW GROSS AT 65.8 DEGREES F	(B140)				



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
6

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions and Requirements	Conditions
PROCESS 3: POWER GENERATION-GAS TURBINES					
				SO ₂ : (9) [40CFR 72 – ACID RAIN]; SO _X : 0.71 LBS/MMCF NATURAL GAS (1) [RULE 2011]	E448.3, I297.2, I298.2, K40.3, K67.5
CO OXIDATION CATALYST, BASF CAMEL, SERVING GAS TURBINE NO. 4, WITH 165.6 CU. FEET OF TOTAL CATALYST VOLUME A/N: 578080	C141	D139			D12.10, E193.4
SELECTIVE CATALYTIC REDUCTION, CORMETECH CMHT, TITANIUM./VANADIUM/TUNGSTEN, SERVING UNIT NO.4, WITH 622 CU. FEET OF TOTAL CATALYST VOLUME, 11' L. X 4.9' W. X 11.6' H, WITH A/N: 578080 AMMONIA INJECTION, INJECTION GRID	C142 (B143)	D139		NH ₃ : 5 PPM (4) [RULE 1303(a)(1)-BACT]	A195.10, D12.11, D12.12, D12.13, E193.4
STACK SERVING UNIT NO. 4, 80' H. X 13.5' DIA. A/N: 578078	S144	D139			
BOILER, AUXILIARY, RENTECH, MODEL D-TYPE, WATER TUBE, NATURAL GAS, 71 MMBTU/HR, WITH LOW NOX BURNER, FLUE GAS RECIRCULATION, WITH A/N: 578081 BURNER, JZHC/COEN RMB, 71 MMBTU/HR, NATURAL GAS WITH LOW NOX BURNER, FLUE GAS RECIRCULATION	D145 (B146)	C147, S149	NOX: MAJOR SOURCE SOX: PROCESS UNIT	CO: 50 PPM NATURAL GAS (4) [RULE 1303(a)(1) - BACT]; CO: 400 PPM (5) [RULE 1146]; CO: 2000 PPM (5A) [Rule 407] NOX: 5.0 PPM NATURAL GAS (4) [RULE 2005]; NOX: 49.180 LBS/MMCF NATURAL GAS (1) [RULE 2012] PM: 0.1 GR/SCF (5) [RULE 409]; SOX: SOX: 0.83 LBS/MMCF NATURAL GAS (1) [RULE 2011]	A63.10, A195.13, A195.14, C1.13, C1.14, D29.8, D29.9, D82.5, E193.4, I297.3, I298.3
SELECTIVE CATALYTIC REDUCTION, BABCOCK AND WILCOX,	C147	D145		NH ₃ : 5 PPM (4) [RULE 1303(a)(1)-BACT]	A195.10, D12.14, D12.15,



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
7

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions and Requirements	Conditions
PROCESS 3: POWER GENERATION-GAS TURBINES					
VANADIUM, SERVING THE AUXILIARY BOILER, WITH 46 CU. FEET OF TOTAL CATALYST VOLUME, WITH A/N: 578082					D12.16, E193.4
AMMONIA INJECTION, INJECTION GRID	(B148)				
STACK SERVING AUXILIARY BOILER, 80' H. X 3' DIA. A/N: 578081	S149	D145			
PROCESS 4: AMMONIA STORAGE					
STORAGE TANK, HORIZONTAL, 45' L X 13' DIA, AQUEOUS AMMONIA 19%, 35000 GALS A/N: 578083	D150				E144.1, C157.1, E193.4
STORAGE TANK, HORIZONTAL, 18' L X 6' DIA, AQUEOUS AMMONIA 19%, 15000 GALS A/N: 578084	D151				E144.1, C157.1, E193.4
PROCESS 5: WASTE WATER TREATMENT					
OIL WATER SEPARATOR A/N: 578085	D152				
OIL WATER SEPARATOR A/N: 578086	D153				

BACKGROUND:

On October 29, 2014, the CEC granted a license to AES for the construction and operation of the HBEP (original configuration). After the CEC issued the HBEP final decision, Southern California Edison announced that AES had been awarded a contract to provide 644 MWs of nominal capacity at the Huntington Beach site. The project configuration selected by SCE required a change to the original HBEP design, thus AES has resubmitted applications to the SCAQMD, and also requested a modification of the CEC license for the new design.

The amended Huntington Beach Energy Project (HBEP) is a proposed 895.5 MW combined cycle/simple cycle power plant to be located at the existing site of the Huntington Beach Generating Station plant in Huntington Beach, approximately 900 feet from the Pacific Ocean. The surrounding



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
8

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

area is a mix of residential, wetland preserve, public beach, and industrial, and is bordered by a manufactured home/recreation vehicle park on the west, Huntington Beach Channel and residential areas to the north and east, a tank farm to the north, the Huntington Beach Wetland Preserve/Magnolia Marsh wetlands on the southeast, and the Huntington Beach State Park and the Pacific Ocean to the south and southwest. The entire parcel on which the Huntington Beach Generating Station is located, including the switchyard and tank farm, is approximately 106 acres, and the new plant will be constructed on about 30 of those acres. The nearest inhabitants to the proposed project site is a residential area approximately 300-400 feet from the site. The site location map is presented in Figure 1.1. The HBEP plot plan is presented in Appendix J.

The current Huntington Beach facility consists of 2 utility boilers. Boilers 1 and 2 are identical units, each rated at 215 MWs output and 2021 mmbtu/hr input. The boilers are equipped with SCR systems, and are fired primarily on pipeline natural gas, with some field gas from offshore platforms also combusted. The boilers were built in the 1950's and use 'once-through' ocean water cooling. There are two 275 hp diesel-fueled emergency engines installed in 2001 for fire control, a 30,000 gallon urea storage tank, and two urea-to-ammonia converters. The urea is used in the SCR systems, and is converted into ammonia before injection into the boiler exhaust with the use of the urea-ammonia converters. There is also an old peaker turbine (Unit 5) that has been shutdown and no longer operates, as well as Boilers 3 and 4, which have also been shutdown.

The current ownership of the equipment at the site is split between AES Huntington Beach, LLC which owns Boilers 1 and 2, the two the emergency engines, and the urea storage tank, and Edison Mission Energy, LLC which purchased Boilers 3 and 4 and permanently retired them in November 2012. AES Huntington Beach is the operator for all the equipment on site.

It should be noted that the shutdown of Boilers 3 and 4 are not a part of the HBEP. The capacity for these units were replaced by a power project in the City of Industry, not owned or operated by AES.

The proposed new facility will be composed of two separate power blocks, a combined cycle block and a simple cycle block. Construction of the combined cycle block is expected to begin in the second quarter of 2017 (outside of some demolition activities and site prep), and construction of the simple cycle block is anticipated in the second quarter of 2022. First fire of the combined cycle power block is expected by 10/1/2019. To offset the generating capacity of the new combined cycle plant, AES will shutdown Boiler 1 at the Huntington Beach plant, and Boiler 7 at the AES Redondo Beach plant by 11/1/2019, which is within 30 days of the new plant coming on line. Both the AES Huntington Beach and AES Redondo Beach plants are wholly-owned subsidiaries of AES Southland Corporation.

First fire of the new simple cycle power block is expected on 11/1/2023. To offset the capacity of the simple cycle plant, AES will shutdown Boiler 2 at the Huntington Beach plant.


 South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 9	PAGES 212
	APPL NO. See Below	DATE 6/7/16
	PROCESSED BY CP01	CHECKED BY

Table 1.1 Construction Schedule

Activity	Timeframe
Demolition of Unit 5 Peaker and East Oil Tank	First QTR 2016
Site Prep and Grading	Fourth QTR 2016
Begin Construction of CCGT	Second QTR 2017
Commercial Operation of Block 1	First/Second QTR 2020
Demolition of Units 3 and 4	First/Second QTR 2020
Begin Construction of SCGT	Second QTR 2022
Commercial Operation of SCGT	First QTR 2024
Demolition of Units 1 and 2	First QTR 2024

Table 1.2 Start Up/Shut Down Dates

New Units	Capacity, MWs	First Fire Date	Retired Units	Capacity, MWs	Shutdown Date
Combined Cycle Block	693.8	10/1/2019	HBGS 1	215	11/1/2019
			RBGS 7	480	11/1/2019
Simple Cycle Block	201.6	11/1/2023	HBGS 2	215	12/31/2020


Total generating capacity being retired as part of this project is 910 MWs. Prior to the start of construction of the new plant, the facility will be required to submit a comprehensive decommissioning plan for the boilers to be shutdown. In accordance with SCAQMD policy, decommissioning must render the units permanently inoperable.

The combined cycle block will consist of two GE 7FA.05 turbine generators (CCTG), a heat recovery steam generator (HRSG), and one steam turbine. The simple cycle power block will consist of two GE LMS100PB turbine generators (SCTG). The turbines will be air cooled. An auxiliary boiler will be used to assist the CCTG during start up. All combustion units will be fired on natural gas exclusively (platform field gas will no longer be used at the site).

Other equipment includes a 35,000 gallon aqueous ammonia storage tank serving the CCTG and auxiliary boiler, a 15,000 gallon aqueous ammonia storage tank serving the SCTG, and 2 oil/water separators. The 2 existing emergency fire pump engines will remain in operation.

AES Huntington Beach, LLC will be the facility owner and operator of the new plant.

The plant will be designed to supply power to the wholesale energy market through the existing substation adjacent to the property (to the north-east). Output will depend on market conditions and dispatch requirements. The plant's expected availability is over 98% on an annual basis, with the

	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 10	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

actual capacity factor anticipated to be between 45-75%¹. AES expects the plant to be dispatched at peaking and intermediate loads on a regular basis. Therefore, the plant is designed to have the ability to start quickly - cold starts should be about 60 minutes for the combined cycle power block and 30 minutes for the simple cycle power block – ramp quickly, and operate fully controlled at high turndown ratios.

The following applications for the project were submitted on September 8, 2015:

Table 1.3 – Project Application Numbers

Application Number	Equipment Description
578073	Combined Cycle Turbine #1
578074	Combined Cycle Turbine #2
578075	SCR/CO Catalyst #1
578076	SCR/CO Catalyst #2
578077	Simple Cycle Turbine #3
578078	Simple Cycle Turbine #4
578079	SCR/CO Catalyst #3
578080	SCR/CO Catalyst #4
578081	Auxiliary Boiler
578082	Auxiliary Boiler SCR
578083	Ammonia Storage
578084	Ammonia Storage
578085	Oil/Water Separation
578086	Oil/Water Separation
578087	Title V Revision

Additional information for the project was received on October 13, 2015, November 11, 2015, and December 4, 2015. SCAQMD deemed the applications complete on December 18, 2015. On March 14, 2016, the facility proposed changes to the equipment operating profile and submitted an application revision. Refer to Appendix R for fees paid.

The plant will be evaluated as a significant revision to the existing Title V permit at the AES, Huntington Beach site (facility ID# 115389). The new project is also subject to NO_x and SO_x RECLAIM and PSD regulations for NO₂, SO_x, CO, GHG, and PM₁₀. The plant is considered a major revision to a major stationary source under Regulation XIII and Rule 2005, and as such is subject to the full requirements of New Source Review. Other major environmental regulations that apply to the new project are 40 CFR72 – Acid Rain, 40CFR 60 Subpart KKKK – New Source Performance Standards for Gas Turbines, 40CFR 60 Subpart TTTT GHG Standards for Electric Utility Generating Units, and AQMD Rule 1401 – Toxics. The project is also subject to the

¹ The maximum annual generation is estimated to be approximately 4,744 gigawatt hrs, based on an average baseload rating of 681.7 MW and 6,612 hrs/yr for the combined cycle block, and 179.4 MW and 1,750 hrs for the simple cycle block, and 98.4% availability.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
11

APPL NO.
See Below

PROCESSED BY
CP01


PAGES
212

DATE
6/7/16

CHECKED BY

California Energy Commissioning (CEC) licensing procedure and an Application for Certification (AFC) has been submitted with that agency (12-AFC-02C).

Figure 1.1 –Site Location



Compliance History


The following information was obtained from the District's Compliance Tracking System for the 5-year period from 1/01/10 to 2/04/16 for the AES Huntington Beach facility.

Notice to Comply D03529

Issued 12/01/10 for failure to include all equipment in the RECLAIM quarterly reports (QCER). The follow up status is 'in compliance.'

Notice to Comply E09956

Issued 10/14/11 for failure to comply with testing condition D28.3 and D29.3 including testing for a 60 minute period. The follow up status is 'in compliance.'

	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 12	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

Notice of Violation P52182

Issued on 10/27/11 for exceeding the start up NOx limit of 38.4 lbs/hr for Boiler #4. This is a closed case.

Notice of Violation P60564

Issued on 12/30/15 for the late submittal of the 2/17/15 electronic emissions report for Boiler #2. This is a closed case.

Notice of Violation P58099

Issued on 2/2/16 for failure to submit the Title V renewal application in a timely manner.

There were no complaints associated with the facility for the stated time period in the AQMD database. The facility has also submitted a statement certifying that all facilities owned and operated in the state are currently in compliance with all applicable air quality regulations, as required by Rule 1303.

PROCESS DESCRIPTION:

The two GE7FA.05 combined cycle turbines will be arranged in a ‘two-on-one’ (2X1) configuration. Each turbine is rated at 232.1 MW (nominal gross), and will be equipped with dry low NOx combustors and evaporative inlet air cooling, a heat recovery steam generator (no duct firing), an SCR and oxidation catalyst, and one 229.7 MW (nominal gross) steam turbine, common to both combustion turbines.

Each combined cycle turbine will vent to a stack 150 feet tall. 19% aqueous ammonia for the combined cycle turbine SCR's will be stored in a 35,000 gallon tank.

An auxiliary boiler will be employed to assist the combined cycle units during start ups. The boiler is rated at 71 mmbtu/hr and will be fired on natural gas. It will be equipped with Low NOx burners, Flue Gas Recirculation, and an SCR.

The two GE LMS100PB simple cycle turbines are each rated at 100.8 MWs (nominal gross), and will be equipped with dry low NOx combustors, SCR's and oxidation catalysts.

Each simple cycle turbine will vent to a stack 80 feet tall. 19% aqueous ammonia for the simple cycle turbine SCR's will be stored in a 15,000 gallon tank.

The system output will vary depending on the ambient air temperature condition, use of evaporative coolers, amount of auxiliary load, generator power factor, and other factors. The tables below show the output on a per turbine basis.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
13

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table 2.1 Combined Cycle Plant Output Per Turbine

	ISO 59 F- 60% RH (Evaporative Cooling Off)	110 F-8% RH (Evaporative Cooling On)	32 F – 87% RH (Evaporative Cooling Off)	66 F – 58% RH (Evaporative Cooling On)
Gas Turbine Heat Input, mmbtu/h HHV	2,240	2,123	2,273	2,248
Gas Turbine Gross Output ¹ , kW	231,197	215,890	236,140	232,073
Steam Turbine Gross Output ² , kW	115,470	96,702	110,675	114,838
Total Gross Power Output ³ , kW	346,667	312,592	346,815	346,911
Net Power Output ³ , Kw	339,875	318,160	340,745	340,840
Net Plant Heat Rate, btu/kWh, LHV	5,967	6,271	6,017	5,984
Net Plant Heat Rate, btu/kWh, HHV	6,576	6,912	6,672	6,596
Net Plant Efficiency, %, LHV	57.2	54.4	56.7	57.0
Net Plant Efficiency, %, HHV	51.9	49.4	51.1	51.7

1 on a per turbine basis

2 one half of the total steam turbine output

3 multiply by 2 to get the output per power block

Table 2.2 Simple Cycle Plant Output Per Turbine

	110 F-8% RH (Evaporative Cooling On)	32 F – 87% RH (Evaporative Cooling Off)	65.8 F – 58% RH (Evaporative Cooling On)
Gas Turbine Heat Input, mmbtu/h HHV	737	880	885
Gas Turbine Gross Output, kW	77,501	100,393	100,814
Net Power Output, Kw	76,041	98,934	99,355
Net Plant Heat Rate, btu/kWh, LHV	8,726	8,012	8,027
Net Plant Heat Rate, btu/kWh, HHV	9,686	8,894	8,910
Net Plant Efficiency, %, LHV	39.1	42.6	42.6
Net Plant Efficiency, %, HHV	35.2	38.4	38.3

There will be no new offsite transmission lines or gas lines needed for the project.

Each of the components is discussed in more detail below:

- *Combined Cycle Combustion Turbines*

The 7FA.05 turbine is the upgraded ‘5th generation’ version of GE’s 7FA frame unit. It features fast start capability (20 minutes to baseload for a cold start, and 15 minutes to baseload for a non-cold start), high turndown ratio (approximately 44%), and increased output and efficiency over the previous generation 7FAs. The fast start capability in combined cycle mode is accomplished by decoupling the combustion turbine from the HRSG and steam turbine, thus bypassing the time



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
14

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

needed to allow the steam turbine to achieve operating temperature. The improved efficiency is a result of hot gas path enhancements and the compressor design, including variable geometry blades, different blade materials, and improved blade aerodynamics.

The turbines will be equipped with inlet air filters, inlet air compressors, and evaporative coolers. Incoming combustion gas will first pass through the facility's compression station and be brought to a pressure of approximately 600 psi prior to combustion.

Heat input for each combustion turbine at maximum low temperature conditions is 2,273 mmbtu/hr (HHV), fuel use at these conditions is approximately 2.16 mmcf/hr, based on a natural gas heat content of 1050 btu/cf. Turbines specs are summarized in the following table:

Table 2.3 Combined Cycle Turbine Data

Specification	
CT Manufacturer	GE
Model	7FA.05
Fuel Type	Pipeline natural gas
Maximum Power Output	236.1 MW (1 turbine @ 32° F)
Maximum Heat Input	2,273 mmbtu/hr HHV (1 turbine @ 32° F)
Maximum Fuel Consumption	2.16 mmcf/hr HHV (1 turbine @ 32° F, 1050 btu/cf)
Maximum Exhaust Flow ¹	70.1 mmcf/hr, dry @ 15% O ₂ (1 turbine @ 32° F)
NO _x Combustion Control	DLN 9 ppm
Steam Turbine Output at 63°F Ambient	221.4 MW (@ 32 deg)
Net Plant Heat Rate, LHV	6,017 btu/kWh @ 32° F
Net Plant Heat Rate, HHV	6,672 btu/kWh @ 32° F
Net Plant Efficiency, HHV	51.1%

1 - estimated using an F-factor of 8710 corrected to 15% O₂

Each turbine will exhaust to a Heat Recovery Steam Generator (HRSG). The HRSGs are designed to convert heat from the exhaust gas to produce steam for use in the steam turbine. Exhaust gases enter the HRSG at approximately 1100 deg F. The HRSG's employ a triple pressure design. Feed water into the HRSG will be converted to high, intermediate, and low pressure steam for use in the triple pressure steam turbine. The steam exits the steam turbine as low pressure steam, enters the air cooled condenser, and is cooled and condensed back into water. The SCR and oxidation catalyst will be contained within the HRSG.

- **CCTG Air Pollution Control (APC) Equipment**

APC equipment will be installed to control NO_x, CO, and VOC from the gas turbines. Each APC system will consist of the following: 1) Dry Low NO_x (DLN) Combustor, 2) SCR, and 3) Oxidation catalyst.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
15

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Dry Low NO_x Combustor - Each CT will be equipped with GE's DLN 2.6 combustor to reduce NO_x emissions to 9 parts-per-million volume dry basis (ppmvd) at 15 percent oxygen (O₂). The dry low NO_x control will be fully operational when the turbine reaches a load of approximately 44 percent or more.

Oxidation Catalyst System – The units will employ a palladium-type oxidation catalyst designed to reduce exhaust gas CO by about 70-85% to 2.0 ppm or less at 15% O₂, and VOC by 50-60% to 2.0 ppm at 15% O₂ (1 hour average).

Table 2.4 CCTG Oxidation Catalyst Data

Specification	
Manufacturer	BASF
Catalyst Type	Palladium in a honeycomb structure
Catalyst Volume	328.8 ft ³
Catalyst Area	1,879 ft ²
Catalyst Dimensions	2.1"W X 26.2'L X 71.8'H
Space Velocity	213,200 hr ⁻¹
Area Velocity	37,307 ft/hr
CO Removal Efficiency	70-85%
Outlet CO	2.0 ppmvd at 15% O ₂ 1 hour average
VOC Removal Efficiency	50-60%
Outlet VOC	2.0 ppmvd at 15% O ₂ 1 hour average
Minimum operating temperature	570 °F

Space and area velocities based on an exhaust flow rate of 70.1 mmcf/hr

Selective Catalytic Reduction System – The SCR will be designed to reduce NO_x emissions to 2.0 ppmvd at 15% O₂ on a 1 hour average basis. The SCR catalyst will be located downstream of the CO catalyst, and will consist of a vanadium/titanium/tungsten type catalyst in a honeycomb structure. Multiple SCR modules are arranged in 1 layer of catalyst approximately 1.5' deep. Total catalyst volume is about 2,761 ft³. Aqueous ammonia (ammonium hydroxide at 19% concentration by weight) from the storage tank will be vaporized, diluted with air, and injection into the exhaust through an injection grid. The amount of ammonia injected will vary depending on NO_x reduction requirements, but will be approximately a 1:1 to 1:1.2 molar ratio of ammonia to incoming NO_x.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
16

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table 2.5 CCTG SCR Catalyst Data

Specification	
Manufacturer	Cormetech
Catalyst Type	Titanium/Vanadium/Tungsten honeycomb
Catalyst Volume	2,761.3 ft ³
Catalyst Area	1,841 ft ²
Catalyst Dimensions	1.5'W X 25.71'L X 71.6'H
Space Velocity	25,387 hr ⁻¹
Area Velocity	38,077 ft/hr
Ammonia Injection Rate	32 gph, 242 lbm/hr of 19% NH ₃
Ammonia Slip	5.0 ppm
Outlet NOx	2.0 ppm at 15% 1 hour average
Guarantee	25,000 hours of operation, or 5 years
SCR/CO catalyst Total Cost	\$1 million
Operating temperature range	570 °F-692°F

Space and area velocities based on an exhaust flow rate of 70.1 mmSCF/hr.

- *Exhaust Stacks*

Each turbine/HRSR will be equipped with identical 20-foot diameter 150 feet tall stacks. The stacks will contain sampling ports for exhaust gas testing.

Table 2.6 CCTG Stack Data

Specification	
Stack Diameter	20 feet
Stack Height	150 feet
Stack Area	314.2 ft ²
Exhaust gas temperature	194 deg F
Exhaust gas velocity	4,017 feet/min @ 32 deg F

- *Simple Cycle Combustion Turbines*

The GE LMS100PB units are aeroderivative turbines which feature fast start capability and load following ability. The turbines will be equipped with inlet air filters, inlet air compressors, and evaporative coolers. The turbines are intercooled. Combustion air is compressed in two stages, and water cooled between stages back to its initial temperature. This reduces the volume of air and the work required to compress it. Water used in the intercooling is cooled in a fin-fan heat exchanger. Incoming combustion gas will be compressed to approximately 600 psi prior to combustion.

Heat input for each combustion turbine at nominal (site average temperature) is 885 mmBtu/hr (HHV), fuel use at these conditions is approximately 0.84 mmcf/hr, based on a natural gas heat content of 1050 Btu/cf. Turbines specs are summarized in the following table:



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
17

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table 2.7 Simple Cycle Turbine Data

Specification	
CT Manufacturer	GE
Model	LMS 100PB
Fuel Type	Pipeline natural gas
Maximum Power Output	100.8 MW (1 turbine @ 65.8°F)
Maximum Heat Input	885 mmbtu/hr HHV (1 turbine @ 65.8°F)
Maximum Fuel Consumption	0.84 mmcf/hr HHV (1 turbine @ 65.8°F, 1050 btu/cf)
Maximum Exhaust Flow ¹	27.3 mmcf/hr, dry @ 15% O ₂ (1 turbine @ 65.8° F)
NO _x Combustion Control	DLN 9 ppm
Net Plant Heat Rate, LHV	8,027 btu/kWh @ 65.8° F
Net Plant Heat Rate, HHV	8,910 btu/kWh @ 65.8° F
Net Plant Efficiency, HHV	38.3%

1 - estimated using an F-factor of 8710 corrected to 15% O₂

Emissions will be minimized with the use of dry low NO_x combustors, SCR and oxidation catalysts.

- **SCTG Air Pollution Control (APC) Equipment**

Dry Low NO_x Combustor - The PB units are equipped with dry low NO_x combustors. The combustor will produce NO_x emissions at 25 parts-per-million volume dry basis (ppmvd) at 15 percent oxygen (O₂). The dry low NO_x control will be fully operational when the turbine reaches a load of approximately 44 percent or more.

Oxidation Catalyst System – An oxidation catalyst will be installed in the exhaust section of the turbine. The catalyst is designed for maximum surface contact with the gas flow, and has a thickness of only 2.5 inches. The catalyst is sized to reduce exhaust gas CO by about 90-96% to 4.0 ppm or less at 15% O₂, and VOC by 50-60% to 2.0 ppm at 15% O₂ (1 hour average).

Table 2.8 SCTG Oxidation Catalyst Data

Specification	
Manufacturer	BASF Camet
Catalyst Type	Palladium in a honeycomb structure
Catalyst Volume	165.6 ft ³
Catalyst Area	794.8 ft ²
Catalyst Dimensions	0.21' W X 2.1' L X 2'H (each module, 187 total modules)
Space Velocity	164,855 hr ⁻¹
Area Velocity	34,348 ft/hr
CO Removal Efficiency	90-96%
Outlet CO	4.0 ppmvd at 15% O ₂ 1 hour average
VOC Removal Efficiency	50-60%
Outlet VOC	2.0 ppmvd at 15% O ₂ 1 hour average
Minimum operating temperature	500 °F

Space and area velocities based on an exhaust flow rate of 27.3 mmscf/hr



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
18

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Selective Catalytic Reduction System – An SCR catalyst will be installed in the exhaust downstream from the oxidation catalyst to reduce NO_x emissions to 2.5 ppmvd at 15% O₂ on a 1 hour average basis. The SCR catalyst will consist of a vanadium/titanium/tungsten type catalyst in a honeycomb structure. Total catalyst volume is about 622 ft³. Aqueous ammonia (ammonium hydroxide at 19% concentration by weight) from the storage tank will be vaporized, diluted with air, and injection into the exhaust through an injection grid. The amount of ammonia injected will vary depending on NO_x reduction requirements, but will be approximately a 1:1 to 1:1.2 molar ratio of ammonia to incoming NO_x.

Table 2.9 SCTG SCR Catalyst Data

Specification	
Manufacturer	Cormetech CMHT
Catalyst Type	Titanium/Vanadium/Tungsten honeycomb
Catalyst Volume	622 ft ³
Catalyst Area	126.5 ft ²
Catalyst Dimensions	4.9" W X 11.5" L X 11" H
Space Velocity	43,891 hr ⁻¹
Area Velocity	215,810 ft/hr
Ammonia Injection Rate	24 gph, 180 lbm/hr of 19% NH ₃
Ammonia Slip	5.0 ppm
Outlet NO _x	2.5 ppm at 15%
Guarantee	24,000 hours of operation, or 3 years
SCR/CO catalyst Total Cost	\$1.1 million
Operating temperature range	500 °F-870°F

Space and area velocities based on an exhaust flow rate of 27.3 mmscf/hr

- **Exhaust Stacks**

Each simple cycle turbine will be equipped with identical 13.5-foot diameter 80 feet tall stacks. The stacks will contain sampling ports for exhaust gas testing.

Table 2.10 SCTG Stack Data

Specification	
Stack Diameter	13.5 feet
Stack Height	80 feet
Stack Area	143.1 ft ²
Exhaust gas temperature	853 deg F
Exhaust gas velocity	6,551 feet/min @ 32 deg F

- **Monitoring Systems**

All four turbines will be equipped with in-stack continuous emission monitors for NO_x, CO, and O₂, along with individual fuel meters. A data acquisition system is required to collect information from



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
19

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

the analyzers and fuel meters to calculate exhaust flows and mass emissions of NO_x for transmission through the remote terminal unit (RTU). Other parameters which are required to be measured and recorded include the ammonia injection rate, exhaust temperature prior to the SCR catalyst, turbine output, and pressure drop across the SCR catalyst. A NO_x analyzer will be placed upstream of each SCR catalyst for fine tuning the ammonia injection rate and also for use in estimating ammonia slip.

- *Auxiliary Boiler*

The auxiliary boiler will be used to provide steam to both assist the combined cycle plant in reaching its base load quickly, and reduce the start up time. The boiler will be equipped with John Zink/Coen Rapid Mix Low NO_x burners and an SCR system to reduce NO_x emissions to 5 ppm and CO emissions to 50 ppm @ 3% O₂, 1 hour average. Steam from the boiler will not be used to generate any electrical power.

Start up operation

Steam produced in the boiler will be used for steam turbine gland sealing, which is required to initiate a vacuum in the condenser. This would normally require a regulated temperature ramp rate and hence a slower start up for the combustion turbine. However, with the gland seals preheated, the combustion turbine is allowed to ramp more quickly to its target production rate, which in turn results in the heating of the control catalysts quicker, and achieving BACT emission levels sooner.

The boiler may operate for extended periods of time at a hot standby load, which will allow the combined cycle turbines to be maintained in a state of readiness. The boiler's burner is capable of operating at a maximum turndown ratio of 0.25 while still meeting BACT emission level. In other instances, the boiler may be started (cold, warm, or hot) just prior to the turbines coming online. In those cases, the boiler will need from 25 minutes (hot start) to 170 minutes (cold start) to meet its BACT emission levels.

Table 2.11 Auxiliary Boiler Data

Specification	
Boiler Manufacturer	Rentech
Model	D-Type
Boiler Type	Water Tube
Fuel Type	Natural gas
Maximum Fuel Consumption	67,619 ft ³ /hr ⁽¹⁾
Maximum Exhaust Flow	723,540 ft ³ /hr ⁽²⁾
Maximum Heat Input	71 mmbtu/hr
NO _x Control	Low NO _x Burner/FGR/SCR
Number of Burners	1 per boiler
Burner Manufacturer/Model	JZHC/Coen RMB
Outlet NO _x	5 ppm @ 3% O ₂ 1 hour average
Outlet CO	50 ppm @ 3% O ₂ 1 hour average

(1) Based on 1050 btu/cf natural gas

(2) Based on an F factor of 8710 cf/mmbtu corrected to 3% O₂



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
20

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table 2.11 Auxiliary Boiler SCR Catalyst Data

Specification	
Manufacturer	B&W
Catalyst Type	Vanadium
Catalyst Volume	46 ft ³
Catalyst Area	28 ft ²
Space Velocity	15,729 hr ⁻¹
Area Velocity	25,841 ft/hr
Ammonia Slip	5 ppm @ 3% O ₂ 1 hour average
Outlet NO _x	5 ppm @ 3% O ₂ 1 hour average
Emissions Guarantee	3 years
Maximum operating temperature	628°F

Space and area velocities based on an exhaust flow rate of 723,540 scf/hr

- *Exhaust Stack*

The boiler exhaust will vent to a 3 foot diameter 80 foot tall stack. The stack will contain sampling ports for exhaust gas testing.

Table 2.12 Auxiliary Boiler Stack Data

Specification	
Stack Diameter	3 feet
Stack Height	80 feet
Stack Area	7.07 ft ²
Exhaust gas temperature	318 deg F
Exhaust gas velocity	4,170 feet/min

- *Ammonia Storage Tanks*

Two new tanks will store 19% aqueous ammonia solution for use in the turbines' and auxiliary boiler SCRs. A 35,000 gallon tank will serve the combined cycle turbines and the boiler. A 15,000 gallon tank will serve the simple cycle turbines. Both tanks will be horizontal pressure vessels with PRVs set at 50 psig. During loading, vapors from the tanks are vented back to the filling truck through the vapor return line. The tanks are designed so that under normal operating conditions, the pressure will not exceed the prv setting.

Estimated maximum aqueous ammonia use is about 32 gallons per hour for each combined cycle turbine (240 lbs/hr/7.5 lbs/gal). At an assumed capacity factor of 0.75 for the combined cycle plant, approximate annual aqueous ammonia use is 420,480 gallons (32 X 24 X 365 X 0.75 X 2 turbines). This is about 12 tank turnovers per year (about one tank filling every 4 weeks on average, accounting for the auxiliary boiler SCR use as well).



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
21

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Estimated maximum hourly aqueous ammonia use is about 24 gallons per hour for each simple cycle turbine (180 lbs/hr/7.5 lbs/gal), At an assumed capacity factor of 0.3 for the simple cycle plant, approximate annual aqueous ammonia use is 126,144 gallons (24 X 24 X 365 X 0.3 X 2 turbines). This is about 8 tank turnovers per year (about one tank filling every 6 weeks on average).

- *Cooling System*

There are no evaporative water cooling towers associated with this project, the combined cycle turbines will be air cooled. Exhaust steam from the STGs will be condensed in an air-cooled condenser. The air-cooled condenser will utilize large fans to blow ambient air across finned tubes through which the low-pressure steam flows. The condensate collects in a receiver located under the air-cooled condenser, Condensate pumps will then return the condensate from the receiver back to the HRSGs for reuse. The steam produced in the auxiliary boiler is passed through the HRSGs and steam turbines, and thus is also condensed in the air cooler. The simple cycle turbines do not require steam condensing, since they do not use heat recovery. The only cooling associated with the simple cycle turbines is the use of a fin fan air cooler to cool the water used in the intercooler.

- *Oil Water Separators*

There will be two new oil water separators (OWS) installed to serve the new power system. The OWS will collect potentially oily wastewater from equipment area wash downs and the HRSG feed water pump skid. The only potential oil contaminant is lubricating oil associated with the gas turbines and associated feed water pumps. Oil will be collected in the OWS and will be removed by vacuum truck before the oil collection section reaches its capacity. One OWS will serve the area around the combined cycle plant, and the other will serve the area around the simple cycle plant.

EMISSIONS:

Emissions from the proposed new project will consist of NO_x, CO, VOC, PM₁₀, PM_{2.5}, and SO_x, plus GHGs and toxics. There are 7 emissions sources: 2 combined cycle turbines, 2 simple cycle turbines, 1 auxiliary boiler, and 2 oil/water separators (emissions from the aqueous ammonia tanks can be assumed to be zero, since they are pressurized tanks).

Emissions from the turbines are calculated for 4 basic operational modes as follows:

1. commissioning – a 1 time event which occurs following installation and just prior to bringing the turbine online for commercial operation
2. start up – occurs each time the turbine is started
3. normal operation
4. shutdown – occurs each time the turbine is shutdown



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
22

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table 3.1 - Operational Scenarios for the HBEP Turbines

Scenario	Description
Commissioning	The commissioning operation will require each CT to operate individually as well as simultaneously under part load and full load. The testing will be performed on each CT for the purpose of “tuning in” the turbine combustor and control systems. Emissions are expected to be higher than normal operation. For the combined cycle turbines, the commissioning will take about 996 operating hours per turbine, for the simple cycle turbines, the commissioning is expected to take about 280 hours per turbine.
Startup	For the combined cycle turbines, 3 types of starts are defined – cold, warm , and hot. Cold starts occur after the turbine has been down for 48 hours or more, and the “start” will last about 1 hour (the time to reach proper operating temperature for full DLN, SCR and CO catalyst control). Warm starts occur after the turbine has been down 9 to 48 hours, and will last 30 minutes. Hot starts occur when the turbine has been down less than 9 hours, and will also last 30 minutes. For the simple cycle turbines, start ups last 30 minutes. Applicant anticipates 80 cold, 88 warm, and 332 hot starts per year for each combined cycle turbine, and 350 starts per year for each simple cycle turbine.
Normal Operating	Normal operation is defined as when the turbines are operating at fully controlled levels. Total operation in normal mode is estimated at 6100 hrs per year for each combined cycle turbine, and 1750 hours per year for each simple cycle turbine.
Shutdown	Shutdown is the process of reducing the turbine load and fuel flow to zero. Emissions tend to be higher during shutdowns due to the reduction in control equipment efficiencies as the process progresses.

The auxiliary boiler start ups will also be broken down into cold warm and hot, with the definition of each start as follows - cold starts occur after the boiler has been shutdown for 48 hours or more, warm starts occur after the boiler has been down for 9-48 hours, and hot starts occur after a shutdown of less than 9 hours.

AES has proposed the following operating schedule for the equipment at the facility:



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
23

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table 3.2 Combined Cycle Turbines Operating Schedule

Combined Cycle Turbine	Duration/ event	Monthly		Annual	
		Maximum # of Events	Maximum Hours of Operation	Maximum # of Events	Maximum Hours of Operation
Cold Starts	1 hr	15	15	80	80
Warm Starts	30 min	12	6	88	44
Hot Starts	30 min	35	17.5	332	166
Shutdowns	30 min	62	31	500	250
Normal Operation	////////	////////	674.5	////////	6100
		TOTAL	744	////////	6640

Table 3.3 Simple Cycle Turbines Operating Schedule

Simple Cycle Turbine	Duration /event	Monthly		Annual	
		Maximum # of Events	Maximum Hours of Operation	Maximum # of Events	Maximum Hours of Operation
Starts	30 min	62	31	350	175
Shutdowns	13 min	62	13.4	350	76
Normal Operation	////////	////////	700	////////	1750
		TOTAL	744	////////	2001

Table 3.4 Auxiliary Boiler Operating Schedule

Auxiliary Boiler	Duration/ event	Monthly		Annual	
		Maximum # of Events	Maximum Hours of Operation	Maximum # of Events	Maximum Hours of Operation
Cold Starts	170 min	2	5.7	24	68
Warm Start	85 min	4	5.7	48	68
Hot Start	25 min	4	1.7	48	20
Normal Operation ¹	////////	////////	222.4	////////	2,573.3
		TOTAL	235.5	////////	2,729.3

1 based on a heat input of 71 mmbtu/hr. Note that the unit may operate more hours at a lower heat input rate



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
24

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Detailed emission calculations can be referenced in Appendices A, B, C, D, E, F, and I.

Hourly Emissions

Table 3.5 Hourly Emissions During Normal Operation

Pollutant	Combined Cycle Turbine, lbs/hr	Simple Cycle Turbine, lbs/hr	Auxiliary Boiler, lbs/hr
NO _x	16.8	8.2	0.42
CO	10.2	7.9	2.83
VOC	5.8	2.3	0.37
PM ₁₀	8.5	6.24	0.51
SO _x	4.6	1.80	0.14

Table 3.6 Emissions During Start Ups and Shutdowns

Equipment	Event	NO _x , lbs/event	CO, lbs/event	VOC, lbs/event
Combined Cycle Turbine	Cold Start	61	325	36
	Warm Start	17	137	25
	Hot Start	17	137	25
	Shutdown	10	133	32
Simple Cycle Turbine	Start	16.6	15.4	2.80
	Shutdown	3.12	28.09	3.06
Auxiliary Boiler	Cold Start	4.22	4.34	1.05
	Warm Start	2.11	2.17	0.52
	Hot Start	0.62	0.64	0.15



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
25

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Daily Maximum Emissions

Table 3.7 Combined Cycle Turbines Daily Emissions (Maximum)


Pollutant	Operating Scenario	Controlled Daily Emissions 1 Turbine
NOx	1 cold start + 1 hot start + 2 shutdowns + 20.5 hrs normal	442.4
CO	1 cold start + 1 hot start + 2 shutdowns + 20.5 hrs normal	937.1
VOC	24 hrs normal (no start ups or shutdowns)	243.9
PM10	24 hrs normal (no start ups or shutdowns)	204
SOx	24 hrs normal (no start ups or shutdowns)	110.4
NH3	24 hr normal (no start ups or shutdowns)	317.8

Table 3.8 Simple Cycle Turbines Daily Emissions (Maximum)

Pollutant	Operating Scenario	Controlled Daily Emissions 1 Turbine
NOx	2 starts + 2 shutdowns + 21.57 hrs normal	216.3
CO	2 starts + 2 shutdowns + 21.57 hrs normal	259
VOC	2 starts + 2 shutdowns + 21.57 hrs normal	61.3
PM10	24 hrs normal (no start ups or shutdowns)	149.8
SOx	24 hrs normal (no start ups or shutdowns)	43.2
NH3	24 hr normal (no start ups or shutdowns)	144

Table 3.9 Auxiliary Boiler Daily Emissions (Maximum)

Pollutant	Operating Scenario	Controlled Daily Emissions
NOx	1 cold start + 21.17 hrs normal	13.1
CO	24 hrs normal (no start ups or shutdowns)	67.9
VOC	24 hrs normal (no start ups or shutdowns)	8.9
PM10	24 hrs normal (no start ups or shutdowns)	12.3
SOx	24 hrs normal (no start ups or shutdowns)	3.4
NH3	24 hr normal (no start ups or shutdowns)	3.8

	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 26	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

Monthly and Daily Average Emissions

Table 3.10 Combined Cycle Turbine Monthly Total and 30-Day Average Emissions (Per Turbine)

Pollutant	Operating Scenario	Total Monthly Emissions	30-Day Average Emissions
NOx	15 cold starts+12 warm starts+35 hot starts+62 shutdowns+674.5 hrs normal	13,665.6	455.5
CO	15 cold starts+12 warm starts+35 hot starts+62 shutdowns+674.5 hrs normal	26,439.9	881.3
VOC	15 cold starts+12 warm starts+35 hot starts+62 shutdowns+674.5 hrs normal	7,611.1	253.7
PM10	744 hrs normal (no starts ups or shutdowns)	6,324	210.8
SOx	744 hrs normal (no start ups or shutdowns)	3,422.4	114.1

Table 3.11 Simple Cycle Turbine Monthly Total and 30-Day Average Emissions (Per Turbine)

Pollutant	Operating Scenario	Total Monthly Emissions	30-Day Average Emissions
NOx	62 starts+62 shutdowns + 700 hrs normal	6,959.4	232.0
CO	62 starts+62 shutdowns + 700 hrs normal	8,273.4	275.8
VOC	62 starts+62 shutdowns + 700 hrs normal	1,972.4	65.7
PM10	744 hrs normal (no start ups or shutdowns)	4,642.6	154.8
SOx	744 hrs normal (no start ups or shutdowns)	1,339.3	44.6

Table 3.12 Auxiliary Boiler Monthly Total and 30-Day Average Emissions

Pollutant	Operating Scenario	Total Monthly Emissions	30-Day Average Emissions
NOx	2 cold starts +4 warm starts + 4 hot starts + 235.5 hrs normal	112.7	3.8
CO	2 cold starts +4 warm starts + 4 hot starts + 235.5 hrs normal	649.5	21.7
VOC	2 cold starts +4 warm starts + 4 hot starts + 235.5 hrs normal	87.1	2.9
PM10	2 cold starts +4 warm starts + 4 hot starts + 235.5 hrs normal	120.0	4.0
SOx	2 cold starts +4 warm starts + 4 hot starts + 235.5 hrs normal	32.9	1.1


	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 27	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

Table 3.13 Facility Monthly Total and 30-Day Average Emissions (Not Including Commissioning)

Equipment	NOx	CO	VOC	PM10	SOx
CCTG 1	13,665.6	26,439.9	7,611.1	6,324	3,422.4
CCTG 2	13,665.6	26,439.9	7,611.1	6,324	3,422.4
SCTG 1	6,959.4	8,273.4	1,972.4	4,642.6	1,339.3
SCTG 2	6,959.4	8,273.4	1,972.4	4,642.6	1,339.3
Aux Boiler	112.7	649.5	87.1	120.0	32.9
OWS 1	0	0	14.3	0	0
OWS 2	0	0	1.8	0	0
Total, lbs/month	41,362.7	70,076.1	19,270.2	22,053.2	9,556.3
30 Day Average, lbs/day	1378.8	2335.9	642.3	735.1	318.5

Table 3.14 Facility Monthly Total and 30-Day Average Emissions (Including Commissioning)

The highest NOx, CO, VOC, and SOx monthly emissions occur during CCTG commissioning. Note that PM10 is higher for the non-commissioning month (refer to Appendix C).

Pollutant	CCTG 1 Commissioning, lbs/month	CCTG 2 Commissioning, lbs/month	Total Facility Emissions, lbs/month	30-Day Average Emissions, lbs/day
NOx	22922	22922	45844	1528.1
CO	99076	99076	198152	6605.1
VOC	14109	14109	28218	940.6
PM10	3090	3090	6180	206.0
SOx	5406	5406	10812	360.4



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
28

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Annual Emissions

Table 3.15 Combined Cycle Turbine Annual Emissions

Pollutant	Operating Scenario	Total Annual Emissions, lbs
NOx	80 cold starts+88 warm starts + 332 hot starts + 500 shutdowns + 6100 hrs normal	119,500
CO	80 cold starts+88 warm starts + 332 hot starts + 500 shutdowns + 6100 hrs normal	212,260
VOC	80 cold starts+88 warm starts + 332 hot starts + 500 shutdowns + 6100 hrs normal	64,760
PM10	80 cold starts+88 warm starts + 332 hot starts + 500 shutdowns + 6100 hrs normal	56,440
SOx	80 cold starts+88 warm starts + 332 hot starts + 500 shutdowns + 6100 hrs normal	9,960
NH3	80 cold starts+88 warm starts + 332 hot starts + 500 shutdowns + 6100 hrs normal	94,550

Table 3.16 Simple Cycle Turbine Annual Emissions

Pollutant	Operating Scenario	Total Annual Emissions, lbs
NOx	350 starts+350 shutdowns + 1750 hrs normal	21,252
CO	350 starts+350 shutdowns + 1750 hrs normal	29,330
VOC	350 starts+350 shutdowns + 1750 hrs normal	6,076
PM10	350 starts+350 shutdowns + 1750 hrs normal	12,485
SOx	350 starts+350 shutdowns + 1750 hrs normal	1,201
NH3	350 starts+350 shutdowns + 1750 hrs normal	10,500



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
29

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table 3.17 Auxiliary Boiler Annual Emissions

Pollutant	Operating Scenario	Total Annual Emissions, lbs
NOx	24 cold starts+48 warm starts + 48 hot starts + 2573.3 hrs normal	1,313
CO	24 cold starts+48 warm starts + 48 hot starts + 2573.3 hrs normal	7,522
VOC	24 cold starts+48 warm starts + 48 hot starts + 2573.3 hrs normal	1,010
PM10	24 cold starts+48 warm starts + 48 hot starts + 2573.3 hrs normal	1,392
SOx	24 cold starts+48 warm starts + 48 hot starts + 2573.3 hrs normal	382
NH3	24 cold starts+48 warm starts + 48 hot starts + 2573.3 hrs normal	412

Table 3.18 Facility Annual Total Emissions (Not Including Commissioning)

Equipment	NOx	CO	VOC	PM10	SOx	NH3
CCTG 1	119,500	212,260	64,760	56,440	9,960	94,550
CCTG 2	119,500	212,260	64,760	56,440	9,960	94,550
SCTG 1	21,252	29,330	6,076	12,485	1201	10,500
SCTG 2	21,252	29,330	6,076	12,485	1201	10,500
Aux Boiler	1,313	7,522	1,010	1,392	382	412
OWS 1	0	0	171	0	0	0
OWS 2	0	0	22	0	0	0
Total, lbs/yr	282,817	490,702	142,875	139,242	22,704	210,512



Table 3.19 Facility Annual Total Emissions (Including Commissioning)

The highest NO_x, CO, VOC, and SO_x annual emissions occur during CCTG commissioning (refer to Appendix C).

Operating Mode	Hours	Emissions, lbs			
		NOx	CO	VOC	SOx
Commissioning CCTG 1	996	27,593	101,326	14,681	4,843
Commissioning CCTG 2	996	27,593	101,326	14,681	4,843
Post Commissioning Operation CCTG 1	6640	119,500	212,260	64,760	9,960
Post Commissioning Operation CCTG 2	6640	119,500	212,260	64,760	9,960
Auxiliary Boiler	2573.3	1,313	7,522	1,010	382
TOTAL EMISSIONS		295,499	634,694	159,892	29,988

The highest PM₁₀ annual emissions occur during SCTG commissioning (refer to Appendix C).

Operating Mode	Hours	PM10
Commissioning SCTG 1	280	1,747
Commissioning SCTG 2	280	1,747
Post Commissioning Operation SCTG 1	2001	12,484.5
Post Commissioning Operation SCTG 2	2001	12,484.5
CCTG 1	6640	56,440
CCTG 2	6640	56,440
Auxiliary Boiler	2573.3	1,392
TOTAL EMISSIONS		142,735



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
31

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Toxic Emissions

Table 3.20 Combined Cycle Turbine Toxic Emissions

Pollutant	Maximum Hourly Emission Rate, lbs/hr	Annual Emissions 1 Turbine, lbs/yr
Ammonia	15.5	94550
1,3 Butadiene	9.48E-04	6.30
Acetaldehyde	3.89E-01	2581.56
Acrolein	7.97E-03	52.92
Benzene	7.19E-03	47.76
Ethyl Benzene	7.04E-02	467.55
Formaldehyde	7.93E-01	5263.51
Naphthalene	2.87E-03	19.07
PAH	1.98E-03	13.17
Propylene Oxide	6.39E-02	424.52
Toluene	2.87E-01	1907.49
Xylene	1.41E-01	936.53
Total	Lbs/yr	106,270.4
	Tons/yr	53.1

Table 3.21 Simple Cycle Turbine Toxic Emissions

Pollutant	Maximum Hourly Emission Rate, lbs/hr	Annual Emissions 1 Turbine, lbs/yr
Ammonia	6.0	10500
1,3 Butadiene	3.73E-04	0.75
Acetaldehyde	1.53E-01	306.18
Acrolein	3.14E-03	6.28
Benzene	2.83E-03	5.66
Ethyl Benzene	2.77E-02	55.45
Formaldehyde	3.12E-01	624.27
Naphthalene	1.13E-03	2.26
PAH	7.80E-04	1.56
Propylene Oxide	2.52E-02	50.35
Toluene	1.13E-01	226.23
Xylene	5.55E-02	111.08
Total	Lbs/yr	11890.1
	Tons/yr	5.95



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
32

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table 3.22 Auxiliary Boiler Toxic Emissions

Pollutant	Maximum Hourly Emission Rate, lbs/hr	Annual Emissions, lbs/yr
Ammonia	0.16	411.7
Benzene	4.06E-04	1.04
Formaldehyde	8.61E-04	2.21
PAH	7.00E-06	0.02
Naphthalene	2.10E-05	0.05
Acetaldehyde	2.17E-04	0.56
Acrolein	1.89E-04	0.49
Toluene	1.86E-03	4.77
Xylene	1.38E-03	3.55
Ethyl Benzene	4.83E-04	1.24
Hexane	3.22E-04	0.83
Propylene	3.71E-02	95.40
Total	Lbs/yr	521.86
	Tons/yr	0.26

GHG Emissions

Table 3.23 Combined Cycle Turbine GHG Emissions

GHG	Hourly Tons Per Turbine	Annual Tons Per Turbine	Annual Tons 2 Turbines
CO2	132.9	873,034.6	1,746,069.1
CH4	2.51E-03	16.45	32.9
N2O	2.51E-04	1.65	3.29
Total Mass	132.9	873,052.7	1,746,105.3
CO2e	133.1	873,937.6	1,747,872.5



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
33

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table 3.24 Simple Cycle Turbine GHG Emissions


GHG	Hourly Tons Per Turbine	Annual Tons Per Turbine	Annual Tons 2 Turbines
CO2	51.8	103,575.5	207,151.1
CH4	9.75E-04	1.96	3.91
N2O	9.75E-05	0.20	0.40
Total Mass	51.8	103,577.7	207,155.4
CO2e	51.9	103,684.1	207,368.1

Table 3.25 Auxiliary Boiler GHG Emissions

GHG	Emissions	
	Lbs/hr	tons/yr
CO2	5067.0	11,065.31
CH4	9.58E-02	0.21
N2O	9.58E-03	0.02
Total Mass	5,066.83	11,065.56
CO2e	5,071.90	11,075.93

Table 3.26 Circuit Breaker GHG Emissions

AEC Electric Breakers	Total SF6 (lbs)	Annual SF6 Emissions (lbs/yr)
1200A 230kV	230	1.15
1200A 230kV	230	1.15
1200A 230kV	230	1.15
3000A 230kV	230	1.15
10000A 18kV	25	0.125
10000A 18kV	25	0.125
10000A 18kV	25	0.125
2000A 230kV	216	1.08
GCB 13.8kV	24	0.12
GCB 13.8kV	24	0.12
	TOTAL	6.3 lbs/yr
	CO2e	71.8 tons/yr

	South Coast Air Quality Management District		PAGE 34	PAGES 212
	Engineering Division Application Processing & Calculations		APPL NO. See Below	DATE 6/7/16
			PROCESSED BY CP01	CHECKED BY

EVALUATION:

RULE 212-Standards for Approving Permits

This project is subject to Rule 212 public notice requirements because the daily maximum VOC, CO, NO_x, and PM₁₀ emissions from the project will all exceed the emissions thresholds specified in subdivision (g) of this rule. The facility is not located within 1000 feet of a school (the closest school is Edison High located approximately 0.6 miles north-east of the site). The District will prepare the public notice and it will contain sufficient information to fully describe the project.

In accordance with subdivision (d) of this rule, the applicant will be required to distribute the public notice to each address within ¼ mile radius of the project.

Subdivision (g) requires that the public notification and comment process include all applicable provisions of 40 CFR Part 51, Section 51.161(b) and 40 CFR Part 124, Section 124.10. The minimum requirements specified in the above documents are included in paragraphs (g)(1), (g)(2), and (g)(3).

In accordance with paragraph (g)(1) of this rule, the District will make the following information available for public inspection at the Huntington Beach Public Library located at 7111 Talbert Ave, Huntington Beach 92648, during the 30-day comment period: public notice, project information submitted by the applicant, and the District's permit to construct evaluation.

In accordance with paragraph (g)(2) of this rule, the public notice will be published in a newspaper which serves the area that will be impacted by the project.


In accordance with paragraph (g)(3) of this rule, the public notice will be mailed to the following persons: the applicant, the Region IX EPA administrator, the ARB, the chief executives of the city and county where the project will be located, the regional land use planning agency, and the state and federal land managers whose lands may be affected by the emissions from the proposed project.

SCAQMD also periodically includes a notice in the *SCAQMD Advisor* advising interested parties on how to receive notification of PSD projects. The latest notice was included in the March 2016 issue.

After the public notice is published, there will be a 30-day period for submittal of public comments.

RULE 218 – Continuous Emission Monitoring

In order to insure the turbines meet the CO BACT limit as specified in the permit, a CO CEMS will be required by permit condition. The CO CEMS must be certified in accordance with Rule 218. The rule requires submittal of an “Application for CEMS” for approval. Once approved, CEMS data must be recorded and records of the data must be maintained on site for at least 2 years. Additionally,

	South Coast Air Quality Management District		PAGE 35	PAGES 212
	Engineering Division Application Processing & Calculations		APPL NO. See Below	DATE 6/7/16
			PROCESSED BY CP01	CHECKED BY

every 6 months a summary of the CEMS data must be submitted to AQMD. Any CEMS breakdowns must also be reported. Compliance with this rule is expected. The auxiliary boiler will not be required to have a CO CEMS.

RULE 401 – Visible Emissions

This rule limits visible emissions to an opacity of less than 20 percent (Ringlemann No.1), as published by the United States Bureau of Mines. Visible emissions are not expected during normal operation from the turbines, auxiliary boiler, oil/water separators, or ammonia tanks.

RULE 402 - Nuisance

This rule requires that a person not discharge from any source whatsoever such quantities of air contaminants or other material which cause injury, detriment, nuisance, or annoyance to any considerable number of persons or to the public, or which cause, or have a natural tendency to cause injury or damage to business or property. The turbines, auxiliary boiler, oil/water separators, and ammonia tanks are not expected to create nuisance problems under normal operating conditions.

RULE 403 – Fugitive Dust

The purpose of this rule is to reduce the amount of particulate matter entrained in the ambient air as a result of man-made fugitive dust sources by requiring actions to prevent, reduce, or mitigate fugitive dust emissions. The provisions of this rule apply to any activity or man-made condition capable of generating fugitive dust. This rule prohibits emissions of fugitive dust beyond the property line of the emission source. The applicant will be taking steps to prevent and/or reduce or mitigate fugitive dust emissions from the project site. They have proposed the following measures:

Watering unpaved roads and disturbed areas

Limiting onsite vehicle speeds to 10 mph and posting the speed limit

Frequent watering during periods of high winds when excavation/grading is occurring

Sweeping onsite paved roads and entrance roads on an as-needed basis

Replacing ground cover in disturbed areas as soon as practical

Covering truck loads when hauling materials that could be entrained during transit

Applying dust suppressants or covers to soil stockpiles and disturbed areas when inactive for more than 2 weeks

In addition, the applicant will need to implement all Best Available Control Measures listed in Table 1 of the rule.

The installation and operation of the turbines and associated equipment is expected to comply with this rule.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE 36	PAGES 212
APPL NO. See Below	DATE 6/7/16
PROCESSED BY CP01	CHECKED BY

Rule 404 – Particulate Matter Concentration

This rule applies to the auxiliary boiler. Turbines are exempt under paragraph (c) of the rule. The rule limits the PM concentration based on the stack flow. At maximum firing rate, the boiler stack flow is estimated to be:

$$71 \text{ mmbtu/hr} \times [8710 \text{ cf/mmbtu}(20.9/20.9-3)] = 723,540 \text{ cf/hr, or } 12,059 \text{ cfm}$$

At this exhaust flow rate, maximum allowable PM concentration is 0.073 gr/scf.

Estimated PM concentration

$$(0.51 \text{ lbs/hr} \times 7000 \text{ gr/lb}) / 723,540 \text{ cf/hr} = 0.0049 \text{ gr/scf}$$

Compliance is expected.

RULE 407 – Liquid and Gaseous Air Contaminants

This rule limits CO emissions to 2000 ppmv. The SO₂ portion of the rule does not apply as the natural gas fired in the turbines and auxiliary boiler will be subject to the sulfur limit in Rule 431.1. The CO emissions from the combined cycle turbines will be controlled by an oxidation catalyst to 2.0 ppmvd at 15% O₂. The CO emissions from the simple cycle turbines will be controlled by an oxidation catalyst to 4.0 ppmvd at 15% O₂, and the CO emissions from the boiler will be maintained at 50 ppm at 3% O₂. Therefore, compliance with this rule is expected.

RULE 409 – Combustion Contaminants

This rule restricts the discharge of contaminants from the combustion of fuel to 0.23 grams per cubic meter (0.1 grain per cubic foot) of gas, calculated to 12% CO₂, averaged over 15 minutes. The turbines and boiler are expected to meet this limit at the maximum firing load based on the calculations shown below. Compliance will be verified through the initial performance test.

$$\text{Grain Loading} = [(A \times B) / (C \times D)] \times 7000 \text{ gr/lb}$$

where:

A = PM₁₀ emission rate during normal operation

B = Rule specified percent of CO₂ in the exhaust (12%)

C = Percent of CO₂ in the exhaust (approx. 4.29% for natural gas)

D = Stack exhaust flow rate

Combined Cycle Turbines



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
37

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

$$\begin{aligned} \text{Grain Loading} &= \frac{8.5 \text{ lbs/hr} \times [(7000 \text{ grains/lb}) \times (12/4.29)]}{70.1\text{E}+06 \text{ scf/hr}} \\ &= \boxed{0.002 \text{ grains/scf}} \end{aligned}$$

$$\begin{aligned} \text{Simple Cycle Turbines Grain Loading} &= \frac{6.24 \text{ lbs/hr} \times [(7000 \text{ grains/lb}) \times (12/4.29)]}{27.3\text{E}+06 \text{ scf/hr}} \\ &= \boxed{0.004 \text{ grains/scf}} \end{aligned}$$

$$\begin{aligned} \text{Auxiliary Boiler Grain Loading} &= \frac{0.51 \text{ lbs/hr} \times [(7000 \text{ grains/lb}) \times (12/4.29)]}{0.724\text{E}+06 \text{ scf/hr}} \\ &= \boxed{0.014 \text{ grains/scf}} \end{aligned}$$

RULE 431.1 – Sulfur Content of Gaseous Fuels

The natural gas supplied to the turbines and auxiliary boiler is expected to comply with the 16 ppmv sulfur limit (calculated as H₂S) specified in this rule. Commercial grade natural gas has an average sulfur content of about 4ppm. The long term (annual) SO_x emissions from the turbines are based on 4 ppm or about 0.25 gr/100 cf concentration. The short term (hourly, daily, and monthly) SO_x emissions from the turbines are based on 12 ppm or about 0.75 gr/100 cf concentration. A condition will be placed on the permit to require that the sulfur content is measured and recorded to insure compliance. The applicant will also comply with reporting and record keeping requirements as outlined in subdivision (e) of this rule.

RULE 475 – Electric Power Generating Equipment

This rule applies to power generating equipment greater than 10 MW installed after May 7, 1976. Requirements are that the equipment meet a limit for combustion contaminants of 11 lbs/hr or 0.01 gr/scf. Compliance is achieved if either the mass limit or the concentration limit is met. Mass PM₁₀ emissions from the combined cycle turbines are estimated at 8.5 lbs/hr, and 0.0026 gr/scf at maximum firing load, and PM₁₀ emissions for the simple cycle turbines are estimated at 6.24 lbs/hr and 0.0049 gr/scf at maximum firing load (see calculations below). Therefore, compliance is



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
38

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

expected. Compliance will be verified through the initial performance test as well as ongoing periodic testing.

$$\text{Stack Exhaust Flow} \left(\frac{\text{scf}}{\text{hr}} \right) = F_d \times \frac{20.9}{(20.9 - \%O_2)} \times TFD$$

where:

Fd: Dry F factor for fuel type, 8710 dscf/MMBtu

O2: Rule specific dry oxygen content in the effluent stream, 3%

TFD: Total fired duty measured at HHV

$$\text{Combustion Particulate} \left(\frac{\text{grain}}{\text{scf}} \right) = \frac{PM_{10}, \text{ lb / hr}}{\text{Stack Exhaust Flow, scf / hr}} \times 7000 \frac{\text{gr}}{\text{lb}}$$

Combined Cycle Turbines

$$\text{Stack flow} = 8710(20.9/17.9) \times 2273 = 23.1 \text{ mmscf/hr}$$

$$\text{Combustion particulate} = (8.5/23.1E+06) \times 7000 = \boxed{0.0026 \text{ gr/scf}}$$

Simple Cycle Turbines

$$\text{Stack flow} = 8710(20.9/17.9) \times 885 = 9.0 \text{ mmscf/hr}$$

$$\text{Combustion particulate} = (6.24/9.0E+06) \times 7000 = \boxed{0.0049 \text{ gr/scf}}$$

RULE 1134 – Emissions of NOx from Gas Turbines

This rule applies to gas turbines, 0.3 MW and larger, installed on or before August 4, 1989. Therefore, as a new installation, the proposed HBEP turbines are not subject to this rule.

RULE 1135 – Emissions of NOx from Electric Power Generating Systems

This rule applies to the electric power generating systems of several of the major utility companies in the basin, including SCE and their successors. The plants which are included in the RECLAIM program are no longer subject to the requirements of this rule.

Rule 1146 – NOx from Boilers

This rule applies to boilers over 5 mmbtu/hr. Emission limits are 9 ppm NOx for gas firing, and 400 ppm CO.

The auxiliary boiler is equipped with a Low NOX burner, incorporating FGR, and manufacturer guaranteed emission rates of NOx ≤ 9 ppm and CO ≤ 50 ppm. The boiler will also be equipped with an SCR which will further reduce NOx to 5 ppm. Under the rule, the unit must be tested periodically using a portable analyzer method every 750 operating hours, or monthly, whichever occurs later. If 3 consecutive tests show compliance without adjustment to the oxygen sensor set points, then the



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
39

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

periodic tests are only required every 2,000 hours or quarterly. Furthermore, for boilers >10 mmbtu/hr, a stack test using the reference methods is required every 3 years. Since the HB facility is subject to NO_x RECLAIM, only the CO limits are applicable to the boiler, and the periodic monitoring and stack testing is only required for CO. Compliance is expected.

REGULATION XIII/Rule 2005 – New Source Review

The new turbines, auxiliary boiler, ammonia tanks, and oil/water separators are subject to NSR. All equipment must be installed with BACT. In addition, some of the emissions are subject to modeling and offsets. The installation of all the new equipment at the Huntington Beach plant is considered a major modification to an existing major source. Therefore, the additional requirements for major sources are applicable.

The applicant is requesting that the project be evaluated under the Rule 1304(a)(2) – Electric Utility Steam Boiler Replacement exemption. This provision applies to the replacement of a utility steam boiler with combined cycle gas turbine(s), or other advanced gas turbines (including intercooled turbines), and allows an exemption from the criteria pollutant modeling required under Rule 1303(b)(1), and from offsets for non-Reclaim pollutants required under Rule 1303(b)(2) in such cases. The exemption applies on a MW to MW basis. Its purpose was to facilitate the removal of older less efficient boiler/steam turbine technology with newer cleaner gas turbine technology at the utilities, in conjunction with the old Rule 1135. Since the advent of Reclaim, the exemption was expanded to include modifications being conducted in order to comply with Reg. XX rules. Rule 2005 does not provide a similar exemption for NO_x.

In order to qualify for the exemption, AES HB is proposing to shutdown 3 boilers in conjunction with the construction of the new HBEP. The 3 boilers include Boilers 1 and 2 at the Huntington Beach site, as well as Boiler 7 at AES' Redondo Beach Generating Facility, located at 1100 N. Harbor Dr, Redondo Beach, CA 90277. The capacity of the boilers being shutdown is shown in the table below:

Table 4.1 Capacity of Units Being Shutdown

Unit	Capacity, MW
Boiler 1, HB	215
Boiler 2, HB	215
Boiler 7, RB	480
Total Shutdown Capacity	910

The shutdown capacity is based on the description of the units as listed in the current SCAQMD permits.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
40

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

The capacity of the new units is summarized below:

Table 4.2 Capacity of New Units

Unit	Total Gross Capacity as Permitted, MW
CCTG 1	346.9
CCTG 2	346.9
SCTG 1	100.8
SCTG 2	100.8
Total New Capacity	895.5

MW rating for the CCTGs at 32° F and includes ½ the rating of the steam turbine

The capacity of the units being shutdown is sufficient to cover the capacity of the new units, therefore, the new units qualify for the offset and modeling exemption. The actual emissions from the 2 units being shutdown at the Huntington Beach facility (Boiler 1 and 2) are shown in Appendix N for reference.

Note that the new turbine's emission increases for PM10 and VOC will be accounted for through SCAQMD's internal offset 'bank', under the provisions of Rule 1304.1. Offsets for CO are not required, since CO is in attainment. NOx and SOx emissions are covered under RECLAIM.

- Offsets (for Non-Exempt Equipment)

The emissions from the auxiliary boiler and oil/water separators do not fall under the utility boiler replacement exemption. Offsets for non-RECLAIM pollutants VOC and PM10 for this equipment will be provided in the form of ERCs (offsets for CO emissions are not required).

Table 4.3 Offsets Required for Equipment Not Exempt Under the Steam Boiler Replacement

Equipment	VOC			PM10		
	Lbs/month	Lbs/day	Offsets Required ¹	Lbs/month	Lbs/day	Offsets Required ¹
Auxiliary Boiler	87.1	2.9	4	120.0	4.0	5
OWS 1	14.3	0.48	1	0	0	0
OWS 2	1.8	0.06	0	0	0	0

1 includes an offset factor of 1.2



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
41

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Under Rule 2005, RTCs to cover the expected emissions of NO_x are required to be held for the first compliance year. Additionally, since the NO_x PTE after the first year is less than the facility's initial allocation, the facility is not required to hold NO_x RTCs for subsequent years. The Huntington Beach facility is also in the SO_x RECLAIM program. Therefore, SO_x RTCs are required to be held to cover the first year of operation. Additionally, because the facility opted into SO_x RECLAIM after 1994, there is no initial allocation. For this reason, SO_x RTCs are required to be held for each compliance year after the first year of operation [paragraph (f)(1)]. RTC requirements are shown in Appendix S.

○ BACT

BACT is required for all criteria pollutants and ammonia. For major sources, BACT is determined at the time the permit is issued, and is the Lowest Achievable Emission Rate (LAER), which has been Achieved in Practice. Based on recently issued permits, (including LADWP Scattergood, Oakley Generating Station, El Segundo Power, Canyon Power, and El Cajon Energy, see Appendix T) SCAQMD has determined that BACT for the gas turbines is as follows:

Table 4.4 Combined Cycle Turbine Required BACT

NO _x	CO	VOC	PM ₁₀	SO _x	NH ₃
2.0 ppmdv @ 15% O ₂ , 1 hour average	2.0 ppmdv @ 15% O ₂ , 1 hour average	2.0 ppmdv @ 15% O ₂ , 1 hour average	Natural gas fuel	Natural gas fuel with fuel sulfur content of no more than 1 grain/100 scf (about 16 ppm)	5.0 ppmdv @ 15% O ₂ , 1 hour average

The applicant is proposing the following emission levels for the combined cycle turbines. The emission levels of NO_x, CO, VOC, and NH₃ in the table are manufacturer guaranteed emissions under normal operating conditions.

TABLE 4.5 – Proposed Control Levels for the HBEP Combined Cycle Turbines

NO _x	CO	VOC	PM ₁₀	SO _x	NH ₃
2.0 ppmvd @ 15% O ₂ , 1 hour average	2.0 ppmvd @ 15% O ₂ , 1 hour average	2.0 ppmvd @ 15% O ₂ , 1 hour average	Exclusive use of natural gas fuel, PM ₁₀ emissions of 8.5 lbs/hr	Exclusive use of natural gas fuel*	5.0 ppmdv @ 15% O ₂ , 1 hour average

**Natural gas provided by the Gas Company is limited to 16 ppm in the South Coast by Rule 431.1. Generally, the actual sulfur content is about 4 ppm (4 ppm corresponds to 0.25 gr/100 scf)*



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
42

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table 4.6 Simple Cycle Turbine Required BACT

NO _x	CO	VOC	PM ₁₀	SO _x	NH ₃
2.5 ppmdv @ 15% O ₂ , 1 hour average	4.0 ppmdv @ 15% O ₂ , 1 hour average	2.0 ppmdv @ 15% O ₂ , 1 hour average	Natural gas fuel	Natural gas fuel with fuel sulfur content of no more than 1 grain/100 scf (about 16 ppm)	5.0 ppmdv @ 15% O ₂ , 1 hour average

The applicant is proposing the following emission levels for the simple cycle turbines. The emission levels of NO_x, CO, VOC, and NH₃ in the table are manufacturer guaranteed emissions under normal operating conditions.

TABLE 4.7 – Proposed Control Levels for the HBEP Simple Cycle Turbines

NO _x	CO	VOC	PM ₁₀	SO _x	NH ₃
2.5 ppmvd @ 15% O ₂ , 1 hour average	4.0 ppmvd @ 15% O ₂ , 1 hour average	2.0 ppmvd @ 15% O ₂ , 1 hour average	Exclusive use of natural gas fuel, PM ₁₀ emissions of 6.24 lbs/hr	Exclusive use of natural gas fuel*	5.0 ppmdv @ 15% O ₂ , 1 hour average

**Natural gas provided by the Gas Company is limited to 16 ppm in the South Coast by Rule 431.1. Generally, the actual sulfur content is about 4 ppm (4 ppm corresponds to 0.25 gr/100 scf)*

Table 4.8 Auxiliary Boiler Required BACT

NO _x	CO	VOC	PM ₁₀	SO _x	NH ₃
5.0 ppmdv @ 3% O ₂ , 1 hour average	100 ppmdv @ 3% O ₂ , (water tube boilers)	none	Natural gas fuel	Natural gas fuel	5.0 ppmdv @ 3% O ₂

The applicant is proposing the following emission levels for the auxiliary boiler. The emission levels of NO_x, CO, and NH₃ in the table are manufacturer guaranteed emissions under normal operating conditions.


	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 43	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

TABLE 4.9 – Proposed Control Levels for the Auxiliary Boiler

NOX	CO	VOC	PM10	SOX	NH3
5.0 ppmvd @ 3% O ₂ , 1 hour average	50.0 ppmvd @ 3% O ₂ , 1 hour average	none	Exclusive use of natural gas fuel	Exclusive use of natural gas fuel	5.0 ppmvd @ 3% O ₂ , 1 hour average

BACT for the ammonia tank is the use of a pressure vessel equipped with a p/v valve.

- Modeling

The applicant conducted a modeling analysis to determine NO₂ impacts from the new turbines as required by Rule 2005. And although non-RECLAIM pollutant emissions from the turbines are exempt from modeling pursuant to the Electric Utility Steam Boiler Replacement exemption, a modeling analysis was performed for CO, SO₂, and PM₁₀ for purposes of the CEC's review of project impacts. Additionally, the auxiliary boiler emissions, which are not exempt from modeling under SCAQMD rules, were included along with the turbines in the modeling performed for the project.

Modeling evaluations were performed using the American Meteorological Society/USEPA AERMOD (version 15181) model and representative meteorological data from the John Wayne Airport meteorological station. Modeling analysis was performed for turbine startups, normal turbine operation, turbine commissioning operations, along with the auxiliary boiler emissions. A discussion of the modeling procedure and the inputs used in the modeling are shown in Appendix H.

The air basin where the facility is located is in attainment for NO₂, CO, and SO₂. PM₁₀ was designated as a federal attainment pollutant in the SCAB on July 26, 2013, however it remains in non-attainment status at the state level and will therefore be evaluated as non-attainment. The compliance determination for NO₂, CO, and SO₂ is a comparison of the project impact plus the background concentration to show that it does not exceed the AAQS. For PM₁₀, the project impact should not exceed the Significant Increment. The results of the model show that the project will not cause a violation, or make significantly worse an existing violation, of any state or national ambient air quality standard. Model results are summarized in the tables below.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
44

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table 4.10 Model Results – Start Up/Shutdown and Normal Operation

Pollutant	Averaging Period	Maximum Predicted Impact (ug/m3)	Background Concentration (ug/m3)	Total Concentration (ug/m3)	NAAQS (ug/m3)	CAAQS (ug/m3)
NO2	1-hour	95	142	237	////////	339
	1-hour Federal	27.8	98.2	126	188	////////
	Annual	0.59	21.8	22.4	100	57
CO	1-hour	631	3,435	4,066	40,000	23,000
	8-hour	149	2,519	2,668	10,000	10,000
SO2	1-hour	5.76	23.1	28.9	////////	655
	1-hour Federal	5.4	23.1	28.5	196	////////
	3-hour	5.01	23.1	28.2	1,300	////////
	24-hour	1.66	5.2	6.86	365	105
PM10	24-hour	4.7	51.0	55.7	150	50
	Annual	0.6	19.3	19.9	////////	20
PM2.5	24-hour Federal	4.7	21.3	26	35	////////
	Annual	0.6	8.6	9.2	12	12

The maximum 1 hour and annual NO2 concentrations include ambient NO2 ratios of 0.80 and 0.75 respectively. The model includes emissions from all 5 stacks combined (2 CCTG, 2 SCTG, and the aux boiler)

Table 4.11 Model Results, CCTG Commissioning

Pollutant	Averaging Period	Maximum Predicted Impact (ug/m3)	Background Concentration (ug/m3)	Total Concentration (ug/m3)	NAAQS (ug/m3)	CAAQS (ug/m3)
NO2	1-hour	169	142	311	////////	339
	Annual	0.66	21.8	22.5	100	57
CO	1-hour	4,341	3,435	7,776	40,000	23,000
	8-hour	3,000	2,519	5,519	10,000	10,000
PM10	Annual	0.57	19.3	19.9	////////	20
PM2.5	Annual	0.57	8.6	9.2	12	12



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
45

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table 4.12 Model Results, SCTG Commissioning

Pollutant	Averaging Period	Maximum Predicted Impact (ug/m3)	Background Concentration (ug/m3)	Total Concentration (ug/m3)	NAAQS (ug/m3)	CAAQS (ug/m3)
NO ₂	1-hour	79.1	142	221	////////	339
	Annual	0.50	21.8	22.3	100	57
CO	1-hour	527	3,435	3,962	40,000	23,000
	8-hour	131	2,519	2,650	10,000	10,000
PM ₁₀	Annual	0.52	19.3	19.8	////////	20
PM _{2.5}	Annual	0.52	8.6	9.1	12	12

The modeling was reviewed by SCAQMD modeling staff and deemed acceptable. Refer to the memo from Ian MacMillan to Andrew Lee dated May 18, 2016.

Other requirements of Rule 1303:

Sensitive Zone Requirements. For this project, ERCs may be obtained from Zone 1 only.

Facility Compliance. This facility is currently in compliance with all applicable rules and regulations of the District.

Alternative Analysis. The project is subject to the California Energy Commission licensing procedure. Under this procedure, a full analysis of the proposal is conducted, including project alternatives. The alternative project analysis was conducted under the previous HBEP AFC in 2012

The following alternative generating technologies were considered:

○ Conventional Boiler and Steam Turbine
Rejected because of the low efficiency and large space requirements

○ Kalina Combined-Cycle
Rejected because the technology is still in development stage

○ Internal Combustion Engine
Rejected because of higher emissions profile and smaller output than proposed turbine plant

The following fuel technology alternatives were considered:

○ Geothermal and Hydroelectric
Rejected because there are no geothermal or hydroelectric resources near the plant site



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
46

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

○ Biomass

Rejected because there are not enough locally available sources of biomass

○ Wind

Rejected because the site does not experience sufficient wind resources

○ Solar

Rejected because of space limitations and lack of sufficient solar resources

AES also considered wet cooling using either potable or recycled water, or seawater, as an alternative to the proposed dry cooling of the turbines. This was rejected because in the case of potable water, its use for power plant cooling purposes is discouraged by SWRCB and the CEC. In the case of recycled water, an additional pipeline and treatment facility would need to be constructed to supply enough water at the required level of treatment to serve the plant. The seawater option was rejected because of the environmental impacts of a seawater intake pipe, and cost considerations.

An alternative to the proposed site of the power plant was determined to be not necessary because PRC 25540.6 [b] states that if the commission finds ‘that the project has a strong relationship to the existing industrial site’’it is therefore reasonable not to analyze alternatives sites for the project’.


Protection of Visibility. Net Increase in emissions from the proposed project exceed the 15 tons per year PM₁₀ and 40 tons per year NO_x thresholds, but the site is not within the specified distance of any Class I areas. Distances to the Class I areas are summarized below:

Table 4.13 Distances to Class I Areas

Federal Class I Area	Threshold Distance (km)	Distance from the HBEP (km)
Cucamonga Wilderness	28	69
San Gabriel Wilderness	29	69.9
San Geronio Wilderness	32	107.6
San Jacinto Wilderness	28	114.2
Agua Tibia Wilderness	28	90.6
Joshua Tree NP	29	145.4

A visibility analysis was conducted under the PSD regulation.

Statewide Compliance. The facility submitted a statement dated October 12, 2015 from Stephen O’Kane, a corporate officer, certifying that all AES’s stationary sources are currently in compliance with applicable state and federal environmental regulations.

	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 47	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

Rule 1304.1 – Electrical Generating Facility Fee for Use of Offset Exemption

The project will utilize the offset exemption of Rule 1304(a)(2) for PM10 and VOC, and is therefore subject to a fee under this rule. The facility has opted to pay an annual fee. The formula for calculating this fee is as follows:

$$[(R_{iA1} \times 100 / MW) + R_{iA2} \times (MW - 100) / MW] \times OF_i \times PTE_{rep_i} \times [(C_{rep} - C_{2YRAvgExisting}) / C_{rep}]$$

Where:

Fi	=	Offset fee for pollutant (i)
RiA1	=	Annual Offset Fee Rate for pollutant (i), in terms of dollars per pound per day, annually (Table A1 of the rule)
RiA2	=	Annual Offset Fee Rate for pollutant (i), in terms of dollars per pound per day, annually (Table A2 of the rule)
MW	=	MW of new replacement units
OFi	=	Offset factor pursuant to Rule 1315(c)(2) for extreme non-attainment pollutants and their precursors (Tables A1 and A2 of the rule)
PTerepi	=	permitted potential to emit of new replacement units for pollutant (i), in pounds per day (maximum permitted monthly emissions ÷ 30 days).
Crep	=	maximum permitted annual megawatt-hour (MWh) generation of the new replacement units (maximum rated capacity (MW) X maximum permitted annual operating hours)
C2yravgexisting	=	maximum annual megawatt-hour (MWh) generation of the existing units to be replaced using the last 24 month period immediately prior to issuance of the permit to construct.

The facility will be required to demonstrate compliance with the specific requirements of this rule prior to the issuance of the Permits to Construct for the HBEP Project. The following calculation provides an estimate of the approximate fee that will be required.

The following factors are used in the equation:

Factor	PM10	VOC
PTerep	731 lbs/day	639 lbs/day
Ri1A	\$997/lb/day	\$47/lb/day
Ri2A	\$3,986/lb/day	\$185/lb/day
OFi	1.0	1.2
MW	895.5 MW	895.5 MW
Crep	4,555,020 MWh	4,555,020 MWh
C2yr	374,439 MW	413,201 MW

Notes:

PTerep is calculated as follows: PM10 – 210.8 lbs/day*2 (CCTG) + 154.8 lbs/day*2 (SCTG) = 731 lbs/day, VOC – 253.7 lbs/day*2 (CCTG) + 65.7 lbs/day*2 (SCTG) = 639 lbs/day



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
48

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Crep is calculated as follows: $693.8 \text{ MW} \times 6,100 \text{ hrs} + 201.6 \text{ MW} \times 1750 \text{ hrs} = 4,584,980 \text{ MWh}$ (no starts or shutdowns included)

C2yr is taken from Appendix Q

PM10

$$F_{PM10} = [(997 \times 100 / 895.5) + 3986 \times (895.5 - 100) / 895.5] \times 1.0 \times 731 \times [(4584980 - 374439) / 4584980]$$

$$F_{PM10} = [(111.33) + (3540.89)] \times (1.0) \times (731) \times (0.9183)$$

$$F_{PM10} = \$2,451,652.38/\text{yr} \text{ (to be adjust by CPI from 2013 dollars)}$$

VOC

$$F_{VOC} = [(47 \times 100 / 895.5) + 185 \times (895.5 - 100) / 895.5] \times 1.2 \times 639 \times [(4584980 - 374439) / 4584980]$$

$$F_{VOC} = [(5.25) + (164.34)] \times (1.2) \times (639) \times (0.9183)$$

$$F_{VOC} = \$119,417.21/\text{yr} \text{ (to be adjust by CPI from 2013 dollars)}$$

Total fee = $2,451,652.38 + 119,417.21 = \$2,571,069.59/\text{yr}$ (to be adjust by CPI from 2013 dollars)

The rule allows the facility the option to pay a lump sum fee after the first year.

RULE 1325/40CFR 51 Appendix S – Federal PM2.5 New Source Review

Rule 1325 is the New Source Review rule for PM2.5 and its precursors, NOx and SO2. This rule applies to new major polluting facilities, major modifications to existing major polluting facilities, or any modification to an existing facility that would constitute a major polluting facility in and of itself. A major polluting facility is defined as a facility located in a federal non-attainment area which has actual emissions, or a potential to emit of greater than 100 tons per year, of either PM2.5 or its precursors. Note that EPA recently re-classified the South Coast basin as serious non-attainment for PM2.5. This effectively reduces the major source threshold from 100 tons per year to 70 tons per year. However, the reclassification does not take effect until August 14, 2017, or earlier if SCAQMD adopts the revised threshold by amending this rule prior to that date.

A major modification is defined as any physical change or change in the method of operation at a major source which results in a significant emission increase and a significant net emissions increase. If subject to this subpart, the facility is required to comply with the following requirements on a pollutant specific basis:

- Use of LAER
- Offset emissions at the applicable offset ratio
- Certification of compliance with emission limits for all major sources under common control
- Conduct an alternative analysis of the project



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
49

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Since Rule 1325 is not SIP approved at this time, the requirements of NSR for PM_{2.5} and its precursors must be implemented through Appendix S. Appendix S sets forth EPA's Interpretive Ruling on the preconstruction review requirements for stationary sources.

As shown in Appendix O, the existing facility is not a major source for PM_{2.5} and SO₂, but is a major source for NO_x. Furthermore, as shown in Appendix O, there will be a significant increase and significant net increase in NO_x resulting from the proposed modification (the significant increase threshold is 40 tpy for NO_x based on new PTE vs. existing actual). Therefore, the HBEP is considered a major modification to an existing major source for NO₂ and is subject to NSR under this rule for NO_x only. The project is also considered a major modification for NO_x under SCAQMD Rule 2005 and Regulation XVII (PSD), and as such, all of the requirements listed above have been addressed under those rules.

RULE 1401 – New Source Review of Toxic Air Contaminants

This rule requires an analysis of the new permit units' impacts due to the release of air toxics. A Tier 4 Health Risk Assessment was performed using CARB's Hotspots Analysis and Reporting Program (HARP, version 2). Model inputs and results are presented in Appendix H. The results of the model are summarized below:

Table 4.14 Model Results – HRA CCTG (individual unit)

Receptor	Cancer Risk Per Million	Chronic Hazard Index	Acute Hazard Index
Maximum Impact	2.38	0.0060	0.032
MEIR	1.36	0.0035	0.0090
MEIW	0.086	0.0060	0.091
Sensitive receptor	0.74	0.00346	0.032

Table 4.15 Model Results – HRA SCTG (individual unit)

Receptor	Cancer Risk Per Million	Chronic Hazard Index	Acute Hazard Index
Maximum Impact	0.086	0.00022	0.0017
MEIR	0.059	0.00015	0.0012
MEIW	0.003	0.00022	0.0017
Sensitive receptor	0.1	0.00012	0.00070



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
50

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table 4.16 Model Results – HRA Auxiliary Boiler

Receptor	Cancer Risk Per Million	Chronic Hazard Index	Acute Hazard Index
Maximum Impact	0.18	0.0005	0.0011
MEIR	0.026	0.00008	0.0003
MEIW	0.004	0.0005	0.001
Sensitive receptor	0.03	0.00008	0.0003

The cancer burden is 0.42 based on a radius of 2.03 km and a population density of 7,000 persons/km.

The results show that the cancer risk for each turbine is less than the rule limit of 10 in one million (for permit units with T-BACT, considered an oxidation catalyst for the turbines), and less than 1 in one million for the auxiliary boiler. Furthermore, the hazard indices are less than 1 for all the turbines and boiler, and the cancer burden is below the threshold of 0.5.


The modeling was reviewed by SCAQMD modeling staff and deemed acceptable. Refer to the memo from Ian MacMillan to Andrew Lee dated May 18, 2016.

REGULATION XVII – Prevention of Significant Deterioration

The South Coast Basin where the project is to be located is in attainment for NO₂, SO₂, CO, and PM₁₀ emissions. Additionally, beginning on January 2, 2011, Greenhouse Gases (GHGs) are a regulated criteria pollutant under the PSD major source permitting program. Therefore each of these pollutants must be evaluated under PSD for this project.

PSD applies on a pollutant-specific basis to a new major source, a significant increase in emissions from an existing major stationary source, or a modification at a non-major source, if the modification is considered major in and of itself. For any of the 28 listed source categories, the major source threshold is 100 tons per year based on actual emissions or potential to emit. The major source threshold is 250 tons/yr for source categories that are not listed. As a natural gas fired combined/simple cycle power plant, the HBEP falls within the 28 source category definitions, and therefore the applicable threshold is 100 tpy.

If the facility is deemed to be major, Rule 1702 further defines a major modification as a significant emission increase of 40 tpy or more of NO₂ or SO₂, 15 tpy of PM₁₀, or 100 tons per year or more of CO (determined on a new PTE vs. existing actual basis). The existing equipment at the Huntington Beach Generating Station is a major source for NO_x, CO, and GHGs, but not PM₁₀ or SO_x. Furthermore, with the addition of the new equipment, there is a significant increase of NO₂ and GHG but not CO, and therefore, a PSD review is required for NO_x and GHGs. Finally, the addition of the new gas turbines does not constitute a major source in and of itself for PM₁₀ or SO_x.

	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 51	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

Requirements for a significant emission increase under Rule 1703 include the following:

- Use of BACT [1703(a)(3)(B)]
- Modeling to determine impacts of the project of National and State AAQS and increases over the baseline concentration [1703(a)(3)(C)]
- Analysis of ambient air quality in the impact area [1703(a)(3)(D)]
- Analysis of project impacts on visibility, soil, and vegetation [1703(a)(3)(E)]

BACT is also required for any pollutant for which there is a net emission increase, therefore BACT applies for all pollutants. The BACT determination for NO₂, CO, SO₂, and PM₁₀ is based on a top-down analysis. This analysis has been performed for power plants of this type multiple times in the recent past, and the facility performed this top-down approach. The technologies considered for each pollutant are summarized in the following table (Appendix T summarizes the emission limits considered in the BACT analysis):

Table 4.14 Control Technologies Evaluated for BACT - Turbines

NO _x	CO	VOC	PM ₁₀	SO _x
Water Injection	Combustion Design	Combustion Design	Combustion Design and Clean Fuel	Combustion Design and Clean Fuel
DLN Combustion	Oxidation Catalyst	Oxidation Catalyst	Electrostatic Precipitators	Wet or Dry Scrubber
XONON™			Baghouse	
SCR				
EMx				
SNCR				



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
52

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table 4.15 Control Technologies Evaluated for BACT - Boiler

NOx	CO	VOC	PM10	SOx
Low NOx Burner/FGR	Combustion Design	Combustion Design	Combustion Design and Clean Fuel	Combustion Design and Clean Fuel

SCR

In its analysis, the facility eliminated electrostatic precipitators and baghouses as technologically infeasible options for PM10 control of the turbines, and also eliminated the wet or dry scrubber option as infeasible for SOx control of the turbines.

The results of the analysis are summarized as follows:

- NO₂ –

Combined Cycle Turbines

- ✓ The combined cycle turbines must meet a limit of 2.0 ppmvd, 1-hour average at 15% O₂. The facility has chosen to use DLN combustors and a conventional SCR system for the control of NOx emissions to this level.

Simple Cycle Turbines

- ✓ The simple cycle turbines must meet a limit of 2.5 ppmvd, 1-hour average at 15% O₂. The facility has chosen to use DLN combustors and a conventional SCR system for the control of NOx emissions to this level.

Auxiliary Boiler

- ✓ The auxiliary boiler must meet a limit of 5.0 ppmvd 1 hour average at 3% O₂. The facility has chosen to use a LowNOx burner/FGR and conventional SCR system for the control of NOx emissions to this level.

- SO₂ – The requirement is to use pipeline quality natural gas. The facility is proposing the use of this fuel type exclusively for all combustion equipment.

- CO –

Combined Cycle Turbines

- ✓ The combined cycle turbines must meet a limit of 2.0 ppmvd based on 1-hour average at 15% O₂. The facility has chosen to use a conventional oxidation catalyst system for the control of CO emissions to this level.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
53

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Simple Cycle Turbines

- ✓ The simple cycle turbines must meet a limit of 4.0 ppmvd based on 1-hour average at 15% O₂. The facility has chosen to use a conventional oxidation catalyst system for the control of CO emissions to this level.

Auxiliary Boiler

- ✓ The auxiliary boiler must meet a limit of 50 ppmvd based on 1-hour average at 3% O₂. The facility has chosen to use combustion design for the control of CO emissions to this level.
- PM₁₀ – The requirement is to use pipeline quality natural gas with a sulfur content (calculated as H₂S) less than 1 grain per 100 scf. The facility is proposing the use of this fuel type exclusively for all combustion equipment.

The PSD modeling analysis requires the following steps:

1. Determine whether preconstruction monitoring is required
2. Assessment of significance under PSD
3. Determine Ambient Air Quality Impacts
4. Determine Impacts in Class I Areas, including visibility, soil, and vegetation

The applicant performed modeling which indicated that the maximum 1-hour and 8-hour CO impacts from turbine operations including start ups and shutdowns are 631 ug/m³ and 149 ug/m³ respectively. These results are below the corresponding US EPA CO Class II SILs of 2,000 ug/m³ and 500 ug/m³. Therefore, 1-hour and 8-hour CO increment analyses are not required.

The peak annual NO₂ impact from the total project is 0.59 ug/m³. This impact is less than the US EPA NO₂ Class II significance impact of level of 1 ug/m³, therefore, no additional PSD analysis is necessary.

Effective July 26, 2013, the South Coast Air Basin has been re-designated to attainment for the 24 hour PM₁₀ NAAQS. The total project's peak 24-hour impact is 4.7 ug/m³, which is less than the Class II SIL of 5 ug/m³, therefore no additional PSD analysis is necessary.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
54

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table 4.16 Comparison of Modeled Results to PSD Significance Thresholds

Pollutant	Averaging Period	Maximum Predicted Impact (ug/m3)	Significant Impact Level (ug/m3)	PSD Class II Increment Standard (ug/m3)	Significant Monitoring Concentration (ug/m3)
NO2	1-hour	95	7.52	////////	////////
	Annual	0.59	1.0	25	14
CO	1-hour	631	2,000	////////	////////
	8-hour	149	500	////////	575
PM10	24-hour*	4.7	5.0	30	10
	Annual	0.6	1.0	17	////////

Note that the 24 hour PM10 results for the PSD model are different from the NSR model results. For the PSD model AES assumed 1 CCTG operating at minimum load for 20 hours and average load for 4 hours, with the other CCTG operating at minimum load for 24 hours. For the NSR model both CCTGs were assumed to operate at minimum load for 24 hours.


For 1-hour NO2 impacts, because the peak impact level from the proposed project of 95 ug/m3 exceeds the significance impact level of 7.52 ug/m3, a NO2 cumulative impact assessment is necessary.

For the NO2 cumulative impact assessment, three facilities, Orange County Sanitation District's Huntington Beach and Fountain Valley facilities and Beta Offshore as well as emissions from shipping lane activities off the coast were selected to be included based on their facility emissions and distance to the project. Seasonal, by hour-of-day background concentrations from the Costa Mesa monitoring station were used in the modeling. Following the form of the standard, the 1-hour NO2 impact from the project plus cumulative sources plus background is 148 ug/m3, which is less than the Federal 1-hour standard of 188 ug/m3. Therefore, no additional PSD analysis is necessary.

Table 4.17 NO2 Cumulative Analysis Results

Source/Year	2010	2011	2012	2013	2014
HBEP	75.4	71.0	73.2	74.1	76.0
HBGS	5.15	5.08	5.32	5.12	4.73
OCSFV	8.92	8.92	8.87	8.91	9.02
OCSHB	56.2	54.0	54.1	54.1	53.7
BETA	58.2	63.2	62.6	66.8	66.1
SHIPS	24.3	23.4	23.9	22.6	23.3
TOTAL PLUS BACKGROUND	140	147	148	143	144

The modeled concentration is the 8th high result. Model result is added to the 98th percentile background concentration for 2010 through 2012 to obtain total concentration.

	South Coast Air Quality Management District		PAGE 55	PAGES 212
	Engineering Division Application Processing & Calculations		APPL NO. See Below	DATE 6/7/16
			PROCESSED BY CP01	CHECKED BY


Visibility Analysis

The nearest Class I areas to the project site are the San Gabriel Wilderness and Cucamonga Wilderness areas located approximately 69 km away. A radial receptor ring was placed at a distance of 50 km from the project (50 km is the maximum receptor distance of the AERMOD model). The maximum project impact for annual NO₂ at 50 km is 0.0055 ug/m³, which is less than the significance level of 0.1 ug/m³, the maximum impact for 24 hour PM₁₀ is 0.042 ug/m³, which is less than the significance level of 0.2 ug/m³, and the maximum annual impact for annual PM₁₀ is 0.32 ug/m³, which is less than the significance level of 0.32 ug/m³.

A screening criteria is acceptable to use for projects located more than 50 km away from a Class I area, in order to estimate the potential impacts on visibility and deposition at these areas. The emissions/distance (Q/D) is calculated using the project's total annual emissions of SO₂, NO_x, PM₁₀, and H₂SO₄ (based on 24 hour maximum allowable emissions) divided by the distance between the project and the nearest Class I area. Q is estimated to be 420 tpy. D would be the distance in km to the nearest Class I area (in this case Cucamonga and San Gabriel Wilderness at 69 km). Approximate Q/D is 6.1, which is less than the threshold of 10. Thus, modeling of visibility and deposition impacts to Class I areas is not necessary.

The project's impacts on visibility in Class II areas were also analyzed. Currently, there are no thresholds for visibility impacts on Class II areas. The project utilized the criteria and thresholds for visibility impacts on Class I areas. Visibility impacts are based on the calculation of two factors – plume contrast and color contrast (ΔE) of the plume when compared to the sky and terrain backgrounds. For Class I areas, the criteria used is based on a perceptibility threshold of 0.05 (absolute value) for contrast and 2.0 for ΔE . The project applicant identified five Class II areas in the project vicinity, Crystal Cove State Park, Water Canyon State Park, Chino Hills State Park, San Mateo Canyon Wilderness Area, and Huntington Beach State Park. The project impacts were determined to be below the thresholds for all areas except for Crystal Cove and Huntington Beach State Parks. The ΔE for Crystal Cove and Huntington Beach State Parks exceeded the thresholds using the Level I VISCREEN analysis. Therefore a Level 2 VISCREEN analysis was performed for these 2 areas. Using the 5 year meteorological data from the John Wayne Airport, the joint frequency distribution tables were created and were used to determine the worst case single wind speed and stability class required for a VISCREEN analysis. Using the Level 2 VISCREEN analysis, the project's impacts for both contrast and ΔE are less than the thresholds for Crystal Cove State Park but exceed the thresholds for Huntington Beach State Park.

It should be noted here that neither VISCREEN (the model used in the analysis) nor the Class I visibility thresholds were established for Class II areas in southern California, which contain numerous urban areas and lots of commercial and industrial activity. EPA requires, for informational purposes only, a visibility analysis of Class II areas using the Class I visibility thresholds and the VISCREEN model. However, this does not necessarily mean that permitting actions or project mitigation are required for any significant Class II visibility impacts that are found.

 South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 56	PAGES 212
	APPL NO. See Below	DATE 6/7/16
	PROCESSED BY CP01	CHECKED BY

Soil and Vegetation Analysis

AES compared the HBEP's impacts and background concentrations to the secondary national ambient air quality standards with the reasoning that the standards were established to include protection against visibility impairment, and damage to animals, crops, vegetation, and buildings. Since the project emissions do not exceed the secondary NAAQS, AES concluded that there will be no significant impacts to soil and vegetation (see letter from AES dated November 11, 2015).

Table 4.18 Impacts Compared to Secondary NAAQS

Pollutant	Averaging Period	Maximum Predicted Impact (ug/m3)	Background Concentration (ug/m3)	Total Impact (ug3/m3)	Secondary NAAQS (ug/m3)
NO2	Annual	0.59	21.8	22.4	100
SO2	3-hour	5.01	23.1	28.2	1,300
PM10	24-hour	4.7	51.0	55.7	150
PM2.5	24-hour Federal	4.7	21.3	26	35
	Annual	0.6	8.6	9.24	12

The modeling was reviewed by SCAQMD modeling staff and deemed acceptable. Refer to the memo from Ian MacMillan to Andrew Lee dated May 18, 2016.

The application documents and modeling files were forwarded to the Federal Land Managers (US Forest Service and National Park Service) on January 6, 2016 to provide these agencies the opportunity to review and comment on the potential impacts of the proposed project on Class I areas. SCAQMD will not issue a final permit to AES until the land managers have issued their determinations.

Rule 1714 – PSD for Greenhouse Gases

As of January 2, 2011 Greenhouse gases (GHGs) are a regulated New Source Review pollutant under the PSD permitting program when they are emitted by new sources or modifications to existing sources at amounts equal to or greater than the applicability thresholds of the GHG tailoring rule. The HBEP project will emit over 1 million tons of CO₂e, and the contemporaneous increase, after considering the shutdown of Boilers 1 and 2, will exceed 75,000 tons per year. The project is therefore subject to BACT for GHGs (reference Appendix I)

For PSD purposes, GHGs are defined as a single air pollutant consisting of the sum of the following six gases:



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
57

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Carbon Dioxide (CO₂)
Nitrous Oxide (N₂O)
Methane (CH₄)
Hydrofluorocarbons
Perfluorocarbons
Sulfur hexafluoride (SF₆)

These gases can be summed together as CO₂ equivalent, or CO₂e, using each gases' global warming potential (GWP). The CO₂e limit as set forth in California law SB1368 under CCR Title 20 Chapter 11 Article 1 is 1,100 lb/_{net}MWh. The limit is based on the total annual CO₂e emissions from all operations, divided by the total annual net MW generation. The limit is not, however, subject to a pre-construction review process in the permit evaluation because as the statute is written, it is the responsibility of the purchaser of the power to make the determination that the power producer they are purchasing from meets this limit prior to buying the power.

Approximate GHG emissions from the HBEP are calculated in Appendix I and summarized in Tables 3.23, 3.24, 3.25, and 3.26

GHG BACT Analysis

EPA has recommended the 5-step "top-down" process to determine BACT for GHGs.


1. Identify all available control options
2. Eliminate technically infeasible options
3. Ranking of controls
4. Economic, energy, and environmental impacts
5. Selecting BACT

Step 1 Identify All Available Control Options

The available CO₂ control technologies are:

- A. Carbon Capture and Sequestration (CCS)
- B. Thermal Efficiency

The option for lower emitting alternative technologies was not considered in the BACT analysis based on the reasoning that an alternative technology such as wind power, solar power, or battery storage would alter the fundamental business purpose of the plant. This is consistent with EPA's March 2011 PSD and Title V Permitting Guidance for Greenhouse Gases, which recognizes that the

	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 58	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

list of options chosen for Step 1 should not necessarily “redefine the nature of the source as proposed by the permit applicant...”

The technologies are described and discussed in the next sections.

A. Carbon Capture and Sequestration (CCS)

CCS is a process that captures, transports, and sequesters CO₂ emissions.

Capturing of CO₂ Emissions

Combustion flue gas or fuel gas streams may be processed for the purpose of separation and capture of carbon dioxide. The physical capture of CO₂ from gas streams can be accomplished using either physical or chemical solvents or solid sorbents, with subsequent desorption to produce a concentrated CO₂ stream. Typically, physical solvents are more suited to pre-combustion capture of CO₂ in a fuel stream which has relatively high levels of CO₂ at high pressure, while chemical solvents work better at capturing CO₂ from dilute low pressure post-combustion flue gas.

Transportation of CO₂ Emissions

Captured CO₂ would then need to be compressed to supercritical temperature and pressure for transport. Because of the extremely high pressures and the special fluid properties of the supercritical CO₂, specialized designs are required for CO₂ pipelines, and for the compressors needed to bring the CO₂ to the required pressure for transport.

Sequestration of CO₂ Emissions

There are several sequestration approaches.

Geologic Sequestration

Geological sequestration is the process of injecting captured CO₂ into deep subsurface rock formations for long term storage. The storage locations can be deep saline aquifers or depleted coal seams, or the use of compressed CO₂ to enhance oil recovery in crude oil production operations. The process involves transporting the compressed CO₂ to a sequestration location, injecting it underground at high pressure. There it remains a supercritical fluid underground. Ideally, over time the CO₂ can dissolve into surrounding water and rocks, creating solid carbonate minerals.

Several geologic formations identified in California might provide a suitable site for geologic sequestration, including a few sites near the HBEP Project. These sites were identified in the Department of Energy (DOE) National Energy Technology Laboratory’s (NETL) *2010 Carbon Sequestration Atlas of the United States and Canada*, and include some oil and gas reservoirs in the Los Angeles Basin, one being an old petroleum production area in Huntington Beach.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
59

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Ocean Storage

In lieu of injecting CO₂ underground as in geologic sequestration, ocean storage is accomplished by injecting CO₂ into the ocean water typically at depth of greater than 1,000 meters. CO₂ is expected to dissolve or form into a horizontal lens which would delay the dissolution of CO₂ into the surrounding environment. The NETL's study stated that California "may be a candidate for CO₂ storage in offshore basins."

Mineral Carbonation

Mineral carbonation is the reaction of CO₂ with metal oxides to form metal carbonates. Metal oxides are abundant in silicate minerals and in waste streams. The natural reaction of CO₂ with metal oxides is a very slow process. The reaction time can be increased by enhancing the purity of these metal oxides. Large scale production of metal oxides to meet the demand of electrical generation is very energy and cost intensive.

B. Thermal Efficiency


Power generation through fossil fuel combustion is a chemical reaction process. The thermal efficiency is defined as the ratio of the net power produced and the heating values of the fuel. The heat rate, measured in Btu/kWh, is generally used as a thermal efficiency indicator. The thermal efficiency is at the highest when the reaction is at stoichiometric, and at the time when CO₂ emissions are the highest.

The following factors affect the thermal efficiency of a power plant:

- Thermal dynamic cycle selection, combined cycle versus simple cycle
- Combustion turbine performance, compression ration and turbine design temperature
- Combustion turbine startup time, load transition time
- Steam turbine startup time, load following time
- Fuel selection

Step 2 Eliminate Technically Infeasible Options

The second step for the BACT analysis is to eliminate technically infeasible options from the control technologies identified in Step 1. For each option that was identified, a technology evaluation was conducted to determine the technical feasibility. The technology is feasible only when the technology is available and applicable. A technology that is not commercially available for the scale

	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 60	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

of the project is also considered infeasible. An available technology is applicable if it can reasonably be installed and operated on the proposed project.

A. Carbon Capture and Sequestration (CCS)

The technical feasibility of each step of the CCS is discussed below.

Carbon Capture Technology


The *Report of the Interagency Task Force on Carbon Capture and Storage* (DOE and EPA, 2010) discusses four operating post-combustion CO₂ capture systems associated with power production. All four are used on coal-based power plants where CO₂ concentrations are typically 12 to 15 percent. None were being used on natural gas fired power plants, where CO₂ concentrations are in the 3-5 percent range. The report further notes the lack of demonstration in practice:

Current technologies could be used to capture CO₂ from new and existing fossil energy power plants, however they are not ready for widespread implementation primarily because they have not been demonstrated at the scale necessary to establish confidence for power plant application. Since CO₂ capture capacities used in current industrial processes are generally much smaller than the capacity required for purpose of GHG emissions mitigation at a typical power plant, there is considerable uncertainty associated with capacities or volumes necessary for commercial deployment.

Many current carbon capture systems are based on a chemical absorption process using amine or chilled ammonia. Upon initiation of the process, the systems require a start up time to begin the countercurrent liquid-gas absorption towers and either chilling of the ammonia solution or heating of regeneration columns for the amine systems. The HBEP turbines often times will be required to start, stop, and ramp load quickly to meet grid demands. It is technically infeasible for the carbon capture systems to start up and shut down or to make large adjustments in gas volume in the time frames required to serve this type of operation. The CCS system could operate at minimum load during periods of expected operation. However, this approach would consume energy, offsetting some of the benefit.

CO₂ Transportation

The basic technologies required for CO₂ transportation (i.e., pipeline, tanker truck, ship) are in commercial use today for a number of applications and can be considered commercially available for liquid CO₂. However, the *Task Force* report shows that there are no existing CO₂ pipelines in California. Any new pipeline constructed for HBEP would need to not only overcome technical issues such as high pressures design (> 2,000 psig) and corrosion resistance, but also the issues of obtaining the necessary permits and right-of-way agreements.

	South Coast Air Quality Management District		PAGE 61	PAGES 212
	Engineering Division Application Processing & Calculations		APPL NO. See Below	DATE 6/7/16
			PROCESSED BY CP01	CHECKED BY

CO₂ Sequestration

Oil and gas production in the vicinity of the HBEP is available for EOR, however only pilot scale projects are known in the region and only estimates are available on the capacity of these fields. Therefore CCS using geological sequestration cannot be demonstrated to be technically feasible in practice for the new power generating system.

Ocean storage is conducted by injecting supercritical liquid CO₂ from either a stationary or towed pipeline at depths typically below 3,000 feet. CO₂ is injected below the thermocline, creating either a rising droplet or a dense phase plume and sinking bottom gravity current. Ocean storage and its ecological impacts are still in the research phase. It is not commercially available.


Mineral carbonation is technically feasible, as reaction chemistry is well understood. However, the sequestration of CO₂ through mineral carbonation has not been demonstrated on a commercial scale.

Summary of CCS Feasibility

In summary, the post-combustion carbon capture technologies are still in the developmental stage or pilot scale projects. These technologies would not be considered commercially available for the project size of a full-scale commercial power plant. In addition, there are no comprehensive standards in place defining requirements for long term sequestration. Therefore, CCS is not yet demonstrated in practice for a commercial-scale, natural gas fired power plant such as the HBEP. In consideration of the uncertainty in the technical feasibility of CCS and its emergence as a promising technology, CCS is carried forward in this BACT analysis as a potential GHG control technology. However, substantial evidence demonstrates that CCS is not yet demonstrated as technically feasible for the HBEP project.

B. Thermal Efficiency

The California Senate Bill (SB) 1368 requires the California Public Utilities Commission (CPUC) to establish a GHG emission performance standard for all baseload utilities by February 1, 2007. The California Energy Commission (CEC) was required to establish a similar standard for local publicly owned utilities by June 30, 2007. The CEC has established a GHG performance standard of 1,100 pounds of CO₂ per net MWh for baseload publicly owned electrical utilities. The California Legislature in Assembly Bill (AB) 1613 (2007), as amended by AB 2791 (2008), established a CO₂ Emission Performance Standard (EPS) for combined heat and power facilities of 1,100 lbs CO₂/MWh. In 2010, the CEC promulgated its regulation to implement AB 1613 in its Guidelines for Certification of Combined Heat and Power Systems Pursuant to the Waste Heat and Carbon Emissions Reduction Act (CEC 2010b).

	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 62	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

It is anticipated that the HBEP plant will meet the California GHG emission performance standard of 1,100 pounds of CO₂ per net megawatt hour.

The thermal efficiency for the new power generating system achieved by the state-of-the-art technologies is a technically feasible alternative for reducing GHG emissions from a fossil-fuel fired low efficiency power plant. In conclusion the combustion process inherent in the new power generating system is achieved in practice and is eligible for consideration under Step 3 of the BACT analysis.

Step 3 - Rank Remaining Control Technologies

Because CCS is not technologically feasible, the only remaining technologically feasible option is thermal efficiency.

Step 4 – Evaluating the Most Effective Controls

Step 4 of the BACT analysis is to evaluate the most effective control. This step involves the consideration of energy, environmental, and economic impacts associated with each control technology. The top-down approach requires that the evaluation begin with the most effective technology. Although carbon control has been deemed infeasible for the HBEP, in response to a suggestion from EPA team members on other recent projects, the economic feasibility of CCS was still evaluated by AES in this step.

A. Carbon Capture and Sequestration (CCS)

The costs of constructing and operating CCS technology would include the following:

- Licensing of scrubber technology and construction of carbon systems
- Reduction in plant output due to the high energy consumption of CCS
- Identification of oil and gas companies with depleted oil reserves having appropriate characteristics for oil recovery.
- Construction of compression systems and pipelines to deliver CO₂
- Hiring of labor to operate, maintain, and monitor the capture, compression, and storage systems.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
63

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

AES relied on the data from the *Task Force* report to estimate the capital cost of a CCS system for the HBEP. From this data, the cost estimate is about \$467 million, which, based on an estimate of \$770-\$880 million for the HBEP plant itself, represents about a 50% increase in the overall cost of the plant.

Furthermore, a pipeline from HBEP to an oil field in either Santa Fe Springs or Dominguez Hills would be about 30 miles long. Costs for an 8 inch CO₂ pipeline are estimated to be \$600,000 per mile based on engineering analysis of the Denbury CO₂ pipeline in Wyoming. Therefore, the pipeline for HBEP would be about \$18 million, representing another 3 percent increase to the capital costs of the HBEP project.


B. Thermal Efficiency

AES compared the efficiency on the HBEP project to several other recently permitted similar projects in California, and found that the HBEP compares favorably. The following table summarizes their findings:

Project	Heat Rate (btu/kWh)	GHG Performance (MTCO ₂ /MWh)
HBEP ¹	6,322 (combined cycle) 9,074 (simple cycle)	0.383
Watson Cogen ²	5,027-6,327	0.219 – 0.318
Palmdale Hybrid Power ³	6,970	0.370
Russell City Energy ⁴	6,852	0.371
El Segundo Redevelopment ⁵	6,754 (combined cycle) 8,458 (simple cycle)	0.409
Carlsbad Energy Center ⁶	9,473	0.503

Notes:

- 1. The net heat rate of the HBEP is at 65.8° F at site elevation and relative humidity of 58.32%, no inlet air cooling. Heat rates averaged over the operating range of 50-100% load. GHG performance based on plant-wide CO₂ emissions of 1,781,868 metric tons per year*
- 2. From Watson Cogeneration Project Commission Final Decision*

	South Coast Air Quality Management District		PAGE 64	PAGES 212
	Engineering Division Application Processing & Calculations		APPL NO. See Below	DATE 6/7/16
			PROCESSED BY CP01	CHECKED BY

3. From Table 3 and 4 of the Palmdale Hybrid Power Project Greenhouse Gas BACT Analysis (AECOM 011)
4. From GHG BACT Analysis Case Study, Russell City Energy Center, November 2009, updated February 3, 2010
5. From El Segundo Power Redevelopment Project Revised Final Determination of Compliance
6. From Carlsbad Energy Center Project Amendments Final Decision

Step 5 – Select BACT

Based on the above analysis, thermal efficiency is the only technically and economically feasible alternative for CO₂/GHG emissions control for the HBEP Project. AES has chosen to use both combined cycle as well as simple cycle turbine technology at the Huntington Beach plant. Although simple cycle turbines are not as efficient as combined cycle units, and therefore they emit more GHG pollutants per MW output, AES has chosen this configuration to meet the anticipated needs of the energy market they serve. The simple cycle units are capable of rapid start up and response to serve the peak load demand. The combined cycle units, although able to start relatively quickly, are not designed for this type of operation. The combined cycle units, in order to achieve superior thermal efficiency, must wait for the steam turbine to reach proper operating temperature. If the combined cycle units were to bypass the steam turbine for the purposes of a quick start, they essentially become a simple cycle unit and therefore lose any advantage they have in thermal efficiency.

Therefore, requiring AES to use only combined cycle units under the GHG BACT analysis would alter the applicant's purpose and objective of the proposed facility.

The conclusion of the GHG top down analysis is that the current design of the facility meets the BACT requirement for GHG emission reductions.

Under this analysis, a BACT limit shall be developed for both the combined cycle and simple cycle units. The BACT limit is applicable to the entire operating profile. Therefore, BACT is determined based on the facility's proposed annual operating scenarios that take into consideration load factor, equipment degradation, and operating hours. The calculated GHG emissions rate for the CCTGs is 967.6 lbs CO₂/net MWh, and the calculated GHG emissions rate for the SCTGs is 1359.0 lbs CO₂/net MWh.

Each combined cycle turbine will be subject to an emission limit of 870,251 tons CO₂ per year, and each simple cycle turbine will be subject to an emission limit of 103,578 tons CO₂ per year. Compliance will be based on a 12-month rolling average as determined by using emission factors and fuel usage.

Detailed calculations are shown in Appendix I.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
65

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

- **Circuit Breakers**

EPA in the Pio Pico Energy Center PSD permit requires the circuit breakers be equipped with a leak detection system, and be calibrated according to manufacturer specifications. EPA considers this to be BACT for circuit breakers. EPA further argues that the requirement is not redundant to the CARB regulation to reduce GHG (SF₆) emissions from gas insulated switchgears, California Code of Registers, Subchapter 10, Article 4, §95350-§95359.

A facility condition F52.2 will be added to enforce the BACT requirement for the circuit breakers, using the same language as the EPA permit.

Other PSD Requirements

In addition to the BACT requirement the PSD requirements generally include air quality modeling, ambient monitoring, and additional impact analysis. The modeling analysis shall demonstrate that there will be no violations of any NAAQS or PSD increments. However, because there are currently no NAAQS or PSD increments established for GHGs, the modeling analysis requirement would not apply for GHGs even if PSD is triggered for GHGs. EPA does not require monitoring for GHGs in accordance with Section 52.21(i)(5)(iii) and Section 51.166(i)(5)(iii), and EPA does not require impact analysis from GHGs in the nearby Class I areas. In addition, no offsets are required for CO because this pollutant is in attainment in the South Coast Air Basin.

Rule 2011 – SO_x RECLAIM, Monitoring Recording and Recordkeeping Requirements


The turbines and auxiliary boiler will be classified as process units under SO_x RECLAIM. As such they are required to measure and record fuel use and calculate mass SO_x emissions using the emission factor on the permit, and electronically report emissions on a quarterly basis

Rule 2012 – NO_x RECLAIM, Monitoring Recording and Recordkeeping Requirements

The turbines and auxiliary boiler will be classified as major NO_x sources under NO_x RECLAIM. As such, they are required to measure and record NO_x concentrations and calculate mass NO_x emissions with a Continuous Emissions Monitoring System (CEMS). The CEMS will include in-stack NO_x and O₂ analyzers, a fuel meter, and a data recording and handling system. NO_x emissions are reported to AQMD on a daily basis. The CEMS system will be required to be installed within 90 days of start up. Compliance is expected.

REGULATION XXX – Title V

The Huntington Beach facility is subject to Title V, and is operating under a valid Title V permit issued on April 29, 2016. The addition of the combined cycle/simple cycle plant and auxiliary equipment will be considered a significant revision to the existing Title V permit. AES has submitted a Title V revision application A/N 578087. As a significant revision, the permit is subject to a 30 day

	South Coast Air Quality Management District		PAGE 66	PAGES 212
	Engineering Division Application Processing & Calculations		APPL NO. See Below	DATE 6/7/16
			PROCESSED BY CP01	CHECKED BY

public notice and a 45 day EPA review and comment period. The public notice requirements are discussed in more detail under the “Public Notice Requirements” section of this report.

State Regulations

California Environmental Quality Act (CEQA)

The project is subject to the licensing procedure under the California Energy Commission (CEC). This procedure analyzes all aspects of the proposed project, and is subject to a public review and comment period. It is therefore considered equivalent to an Environmental Impact Report, and satisfies the requirements of CEQA. CEC’s process will fully evaluate all air quality impacts for the entire project.

Federal Regulations

NSPS for Small Boilers - 40CFR Part 60 Subpart Dc

This performance standard applies to steam generators rated between 10 and 100 mmbtu/hr constructed after June 9, 1989. However, the emission limits are only applicable to coal or oil fired units. Since the auxiliary boiler will be fired on natural gas exclusively, only records of the amount of fuel combusted on a monthly basis is required [§60.48c(g)(2)].

NSPS for Stationary Gas Turbines - 40CFR Part 60 Subpart GG

This regulation has been superseded by 40CFR 60 Subpart KKKK.

NSPS for Stationary Gas Turbines - 40CFR Part 60 Subpart KKKK

The turbines are subject to Subpart KKKK because their heat input is greater than 10.7 gigajoules per hour (10 MMBtu per hour) at peak load, based on the higher heating value of the fuel fired. Actual unit rating is

Combined Cycle Turbines

2273E+06 btu/hr (HHV) X 1055 joules/btu = 2398.0 gigajoules/hr.

Simple Cycle Turbines

885E+06 btu/hr (HHV) X 1055 joules/btu = 933.7 gigajoules/hr.

The standards applicable for a natural gas turbine greater than 850 mmbtu/hr are as follows:

NO_x: 15 ppm at 15% O₂ (0.43 lbs/MWh)

SO_x: 0.90 lbs/MWh discharge, or 0.060 lbs/mmbtu potential SO₂ in the fuel

Monitoring



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
67

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

The regulation requires that the fuel consumption and water to fuel ratio be monitored and recorded on a continuous basis, or alternatively, that a NO_x and O₂ CEMS be installed. For the SO_x requirement, either a fuel meter to measure input, or a watt-meter to measure output is required, depending on which limit is selected. Also, daily monitoring of the sulfur content of the fuel is required if the fuel limit is selected. However, if the operator can provide supplier data showing the sulfur content of the fuel is less than 20 grains/100cf (for natural gas), then daily fuel monitoring is not required.

Testing

An initial performance test is required for both NO_x and SO₂. For units with a NO_x CEMS, a minimum of 9 RATA reference method runs is required at an operating load of +/- 25 percent of 100 percent load. For SO₂, either a fuel sample methodology or a stack measurement can be used, depending on the chosen limit. Annual performance tests are also required for NO_x and SO₂.

Compliance with the requirements of this rule is expected.

NSPS for GHGs from Electric Generating Units - 40CFR Part 60 Subpart TTTT


This regulation applies to new combustion turbines which commence construction after January 8, 2014, and which are rated greater than 250 mmbtu/hr heat input and 25 MW power output. For a unit that supplies net power in an amount greater than its design efficiency times its potential electric output and combusts more than 90% natural gas, the applicable standard is 1,000 lbs CO₂/gross. For a unit that supplies net power in an amount less than its design efficiency times its potential electric output and combusts more than 90% natural gas, the applicable standard is 120 lbs CO₂/mmbtu. 50% is the highest efficiency to be used in the equation, so if a unit has a design efficiency greater than 50%, then 50% is used as the default.

Combined Cycle Turbines

The potential electrical output of each of the combined cycle units is approximately 3,038.9 GW, assuming a gross output per turbine of 346.911 MW (includes ½ the steam turbine) and 8,760 hrs/yr operation (the regulation does not take into account any limitations on operation in determining the potential output). The design efficiency is greater than 50% (on a LHV basis), therefore if the unit supplies 1,519.5 GW (0.50*3,038.9) of power or more on a 12 operating month and 3 year rolling average basis, their applicable limit would be 1,000 lbs CO₂/gross MW. Calculations in Appendix I show that the units can be expected to meet this limit.

Simple Cycle Turbines

The potential electrical output of each of the simple cycle units is approximately 883.1 GW, assuming a gross output per turbine of 100.814 MW and 8,760 hrs/yr operation (the regulation does not take into account any limitations on operation in determining the potential output). The design efficiency is 42.6% (on a LHV basis), , therefore if the unit supplies less than 376.2 GW (0.426*883.1) of power on a 12 operating month and 3 year rolling average basis, the applicable limit would be 120 lbs CO₂/mmbtu. EPA has established a default emission rate of 117 lbs CO₂/mmbtu for natural gas fired turbines, therefore the HBEP simple cycle turbines can be expected to meet the

	South Coast Air Quality Management District		PAGE 68	PAGES 212
	Engineering Division Application Processing & Calculations		APPL NO. See Below	DATE 6/7/16
			PROCESSED BY CP01	CHECKED BY

limit. It should be noted that, based on calculations shown in Appendix I, the simple cycle turbines would not meet the 1,000 lbs CO₂/gross MW standard. Therefore, it is appropriate to limit the simple cycle turbines to a maximum annual net electric sales of 376.2 GW.

For all the HBEP turbines, the actual net electric sales will be based on operating data for a 12-month operating-month and 3-year-rolling average time frame. The lbs CO₂ per MW for the combined cycle turbines will be calculated from this operating data to determine compliance on an ongoing basis. The facility is required to keep records of its heat input and energy output to make these determinations.

NESHAPS for Stationary Gas Turbines - 40CFR Part 63 Subpart YYYYY

This regulation applies to gas turbines located at major sources of HAP emissions. A major source is defined as a facility with emissions of 10 tpy or more of a single HAP or 25 tpy or more of a combination of HAPs based on the potential to emit. The total combined potential HAP emissions from all the combined cycle turbines, simple cycle turbines, and auxiliary boiler are about 13 tpy, and the total formaldehyde emissions from all sources combined is about 6 tpy, therefore, AES Huntington Beach is classified as an area source of HAPs, and is not subject to this subpart (calculations can be referenced in Appendix O).

40 CFR Part 64 – Compliance Assurance Monitoring

The CAM regulation applies to emission units at major stationary sources required to obtain a Title V permit, which use control equipment to achieve a specified emission limit and which have emissions that are at least 100% of the major source thresholds on a pre-control basis. The rule is intended to provide “reasonable assurance” that the control systems are operating properly to maintain compliance with the emission limits. Based on the emission calculations shown in Appendix O, the AES Huntington Beach facility is a major source. The combined cycle turbine pre-control emissions are greater than the major source thresholds for NO_x, CO, and VOC. The combined cycle turbines will be subject to an emission limit for each of these pollutants, and will use control systems to meet these limits. The simple cycle turbine pre-control emissions are greater than the major source threshold for NO_x and CO, the turbines will be subject to an emission limit for each of these pollutants, and will use control systems to meet these limits. The auxiliary boiler pre-control emissions do not trigger the thresholds for any pollutant.

Combined Cycle Turbines

NO_x

- Emission Limit – NO_x is subject to a 2.0 ppm 1 hour BACT limit.
- Control Equipment – NO_x is controlled with SCR
- ✓ Requirement - As a NO_x Major Source under Reclaim, the turbines are required to have CEMS under Rule 1212. The use of a continuous monitor to show compliance with an emission limit is exempt from CAM under 64.2(b)(vi).



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
69

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

CO

- Emission Limit – CO is subject to a 2.0 ppm 1 hour BACT limit.
- Control Equipment – CO is controlled with the oxidation catalyst.
- ✓ Requirement – The turbines will be required to use a CO CEMS under Rule 218. The use of a continuous monitor to show compliance with an emission limit is exempt from CAM under 64.2(b)(vi).

VOC

- Emission Limit – VOC is subject to a 2.0 ppm 1 hour BACT limit.
- Control Equipment – VOC is controlled with the oxidation catalyst.
- ✓ Requirement – The oxidation catalyst is effective at operating temperatures above 500°F. The facility is required to maintain a temperature gauge in the exhaust (condition D12.7), which will measure the exhaust temperature on a continuous basis and record the readings on an hourly basis. The exhaust temperature is required to be at least 500°F, (with exceptions for start ups and shutdowns). This will insure that the oxidation catalyst is operating properly.

Simple Cycle Turbines

NOx


- Emission Limit – NOx is subject to a 2.5 ppm 1 hour BACT limit.
- Control Equipment – NOx is controlled with SCR
- ✓ Requirement - As a NOx Major Source under Reclaim, the turbines are required to have CEMS under Rule 2012. The use of a continuous monitor to show compliance with an emission limit is exempt from CAM under 64.2(b)(vi).

CO

- Emission Limit – CO is subject to a 4.0 ppm 1 hour BACT limit.
- Control Equipment – CO is controlled with the oxidation catalyst.
- ✓ Requirement – The turbines will be required to use a CO CEMS under Rule 218. The use of a continuous monitor to show compliance with an emission limit is exempt from CAM under 64.2(b)(vi).

40 CFR Part 72 - (Acid Rain Provisions)

The facility will be subject to the requirements of the federal acid rain program, because the turbines are utility units greater than 25 MW. The acid rain program is similar to RECLAIM in that facilities are required to cover SO₂ emissions with “SO₂ allowances” that are similar in concept to RTCs. The Huntington Beach facility was given initial allowance allocations based on the past operation of their boilers. AES can either use those allocations, or if insufficient, must purchase additional allocations to cover the operation of the new turbines. The applicant is also required to monitor SO₂ emissions through use of fuel gas meters and gas constituent analyses, or, if fired with pipeline quality natural gas, as in the case of the Huntington Beach facility, a default emission factor of 0.0006 lbs/mmbtu is allowed. SO₂ mass emissions are to be recorded every hour. NO_x and O₂ must be monitored with

	South Coast Air Quality Management District		PAGE 70	PAGES 212
	Engineering Division Application Processing & Calculations		APPL NO. See Below	DATE 6/7/16
			PROCESSED BY CP01	CHECKED BY

CEMS in accordance with the specifications of Part 75. Under this program, NO_x and SO_x emissions will be reported directly to the U.S. EPA. Part 75 requires that the CEMS be installed and certified within 90 days of initial startup. Compliance is expected. Note that Section K of the permit will include the Acid Rain rule references applicable to this facility, specifically Part 72 and Part 73.

Public Notice Requirements

The project is subject to public notice under Rule 212, Rule 1710, and Rule 3006. Following are the notice requirements for each rule:

Rule 212


The project is subject to the noticing requirements of paragraph (g). This paragraph requires that the notification follow the procedures of 40 CFR51, Section 51.161(b), and 40 CFR124, Section 124.10. Rule 212(g) also requires 1) the AQMD analysis and information submitted by the operator must be available for public inspection in the area affected, 2) notice by prominent advertisement in the affected area, and 3) mailing a copy of the notice to EPA, CARB, chief executives of the city and county where the source is located, any land use agencies, State and Federal Land Managers or Indian Governing Body whose lands may be affected by the project.

In addition to the above, Section 124.10 requires that the notice be sent to Federal and State agencies with jurisdiction over fish, shellfish, and wildlife resources and over coastal zone management plans, the Advisory Council on Historic Preservation, State and Historic Preservation Officers, to any unit of local government having jurisdiction over the area where the facility is proposed to be located and to each State agency having any authority under State law with respect to the construction or operation of such facility. Section 124.10(c)(ix) requires the development of a mailing list consisting of those who request in writing to be on the list, solicitations for area lists of past participants in the area of the project, and notifying the public of the opportunity to be put on the mailing list through periodic publication in the public press, newsletters, environmental bulletins, etc.

The applicant must also distribute the notification to all addresses within a ¼ mile radius of the facility.

Rule 1710

As a major modification under PSD, the project is subject to the noticing requirements of Rule 1710. SCAQMD is required to make available for public review the application submittal, the preliminary determination of compliance and any documents considered in making the determination. Noticing requirements include a newspaper notification, distribution of a notice within ¼ mile radius of the facility, and providing the notice to responsible agencies, the list of which is very similar to that specified under Rule 212, but also includes other state or local air pollution control agencies. Furthermore, SCAQMD must provide the opportunity for a public hearing on the project, consider all written comments and comments received at any public hearings available for public inspection, and

	South Coast Air Quality Management District		PAGE 71	PAGES 212
	Engineering Division Application Processing & Calculations		APPL NO. See Below	DATE 6/7/16
			PROCESSED BY CP01	CHECKED BY

notify the application of the final determination. The final determination must be made available for public inspection.

Rule 3006

Rule 3006 requires the notice be sent to those who request in writing to be on a list and other means determined by the EO to insure adequate notice to the affected public. SCAQMD generates a mailing list which consists of those who have made requests to either EPA or SCAQMD to be notified.

Rule 3006 also requires that the notice contain the following:


- i) The identity and location of the affected facility;
- (ii) The name and mailing address of the facility's contact person;
- (iii) The identity and address of the South Coast Air Quality Management District as the permitting authority processing the permit;
- (iv) The activity or activities involved in the permit action;
- (v) The emissions change involved in any permit revision;
- (vi) The name, address, and telephone number of a person who interested persons may contact to review additional information including copies of the proposed permit, the application, all relevant supporting materials, including compliance documents as defined in paragraph (b)(5) of Rule 3000, and all other materials available to the Executive Officer that are relevant to the permit decision;
- (vii) A brief description of the public comment procedures provided; and,
- (viii) The time and place of any proposed permit hearing that may be held or a statement of the procedures to request a proposed permit hearing if one has not already been requested.

Title V also allows for a 45 day review and comment period by the U.S. EPA.

A copy of the notice and the mailing list of those sent the notice is included in this file.

RECOMMENDATION:

Based on the forgoing analysis, it is recommended that a Permit to Construct be issued following 1) completion of the 30 day public and 45 day EPA review and comment period, 2) CEC's approval of the proposed license amendment petition, 3) completion of the Federal Land Managers review, and 4) securing all necessary emission offsets. The following conditions shall apply:

	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 72	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

CONDITIONS:

FACILITY-WIDE CONDITIONS

F2.1

The operator shall limit emissions from this facility as follows:

CONTAMINANT	EMISSIONS LIMIT
PM	Less than 100 TONS IN ANY ONE YEAR

For purposes of this condition, the PM shall be defined as particulate matter with aerodynamic diameter of 2.5 microns or less.

For purposes of demonstrating compliance with the 100 tons per year limit the operator shall sum the PM_{2.5} emissions for each of the sources at this facility by calculating a 12 month rolling average as follows:

Using the calendar monthly fuel use data and following emission factors for each combined cycle turbine PM_{2.5} = 3.94 lbs/mmcf., for each simple cycle turbine PM_{2.5} = 7.43 lbs/mmcf, for the auxiliary boiler PM_{2.5} = 7.54 lbs/mmcf, for Boiler 1 PM_{2.5} = 1.86 lbs/mmcf, for Boiler 2 PM_{2.5} = 2.1 lbs/mmcf. For each emergency engine using the rated hp and the calendar monthly hourly usage data and the following emission factor PM_{2.5} = 0.38 gr/bhp-hr.

The operator may apply to change the factors, via permit application, once a different value is demonstrated, subject to SCAQMD review of testing procedures and protocols.


The operator shall submit written reports of the monthly PM_{2.5} compliance demonstrations required by this condition. The report submittal shall be included with the semi annual Title V report as required under Rule 3004(a)(4)(f). Records of the monthly PM_{2.5} compliance demonstrations shall be maintained on site for at least five years and made available upon SCAQMD request.
[Rule 1325]

F52.1

This facility is subject to the applicable requirements of the following rules or regulations:

The facility shall submit a detailed retirement plan for the permanent shutdown of Huntington Beach (HB) Boilers 1 and 2 and Redondo Beach (RB) Boiler 7 describing in detail the steps and schedule that will be taken to render the boilers permanently inoperable. The retirement plan shall be submitted to SCAQMD within 60 days after the Permits to Construct are issued for gas turbines CCTG 1, CCTG 2, SCTG 1, and SCTG 2.

AES shall not commence any construction of HB Boilers 1 and 2 and RB Boiler 7 repowering project equipment including gas turbines CCTG 1, CCTG 2, SCTG 1, SCTG 2, Auxiliary Boiler, ammonia

	South Coast Air Quality Management District		PAGE 73	PAGES 212
	Engineering Division Application Processing & Calculations		APPL NO. See Below	DATE 6/7/16
			PROCESSED BY CP01	CHECKED BY

storage tanks, or the oil water separators, unless the retirement plan is approved in writing by SCAQMD. If SCAQMD notifies AES that the plan is not approvable, AES shall submit a revised plan addressing SCAQMD's concerns within 30 days.

Within 30 calendar days of actual shutdown, or by no later than November 1, 2019, AES shall provide SCAQMD with a notarized statement that HB Beach Boiler 1 and RB Boiler 7 are permanently shutdown and that any re start or operation of the units shall require new Permits to Construct and be subject to all requirements of non-attainment new source review and the prevention of significant deterioration program.

Within 30 calendar days of actual shutdown, or by no later than December 31, 2020, AES shall provide SCAQMD with a notarized statement that HB Beach Boiler 2 is permanently shutdown and that any re start or operation of the unit shall require a new Permit to Construct and be subject to all requirements of non-attainment new source review and the prevention of significant deterioration program.

AES shall notify SCAQMD 30 days prior to the implementation of the approved retirement plan for permanent shutdown of HB Boiler 1 and RB Boiler 7, or advise SCAQMD as soon practicable should AES undertake permanent shutdown prior to November 1, 2019.

AES shall notify SCAQMD 30 days prior to the implementation of the approved retirement plan for permanent shutdown of HB Boiler 2, or advise SCAQMD as soon practicable should AES undertake permanent shutdown prior to December 31, 2020.

AES shall cease operation of HB Boiler 1 within 90 calendar days of the first fire of either CCTG 1 or CCTG 2, whichever is earlier. AES shall cease operation of HB Boiler 2 within 90 calendar days of the first fire of either SCTG 1 or SCTG 2, whichever is earlier. AES shall cease operation of RB Boiler 7 prior to the first fire of either CCTG 1 or CCTG 2, whichever is earlier.

At least 6 months prior to November 1, 2019, AES may submit a permit modification application requesting the permission to shutdown a combination of boilers other than HB Boiler 1, HB Boiler 2, and RB Boiler 7 to offset the increases for this project. The other boilers must be located at AES facilities Huntington Beach GS, Redondo Beach GS, or Alamitos GS, and approval of the application must be received prior to any changes being made to the shutdowns outlined in this condition.
[Rule 1304 – Modeling and Offset Exemption, Rule 1313]

F52.2

This facility is subject to the applicable requirements of the following rules or regulations:

For all circuit breakers at the facility utilizing SF₆, the operator shall install, operate, and maintain enclosed-pressure SF₆ circuit breakers with a maximum annual leak rate of 0.5 percent by weight. The circuit breakers shall be equipped with a 10 percent by weight leak detection system. The leak



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
74

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

detection system shall be calibrated in accordance with manufacturer's specifications. The manufacturer's specifications and all records of calibrations shall be maintained on site.

The total CO₂e emissions from all circuit breakers shall not exceed 71.8 tons per calendar year.

The operator shall calculate the SF₆ emissions due to leakage from the circuit breakers by using the mass balance in equation DD-1 at 40 CFR Part 98, Subpart DD on an annual basis. Records of such calculations shall be maintained on site.

[Rule 1714]

COMBINED CYCLE GAS TURBINE CONDITIONS

A63.6

The operator shall limit emission from this equipment as follows:

CONTAMINANT	EMISSION LIMIT
PM10	3,090 LBS IN ANY ONE MONTH
CO	99,076 LBS IN ANY ONE MONTH
VOC	14,109 LBS IN ANY ONE MONTH

The above limits apply during commissioning. The above limits apply to each turbine.

The operator shall calculate compliance with the emission limit(s) by using fuel use data and the following emission factors: VOC: 10.16 lbs/mmcf, PM10: 5.86 lbs/mmcf, and CO: 70.09 lbs/mmcf.

A63.7

The operator shall limit emission from this equipment as follows:


CONTAMINANT	EMISSION LIMIT
PM10	6,324 LBS IN ANY ONE MONTH
CO	26,440 LBS IN ANY ONE MONTH
VOC	7,611 LBS IN ANY ONE MONTH

The above limits apply after the equipment is commissioned. The above limits apply to each turbine.

[Rule 1303 – Offsets]

The operator shall calculate compliance with the emission limit(s) by using fuel use data and the following emission factors: VOC: 2.66 lbs/mmcf, PM10: 3.94 lbs/mmcf.

The operator shall calculate compliance with the emission limits for CO after the CO CEMS certification based upon readings from the SCAQMD certified CEMS.

	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 75	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

[Rule 1303 – Offsets]

A99.4

The 19.09 LBS/MMCF NO_x emission limits shall only apply during the first year of operation prior to CEMS certification for reporting NO_x emissions.

[Rule 2012]

A195.6

The 2.0 PPMV NO_x emission limit(s) is averaged over 60 minutes at 15 percent O₂, dry. This limit shall not apply during commissioning, turbine start ups and turbine shutdowns.

[Rule 1703-PSD, Rule 2005]

A195.7

The 2.0 PPMV CO emission limit(s) is averaged over 60 minutes at 15 percent O₂, dry. This limit shall not apply during commissioning, turbine start ups and turbine shutdowns.

[Rule 1703-PSD]

A195.8

The 2.0 PPMV VOC emission limit(s) is averaged over 60 minutes at 15 percent O₂, dry. This limit shall not apply during commissioning, turbine start ups and turbine shutdowns.

[Rule 1303(a) – BACT, Rule 1303(b)(2) - Offsets]

A195.9

The 1,000 lbs/MW-hr CO₂ emissions limit(s) is averaged over a rolling 12 operating month basis. The limit shall only apply if the turbine supplies more than 1,519,500 MWh net electrical output to a utility distribution system over a rolling 12 operating month basis and a 3 year rolling average basis.

[40CFR 60 Subpart TTTT]

A327.1

For the purpose of determining compliance with District Rule 475, combustion contaminants emissions may exceed the concentration limit or the mass emission limit listed, but not both limits at the same time.

[Rule 475]

B61.1

The operator shall not use natural gas containing the following specified compounds:

Compound	Grains per 100 scf
H ₂ S	Greater than 0.25



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
76

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

This concentration limit is an annual average based on monthly sample of natural gas composition or gas supplier documentation. Gaseous fuel samples shall be tested using District Method 307-91 for total sulfur calculated as H₂S.

[Rule 1303(b) – Offset]

C1.7

The operator shall limit the number of start ups to no more than 62 in any one calendar month.

The number of cold start ups shall not exceed 15 per month, the number of warm start ups shall not exceed 12 per month, and the number of hot start ups shall not exceed 35 per month. Additionally, the number of cold start ups shall not exceed 80 per year, the number of warm start ups shall not exceed 88 per year, and the number of hot start ups shall not exceed 332 per year.

For the purposes of this condition: A cold start up is defined as a start up which occurs after the steam turbine has been shutdown for 48 hours or more. A cold start up shall not exceed 60 minutes. Emissions during the 60 minutes that includes a cold start up shall not exceed the following: NO_x - 61 lbs., CO – 325 lbs., VOC – 36 lbs.

A warm start up is defined as a start up which occurs after the steam turbine has been shutdown for 9 – 48 hours. A warm start up shall not exceed 30 minutes. Emissions during the 30 minutes that includes a warm start up shall not exceed the following: NO_x - 17 lbs., CO – 137 lbs., VOC – 25 lbs.

A hot start up is defined as a start up which occurs after the steam turbine has been shutdown for less than 9 hours. A hot start up shall not exceed 30 minutes. Emissions during the 30 minutes that includes a hot start up shall not exceed the following: NO_x - 17 lbs., CO – 137 lbs., VOC – 25 lbs.

The beginning of a start up occurs at initial fire in the combustor and the end of start up occurs when the BACT levels are achieved. If during start up the process is aborted the process will count as one start up.

The operator shall maintain records, in a manner approved by the SCAQMD to demonstrate compliance with this condition.

[Rule 2005]

C1.8

The operator shall limit the number of shutdowns to no more than 62 in any one calendar month.

Additionally, the number of shutdowns shall not exceed 500 per year.

Shutdown time shall not exceed 30 minutes per shutdown. Emissions during the 30 minutes that includes a shutdown shall not exceed the following: NO_x – 10 lbs., CO – 133 lbs., VOC – 32 lbs.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
77

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

The operator shall maintain records, in a manner approved by the SCAQMD to demonstrate compliance with this condition.

[Rule 2005]

C1.9

The operator shall limit the hours of operation to no more than 6640 in any one calendar year.

The limit includes baseload operation as well as start ups and shutdowns. The limit does not apply to the calendar year in which the units are commissioned.

Combined Cycle Turbines No. 1 and No. 2 shall not simultaneously operate at minimum load for more than 20 consecutive hours (approximately 44% of full load rating).

The operator shall maintain records, in a manner approved by the SCAQMD to demonstrate compliance with this condition.

[Rule 2005, Rule 1703]

D29.5

The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant to be tested	Required Test Method(s)	Averaging Time	Test Location
NOX emissions	District method 100.1	1 hour	Outlet of the SCR
CO emissions	District method 100.1	1 hour	Outlet of the SCR
SOX emissions	District Lab method 307-91	District approved averaging time	Fuel Sample
VOC emissions	District method 25.3	1 hour	Outlet of the SCR
PM10 emissions	EPA method 201A/District method 5.1	District approved averaging time	Outlet of the SCR
PM2.5	EPA method 201A and 202	District approved averaging time	Outlet of the SCR
NH3 emissions	District method 207.1 and 5.3 or EPA method 17	1 hour	Outlet of the SCR

The test shall be conducted after SCAQMD approval of the source test protocol, but no later than 180 days after initial start-up. The SCAQMD shall be notified of the date and time of the test at least 10 days prior to the test.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
78

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

The test shall be conducted to determine the oxygen levels in the exhaust. In addition, the tests shall measure the fuel flow rate (CFH), the flue gas flow rate, and the turbine generating output in MW net and MW gross.

The test shall be conducted in accordance with an SCAQMD approved test protocol. The protocol shall be submitted to the SCAQMD engineer no later than 45 days before the proposed test date and shall be approved by the SCAQMD before the test commences. The test protocol shall include the proposed operating conditions of the turbine during the tests, the identity of the testing lab, a statement from the testing lab certifying that it meets the criteria of Rule 304, and a description of all sampling and analytical procedures.

The test shall be conducted when this equipment is operating at 3 load conditions, including within 5 percent of maximum, within 5 percent of minimum, and one intermediate load.

For natural gas fired turbines only, an alternative to AQMD Method 25.3 for the purpose of demonstrating compliance with BACT as determined by CARB and SCAQMD may be the following:

- a) Triplicate stack gas samples extracted directly into Summa canisters, maintaining a final canister pressure between 400-500 mm Hg absolute,
- b) Pressurization of the Summa canisters with zero gas analyzed/certified to less than 0.05 ppmv total hydrocarbons as carbon, and
- c) Analysis of Summa canisters per unmodified EPA Method TO-12 (with pre-concentration) or the canister analysis portion of AQMD Method 25.3 with a minimum detection limit of 0.3 ppmv or less and reported to two significant figures. The temperature of the Summa canisters when extracting the samples for analysis shall not be below 70 F

The use of this alternative method for VOC compliance determination does not mean that it is more accurate than unmodified AQMD Method 25.3, nor does it mean that it may be used in lieu of AQMD Method 25.3 without prior approval, except for the determination of compliance with the BACT level of 2.0 ppmv ROG calculated as carbon set by CARB for natural gas fired turbines.

For purposes of this condition, an alternative test method may be allowed for any of the above pollutants upon concurrence by EPA, CARB, and SCAQMD.

[Rule 1303(a)(1) – BACT, Rule 1303(b)(2) – Offset, Rule 1703-PSD, Rule 2005]



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
79

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

D29.6

The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant to be tested	Required Test Method(s)	Averaging Time	Test Location
NH3 emissions	District method 207.1 and 5.3 or EPA method 17	1 hour	Outlet of the SCR

The test shall be conducted and the results submitted to the District within 60 days after the test date. The SCAQMD shall be notified of the date and time of the test at least 10 days prior to the test.

The test shall be conducted at least quarterly during the first twelve months of operation and at least annually thereafter. The NO_x concentration, as determined by the CEMS, shall be simultaneously recorded during the ammonia slip test. If the CEMS is inoperable, a test shall be conducted to determine the NO_x emissions using District Method 100.1 measured over a 60 minute averaging time period.

The test shall be conducted to demonstrate compliance with the Rule 1303 concentration limit

[Rule 1303(a)(1) – BACT]

D29.7

The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant to be tested	Required Test Method(s)	Averaging Time	Test Location
SOX emissions	District Lab method 307-91	District approved averaging time	Fuel Sample
VOC emissions	District method 25.3	1 hour	Outlet of the SCR
PM10 emissions	EPA method 201A/District method 5.1	District approved averaging time	Outlet of the SCR

The test shall be conducted at least once every three years.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
80

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

The test shall be conducted and the results submitted to the SCAQMD within 60 days after the test date. The SCAQMD shall be notified of the date and time of the test at least 10 days prior to the test.

The test shall be conducted when this equipment is operating at 100 percent of maximum heat input.

For natural gas fired turbines only, an alternative to AQMD Method 25.3 for the purpose of demonstrating compliance with BACT as determined by CARB and SCAQMD may be the following:

- a) Triplicate stack gas samples extracted directly into Summa canisters, maintaining a final canister pressure between 400-500 mm Hg absolute,
- b) Pressurization of the Summa canisters with zero gas analyzed/certified to less than 0.05 ppmv total hydrocarbons as carbon, and
- c) Analysis of Summa canisters per unmodified EPA Method TO-12 (with pre-concentration) or the canister analysis portion of AQMD Method 25.3 with a minimum detection limit of 0.3 ppmv or less and reported to two significant figures. The temperature of the Summa canisters when extracting the samples for analysis shall not be below 70 F

The use of this alternative method for VOC compliance determination does not mean that it is more accurate than unmodified AQMD Method 25.3, nor does it mean that it may be used in lieu of AQMD Method 25.3 without prior approval, except for the determination of compliance with the BACT level of 2.0 ppmv ROG calculated as carbon set by CARB for natural gas fired turbines.

For purposes of this condition, an alternative test method may be allowed for any of the above pollutants upon concurrence by EPA, CARB, and SCAQMD.

[Rule 1303(a)(1) – BACT, Rule 1303(b)(2) – Offset, Rule 475]

D82.1

The operator shall install and maintain a CEMS to measure the following parameters:

CO concentration in ppmv

Concentrations shall be corrected to 15 percent oxygen on a dry basis. The CEMS shall be installed and operating no later than 90 days after initial startup of the turbine, in accordance with approved SCAQMD Rule 218 CEMS plan application. The operator shall not install the CEMS prior to receiving initial approval from SCAQMD.

The CEMS shall be installed and operated to measure the CO concentration over a 15 minute averaging time period.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
81

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

The CEMS shall convert the actual CO concentrations to mass emission rates (lbs/hr) using the equation below and record the hourly emission rates on a continuous basis.

CO Emission Rate, lbs/hr = $K * C_{co} * F_d [20.9 / (20.9\% - \%O_2 d)] [(Q_g * HHV) / 10E6]$, where

K = $7.267 * 10^{-8}$ (lbs/scf)/ppm

C_{co} = Average of 4 consecutive 15 min. average CO concentrations, ppm

F_d = 8710 dscf/MMBTU natural gas

%O₂, d = Hourly average % by volume O₂ dry, corresponding to C_{co}

Q_g = Fuel gas usage during the hour, scf/hr

HHV = Gross high heating value of the fuel gas, BTU/scf

[Rule 1703-PSD]

D82.2

The operator shall install and maintain a CEMS to measure the following parameters:

NO_x concentration in ppmv

Concentrations shall be corrected to 15 percent oxygen on a dry basis. The CEMS shall be installed and operating no later than 90 days after initial startup of the turbine, in accordance with approved SCAQMD REG XX CEMS plan application. The operator shall not install the CEMS prior to receiving initial approval from SCAQMD.

Rule 2012 provisional RATA testing shall be completed and submitted to the SCAQMD within 90 days of the conclusion of the turbine commissioning period. During the interim period between the initial start up and the provisional certification date of the CEMS, the operator shall comply with the requirements of Rule 2012(h)(2) and 2012(h)(3).

[Rule 1703 – PSD, Rule 2005, Rule 2012]

E193.3


The operator shall install this equipment according to the following requirements:

Construction shall commence within 12 months of the date of the permit to construct unless the permit is extended, but in no case should the start of construction exceed 18 months from the date of the permit to construct. Construction shall not be discontinued for a period of 18 months or more.

[Rule 205, 40 CFR Part 52]

E193.4

The operator shall upon completion of the construction, operate and maintain this equipment according to the following specifications:

	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 82	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

In accordance with all mitigation measures stipulated in the final California Energy Commission decision for the 12-AFC-02C project.

[CEQA]

E193.5

The operator shall install this equipment according to the following requirements:

Total commissioning hours shall not exceed 996 hours of operation for each turbine from the date of initial turbine start up. Total commissioning hours without control shall not exceed 216 hours of operation for each turbine.

The operator shall vent this equipment to the CO oxidation catalyst and SCR control system whenever the turbine is in operation after commissioning.

The operator shall provide SCAQMD with written notification of the initial start up date. Written records of commissioning, start ups, and shutdowns shall be maintained and be made available upon request from SCAQMD.

[Rule 1303 – BACT, Rule 1303 – Offsets, Rule 1703 – PSD, Rule 2005]

E193.6

The operator shall upon completion of the construction, operate and maintain this equipment according to the following specifications:

The operator shall record the total net power generated in a calendar month in megawatt-hours.

The operator shall calculate and record greenhouse gas emissions for each calendar month using the following formula:

$$\text{CO}_2 = 60.009 * \text{FF}$$

Where, CO₂ is in tons and FF is the monthly fuel usage in millions standard cubic feet.

The operator shall calculate and record the CO₂ emissions in pounds per net megawatt-hour on a 12-month rolling average. The CO₂ emissions from this equipment shall not exceed 873,035 tons per year per turbine on a 12-month rolling average basis. The calendar annual average CO₂ emissions shall not exceed 967.6 pounds per net MW-hour.

The operator shall maintain records in a manner approved by the SCAQMD to demonstrate compliance with this condition. The records shall be made available to SCAQMD upon request.

[Rule 1714]



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
83

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

E448.1

The operator shall comply with the following requirements:

The total electricity output on a gross basis from combined cycle turbines devices D115 and D124, and their common steam turbine shall not exceed 693.8 MW.

The gross electrical output shall be measured at the single generator serving each of the combined cycle turbines, and the single generator serving the common steam turbine. The monitoring equipment shall meet ANSI Standard No. C12 or equivalent, and have an accuracy of +/- 0.2 percent. The gross electrical output from the generators shall be recorded at the CEMS DAS over a 15 minute averaging time period.

The operator shall record and maintain written records of the maximum amount of electricity produced from this equipment and shall make such records available to the Executive Officer upon request. The records shall be maintained for a minimum of 5 years in a manner approved by SCAQMD.

[Rule 1303 –Offsets, Rule 2005]

I297.1

This equipment shall not be operated unless the facility holds 147,093 pounds of NO_x RTCs in its allocation account to offset the annual emissions increase for the first year of operation. The RTCs held to satisfy the first year of operation portion of this condition may be transferred only after one year from the initial start of operation. RTCs held to satisfy the compliance year portion of this condition may be transferred only after the compliance year for which the RTCs are held. If the initial or annual hold amount is partially satisfied by holding RTCs that expire midway through the hold period, those RTCs may be transferred upon their respective expiration dates. This hold amount is in addition to any other amount of RTCs required to be held under other condition(s) stated in this permit.

[Rule 2005]

I298.1

This equipment shall not be operated unless the facility holds 14,803 pounds of SO_x RTCs in its allocation account to offset the annual emissions increase for the first year of operation. The RTCs held to satisfy the first year of operation portion of this condition may be transferred only after one year from the initial start of operation. In addition, this equipment shall not be operated unless the operator demonstrates to the Executive Officer that, at the commencement of each compliance year after the start of operation, the facility holds 9,960 pounds of SO_x RTCs valid during that compliance year. RTCs held to satisfy the compliance year portion of this condition may be transferred only after the compliance year for which the RTCs are held. If the initial or annual hold amount is partially satisfied by holding RTCs that expire midway through the hold period, those RTCs may be transferred upon their respective expiration dates. This hold amount is in addition to any other amount of RTCs required to be held under other condition(s) stated in this permit.

[Rule 2005]



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
84

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

K40.3

The operator shall provide to the District a source test report in accordance with the following specifications:

Source test results shall be submitted to the District no later than 60 days after the source tests required under conditions D29.5, D29.6 and D29.7 are conducted.

Emission data shall be expressed in terms of concentration (ppmv) corrected to 15 percent oxygen (dry basis), mass rate (lb/hr), and lb/MMCF. In addition, solid PM emissions, if required to be tested, shall also be reported in terms of grains/DSCF.

All exhaust flow rate shall be expressed in terms of dry standard cubic feet per minute (DSCFM) and dry actual cubic feet per minute. All moisture concentration shall be expressed in terms of percent corrected to 15 percent oxygen.

Source test results shall also include the oxygen levels in the exhaust, fuel flow rate (CFH), the flue gas temperature, and the generator power output (MW) under which the test was conducted.

[Rule 1303(a)(1) – BACT, Rule 1303(b)(2) – Offset]

K67.5

The operator shall keep records in a manner approved by the District, for the following parameter(s) or item(s):

Commissioning hours and type of control and fuel use

Date, time, and duration of each start-up and shutdown, and the type of start up (cold, warm, or hot).

In addition to the requirements of a certified CEMS, natural gas fuel use records shall be kept during and after the commissioning period and prior to CEMS certification

Minute by minute data (NO₂ and O₂ concentration and fuel flow rate at a minimum) for each turbine start up and shutdown

Total annual power output in MWh

[Rule 1303(b)(2) - Offsets]

SCR CONDITIONS (COMBINED CYCLE UNIT SCRS)

A195.10

The 5 ppmv NH₃ emission limit is averaged over 60 minutes at 15% O₂, dry basis. The operator shall calculate and continuously record the NH₃ slip concentration using the following:

$$\text{NH}_3 \text{ (ppmv)} = [a - b \cdot (c \cdot 1.2) / 1\text{E}+06] \cdot 1\text{E}+06 / b$$



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
85

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

where,

a = NH₃ injection rate (lbs/hr)/17(lb/lb-mol)

b = dry exhaust gas flow rate (scf/hr)/385.3 scf/lb-mol)

c = change in measured NO_x across the SCR (ppmvd at 15% O₂)

The operator shall install and maintain a NO_x analyzer to measure the SCR inlet NO_x ppmv accurate to plus or minus 5 percent calibrated at least once every twelve months. The NO_x analyzer shall be installed and operated within 90 days of initial start-up.

The operator shall use the above described method or another alternative method approved by the Executive Officer.

The ammonia slip calculation procedures described above shall not be used for compliance determination or emission information without corroborative data using an approved reference method for the determination of ammonia.

[Rule 1303(a)(1) – BACT]

D12.7

The operator shall install and maintain a(n) flow meter to accurately indicate the flow rate of the total hourly throughput of injected ammonia.

The operator shall also install and maintain a device to continuously record the ammonia flow rate. Continuously record shall be defined as recording at least once every hour and shall be calculated based upon the average of the continuous monitoring for that hour. The flow meter shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months. The injected ammonia rate shall be maintained within 44.0 lbs/hr and 242.0 lbs/hr except during start ups and shutdowns

[Rule 1303(a)(1) – BACT]

D12.8

The operator shall install and maintain a(n) temperature gauge to accurately indicate the temperature in the exhaust at the inlet to the SCR reactor.

The operator shall also install and maintain a device to continuously record the exhaust temperature. Continuously record shall be defined as recording at least once every hour and shall be calculated based upon the average of the continuous monitoring for that hour. The temperature gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months. The exhaust temp at the inlet of the SCR shall be maintained between 570-692 deg F except during start up and shutdowns

[Rule 1303(a)(1) – BACT]

D12.9

The operator shall install and maintain a(n) pressure gauge to accurately indicate the differential pressure across the SCR catalyst bed in inches of water column.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
86

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

The operator shall also install and maintain a device to continuously record the differential pressure. Continuous monitoring shall be defined as measuring at least once every month and shall be calculated based upon the average of the continuous monitoring for that month. The pressure gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months. The differential pressure shall not exceed 1.6 inches WC.
[Rule 1303(a)(1) – BACT]

E193.4

The operator shall upon completion of the construction, operate and maintain this equipment according to the following specifications:

In accordance with all mitigation measures stipulated in the final California Energy Commission decision for the 12-AFC-02C project.

[CEQA]

**CO CATALYST
(COMBINED CYCLE UNITS CO CATALYST)**

D12.10

The operator shall install and maintain a(n) temperature gauge to accurately indicate the temperature in the exhaust at the inlet to the CO Catalyst.

The operator shall also install and maintain a device to continuously record the exhaust temperature. Continuously record shall be defined as recording at least once every hour and shall be calculated based on the average of the continuous monitoring for that hour. The temperature gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months. The exhaust temp at the CO Catalyst inlet shall be maintained at a minimum of 570 deg F except during start up and shutdowns.

[Rule 1303(a)(1) – BACT, Rule 1703]

E193.4

The operator shall upon completion of the construction, operate and maintain this equipment according to the following specifications:

In accordance with all mitigation measures stipulated in the final California Energy Commission decision for the 12-AFC-02C project.

[CEQA]



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
87

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

SIMPLE CYCLE GAS TURBINE CONDITIONS

A63.8

The operator shall limit emission from this equipment as follows:

CONTAMINANT	EMISSION LIMIT
PM10	4,643 LBS IN ANY ONE MONTH
CO	8,273 LBS IN ANY ONE MONTH
VOC	1,972 LBS IN ANY ONE MONTH

The above limits apply after the equipment is commissioned. The above limits apply to each turbine.

The operator shall calculate compliance with the emission limit(s) by using fuel use data and the following emission factors: VOC: 2.74 lbs/mmcf, PM10: 7.43 lbs/mmcf.

The operator shall calculate compliance with the emission limits for CO after the CO CEMS certification based upon readings from the SCAQMD certified CEMS.

[Rule 1303 – Offsets]

A63.9

The operator shall limit emission from this equipment as follows:

CONTAMINANT	EMISSION LIMIT
PM10	1,747 LBS IN ANY ONE MONTH
CO	25,449 LBS IN ANY ONE MONTH
VOC	836 LBS IN ANY ONE MONTH

The above limits apply during commissioning. The above limits apply to each turbine.

The operator shall calculate compliance with the emission limit(s) by using fuel use data and the following emission factors: VOC: 3.67 lbs/mmcf, PM10: 7.67 lbs/mmcf, and CO: 111.76 lbs/mmcf.

[Rule 1303 – Offsets]

A99.5

The 25.11 LBS/MMCF NO_x emission limits shall only apply during during the first year of operation prior to CEMS certification for reporting NO_x emissions.

[Rule 2012]



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
88

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

A195.11

The 2.5 PPMV NOX emission limit(s) is averaged over 60 minutes at 15 percent O2, dry. This limit shall not apply during commissioning, turbine start ups and turbine shutdowns.

[Rule 1703-PSD, Rule 2005]

A195.12

The 4.0 PPMV CO emission limit(s) is averaged over 60 minutes at 15 percent O2, dry. This limit shall not apply during commissioning, turbine start ups and turbine shutdowns.

[Rule 1703-PSD]

A195.8

The 2.0 PPMV VOC emission limit(s) is averaged over 60 minutes at 15 percent O2, dry. This limit shall not apply during commissioning, turbine start ups and turbine shutdowns.

[Rule 1303(a) – BACT, Rule 1303(b)(2) - Offsets]

A327.1

For the purpose of determining compliance with District Rule 475, combustion contaminants emissions may exceed the concentration limit or the mass emission limit listed, but not both limits at the same time.

[Rule 475]

B61.1

The operator shall not use natural gas containing the following specified compounds:

Compound	Grains per 100 scf
H2S	Greater than 0.25

This concentration limit is an annual average based on monthly sample of natural gas composition or gas supplier documentation. Gaseous fuel samples shall be tested using District Method 307-91 for total sulfur calculated as H2S.

[Rule 1303(b) – Offset]

C1.10

The operator shall limit the number of start ups to no more than 62 in any one calendar month.

Additionally, the number of start ups shall not exceed 350 per year.

A start up shall not exceed 30 minutes. Emissions during the 30 minutes that includes a start up shall not exceed the following: NOx – 16.6 lbs., CO – 15.4 lbs., VOC – 2.8 lbs.

The beginning of a start up occurs at initial fire in the combustor and the end of start up occurs when the BACT levels are achieved. If during start up the process is aborted the process will count as one start up.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
89

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

The operator shall maintain records, in a manner approved by the SCAQMD to demonstrate compliance with this condition.

[Rule 2005]

C1.11

The operator shall limit the number of shutdowns to no more than 62 in any one calendar month.

Additionally, the number of shutdowns shall not exceed 350 per year.

Shutdown time shall not exceed 13 minutes per shutdown. Emissions during the 13 minutes that includes a shutdown shall not exceed the following: NO_x – 3.12 lbs., CO – 28.1 lbs., VOC – 3.06 lbs.

The operator shall maintain records, in a manner approved by the SCAQMD to demonstrate compliance with this condition.

[Rule 2005]

C1.12

The operator shall limit the hours of operation to no more than 2001 in any one calendar year.

The limit includes baseload operation as well as start ups and shutdowns. The limit does not apply to the calendar year in which the units are commissioned.

The operator shall maintain records, in a manner approved by the SCAQMD to demonstrate compliance with this condition.

[Rule 2005]

D29.5

The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant to be tested	Required Test Method(s)	Averaging Time	Test Location
NOX emissions	District method 100.1	1 hour	Outlet of the SCR
CO emissions	District method 100.1	1 hour	Outlet of the SCR
SOX emissions	District Lab method 307-91	District approved averaging time	Fuel Sample
VOC emissions	District method 25.3	1 hour	Outlet of the SCR



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
90

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

PM10 emissions	EPA method 201A/District method 5.1	District approved averaging time	Outlet of the SCR
PM2.5	EPA method 201A and 202	District approved averaging time	Outlet of the SCR
NH3 emissions	District method 207.1 and 5.3 or EPA method 17	1 hour	Outlet of the SCR

The test shall be conducted after SCAQMD approval of the source test protocol, but no later than 180 days after initial start-up. The SCAQMD shall be notified of the date and time of the test at least 10 days prior to the test.

The test shall be conducted to determine the oxygen levels in the exhaust. In addition, the tests shall measure the fuel flow rate (CFH), the flue gas flow rate, and the turbine generating output in MW net and MW gross.

The test shall be conducted in accordance with an SCAQMD approved test protocol. The protocol shall be submitted to the SCAQMD engineer no later than 45 days before the proposed test date and shall be approved by the SCAQMD before the test commences. The test protocol shall include the proposed operating conditions of the turbine during the tests, the identity of the testing lab, a statement from the testing lab certifying that it meets the criteria of Rule 304, and a description of all sampling and analytical procedures.

The test shall be conducted when this equipment is operating at 3 load conditions, including within 5 percent of maximum, within 5 percent of minimum, and one intermediate load.

For natural gas fired turbines only, an alternative to AQMD Method 25.3 for the purpose of demonstrating compliance with BACT as determined by CARB and SCAQMD may be the following:

- Triplicate stack gas samples extracted directly into Summa canisters, maintaining a final canister pressure between 400-500 mm Hg absolute,
- Pressurization of the Summa canisters with zero gas analyzed/certified to less than 0.05 ppmv total hydrocarbons as carbon, and
- Analysis of Summa canisters per unmodified EPA Method TO-12 (with pre-concentration) or the canister analysis portion of AQMD Method 25.3 with a minimum detection limit of 0.3 ppmv or less and reported to two significant figures. The temperature of the Summa canisters when extracting the samples for analysis shall not be below 70 F

The use of this alternative method for VOC compliance determination does not mean that it is more accurate than unmodified AQMD Method 25.3, nor does it mean that it may be used in



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
91

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

lieu of AQMD Method 25.3 without prior approval, except for the determination of compliance with the BACT level of 2.0 ppmv ROG calculated as carbon set by CARB for natural gas fired turbines.

For purposes of this condition, an alternative test method may be allowed for any of the above pollutants upon concurrence by EPA, CARB, and SCAQMD.

[Rule 1303(a)(1) – BACT, Rule 1303(b)(2) – Offset, Rule 1703-PSD, Rule 2005]

D29.6

The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant to be tested	Required Test Method(s)	Averaging Time	Test Location
NH ₃ emissions	District method 207.1 and 5.3 or EPA method 17	1 hour	Outlet of the SCR

The test shall be conducted and the results submitted to the District within 60 days after the test date. The SCAQMD shall be notified of the date and time of the test at least 10 days prior to the test.

The test shall be conducted at least quarterly during the first twelve months of operation and at least annually thereafter. The NO_x concentration, as determined by the CEMS, shall be simultaneously recorded during the ammonia slip test. If the CEMS is inoperable, a test shall be conducted to determine the NO_x emissions using District Method 100.1 measured over a 60 minute averaging time period.


The test shall be conducted to demonstrate compliance with the Rule 1303 concentration limit

[Rule 1303(a)(1) – BACT]

D29.7

The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant to be tested	Required Test Method(s)	Averaging Time	Test Location
SOX emissions	District Lab method 307-91	District approved averaging time	Fuel Sample
VOC emissions	District method 25.3	1 hour	Outlet of the SCR

	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 92	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

PM10 emissions	EPA method 201A/District method 5.1	District approved averaging time	Outlet of the SCR
----------------	---	-------------------------------------	-------------------

The test shall be conducted at least once every three years.

The test shall be conducted and the results submitted to the SCAQMD within 60 days after the test date. The SCAQMD shall be notified of the date and time of the test at least 10 days prior to the test.

The test shall be conducted when this equipment is operating at 100 percent of maximum heat input.

For natural gas fired turbines only, an alternative to AQMD Method 25.3 for the purpose of demonstrating compliance with BACT as determined by CARB and SCAQMD may be the following:

- a) Triplicate stack gas samples extracted directly into Summa canisters, maintaining a final canister pressure between 400-500 mm Hg absolute,
- b) Pressurization of the Summa canisters with zero gas analyzed/certified to less than 0.05 ppmv total hydrocarbons as carbon, and
- c) Analysis of Summa canisters per unmodified EPA Method TO-12 (with pre-concentration) or the canister analysis portion of AQMD Method 25.3 with a minimum detection limit of 0.3 ppmv or less and reported to two significant figures. The temperature of the Summa canisters when extracting the samples for analysis shall not be below 70 F

The use of this alternative method for VOC compliance determination does not mean that it is more accurate than unmodified AQMD Method 25.3, nor does it mean that it may be used in lieu of AQMD Method 25.3 without prior approval, except for the determination of compliance with the BACT level of 2.0 ppmv ROG calculated as carbon set by CARB for natural gas fired turbines.

For purposes of this condition, an alternative test method may be allowed for any of the above pollutants upon concurrence by EPA, CARB, and SCAQMD.

[Rule 1303(a)(1) – BACT, Rule 1303(b)(2) – Offset, Rule 475]

D82.3

The operator shall install and maintain a CEMS to measure the following parameters:

CO concentration in ppmv



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
93

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Concentrations shall be corrected to 15 percent oxygen on a dry basis. The CEMS shall be installed and operating no later than 90 days after initial startup of the turbine, in accordance with approved SCAQMD Rule 218 CEMS plan application. The operator shall not install the CEMS prior to receiving initial approval from SCAQMD.

The CEMS shall be installed and operated to measure the CO concentration over a 15 minute averaging time period.

The CEMS shall convert the actual CO concentrations to mass emission rates (lbs/hr) using the equation below and record the hourly emission rates on a continuous basis.

CO Emission Rate, lbs/hr = $K * C_{co} * F_d [20.9 / (20.9\% - \%O_2 d)] [(Q_g * HHV) / 10E6]$, where

K = $7.267 * 10^{-8}$ (lbs/scf)/ppm

C_{co} = Average of 4 consecutive 15 min. average CO concentrations, ppm

F_d = 8710 dscf/MMBTU natural gas

%O₂, d = Hourly average % by volume O₂ dry, corresponding to C_{co}

Q_g = Fuel gas usage during the hour, scf/hr

HHV = Gross high heating value of the fuel gas, BTU/scf

[Rule 1703-PSD]

D82.4

The operator shall install and maintain a CEMS to measure the following parameters:

NO_x concentration in ppmv

Concentrations shall be corrected to 15 percent oxygen on a dry basis. The CEMS shall be installed and operating no later than 90 days after initial startup of the turbine, in accordance with approved SCAQMD REG XX CEMS plan application. The operator shall not install the CEMS prior to receiving initial approval from SCAQMD.


Rule 2012 provisional RATA testing shall be completed and submitted to the SCAQMD within 90 days of the conclusion of the turbine commissioning period. During the interim period between the initial start up and the provisional certification date of the CEMS, the operator shall comply with the requirements of Rule 2012(h)(2) and 2012(h)(3).

[Rule 1703 – PSD, Rule 2005, Rule 2012]

E193.3

The operator shall install this equipment according to the following requirements:

Construction shall commence within 12 months of the date of the permit to construct unless the permit is extended, but in no case should the start of construction exceed 18

	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 94	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

months from the date of the permit to construct. Construction shall not be discontinued for a period of 18 months or more.

[Rule 205, 40 CFR Part 52]

E193.4

The operator shall upon completion of the construction, operate and maintain this equipment according to the following specifications:

In accordance with all mitigation measures stipulated in the final California Energy Commission decision for the 12-AFC-02C project.

[CEQA]

E193.7

The operator shall install this equipment according to the following requirements:

Total commissioning hours shall not exceed 280 hours of operation for each turbine from the date of initial turbine start up. Total commissioning hours without control shall not exceed 4 hours of operation for each turbine.

The operator shall vent this equipment to the CO oxidation catalyst and SCR control system whenever the turbine is in operation after commissioning.

The operator shall provide SCAQMD with written notification of the initial start up date. Written records of commissioning, start ups, and shutdowns shall be maintained and be made available upon request from SCAQMD.

[Rule 1303 – BACT, Rule 1303 – Offsets, Rule 1703 – PSD, Rule 2005]

E193.8

The operator shall upon completion of the construction, operate and maintain this equipment according to the following specifications:

The operator shall record the total net power generated in a calendar month in megawatt-hours.

The operator shall calculate and record greenhouse gas emissions for each calendar month using the following formula:

$$\text{CO}_2 = 60.009 * \text{FF}$$

Where, CO₂ is in tons and FF is the monthly fuel usage in millions standard cubic feet.

The operator shall calculate and record the CO₂ emissions in pounds per net megawatt-hour on a 12-month rolling average. The CO₂ emissions from this equipment shall not exceed 103,576 tons per



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
95

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

year per turbine on a 12-month rolling average basis. The calendar annual average CO₂ emissions shall not exceed 1378.0 pounds per net MW-hour.

The operator shall maintain records in a manner approved by the SCAQMD to demonstrate compliance with this condition. The records shall be made available to SCAQMD upon request.
[Rule 1714]

E448.2

The operator shall comply with the following requirements:

The total electricity output on a gross basis from simple cycle turbines devices D133 and D139 shall not exceed 201.6 MW.

The gross electrical output shall be measured at the single generator serving each of the simple cycle turbines. The monitoring equipment shall meet ANSI Standard No. C12 or equivalent, and have an accuracy of +/- 0.2 percent. The gross electrical output from the generators shall be recorded at the CEMS DAS over a 15 minute averaging time period.

The operator shall record and maintain written records of the maximum amount of electricity produced from this equipment and shall make such records available to the Executive Officer upon request. The records shall be maintained for a minimum of 5 years in a manner approved by SCAQMD.

[Rule 1303 –Offsets, Rule 2005]

E448.3

The operator shall comply with the following requirements:

This equipment shall not supply more than 43 percent of its potential electrical output or more than 376,200 MWh net electrical output to a utility distribution system on a 12 operating month rolling average and a 3 year rolling average basis

The operator shall record and maintain written records of the amount of electricity supplied to the utility distribution system expressed as a percentage of the total potential electrical output of the turbine and shall make the records available to the Executive Officer upon request.

[40CFR 60 Subpart TTTT]

I297.2

This equipment shall not be operated unless the facility holds 26,970 pounds of NO_x RTCs in its allocation account to offset the annual emissions increase for the first year of operation. The RTCs held to satisfy the first year of operation portion of this condition may be transferred only after one year from the initial start of operation. RTCs held to satisfy the compliance year portion of this condition may be transferred only after the compliance year for which the RTCs are held. If the initial



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
96

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

or annual hold amount is partially satisfied by holding RTCs that expire midway through the hold period, those RTCs may be transferred upon their respective expiration dates. This hold amount is in addition to any other amount of RTCs required to be held under other condition(s) stated in this permit.

[Rule 2005]

I298.2

This equipment shall not be operated unless the facility holds 1,660 pounds of SO_x RTCs in its allocation account to offset the annual emissions increase for the first year of operation. The RTCs held to satisfy the first year of operation portion of this condition may be transferred only after one year from the initial start of operation. In addition, this equipment shall not be operated unless the operator demonstrates to the Executive Officer that, at the commencement of each compliance year after the start of operation, the facility holds 1,201 pounds of SO_x RTCs valid during that compliance year. RTCs held to satisfy the compliance year portion of this condition may be transferred only after the compliance year for which the RTCs are held. If the initial or annual hold amount is partially satisfied by holding RTCs that expire midway through the hold period, those RTCs may be transferred upon their respective expiration dates. This hold amount is in addition to any other amount of RTCs required to be held under other condition(s) stated in this permit.

[Rule 2005]

K40.3

The operator shall provide to the District a source test report in accordance with the following specifications:

Source test results shall be submitted to the District no later than 60 days after the source tests required under conditions D29.1, D29.2, and D29.3 are conducted.

Emission data shall be expressed in terms of concentration (ppmv) corrected to 15 percent oxygen (dry basis), mass rate (lb/hr), and lb/MMCF. In addition, solid PM emissions, if required to be tested, shall also be reported in terms of grains/DSCF.

All exhaust flow rate shall be expressed in terms of dry standard cubic feet per minute (DSCFM) and dry actual cubic feet per minute. All moisture concentration shall be expressed in terms of percent corrected to 15 percent oxygen.

Source test results shall also include the oxygen levels in the exhaust, fuel flow rate (CFH), the flue gas temperature, and the generator power output (MW) under which the test was conducted.

[Rule 1303(a)(1) – BACT, Rule 1303(b)(2) – Offset]

K67.5

The operator shall keep records in a manner approved by the District, for the following parameter(s) or item(s):

Commissioning hours and type of control and fuel use
Date, time, and duration of each start-up and shutdown



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
97

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

In addition to the requirements of a certified CEMS, natural gas fuel use records shall be kept during and after the commissioning period and prior to CEMS certification
Minute by minute data (NO₂ and O₂ concentration and fuel flow rate at a minimum) for each turbine start up

Total annual power output in MWh

[Rule 1303(b)(2) - Offsets]

SCR CONDITIONS (SIMPLE CYCLE UNIT SCRS)

A195.10

The 5 ppmv NH₃ emission limit is averaged over 60 minutes at 15% O₂, dry basis. The operator shall calculate and continuously record the NH₃ slip concentration using the following:

$$\text{NH}_3 \text{ (ppmv)} = [a - b \cdot (c \cdot 1.2) / 1\text{E}+06] \cdot 1\text{E}+06 / b$$

where,

a = NH₃ injection rate (lbs/hr)/17(lb/lb-mol)

b = dry exhaust gas flow rate (scf/hr)/385.3 scf/lb-mol)

c = change in measured NO_x across the SCR (ppmvd at 15% O₂)

The operator shall install and maintain a NO_x analyzer to measure the SCR inlet NO_x ppmv accurate to plus or minus 5 percent calibrated at least once every twelve months. The NO_x analyzer shall be installed and operated within 90 days of initial start-up.

The operator shall use the above described method or another alternative method approved by the Executive Officer.

The ammonia slip calculation procedures described above shall not be used for compliance determination or emission information without corroborative data using an approved reference method for the determination of ammonia.

[Rule 1303(a)(1) – BACT]

D12.11

The operator shall install and maintain a(n) flow meter to accurately indicate the flow rate of the total hourly throughput of injected ammonia.

The operator shall also install and maintain a device to continuously record the ammonia flow rate. Continuously record shall be defined as recording at least once every hour and shall be calculated based upon the average of the continuous monitoring for that hour. The flow meter shall be accurate to within plus or minus 5 percent. It shall be calibrated once



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
98

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

every 12 months. The injected ammonia rate shall be maintained within 110 lbs/hr and 180 lbs/hr except during start ups and shutdowns

[Rule 1303(a)(1) – BACT]

D12.12

The operator shall install and maintain a(n) temperature gauge to accurately indicate the temperature in the exhaust at the inlet to the SCR reactor.

The operator shall also install and maintain a device to continuously record the exhaust temperature. Continuously record shall be defined as recording at least once every hour and shall be calculated based upon the average of the continuous monitoring for that hour. The temperature gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months. The exhaust temp at the inlet of the SCR shall be maintained between 500-870 deg F except during start up and shutdowns

[Rule 1303(a)(1) – BACT]

D12.13

The operator shall install and maintain a(n) pressure gauge to accurately indicate the differential pressure across the SCR catalyst bed in inches of water column.

The operator shall also install and maintain a device to continuously record the differential pressure. Continuous monitoring shall be defined as measuring at least once every month and shall be calculated based upon the average of the continuous monitoring for that month. The pressure gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months. The differential pressure shall not exceed 3.0 inches WC.

[Rule 1303(a)(1) – BACT]

E193.4

The operator shall upon completion of the construction, operate and maintain this equipment according to the following specifications:

In accordance with all mitigation measures stipulated in the final California Energy Commission decision for the 12-AFC-02C project.

[CEQA]

**CO CATALYST
(SIMPLE CYCLE UNITS CO CATALYST)**

D12.10

The operator shall install and maintain a(n) temperature gauge to accurately indicate the temperature in the exhaust at the inlet to the CO Catalyst.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
99

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

The operator shall also install and maintain a device to continuously record the exhaust temperature. Continuously record shall be defined as recording at least once every hour and shall be calculated based on the average of the continuous monitoring for that hour. The temperature gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months. The exhaust temp at the CO Catalyst inlet shall be maintained at a minimum of 500 deg F except during start up and shutdowns.

[Rule 1303(a)(1) – BACT, Rule 1703]

E193.4

The operator shall upon completion of the construction, operate and maintain this equipment according to the following specifications:

In accordance with all mitigation measures stipulated in the final California Energy Commission decision for the 12-AFC-02C project.

[CEQA]

AMMONIA STORAGE TANK CONDITIONS

E144.1

The operator shall vent this equipment, during filling, only to the vessel from which it is being filled.
[Rule 1303(a)(1)-BACT]

C157.1

The operator shall install and maintain a pressure relief valve set at 50 psig.
[Rule 1303(a)(1)-BACT]

E193.4

The operator shall upon completion of the construction, operate and maintain this equipment according to the following specifications:

In accordance with all mitigation measures stipulated in the final California Energy Commission decision for the 12-AFC-02C project.

[CEQA]

AUXILIARY BOILER CONDITIONS

A63.10



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
100

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

The operator shall limit emission from this equipment as follows:

CONTAMINANT	EMISSION LIMIT
PM10	120 LBS IN ANY ONE MONTH
CO	650 LBS IN ANY ONE MONTH
VOC	87 LBS IN ANY ONE MONTH

The operator shall calculate compliance with the emission limit(s) by using fuel use data and the following emission factors: VOC: 5.47 lbs/mmcf, PM10: 7.54 lbs/mmcf, CO: 41.9 lbs/mmcf.

[Rule 1303 – Offsets]

A195.13

The 5.0 PPMV NOX emission limit(s) is averaged over 60 minutes at 3 percent O₂, dry. This limit shall not apply during boiler start ups.

[Rule 2005]

A195.14

The 50 PPMV CO emission limit(s) is averaged over 60 minutes at 3 percent O₂, dry. This limit shall not apply during boiler start ups.

[Rule 1703-PSD]

C1.13

The operator shall limit the number of start ups to no more than 10 in any one calendar month.

The number of cold start ups shall not exceed 2 per month, the number of warm start ups shall not exceed 4 per month, and the number of hot start ups shall not exceed 4 per month. Additionally, the number of cold start ups shall not exceed 24 per year, the number of warm start ups shall not exceed 48 per year, and the number of hot start ups shall not exceed 48 per year.

For the purposes of this condition: A cold start up is defined as a start up which occurs after the boiler shutdown for 48 hours or more. A cold start up shall not exceed 170 minutes. Emissions during the 170 minutes that includes a cold start up shall not exceed the following: NO_x – 4.22 lbs., CO – 4.34 lbs., VOC – 1.05 lbs.

A warm start up is defined as a start up which occurs after the boiler has been shutdown for 9 – 48 hours. A warm start up shall not exceed 85 minutes. Emissions during the 85 minutes that includes a warm start up shall not exceed the following: NO_x – 2.11 lbs., CO – 2.17 lbs., VOC – 0.52 lbs.

A hot start up is defined as a start up which occurs after the boiler has been shutdown for less than 9 hours. A hot start up shall not exceed 25 minutes. Emissions during the 25 minutes that includes a hot start up shall not exceed the following: NO_x – 0.62 lbs., CO – 0.64 lbs., VOC – 0.15 lbs.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
101

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

The beginning of a start up occurs at initial fire in the burner and the end of start up occurs when the BACT levels are achieved. If during start up the process is aborted the process will count as one start up.

The operator shall maintain records, in a manner approved by the SCAQMD to demonstrate compliance with this condition.

[Rule 2005]

C1.14

The operator shall limit the heat input to no more than 189,155 mmbtu in any one calendar year.

The limit includes normal operation as well as start ups and shutdowns. The heat input shall be calculated using the fuel use data and a natural gas HHV of 1,050 btu/mmcf.

The operator shall maintain records, in a manner approved by the SCAQMD to demonstrate compliance with this condition.

[Rule 2005]

D29.8

The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant to be tested	Required Test Method(s)	Averaging Time	Test Location
NOX emissions	District Method 100.1	1 hour	Outlet of the SCR
CO emissions	District Method 100.1	1 hour	Outlet of the SCR
PM10 emissions	District Method 5.1	District approved averaging time	Outlet of the SCR
NH3 emissions	District Method 207.1 and 5.3 or EPA Method 17	1 hour	Outlet of the SCR
PM2.5	EPA method 201A and 202	District approved averaging time	Outlet of the SCR

The test shall be conducted after SCAQMD approval of the source test protocol, but no later than 180 days after initial start-up. The SCAQMD shall be notified of the date and time of the test at least 10 days prior to the test.

The test shall be conducted when this equipment is operating at 100 percent, 50 percent, and minimum load.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
102

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

The test shall be conducted to determine the oxygen levels in the exhaust. In addition, the tests shall measure the fuel flow rate (CFH), and the flue gas flow rate.

The test shall be conducted in accordance with an SCAQMD approved test protocol. The protocol shall be submitted to the SCAQMD engineer no later than 45 days before the proposed test date and shall be approved by the SCAQMD before the test commences.

The test protocol shall include the proposed operating conditions of the boiler during the tests, the identity of the testing lab, a statement from the testing lab certifying that it meets the criteria of Rule 304, and a description of all sampling and analytical procedures.

[Rule 1303(a)(1) – BACT, Rule 1303(b)(2) – Offset, Rule 1703-PSD, Rule 2005]

D29.9

The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant to be tested	Required Test Method(s)	Averaging Time	Test Location
CO emissions	District Method 100.1	1 hour	Outlet of the SCR

The test shall be conducted at least once every three years, or in accordance with the schedule specified in Rule 1146.

The test shall be conducted and the results submitted to the SCAQMD within 60 days after the test date. The SCAQMD shall be notified of the date and time of the test at least 10 days prior to the test.

The test shall be conducted when this equipment is operating at 100 percent of maximum load.

In addition to the Method 100.1 test, the operator shall also perform periodic CO emissions tests on the boiler with a portable analyzer in accordance with the schedule and specifications outlined in Rule 1146.

[Rule 1146]

D82.5

The operator shall install and maintain a CEMS to measure the following parameters:

NO_x concentration in ppmv

Concentrations shall be corrected to 15 percent oxygen on a dry basis. The CEMS shall be installed and operating no later than 90 days after initial startup of the boiler, in accordance



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
103

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

with approved SCAQMD REG XX CEMS plan application. The operator shall not install the CEMS prior to receiving initial approval from SCAQMD.

Rule 2012 provisional RATA testing shall be completed and submitted to the SCAQMD within 90 days of the conclusion of the combined cycle turbine commissioning and boiler construction period. During the interim period between the initial start up and the provisional certification date of the CEMS, the operator shall comply with the requirements of Rule 2012(h)(2) and 2012(h)(3).

[Rule 1703 – PSD, Rule 2005, Rule 2012]

E193.4

The operator shall upon completion of the construction, operate and maintain this equipment according to the following specifications:

In accordance with all mitigation measures stipulated in the final California Energy Commission decision for the 12-AFC-02C project.

[CEQA]

I297.3

This equipment shall not be operated unless the facility holds 1,313 pounds of NO_x RTCs in its allocation account to offset the annual emissions increase for the first year of operation. The RTCs held to satisfy the first year of operation portion of this condition may be transferred only after one year from the initial start of operation. RTCs held to satisfy the compliance year portion of this condition may be transferred only after the compliance year for which the RTCs are held. If the initial or annual hold amount is partially satisfied by holding RTCs that expire midway through the hold period, those RTCs may be transferred upon their respective expiration dates. This hold amount is in addition to any other amount of RTCs required to be held under other condition(s) stated in this permit.

[Rule 2005]

I298.3

This equipment shall not be operated unless the facility holds 382 pounds of SO_x RTCs in its allocation account to offset the annual emissions increase for the first year of operation. The RTCs held to satisfy the first year of operation portion of this condition may be transferred only after one year from the initial start of operation. In addition, this equipment shall not be operated unless the operator demonstrates to the Executive Officer that, at the commencement of each compliance year after the start of operation, the facility holds 360 pounds of SO_x RTCs valid during that compliance year. RTCs held to satisfy the compliance year portion of this condition may be transferred only after the compliance year for which the RTCs are held. If the initial or annual hold amount is partially satisfied by holding RTCs that expire midway through the hold period, those RTCs may be transferred upon their respective expiration dates. This hold amount is in addition to any other amount of RTCs required to be held under other condition(s) stated in this permit.

[Rule 2005]



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
104

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

**SCR CONDITIONS
(AUXILAIRY BOILER SCR)**

A195.10

The 5 ppmv NH₃ emission limit is averaged over 60 minutes at 15% O₂, dry basis. The operator shall calculate and continuously record the NH₃ slip concentration using the following:

$$\text{NH}_3 \text{ (ppmv)} = [a - b \cdot (c \cdot 1.2) / 1\text{E}+06] \cdot 1\text{E}+06 / b$$

where,

a = NH₃ injection rate (lbs/hr)/17(lb/lb-mol)

b = dry exhaust gas flow rate (scf/hr)/385.3 scf/lb-mol)

c = change in measured NO_x across the SCR (ppmvd at 15% O₂)

The operator shall install and maintain a NO_x analyzer to measure the SCR inlet NO_x ppmv accurate to plus or minus 5 percent calibrated at least once every twelve months. The NO_x analyzer shall be installed and operated within 90 days of initial start-up.

The operator shall use the above described method or another alternative method approved by the Executive Officer.

The ammonia slip calculation procedures described above shall not be used for compliance determination or emission information without corroborative data using an approved reference method for the determination of ammonia.

[Rule 1303(a)(1) – BACT]

D12.14

The operator shall install and maintain a(n) flow meter to accurately indicate the flow rate of the total hourly throughput of injected ammonia.

The operator shall also install and maintain a device to continuously record the ammonia flow rate. Continuously record shall be defined as recording at least once every hour and shall be calculated based upon the average of the continuous monitoring for that hour. The flow meter shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months. The injected ammonia rate shall be maintained within 1.0 lbs/hr and 3.9 lbs/hr except during start ups and shutdowns

[Rule 1303(a)(1) – BACT]

D12.15

The operator shall install and maintain a(n) temperature gauge to accurately indicate the temperature in the exhaust at the inlet to the SCR reactor.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
105

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

The operator shall also install and maintain a device to continuously record the exhaust temperature. Continuously record shall be defined as recording at least once every hour and shall be calculated based upon the average of the continuous monitoring for that hour. The temperature gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months. The exhaust temperature shall be maintained between 406-636 deg F except during start ups and shutdowns

[Rule 1303(a)(1) – BACT]

D12.16

The operator shall install and maintain a(n) pressure gauge to accurately indicate the differential pressure across the SCR catalyst bed in inches of water column.

The operator shall also install and maintain a device to continuously record the differential pressure. Continuous monitoring shall be defined as measuring at least once every month and shall be calculated based upon the average of the continuous monitoring for that month. The pressure gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months. The differential pressure shall not exceed 2.0 inches WC.

[Rule 1303(a)(1) – BACT]

E193.4

The operator shall upon completion of the construction, operate and maintain this equipment according to the following specifications:

In accordance with all mitigation measures stipulated in the final California Energy Commission decision for the 12-AFC-02C project.

[CEQA]



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
106

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

**Huntington Beach Energy Project
List of Appendices**

1. Appendix A – Combined Cycle Turbine Criteria Pollutant Emission Calculations
 - Normal Operation
 - Start Up Emissions
 - Shutdown Emission
 - Maximum Hourly
 - Maximum Daily Emissions
 - 30- Day Average Emissions
 - Annual Emission
2. Appendix B – Simple Cycle Turbine Criteria Pollutant Emission Calculations
 - Normal Operation
 - Start Up Emissions
 - Shutdown Emission
 - Maximum Hourly
 - Maximum Daily Emissions
 - 30- Day Average Emissions
 - Annual Emissions
3. Appendix C – Commissioning Calculations
 - Commissioning Emissions Combined Cycle Turbines
 - Commissioning Emissions Simple Cycle Turbines
 - Annual Facility Emissions Including Commissioning
 - Monthly Facility Emissions Including Commissioning
4. Appendix D – Auxiliary Boiler Criteria Pollutant Emission Calculations
 - Normal Operation
 - Start Up Emissions
 - Maximum Hourly
 - Maximum Daily Emissions
 - 30- Day Average Emissions
 - Annual Emission
5. Appendix E – Air Toxics Emission Calculations
 - Combined Cycle Turbines
 - Simple Cycle Turbines
 - Auxiliary Boiler
6. Appendix F – Oil Water Separator Calculations
7. Appendix G – Existing Boiler’s Actual Emissions



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
107

APPL NO.
See Below


PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

8. Appendix H - Modeling
9. Appendix I – GHG Calculations
 - Combined Cycle Turbines
 - Simple Cycle Turbines
 - Auxiliary Boiler
10. Appendix J – Facility Plot Plan
11. Appendix K – Plant Elevation Views
12. Appendix L – Process Flow
13. Appendix M – Nearest Schools
14. Appendix N– Existing Facility Reported Emissions
15. Appendix O – Major Source Determinations
16. Appendix P – Reclaim NOx Reporting Factor
17. Appendix Q – Existing Boilers Historical Power Generation
18. Appendix R – Fees
19. Appendix S – RECLAIM Trading Credit Requirement
20. Appendix T – Review of BACT Levels for Recent Projects
21. Appendix U – Modeling Review Memo

	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 108	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

Appendix A

Combined Cycle Turbine Criteria Pollutant Emission Calculations

Normal Operation

➤ Table A.1 Manufacturer Guaranteed Emissions CCTG

Pollutant	Guarantee
NO _x	2.0 ppm @ 15%
CO	2.0 ppm @ 15%
VOC	2.0 ppm @ 15%
PM ₁₀	See note below
SO _x	See note below
NH ₃	5 ppm @ 15%

The manufacturer guarantee for PM₁₀ is 10.2 lbs/hr, which includes 6.7 lbs/hr from the combustion turbine. AES provided a (total) PM₁₀ emission rate of 8.5 lbs/hr.

There is no manufacturer guarantee for SO_x. AES based short term (lbs/hr, lbs/day and lbs/month) SO_x emissions on 12 ppm sulfur in the natural gas (0.75 gr/100 scf), and long term (annual) SO_x on 4 ppm sulfur (0.25 gr/100 scf).



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
109

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table A.2 Combined Cycle Gas Turbine Performance Data

Ambient Conditions	110°F, 8% RH	65.8°F, 58% RH	32°F, 87% RH
Fuel Type	Nat Gas	Nat Gas	Nat Gas
Evaporative Cooling On/Off	On	On	Off
O2 Percent	13.97	13.60	13.82
H2O Percent	5.97	5.87	5.20
Exhaust Temp, °F	221	213	216
Gross Heat Rate, btu/kWh (HHV)	9,833	9,687	9,628
Turbine Heat Input, mmbtu/hr (HHV)	2,123	2,248	2,273
Turbine Fuel Use, mmscf/hr	2.03	2.15	2.16
Stack Exhaust Flow, 10 ³ acfm	1250.8	1244.4	1261.9
Stack Exhaust Flow, ft ³ /hr (dry, @15%O ₂)	63,554,099	66,563,346	66,321,830
Gross Output, MW (1 CTG)	215.890	232.073	236.140
Net Output, MW (1 CTG)	215.152	231.335	235.402
	NO_x		
Concentration, ppmv dry, @ 15% O ₂	2.0	2.0	2.0
Hourly Emissions, lb/hr	15.48	16.39	16.48
Daily Emissions, lb/day	371.5	393.4	395.5
lbs/mmcf	7.63	7.63	7.63
lbs/mmbtu	0.0073	0.0073	0.0073
lbs/gross MW-hr (1 CTG)	0.072	0.071	0.070
Lbs/net MW-hr (1 CTG)	0.072	0.071	0.070
	CO		
Concentration, ppmv @ 15% O ₂	2.0	2.0	2.0
Hourly Emissions, lb/hr	9.42	9.98	10.03
Daily Emissions, lb/day	226.1	239.5	240.7
lbs/mmcf	4.64	4.64	4.64
lbs/mmbtu	0.0044	0.0044	0.0044
	VOC		
Concentration, ppmv, @ 15% O ₂	2.0	2.0	2.0
Hourly Emissions, lb/hr	5.40	5.72	5.75
Daily Emissions, lb/day	129.6	137.3	138.0
lbs/mmcf	2.66	2.66	2.66
lbs/mmbtu	0.0025	0.0025	0.0025



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
110

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table A.2 Combined Cycle Gas Turbine Performance Data (continued)

Ambient Conditions	110°F, 7.9% RH	65.8°F, 65% RH	32°F, 86.7% RH
Fuel Type	Nat Gas	Nat Gas	Nat Gas
Evaporative Cooling On/Off	On	On	Off
O2 Percent	13.97	13.60	13.82
H2O Percent	5.97	5.87	5.20
Exhaust Temp, °F	221	213	216
Gross Heat Rate (HHV)	9,833	9,687	9,628
Turbine Heat Input, mmbtu/hr (HHV)	2,123	2,248	2,273
Turbine Fuel Use, mmscf/hr	2.03	2.15	2.16
Stack Exhaust Flow, dscfm	1250.8	1244.4	1261.9
Stack Exhaust Flow, ft3/hr (dry, @ 15%O2)	63,554,099	66,563,346	66,321,830
Gross Output, MW (1 CTG)	215.890	232.073	236.140
Net Output, MW (1 CTG)	215.152	231.335	235.402
	SOX		
Concentration, ppmv, @ 15% O2	0.37	0.36	0.36
Hourly Emissions, lb/hr	4.60	4.81	4.86
Daily Emissions, lb/day	110.4	115.54	116.64
lbs/mmcf	2.27	2.24	2.25
lbs/mmbtu	0.0022	0.0021	0.0021
	PM10		
Hourly Emissions, lb/hr	8.50	8.50	8.50
Daily Emissions, lb/day	204	204	204
lbs/mmcf	4.19	3.95	3.94
lbs/mmbtu	0.0040	0.0038	0.0037
	NH3		
Concentration, ppm	5	5	5
Hourly Emissions, lb/hr	14.0	14.7	14.6
Daily Emissions, lb/day	336.8	352.7	351.4

Exhaust gas calculation:

$$\begin{aligned}
 1250.8(1-.0597)(520/221+460) &= 898.1E+3 \text{ cfm, dry @ stack O}_2 \\
 898.1E+3*[(20.9-13.97)/(20.9-15)] &= 1054.9E+3 \text{ dscfm} = 63.554 \text{ mmscfh}
 \end{aligned}$$

Emission Rates Normal Operation

The following calculation procedure will be used to estimate the highest hourly emission rate (low temperature case) during normal operation. Although the following emissions may differ from what is reported by AES and reflected in Table A.2, the calculations below are based on a standard F factor methodology. Also note



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
111

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

that the average hourly emission rate (annual average temperature case) is essentially the same since the maximum and average heat input and exhaust rates differ by less than 1%.

Heat Input @ 32 deg F	=	2273 mmbtu/hr		
Exhaust flow @ 32 deg F	=	2273*8710*3.54	=	70.1 mmscf/hr
Fuel use @ 32 deg F	=	2273/1050	=	2.16 mmscf/hr

Table A.3 Maximum Hourly Emissions CCTG

Pollutant	Concentration	Mass Emission Rate
	ppm	lbs/hr
NO _x ⁽¹⁾	9.0/2.0	75.4/16.8
CO ⁽¹⁾	10.0/2.0	51.0/10.2
VOC	2.0	5.8
PM ₁₀	////////	8.5
SO _x	0.75 gr/100 scf fuel	4.6
NH ₃	5.0	15.5

(1) with DLN only/DLN + SCR & CO Catalyst

Sample Calculations:

NO_x (2.0 ppm*70.1 mmscf/hr*46 lbs/lb-mole)/385 cf/lb-mole = 16.8 lbs/hr
DLN+SCR

SO_x calculation:

0.75 grains/100 scf fuel converts to SO_x per mmscf fuel as follows: 0.75 grains/ 100 scf(lb/7000 grains)(64 lbs/lb-mole SO₂/32 lbs/lb-mole S)(1E6 cf/mmscf) = 2.14 lbs SO₂/mmscf fuel.

SO_x (2.14 lbs SO₂/mmscf)*2.16 mmscf = 4.6 lbs/hr

Start Up Operation

There are 3 basic types of starts – cold, and warm and hot. A cold start up is defined as a start of the CT that occurs when the system is at ambient temperature, which would typically occur after a period of 48 hours or more from the last shutdown. Dry Low NO_x (DLN) combustors will reduce NO_x to 9 ppm within 10 minutes, and the SCR will become functional within about 30 minutes. Typically, the BACT emission levels will be achieved within 60 minutes from the beginning of a cold start.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
112

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

A warm start occurs after a shutdown lasting between 10 to 48 hours, and a hot start occurs after a shutdown of less than 10 hours. Both warm and hot starts will take about 30 minutes to complete.

The turbines can be shutdown in 30 minutes.

AES anticipates up to 15 cold, 12 warm, and 35 hot starts per month, and 80 cold, 88 warm, and 332 hot starts of the combined cycle turbines per year, with a maximum of 2 starts per day.

Following is a break down of emissions during start up operations.

Table A.4 Combined Cycle Cold Start Emissions Data

Pollutant	Time, minutes	Inlet, lbs/hr	Inlet Total, lbs	Reduction, %	Total Outlet, lbs
NOx	0-10	64	11	0	11
	10-20	95	16	0	16
	20-30	75	13	0	13
	30-40	75	13	56	6
	40-50	75	13	68	4
	50-60	75	13	80	3
TOTAL					61
CO	0-10	738	123	24	93
	10-20	1351	225	28	162
	20-30	59	10	40	6
	30-40	59	10	60	4
	40-50	59	10	72	3
	50-60	59	10	80	2
TOTAL					325
VOC	0-10	84	14	15	12
	10-20	127	21	18	17
	20-30	5	0.8	25	0.6
	30-40	5	0.8	38	0.5
	40-50	5	0.8	45	0.4
	50-60	5	0.8	50	0.4
TOTAL					36

Totals include an engineering margin



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
113

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table A.5 Combined Cycle Warm/Hot Start Emissions Data

Pollutant	Time, minutes	Inlet, lbs/hr	Inlet Total, lbs	Reduction, %	Total Outlet, lbs
NOx	0-10	64	11	32	7
	10-20	95	16	72	4
	20-30	75	13	80	3
TOTAL					17
CO	0-10	738	123	60	49
	10-20	1351	225	72	63
	20-30	59	10	80	2
TOTAL					137
VOC	0-10	84	14	38	9
	10-20	127	21	45	12
	20-30	5.3	0.9	50	0.4
TOTAL					25

Totals include an engineering margin

Shut Down Operation

A shutdown is expected to take about 30 minutes to complete. Following is a summary of the estimated emissions during a shutdown as provide by AES.

Table A.6 Combined Cycle Shutdown Emissions Data

Pollutant	Time, minutes	Inlet, lbs/hr	Inlet Total, lbs	Reduction, %	Total Outlet, lbs
NOx	0-10	53	9	80	2
	10-20	17	3	80	0.6
	20-30	100	17	43	6
TOTAL					10
CO	0-10	1531	255	80	51
	10-20	1092	182	80	36
	20-30	439	73	68	23
TOTAL					133
VOC	0-10	128	21	50	11
	10-20	168	28	50	14
	20-30	21	3	47	2
TOTAL					32

Totals include an engineering margin



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
114

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table A.7 Start Up/Shutdown Emissions Per CCTG Turbine, Summary

Pollutant	Cold Start, 60 minutes	Warm Start, 30 minutes	Hot Start, 30 minutes	Shutdown
	Lbs/event	Lbs/event	Lbs/event	Lbs/event
NO _x	61	17	17	10
CO	325	137	137	133
VOC	36	25	25	32

Daily Emissions

Daily emissions are calculated assuming the following emission rates per turbine:

Table A.8 Maximum Emission Rates (1 CCTG)

	NO _x	CO	VOC	PM10	SO _x	NH ₃
Normal Operations Controlled (lbs/hr)	16.8	10.2	5.8	8.5	4.6	15.5
Normal Operations Uncontrolled (lbs/hr)	75.4	51.0	5.8	8.5	4.6	0
Cold Start (total lbs)	61.0	325.0	36.0	8.5	4.6	0
Warm Start (total lbs)	17.0	137.0	25.0	4.25	2.3	0
Hot Start (total lbs)	17.0	137.0	25.0	4.25	2.3	0
Shutdown (total lbs)	10.0	133.0	32.0	4.25	2.3	0

Uncontrolled emission rates based on DLN without SCR, NO_x=9 ppm, CO=10 ppm, VOC=2 ppm

Daily emissions are calculated on a per turbine basis for 2 potential operating scenarios. The first assumes 1 cold start, 1 hot start, 2 shutdowns and the remaining hours of the day at full load, and the second assumes 24 hrs at full load operation.

Table A.9 Controlled Daily Emissions (1 CCTG)

	Duration	Emissions, lbs					NH3
		NOx	CO	VOC	PM10	SOx	
Scenario 1							
Cold Start	1	61.0	325.0	36.0	8.5	4.6	0
Normal Operation	20.5	344.4	209.1	118.9	174.25	94.3	317.75
Shutdown (2)	1	20.0	266.0	64.0	8.5	4.6	0
Downtime	1	0	0	0	0	0	0
Hot Start (1)	0.5	17.0	137.0	25.0	4.25	2.3	0
TOTAL	24	442.4	937.1	243.9	195.5	105.8	317.75
Scenario 2							
Normal Operation	24	403.2	244.8	139.2	204	110.4	317.75



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
115

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table A.10 Uncontrolled Daily Emissions (1 CCTG)

		Emissions, lbs					
		Duration	NOx	CO	VOC	PM10	
Scenario 1							
Cold Start	1	61.0	325.0	36.0	8.5	4.6	0
Normal Operation	20.5	1545.7	1045.5	118.9	174.25	94.3	0
Shutdown (2)	1	20.0	266.0	64.0	8.5	4.3	0
Downtime	1	0	0	0	0	0	0
Hot Start (1)	0.5	17.0	137.0	25.0	4.25	2.3	0
TOTAL	24	1643.7	1773.5	243.9	195.5	105.8	0
Scenario 2							
Normal Operation	24	1809.6	1224	139.2	204	110.4	0

Table A.11 Maximum Controlled/Uncontrolled Daily Emissions (1 CCTG)

Pollutant	Operating Scenario	Uncontrolled Daily Emissions	Controlled Daily Emissions
NOx	See Below	1809.6	442.4
CO	1 cold, 1 hot, 2 shutdowns, 20.5 hours normal	1773.5	937.1
VOC	24 hr normal	243.9	243.9
PM10	24 hr normal	204	204
SOx	24 hr normal	110.4	110.4
NH3	24 hr normal	//////////	317.8

For NOx, the maximum uncontrolled emissions result from the 24 hr normal operation scenario, while the maximum controlled emissions result from the 1 cold, 1 hot, 2 shutdown scenario.

Monthly Emissions

Table A.12 Maximum Monthly Operation CCTG

Event	# Per Month	Duration/event	Duration/month, hrs
Cold Start	15	1 hour	15
Warm Start	12	30 minutes	6
Hot Start	35	30 minutes	17.5
Shutdown	62	30 minutes	31
100% Load @ 65.8 deg F	//////////	//////////	674.5
		Total Hrs	744



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
116

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Monthly emissions and the 30 Day Averages are calculated for 2 scenarios, one assuming the maximum starts and shutdowns are based on the above operating profile, and the second assuming no start ups or shutdowns. The following factors are used:

Table A.13 Emission Factors for 30 Day Calculation CCTG

Event	Lbs/hr or lbs/event					
	NOx	CO	VOC	PM10	SOx	NH3
Cold Start	61.0	325.0	36.0	8.5	4.6	0
Warm Start	17.0	137.0	25.0	4.25	2.3	0
Hot Start	17.0	137.0	25.0	4.25	2.3	0
Shutdown	10.0	133.0	32.0	4.25	2.3	0
Normal @ 65.8 deg	16.8	10.2	5.8	8.5	4.6	15.5

Table A.14 30 Day Emissions /Scenario 1/ Start Ups and Shut Downs (1 CCTG)

Event	Duration, hrs/month	# of events	Emissions					
			NOx	CO	VOC	PM10	SOx	NH3
Cold	15	15	915	4875	540	127.5	69	0
Warm	6	12	204	1644	300	51	27.6	0
Hot	17.5	35	595	4795	875	148.8	80.5	0
Shutdown	31	62	620	8246	1984	263.5	142.6	0
Normal @ 65.8 deg	674.5	//////	11331.6	6879.9	3912.1	5733.3	3102.7	10454.8
Total, lbs/month			13665.6	26439.9	7611.1	6324	3422.4	10454.75
Average lbs/day			455.5	881.3	253.7	210.8	114.1	348.5

Table A.15 30 Day Emissions /Scenario 2/ No Starts (1 CCTG)

Event	Duration, hrs/month	# of events	Emissions					
			NOx	CO	VOC	PM10	SOx	NH3
Normal @ 65.8 deg	744	//////	12499.2	7588.8	4315.2	6324	3422.4	11532
Total, lbs/month			12499.2	7588.8	4315.2	6324	3422.4	11532
Average lbs/day			416.6	253.0	143.8	210.8	114.1	384.4


	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 117	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

Table A.16 30 Day Emissions (1 CCTG)

Pollutant	Operating Scenario	Total Monthly Emissions	30-Day Average Emissions
NOx	15 cold starts+12 warm starts+35 hot starts+62 shutdowns+674.5 hrs normal	13,665.6	455.5
CO	15 cold starts+12 warm starts+35 hot starts+62 shutdowns+674.5 hrs normal	26,439.9	881.3
VOC	15 cold starts+12 warm starts+35 hot starts+62 shutdowns+674.5 hrs normal	7,611.1	253.7
PM10	744 hrs normal	6,324	210.8
SOx	744 hrs normal	3,422.4	114.1

Annual Emissions

Table A.17 Maximum Annual Operation CCTG

Event	# Per Year	Duration/event	Duration/yr, hrs
Cold Start	80	1 hour	80
Warm Start	88	30 minutes	44
Hot Start	332	30 minutes	166
Shutdown	500	30 minutes	250
100% Load @ 65.8 deg F	////////////////	////////////////	6100
		Total Hrs	6640

Annual emissions for the combined cycle plant are calculated assuming the following emission rates per turbine:

Table A.18 Combined Cycle Emission Rates (annual basis)

	NOx	CO	VOC	PM10	SOx	NH3
Normal Operations Controlled (lbs/hr)	16.8	10.2	5.8	8.5	1.5	15.5
Cold Start (total lbs)	61.0	325.0	36.0	8.5	1.5	0
Warm Start (total lbs)	17.0	137.0	25.0	4.25	0.75	0
Hot Start (total lbs)	17.0	137.0	25.0	4.25	0.75	0
Shutdown (total lbs)	10.0	133.0	32.0	4.25	0.75	0

SOx for annual emissions is based on 0.25 gr/100 scf:

0.25 grains/100 scf fuel converts to SOx per mmcf fuel as follows: 0.25 grains/ 100 scf(lb/7000 rains)(64 lbs/lb-mole SO2/32 lbs/lb-mole S)(1E6 cf/mmcf) = 0.71 lbs SO2/mmcf fuel.

$$\text{SOx} \quad (0.71 \text{ SO}_2/\text{mmscf}) * 2.16 \text{ mmscf} \quad = \quad 1.5 \text{ lbs/hr}$$



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
118

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table A.19 Combined Cycle Annual Emissions, Non-Commissioning Year

Operating Mode	Emissions Per Turbine, lbs					
	NOx	CO	VOC	PM10	SOx	NH3
Cold Starts	4880	26000	2880	680	120	0
Warm Starts	1496	12056	2200	374	66	0
Hot Starts	5644	45484	8300	1411	249	0
Shutdowns	5000	66500	16000	2125	375	0
Normal Operation	102480	62220	35380	51850	9150	94550
TOTAL 1 TURBINE	119500	212260	64760	56440	9960	94550
TOTAL 2 TURBINES	239000	424520	129520	112880	19920	189100

Sample Calcs:

NOx cold starts = 61 lbs/start * 80 starts/yr = 4880 lbs

PM10 warm starts = 4.25 lbs/start * 88 starts/yr = 374 lbs

SOx normal operation = 1.5 lbs/hr * 6100 hrs/yr = 9150 lbs



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
119

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Appendix B

Simple Cycle Turbine Criteria Pollutant Emission Calculations

Normal Operation

➤ Table B.1 Manufacturer Guaranteed Emissions SCTG

Pollutant	Guarantee
NO _x	2.5 ppm @ 15%
CO	4.0 ppm @ 15%
VOC	2.0 ppm @ 15%
PM ₁₀	See note below
SO _x	See note below
NH ₃	5 ppm @ 15%

The manufacturer guarantee for PM₁₀ is 5 lbs/hr, AES provided a (total) PM₁₀ emission rate of 6.24 lbs/hr.

There is no manufacturer guarantee for SO_x. AES based short term (lbs/hr, lbs/day and lbs/month) SO_x emissions on 12 ppm sulfur in the natural gas (0.75 gr/100 scf), and long term (annual) SO_x on 4 ppm sulfur (0.25 gr/100 scf).



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
120

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table B.2 Simple Cycle Gas Turbine Performance Data

Ambient Conditions	110°F, 8% RH	65.8°F, 58% RH	32°F, 87% RH
Fuel Type	Nat Gas	Nat Gas	Nat Gas
Evaporative Cooling On/Off	On	On	Off
O2 Percent	14.05	14.00	14.23
H2O Percent	5.90	5.64	4.98
Exhaust Temp, °F	848	794	789
Gross Heat Rate, btu/kWh (HHV)	9,504	8,781	8,765
Turbine Heat Input, mmbtu/hr (HHV)	737	885	880
Turbine Fuel Use, mmscf/hr	0.702	0.843	0.838
Stack Exhaust Flow, 10 ³ acfm	829.8	941.4	938.2
Stack Exhaust Flow, ft ³ /hr (dry, @15%O ₂)	9,425,136	11,942,847	13,301,563
Gross Output, MW (1 CTG)	77.501	100.814	100.393
Net Output, MW (1 CTG)	76.041	99.355	98.934
	NO_x		
Concentration, ppmv dry, @ 15% O ₂	2.5	2.5	2.5
Hourly Emissions, lb/hr	6.89	8.29	8.24
Daily Emissions, lb/day	165.4	199.0	197.8
lbs/mmcf	9.81	9.83	9.83
lbs/mmbtu	0.0093	0.0094	0.0094
lbs/gross MW-hr (1 CTG)	0.089	0.082	0.082
Lbs/net MW-hr (1 CTG)	0.091	0.083	0.083
	CO		
Concentration, ppmv @ 15% O ₂	4.0	4.0	4.0
Hourly Emissions, lb/hr	6.72	8.07	8.02
Daily Emissions, lb/day	161.3	193.7	192.5
lbs/mmcf	9.57	9.57	9.57
lbs/mmbtu	0.0091	0.0091	0.0091
	VOC		
Concentration, ppmv, @ 15% O ₂	2.0	2.0	2.0
Hourly Emissions, lb/hr	1.92	2.31	2.30
Daily Emissions, lb/day	46.1	55.4	55.2
lbs/mmcf	2.74	2.74	2.74
lbs/mmbtu	0.0026	0.0026	0.0026


	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 121	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

Table B.2 Simple Cycle Gas Turbine Performance Data (continued)

Ambient Conditions	110°F, 7.9% RH	65.8°F, 65% RH	32°F, 86.7% RH
Fuel Type	Nat Gas	Nat Gas	Nat Gas
Evaporative Cooling On/Off	On	On	Off
O2 Percent	14.05	14.00	14.23
H2O Percent	5.90	5.64	4.98
Exhaust Temp, °F	848	794	789
Gross Heat Rate (HHV)	9,504	8,781	8,765
Turbine Heat Input, mmbtu/hr (HHV)	737	885	880
Turbine Fuel Use, mmscf/hr	0.702	0.843	0.838
Stack Exhaust Flow, dscfm	829.8	941.4	938.2
Stack Exhaust Flow, ft3/hr (dry, @15%O2)	9,425,136	11,942,847	13,301,563
Gross Output, MW (1 CTG)	77.501	100.814	100.393
Net Output, MW (1 CTG)	76.041	99.355	98.934
	SOX		
Concentration, g/100scf fuel	0.75	0.75	0.75
Hourly Emissions, lb/hr	0.96	1.16	1.15
Daily Emissions, lb/day	23.0	27.8	27.6
lbs/mmcf	1.40	1.69	1.68
lbs/mmbtu	0.0013	0.0013	0.0013
	PM10		
Hourly Emissions, lb/hr	5.92	6.24	6.24
Daily Emissions, lb/day	142.1	149.8	149.8
lbs/mmcf	8.43	7.40	7.45
lbs/mmbtu	0.0080	0.0071	0.0071
	NH3		
Concentration, ppm	5	5	5
Hourly Emissions, lb/hr	5.1	6.14	6.10
Daily Emissions, lb/day	122.4	147.4	146.4

Exhaust gas calculation:

$$\begin{aligned}
 938.2(1-.0498)(520/789+460) &= 196.1E+3 \text{ cfm, dry @ stack O}_2 \\
 196.1E+3*[(20.9-14.23)/(20.9-15)] &= 221.7E+3 \text{ dscfm} = 13.3 \text{ mmscfh}
 \end{aligned}$$

Emission Rates Normal Operation

The following calculation procedure will be used to estimate the highest hourly emission rate (average temperature case) during normal operation. Although the following emissions may differ from what is reported by AES and reflected in Table B.2, the calculations below are based on a standard F factor methodology.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
122

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Heat Input @ 65.8 deg F	=	885 mmbtu/hr		
Exhaust flow @ 65.8 deg F	=	885*8710*3.54	=	27.3 mmscf/hr
Fuel use @ 65.8 deg F	=	885/1050	=	0.84 mmscf/hr

Table B.3 Maximum Hourly Emissions SCTG

Pollutant	Concentration ppm	Mass Emission Rate lbs/hr
NO _x ⁽¹⁾	25/2.5	82.0/8.2
CO ⁽¹⁾	100/4.0	198.5/7.9
VOC	2.0	2.3
PM10	////////	6.24
SO _x	////////	1.80
NH3	5.0	6.0

(2) with DLN only/DLN + SCR & CO Catalyst

Sample Calculations:

NO_x (2.5 ppm*27.3 mmscf/hr*46 lbs/lb-mole)/385 cf/lb-mole = 8.2 lbs/hr
DLN+SCR

SO_x calculation:

0.75 grains/100 scf fuel converts to SO_x per mmscf fuel as follows: 0.75 grains/ 100 scf(lb/7000 rains)(64 lbs/lb-mole SO₂/32 lbs/lb-mole S)(1E6 cf/mmscf) = 2.02 lbs SO₂/mmscf fuel.

SO_x (2.14 SO₂/mmscf)*0.843 mmscf = 1.80 lbs/hr

Start Up Operation

A start up for the simple cycle turbines lasts 30 minutes, and a shutdown lasts 13 minutes.

AES anticipates up to 62 starts per month, and 350 starts of the simple cycle turbines per year, with a maximum of 2 starts per day.

Following is a break down of emissions during start up operations.

Table B.4 Simple Cycle Turbine Start Up Emissions Data



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
123

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Pollutant	Time, minutes	Inlet, lbs/hr	Inlet Total, lbs	Reduction, %	Total Outlet, lbs
NOx	0-10		4.94	0	4.94
	10-20	82	13.7	45	7.52
	20-30	82	13.7	90	1.37
TOTAL					16.6
CO	0-10		31.67	80	6.34
	10-20	485	80.8	96	3.25
	20-30	485	80.8	96	3.25
TOTAL					15.4
VOC	0-10		1	42	0.58
	10-20	10.5	1.75	50	0.88
	20-30	10.5	01.75	50	0.88
TOTAL					2.8

Totals include an engineering margin

Shut Down Operation

A shutdown is expected to take about 13 minutes to complete. Following is a summary of the estimated emissions during a shutdown as provide by AES.

Table B.5 Simple Cycle Turbine Shutdown Emissions Data

Pollutant	Time, minutes	Inlet Total, lbs	Reduction, %	Total Outlet, lbs
NOx	0-13	5.67	45	3.12
CO	0-13	54.01	48	28.09
VOC	0-13	4.08	25	3.06

Totals include an engineering margin

Table B.6 Start Up/Shutdown Emissions Per SCTG Turbine, Summary

Pollutant	Start Up, 30 minutes	Shutdown, 13 Minutes
	Lbs/event	Lbs/event
NOx	16.6	3.12
CO	15.4	28.09
VOC	2.8	3.06

Daily Emissions

Daily emissions are calculated assuming the following emission rates per turbine:



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
124

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table B.7 Maximum Emission Rates (1 SCTG)

	NO _x	CO	VOC	PM ₁₀	SO _x	NH ₃
Normal Operations Controlled (lbs/hr)	8.2	7.9	2.3	6.24	1.80	6.0
Normal Operations Uncontrolled (lbs/hr)	82.0	198.5	2.3	6.24	1.80	0
Start (total lbs)	16.6	15.4	2.8	3.12	0.90	0
Shutdown (total lbs)	3.12	28.9	3.06	1.35	0.39	0

Uncontrolled emission rates based on DLN without SCR, NO_x=25 ppm, CO=10 ppm, VOC=2 ppm

Daily emissions are calculated on a per turbine basis for 2 potential operating scenarios. The first assumes 2 starts, 2 shutdowns and the remaining hours of the day at full load, and the second assumes 24 hrs at full load operation.

Table B.8 Controlled Daily Emissions (1 SCTG)

		Emissions, lbs					
		NOx	CO	VOC	PM10	SOx	
Duration							NH3
Scenario 1							
Start (2)	1	33.2	30.8	5.6	6.24	1.8	0
Normal Operation	21.57	176.9	170.4	49.6	134.6	38.8	129.4
Shutdown (2)	0.43	6.2	57.8	6.12	2.7	0.78	0
Downtime	1	0	0	0	0	0	0
TOTAL	24	216.3	259	61.3	143.5	41.4	129.4
Scenario 2							
Normal Operation	24	196.8	189.6	55.2	149.8	43.2	144

Table B.9 Uncontrolled Daily Emissions (1 SCTG)

	Duration	Emissions, lbs					NH3
		NOx	CO	VOC	PM10	SOx	
Scenario 1							
Start (2)	1	33.2	30.8	5.6	6.24	1.8	0
Normal Operation	21.57	1768.8	4281.6	49.6	134.6	38.8	0
Shutdown (2)	0.43	6.2	57.8	6.12	2.7	0.78	0
Downtime	1	0	0	0	0	0	0
TOTAL	24	1808.2	4370.2	61.3	143.5	41.4	0
Scenario 2							
Normal Operation	24	1968.0	4764.0	55.2	149.8	43.2	0


	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 125	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

Table B.10 Maximum Controlled/Uncontrolled Daily Emissions (1 SCTG)

Pollutant	Operating Scenario	Uncontrolled Daily Emissions	Controlled Daily Emissions
NOx	See Below	1968	216.3
CO	See Below	4764	259
VOC	2 starts, 2 shutdowns, 21.57 hours normal	61.3	61.3
PM10	24 hr normal	149.8	149.8
SOx	24 hr normal	43.2	43.2
NH3	24 hr normal	//////////	144

For NOx and CO, the maximum uncontrolled emissions result from the 24 hr normal operation scenario, while the maximum controlled emissions result from the 2 start, 2 shutdown scenario.

Monthly Emissions

Table B.11 Maximum Monthly Operation SCTG

Event	# Per Month	Duration/event	Duration/month, hrs ⁽¹⁾
Start	62	30 minutes	31
Shutdown	62	13 minutes	13.4
100% Load @ 65.8 deg F	//////////	//////////	699.6
		Total Hrs	744

Monthly emissions and the 30 Day Averages are calculated for 2 scenarios, one assuming the maximum starts and shutdowns are based on the above operating profile, and the second assuming no start ups or shutdowns. The following factors are used:

Table B.12 Emission Factors for 30 Day Calculation SCTG

Event	lbs/event or lbs/hr					
	NOx	CO	VOC	PM10	SOx	NH3
Start	16.6	15.4	2.8	3.12	0.90	0
Shutdown	3.12	28.9	3.06	1.35	0.39	0
Normal @ 65.8 deg	8.2	7.9	2.3	6.24	1.80	6.0



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
126

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table B.13 30 Day Emissions /Scenario 1/, Start Ups and Shut Downs (1 SCTG)

Event	Duration, hrs/month	# of events	Emissions					
			NO _x	CO	VOC	PM10	SO _x	NH ₃
Start	31	62	1029.2	954.8	173.6	193.4	55.8	0
Shutdown	13.4	62	193.4	1791.8	189.7	83.7	24.2	0
Normal @ 65.8 deg	699.6	//////	5736.7	5526.8	1609.1	4365.5	1259.3	4197.6
Total, lbs/month			6959.4	8273.4	1972.4	4642.6	1339.3	4197.6
Average lbs/day			232.0	275.8	65.7	154.8	44.6	139.9

Table B.14 30 Day Emissions /Scenario 2/ No Starts (1 SCTG)

Event	Duration, hrs/month	# of events	Emissions					
			NO _x	CO	VOC	PM10	SO _x	NH ₃
Normal @ 65.8 deg	744	//////	6100.8	5877.6	1711.2	4642.6	1339.3	4464
Total, lbs/month			6100.8	5877.6	1711.2	4642.6	1339.3	4464
Average lbs/day			203.4	195.9	57.0	154.8	44.6	148.8

Table B.15 30 Day Emissions (1 SCTG)

Pollutant	Operating Scenario	Total Monthly Emissions	30-Day Average Emissions
NO _x	62 starts +62 shutdowns+700 hrs normal	6959.4	232.0
CO	62 starts +62 shutdowns+700 hrs normal	8273.4	275.8
VOC	62 starts +62 shutdowns+700 hrs normal	1972.4	65.7
PM10	744 hrs normal	4642.6	154.8
SO _x	744 hrs normal	1339.3	44.6



**South Coast
Air Quality Management District**
Engineering Division
Application Processing & Calculations

PAGE 127	PAGES 212
APPL NO. See Below	DATE 6/7/16
PROCESSED BY CP01	CHECKED BY

Annual Emissions

Table B.16 Maximum Annual Operation SCTG

Event	# Per Year	Duration/event	Duration/yr, hrs
Start	350	30 minutes	175
Shutdown	350	13 minutes	76
100% Load @ 65.8 deg F	//////////	//////////	1750
		Total Hrs	2001

Annual emissions for the simple cycle plant are calculated assuming the following emission rates per turbine:

Table B.17 Simple Cycle Emission Rates (annual basis)

	NO _x	CO	VOC	PM ₁₀	SO _x	NH ₃
Normal Operations Controlled (lbs/hr)	8.2	7.9	2.3	6.24	0.60	6.0
Start (total lbs)	16.6	15.4	2.8	3.12	0.30	0
Shutdown (total lbs)	3.12	28.9	3.06	1.35	0.13	0

SO_x for annual emissions is based on 0.25 gr/100 scf:

0.25 grains/100 scf fuel converts to SO_x per mmcf fuel as follows: 0.25 grains/ 100 scf(lb/7000 rains)(64 lbs/lb-mole SO₂/32 lbs/lb-mole H₂S)(1E6 cf/mmcf) = 0.71 lbs SO₂/mmcf fuel.

$$\text{SO}_x \quad (0.71 \text{ SO}_2/\text{mmscf}) * 0.84 \text{ mmscf} \quad = \quad 0.60 \text{ lbs/hr}$$



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
128

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table B.18 Simple Cycle Annual Emissions, Non-Commissioning Year

Operating Mode	Emissions Per Turbine, lbs					
	NOx	CO	VOC	PM10	SOx	NH3
Starts	5810	5390	980	1092	105	0
Shutdowns	1092	10115	1071	472.5	45.5	0
Normal Operation	14350	13825	4025	10920	1050	10500
TOTAL 1 TURBINE	21252	29330	6076	12484.5	1200.5	10500
TOTAL 2 TURBINES	42504	58660	12152	24969	2401	21000

Sample Calcs:

$$\text{NOx starts} = 16.6 \text{ lbs/start} * 350 \text{ starts/yr} = 5810 \text{ lbs}$$

$$\text{PM10 starts} = 3.12 \text{ lbs/start} * 350 \text{ starts/yr} = 1092 \text{ lbs}$$

$$\text{SOx normal operation} = 0.6 \text{ lbs/hr} * 1750 \text{ hrs/yr} = 1050 \text{ lbs}$$



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
129

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

**Appendix C
Commissioning and Annual Emissions**

Each turbine will go through a series of tests during commissioning to prepare for commercial operation.

Combined Cycle Commissioning

The commissioning for each combined cycle turbine is expected to take up to 996 hours, for a total of 1,992 hours total commissioning for the 2 turbines. Up to 216 of those hours will be operation with no control, the rest will be partially controlled.

Table C.1 Summary of Combined Cycle Commissioning Emissions

Activity	Duration (hours)	CT Load (%)	Fuel Use		Pollutant Emission Rates (per turbine), lbs/hr			Total Emissions (per turbine), lbs				
			mmscf/hr	mmscf/activity	NOx	CO	VOC	NOx	CO	VOC	SO2	PM10
FSNL	48	10	0.22	10.39	130	1,900	270	6,240	91,200	12,960	233	408
Steam Blows	120	40	0.87	103.91	68.3	32.4	3.00	8,190	3,888	360	583	1,020
Set Unit HRSG & Steam Safety Valves	12	40	0.87	10.39	68.3	32.4	3.00	819	389	36	58.3	102
DLN Emissions Tuning	12	50	1.08	12.99	47.3	23.8	2.00	567	285	24	58.3	102
Emissions Tuning	12	60	1.30	15.59	52.5	24.8	2.00	630	298	24	58.3	102
Emissions Tuning	12	80	1.73	20.78	63.0	29.2	2.50	756	350	30	58.3	102
Verify STG on Turning Gear, Combined Blows Finalize Bypass Valve Tuning	168	80	1.73	290.94	13.9	6.42	1.63	2,338	1,078	273	816	1,428
CTG Baseload Testing/Tuning	24	100	2.16	51.95	16.2	7.60	1.95	388	182	47	117	204



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE 130	PAGES 212
APPL NO. See Below	DATE 6/7/16
PROCESSED BY CP01	CHECKED BY

Load STG/Combined Cycle (2X1)	48	50	1.08	51.95	10.4	5.23	1.30	499	251	62	233	408
STG Load Test/Combined Cycle Tuning	96	80	1.73	166.25	13.9	6.42	1.63	1,331	616	156	467	816
RATA/Pre- performance Testing	84	80	1.73	145.47	13.9	6.42	1.63	1,164	539	137	408	714
Source Testing & Drift Test Day 1	24	50	1.08	25.98	10.4	5.23	1.30	249	125	31	117	204
Source Testing & Drift Test Day 2	24	50	1.08	25.98	10.4	5.23	1.30	249	125	31	117	204
Source Testing & Drift Test Day 3	24	50	1.08	25.98	10.4	5.23	1.30	249	125	31	117	204
Source Testing & Drift Test Day 4	24	50	1.08	25.98	10.4	5.23	1.30	249	125	31	117	204
Source Testing & Drift Test Day 5	24	50	1.08	25.98	10.4	5.23	1.30	249	125	31	117	204
Source Testing & Drift Test Day 6	24	50	1.08	25.98	10.4	5.23	1.30	249	125	31	117	204
Source Testing & Drift Test Day 7	24	50	1.08	25.98	10.4	5.23	1.30	249	125	31	117	204
Performance Testing	132	100	2.16	285.75	16.2	7.60	1.95	2,134	1,004	257	642	1,122
CALISO Certification	60	75	1.62	97.41	13.4	6.18	1.63	804	371	98	292	510
TOTALS	996	////////	////////	1445.6	////////	////////	////////	27,593	101,326	14,681	4,843	8,466

Shaded activities reflect control by DLN, SCR and oxidation catalyst. Assumed control efficiencies – NO_x – 78%, CO -78%, and VOC – 35%
PM₁₀ based on 8.5 lbs/hr, SO_x based on 4.86 lbs/hr



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE 131	PAGES 212
APPL NO. See Below	DATE 6/7/16
PROCESSED BY CP01	CHECKED BY

Table C.2 Combined Cycle Simultaneous Commissioning

Both turbines will operate during the following tests. (The total emissions from these tests are accounted for in Table C.1, this table shows the higher lbs/hr emission rates due to 2 turbines operating simultaneously).

Activity	Duration (hours)	CT Load (%)	Pollutant Emission Rates, lbs/hr per turbine			Total Emissions Rate (2 turbines), lbs/hr				
			NO _x	CO	VOC	NO _x	CO	VOC	SO _x	PM ₁₀
FSNL	48	10	130	1,900	270	260	3800	540	9.72	17
Steam Blows	120	40	68.3	32.4	3.00	136.6	64.8	6	9.72	17
Set unit HRSG and steam safety valves	12	40	68.3	32.4	3.00	136.6	64.8	6	9.72	17
STG Bypass Valve Tuning HRSG Blowdown	168	80	63.0	29.2	2.50	126	58.4	5	9.72	17

Shaded activities reflect control by DLN, SCR and oxidation catalyst. Assumed control efficiencies – NO_x – 78%, CO -78%, and VOC – 35%. SO_x based on 4.86 lbs/hr per turbine, PM₁₀ based on 8.5 lbs/hr per turbine

Simple Cycle Commissioning

The commissioning for each simple cycle turbine is expected to take up to 280 hours, for a total of 560 hours total commissioning for the 2 turbines. Up to 4 of those hours will be operation with no control, the rest will be partially controlled.

Table C.3 Summary of Simple Cycle Commissioning Emissions

Activity	Duration (hours)	CT Load (%)	Fuel Use		Pollutant Emission Rates (per turbine), lbs/hr			Total Emissions (per turbine), lbs				
			mmscf/hr	mmscf/activity	NO _x	CO	VOC	NO _x	CO	VOC	SO ₂	PM ₁₀
FSNL	4	5	0.042	0.17	40.1	244.0	5.1	160.2	976.0	20.3	6.6	25.0



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
132

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

DNL Emission Tuning	12	100	0.843	10.11	20.5	90.0	3.1	246.0	1,080.0	36.7	19.7	74.9
Emission Tuning	12	75	0.632	7.59	16.5	72.5	2.7	198.0	869.4	32.2	19.7	74.9
Base Load Testing	12	75	0.632	7.59	16.5	72.5	1.1	198.0	869.4	13.7	19.7	74.9
Refire	12	100	0.843	10.11	20.5	90.0	3.1	246.0	1,080.0	36.7	19.7	74.9
Source Testing/RATA/Pre-performance Testing	168	100	0.843	141.60	20.5	90.0	3.1	3,440.0	15,120.0	513.3	275.5	1,048.3
Water Wash & Performance Prep	24	100	0.843	20.23	20.5	90.0	3.1	492.0	2,160.0	73.3	39.4	149.8
Performance Testing	24	100	0.843	20.23	20.5	90.0	3.1	492.0	2,160.0	73.3	39.4	149.8
CALISO Certification	12	100	0.843	10.11	20.5	90.0	3.1	246.0	1,080.0	36.7	19.7	74.9
TOTALS	280	//////		227.7	//////	//////	//////	5,718	25,449	836	459	1,747

Shaded activities reflect control by DLN, SCR and oxidation catalyst. Assumed control efficiencies – NO_x – 75%, CO -75%, and VOC – 33%
PM₁₀ based on 6.24 lbs/hr, SO_x based on 1.64 lbs/hr

Table C.4 Simple Cycle Simultaneous Commissioning

Both turbines will operate during the following tests. ((The total emissions from these tests are accounted for in Table C.3, this table shows the higher lbs/hr emission rates due to 2 turbines operating simultaneously). All simple cycle commissioning activities can potentially be conducted simultaneously on both turbines, however, it is more likely that the activities up to re-fire will be done on the first turbine alone, after which the second turbine would begin its commissioning.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
133

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Activity	Duration (hours)	CT Load (%)	Pollutant Emission Rates, lbs/hr per turbine			Total Emission Rate (2 turbines), lbs/hr				
			NOx	CO	VOC	NOx	CO	VOC	SOx	PM10
FSNL	4	5	40.1	244.0	5.1	80.2	488	10.2	3.28	12.48
DNL Emission Tuning	12	100	20.5	90.0	3.1	41	180	6.2	3.28	12.48
Emission Tuning	12	75	16.5	72.5	2.7	33	145	5.4	3.28	12.48
Base Load Testing	12	75	16.5	72.5	1.1	33	145	2.2	3.28	12.48
Refire	12	100	20.5	90.0	3.1	41	180	6.2	3.28	12.48
Source Testing/RATA/Pre- performance Testing	168	100	20.5	90.0	3.1	41	180	6.2	3.28	12.48
Water Wash & Performance Prep	24	100	20.5	90.0	3.1	41	180	6.2	3.28	12.48
Performance Testing	24	100	20.5	90.0	3.1	41	180	6.2	3.28	12.48
CALISO Certification	12	100	20.5	90.0	3.1	41	180	6.2	3.28	12.48

Shaded activities reflect control by DLN, SCR and oxidation catalyst. Assumed control efficiencies – NOx – 75%, CO -75%, and VOC – 33%
PM10 based on 6.24 lbs/hr, SOx based on 1.64 lbs/hr

Table C.5 Total Commissioning Emissions (Per Block)

Pollutant	Combined Cycle Per Turbine	Total Combined Cycle Block		Simple Cycle Per Turbine	Total Simple Cycle Block	
	Lbs	Lbs	Tons	Lbs	Lbs	Tons
NOx	27,593	55,186	27.6	5,718	11,436	5.7
CO	101,326	202,652	101.3	25,449	50,898	25.4
VOC	14,681	29,362	14.7	836	1,672	0.84
PM10	8,466	16,932	8.5	1,747	3,494	1.7
SO2	4,843	9,686	4.8	459	918	0.46



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE 134	PAGES 212
APPL NO. See Below	DATE 6/7/16
PROCESSED BY CP01	CHECKED BY

Annual Emissions During Commissioning

The following is an estimate of annual emissions during a commissioning year, which may include commissioning activities as well as normal operation of the turbines and auxiliary boiler.

Commissioning of the combined cycle units will not coincide with any operation of the simple cycle units (combined cycle units start operation in 2020, simple cycle units don't begin construction until 2022). So, the annual emissions for the plant when the combined cycle units are commissioned will consist of 996 hrs of commissioning per turbine + the balance of the 12 months with normal turbine operation and auxiliary boiler operation. It will be assumed that the CCTGs and auxiliary boiler will operate their full allotment of allowable annual operating hours after commissioning. Note that in the modeling performed for annual NO_x during the year commissioning is performed on the combined cycle turbines, emissions of 101,009 lbs per year of NO_x (11.5 lbs/hr) were assumed. This assumption includes the CCTG operating at minimum load conditions (about 44%) after commissioning, not maximum load. This is because the CCTG minimum load emissions and associated stack parameters resulted in a higher impact than assuming full load emissions and stack parameters.

Table C.6 Total Plant Annual Emissions, Combined Cycle Commissioning Year

Operating Mode	Hours	Emissions, lbs				
		NO _x	CO	VOC	PM10	SO _x
Commissioning CCTG 1	996	27,593	101,326	14,681	8,466	4,843
Commissioning CCTG 2	996	27,593	101,326	14,681	8,466	4,843
Post Commissioning Operation CCTG 1	6640	119,500	212,260	64,760	56,440	9,960
Post Commissioning Operation CCTG 2	6640	119,500	212,260	64,760	56,440	9,960
Auxiliary Boiler	2573.3	1,313	7,522	1,010	1,392	382
TOTAL EMISSIONS		295,499	634,694	159,892	131,204	29,988



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
135

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Emissions during the 12 months when the simple cycle units are commissioned will consist of 280 hrs per simple cycle turbine commissioning + normal operation of the combined cycle plant and auxiliary boiler, and balance of the year with simple cycle operation.

Table C.7 Total Plant Annual Emissions, Simple Cycle Commissioning Year


Operating Mode	Hours	Emissions, lbs				
		NOx	CO	VOC	PM10	SOx
Commissioning SCTG 1	280	5,718	25,449	836	1,747	459
Commissioning SCTG 2	280	5,718	25,449	836	1,747	459
Post Commissioning Operation SCTG 1	2001	21,252	29,330	6,076	12,484.5	1,200.5
Post Commissioning Operation SCTG 2	2001	21,252	29,330	6,076	12,484.5	1,200.5
CCTG 1	6640	119,500	212,260	64,760	56,440	9,960
CCTG 2	6640	119,500	212,260	64,760	56,440	9,960
Auxiliary Boiler	2573.3	1,313	7,522	1,010	1,392	382
TOTAL EMISSIONS		294,253	541,600	144,354	142,735	23,621

Monthly Emissions During Commissioning

The following is an estimate of monthly maximum emissions during commissioning. The estimate of commissioning emissions during a 30 day period is performed to compare to the monthly maximum emissions during normal operation of the entire plant (see Table 3.13). The higher monthly amount is required to be offset (for VOC and PM10).

Scenario 1 - Combined Cycle Commissioning

When the combined cycle units are commissioned sometime in late 2019 or early 2020, neither the simple cycle units nor the auxiliary boiler will be in operation yet. Therefore, it is only the emissions from the combined cycle units commissioning itself which will need to be compared to the maximum monthly emissions from normal operation outside of commissioning.

 South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 136	PAGES 212
	APPL NO. See Below	DATE 6/7/16
	PROCESSED BY CP01	CHECKED BY

Since the total hours for combined cycle commissioning exceeds the total hours in one month (996 vs. 744), and since the exact commissioning schedule is unknown, an assumption must be made as to the number of hours and which commissioning activities could reasonably be completely in one month's time. For argument's sake, it will be assumed that the first 636 hours of combined cycle commissioning activities will be completed in one month (up to and including the RATA testing).

Table C.8 Estimated 30 Day Emissions CCTG Commissioning Month

Pollutant	CCTG 1 Commissioning, lbs/month ¹	CCTG 2 Commissioning, lbs/month ¹	Total Facility Emissions, lbs/month	30-Day Average Emissions, lbs/day
NOx	22922	22922	45844	1528.1
CO	99076	99076	198152	6605.1
VOC	14109	14109	28218	940.6
PM10	3090	3090	6180	206.0
SOx	5406	5406	10812	360.4

¹ Refer to Table C.1

Scenario 2 – Simple Cycle Commissioning

When the simple cycle units are commissioned sometime in late 2023 or early 2024, the combined cycle units and auxiliary boiler will be operating normally. Therefore, the monthly emissions from commissioning of the simple cycle units should be added to the monthly emissions from the combined cycle units and auxiliary boiler to make the comparison. Furthermore, the expected hours of commissioning for the simple cycle units (280) can be assumed to fall into one month's time.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
137

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table C.9 Estimated 30 Day Emissions SCTG Commissioning Month

Pollutant	SCTG 1 Commissioning, lbs/month ¹	SCTG 1 Commissioning, lbs/month ¹	CCTG 1, lbs/month ²	CCTG 2, lbs/month ²	Aux Boiler, lbs/month ³	Total Facility Emissions, lbs/month	30-Day Average Emissions, lbs/day
NOx	5718	5718	13666	13666	175	38943	1298.1
CO	25449	25449	26440	26440	1070	104848	3494.9
VOC	836	836	7611	7611	142	17036	567.9
PM10	459	459	6324	6324	196	13762	458.7
SOx	1747	1747	3422	3422	54	10392	346.4

1 Refer to Table C.5, 2 Refer to Table A.16, 3 Refer to Table D.6

A comparison of Tables C.8 and C.9 shows that the monthly emissions during combined cycle turbine commissioning are higher than the monthly emissions during simple cycle turbine commissioning in all cases except PM10. Furthermore, in a comparison of Tables 3.13 and Tables C.8 and C.9, the estimated monthly emissions during combined cycle turbine commissioning will be higher for NOx, CO, VOC, and SOx, than the maximum monthly emissions during normal operation of the entire plant outside of commissioning. Only monthly PM10 emissions are calculated to be higher during operation if the plant outside of commissioning.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
138

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Appendix D

Auxiliary Boiler Emission Calculations

Normal Operation

➤ Table D.1 Emission Factors Auxiliary Boiler

Pollutant	Factor	Source
NO _x	5 ppm @ 3%	Manufacturer guarantee
CO	50 ppm @ 3%	Manufacturer guarantee
VOC	5.5 lbs/mmcf	Form B-1
PM ₁₀	7.5 lbs/mmcf	Form B-1
SO _x	0.75 gr/100 scf	See note below
NH ₃	5 ppm @ 3%	Manufacturer guarantee

SO_x emissions are based on 12 ppm sulfur in the natural gas (0.75 gr/100 scf).

Data:

Specific Molar Volume

385 ft³/lb-mole

Heat Input

71 mmbtu/hr

Exhaust flow

723,540 ft³/hr (based on F factor of 8710 corrected to 3% O₂)

Fuel Use

67,619 ft³/hr (based on 1050 btu/ft³)

Start Up Operation

There are 3 basic types of starts for the auxiliary boiler— cold, and warm and hot. A cold start up is defined as a start of the boiler that occurs when the system is at ambient temperature, which would typically occur after a period of 48 hours or more from the last shutdown. Typically, the BACT emission levels will be achieved within 170 minutes from the beginning of a cold start.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
139

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

A warm start occurs after a shutdown lasting between 10 to 48 hours, and a hot start occurs after a shutdown of less than 10 hours. Warm starts will take about 85 minutes to complete, and hot starts will take about 25 minutes.

AES anticipates up to 2 cold, 4 warm, and 4 hot starts per month, and 24 cold, 48 warm, and 48 hot starts of the auxiliary boiler per year, with a maximum of 1 start per day.

Table D.2 Start Up Emissions Auxiliary Boiler

Pollutant	Cold Start, 170 minutes		Warm Start, 85 minutes		Hot Start, 25 minutes	
	Lbs/hr	Lbs/event	Lbs/hr	Lbs/event	Lbs/hr	Lbs/event
NO _x	1.49	4.22	1.49	2.11	0.87	0.62
CO	1.53	4.34	1.53	2.17	2.29	0.64

The lbs/hr numbers represent the highest hour during the event

Hourly Emissions

Table D.3 Hourly Emission Rates Auxiliary Boiler

	NO _x	CO	VOC	PM10	SO _x	NH ₃
Normal Operations Controlled (lbs/hr)	0.42	2.83	0.37	0.51	0.14	0.16
Normal Operations Uncontrolled (lbs/hr)	0.76	2.83	0.37	0.51	0.14	0
Cold Start (total lbs)	4.22	4.34	1.05	1.45	0.40	0
Warm Start (total lbs)	2.11	2.17	0.52	0.72	0.20	0
Hot Start (total lbs)	0.62	0.64	0.15	0.21	0.06	0

Sample Calcs:

$$\text{NO}_{x\text{normal controlled}} = (5 \text{ ppm} * 723,540 * 46) / 385\text{E}+06 = 0.42$$

$$\text{NO}_{x\text{normal uncontrolled}} = (9 \text{ ppm} * 723,540 * 46) / 385\text{E}+06 = 0.76$$

$$\text{VOC}_{\text{normal}} = (5.5 \text{ lbs/mmcf} * 67,619) / 1\text{E}+06 = 0.37$$

SO_x:

0.75 grains/100 scf fuel converts to SO_x per mmcf fuel as follows: 0.75 grains/ 100 scf(lb/7000 grains)(64 lbs/lb-mole SO₂/32 lbs/lb-mole H₂S)(1E6 cf/mmcf) = 2.14 lbs SO₂/mmcf fuel.

$$\text{SO}_{x\text{normal}} = (2.14 \text{ SO}_2/\text{mmcf} * 67,619 \text{ mmcf}) / 1\text{E}+06 = 0.14 \text{ lbs/hr}$$

$$\text{VOC}_{\text{cold start}} = (170 \text{ min}/60 \text{ min}) * 0.37 \text{ lbs/hr} = 1.05$$



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
140

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Daily Emissions

Daily emissions are calculated for 2 potential operating scenarios. The first assumes 1 cold start and the remaining hours of the day at full load, and the second assumes 24 hrs at full load operation.

Table D.4 Auxiliary Boiler Daily Controlled Emissions

	Duration	Emissions, lbs					NH3
		NOx	CO	VOC	PM10	SOx	
Scenario 1							
Cold Start (1)	2.83	4.22	4.34	1.05	1.45	0.4	0
Normal Operation	21.17	8.89	59.91	7.83	10.80	2.96	3.39
TOTAL	24	13.11	64.25	8.88	12.25	3.36	3.39
Scenario 2							
Normal Operation	24	10.08	67.92	8.88	12.25	3.36	3.84

Table D.5 Auxiliary Boiler Daily Uncontrolled Emissions

		Emissions, lbs					
	Duration	NOx	CO	VOC	PM10	SOx	NH3
Scenario 1							
Cold Start (1)	2.83	4.22	4.34	1.05	1.45	0.4	0
Normal Operation	21.17	16.09	59.91	7.83	10.80	2.96	0
TOTAL	24	20.31	64.25	8.88	12.25	3.36	0
Scenario 2							
Normal Operation	24	18.24	67.92	8.88	12.25	3.36	0

Table D.6 Maximum Controlled/Uncontrolled Daily Emissions

Pollutant	Operating Scenario	Uncontrolled Daily Emissions	Controlled Daily Emissions
NOx	1 cold start + 21.17 hours normal operation	20.3	13.1
CO	24 hr normal	67.9	67.9
VOC	24 hr normal	8.9	8.9
PM10	24 hr normal	12.3	12.3
SOx	24 hr normal	3.4	3.4
NH3	24 hr normal	//////////	3.8



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
141

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Monthly Emissions

Monthly emissions and the 30 Day Averages are calculated for 2 scenarios, one assuming the maximum starts and shutdowns are based on the monthly operating profile, and the second assuming no start ups or shutdowns.

Table D.7 Maximum Monthly Operation Auxiliary Boiler

Event	# Per Month	Duration	Duration/month, hrs
Cold Start	2	170 minutes	5.7
Warm Start	4	85 minutes	5.7
Hot Start	4	25 minutes	1.7
Normal	//////////	15,793 mmbtu	222.4 ⁽¹⁾
		Total Hrs	235.5

¹ Based on 71 mmbtu/hr. Note that the unit may operate more hours at a lower heat input rate

Table D.8 30 Day Emissions Scenario 1/Start Ups and Shutdowns

Event	Emissions				
	NOx	CO	VOC	PM10	SOx
Cold Start	8.4	8.7	2.1	2.9	0.8
Warm Start	8.4	8.7	2.1	2.9	0.8
Hot Start	2.5	2.6	0.63	0.8	0.2
Normal	93.4	629.5	82.3	113.4	31.1
Total, lbs/month	112.7	649.5	87.1	120.0	32.9
Average lbs/day	3.8	21.7	2.9	4.0	1.1

Table D.9 30 Day Emissions /Scenario 2/ No Starts

Event	Duration		Emissions					
	mmbtu/month	hrs/month	NOx	CO	VOC	PM10	SOx	NH3
Normal	15,793	222.4	93.4	629.5	82.3	113.4	31.1	35.6
	Total, lbs/month		93.4	629.5	82.3	113.4	31.1	35.6
	Average lbs/day		3.1	21.0	2.7	3.8	1.0	1.2

¹ based on 71 mmbtu/hr


	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 142	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

Table D.10 30 Day Emissions

Pollutant	Operating Scenario	Total Monthly Emissions	30-Day Average Emissions
NOx	2 cold starts +4 warm starts + 4 hot starts + 235.5 hrs normal	112.7	3.8
CO	2 cold starts +4 warm starts + 4 hot starts + 235.5 hrs normal	649.5	21.7
VOC	2 cold starts +4 warm starts + 4 hot starts + 235.5 hrs normal	87.1	2.9
PM10	2 cold starts +4 warm starts + 4 hot starts + 235.5 hrs normal	120.0	4.0
SOx	2 cold starts +4 warm starts + 4 hot starts + 235.5 hrs normal	32.9	1.1

Annual Emissions

Table D.11 Maximum Annual Operation Auxiliary Boiler

Event	# Per Year	Duration	Duration/yr, hrs
Cold Start	24	170 minutes	68
Warm Start	48	85 minutes	68
Hot Start	48	25 minutes	20
Normal	//////////	182,703 mmbtu	2573.3 ⁽¹⁾
		Total Hrs	2729.3

¹ Based on 71 mmbtu/hr. Note that the unit may operate more hours at a lower heat input rate

Table D.12 Annual Emissions Auxiliary Boiler

Event	Emissions					
	NOx	CO	VOC	PM10	SOx	NH3
Cold Start	101.3	104.2	25.2	34.8	9.6	0
Warm Start	101.3	104.2	25.2	34.6	9.6	0
Hot Start	29.8	30.7	7.4	10.1	2.9	0
Normal	1080.8	7282.4	952.1	1312.4	360.3	411.7
Total, lbs/yr	1313.2	7521.5	1009.9	1391.9	382.4	411.7

Sample Calc:



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
143

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

$$\text{NO}_x = 24*(4.22) + 48*(2.11) + 48*(0.62) + 2573.3*(0.42) = 1313.2$$

Appendix E

Air Toxic Emission Calculations

Combined Cycle Turbines

Data:

Maximum fuel use (@ 1050 btu/cf) 2.16 mmcf/hr
Maximum annual hours of operation (incl start/shutdown) 6,640 hrs/yr

Total Annual Fuel Use	14,342 mmcf/yr
-----------------------	----------------

Table E.1 Toxic Emissions Per Combined Cycle Turbine

Pollutant	Emission Factor, lbs/mmcf	Maximum Hourly Emission Rate, lbs/hr	Annual Emissions 1 Turbine, lbs/yr
Ammonia	//////////	15.5	94550
1,3 Butadiene	4.39E-04	9.48E-04	6.30
Acetaldehyde	1.80E-01	3.89E-01	2581.56
Acrolein	3.69E-03	7.97E-03	52.92
Benzene	3.33E-03	7.19E-03	47.76
Ethyl Benzene	3.26E-02	7.04E-02	467.55
Formaldehyde	3.67E-01	7.93E-01	5263.51
Naphthalene	1.33E-03	2.87E-03	19.07
PAH	9.18E-04	1.98E-03	13.17
Propylene Oxide	2.96E-02	6.39E-02	424.52
Toluene	1.33E-01	2.87E-01	1907.49
Xylene	6.53E-02	1.41E-01	936.53
		Total	Lbs/yr
			106,270.4
			Tons/yr
			53.1

Notes:

Emission factors from USEPA AP-42 Table 3.1-3, except 1) Formaldehyde, Benzene, and Acrolein emission factors which are from the Background document for AP-42 Section 3.1, Table 3.4-1 for natural gas turbine with CO catalyst. Ammonia emissions based on 5 ppm NH3 slip, 6100 hours/yr operation (not including start/shutdown). The emission estimates in this table may differ slightly from what was used in the HRA. For the HRA AES assumed fuel use at the annual average temperature, not the site low temperature.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
144

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Simple Cycle Turbines

Data:

Maximum fuel use (@ 1050 btu/cf) 0.85 mmcf/hr

Maximum annual hours of operation (incl start/shutdown) 2,001 hrs/yr

Total Annual Fuel Use	1,701 mmcf/yr
-----------------------	---------------

Table E.2 Toxic Emissions Per Simple Cycle Turbine

Pollutant	Emission Factor, lbs/mmcf	Maximum Hourly Emission Rate, lbs/hr	Annual Emissions 1 Turbine, lbs/yr
Ammonia	//////////	6.0	10500
1,3 Butadiene	4.39E-04	3.73E-04	0.75
Acetaldehyde	1.80E-01	1.53E-01	306.18
Acrolein	3.69E-03	3.14E-03	6.28
Benzene	3.33E-03	2.83E-03	5.66
Ethyl Benzene	3.26E-02	2.77E-02	55.45
Formaldehyde	3.67E-01	3.12E-01	624.27
Naphthalene	1.33E-03	1.13E-03	2.26
PAH	9.18E-04	7.80E-04	1.56
Propylene Oxide	2.96E-02	2.52E-02	50.35
Toluene	1.33E-01	1.13E-01	226.23
Xylene	6.53E-02	5.55E-02	111.08
		Total	Lbs/yr 11890.1
			Tons/yr 5.95

Notes:

Emission factors from USEPA AP-42 Table 3.1-3, except 1) Formaldehyde, Benzene, and Acrolein emission factors which are from the Background document for AP-42 Section 3.1, Table 3.4-1 for natural gas turbine with CO catalyst. Ammonia emissions based on 5 ppm NH₃ slip, 1750 hours/yr operation (not including start/shutdown).



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
145

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Auxiliary Boiler

Data:

Maximum fuel use (@ 1050 btu/cf)	0.07 mmcf/hr
Maximum annual hours of operation (incl starts)	2,573.3 hrs/yr
Total Annual Fuel Use	180 mmcf/yr

Table E.3 Toxic Emissions Auxiliary Boiler

Pollutant	Emission Factor, lbs/mmcf	Maximum Hourly Emission Rate, lbs/hr	Annual Emissions, lbs/yr
Ammonia	//////////	0.16	411.7
Benzene	5.80E-03	4.06E-04	1.04
Formaldehyde	1.23E-02	8.61E-04	2.21
PAH	1.00E-04	7.00E-06	0.02
Naphthalene	3.00E-04	2.10E-05	0.05
Acetaldehyde	3.10E-03	2.17E-04	0.56
Acrolein	2.70E-03	1.89E-04	0.49
Toluene	2.65E-02	1.86E-03	4.77
Xylene	1.97E-02	1.38E-03	3.55
Ethyl Benzene	6.90E-03	4.83E-04	1.24
Hexane	4.60E-03	3.22E-04	0.83
Propylene	5.30E-01	3.71E-02	95.40
		Total	Lbs/yr 521.86
			Tons/yr 0.26

Notes:

Emission factors from Ventura County APCD.

Ammonia emissions based on 5 ppm NH₃ slip, 2573.5 hours/yr operation (not including start/shutdown)



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
146

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Appendix F

Oil Water Separator Emission Calculations

There will be 2 new oil water separators (OWS), 1 serving the combined cycle plant area, and the other serving the simple cycle turbine area. The separators will collect rainwater runoff which may contain any oil from spills on the ground or from any oily residues on the equipment itself. These oils will consist mainly of heavy lubricating oils.

Data:

OWS #1 Collection Area (combined cycle area)

115,359 FT²

OWS #2 Collection Area (simple cycle area)

14,692 FT²

Huntington Beach Yearly Average Precipitation

11.9 inches (30 year average, source www.weatherbase.com)

VOC Emission Factor

0.2 lbs/1000 gals (source Table 5.1-3 EPA AP-42)

Calculations:

OWS #1

$(115,359 \text{ FT}^2 * 11.9/12 \text{ FT/yr precipitation}) * 7.48 \text{ gallons/FT}^3 = 855,695 \text{ gals/yr}$

$855,695 \text{ gals/yr} * 0.2 \text{ lbs/1000 gals} = 171.1 \text{ lbs/yr}$

OWS #2

$(14,692 \text{ FT}^2 * 11.9/12 \text{ FT/yr precipitation}) * 7.48 \text{ gallons/FT}^3 = 108,980 \text{ gals/yr}$

$108,980 \text{ gals/yr} * 0.2 \text{ lbs/1000 gals} = 21.8 \text{ lbs/yr}$



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
147

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Appendix G

Existing Facility Emissions

The existing facility consists of utility Boilers 1 and 2. The boilers are natural gas fired, each rated at 2021 mmbtu/hr heat input and 215 MW power output. The boilers are controlled with SCR systems. NO_x is limited to 7 ppm on an annual average basis. EPA Acid Rain data for monthly heat input was obtained for the years 2011-2015 in order for the actual emissions of these units to be calculated. The fuel use is estimated using a heat content of 1050 btu/cf. The emission factors used to estimate emissions for each unit are based on either CEMS data, source test results, or for SO_x, the default emission factor. The following tables summarize the data.

Table G.1 Existing Boilers Emission Factors for Determination of Past Actual Emissions

Pollutant	Boiler 1 Emission Factor	Source	Boiler 2 Emission Factor	Source
NO _x	Based on quarterly reports			
VOC	1.64 lbs/mmcsf	12/18/11 source test	0.9 lbs/mmcsf	11/14/12 source test
CO	0.274 lbs/mmbtu	Average of the 12/11/07 & 4/7/10 source tests for Boiler 1 & 4/6/10 source test for Boiler 2	0.274 lbs/mmbtu	Average of the 12/11/07 & 4/7/10 source tests for Boiler 1 & 4/6/10 source test for Boiler 2
SO _x	0.83 lbs/mmcsf	AQMD Form B-1 factor	0.83 lbs/mmcsf	AQMD Form B-1 factor
PM10	1.86 lbs/mmcsf	11/14/12 source test	2.1 lbs/mmcsf	11/14/12 source test
CO ₂	53.06 kg/mmbtu	EPA	53.06 kg/mmbtu	EPA

Table G.2 Boiler #1 Past Actual Emissions

Year	Month	Fuel Use		VOC	CO	NO _x	SO _x	PM10	CO ₂
		mmscf	mmbtu	lbs	lbs	lbs	lbs	lbs	tons
2011	1	62.763	60,156	96.3	16482.8	444.53	48.7	109.2	3519.0
	2	0	0	0.0	0.0	0	0.0	0.0	0.0
	3	6.074	7,373	11.9	2020.3	1312.12	6.0	13.5	431.3
	4	400.181	413,469	664.0	113290.5	2494.6	336.1	753.1	24187.4
	5	283.706	290,452	467.5	79583.9	4987.65	236.6	530.2	16991.1
	6	440.604	451,166	726.1	123619.6	5510.48	367.5	823.5	26392.6
	7	633.652	648,876	1039.8	177791.9	3892.44	526.3	1179.3	37958.4
	8	409.049	418,914	671.4	114782.3	3641.22	339.8	761.4	24505.9
	9	307.224	314,013	503.2	86039.5	2504.27	254.6	570.7	18369.3
	10	114.327	117,214	187.5	32116.6	968.99	94.9	212.7	6856.9
	11	112.735	115,873	185.8	31749.2	1293.79	94.0	210.7	6778.4
	12	42	43	0.1	11.8	0.27	0.0	0.1	2.5
	Total	2,770.357	2,837,549	4,554	777,488	27,050	2,305	5,164	165993



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
148

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

2012	1	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
	2	161.435	166,143	264.8	45578.5	7418.61	134.0	300.3	9719.1
	3	105.458	108,533	173.0	29774.3	2794.12	87.5	196.2	6349.0
	4	350.268	557,829	888.9	153031.2	3796.91	449.9	1008.2	32632.2
	5	351.224	424,521	676.5	116460.2	5655.08	342.4	767.2	24833.9
	6	305.425	474,294	755.8	130114.6	7262.46	382.5	857.2	27745.6
	7	289.921	192,818	307.3	52896.4	9010.13	155.5	348.5	11279.6
	8	494.545	433,370	690.6	118887.8	8257.04	349.5	783.2	25351.6
	9	571.910	390,080	621.6	107012.0	6466.24	314.6	705.0	22819.2
	10	78.190	80,470	128.2	22075.7	417.97	64.9	145.4	4707.4
	11	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	12	133.084	0.0	218.3	37574.1	1118.87	110.5	247.5	0.0
	Total	5,750.375	2,828,058	4,725	813,405	52,197	2,391	5,359	165438
	Ave	4,260.366	2,832,804	4,640	79,5447	39,624	2,348	5,262	165716
2013	1	199.18	209,140	326.66	57304.31	1,928.57	165.32	370.48	12234.4
	2	467.58	490,963	766.84	134523.7	3,578.45	388.09	869.71	28720.7
	3	196.80	206,644	322.76	56620.4	1,218.43	163.35	366.05	12088.4
	4	114.90	120,649	188.44	33057.74	1,413.80	95.37	213.72	7057.8
	5	296.83	311,671	486.80	85397.91	1,915.94	246.37	552.10	18232.3
	6	307.18	322,542	503.78	88376.37	2,179.05	254.96	571.36	18868.3
	7	323.14	339,302	529.96	92968.75	1,846.28	268.21	601.05	19848.7
	8	344.79	362,035	565.46	99197.48	1,699.16	286.18	641.32	21178.6
	9	269.30	282,766	441.65	77477.75	1,268.28	223.52	500.90	16541.4
	10	181.65	190,735	297.91	52261.31	1,397.69	150.77	337.87	11157.7
	11	322.22	338,328	528.44	92701.82	2,302.05	267.44	599.32	19791.7
	12	462.50	485,630	758.51	133062.6	2,994.67	383.88	860.26	28408.7
	Total	3,486	3,660,402	5,717	1,002,950	27,742	2,893	6,484	214129
	Ave	4,618	3,244,230	5,221	908,178	37,970	2,642	5,922	189784
2014	1	344.68	361,909	565.27	99,163.18	2,255.95	286.08	641.10	21171.2
	2	92.91	97,555	152.37	26729.93	593.61	77.11	172.81	5706.8
	3	490.97	515,520	805.19	141252.5	2,584.59	407.51	913.21	30157.2
	4	424.37	445,590	695.97	122091.8	2,647.54	352.23	789.33	26066.4
	5	338.24	355,153	554.72	97311.98	2,246.73	280.74	629.13	20776.0
	6	332.66	349,292	545.56	95705.98	2,477.90	276.11	618.75	20433.1
	7	620.64	651,677	1017.86	178559.4	5,443.45	515.13	1154.40	38122.2
	8	599.45	629,421	983.10	172461.3	4,423.83	497.54	1114.97	36820.3
	9	544.96	572,206	893.73	156784.4	3,777.74	452.32	1013.62	33473.3
	10	342.50	359,624	561.70	98536.95	2,507.04	284.27	637.05	21037.5
	11	67.16	70,517	110.14	19321.77	574.33	55.74	124.92	4125.1
	12	72.63	76,260	119.11	20895.32	728.59	60.28	135.09	4461.1
	Total	4,271	4,484,724	7,005	1,228,814	30,261	3,545	7,994	262350
	Ave	3,879	4,072,563	6,361	1,115,882	27,002	3,219	7,239	238240
2015	1	404.20	424,410	662.89	116288.3	3,186.09	335.49	751.81	24827.4
	2	0	0	0.00	0	0.00	0.00	0.00	0.0
	3	218.58	229,510	358.47	62885.82	1,954.70	181.42	406.56	13426.0
	4	81.94	86,041	134.39	23575.34	677.00	68.01	152.42	5033.3
	5	185.96	195,259	304.98	53500.99	1,757.67	154.35	345.89	11422.4
	6	494.00	518,698	810.16	142123.4	3,815.33	410.02	918.84	30343.1



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
149

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

7	552.61	580,237	906.27	158984.8	4,014.53	458.66	1027.85	33943.1
8	583.09	612,247	956.27	167755.7	4,205.11	483.97	1084.55	35815.6
9	534.20	560,914	876.09	153690.3	3,958.25	443.39	993.62	32812.7
10	378.05	396,949	620.00	108763.9	3,549.52	313.78	703.17	23221.0
11	88.78	93,216	145.59	25541.13	999.49	73.68	165.13	5453.0
12	231.83	243,426	380.21	66698.67	1,757.06	192.42	431.21	14240.1
Total	3,753	3,940,906	6,155	1,079,808	29,875	3,115	6,981	230538
Ave	4,012	4,212,815	6,580	1,154,311	30,068	3,330	7,488	246444

Average based on previous 2 years

Table G.3 Boiler #2 Past Actual Emissions

Year	Month	Fuel Use		VOC	CO	NOx	SOx	PM10	CO2
		mmscf	Mmbtu	lbs	lbs	lbs	lbs	lbs	tons
2011	1	14.056	13,472	11.8	3691.3	185.47	10.9	27.6	788.1
	2	106.169	101,824	89.8	27899.8	1500.59	82.8	209.5	5956.6
	3	278.364	337,906	299.0	92586.2	1777.49	275.7	697.6	19767.0
	4	37.870	39,127	34.5	10720.9	274.72	31.8	80.5	2288.9
	5	22.156	22,683	20.0	6215.1	333.27	18.5	46.7	1326.9
	6	250.102	256,098	226.2	70170.7	2667.85	208.6	527.7	14981.4
	7	547.540	560,695	493.1	153630.4	3952.23	454.7	1150.6	32799.9
	8	552.538	565,863	497.7	155046.5	5011.13	459.0	1161.2	33102.2
	9	402.546	411,441	361.8	112734.9	5205.98	333.7	844.2	24068.7
	10	287.825	295,093	259.1	80855.5	2764.63	239.0	604.6	17262.5
	11	261.011	268,277	236.1	73507.9	3899.59	217.7	550.8	15693.8
	12	328.531	340,574	298.4	93317.4	4236.25	275.2	696.3	19923.1
	Total	3,088.708	3,213,053	2,828	880,377	31,809	2,608	6,597	187959
2012	1	368.745	379,499	331.9	104109.1	4899.35	306.1	774.4	22200.2
	2	576.575	593,390	518.9	162786.6	5543.86	478.6	1210.8	34712.5
	3	700.052	720,468	630.0	197648.4	7185.58	581.0	1470.1	42146.4
	4	123.418	196,553	171.9	53921.2	1430.62	158.5	401.1	11498.1
	5	583.942	705,805	617.2	193625.9	5097.79	569.2	1440.2	41288.6
	6	468.252	727,148	635.9	199480.8	5817.53	586.4	1483.7	42537.2
	7	443.085	294,683	257.7	80841.2	7953.6	237.7	601.3	17238.6
	8	603.752	529,068	462.7	145141.0	7549.64	426.7	1079.6	30949.8
	9	595.486	406,160	355.2	111423.3	6371.91	327.6	828.8	23759.8
	10	558.382	574,666	502.5	157650.1	2535.32	463.5	1172.6	33617.2
	11	412.050	424,067	370.8	116335.6	2259.07	342.0	865.3	24807.3
	12	316.606	325,839	284.9	89388.6	2775.45	262.8	664.9	19061.1
	Total	5750.345	5,877,346	5,139.6	1,612,351.8	59,419.72	4,740.1	11,992.8	343817
	Ave	4,419.527	4,545,200	3,984	1,246,364	45,614	3,674	9,295	265888
2013	1	508.25	533,662	457.42	146223.3	2,533.56	421.85	1067.32	31218.5
	2	600.63	630,664	540.57	172801.8	2,959.25	498.52	1261.33	36893.0
	3	512.17	537,783	460.96	147352.7	2,537.59	425.10	1075.57	31459.6
	4	178.34	187,258	160.51	51308.66	1,683.98	148.02	374.52	10954.3
	5	513.69	539,377	462.32	147789.4	2,991.66	426.36	1078.75	31552.8



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
150

APPL NO.
See Below

PROCESSED BY
CP01


PAGES
212

DATE
6/7/16

CHECKED BY

	6	446.02	468,318	401.42	128319.2	2,892.26	370.19	936.64	27396.0
	7	597.57	627,451	537.82	171921.6	3,173.67	495.99	1254.90	36705.0
	8	724.55	760,783	652.10	208454.4	3,056.39	601.38	1521.57	44504.8
	9	530.87	557,416	477.78	152731.9	2,645.23	440.62	1114.83	32608.1
	10	168.77	177,203	151.89	48553.73	1,203.35	140.08	354.41	10366.1
	11	398.92	418,863	359.03	114768.4	2,540.20	331.10	837.73	24502.9
	12	130.09	136,600	117.09	37428.26	1,079.85	107.98	273.20	7990.9
	Total	5,310	5,575,377	4,779	1,527,653	29,297	4,407	11,151	326152
	Ave	5,330	5,726,362	4,959	1,570,002	44,358	4,574	11,572	334985
2014	1	70.77	74,308	63.69	20360.42	455.91	58.74	148.62	4346.9
	2	83.52	87,699	75.17	24029.44	528.73	69.32	175.40	5130.3
	3	219.43	230,400	197.49	63129.57	1,465.27	182.13	460.80	13478.1
	4	155.26	163,024	139.73	44668.49	1,123.73	128.87	326.05	9536.7
	5	259.35	272,317	233.41	74614.97	1,923.64	215.26	544.63	15930.2
	6	478.54	502,469	430.69	137676.5	3,157.34	397.19	1004.94	29393.8
	7	636.19	667,997	572.57	183031.1	3,946.20	528.04	1335.99	39076.9
	8	701.74	736,830	631.57	201891.4	4,593.78	582.45	1473.66	43103.6
	9	760.94	798,991	684.85	218923.4	5,083.86	631.58	1597.98	46739.9
	10	771.84	810,433	694.66	222058.8	4,868.91	640.63	1620.87	47409.2
	11	563.02	591,176	506.72	161982.2	3,511.95	467.31	1182.35	34583.0
	12	381.77	400,856	343.59	109834.4	2,266.17	316.87	801.71	23449.5
	Total	5,082	5,336,499	4,574	1,462,201	32,925	4,218	10,673	312178
	Ave	5,196	5,455,938	4,677	1,494,927	31,111	4,313	10,912	319165
2015	1	0.19	195	0.17	53.3204	4.53	0.15	0.39	11.4
	2	0	0	0.00	0	0.00	0.00	0.00	0.0
	3	298.95	313,897	269.05	86007.72	2,046.53	248.13	627.79	18362.6
	4	158.92	166,866	143.03	45721.26	1,399.00	131.90	333.73	9761.4
	5	130.24	136,757	117.22	37471.45	1,018.57	108.10	273.51	8000.1
	6	361.20	379,263	325.08	103918	3,203.22	299.80	758.53	22186.4
	7	512.35	537,969	461.12	147403.4	3,930.13	425.25	1075.94	31470.5
	8	629.81	661,302	566.83	181196.7	4,522.98	522.74	1322.60	38685.3
	9	549.81	577,299	494.83	158179.8	4,105.33	456.34	1154.60	33771.2
	10	445.31	467,571	400.77	128114.3	3,511.15	369.60	935.14	27352.3
	11	351.70	369,281	316.53	101183	3,394.97	291.91	738.56	21602.4
	12	435.97	457,764	392.37	125427.3	3,315.71	361.85	915.53	26778.6
	Total	3,874	4,068,162	3,487	1,114,676	30,452	3,216	8,136	237982
	Ave	4,478	4,702,331	4,031	1,288,439	31,689	3,717	9,405	275080

Average based on previous 2 years

	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 151	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

Appendix H

Modeling

The proposed projects will result in the release of 5 criteria pollutants plus toxics. Modeling is required to determine the impacts on ambient air quality and visibility from the release of NO_x, SO_x, CO, and PM₁₀. Also, a health risk assessment is required for toxics. Modeling for the criteria pollutant impacts was conducted based on both an individual and combined basis from the 4 new turbines and auxiliary boiler, and on an individual equipment basis for the HRA.

Meteorological data from the John Wayne airport station was used. Although the District's Costa Mesa meteorological station is closer to the project site, the data from the John Wayne airport station was deemed appropriate for this project because of the following factors:

- a) Surface characteristics at John Wayne airport are more similar to the project site
- b) John Wayne airport data is more current
- c) John Wayne airport has less missing data
- d) Costa Mesa data is problematic

Background concentrations were determined using the Costa Mesa station data, except for PM₁₀ and PM_{2.5}, which is from the Mission Viejo station.

The stack parameters and emission rates used in the modeling, and the model results are summarized in the following tables:

Criteria Pollutant Modeling

Start Up/Shutdown and Normal Operations

A screening level model was performed for 41 different load/ambient temperature/exhaust conditions as shown in Tables 1A and 1B.

Table H.2 outlines the stack locations and dimensions. Location and elevation is in reference to UTM North American Datum 1983 Zone 11 coordinate system.

Tables H.3A, H.3B, H.3C, and H.3D outline the emission rates used in the models. Note that the 1 hour NO₂ and CO model runs assume the CCTG in cold start up and the SCTG undergoing 1 start, 1 shutdown, and the remainder of the hour at full load steady state conditions. The 8 hour CO model run assumes the CCTG undergoes 2 cold starts, 2 shutdowns, and the remainder of the 8 hours at full load steady state conditions, and the SCTG undergoes 2 starts, 2 shutdowns, and the remainder of the



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
152

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

8 hours at full load steady state conditions. All PM10 and SOx runs assume full load steady state conditions, except the annual PM10 model run.

The annual NO2 and PM10 is based on 80 cold starts, 88 warm starts, 332 hot starts, 500 shutdowns, and 6,100 hours at full load steady state conditions at 65.8°F for the CCTG, 350 start ups, 350 shutdowns and 1,750 hours at full load steady state conditions at 65.8 °F for the SCTG, and 12 start ups and an annual heat input of 189,155 mmbtu for the auxiliary boiler.

Table H.1A
CCTG and SCTG Load Analysis

Temp	Scenario	CCTG			SCTG		
		Load	Exhaust Temp	Exit Velocity	Load	Exhaust Temp	Exit Velocity
32 °F	1	Max	375	20.4	Max	694	33.3
	2	Max	375	20.4	Ave	709	28.7
	3	Max	375	20.4	Min	748	23.8
	4	Ave	354	15.6	Max	694	33.3
	5	Ave	354	15.6	Ave	709	28.7
	6	Ave	354	15.6	Min	748	23.8
	7	Min	350	12.2	Max	694	33.3
	8	Min	350	12.2	Ave	709	28.7
	9	Min	350	12.2	Min	748	23.8
65.8 °F	10	Max w evap	374	20.1	Max w evap	697	33.1
	11	Max w evap	374	20.1	Max	699	33.0
	12	Max w evap	374	20.1	Ave	709	28.4
	13	Max w evap	374	20.1	Min	748	23.6
	14	Max	375	20.2	Max w evap	697	33.1
	15	Max	375	20.2	Max	699	33.0
	16	Max	375	20.2	Ave	709	28.4
	17	Max	375	20.2	Min	748	23.6
	18	Ave	353	14.9	Max w evap	697	33.1
	19	Ave	353	14.9	Max	699	33.0
	20	Ave	353	14.9	Ave	709	28.4
	21	Ave	353	14.9	Min	748	23.6
	22	Min	350	11.8	Max w evap	697	33.1
	23	Min	350	11.8	Max	699	33.0
	24	Min	350	11.8	Ave	709	28.4
	25	Min	350	11.8	Min	748	23.6
110 °F	26	Max w evap	378	20.2	Max w evap	726	29.4
	27	Max w evap	378	20.2	Max	746	27.1
	28	Max w evap	378	20.2	Ave	769	23.7
	29	Max w evap	378	20.2	Min	809	20.0
	30	Max	379	18.0	Max w evap	726	29.4
	31	Max	379	18.0	Max	746	27.1
	32	Max	379	18.0	Ave	769	23.7
	33	Max	379	18.0	Min	809	20.0
	34	Ave	365	13.9	Max w evap	726	29.4



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
153

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

	35	Ave	365	13.9	Max	746	27.1
	36	Ave	365	13.9	Ave	769	23.7
	37	Ave	365	13.9	Min	809	20.0
	38	Min	358	12.1	Max w evap	726	29.4
	39	Min	358	12.1	Max	746	27.1
	40	Min	358	12.1	Ave	769	23.7
	41	Min	358	12.1	Min	809	20.0

The Auxiliary Boiler was included in each run with the following parameters:

Table H.1B
Auxiliary Boiler

Temp, °F	Scenario	Load	Exhaust Temp, K	Exit Velocity, m/s
32/65.8/110	1-41	Max	432	21.2

Table H.2
Stack Locations and Dimensions All Sources

Equipment	Easting (m)	Northing (m)	Base Elevation (m)	Stack Ht (m)	Stack Dia (m)
7FA.05	409449	3723148	3.66	45.7	6.10
7FA.05	409474	3723182	3.66	45.7	6.10
LMS-100	409149	3723193	3.66	24.4	4.11
LMS-100	409185	3723168	3.66	24.4	4.11
Auxiliary Boiler	409438	3723236	3.66	24.4	0.91

Table H.3A
Short Term Emission Rates CCTG

Temp	1-Hour NO2 (lbs/hr)	1-Hour CO (lbs/hr)	8-Hour CO (lbs/hr)				1-Hour/3-Hour/24 Hour SOx (lbs/hr)				24-Hour PM10/PM2.5 (lbs/hr)
	All Loads	All Loads	Max*	Max	Ave	Min	Max*	Max	Ave	Min	All Loads
32	61.0	325	/////	121	119	118	/////	4.86	3.84	2.95	8.5
65.8	57.0	287	108	108	106	105	4.81	4.78	3.72	2.79	8.5
110	53.0	220	85.1	84.5	83.5	82.7	4.60	4.16	3.33	2.67	8.5

* With evaporative cooling



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
154

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

**Table H.3B
Short Term Emission Rates SCTG**

Temp	1-Hour NO ₂ (lbs/hr)				1-Hour CO (lbs/hr)				8-Hour CO (lbs/hr)				1-Hour/3-Hour/24 Hour SO _x				PM ₁₀
	Max*	Max	Ave	Min	Max*	Max	Ave	Min	Max*	Max	Ave	Min	Max*	Max	Ave	Min	All
32	//////	22.0	21.6	21.2	//////	45.8	45.3	44.9	//////	17.5	16.2	15.0	//////	1.63	1.32	1.02	6.24
65.8	22.1	22.0	21.6	21.2	45.8	45.7	45.3	44.9	17.5	17.4	16.2	15.0	1.64	1.61	1.31	1.01	6.24
110	21.7	21.5	21.2	20.9	45.4	45.2	44.9	44.6	16.4	15.8	15.0	14.1	1.36	1.22	1.01	0.80	6.24

* With evaporative cooling

**Table H.3C
Long Term Emission Rates CCTG and SCTG**

Temp 65.8°F	Annual NO _x (lbs/hr)				Annual PM ₁₀ /PM _{2.5} (lbs/hr)	
	Max*	Max	Ave	Min	All Loads	
CCTG	13.2	13.1	10.5	8.38	6.42	
SCTG	2.44	2.42	2.11	1.81	1.43	


* With evaporative cooling

**Table H.3D
Emission Rates Auxiliary Boiler**

1-Hour NO ₂ (lbs/hr)	1-Hour CO (lbs/hr)	8-Hour CO (lbs/hr)-	1-Hour/3-Hour SO _x (lbs/hr)	24 hour SO _x (lbs/hr)	24-Hour PM ₁₀ /PM _{2.5} (lbs/hr)	Annual NO _x (lbs/hr)	Annual PM ₁₀ /PM _{2.5} (lbs/hr)
0.42	2.83	2.37	0.048	0.025	0.157	0.15	0.15

**Table H.4
Model Results – Start up/Shutdown and Normal Operation (all 5 stacks combined)**

Pollutant	Averaging Period	Maximum Predicted Impact (ug/m ³)	Background Concentration (ug/m ³)	Total Concentration (ug/m ³)
NO ₂	1-hour	95	142	237
	1-hour Federal	27.8	98.2	126
	Annual	0.59	21.8	22.4
CO	1-hour	631	3,435	4,066
	8-hour	149	2,519	2,668
SO ₂	1-hour	5.76	23.1	28.9
	1-hour Federal	5.4	23.1	28.5
	3-hour	5.01	23.1	28.2
	24-hour	1.66	5.2	6.86
PM ₁₀	24-hour	4.7	51.0	55.7
	Annual	0.6	19.3	19.9
PM _{2.5}	24-hour Federal	4.7	21.3	26
	Annual	0.6	8.6	9.2

	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 155	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

The maximum 1 hour and annual NO₂ concentrations include ambient NO₂ ratios of 0.80 and 0.75 respectively.

Background concentrations for NO₂, CO, and SO₂ are the maximum recorded values for the Costa Mesa monitoring station, and for PM₁₀ and PM_{2.5} maximum recorded values from the Mission Viejo monitoring station, during the years 2011-2014, except for Federal 1-hour NO₂, and 24-hour PM_{2.5} which the background concentration is based on the 98th percentile of the 3-year average, and for Federal 1-hour SO₂, which the background concentration is based on the 99th percentile of the 3-year average (however, since the 3 most recent years were not available for SO₂, the maximum 1-hour concentration was used instead).

Commissioning

Six short term scenarios were modeled as shown in Table 5. Annual emissions were also modeled. The annual scenarios are shown in Table 6 and include 1) commissioning of the CCTGs with the balance of the year in normal operation (no SCTG operation), and 2) commissioning of the SCTGs with the balance of the year in normal operation, as well as the CCTG's in start up operation. All scenarios include the auxiliary boiler with emissions as shown in Table 3D and exhaust parameters as shown in Table 1B.

Table H.5
Commissioning Short Term Modeled Scenarios and Emission Rates

Turbine Operating Scenario	Pollutant	Averaging Period	Emissions Per Turbine, lbs/hr	
			Commissioning	Start Up
2 CCTG undergoing commissioning at 10% load	NO _x	1-hour	130	/////
	CO	1-hour	1900	/////
		8-hour	1900	/////
2 CCTG undergoing commissioning at 40% load	NO _x	1-hour	68.3	/////
2 CCTG undergoing commissioning at 80% load	NO _x	1-hour	63.0	/////
2 SCTG undergoing commissioning at 5% load with 2 CCTG in cold start up	NO _x	1-hour	40.1	61.0
	CO	1-hour	244	325
		8-hour	244	95.2
2 SCTG undergoing commissioning at 75% load with 2 CCTG in cold start up	CO	1-hour	72.5	325
		8-hour	72.5	95.2



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
156

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

2 SCTG undergoing commissioning at 100% load with 2 CCTG in cold start up	CO	1-hour	90.0	325
		8-hour	90.0	95.2

Table H.6
Commissioning Long Term Scenarios and Emission Rates

Turbine Operating Scenario	Averaging Time	Pollutant	Emissions Per Turbine, lbs/hr	
			CCTG	SCTG
2 CCTG commissioned with balance of year in normal operation	Annual	NOx	11.5	//////
		PM10/PM2.5	7.38	//////
2 SCTG commissioned with balance of year in normal operation and 2 CCTG in start up operation	Annual	NOx	8.12	2.76
		PM10/PM2.5	6.42	1.63

Table H.7
Commissioning Stack Parameters

Turbine Operating Scenario	Stack Temp, K	Exhaust Velocity, m/s
CCTG 10% Load	361	9.33
CCTG 40% Load	359	11.9
CCTG 80% Load	366	16.1
CCTG Annual	350	12.2
SCTG 5% Load	728	10.0
SCTG 75% Load	694	33.3
SCTG 100% Load	748	23.8



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
157

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table H.8
Model Results – CCTG Commissioning

Pollutant	Averaging Period	Maximum Predicted Impact (ug/m3)	Background Concentration (ug/m3)	Total Concentration (ug/m3)
NO2	1-hour	169	142	311
	Annual	0.66	21.8	22.5
CO	1-hour	4,341	3,435	7,776
	8-hour	3,000	2,519	5,519
PM10	Annual	0.57	19.3	19.9
PM2.5	Annual	0.57	8.6	9.2

Table H.9
Model Results – SCTG Commissioning

Pollutant	Averaging Period	Maximum Predicted Impact (ug/m3)	Background Concentration (ug/m3)	Total Concentration (ug/m3)
NO2	1-hour	79.1	142	221
	Annual	0.50	21.8	22.3
CO	1-hour	527	3,435	3,962
	8-hour	131	2,519	2,650
PM10	Annual	0.52	19.3	19.8
PM2.5	Annual	0.52	8.6	9.1

PSD

- Ambient Air Quality Impacts

The results of the operational impacts modeling were compared to the Class II significance impact levels (SILs), PSD Calls II Increment Standards, and Significant Monitoring Concentration. The model for 24 hour PM10 was re-run assuming 1 CCTG operating at minimum load for 20 hours, and average load for 4 hours, while the other CCTG operating at minimum load for 24 hours, with both SSTG operating at 50% load, and the AB operating at full load (assuming both CCTG's operating 24 hours at minimum load results in an impact greater than the SIL, see Table 4).



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
158

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table H.10

Model Inputs for 24 Hour PM10 for Comparison to PSD Thresholds

Source	Emission Rate, lbs/day	Stack Temp, K	Exhaust Velocity, m/s
CCTG 1 (20 hrs @44% Load) ¹	170	350	11.8
CCTG 1 (4 hrs @ 75% Load) ¹	34	353	14.9
CCTG 2 (24 hrs @44% Load) ¹	204	353	14.9
SCTG 1 (24 hrs @50% Load)	150	748	23.6
SCTG 2 (24 hrs @50% Load)	150	748	23.6
AB 100% Load	3.77	432	21.2

1 One CCTG assumed to operate at 44% load for 20 hrs/day and 75% load for 4 hrs/day, the other CCTG assumed to operate 24 hrs/day at 44% load. Both turbines were not assumed to operate at 44% load for 24 hours because this is an unlikely scenario.

Table H.11

Comparison of Modeled Results to PSD Significance Thresholds

Pollutant	Averaging Period	Maximum Predicted Impact (ug/m3)	Significant Impact Level (ug/m3)	PSD Class II Increment Standard (ug/m3)	Significant Monitoring Concentration (ug/m3)
NO2	1-hour	95	7.52	////////	////////
	Annual	0.59	1.0	25	14
CO	1-hour	631	2,000	////////	////////
	8-hour	149	500	////////	575
PM10	24-hour	4.7	5.0	30	10
	Annual	0.6	1.0	17	////////

The results show that the facility is required to conduct a cumulative modeling analysis for 1 hour NO2 since the operational impact is greater than the Class II SIL of 7.5 ug/m3. Tables 11A and 11B show the sources included in the cumulative analysis:



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
159

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table H.11A
Cumulative Analysis Stack Parameters and Emission Rates, Point Sources

Facility	Source	Emission Rate	Easting	Northing	Base Elevation	Stack Ht	Stack Dia	Stack Temp	Exit Velocity
		(Lbs/hr)	(m)	(m)	(m)	(m)	(m)	(K)	(m/s)
HBEP	CCTG 1	57.0	409449	3723146	3.66	45.7	6.10	350	11.8
	CCTG 2	57.0	409474	3723182	3.66	45.7	6.10	350	11.8
	SSTG 1	21.2	409149	3723193	3.66	24.4	4.11	748	23.6
	SSTG 2	21.2	409185	3723168	3.66	24.4	4.11	748	23.6
	AuxBoiler	0.42	409438	3723236	3.66	24.4	0.91	432	21.2
	Boiler 1	34.3	409274	3723095	3.66	61.0	6.27	367	7.90
OC Sanitation Fountain Valley	1730101	5.17	412962	3728359	8.00	7.41	2.23	1089	1.37
	1730102	0.08	412914	3728328	7.70	7.62	0.55	475	7.03
	1730103	7.78	412935	3728401	8.00	18.9	0.76	533	17.9
	1730104	7.78	412942	3728391	8.00	18.9	0.76	533	17.9
	1730105	7.78	412939	3728396	8.00	18.9	0.76	533	17.9
OC Sanitation Huntington Beach	2911001	0.6	411071	3722213	1.60	7.62	0.53	475	7.44
	2911002	0.87	411096	3722214	1.60	7.41	0.68	1089	1.37
	2911003	6.90	411240	3722455	1.60	18.0	0.76	589	22.9
	2911004	6.90	411248	3722455	1.60	18.0	0.76	589	22.9
	2911005	6.90	411255	3722455	1.60	18.0	0.76	589	22.9
	2911006	6.90	411263	3722455	1.60	18.0	0.76	589	22.9
	2911007	6.90	411270	3722455	1.60	18.0	0.76	589	22.9
BETA Offshore	16607301	15.1	395222	3716431	0	18.3	0.30	661	31.1
	16607302	15.1	395222	3716431	0	18.3	0.30	641	30.0
	16607303	15.1	395222	3716431	0	18.3	0.30	585	24.2
	16607304	15.1	394082	3717932	0	18.3	0.30	663	28.7
	16607305	15.1	394082	3717932	0	18.3	0.30	684	34.7
	16607306	15.1	394082	3717932	0	18.3	0.30	583	21.1
	16607307	2.94	395265	3716544	0	18.3	0.61	671	39.4
	16607308	2.46	395265	3716544	0	18.3	0.61	671	38.1
	16607309	2.78	395265	3716544	0	18.3	0.61	677	37.5
	16607310	20.0	395265	3716544	0	18.3	0.76	671	81.2
	16607311	19.7	395265	3716544	0	18.3	0.76	669	81.1
	16607312	19.7	395265	3716544	0	18.3	0.76	668	81.4
	16607313	81.6	395265	3716544	0	22.9	0.51	464	8.35

Table H.11B
Cumulative Analysis Stack Parameters and Emission Rates, Volume Sources

Facility	Source ID	Emission Rate	Base Elevation	Release Ht	Initial Horizontal Dimension	Initial Vertical Dimension
		(Lbs/hr)	(m)	(m)	(m)	(m)
Shipping Lanes (total for 525 sources)	734601-774425	202	0	0	186	23.3



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
160

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table H.12
Cumulative Analysis Results

Source/Year	2010	2011	2012	2013	2014
HBEP	75.4	71.0	73.2	74.1	76.0
HBGS	5.15	5.08	5.32	5.12	4.73
OCSFV	8.92	8.92	8.87	8.91	9.02
OCSHB	56.2	54.0	54.1	54.1	53.7
BETA	58.2	63.2	62.6	66.8	66.1
SHIPS	24.3	23.4	23.9	22.6	23.3
TOTAL PLUS BACKGROUND	140	147	148	143	144

The modeled concentration is the 8th high result. Model result is added to the 98th percentile seasonal hour-of-day background concentration for 2010 through 2012 to obtain total concentration.

- Class I Deposition and Visibility Analysis

Actual ambient air quality impacts at Class I areas were not determined. The nearest Class I areas to the project site are the Cucamonga Wilderness and the San Gabriel Wilderness, both 69 km away.

The applicant determined the following maximum predicted impacts for the project at 50 km.

Table H.13
Predicted Impacts at 50 km (all 5 stacks combined)

Pollutant	Averaging Time	Maximum Modeled Concentration at 50 km (ug/m3)	Significant Impact Level (ug/m3)	PSD Class I Increment Standard (ug/m3)
NO2	Annual	0.0057	0.1	2.5
PM10	24-hour	0.042	0.3	2.0
	Annual	0.0057	0.2	1.0

The analysis used the emission rates and stack parameters from Tables 1A, 1B, 2, 3A, 3B, 3C, and 3D which result in the worst case impacts for each source/pollutant/averaging time.

Since the impacts are all less than the SIL and Class I Increment Standard, the applicant concluded that the impacts at the more distant Class I areas would be negligible (AFC page 5.1-19 and Table 5.1-27).



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
161

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

A full visibility and deposition analysis for Class I areas was not conducted under PSD. The applicant cited a screening criteria under FLAG 2010 which states that for sources > 50km from a Class I area, if Q/D is < 10, no analysis is required. Q is the sum of the annual NO_x, SO₂, H₂SO₄, and PM₁₀ in tons from the project, estimated to be 420 tpy. D would be the distance in km to the nearest Class I area (in this case Cucamonga and San Gabriel Wilderness at 69 km). Approximate Q/D is 6.1.

- Class II Visibility Analysis

A visibility analysis was conducted on nearby Class II areas using VISCREEN. Most areas were shown to meet the color difference and contrast criteria using a Level I analysis. Because Crystal Cove State Park and Huntington Beach State Park results were greater than the criteria levels (Color Difference -2, Contrast – 0.05), they were further analyzed using a Level II analysis. Crystal Cove results were less than the criteria thresholds using the Level II analysis, while Huntington Beach State Park results were above the criteria thresholds.

Table 14 shows the emission rates used in the analysis, Tables 15A and 15B show the results.

Table H.14
VISCREEN Emission Rates

Pollutant	Emissions, tpy
NO ₂	136
PM ₁₀	69.4

Table H.15A
Class II Level I Visibility Results

Class II Area	Variable	Sky	Terrain
Crystal Cove	Color	2.510	5.419
	Contrast	0.03	0.029
Water Canyon	Color	1.11	1.658
	Contrast	0.013	0.014
Chino Hills State Park	Color	0.912	1.525
	Contrast	0.011	0.014
San Mateo Canyon Wilderness Area	Color	0.703	1.113
	Contrast	0.008	0.011

Note:

Criteria Levels for Class I areas:

Color Difference – 2

Contrast – 0.05



**South Coast
Air Quality Management District**
Engineering Division
Application Processing & Calculations

PAGE 162	PAGES 212
APPL NO. See Below	DATE 6/7/16
PROCESSED BY CP01	CHECKED BY

Table H.15B
Class II Level II Visibility Results

Class II Area	Stability Class	Variable	Sky	Terrain
Crystal Cove	D	Color	0.265	0.644
		Contrast	0.003	0.003
Huntington Beach State Park	A	Color	7.889	////////
		Contrast	0.139	////////
	B	Color	10.162	////////
		Contrast	0.182	////////
	C	Color	5.976	////////
		Contrast	0.076	////////
	D	Color	7.659	////////
		Contrast	0.098	////////

Note:

Criteria Levels for Class I areas:

Color Difference – 2

Contrast – 0.05

Health Risk Assessment

Air Toxics Health Risk Assessment (HRA)

A Tier 4 HRA was performed for the project using CARB's Hotspots Analysis and Reporting Program (HARP 2).

Table H.16
Modeled Stack Parameters for HRA

Source	Load ¹ , %	Stack Temp, K	Exhaust Velocity, m/s
CCTG	44	350	11.8
SCTG	50	748	23.6
AB	////////	432	21.2

¹ The load percentage is only used to determine stack parameters, not emission rates. Emission rates are based on 100% load, see Tables 17 and 18.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
163

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table H.17
Gas Turbine Toxic Emission Rates

Pollutant	Emission Factor	Emissions per CCTG Turbine ⁽¹⁾		Emissions per SCTG Turbine ⁽²⁾	
	lbs/mmbtu	lbs/hr	lbs/yr	lbs/hr	lbs/yr
Ammonia	5 ppm	15.2	100,928	6.14	12,286
Acetaldehyde	1.71E-04	3.89E-01	2552.5	1.51E-01	212.0
Acolein	3.51E-06	7.98E-03	52.4	3.11E-03	4.4
Benzene	3.17E-06	7.21E-03	47.3	2.81E-03	3.9
1,3 Butadiene	4.18E-07	9.50E-04	6.2	3.70E-04	0.5
Ethyl Benzene	3.11E-05	7.07E-02	464.2	2.75E-02	38.6
Formaldehyde	3.50E-04	7.96E-01	5224.4	3.10E-01	434.0
Naphthalene	1.26E-06	2.86E-03	18.8	1.12E-03	1.6
PAH	8.74E-07	1.99E-03	13.0	7.73E-04	1.1
Propylene Oxide	2.82E-05	6.41E-02	420.9	2.50E-02	35.0
Toluene	1.26E-04	2.86E-01	1880.8	1.12E-01	156.2
Xylene	6.22E-05	1.41E-01	928.4	5.50E-02	77.1

(1) Hourly emission rates based on 2,273 mmbtu/hr (maximum heat input at low temp), annual emission rates based on 2,248 mmbtu/hr (heat input annual average temp) and 6,640 hours/yr operation (6,100 hours normal operation plus 500 start ups and shutdowns)

(2) hourly and annual emission rates based on 885 mmbtu/hr and 2001 hours/yr operation (1,750 hours normal operation and 350 start ups and shutdowns)

Table H.18
Auxiliary Boiler Toxic Emission Rates

Pollutant	Emission Factor	Emissions ⁽¹⁾	
	lbs/mmbtu	lbs/hr	lbs/yr
Benzene	5.52E-06	3.91E-04	1.04E+00
Formaldehyde	1.17E-05	8.29E-04	2.21E+00
PAHs	9.52E-08	6.74E-06	1.80E-02
Naphthalene	2.86E-07	2.02E-05	5.41E-02
Acetaldehyde	2.95E-06	2.09E-04	5.58E-01
Acrolein	2.57E-06	1.82E-04	4.86E-01
Toluene	2.52E-05	1.79E-03	4.77E+00
Xylene	1.88E-05	1.33E-03	3.56E+00
Ethylbenzene	6.57E-06	4.65E-04	1.24E+00
Hexane	4.38E-06	3.10E-04	8.28E-01

(1) Hourly emission rates based on 71 mmbtu/hr, annual emission rates based on 189,155 mmbtu/hr



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
164

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table H.19A

Model Results – HRA CCTG (individual unit)

Receptor	Cancer Risk Per Million	Chronic Hazard Index	Acute Hazard Index
Maximum Impact	2.38	0.0060	0.032
MEIR	1.36	0.0035	0.0090
MEIW	0.086	0.0060	0.091
Sensitive receptor	0.74	0.00346	0.032

Table H.19B

Model Results – HRA SCTG (individual unit)

Receptor	Cancer Risk Per Million	Chronic Hazard Index	Acute Hazard Index
Maximum Impact	0.086	0.00022	0.0017
MEIR	0.059	0.00015	0.0012
MEIW	0.003	0.00022	0.0017
Sensitive receptor	0.1	0.00012	0.00070

Table H.19C

Model Results – HRA AB

Receptor	Cancer Risk Per Million	Chronic Hazard Index	Acute Hazard Index
Maximum Impact	0.18	0.0005	0.0011
MEIR	0.026	0.00008	0.0003
MEIW	0.004	0.0005	0.001
Sensitive receptor	0.03	0.00008	0.0003



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
165

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Appendix I

Greenhouse Gases

Out of the six GHG pollutants:

carbon dioxide, CO₂,
methane, CH₄,
nitrous oxide, N₂O
hydrofluorocarbons, HFCs
perfluorocarbons, PFCs
sulfur hexafluoride, SF₆

Only the first 3 are emitted by combustion sources. Sulfur hexafluoride can be emitted by circuit breakers.

The following emission factors and global warming potential (GWP) will be used in the calculations:

Table I.1 GHG Emission Factors

GHG	Emission Factor, natural gas		GWP
	kg/mmbtu	lbs/mmcf	
CO ₂	53.06	120,017	1.0
CH ₄	1.0E-03	2.26	25
N ₂ O	1.0E-04	0.226	298

The emission factors in kg/mmbtu are converted to lbs/mmcf assuming the default HHV of 1026 btu/cf from 40 CFR98 Subpart C Table C-1. 1 kg = 2.2046 lbs.

CO₂ equivalent (CO₂e) is calculated using the following equation:

$$\text{CO}_2\text{e} = \text{CO}_2 + 25 \cdot \text{CH}_4 + 298 \cdot \text{N}_2\text{O}$$

Or, using fuel consumption (F):

$$\text{CO}_2\text{e} = 120,017 \cdot F + 2.26 \cdot 25 \cdot F + 0.226 \cdot 298 \cdot F = 120,141 \cdot F \text{ (in lbs)}$$

$$\text{CO}_2\text{e} = 60.070 \cdot F \text{ (in tons)}$$

Existing Sources

There are 2 existing sources of GHG emissions at the Huntington Beach site, Boilers 1 and 2. The following data will be used in the GHG PTE calculations for these units:

PTE



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
166

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Maximum Rating

Boiler 1 2021 mmbtu/hr, 8,760 hrs/yr

Boiler 2 2021 mmbtu/hr, 8,760 hrs/yr

Table I.2 Boilers 1 and 2 GHG PTE

Pollutant	Boiler 1, tons		Boiler 2, tons	
	Hourly	Annual	Hourly	Annual
CO2	118.2	1,035,432	118.2	1,035,432
CH4	2.23E-03	19.5	2.23E-03	19.5
N2O	2.23E-04	1.95	2.23E-04	1.95
Total Mass	118.2	1,035,453	118.2	1,035,453
CO2e	118.3	1,036,503	118.3	1,036,503

Actual Emissions

The data from Appendix G is used to calculate the past actual emissions.

Table I.3 Boilers 1 and 2 GHG Actual Emissions

	2011	2012	2013	2014	2015
Boiler 1					
heat input, mmbtu	2,837,549	2,828,058	3,660,402	4,484,724	3,940,906
CO2, lbs	331,925,348	330,815,128	428,179,463	524,605,415	460,991,720
CH4, lbs	6255.7	6234.7	8069.7	9887.0	8688.1
N2O, lbs	625.6	623.5	807.0	988.7	868.8
Total Mass, tons	165,966	165,411	214,094	262,308	230,501
CO2e, tons	166,134	165,578	214,311	262,574	230,734
Boiler 2					
heat input, mmbtu	3,213,053	5,877,346	5,575,377	5,336,499	4,068,162
CO2, lbs	375,850,332	687,508,872	652,185,724	624,242,713	475,877,627
CH4, lbs	7083.5	12957.2	12291.5	11764.8	8968.7
N2O, lbs	708.3	1295.7	1229.1	1176.5	896.9
Total Mass, tons	187,929	343,762	326,100	312,128	237,944
CO2e, tons	188,119	344,109	326,430	312,444	238,185

New Sources

Combined Cycle Turbines

PTE –

The GHG potential to emit is based on heat input at baseload conditions (highest efficiency)


 South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 167	PAGES 212
	APPL NO. See Below	DATE 6/7/16
	PROCESSED BY CP01	CHECKED BY

Table I.4 – Combined Cycle Turbines Heat Input

Hourly Heat Input	2,273 mmbtu/hr	Based on low temperature conditions
Annual Heat Input	14,926,720 mmbtu/yr	Based on 2,248 mmbtu/hr (site average temperature conditions) and 6640 hrs/yr operation (includes start ups and shutdowns)

Table I.5 Combined Cycle Turbines GHG PTE

GHG	Hourly Tons Per Turbine	Annual Tons Per Turbine	Annual Tons 2 Turbines
CO2	132.9	873,034.6	1,746,069.1
CH4	2.51E-03	16.45	32.9
N2O	2.51E-04	1.65	3.29
Total Mass	132.9	873,052.7	1,746,105.3
CO2e	133.1	873,937.6	1,747,872.5

Estimated Actual Emissions

The analysis of the projected actual GHG emissions over the course of the year considers all operating modes, including baseload, non-baseload, start ups, and shutdowns. This is essentially a calculation of the estimated efficiency of the turbine under actual operating conditions over the course of a year in order to determine the GHG emitted per MW. In order to make this determination, assumptions have to be made as to the number of hours in non-baseload operation, as well as the heat rates during starts and shutdowns.

Table I.6 Combined Cycle Heat Rate Data 1X1 Configuration

1X1 Configuration	Minimum CT Turndown (approx. 44%)	First Intermediate Point (approx. 63%)	Second Intermediate Point (approx. 81%)	Baseload (100%)
Net Plant Output (kW)	167,083	214,510	267,595	326,268
Gross Plant Output (kW)	177,553	277,169	280,534	339,854
Net Plant Heat Rate LHV (btu/kWh)	7,132	6,413	6,281	6,190
Gross Plant Heat Rate LHV (btu/kWh)	6,711	6,056	5,992	5,942
Net Plant Heat Rate HHV (btu/kWh)	7,913	7,116	6,970	6,868



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
168

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table I.7 Combined Cycle Heat Rate Data 2X1 Configuration

2X1 Configuration	Minimum CT Turndown (approx. 44%)	First Intermediate Point (approx. 63%)	Second Intermediate Point (approx.. 81%)	Baseload (100%)
Net Plant Output (kW)	347,857	444,518	547,347	661,631
Gross Plant Output (kW)	366,550	464,168	568,112	683,675
Net Plant Heat Rate LHV (btu/kWh)	6,851	6,190	6,142	6,105
Gross Plant Heat Rate LHV (btu/kWh)	6,502	5,928	5,917	5,908
Net Plant Heat Rate HHV (btu/kWh)	7,602	6,868	6,815	6,774

Table I.8 Combined Cycle Heat Rate Summary

Operating Mode		Hours/Yr	Net Heat Rate Btu/kWhr	Notes
Baseload	1X1	1200	7,217	Average net at HHV from Table I.6
Baseload	2X1	4900	7,015	Average net at HHV from Table I.7
Start ups	A. First fire to baseload	219	19,783	The annual start up time is based on 1) the permitted annual start ups and 2) the assumption that it takes 33 minutes from first fire to baseload for a cold start and 25 minutes from first fire to baseload for a non-cold start. The heat rate is assumed to be 2.5 times the 44% load net heat rate at HHV for 1X1 configuration
	B. Baseload to completion	71	7,217	This is the time after the unit reaches baseload to completion of the start (27 minutes for cold start and 5 minutes for non-cold). For simplicity, the heat rate is assumed to be the same as 1X1 configuration.
Shutdowns	Baseload to zero fuel flow	250	11,870	The shutdown time is based on 500 annual shutdowns and 30 minutes from baseload to zero fuel flow. The heat rate is assumed to be 1.5 times the 44% load net heat rate at HHV for 1X1 configuration.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE 169	PAGES 212
APPL NO. See Below	DATE 6/7/16
PROCESSED BY CP01	CHECKED BY

The overall weighted average heat rate is obtained by taking the average heat rate for each configuration multiplied by the hours of operation per configuration, and dividing by the total annual hours of operation. The GHG emissions are then calculated based on the average heat rate.

Overall net heat rate = $[(\text{Avg Heat Rate 1X1 Config} * \# \text{ of Hours for 1X1 Config}) + (\text{Avg Heat Rate 2X1 Config} * \# \text{ of Hours 2X1 Config}) + (\text{Start Heat Rate A} * \# \text{ of Hours Start Up A}) + (\text{Start Heat Rate B} * \# \text{ of Hours Start Up B}) + (\text{Shutdown Heat Rate} * \# \text{ of Hours Shutdowns})] / \text{Total Annual Hours of Operation}$

Overall net heat rate = $(7217 \text{ btu/kWh} * 1200 \text{ hrs} + 7015 \text{ btu/h} * 4900 \text{ hrs} + 19783 \text{ btu/kWh} * 219 \text{ hrs} + 7217 \text{ btu/kWh} * 71 \text{ hrs} + 11870 \text{ btu/kWh} * 250 \text{ hrs}) / (6640) = 7657.6 \text{ btu/kWh}$

CO2

$7657.6 \text{ btu/kWh} * 1000 \text{ kWh/MWh} * 1 * 10\text{E-}06 \text{ MMBtu/Btu} * 53.06 \text{ kg CO}_2/\text{MMBtu-HHV} * 2.205 \text{ lb/kg} = 895.9 \text{ lb CO}_2/\text{MWH}$

895.9 lb CO2/netMWH @ HHV (no equipment degradation)

Assuming an 8% equipment degradation, the estimated heat rate and CO2 emissions are

Heat Rate with equipment degradation	$7657.6 \text{ btu/kw-hr} * 1.08 =$	8270.2 btu/kw-hr
CO2 with equipment degradation	$895.9 * 1.08 =$	967.6 lb CO2/netMWH @ HHV

Simple Cycle Turbines

PTE –

The GHG potential to emit is based on heat input at baseload conditions (highest efficiency)



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
170

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table I.9 – Simple Cycle Turbines Heat Input

Hourly Heat Input	885 mmbtu/hr	Based on site average temperature conditions
Annual Heat Input	1,770,885 mmbtu/yr	Based on 885 mmbtu/hr (site average temperature conditions) and 2001 hrs/yr operation (includes start ups and shutdowns)

Table I.10 Simple Cycle Turbines GHG PTE

GHG	Hourly Tons Per Turbine	Annual Tons Per Turbine	Annual Tons 2 Turbines
CO2	51.8	103,575.5	207,151.1
CH4	9.75E-04	1.96	3.91
N2O	9.75E-05	0.20	0.40
Total Mass	51.8	103,577.7	207,155.4
CO2e	51.9	103,684.1	207,368.1

Estimated Actual Emissions

The analysis of the projected actual GHG emissions over the course of the year considers all operating modes, including baseload, non-baseload, start ups, and shutdowns. This is essentially a calculation of the estimated efficiency of the turbine under actual operating conditions over the course of a year in order to determine the GHG emitted per MW. In order to make this determination, assumptions have to be made as to the number of hours in non-baseload operation, as well as the heat rates during starts and shutdowns.

Table I.11 Simple Cycle Heat Rate Data

	50% Load	75% Load	Baseload (100%)
Net Turbine Output (kW)	47,476	72,448	99,355
Gross Turbine Output (kW)	48,935	73,908	100,814
Net Turbine Heat Rate LHV (btu/kWh)	10,394	8,801	8,027
Gross Turbine Heat Rate LHV (btu/kWh)	10,084	8,627	7,911
Net Turbine Heat Rate HHV (btu/kWh)	11,533	9,765	8,907



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
171

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table I.12 Simple Cycle Heat Rate Summary

Operating Mode		Hours/Yr	Net Heat Rate Btu/kWh	Notes
Baseload		1750	10,068	Average net at HHV from Table I.11
Start ups	A. First fire to baseload	60	28,833	The annual start up time is based on 1) the permitted annual start ups and 2) the assumption that it takes 10.2 minutes from first fire to baseload. The heat rate is assumed to be 2.5 times the 50% load net heat rate at HHV.
	B. Baseload to completion	115	10,068	This is the time after the unit reaches baseload to completion of the start (19.8 minutes).
Shutdowns	Baseload to zero fuel flow	76	17,300	The shutdown time is based on 350 annual shutdowns and 13 minutes from baseload to zero fuel flow. The heat rate is assumed to be 1.5 times the 50% load net heat rate at HHV.

The overall weighted average heat rate is obtained by taking the average heat rate for each configuration multiplied by the hours of operation per configuration, and dividing by the total annual hours of operation. The GHG emissions are then calculated based on the average heat rate.

Overall net heat rate = $\frac{[(\text{Avg Heat Rate Baseload} * \# \text{ of Hours for Baseload}) + (\text{Start Heat Rate A} * \# \text{ of Hours Start Up A}) + (\text{Start Heat Rate B} * \# \text{ of Hours Start Up B}) + (\text{Shutdown Heat Rate} * \# \text{ of Hours Shutdowns})]}{\text{Total Annual Hours of Operation}}$

Overall net heat rate = $\frac{(10068 \text{ btu/kWh} * 1750 \text{ hrs} + 28833 \text{ btu/h} * 60 \text{ hrs} + 10068 \text{ btu/kWh} * 115 \text{ hrs} + 17300 \text{ btu/kWh} * 76 \text{ hrs})}{(2001)} = 10,905 \text{ btu/kWh}$

CO2

$10,905 \text{ btu/kWh} * 1000 \text{ kWh/MWh} * 1 * 10\text{E-}06 \text{ MMBtu/Btu} * 53.06 \text{ kg CO}_2/\text{MMBtu-HHV} * 2.205 \text{ lb/kg} = 1275.9 \text{ lb CO}_2/\text{MWH}$

1275.9 lb CO2/netMWH @ HHV (no equipment degradation)

Assuming an 8% equipment degradation, the estimated heat rate and CO2 emissions are

Heat Rate with equipment degradation $10905 \text{ btu/kw-hr} * 1.08 = 11,777 \text{ btu/kw-hr}$
CO2 with equipment degradation $1275.9 * 1.08 = 1378.0 \text{ lb CO}_2/\text{netMWH @ HHV}$



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
172

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Auxiliary Boiler

The following data is used in the calculation:

Maximum Rating = 71 mmbtu/hr
Maximum Hour/Day Operation = 24
Maximum Heat Input/yr = 189,155 mmbtu (includes start ups and shutdowns)

The following emission factors are from EPA (2009 FR *Mandatory Reporting of Greenhouse Gases, Final Rule*)

Pollutant	Factor
	kg/mmbtu
CO2	53.06
CH4	1.0E-03
N2O	1.0E-04

Table I.13 Auxiliary Boiler GHG Emissions

Pollutant	Emissions		
	lbs/hr	lbs/day	tons/yr
CO2	5067.0	121,609.03	11,065.31
CH4	9.58E-02	2.30	0.21
N2O	9.58E-03	0.23	0.02
Total Mass	5,066.83	121,611.11	11,065.56
CO2e	5,071.90	121,726.03	11,075.93



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
173

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

- SF6

There are 10 circuit breakers at the AES HB facility. The leak rate is assumed to be 0.5 percent per year. The estimated SF6 mass emissions are 6.3 pounds per year. This is equivalent to 71.8 tons per year of CO2e assuming a global warming potential for SF6 of 22,800.

AEC Electric Breakers	Total SF6 (lbs)	Annual SF6 Emissions (lbs/yr)
1200A 230kV	230	1.15
1200A 230kV	230	1.15
1200A 230kV	230	1.15
3000A 230kV	230	1.15
10000A 18kV	25	0.125
10000A 18kV	25	0.125
10000A 18kV	25	0.125
2000A 230kV	216	1.08
GCB 13.8kV	24	0.12
GCB 13.8kV	24	0.12
TOTAL		6.3




**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE 174	PAGES 212
APPL NO. See Below	DATE 6/7/16
PROCESSED BY CP01	CHECKED BY

Appendix J – Facility Plot Plan






**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations


PAGE 175	PAGES 212
APPL NO. See Below	DATE 6/7/16
PROCESSED BY CP01	CHECKED BY

Appendix K – Elevation Views

Looking East



Looking North






**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations


PAGE 176
APPL NO. See Below
PROCESSED BY CP01

PAGES 212
DATE 6/7/16
CHECKED BY

Looking South



Looking West





South Coast
Air Quality Management District

Engineering Division
Application Processing & Calculations

PAGE
177

APPL NO.
See Below


PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Appendix L – Process Flow



PROCESS FLOW DIAG
POWER BI

San Gabriel Generating
April 2007
28067169

URS

FIGURE

Source:
Sargent & Lundy, 150406, ehwaia_pjld.dgn

280671 rev. 1/Heat Emission/Process2/Fully Developed/2.5_pjld.dgn



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
178

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Appendix M

Nearest Schools

The following schools (K-12) were determined to be located within the vicinity of the proposed project:


	School	Location	Approx Distance from HBEP
1	Edison High	21400 Magnolia St	0.6 miles NE
2	William E Kettler School	8750 Dorsett Dr	0.65 miles NE
3	John H Eader School	9291 Banning Ave	0.91 miles SE
4	John R Peterson Elementary	20661 Farnsworth Lane	1.18 miles NW
5	Brethren Christian Jr/Sr High	21141 Strathmoor Lane	1.39 miles NE
6	St Simon and St Jude Elementary	20400 Magnolia St	1.14 miles NE
7	Sacred Heart Institute School	419 Main St	1.45 miles NW
8	Isaac L Sowers Middle School	9300 Indianapolis Ave	1.48 miles NE
9	S A Moffett Elementary	8900 Burlcrest Dr	1.5 miles N
10	Robert H Burke School	9700 Levee Dr	1.57 miles NE



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE 179	PAGES 212
APPL NO. See Below	DATE 6/7/16
PROCESSED BY CP01	CHECKED BY





**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
180

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Appendix N

Facility Reported Emissions

The following tables summarize the annual emissions reported to SCAQMD by the facility for the most recent 2 year period available:

Table N.1 Reported Criteria Emissions

Pollutant	Emissions, tpy	
	2014	2015
NO _x	31.737	30.288
CO	762.369	353.972
VOC	5.851	4.815
PM ₁₀	9.356	7.474
SO _x	3.962	2.434

Table N.2 Reported Toxic Emissions

Pollutant	Emissions, lbs/yr	
	2014	2015
Ammonia	29681.74	10894.0
Benzene	16.305	13.389
Formaldehyde	35.052	29.013
Naphthalene	2.838	2.292
PAHs	0.96	0.784
1,3 Butadiene	0.185	0.294

These emissions are for the total facility and include operation of the utility boilers, the 2 emergency generators, and smaller unpermitted equipment used at the site.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
181

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Appendix O

Major Source Determinations

1. PSD

For purposes of PSD, the major source threshold for a fossil fuel fired steam electric plant with a heat input greater than 250 mmbtu/hr is the actual or potential to emit 100 tpy of any regulated NSR pollutant less any emission reduction from shutdown or modification. If the existing source exceeds 100 tpy on a pollutant specific basis, it is deemed to be an existing major source. In that case, if the modification to the existing major source is a major modification, the new source is subject to PSD. In the case of an existing minor source, if the new source 'in and of itself' is major, ie > 100 tpy, (without netting), PSD is applicable. For GHG emissions, the major source threshold is EITHER 75,000 tpy CO₂e AND a net increase greater than 0 tpy total GHG mass if the source is subject to PSD for another regulated pollutant ('anyway' sources). Or, for an existing major source of GHG's, the modification is major if it results in an increase of 75,000 tpy CO₂e AND a net increase of GHG mass greater than 0 tpy. For an existing minor source of GHG's, the modification is major if it results in an increase of 100,000 tpy CO₂e AND a net increase greater than 100 tpy GHG.

Existing Facility

The PTE of the existing facility is summarized in Table O.1, and is calculated using the following data:

Boiler 1:

Rating	=	2021 mmbtu/hr
Fuel use	=	1.92 mmscf/hr (@ 1050 btu/scf)
Exhaust Flow	=	29 mmscf/hr (from 2001 source test)
NO _x conc	=	7 ppm (use molar volume of 379 lb-lb-mole)
CO E.F.	=	0.274 lbs/mmbtu (from Table G.1)
VOC E.F.	=	1.64 lbs/mmscf (from Table G.1)
SO ₂ E.F.	=	0.83 lbs/mmscf (from Table G.1)
PM _{2.5} E.F.	=	1.86 lbs/mmscf (from Table G.1)
GHG E.F.	=	53.06 kg/mmbtu CO ₂ , 1E-03 kg/mmbtu CH ₄ , 1E-04 kg/mmbtu N ₂ O

Boiler 2:

Rating	=	2021 mmbtu/hr
Fuel use	=	1.92 mmscf/hr (@ 1050 btu/scf)
Exhaust Flow	=	29 mmscf/hr (from 2001 source test)



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
182

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

NOx conc. = 7 ppm (use molar volume of 379 lb-lb-mole)
 CO E.F. = 0.274 lbs/mmbtu (from Table G.1)
 VOC E.F. = 0.9 lbs/mmcf (from Table G.1)
 SO2 E.F. = 0.83 lbs/mmcf (from Table G.1)
 PM2.5 E.F. = 2.1 lbs/mmcf (from Table G.1)
 GHG E.F. = 53.06 kg/mmbtu CO2, 1E-03 kg/mmbtu CH4, 1E-04 kg/mmbtu N2O

Table O.1 Existing Facility Major Source Determination (PTE)

Pollutant	PTE, tpy		Total	Major Source?
	Boiler 1	Boiler 2		
NOx	107.8	107.8	215.6	Y
CO	2,415	2,415	4,830	Y
VOC	13.8	7.6	21.4	N
PM10/2.5	15.6	17.7	33.3	N
SO2	7.0	7.0	14.0	N
CO2e	1,029,792	1,029,792	2,059,584	Y

Table O.2 New Facility Major Source Determination (PTE)

Pollutant	PTE, tpy				Major Source?
	CCTG 1&2	SCTG 1&2	Aux Boiler	Total	
NOx	119.5	21.3	0.7	141.5	Y
CO	212.3	29.3	3.8	245.4	Y
VOC	64.8	6.1	0.5	71.4	N
PM10	56.44	12.5	0.7	69.6	N
PM2.5	56.44	12.5	0.7	69.6	N ¹
SOx	9.96	1.20	0.2	11.36	N
CO2e	1,747,873	207,368	11,076	1,966,317	Y

¹ The major source threshold for PM2.5 under Rule 1325/40CFR 51 Appendix S is 70 tpy for areas of severe non-attainment

Combined cycle Turbines

NOx = 6,100 hrs *(16.8 lbs/hr) + 80 cold starts (61 lbs/start) + 88 warm starts (17 lbs/start) + 332 hot starts (17 lbs/start) + 500 shutdowns (10 lbs/shutdown)

PM2.5 = 6,100 hrs (8.5 lbs/hr) + 80 cold starts (8.5 lbs/start) + 88 warm starts (4.25 lbs/start) + 332 hot starts (4.25 lbs/start) + 500 shutdowns (4.25 lbs/shutdown)

Simple Cycle Turbines

NOx = 1,750 hrs *(8.2 lbs/hr) + 350 starts (16.6 lbs/start) + 350 shutdowns (3.12 lbs/shutdown)



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
183

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

PM2.5 = 1,750 hrs (6.24 lbs/hr) + 350 starts (3.12 lbs/start) + 350 shutdowns (1.35 lbs/shutdown)

For purposes of determining the net emissions increase for PSD and Rule 1325/40CFR 51 Appendix S, the actual emissions of the existing equipment to be shutdown (Boilers 1&2) is subtracted from the PTE of the new equipment (CCTG 1&2, SCTG 1&2, Auxiliary Boiler). This calculation needs to be applied to NO_x, CO, and GHGs since the existing source is considered major for these 3 pollutants only.

Table O.3 New Facility Significant Increase Determination (PTE vs Past Actual)

	NO _x , tpy	CO, tpy	CO _{2e}
HBEP PTE	141.5	245.4	1,965,939
HB Boilers 1&2 Past Actual	42.6	1,221	521,524
Net Increase	98.9	0	1,444,415

Past actuals from Appendix G for years 2014 and 2015

2. 40CFR 64 CAM

The CAM Regulations of 40CFR 64 apply on a pollutant specific basis to units at major sources required to obtain a part 70 or 71 permit which have pre-control potential to emit (PTE) emission levels exceeding the major source thresholds.

Table O.4 Combined Cycle Turbine Emission Rates

	NO _x	CO	VOC	PM ₁₀	SO _x
Normal Operations Uncontrolled (lbs/hr)	75.4	51.0	5.8	8.5	1.5
Cold Start (total lbs)	61.0	325.0	36.0	8.5	1.5
Warm Start (total lbs)	17.0	137.0	25.0	4.25	0.75
Hot Start (total lbs)	17.0	137.0	25.0	4.25	0.75
Shutdown (total lbs)	10.0	133.0	32.0	4.25	0.75

Table O.5 Combined Cycle Turbine Annual Operating Schedule

Event	# Per Year	Duration/event	Duration/yr, hrs
Cold Start	80	1 hour	80
Warm Start	88	30 minutes	44
Hot Start	332	30 minutes	166
Shutdown	500	30 minutes	250
100% Load @ 65.8 deg F	//////////	//////////	6100
		Total Hrs	6640



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
184

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table O.6 Combined Cycle Turbine Pre Control Annual PTE and Major Source Determination

Pollutant	Annual Uncontrolled Emissions, 1 CCTG		Threshold	Major Source?
	Lbs/yr	Tpy	Tpy	
NO _x	476,960	238.5	10	Y
CO	461,140	230.6	50	Y
VOC	64,760	32.4	10	Y
PM ₁₀	56,440	28.2	70	N
SO _x	9,960	5.0	100	N

Table O.7 Simple Cycle Turbine Emission Rates

	NO _x	CO	VOC	PM ₁₀	SO _x
Normal Operations Uncontrolled (lbs/hr)	82.0	198.5	2.3	6.24	0.60
Start (total lbs)	16.6	15.4	2.8	3.12	0.30
Shutdown (total lbs)	3.12	28.9	3.06	1.35	0.13

Table O.8 Simple Cycle Turbine Annual Operating Schedule

Event	# Per Year	Duration/event	Duration/yr, hrs
Start	350	30 minutes	175
Shutdown	350	13 minutes	76
100% Load @ 65.8 deg F	//////////	//////////	1750
		Total Hrs	2001

Table O.9 Simple Cycle Turbine Pre Control Annual PTE and Major Source Determination

Pollutant	Annual Uncontrolled Emissions, 1 SCTG		Threshold	Major Source?
	Lbs/yr	Tpy	Tpy	
NO _x	150,402	75.2	10	Y
CO	362,880	181.4	50	Y
VOC	6,076	3.0	10	N
PM ₁₀	12,484.5	6.2	70	N
SO _x	12,000.5	0.60	100	N



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
185

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Table O.10 Auxiliary Boiler Pre Control Annual PTE and Major Source Determination


Pollutant	Annual Uncontrolled Emissions, Aux Boiler		Threshold	Major Source?
	Lbs/yr	Tpy	Tpy	
NOx	2,188	1.1	10	N
CO	7,522	3.8	50	N
VOC	1,010	0.50	10	N
PM10	1,392	0.70	70	N
SOx	382	0.20	100	N

3. 40CFR 63 - NESHAPS

For NESHAPS, a major source is defined as a site that emits or has the potential to emit 10 tpy or more of any single HAP, or 25 tpy or more of any combination of HAPs (HAP being defined as one of the 187 air contaminants listed in the Section 112(b)(1), which does not include ammonia). See Appendix E for the calculations.

Table O.11 Total Facility TAC Emissions

Pollutant	CCTG 1&2	SCTG 1&2	Aux Boiler	Total	
	Lbs/yr	lbs/yr	lbs/yr	Lbs/yr	Tons/yr
1,3 Butadiene	12.60	1.5	////////	14.1	7.05E-03
Acetaldehyde	5163.12	612.36	0.98	5776.46	2.89E+00
Acrolein	105.84	12.56	0.86	119.26	5.96E-02
Benzene	95.52	11.32	1.84	108.68	5.43E-02
Ethyl Benzene	935.1	110.9	2.19	1048.19	5.24E-01
Formaldehyde	10527.02	1248.54	3.90	11799.46	5.89E+00
Naphthalene	38.14	4.52	0.10	42.76	2.14E-02
PAH	26.34	3.12	0.03	29.49	1.47E-02
Propylene Oxide	849.04	100.7	////////	949.74	4.75E-01
Toluene	3814.98	452.46	8.40	4275.84	2.14E+00
Xylene	1873.06	222.16	6.24	2101.46	1.05E+00
Hexane	////////	////////	1.46	1.46	7.30E-04
Propylene	////////	////////	168.01	168.01	8.40E-02
Total, lbs/yr	23342.7	2780.14	194.01		
Total 3 sources, tpy			13.2		

 South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 186	PAGES 212
	APPL NO. See Below	DATE 6/7/16
	PROCESSED BY CP01	CHECKED BY

Appendix P

Reporting Emission Factor Determinations

NO_x

The facility is required to report NO_x emissions based on the emission factor in the permit for any operation which occurs before initial certification of the CEMS (after certification or 180 days after installation whichever occurs first, missing data procedures are used). The facility will most likely certify its CEMS during or shortly after commissioning is completed. Therefore, the factor for the turbines will be based on the total expected emissions during commissioning as follows:

Table P.1 Combined Cycle Turbines RECLAIM Reporting Factor

Total Turbine Emissions During Commissioning, lbs	Total Turbine Fuel Use During Commissioning, mmcf	Reclaim Reporting Factor, lbs/mmcf
27,593	1445.6	19.09

Refer to Table C.1

Table P.2 Simple Cycle Turbines RECLAIM Reporting Factor

Total Turbine Emissions During Commissioning, lbs	Total Turbine Fuel Use During Commissioning, mmcf	Reclaim Reporting Factor, lbs/mmcf
5,718	227.7	25.11

Refer to Table C.3

The facility is required to measure and record fuel use during commissioning.

The SO_x factor for the turbines will be based on 0.25 gr/100 scf converted to lbs/mmcf as follows:

$$(0.25 \text{ grains/ } 100 \text{ scf})(\text{lb}/7000 \text{ grains})(64 \text{ lbs/lb-mole SO}_2/32 \text{ lbs/lb-mole S})(1\text{E}6 \text{ cf/mmcf}) = 0.71 \text{ lbs SO}_2/\text{mmcf fuel}$$

Table P.3 Auxiliary Boiler RECLAIM Reporting Factors

Pollutant	Reporting Factor, lbs/mmcf	Source
NO _x	49.180	Rule 2002 Table 1 for natural gas fired boilers subject to Rule 1146
SO _x	0.83	Rule 2002 Table 2 for natural gas fired external combustion equipment



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
187

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

VOC, PM10, CO

The monthly emission limits in Condition A63 will be verified with the use of reporting factors for VOC and PM10. CO will be verified with CEMS data, however, for the commissioning monthly limits, the CO will also be verified with an emission factor, since the CEMS will not be certified yet.

Table P.4 Combined Cycle Turbines Non-RECLAIM Reporting Factors During Commissioning

Pollutant	Total Turbine Emissions During Commissioning, lbs	Total Turbine Fuel Use During Commissioning, mmcf	Reporting Factor, lbs/mmcf
PM10	8,466	1445.6	5.86
VOC	14,681	1445.6	10.16
CO	101,326	1445.6	70.09

Table P.5 Combined Cycle Turbines Non-RECLAIM Reporting Factors After Commissioning

Pollutant	Baseload Emissions, lbs/hr	Baseload Maximum Fuel Use, mmcf	Reporting Factor, lbs/mmcf
PM10	8.5	2.16	3.94
VOC	5.75	2.16	2.66

Table P.6 Simple Cycle Turbines Non-RECLAIM Reporting Factors During Commissioning

Pollutant	Total Turbine Emissions During Commissioning, lbs	Total Turbine Fuel Use During Commissioning, mmcf	Reporting Factor, lbs/mmcf
PM10	1,747	227.7	7.67
VOC	836	227.7	3.67
CO	25,449	227.7	111.76

Table P.7 Simple Cycle Turbines Non-RECLAIM Reporting Factors After Commissioning

Pollutant	Baseload Emissions, lbs/hr	Baseload Maximum Fuel Use, mmcf	Reporting Factor, lbs/mmcf
PM10	6.24	0.84	7.43
VOC	2.3	0.84	2.74


	South Coast Air Quality Management District Engineering Division Application Processing & Calculations	PAGE 188	PAGES 212
		APPL NO. See Below	DATE 6/7/16
		PROCESSED BY CP01	CHECKED BY

Table P.8 Auxiliary Boiler Non-RECLAIM Reporting Factors

Pollutant	Emissions, lbs/hr	Maximum Fuel Use, mmcf	Reporting Factor, lbs/mmcf
PM10	0.51	0.0676	7.54
VOC	0.37	0.0676	5.47
CO	2.83	0.0676	41.9



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
189

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Appendix Q

Existing Units Historical Power Generation

Table Q.1

Year	Month	Gross MW		
		HB1	HB2	RB7
2015	12	21046	39937	0
	11	7344	31002	0
	10	35275	40979	0
	9	48060	49441	91800
	8	52492	56582	42413
	7	50104	46779	52871
	6	45828	33731	16443
	5	16857	11278	0
	4	7888	14627	0
	3	20526	27036	0
	2	0	0	0
	1	39234	0	0
Total		344,654	351,392	203,527
2014	12	6606	35772	0
	11	6090	52372	30971
	10	32263	72695	0
	9	51396	71831	8820
	8	57013	66301	31
	7	59022	59723	0
	6	30427	43939	0
	5	32495	24256	603
	4	41013	13434	0
	3	48000	20677	0
	2	8691	7954	0
	1	31208	6056	0
Total		404,224	475,010	40,425
Unit 2 Yr Average		374,439	413,201	121,976
Unit Average Capacity Factor		0.20	0.22	0.03

HB 1 and 2 Rating = 215 MW, RB 7 Rating = 480 MW



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
190

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Appendix R

Summary of Applications and Processing Fees

The following table summarizes the application submittals and associated processing fees.

A/N	Submittal Date	Equip	Bcat	Fee Sch	Fee
578073	Sept 9, 2015	Combined Cycle Turbine #1	013709	G	\$18,050.38
578074	Sept 9, 2015	Combined Cycle Turbine #2	013709	G Identical	9,025.19
578075	Sept 9, 2015	SCR/CO Catalyst #1	81	C	3,835.06
578076	Sept 9, 2015	SCR/CO Catalyst #2	81	C Identical	1,917.53
578077	Sept 9, 2015	Simple Cycle Turbine #1	013709	G	18,050.38
578078	Sept 9, 2015	Simple Cycle Turbine #2	013709	G Identical	9,025.19
578079	Sept 9, 2015	SCR/CO Catalyst #3	81	C	3,835.06
578080	Sept 9, 2015	SCR/CO Catalyst #4	81	C Identical	1,917.53
578081	Sept 9, 2015	Auxiliary Boiler	011705	E	6,085.38
578082	Sept 9, 2015	Auxiliary Boiler SCR	81	C	3,835.06
578083	Sept 9, 2015	Ammonia Storage	210900	A	1,521.32
578084	Sept 9, 2015	Ammonia Storage	210900	A Identical	760.66
578085	Sept 9, 2015	Oil/Water Separation	294804	C	3,835.06
578086	Sept 9, 2015	Oil/Water Separation	294804	C Identical	1,917.53
578087	Sept 9, 2015	Title V Revision	555009	C	1,994.55
Expedited Review					41,805.67
Total					\$127,411.55

Schedule G equipment is also subject to a Time and Material Fee of \$158.49/hr for hours worked over 117 hours.

Public notice, modeling review, and significant project fees will be billed to the facility after the permit is issued.

	Current Rate
Public Notice	\$1,265.25
Modeling Review ⁽¹⁾	4,640.64
PSD Review	2,222.09
Total	\$7,927.98

(1) Plus T&M @ \$132.72/hr if above 35 hours



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
191

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Appendix S

RECLAIM Trading Credit Requirement

- NO_x

In accordance with Rule 2005 the facility is required to set aside sufficient RECLAIM Trading Credits (RTC) to cover the NO_x emissions from the first year operation. The facility is not required to hold NO_x RTCs for the subsequent years since the NO_x PTE from the new equipment is less than the facility's initial allocation, and the facility is not considered 'new' (it has been in Reclaim since 1994).

Combined Cycle Turbines

During the 1st year, the combined cycle turbines will undergo commissioning, therefore, the NO_x emissions for the 1st year of operation assumes both commissioning and normal operation for each turbine.

Equipment	1st Year		Total 1 st Year NO _x Holding Requirement
	Commissioning	Post Commissioning	
CCTG 1	27,593	119,500	147,093
CCTG 2	27,593	119,500	147,093

Simple Cycle Turbines

During their 1st year of operation, the simple cycle turbines will undergo commissioning, therefore, the NO_x emissions for the 1st year assumes both commissioning and normal operation for each simple cycle turbine.

Equipment	1st Year		Total 1 st Year NO _x Holding Requirement
	Commissioning	Post Commissioning	
SCTG 1	5,718	21,252	26,970
SCTG 2	5,718	21,252	26,970

Auxiliary Boiler

The NO_x holdings for the auxiliary boiler are based on the proposed annual operating schedule.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
192

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Equipment	Total 1 st Year NOx Holding Requirement
Auxiliary Boiler	1,313

The total NOx RTC requirements are:

Equipment	Plant 1 st Year of Operation	Interim Years After Plant 1 st Year Prior to SCTG	SCTG Commissioning Year	After SCTG Commissioning and All Subsequent Years
CCTG 1	147,093	0	0	0
CCTG 2	147,093	0	0	0
SCTG 1	0	0	26,970	0
SCTG 2	0	0	26,970	0
Auxiliary Boiler	1,313	0	0	0
TOTAL	295,499	0	53,940	0

- The current NOx RTC holding for the Huntington Beach facility is 179,740 lbs/yr. The initial NOx RTC allocation for this facility is 1,276,547 lbs/yr.

- **SO_x**

Rule 2005 paragraph (f)(1) requires that for a facility modification which increases the annual allocation to a level greater than the starting allocation, offsets are required for the first year of operation, and each subsequent year. Since the facility opted into SO_x RECLAIM, there was no initial allocation for SO_x. Therefore, any increase is considered subject to the holding requirement for all compliance years.

Combined Cycle Turbines

During the 1st year, the combined cycle turbines will undergo commissioning, therefore, the SO_x emissions for the 1st year of operation assumes both commissioning and normal operation for each turbine. After the first year, commissioning will be completed, and the anticipated annual SO_x emissions are based on the proposed operating schedule.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
193

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Equipment	1st Year		Total 1 st Year SOx Holding Requirement	After 1 st Year SOx Holding Requirement
	Commissioning	Post Commissioning		
CCTG 1	4,843	9,960	14,803	9,960
CCTG 2	4,843	9,960	14,803	9,960

Simple Cycle Turbines

During their 1st year of operation, the simple cycle turbines will undergo commissioning, therefore, the SOx emissions for the 1st year assumes both commissioning and normal operation for each simple cycle turbine. After the first year, commissioning will be completed, and the anticipated annual SOx emissions are based on the proposed operating schedule.

Equipment	1st Year		Total 1 st Year SOx Holding Requirement	After 1 st Year SOx Holding Requirement
	Commissioning	Post Commissioning		
SCTG 1	459	1200.5	1,660	1,201
SCTG 2	459	1200.5	1,660	1,201

Auxiliary Boiler

The SOx holdings for the auxiliary boiler are based on the proposed annual operating schedule.

Equipment	Total 1 st Year NOx Holding Requirement	After 1 st Year NOx Holding Requirement
Auxiliary Boiler	382	382

The total SOx RTC requirements are:

Equipment	Plant 1 st Year of Operation	Interim Years After Plant 1 st Year Prior to SCTG	SCTG Commissioning Year	After SCTG Commissioning and All Subsequent Years
CCTG 1	14,803	9,960	9,960	9,960
CCTG 2	14,803	9,960	9,960	9,960
SCTG 1	0	0	1,660	1,201
SCTG 2	0	0	1,660	1,201
Auxiliary Boiler	382	382	382	382
TOTAL	29,988	20,302	23,622	22,704



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE 194	PAGES 212
APPL NO. See Below	DATE 6/7/16
PROCESSED BY CP01	CHECKED BY

- The current SO_x RTC holding for the Huntington Beach facility is 7,597 lbs/yr. The initial SO_x RTC allocation for this facility is 0 lbs/yr.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
195

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Appendix T

Review of Criteria Pollutant BACT Levels for Recent Projects

Following is a partial list of the BACT levels for some recent projects that were considered in the criteria pollutant BACT analysis for HBEP from the SCAQMD, EPA, BAAQMD, CARB, and SJVAPCD BACT clearinghouses.

NO_x

Combined Cycle Turbines

Facility	NO _x Emissions Limit @ 15% O ₂
Oakley Generating Station	2.0 ppm (1 hour)
GWF Tracy Combined-Cycle Project	2.0 ppm (1 hour)
Watson Cogeneration Project	2.0 ppm (1 hour)
Magnolia Power Project	2.0 ppm (3 hour)
Otay Mesa Energy Center	2.0 ppm (1 hour)
El Segundo Power	2.0 ppm (1 hour)
LADWP Scattergood	2.0 ppm (1 hour)

Simple Cycle Turbines

Facility	NO _x Emissions Limit @ 15% O ₂
Lambie Energy Center	2.5 ppm (3 hour)
EL Cajon Energy, LLC	2.5 ppm (1 hour)
Escondido Energy Center	2.5 ppm (1 hour)
Pio Pico Energy Center	2.5 ppm (1 hour)
LADWP Scattergood	2.5 ppm (1 hour)
LADWP Haynes	2.5 ppm (1 hour)
EL Segundo Power	2.5 ppm (1 hour)

Auxiliary Boiler

Facility	NO _x Emissions Limit @ 3% O ₂
Moundsville Power LLC	2.0 lbs/hr
Pinecrest Energy Center LLC	16 ppmvd
La Paloma Energy Center LLC	0.02 lbs/mmbtu
City of Palmdale Hybrid	9 ppmvd (3 hour)
Consumers Energy	0.018 lb/mmbtu



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
196

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Sandy Creek Energy Assoc
AES HB

1.8 lbs/hr
5 ppm (1 hour)

CO

Combined Cycle Turbines

Facility	CO Emissions Limit @ 15% O ₂
Oakley Generating Station	2.0 ppm (1 hour)
Vernon City Light and Power	2.0 ppm (3 hour)
Russell City Energy Center	2.0 ppm (1 hour)
LADWP Scattergood	2.0 ppm (1 hour)
El Segundo Power	2.0 ppm (1 hour)
CPV Warren	1.3 ppm without duct firing, 1.2 ppm with duct firing
Warren County Power	1.3 ppm without duct burners
Kleen Energy Systems	0.9 ppm (1 hour)

The Warren County Power Station became operational in December 2014. The Kleen Energy Systems permit allows exemptions from the 0.9 ppm CO limit during load changes.

Simple Cycle Turbines

Facility	CO Emissions Limit @ 15% O ₂
Great River Energy	4.0 ppm (4 hour)
Carlsbad Energy	4.0 ppm (1hour)
Pio Pico Energy Center	4.0 ppm (1 hour)
Canyon Power	4.0 ppm (1 hour)
LADWP Scattergood	4.0 ppm (1 hour)
LADWP Haynes	4.0 ppm (1 hour)
EL Segundo Power	4.0 ppm (1 hour)

Auxiliary Boiler

Facility	CO Emissions Limit @ 3% O ₂
Moundsville Power LLC	4.0 lbs/hr
Pinecrest Energy Center LLC	75 ppmvd
La Paloma Energy Center LLC	75 ppmvd (3 hour)
City of Palmdale Hybrid	50 ppmvd (3 hour)
Consumers Energy	0.035 lb/mmmbtu
Southern Co/Georgia Power	0.037 ln/mmmbtu (3 hour)



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
197

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Sandy Creek Energy Assoc
Northern States Power, Xcel
AES HB

6.1 lbs/hr
0.08 lb/mmbtu (3 hour)
5 ppm (1 hour)

The AES HB units 3 and 4 were large utility boilers, rated at 2,088 mmbtu/hr using CO oxidation catalysts (these are now retired units). There is no indication in the BACT Clearinghouses that smaller auxiliary-type boilers have been required to achieve this emission level.

VOC

Combined Cycle Turbines

Facility	VOC Emissions Limit @ 15% O ₂
Florida Power and Light Martin	1.3 ppm without duct firing
Duke Energy	1 ppm without duct firing (3 hour)
Fairbault Energy Park	1.5 ppm without duct firing
VA Power – Possum Point	1.2 ppm without duct firing
Sacramento Municipal	1.4 ppm
Liberty Generating Station	1.0 ppm
Empire Power, NY	1.0 ppm
CPV Warren	0.7 ppm without duct firing, 1.6 ppm with duct firing
Warren County Power	0.7 ppm without duct firing, 1.0 ppm with duct firing
Chouteau Power	0.3 ppm with duct firing (3 hour)

Different test methods are used by different air districts to stack test for VOC emissions, which results in varying test results. The BACT limit of 2.0 ppm chosen for HBEP is based on the method used in SCAQMD.

Simple Cycle Turbine

Facility	VOC Emissions Limit @ 15% O ₂
Indigo Energy	2.0 ppm
LADWP Scattergood	2.0 ppm (1 hour)
El Segundo Power	2.0 ppm (1 hour)
El Paso Belle Glade, FL	1.4 ppm
Deerfield Beach Energy Center	1.4 ppm
Florida Power and Light Manatee	1.3 ppm
Progress Bartow Power	1.2 ppm

Different test methods are used by different air districts to stack test for VOC emissions, which results in varying test results. The BACT limit of 2.0 ppm chosen for HBEP is based on the method used in SCAQMD.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
198

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

*Andrew Shaker,
CHRS*

**SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
M E M O R A N D U M**

DATE: May 18, 2016
TO: Andrew Lee
FROM: Ian MacMillan *IM*
SUBJECT: Modeling Review of Huntington Beach Energy (Facility ID #115389)
(A/N: 578073-86)

As you requested, Planning, Rule Development & Area Sources (PRDAS) staff reviewed the dispersion modeling analysis and health risk assessment (HRA) conducted for the proposed construction of four gas turbines and an auxiliary boiler at the AES Huntington Beach Generating Station located at 21730 Newland Street in the city of Huntington Beach. The project consists of one two-on-one combined-cycle power block (GE 7FA.05), one simple-cycle power block (two GE LMS 100PB), along with one natural-gas fired auxiliary boiler. The dispersion modeling analysis and HRA (report) and electronic files were submitted for PRDAS staff review along with the modeling request memo dated December 18, 2015, with a revised dispersion modeling analysis and HRA (report) submitted with the modeling request memo dated March 18, 2016.

SUMMARY OF MODELING REVIEW

- **Modeling Conducted Pursuant to SCAQMD Regulations XIII Requirements**
 - ✓ SCAQMD Rule 1304(a)(2) provides an exemption from the modeling requirement of Rule 1303(b)(1) for the installation of the new turbines since AES is permanently retiring their existing electric steam utility boilers. The modeling requirements of Rule 1303(b)(1) do apply to the proposed auxiliary boiler. The modeled impacts from the auxiliary boiler are below all thresholds in Rule 1303.
- **Modeling Conducted Pursuant to SCAQMD Regulation XIV Requirements**
 - ✓ The project's health risks are less than the Rule 1401 cancer and non-cancer permit limits of 10 in one million (for permit units with T-BACT), and hazard index of 1, respectively.
- **Modeling Conducted Pursuant to SCAQMD Regulation XX Requirements**
 - ✓ All equipment in the proposed project is subject to SCAQMD Rule 2005 review for NO₂ and SO₂. Modeled impacts from each piece of equipment are below all ambient air quality thresholds for NO₂ and SO₂.
- **Modeling Conducted Pursuant to Federal Prevention of Significant Deterioration (PSD) Requirements**
 - ✓ The project is subject to PSD regulations for CO, NO₂, PM₁₀, and greenhouse gases (GHG). Impacts were compared to applicable Class I and II SIL's. The project's CO impacts do not exceed the Significant Impact Level (SIL) and no further PSD analysis is needed. The project's PM₁₀ impacts will not exceed the SIL only after a permit condition is added to limit the operating parameters of the project, as agreed to by the applicant. Since the project's NO₂ impacts exceeded the 1-hour NO₂ SIL, a cumulative impact assessment was conducted. As there were no modeled exceedances of the federal 1-hour NO₂ standard, no further PSD analysis is required.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE 199	PAGES 212
APPL NO. See Below	DATE 6/7/16
PROCESSED BY CP01	CHECKED BY

Andrew Lee

- 2 -

May 18, 2016

- ✓ The project's impacts on visibility and deposition at the nearest Class I area did not exceed the screening threshold. Additional information is provided in the detailed comments below on an additional analysis requested by EPA Region 9 on visibility in Class II areas.
- **Modeling Conducted Pursuant to CEQA**
 - ✓ The modeling report was prepared by the project applicant as part of an Addendum to a previously approved Final Staff Assessment (FSA) for the California Energy Commission (CEC). An FSA is the CEC's CEQA document prepared under its certified regulatory program. PRDAS staff has confirmed the modeling analysis conclusion that the proposed project's impacts do not exceed what was previously approved in the FSA.
 - ✓ SCAQMD is both a responsible agency and a commenting agency under CEQA for this project. As noted above in the memo summary, the modeling analysis conforms to SCAQMD regulations and SCAQMD does not have any comments as a responsible agency.
 - ✓ In order to evaluate the project's air quality impacts for the California Energy Commission's (CEC's) CEQA document, the applicant included a modeling analysis of the impacts from the entire project. The modeling analysis that PRDAS staff reviewed concluded that the project would exceed SCAQMD PM10 and PM2.5 localized thresholds that are recommended for general CEQA use, but that impacts would be less than significant because the project would provide emission offsets. The impacted area is in an unoccupied area adjacent to the project site.
 - ✓ As a commenting agency, PRDAS staff notes that regional emission offsets should not be used as mitigation for a localized impact. However, as the turbine portion of this project is exempt from analyzing PM10 localized impacts pursuant to SCAQMD Regulation XIII, the SCAQMD PM10 localized CEQA thresholds for general use should only be applied to the boiler portion of the project. The boiler on its own does not exceed SCAQMD PM10 and PM2.5 localized CEQA thresholds.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
200

APPL NO.
See Below
PROCESSED BY
CP01

PAGES
212

DATE
6/7/16
CHECKED BY

Andrew Lee

- 3 -

May 18, 2016

DETAILED COMMENTS ON THE MODELING REVIEW

AERMOD Dispersion Modeling Approach

- ✓ The applicant utilized AERMOD (version 15181) for the air dispersion modeling, which is the current EPA approved model.
- ✓ The applicant processed meteorological data from the John Wayne/Orange County Airport's NWS station (WBAN Station #93184), which is appropriate for the project. This station was approved for use in PRDAS's staff memo dated December 12, 2013. Meteorological data was collected for the years 2010 – 2014, and was processed with AERMET (version 15181). Upper air data was collected from the San Diego Miramar NWS station (WBAN Station #03190). AERMINUTE (version 15272) was used to process 1-minute rolling averaged ASOS wind data. A 0.50 m/s threshold wind speed was applied in Stage 3 AERMET processing. Surface station data was processed with the coordinates set to 33.68°, -117.87°.
- ✓ The AERMOD modeling generally conforms to the SCAQMD's dispersion modeling methodology.
- ✓ The applicant used the monitoring data for SRA 18, North Coastal Orange County (Costa Mesa) for the pollutants CO, NO₂, O₃, and SO₂ and SRA 19, Saddleback Valley (Mission Viejo) monitoring stations for PM₁₀ and PM_{2.5}. Three years of data was used (2011-2013) to determine the background concentrations. As 2014 monitoring data is now available, background concentrations were updated for the applicable pollutants. The predicted modeling impacts were added to the highest background concentrations for comparison to the state and federal ambient air quality standards (AAQS).
- ✓ The receptor grid area covered is adequate to determine the maximum impacts from the facility.
- ✓ Since there are no restrictions for the auxiliary boiler on the operating hours, the modeling assumed continuous operations of 8760 hours/year (24 hours/day, 7 days/week, and 52 weeks/year). For the combined cycle turbines, the permit was evaluated at 6100 operating hours per year and 1750 hours per year for the simple cycle turbines.
- ✓ PRDAS staff reproduced the modeling analysis and our results and review are summarized below.

Modeling Review for Compliance with Applicable Federal, State, and Local Regulations

1. Federal PSD Air Quality Analyses

- ✓ The proposed project is subject to Prevention of Significant Deterioration (PSD) review for CO, NO₂, and PM₁₀; therefore, the project's impacts are compared to the corresponding U.S. EPA significant impacts levels (SIL) for each pollutant¹.

a. Class I Areas

- ✓ The nearest Class I areas to the project site are the San Gabriel Wilderness and Cucamonga Wilderness areas located approximately 69 km away. A radial receptor ring was placed at

¹ Commissioning activities are not to be included per discussion with U.S. EPA Region 9 staff.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
201

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Andrew Lee

- 4 -

May 18, 2016

a distance of 50 km from the project (50 km is the maximum receptor distance of the AERMOD model).

- ✓ The stack parameters and emission rates modeled are consistent with the parameters listed in Tables 1A, 1B, 2, 3A, 3B, 3C, and 3D of the report and are assumed to be correct.

Table A – Total Project Operational Impacts to Class I Areas

Pollutant & Averaging Time	Project's Modeled Operational Impact ($\mu\text{g}/\text{m}^3$)	Class I SIL ($\mu\text{g}/\text{m}^3$)	Exceeds Class I SIL?
NO ₂ , Annual	0.006	0.1	No
PM ₁₀ , 24-hr	0.042	0.2	No
PM ₁₀ , Annual	0.006	0.32	No

b. Class II Areas

- ✓ The project applicant identified five Class II areas in the project vicinity – Crystal Cove State Park, Water Canyon State Park, Chino Hills State Park, San Mateo Canyon Wilderness Area, and Huntington Beach State Park.
- ✓ The stack parameters and emission rates modeled are consistent with the parameters listed in Tables 1A, 1B, 2, 3A, 3B, 3C, and 3D of the report and are assumed to be correct.

Table B – Total Project Operational Impacts to Class II Areas

Pollutant & Averaging Time	Project's Modeled Operational Impact ($\mu\text{g}/\text{m}^3$)	Class II SIL ($\mu\text{g}/\text{m}^3$)	Exceeds Class II SIL?
CO, 1-hr	631	2,000	No
CO, 8-hr	149	500	No
NO ₂ , 1-hr ^b	94.5	7.5 ^a	Yes
NO ₂ , Annual ^b	0.6	1	No
PM ₁₀ , 24-hr	4.7	5	No
PM ₁₀ , Annual	0.6	1	No

Note: ^a Interim/Proposed SIL, not yet finalized.

^b The conversion of NO_x to NO₂ was done using Tier 2 conversion ratios of 0.8 for 1-hour and 0.75 for annual.

- ✓ For 24-hour PM₁₀, refined modeling was performed assuming one GE 7FA.05 would operate 24 hours per day at 44 percent load, and one GE 7FA.05 would operate 20 hours per day at 44 percent load and 4 hours per day at 75 percent load. This will require a permit condition.
- ✓ The U.S. EPA established a new 1-hour NO₂ standard of 0.100 ppm (or 188 $\mu\text{g}/\text{m}^3$) that became effective on April 12, 2010. In order to show compliance with the federal 1-hour



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE 202	PAGES 212
APPL NO. See Below	DATE 6/7/16
PROCESSED BY CP01	CHECKED BY

Andrew Lee

- 5 -

May 18, 2016

NO₂ standard, the applicant used the maximum hourly emissions from startup, shutdown, and normal operations. Given the number of startups and shutdowns, the emissions from these events cannot be considered as intermittent, as described in the U.S. EPA's memo dated March 1, 2011. Emissions from commissioning were not included because commissioning is a once in a lifetime event and the form of the standard involves a three year average of the 98th percentile of the annual distribution of daily maximum 1-hour concentrations.

- ✓ The maximum 1-hour NO₂ impact from the proposed project is 94.5 µg/m³. This impact exceeds the U.S. EPA 1-hour NO₂ significance impact level of 7.52 µg/m³. Therefore, a cumulative impact assessment is necessary.
- ✓ For the cumulative impact assessment, three facilities (Orange County Sanitation District's Huntington Beach and Fountain Valley facilities and Beta Offshore) as well as emissions from shipping lane activity off the coast were selected to be included based on their facility emissions and distance to the project. Seasonal, by hour-of-day background concentrations from the Costa Mesa monitoring station were used in the modeling. The conversion of NO_x to NO₂ was done using the Tier 2 ARM, with a value of 0.8 for the 1-hour. Following the form of the standard, the 1-hour NO₂ impact from the project plus cumulative projects plus background is 144.0 µg/m³, which is less than the federal 1-hour NO₂ standard of 188 µg/m³; therefore, the project does not exceed PSD requirements.

c. Visibility Impact Analysis for Class I and Class II Areas

- ✓ In order to estimate the potential impacts on visibility and deposition at the nearest Class I areas, a screening criteria was used for projects located more than 50 km away from a Class I area. The emissions/distance (Q/D) is calculated using the project's total annual emissions of SO₂, NO_x, PM₁₀, and H₂SO₄ (based on 24-hour maximum allowable emissions) divided by the distance between the project and the nearest Class I area. The project's total annual emissions are 420 TPY. The Q/D ratio is 6.1, which is less than the threshold of 10; therefore, modeling of visibility and deposition impacts to Class I areas are not necessary.
- ✓ Additionally, the project's impacts on visibility in Class II areas were also analyzed pursuant to EPA Region 9 request. The evaluation below is presented solely for informational purposes as there are no thresholds for visibility impacts on Class II areas. The project utilized the criteria and thresholds for Class I areas, which is conservative. Visibility impacts are based on the calculation of two factors – plume contrast and color contrast (ΔE) of the plume when compared to the sky and terrain backgrounds. For Class I areas, the criteria used is based on a perceptibility threshold of 0.05 (absolute value) for contrast and 2.0 for ΔE.
- ✓ The project applicant identified five Class II areas in the project vicinity – Crystal Cove State Park, Water Canyon State Park, Chino Hills State Park, San Mateo Canyon Wilderness Area, and Huntington Beach State Park. Using the Level 1 VISCREEN analysis, three areas were screened out and did not require further analysis. The two areas requiring a Level 2 VISCREEN analysis include Crystal Cove State Park and Huntington Beach State Park.
- ✓ Using the 5-year meteorological data from the John Wayne airport, joint frequency distribution tables were created and used to determine the worst-case single wind speed and stability class required for a Level 2 VISCREEN analysis. Using the Level 2



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
203

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Andrew Lee

- 6 -

May 18, 2016

VISCREEN analysis, the project's impacts for both contrast and ΔE are less than the Class I thresholds for Crystal Cove State Park.

- ✓ Huntington Beach State Park was analyzed using a Level 2 VISCREEN analysis for each individual stability class. Based on the modeled impacts, the sky background Class I thresholds are exceeded for contrast and color difference for stability classes A, B, C, and D. This corresponds to 4.5% of the time or 395 hours per year when the wind is blowing towards the State Park and the park is open (from 6:00am to 10:00pm).
- ✓ Currently, there are no established thresholds for Class II areas; therefore, it is not possible to determine if the project presents a significant visibility impact to Class II areas.

2. Rule 2005 Air Quality Analyses

- ✓ The proposed project is subject to SCAQMD Rule 2005 review for NO_2 and SO_2 . Each combustion emission unit was modeled separately, and the maximum results are presented below.
- ✓ The stack parameters and emission rates modeled are consistent with the parameters listed in Tables 1A, 1B, 2, 3A, 3B, 3C, and 3D of the report and are assumed to be correct.
- ✓ NO_2 and SO_2 modeled concentrations per emission unit, when added to the highest background values, are below applicable ambient air quality standards.

**Table C – Impacts for Rule 2005
Maximum Results From Highest Permit Unit For Each Pollutant**

Pollutant & Averaging Time	Maximum Modeled Concentration ($\mu\text{g}/\text{m}^3$)	Background Concentration ^a ($\mu\text{g}/\text{m}^3$)	Total Concentration ($\mu\text{g}/\text{m}^3$)	California AAQS ^b ($\mu\text{g}/\text{m}^3$)	Federal AAQS ^b ($\mu\text{g}/\text{m}^3$)	Exceeds Threshold ?
NO_2 , 1-hour ^c	60.3	142	202.3	339	-	No
NO_2 , 1-hour ^c	62.0	98.2	160.2	-	188 ^d	No
NO_2 , Annual ^c	0.3	21.8	22.1	57	100	No
SO_2 , 1-hr	5.7	23.1	28.8	655	-	No
SO_2 , 1-hr	2.8	8.8	11.6	-	196 ^e	No
SO_2 , 3-hr	5.1	23.1	28.2	-	1,300	No
SO_2 , 24-hr	1.7	5.2	6.9	105	-	No

Note: ^a Maximum values for CO , NO_2 , and SO_2 from SRA 18, North Coastal Orange County (No. 3195) monitoring station and PM_{10} from SRA 19, Saddleback Valley (No. 3812) monitoring station for the last three years (2012-2014).

^b Both the California and Federal AAQS values listed are not to be exceeded, except otherwise noted

^c The conversion of NO_x to NO_2 was done using the Tier 2 conversion ratios of 0.8 for 1-hour and 0.75 for annual.

^d On April 12, 2010, the U.S. EPA established a new 1-hour NO_2 standard of 100 ppb (188 $\mu\text{g}/\text{m}^3$). The form of the federal 1-hour NO_2 standard involves a three year average of the 98th percentile of the annual distribution of daily maximum 1-hour concentrations. Based on the U.S. EPA's memo dated March 1, 2011, commissioning is a once in a lifetime event and therefore, the federal 1-hour NO_2 standard does not apply.

^e On June 2, 2010, the U.S. EPA established a new 1-hour SO_2 standard of 75 ppb (196 $\mu\text{g}/\text{m}^3$). The form of the federal 1-hour SO_2 standard involves a three year average of the 99th percentile of the annual distribution of daily maximum 1-hour concentrations.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
204

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Andrew Lee

- 7 -

May 18, 2016

3. SCAQMD Regulation XIII - Impacts During Normal Operations

- ✓ The auxiliary boiler is subject to the modeling requirements of Regulation XIII and the Rule 1303 thresholds apply.
- ✓ The stack parameters and emission rates modeled are consistent with the parameters listed in Tables 1A, 1B, 2, 3A, 3B, 3C, 3D, 11A, and 11B of the report and are assumed to be correct.

Table D – Impacts during Normal Operation – Auxiliary Boiler

Attainment Pollutant & Averaging Time	Maximum Modeled Concentration (µg/m³)	Background Concentration ^a (µg/m³)	Total Concentration (µg/m³)	California AAQS ^b (µg/m³)	Federal AAQS ^b (µg/m³)	Exceeds Threshold ?
CO, 1-hr	23	3,435	3,458	23,000	40,000	No
CO, 8-hr	11	2,519	2,530	10,000	10,000	No
NO ₂ , 1-hr ^c	2.7	142.3	145.0	339	-	No
NO ₂ , 1-hr ^c	2.1	98.7	100.8	-	188 ^d	No
NO ₂ , Annual ^c	0.2	21.8	22.0	57	100	No
SO ₂ , 1-hr	0.4	23.1	23.5	655	-	No
SO ₂ , 1-hr	0.4	8.8	9.2	-	196 ^e	No
SO ₂ , 3-hr	0.3	23.1	23.4	-	1,300	No
SO ₂ , 24-hr	0.2	5.2	5.4	105	-	No
PM ₁₀ , 24-hr	0.5	51.1	51.6	-	150	No
Non-attainment Pollutant & Averaging Time	Maximum Modeled Concentration (µg/m³)	California AAQS (µg/m³)	Federal AAQS (µg/m³)	Rule 1303 Thresholds ^f (µg/m³)		Exceeds Threshold ?
PM ₁₀ , 24-hr	0.5	50	150	2.5		No
PM ₁₀ , Annual	0.2	20	-	1		No
PM _{2.5} , 24-hr	0.5	-	35	2.5		No
PM _{2.5} , Annual	0.2	12	12	1		No

Note: ^a Maximum values for CO, NO₂, and SO₂ from SRA 18, North Coastal Orange County (No. 3195) monitoring station and PM₁₀ from SRA 19, Saddleback Valley (No. 3812) monitoring station for the last three years (2012-2014).

^b Both the California and Federal AAQS values listed are not to be exceeded, except otherwise noted

^c The conversion of NO_x to NO₂ was done using the Tier 2 conversion ratios of 0.8 for 1-hour and 0.75 for annual.

^d On April 12, 2010, the U.S. EPA established a new 1-hour NO₂ standard of 100 ppb (188 µg/m³). The form of the federal 1-hour NO₂ standard involves a three year average of the 98th percentile of the annual distribution of daily maximum 1-hour concentrations. Based on the U.S. EPA's memo dated March 1, 2011, commissioning is a once in a lifetime event and therefore, the federal 1-hour NO₂ standard does not apply.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
205

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Andrew Lee

- 8 -

May 18, 2016

^e On June 2, 2010, the U.S. EPA established a new 1-hour SO₂ standard of 75 ppb (196 µg/m³). The form of the federal 1-hour SO₂ standard involves a three year average of the 99th percentile of the annual distribution of daily maximum 1-hour concentrations.

^f The South Coast Air Basin is designated non-attainment for the state PM₁₀ standards, and state and federal PM_{2.5} standards; therefore, project increments are compared to the significant change thresholds in Rule 1303.

4. SCAQMD Regulation XIV - Health Risk Impacts

- ✓ The applicant performed the risk assessment with the Hot Spots Analysis and Reporting Program Version 2 (HARP2, version 15197).
- ✓ The stack parameters and emission rates modeled are consistent with the parameters listed in Tables 16, 17, and 18 of the report and are assumed to be correct.
- ✓ The peak cancer risk for the proposed project is 4.7 in one million for a resident and 0.2 in one million for a worker. Based on a radius of 2.03 km (for the one in a million cancer risk contour) and a population density of 7,000 persons/km², the cancer burden is estimated to be 0.42. This is below the cancer burden threshold of 0.5.

Table E – Health Risk Impacts - Total Project

Receptor Type	Cancer Risk	Chronic Hazard Index	Acute Hazard Index	Cancer Risk Threshold	Chronic HI Threshold	Acute HI Threshold	Exceeds Any Threshold?
Sensitive	4.7 in one million	6.73 E-03	1.72 E-02	10 in one million ^a	1.0	1.0	No
Worker	0.2 in one million	1.01 E-02	4.06 E-02	10 in one million ^a	1.0	1.0	No

Note: ^a For permit units without TBACT, the Rule 1401 cancer risk threshold is 1 in one million. For permit units with TBACT, the Rule 1401 cancer risk threshold is 10 in one million

Table F – Health Risk Impacts – By Permit Unit - GE 7FA.05

Receptor Type	Cancer Risk	Chronic Hazard Index	Acute Hazard Index	Cancer Risk Threshold	Chronic HI Threshold	Acute HI Threshold	Exceeds Any Threshold?
Sensitive	2.4 in one million	3.46 E-03	9.05 E-03	10 in one million ^a	1.0	1.0	No
Worker	0.1 in one million	6.04 E-03	3.16 E-02	10 in one million ^a	1.0	1.0	No

Note: ^a For permit units without TBACT, the Rule 1401 cancer risk threshold is 1 in one million. For permit units with TBACT, the Rule 1401 cancer risk threshold is 10 in one million



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
206

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Andrew Lee

- 9 -

May 18, 2016

Table G – Health Risk Impacts – By Permit Unit - GE LMS 100PB

Receptor Type	Cancer Risk	Chronic Hazard Index	Acute Hazard Index	Cancer Risk Threshold	Chronic HI Threshold	Acute HI Threshold	Exceeds Any Threshold?
Sensitive	0.1 in one million	1.06 E-04	7.76 E-04	10 in one million ^a	1.0	1.0	No
Worker	0.003 in one million	1.82 E-04	1.69 E-04	10 in one million ^a	1.0	1.0	No

Note: ^a For permit units without TBACT, the Rule 1401 cancer risk threshold is 1 in one million. For permit units with TBACT, the Rule 1401 cancer risk threshold is 10 in one million

Table H – Health Risk Impacts – Auxiliary Boiler

Receptor Type	Cancer Risk	Chronic Hazard Index	Acute Hazard Index	Cancer Risk Threshold	Chronic HI Threshold	Acute HI Threshold	Exceeds Any Threshold?
Sensitive	0.03 in one million	7.99 E-05	3.55 E-04	10 in one million ^a	1.0	1.0	No
Worker	0.004 in one million	4.59 E-04	9.42 E-04	10 in one million ^a	1.0	1.0	No

Note: ^a For permit units without TBACT, the Rule 1401 cancer risk threshold is 1 in one million. For permit units with TBACT, the Rule 1401 cancer risk threshold is 10 in one million

5. Fumigation Air Quality Analyses

- ✓ Since there are tall stacks along the shoreline, the shoreline fumigation and inversion break-up impacts of the project were analyzed since during these short term events the maximum impacts could be higher.
- ✓ Both inversion break-up and shoreline fumigation were evaluated in the report for 1-hour NO₂, 1-hour, 3-hour, and 24-hour SO₂, 1-hour and 8-hour CO, and 24-hour PM₁₀. Because these meteorological phenomena do not persist for long periods, only the shorter averaging periods (≤ 8 hrs) should be considered.
- ✓ AERSCREEN (version 15181) was utilized for the analysis. The modeling parameters for the worst-case operating scenarios were used for each of the modeled pollutants and averaging times. AERSCREEN is the model EPA recommends to analyze impacts from inversion break-up and shoreline fumigation. However, AERSCREEN cannot provide results that correspond to the federal ambient air quality standards for NO₂ and SO₂, due to the form of those standards. For these pollutants, the maximum value is reported in the table below instead of the 98th or 99th percentile, respectively.
- ✓ Both inversion break-up and shoreline fumigation impacts, combined with background concentrations, are below the applicable ambient air quality standards.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE
207

APPL NO.
See Below

PROCESSED BY
CP01

PAGES
212

DATE
6/7/16

CHECKED BY

Andrew Lee

- 10 -

May 18, 2016

Table I – Impacts during Normal Operations for Inversion Break-Up – Total Project

Attainment Pollutant & Averaging Time	Maximum Modeled Concentration ($\mu\text{g}/\text{m}^3$)	Background Concentration ^a ($\mu\text{g}/\text{m}^3$)	Total Concentration ($\mu\text{g}/\text{m}^3$)	Federal AAQS ^b ($\mu\text{g}/\text{m}^3$)	California AAQS ($\mu\text{g}/\text{m}^3$)
CO, 1-hr	529	3,435	3,964	40,000	23,000
CO, 8-hr	178	2,519	2,697	10,000	10,000
NO ₂ , 1-hr	85.3	142.3	227.6	-	339
SO ₂ , 1-hr	5.5	23.1	28.6	-	655
SO ₂ , 3-hr	5.3	23.1	28.4	1,300	-

Note: ^a Maximum values for CO, NO₂, and SO₂ from SRA 18, North Coastal Orange County (No. 3195) monitoring station and PM₁₀ from SRA 19, Saddleback Valley (No. 3812) monitoring station for the last three years (2012-2014).

^b Both the California and Federal AAQS values listed are not to be exceeded. The federal NO₂ and SO₂ standards cannot be evaluated with AERSCREEN due to the form of those standards and are not considered in this analysis.

Table J – Impacts during Normal Operations for Shoreline Fumigation – Total Project

Attainment Pollutant & Averaging Time	Maximum Modeled Concentration ($\mu\text{g}/\text{m}^3$)	Background Concentration ^a ($\mu\text{g}/\text{m}^3$)	Total Concentration ($\mu\text{g}/\text{m}^3$)	Federal AAQS ^b ($\mu\text{g}/\text{m}^3$)	California AAQS ($\mu\text{g}/\text{m}^3$)
CO, 1-hr	125	3,435	3,560	40,000	23,000
CO, 8-hr	38	2,519	2,557	10,000	10,000
NO ₂ , 1-hr	47.2	142.3	189.5	-	339
SO ₂ , 1-hr	3.5	23.1	26.6	-	655
SO ₂ , 3-hr	3.6	23.1	26.7	1,300	-

Note: ^a Maximum values for CO, NO₂, and SO₂ from SRA 18, North Coastal Orange County (No. 3195) monitoring station and PM₁₀ from SRA 19, Saddleback Valley (No. 3812) monitoring station for the last three years (2012-2014).

^b Both the California and Federal AAQS values listed are not to be exceeded. The federal NO₂ and SO₂ standards cannot be evaluated with AERSCREEN due to the form of those standards and are not considered in this analysis.

6. Modeling Review of Project Impacts for CEC's CEQA Evaluation

- ✓ The modeling report was prepared by the project applicant as part of an Addendum to a previously approved Final Staff Assessment (FSA) for the California Energy Commission (CEC). An FSA is the CEC's CEQA document prepared under its certified regulatory program. PRDAS staff has confirmed the modeling analysis conclusion that the proposed project's impacts do not exceed what was previously approved in the FSA.
- ✓ SCAQMD is both a responsible agency and a commenting agency under CEQA for this project. As noted above in the memo above, the modeling analysis conforms to SCAQMD regulations and SCAQMD does not have any comments as a responsible agency.
- ✓ In order to evaluate the project's air quality impacts for the California Energy Commission's (CEC's) CEQA document, the applicant included a modeling analysis of the impacts from the entire project. The modeling analysis that PRDAS staff reviewed



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE 208	PAGES 212
APPL NO. See Below	DATE 6/7/16
PROCESSED BY CP01	CHECKED BY

Andrew Lee

- 11 -

May 18, 2016

concluded that the project would exceed SCAQMD PM10 and PM2.5 localized thresholds that are recommended for general CEQA use, but that impacts would be less than significant because the project would provide emission offsets. The impacted area is in an unoccupied area adjacent to the project site (see map at the end of this memo).

- ✓ As a commenting agency, PRDAS staff notes that regional emission offsets should not be used as mitigation for a localized impact. However, as the turbine portion of this project is exempt from analyzing PM10 localized impacts pursuant to SCAQMD Regulation XIII, the SCAQMD PM10 localized CEQA thresholds for general use should only be applied to the boiler portion of the project. The boiler on its own does not exceed SCAQMD PM10 and PM2.5 localized CEQA thresholds.

a. Impacts During Commissioning

- ✓ The two GE 7FA.05 turbines and two GE LMS 100PB turbines are not subject to the modeling requirements of Regulation XIII per Rule 1304(a)(2); therefore the Rule 1303 thresholds do not apply. However, the applicant included a modeling analysis of the impacts from the new turbines and the auxiliary boiler in support of the CEC's CEQA document and PRDAS staff reviewed the modeling in the report.
- ✓ Turbine commissioning is an once-in-a-lifetime event. A total of 6 scenarios were modeled. 3 scenarios were modeled for the two GE 7FA.05's, all of which included the auxiliary boiler in normal operation. 3 scenarios were modeled for the two GE LMS 100PB's, all of which included the auxiliary boiler in normal operation as well. The auxiliary boiler will be installed and commissioned prior to the first fire of the combined-cycle CTGs.
- ✓ NO2 was modeled using the Tier 3 method Plume Volume Molar Ratio Method (PVMRM).
- ✓ The stack parameters and emission rates modeled are consistent with the parameters listed in Tables 5, 6, and 7 of the Engineering Memorandum and are assumed to be correct.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE 209	PAGES 212
APPL NO. See Below	DATE 6/7/16
PROCESSED BY CP01	CHECKED BY

Andrew Lee

- 12 -

May 18, 2016

**Table K – Impacts during Commissioning for GE 7FA.05 and
Auxiliary Boiler in Normal Operation**

Attainment Pollutant & Averaging Time	Maximum Modeled Concentration ($\mu\text{g}/\text{m}^3$)	Background Concentration ^a ($\mu\text{g}/\text{m}^3$)	Total Concentration ($\mu\text{g}/\text{m}^3$)	California AAQS ^b ($\mu\text{g}/\text{m}^3$)	Federal AAQS ^b ($\mu\text{g}/\text{m}^3$)
CO, 1-hr	4,341	3,435	7,776	23,000	40,000
CO, 8-hr	3,000	2,519	5,519	10,000	10,000
NO ₂ , 1-hr ^c	169	142.3	311.3	339	- ^d
NO ₂ , Annual ^c	0.7	21.8	22.5	57	100
SO ₂ , 1-hr	6.0	23.1	29.1	655	196 ^e
SO ₂ , 3-hr	5.1	23.1	28.2	-	1,300
SO ₂ , 24-hr	1.7	5.2	6.9	105	-
Non-attainment Pollutant & Averaging Time	Maximum Modeled Concentration ($\mu\text{g}/\text{m}^3$)	California AAQS ($\mu\text{g}/\text{m}^3$)	Federal AAQS ($\mu\text{g}/\text{m}^3$)	Rule 1303 Thresholds ^b ($\mu\text{g}/\text{m}^3$)	
PM ₁₀ , 24-hr	5.7	50	150	2.5	
PM ₁₀ , Annual	0.6	20	-	1	
PM _{2.5} , 24-hr	5.7	-	35	2.5	
PM _{2.5} , Annual	0.6	12	12	1	

Note: ^a Maximum values for CO, NO₂, and SO₂ from SRA 18, North Coastal Orange County (No. 3195) monitoring station and PM₁₀ from SRA 19, Saddleback Valley (No. 3812) monitoring station for the last three years (2012-2014).

^b Since the Rule 1303 thresholds do not apply, the AAQS and Rule 1303 thresholds shown here are for informational purposes only.

^c The conversion of NO_x to NO₂ was done using the Tier 3 method Plume Volume Molar Ratio Method (PVMRM).

^d On April 12, 2010, the U.S. EPA established a new 1-hour NO₂ standard of 100 ppb (188 $\mu\text{g}/\text{m}^3$). The form of the federal 1-hour NO₂ standard involves a three year average of the 98th percentile of the annual distribution of daily maximum 1-hour concentrations. Based on the U.S. EPA's memo dated March 1, 2011, commissioning is a once in a lifetime event and therefore, the federal 1-hour NO₂ standard does not apply.

^e On June 2, 2010, the U.S. EPA established a new 1-hour SO₂ standard of 75 ppb (196 $\mu\text{g}/\text{m}^3$). The form of the federal 1-hour SO₂ standard involves a three year average of the 99th percentile of the annual distribution of daily maximum 1-hour concentrations.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE 210	PAGES 212
APPL NO. See Below	DATE 6/7/16
PROCESSED BY CP01	CHECKED BY

Andrew Lee

- 13 -

May 18, 2016

**Table L – Impacts during Commissioning for GE LMS100 PB and
Auxiliary Boiler in Normal Operation**

Attainment Pollutant & Averaging Time	Maximum Modeled Concentration ($\mu\text{g}/\text{m}^3$)	Background Concentration ^a ($\mu\text{g}/\text{m}^3$)	Total Concentration ($\mu\text{g}/\text{m}^3$)	California AAQS ^b ($\mu\text{g}/\text{m}^3$)	Federal AAQS ^b ($\mu\text{g}/\text{m}^3$)
CO, 1-hr	527	3,435	3,962	23,000	40,000
CO, 8-hr	131	2,519	2,645	10,000	10,000
NO ₂ , 1-hr ^c	79.1	142.3	221.4	339	- ^d
NO ₂ , Annual ^c	0.5	21.8	22.3	57	100
SO ₂ , 1-hr	5.8	23.1	28.9	655	196 ^e
SO ₂ , 3-hr	5.0	23.1	28.1	-	1,300
SO ₂ , 24-hr	1.7	5.2	6.9	105	-
Non-attainment Pollutant & Averaging Time	Maximum Modeled Concentration ($\mu\text{g}/\text{m}^3$)	California AAQS ($\mu\text{g}/\text{m}^3$)	Federal AAQS ($\mu\text{g}/\text{m}^3$)	Rule 1303 Thresholds ^b ($\mu\text{g}/\text{m}^3$)	
PM ₁₀ , 24-hr	5.1	50	150	2.5	
PM ₁₀ , Annual	0.5	20	-	1	
PM _{2.5} , 24-hr	5.1	-	35	2.5	
PM _{2.5} , Annual	0.5	12	12	1	

Note: ^a Maximum values for CO, NO₂, and SO₂ from SRA 18, North Coastal Orange County (No. 3195) monitoring station and PM₁₀ from SRA 19, Saddleback Valley (No. 3812) monitoring station for the last three years (2012-2014).

^b Since the Rule 1303 thresholds do not apply, the AAQS and Rule 1303 thresholds shown here are for informational purposes only.

^c The conversion of NO_x to NO₂ was done using the Tier 3 method Plume Volume Molar Ratio Method (PVMRM).

^d On April 12, 2010, the U.S. EPA established a new 1-hour NO₂ standard of 100 ppb (188 $\mu\text{g}/\text{m}^3$). The form of the federal 1-hour NO₂ standard involves a three year average of the 98th percentile of the annual distribution of daily maximum 1-hour concentrations. Based on the U.S. EPA's memo dated March 1, 2011, commissioning is a once in a lifetime event and therefore, the federal 1-hour NO₂ standard does not apply.

^e On June 2, 2010, the U.S. EPA established a new 1-hour SO₂ standard of 75 ppb (196 $\mu\text{g}/\text{m}^3$). The form of the federal 1-hour SO₂ standard involves a three year average of the 99th percentile of the annual distribution of daily maximum 1-hour concentrations.

b. Impacts During Normal Operations

- ✓ The two GE 7FA.05 turbines and two GE LMS 100PB turbines are not subject to the modeling requirements of Regulation XIII per Rule 1304(a)(2); therefore the Rule 1303 thresholds do not apply. However, the applicant included a modeling analysis of the impacts from the new turbines and the auxiliary boiler in support of the CEC's CEQA document and PRDAS staff reviewed the modeling in the report.
- ✓ The stack parameters and emission rates modeled are consistent with the parameters listed in Table 1A, 1B, 2, 3A, 3B, 3C, and 3D of the report and are assumed to be correct.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE 211	PAGES 212
APPL NO. See Below	DATE 6/7/16
PROCESSED BY CP01	CHECKED BY

Andrew Lee

- 14 -

May 18, 2016

- ✓ The applicant will take a permit condition which limits the daily operation of the GE 7FA.05 turbines to no more than 20 hours at 44% load.

Table M- Impacts during Normal Operation – Total Project

Attainment Pollutant & Averaging Time	Maximum Modeled Concentration (µg/m³)	Background Concentration ^a (µg/m³)	Total Concentration (µg/m³)	California AAQS ^b (µg/m³)	Federal AAQS ^b (µg/m³)
CO, 1-hr	631	3,435	4,066	23,000	40,000
CO, 8-hr	149	2,519	2,668	10,000	10,000
NO ₂ , 1-hr ^c	94.5	142.3	236.8	339	-
NO ₂ , 1-hr ^c	-	-	125.4	-	188 ^d
NO ₂ , Annual ^c	0.6	21.8	22.4	57	100
SO ₂ , 1-hr	5.8	23.1	28.9	655	-
SO ₂ , 1-hr	5.4	8.8	14.2	-	196 ^e
SO ₂ , 3-hr	5.0	23.1	28.1	-	1,300
SO ₂ , 24-hr	1.7	5.2	6.9	105	-
PM ₁₀ , 24-hr	4.3	51.1	55.4	-	150
Non-attainment Pollutant & Averaging Time	Maximum Modeled Concentration (µg/m³)	California AAQS (µg/m³)	Federal AAQS (µg/m³)	Rule 1303 Thresholds ^b (µg/m³)	
PM ₁₀ , 24-hr	4.7	50	150	2.5	
PM ₁₀ , Annual	0.6	20	-	1	
PM _{2.5} , 24-hr	4.7	-	35	2.5	
PM _{2.5} , Annual	0.6	12	12	1	

Note: ^a Maximum values for CO, NO₂, and SO₂ from SRA 18, North Coastal Orange County (No. 3195) monitoring station and PM₁₀ from SRA 19, Saddleback Valley (No. 3812) monitoring station for the last three years (2012-2014).

^b Since the Rule 1303 thresholds do not apply, the AAQS and Rule 1303 thresholds shown here are for informational purposes only.

^c The conversion of NO_x to NO₂ was done using the Tier 2 conversion ratios of 0.8 for 1-hour and 0.75 for annual.

^d On April 12, 2010, the U.S. EPA established a new 1-hour NO₂ standard of 100 ppb (188 µg/m³). The form of the federal 1-hour NO₂ standard involves a three year average of the 98th percentile of the annual distribution of daily maximum 1-hour concentrations. Based on the U.S. EPA's memo dated March 1, 2011, commissioning is a once in a lifetime event and therefore, the federal 1-hour NO₂ standard does not apply.

^e On June 2, 2010, the U.S. EPA established a new 1-hour SO₂ standard of 75 ppb (196 µg/m³). The form of the federal 1-hour SO₂ standard involves a three year average of the 99th percentile of the annual distribution of daily maximum 1-hour concentrations.

- ✓ As shown in Figure 1 below, there are no sensitive receptors located in the area of the modeled exceedance.



**South Coast
Air Quality Management District**

Engineering Division
Application Processing & Calculations

PAGE 212	PAGES 212
APPL NO. See Below	DATE 6/7/16
PROCESSED BY CP01	CHECKED BY

Andrew Lee

- 15 -

May 18, 2016



Figure 1 – Maximum 24-Hour PM Impact from Normal Operation of the Project
($2.5 \mu\text{g}/\text{m}^3$ Contour)

Modeling staff spent a total of 180 hours on this review. Please direct any questions to Jillian Wong at Ext. 3176.

cc: Chris Perri
JW:MS