

DOCKETED

Docket Number:	15-AFC-02
Project Title:	Mission Rock Energy Center
TN #:	214590
Document Title:	Mission Rock Energy Center Response to Staff's Data Request No. 1
Description:	N/A
Filer:	Deric Wittenborn
Organization:	Ellison, Schneider & Harris LLP
Submitter Role:	Applicant
Submission Date:	11/30/2016 3:26:28 PM
Docketed Date:	11/30/2016

ELLISON, SCHNEIDER & HARRIS L.L.P.

ATTORNEYS AT LAW

2600 CAPITOL AVENUE, SUITE 400

SACRAMENTO, CALIFORNIA 95816

TELEPHONE: (916) 447-2166

<http://www.eslawfirm.com>

November 30, 2016

Mike Monasmith
Project Manager
California Energy Commission
1516 Ninth Street
Sacramento, CA 95814-5512

RE: Mission Rock Energy Center (15-AFC-02): California Energy Commission Staff's Data Request No. 1

Dear Mr. Monasmith:

In response to Energy Commission ("Commission") Staff's Data Request No. 1, Mission Rock Energy Center, LLC (the "Applicant") is providing the attached table that was submitted to the Ventura County Air Pollution Control District.

Please contact me at 916-447-2166 if you have any questions.

Sincerely,



ELLISON, SCHNEIDER & HARRIS LLP

Greggory L. Wheatland

Samantha G. Neumyer

Attorneys for the Applicant

APCD Worst case calculations

Assumptions:

Normal turbine emission factors from Attachment 5.1A-1 Turbine performance data (run #1)
 Startup/shutdown emission factors from Appendix table 5.1A-1 Maximum hourly, daily, annual emissions calculations.
 PM10 at 2.0 lb/hr.
 SOx at 0.75 grains all the time.
 Worst case hour is startup/shutdown/startup all in 1 hr.
 Annual turbine emissions = 150 startups+150 shutdowns+ 2402.5 hrs steady state (based on run #1 emission factors)

Startup and Shutdown Hourly Emissions (lbs)						
Pollutant	Startup Emissions			Shutdown Emissions		
	Startup +	Normal Operation =	Maximum Hourly Startup	Shutdown +	Normal Operation =	Maximum Hourly Shutdown
Duration (min)	30	30	60	9	51	60
ROC	1.00	0.3672	1.3672	1.00	1.220.60	2.221.60
NOx	9.10	2.559	11.659	1.820	4.2340	6.025.60
PM ₁₀	1.00	1.00	2.00	0.30	1.70	2.00
SOx	0.3060	0.2960	0.591.20	0.1048	0.491.02	0.591.20
CO	5.50	2.4852	8.027.99	1.80	4.238	6.028
NH3	1.89	1.89	3.787	0.57	3.20	3.77

Startup/Shutdown/Restart Hourly Emissions (lbs)				
Pollutant	Startup+	Shutdown+	Restart (Startup)=	Maximum Hourly Startup/Shutdown/Restart Emissions
Duration (min)	30	9	24	60
ROC	1.00	1.00	0.70	2.70
NOx	9.10	1.20	6.37	16.67
PM ₁₀	1.00	0.30	0.70	2.00
SOx	0.60	0.18	0.42	1.20
CO	5.50	1.80	3.85	11.15
NH3	1.89	0.57	1.32	3.78

Commented [GD1]: This scenario is not proposed for the permit. Only one startup per hour.

Formatted Table

Startup and Shutdown Annual Emissions <u>(per turbine)</u>				
Pollutant	Startup		Shutdown	
	Pounds Per Startup	Tons Per Year (150 Startups/yr)	Pounds Per Shutdown	Tons Per Year (150 Shutdowns/yr)
ROC	1.00	0.075	1.00	0.075
NOx	9.10	0.683	1.20	0.09
PM ₁₀	1.00	0.075	0.30	0.023
SOx	0.360	0.02245	0.1048	0.0074435
CO	5.50	0.4125	1.80	0.135
NH3	1.89	0.14175	0.57	0.042575

New Turbine Emission Calculations - Normal Operation per turbine				
Pollutant	Emission Factor	Emission Factor Basis	Maximum Pounds Per Hour (@ 566.2 MMBtu/hr)	Annual Tons Per Year (2402.5 hr/yr) (@ 561.0 MMBtu/hr)
ROC	0.00126254 lb/MMBtu	2.01 ppmvd (BACT)	1.420.71	0.8471.74
NOx	0.00901 lb/MMBtu	2.5 ppmvd (BACT)	5.10	6.134.85
PM ₁₀	N/A	2.0 lb/hr per MRECGE?	2.0	2.40
SOx	0.001021375 lb/MMBtu	0.75 grain	0.5941.24	1.450.74
CO	0.00877 lb/MMBtu	4.0 ppmvd per GE	4.97	5.916
NH3	N/A	5.0 ppmvd (BACT)	3.77	4.4953

New Turbine Emission Calculations – Maximum Annual Emissions					
Pollutant	Annual Startups	Annual Shutdown	Annual Normal op	Total annual turbine operation	Annual x 5 turbines
	Tons Per Year	Tons Per Year	Tons Per Year	Tons Per Year	Tons per year
ROC	0.0750 075	0.0750 075	0.8474 74	1.861 00	4.989 30
NOx	0.6830 68	0.0990 09	4.856 13	5.636 90	28.1334 60
PM ₁₀	0.0750 075	0.00740 023	2.402 40	2.50	12.50 12.50
SOx	0.0220 045	0.01990 0135	0.7094 45	0.741 51	7.553 69
CO	0.41250 4125	0.1350 135	5.915 96	6.465 1	32.295 6
NH3	0.141750 14175	0.04250 04275	4.494 53	4.497 4	22.4523 55

Max Annual is- 150 SU + 150 SD + 2402.5 hr normal op = 2500 hrs total usage

Formatted Table

New Turbine Emission Calculations – Maximum Permitted Emissions Hourly and Annual Operations					
Pollutant	Hourly*		Annual**		Annual x 5 turbines
	Pounds Per Hour		Tons Per Year		Tons per year
ROC	1.362 70		1.001 86		4.989 30
NOx	11.6516 67		5.636 90		28.1334 60
PM ₁₀	2.002 00		2.502 50		12.5012 50
SOx	0.594 20		0.741 51		3.697 58
CO	7.9911 15		6.466 51		32.2932 55
NH3	3.783 78		4.494 74		22.4523 55

*Max hourly is -SU/Full LoadSD/re-SU all in 1 hr

** Annual is -150 hrs startup+ 150 hrs shutdown + 2402.5 hrs normal operation

Formatted Table

Engine emission calculations.

Engine operated 52 hrs/yr for maintenance and testing purposes.

New 220 BHP Emergency Fire Pump Engine Emission Calculations				
Pollutant	Emission Factor (g/bhp-hr)	Emission Factor Basis	Pounds Per Hour	Tons Per Year (52 hr/yr)
ROC	0.2	EPA Tier 3 non-road diesel standards	0.10	0.003
NOx	2.8	EPA Tier 3 non-road diesel standards	1.36	0.035
PM ₁₀	0.15	EPA Tier 3 non-road diesel standards	0.07	0.002
SOx	0.0051	Very low sulfur fuel (15 ppmw) mass balance see below	0.0023	0.0006
CO	2.6	EPA Tier 3 non-road diesel standards	1.26	0.033

$$\frac{0.000015 \text{ lb-S}}{\text{lb-fuel}} \times \frac{7.1 \text{ lb-fuel}}{\text{gallon}} \times \frac{2 \text{ lb-SO}_2}{1 \text{ lb-S}} \times \frac{1 \text{ gal}}{137,000 \text{ Btu}} \times \frac{1 \text{ bhp input}}{0.35 \text{ bhp out}} \times \frac{2,542.5 \text{ Btu}}{\text{bhp-hr}} \times \frac{453.6 \text{ g}}{\text{lb}} = 0.0051 \frac{\text{g-SO}_x}{\text{bhp-hr}}$$

Table VII - 7

New Turbine Commissioning Emissions		
Pollutant	Maximum Commissioning Emissions (lbs/hr) (Per Turbine)	Total Commissioning Emissions (tpy) (5 Turbines)
ROC	3.0464.40	0.1643.52
NOx	68.0246.30	2.0711.70
CO	117.33973.00	4.4331.74