

DOCKETED

Docket Number:	16-AFC-01
Project Title:	Stanton Energy Reliability Center
TN #:	214902
Document Title:	Order Accepting the Executive Director's Recommendation to Find the AFC Incomplete - Order No: 16-1214-3
Description:	Order Accepting the Executive Director's Recommendation to find the Stanton Energy Reliability Center Application for Certification (AFC) Incomplete
Filer:	Cody Goldthrite
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	12/19/2016 11:26:23 AM
Docketed Date:	12/19/2016

STATE OF CALIFORNIA

STATE ENERGY RESOURCES
CONSERVATION AND DEVELOPMENT COMMISSION

In the Matter of:

**Application for Certification for the
*Stanton Energy Reliability Center***

Docket No. 16-AFC-01

ORDER ACCEPTING THE EXECUTIVE DIRECTOR'S RECOMMENDATION TO FIND
THE STANTON ENERGY RELIABILITY CENTER APPLICATION FOR
CERTIFICATION (AFC) INCOMPLETE

On October 26, 2016, Stanton Energy Reliability Center, LLC, filed an application for certification (AFC) to construct and operate the Stanton Energy Reliability Center (SERC) an electrical generating facility in the city of Stanton, at 10711 Dale Avenue, Orange County, California. The facility would be located on two parcels with a combined 3.978 acres in a district of Stanton zoned Industrial General.

SERC would consist of two General Electric (GE) LM6000-based EGTs, which are natural gas-fired, simple-cycle combustion turbines, each with a clutch to provide operational flexibility as a synchronous condenser and an integrated 10-megawatt (MW) GE Battery Energy Storage System. In total, SERC would provide 98 MW (nominal) of capacity.

Energy Commission Staff completed its data adequacy review of the AFC in accordance with the California Code of Regulations, title 20, section 1704, and Division 2, Chapter 5, Appendix B for the 12-month permitting process. On November 29, 2016, Robert Oglesby, Executive Director, submitted Staff's Data Adequacy Recommendation for the Stanton Energy Reliability Center to the Commission, indicating that staff has determined that the information contained in the AFC is deficient in nine areas, namely: Air Quality, Cultural Resources, Geological Hazards, Project Overview, Reliability, Socioeconomics, Traffic and Transportation, Transmission System Design and Water Resources. On this basis, the Executive Director recommended the Commission adopt the list of deficiencies identified in Staff's Data Adequacy Worksheets, attached to

Staff's Data Adequacy Recommendation, and not find the AFC complete until the additional information specified in the data adequacy worksheets is supplied.

The Energy Commission hereby accepts the Executive Director's Recommendation, and adopts the list of deficiencies identified in Staff's Data Adequacy Worksheets, and finds the AFC incomplete at this time.

CERTIFICATION


The undersigned Secretariat to the Commission does hereby certify that the foregoing is a full, true, and correct copy of an Order duly and regularly adopted at a meeting of the California Energy Commission held on December 14, 2016.

AYE: Weisenmiller, Douglas, McAllister, Hochschild, Scott

NAY: None

ABSENT: None

ABSTAIN: None



Cody Goldthrite
Secretariat