

## DOCKETED

<b>Docket Number:</b>	17-AAER-06
<b>Project Title:</b>	Commercial and Industrial Fans & Blowers
<b>TN #:</b>	217667
<b>Document Title:</b>	Dale Price Comments Commercial and Industrial Fans & Blowers Webinar May 11, 2017
<b>Description:</b>	N/A
<b>Filer:</b>	System
<b>Organization:</b>	Dale Price
<b>Submitter Role:</b>	Public
<b>Submission Date:</b>	5/20/2017 10:41:27 AM
<b>Docketed Date:</b>	5/22/2017

*Comment Received From: Dale Price*

*Submitted On: 5/20/2017*

*Docket Number: 17-AAER-06*

## **Commercial and Industrial Fans & Blowers Webinar May 11, 2017**

Ref: Slide 22, "Clarify the definition of a fan and blower"

Fans displace air at low to medium pressures, normally measured in inches of water gauge. Fans can be further classified based on whether the primary work performed by the fan is on the fan inlet or outlet side of the fan. When the primary work is performed on the inlet side of the fan, the fan is often referred to as an induced draft fan or exhauster. When the primary work is performed on the outlet side of the fan, the fan is often referred to as a forced draft fan or blower