

## DOCKETED

<b>Docket Number:</b>	17-BSTD-01
<b>Project Title:</b>	2019 Building Energy Efficiency Standards PreRulemaking
<b>TN #:</b>	219859
<b>Document Title:</b>	Presentation - Demand Control Ventilation for Classrooms
<b>Description:</b>	By: Mark Alatorre, PE
<b>Filer:</b>	Hilary Fiese
<b>Organization:</b>	California Energy Commission
<b>Submitter Role:</b>	Commission Staff
<b>Submission Date:</b>	6/23/2017 10:31:54 AM
<b>Docketed Date:</b>	6/23/2017



# **Demand Control Ventilation for Classrooms**

Mark Alatorre, PE  
Building Standards Office  
Efficiency Division

Pre-Rulemaking Workshop  
Imbrecht Hearing Room  
June 20, 2017



# Acknowledgements

California Statewide Codes and Standards Team

CASE Authors:

- Jeff Stein (Taylor Engineering)
- Stefan Gracik (Integral Group)
- Matt Dahlhausen (Integral Group)



## Background

- Carbon Dioxide (CO<sub>2</sub>) based Demand Control Ventilation (DCV) has been in use for over thirty years.
- ASHRAE 90.1 has mandated DCV for classrooms since 1999
- ASHRAE 90.1 has continually reduced the space density for triggering DCV
  - 25 people per 1000 square feet



# Background

- Demand Control Ventilation (DCV) has been part of the Energy Efficiency Standards since 1992
- 2001 Title 24, Part 6 – mandated for high-density spaces (including classrooms)
- 2005 Title 24, Part 6 – classrooms were exempt from DCV



# Background

- Given CO<sub>2</sub> based DCV have been in high use both in California and nationally
  - Improvement in sensor reliability
  - Reduction in sensor cost
- CASE Team contends that systems incorporating CO<sub>2</sub> DCV results in better indoor air quality compared to non DCV



# Background

- Product availability
  - Many manufacturers of standalone CO2 sensors
  - Building Automation Systems (BAS), most offer thermostats with embedded CO2 sensors
- Technology
  - Variety in sensor type, which should be understood by designers based on application



## Proposed Code Change

- Amend Section 120.1(c)3 to apply to more spaces, including classrooms
- Also add “modulating outside air control” and “design outdoor airflow rate > 3000 cfm” as triggers for DCV
- These changes will align Section 120.1(c)3 with ASHRAE 90.1





# Energy Analysis

- CBECC-Com can model DCV
- No changes to the proposed model other than DCV

Prototype ID	Occupancy Type (Residential, Retail, Office, etc.)	Area (ft <sup>2</sup> )	Number of Stories	Statewide Area (million ft <sup>2</sup> )
Prototype 1	Small Schools	24,413	1	9.17
Prototype 2	Large Schools	210,886	2	6.12



# Energy Analysis – First Year Impact per ft<sup>2</sup>

Small School				
Climate Zone	Electricity Savings (kWh/yr)	Peak Electricity Demand Reductions (kW)	Natural Gas Savings (therms/yr)	TDV Energy Savings (TDV kBtu/yr)
1	0.08	2.34 x 10 <sup>-5</sup>	0.06	13.20
2	0.23	2.89 x 10 <sup>-4</sup>	0.04	22.35
3	0.08	6.64 x 10 <sup>-5</sup>	0.03	10.13
4	0.22	1.39 x 10 <sup>-4</sup>	0.03	19.90
5	0.08	2.88 x 10 <sup>-5</sup>	0.04	10.01
6	0.12	1.20 x 10 <sup>-4</sup>	0.01	11.07
7	0.05	1.72 x 10 <sup>-4</sup>	0.01	6.53
8	0.23	2.70 x 10 <sup>-4</sup>	0.01	17.22
9	0.33	2.08 x 10 <sup>-4</sup>	0.02	25.52
10	0.36	2.77 x 10 <sup>-4</sup>	0.02	25.97
11	0.43	2.04 x 10 <sup>-4</sup>	0.03	33.04
12	0.35	2.32 x 10 <sup>-4</sup>	0.03	28.19
13	0.44	1.50 x 10 <sup>-4</sup>	0.03	27.67
14	0.44	2.85 x 10 <sup>-4</sup>	0.03	29.60
15	0.73	2.43 x 10 <sup>-4</sup>	0.01	36.30
16	0.16	8.03 x 10 <sup>-5</sup>	0.06	17.43



# Energy Analysis – First Year Impact per ft<sup>2</sup>

Large School				
Climate Zone	Electricity Savings (kWh/yr)	Peak Electricity Demand Reductions (kW)	Natural Gas Savings (therms/yr)	TDV Energy Savings (TDV kBtu/yr)
1	0.07	2.85 x 10 <sup>-5</sup>	0.06	12.95
2	0.13	6.33 x 10 <sup>-5</sup>	0.04	15.24
3	0.06	4.52 x 10 <sup>-5</sup>	0.03	8.46
4	0.12	5.53 x 10 <sup>-5</sup>	0.03	13.07
5	0.06	5.42 x 10 <sup>-5</sup>	0.04	9.55
6	0.07	9.38 x 10 <sup>-5</sup>	0.02	7.43
7	0.03	7.35 x 10 <sup>-5</sup>	0.01	4.16
8	0.12	5.38 x 10 <sup>-5</sup>	0.01	9.14
9	0.16	1.19 x 10 <sup>-4</sup>	0.02	13.01
10	0.16	2.78 x 10 <sup>-5</sup>	0.02	13.34
11	0.22	9.24 x 10 <sup>-5</sup>	0.03	19.58
12	0.18	7.44 x 10 <sup>-5</sup>	0.03	17.31
13	0.23	5.48 x 10 <sup>-5</sup>	0.03	17.57
14	0.23	2.52 x 10 <sup>-5</sup>	0.03	17.39
15	0.34	4.99 x 10 <sup>-5</sup>	0.01	17.43
16	0.10	6.08 x 10 <sup>-5</sup>	0.05	13.94



# Energy Analysis – 15 Year Costs per ft<sup>2</sup>

Small School			
Climate Zone	15-Year TDV Electricity Cost Savings (2020 PV\$)	15-Year TDV Natural Gas Cost Savings (2020 PV\$)	Total 15-Year TDV Energy Cost Savings (2020 PV\$)
1	\$0.20	\$0.97	\$1.17
2	\$1.30	\$0.68	\$1.99
3	\$0.39	\$0.51	\$0.90
4	\$1.30	\$0.47	\$1.77
5	\$0.29	\$0.60	\$0.89
6	\$0.73	\$0.25	\$0.98
7	\$0.45	\$0.13	\$0.58
8	\$1.30	\$0.23	\$1.53
9	\$1.98	\$0.29	\$2.27
10	\$1.96	\$0.35	\$2.31
11	\$2.35	\$0.59	\$2.94
12	\$1.91	\$0.60	\$2.51
13	\$1.89	\$0.57	\$2.46
14	\$2.04	\$0.59	\$2.63
15	\$3.05	\$0.18	\$3.23
16	\$0.56	\$0.99	\$1.55



# Energy Analysis – 15 Year Costs per ft<sup>2</sup>

Large School			
Climate Zone	15-Year TDV Electricity Cost Savings (2020 PV\$)	15-Year TDV Natural Gas Cost Savings (2020 PV\$)	Total 15-Year TDV Energy Cost Savings (2020 PV\$)
1	\$0.18	\$0.97	\$1.15
2	\$0.64	\$0.71	\$1.36
3	\$0.22	\$0.53	\$0.75
4	\$0.66	\$0.50	\$1.16
5	\$0.19	\$0.66	\$0.85
6	\$0.37	\$0.29	\$0.66
7	\$0.21	\$0.16	\$0.37
8	\$0.56	\$0.26	\$0.81
9	\$0.83	\$0.33	\$1.16
10	\$0.81	\$0.38	\$1.19
11	\$1.14	\$0.60	\$1.74
12	\$0.93	\$0.61	\$1.54
13	\$0.98	\$0.58	\$1.56
14	\$0.95	\$0.60	\$1.55
15	\$1.35	\$0.20	\$1.55
16	\$0.33	\$0.91	\$1.24



# Lifecycle Cost-Effectiveness per ft<sup>2</sup>

Small School			
Climate Zone	Benefits TDV Energy Cost Savings + Other PV Savings <sup>1</sup> (2020 PV\$)	Costs Total Incremental PV Costs <sup>2</sup> (2020 PV\$)	Benefit-to- Cost Ratio
1	\$1.17	\$0.21	5.6
2	\$1.99	\$0.21	9.5
3	\$0.90	\$0.21	4.3
4	\$1.77	\$0.21	8.4
5	\$0.89	\$0.21	4.2
6	\$0.98	\$0.21	4.7
7	\$0.58	\$0.21	2.8
8	\$1.53	\$0.21	7.3
9	\$2.27	\$0.21	10.8
10	\$2.31	\$0.21	11.0
11	\$2.94	\$0.21	14.0
12	\$2.51	\$0.21	11.9
13	\$2.46	\$0.21	11.7
14	\$2.63	\$0.21	12.5
15	\$3.23	\$0.21	15.4
16	\$1.55	\$0.21	7.4



# Lifecycle Cost-Effectiveness per ft<sup>2</sup>

Large School			
Climate Zone	Benefits TDV Energy Cost Savings + Other PV Savings <sup>1</sup> (2020 PV\$)	Costs Total Incremental PV Costs <sup>2</sup> (2020 PV\$)	Benefit-to- Cost Ratio
1	\$1.15	\$0.21	5.5
2	\$1.36	\$0.21	6.5
3	\$0.75	\$0.21	3.6
4	\$1.16	\$0.21	5.5
5	\$0.85	\$0.21	4.0
6	\$0.66	\$0.21	3.1
7	\$0.37	\$0.21	1.8
8	\$0.81	\$0.21	3.9
9	\$1.16	\$0.21	5.5
10	\$1.19	\$0.21	5.7
11	\$1.74	\$0.21	8.3
12	\$1.54	\$0.21	7.3
13	\$1.56	\$0.21	7.4
14	\$1.55	\$0.21	7.4
15	\$1.55	\$0.21	7.4
16	\$1.24	\$0.21	5.9



# Statewide Energy and Cost Savings

Small School					
Climate Zone	Statewide Construction in 2020 (million ft2)	First-Year Electricity Savings (GWh)	First-Year Peak Electrical Demand Reduction (MW)	First-Year Natural Gas Savings (million therms)	Lifecycle <sup>2</sup> Present Valued Energy Cost Savings (PV\$ million)
1	0.0498	0.004	0.001	0.003	\$0.06
2	0.2474	0.056	0.071	0.010	\$0.49
3	0.9078	0.073	0.060	0.027	\$0.82
4	0.5588	0.125	0.078	0.015	\$0.99
5	0.1085	0.008	0.003	0.004	\$0.10
6	0.5999	0.069	0.072	0.009	\$0.59
7	0.6454	0.032	0.111	0.005	\$0.38
8	0.8754	0.199	0.236	0.011	\$1.34
9	0.8878	0.293	0.185	0.015	\$2.02
10	1.2399	0.447	0.343	0.025	\$2.87
11	0.3230	0.139	0.066	0.011	\$0.95
12	1.3180	0.459	0.306	0.045	\$3.31
13	0.7148	0.314	0.107	0.023	\$1.76
14	0.2255	0.100	0.064	0.007	\$0.59
15	0.2278	0.166	0.055	0.002	\$0.74
16	0.2433	0.039	0.020	0.014	\$0.38
<b>Total</b>	<b>9.1729</b>	<b>2.525</b>	<b>1.779</b>	<b>0.226</b>	<b>\$17.37</b>





# Statewide Energy and Cost Savings

Small School					
Climate Zone	Statewide Construction in 2020 (million ft2)	First-Year Electricity Savings (GWh)	First-Year Peak Electrical Demand Reduction (MW)	First-Year Natural Gas Savings (million therms)	Lifecycle <sup>2</sup> Present Valued Energy Cost Savings (PV\$ million)
1	0.0332	0.002	0.001	0.002	\$0.04
2	0.1649	0.021	0.010	0.007	\$0.22
3	0.6052	0.034	0.027	0.019	\$0.46
4	0.3725	0.043	0.021	0.011	\$0.43
5	0.0723	0.004	0.004	0.003	\$0.06
6	0.3999	0.029	0.037	0.007	\$0.26
7	0.4302	0.014	0.032	0.004	\$0.16
8	0.5836	0.068	0.031	0.009	\$0.47
9	0.5918	0.096	0.070	0.011	\$0.69
10	0.8266	0.135	0.023	0.018	\$0.98
11	0.2153	0.048	0.020	0.007	\$0.38
12	0.8786	0.154	0.065	0.031	\$1.35
13	0.4765	0.108	0.026	0.016	\$0.74
14	0.1504	0.034	0.004	0.005	\$0.23
15	0.1519	0.051	0.008	0.002	\$0.24
16	0.1622	0.017	0.010	0.009	\$0.20
<b>Total</b>	<b>6.1153</b>	<b>0.859</b>	<b>0.390</b>	<b>0.158</b>	<b>\$6.92</b>



# Proposed Code Language

SECTION 120.1- REQUIREMENTS FOR VENTILATION 120.1(c)3 as follows:

~~3. **Required Demand Control Ventilation.** HVAC systems with the following characteristics shall have demand ventilation controls complying with 120.1(c)4:~~

~~A. They have an air economizer; and~~

~~B. They serve a space with a design occupant density, or a maximum occupant load factor for egress purposes in the CBC, greater than or equal to 25 people per 1000 square feet (40 square feet or less per person); and~~

~~C. They are either:~~

~~i. Single zone systems with any controls; or~~

~~ii. Multiple zone systems with Direct Digital Controls (DDC) to the zone level.~~



# Proposed Code Language

3. **Required Demand Control Ventilation.** Demand ventilation controls complying with 120.1(c)4 are required for a space with a design occupant density, or a maximum occupant load factor for egress purposes in the CBC, greater than or equal to 25 people per 1000 square feet (40 square feet or less per person) if the system serving the space has one or more of the following:
- A. an air economizer
  - B. modulating outside air control
  - C. design outdoor airflow rate > 3000 cfm

**EXCEPTION 1 to Section 120.1(c)3:** ~~Classrooms, call centers, office spaces served by multiple zone systems that are continuously occupied during normal business hours with occupant density greater than 25 people per 1000 ft<sup>2</sup> as specified by Section 120.1(b)2B, healthcare facilities and medical buildings, and public areas of social services buildings are not required to have demand control ventilation.~~ Spaces with one of the following occupancy categories as defined in the California Mechanical Code: correctional cells, daycare sickrooms, science labs, barber shops, beauty and nail salons, and bowling alley seating.

**EXCEPTION 5 to Section 120.1(c)3:** ~~Spaces with an area of less than 1,500 square feet complying with Section 120.1(c)5.~~



# Questions?

Mark Alatorre

[mark.alatorre@energy.ca.gov](mailto:mark.alatorre@energy.ca.gov)

(916) 654-4642

Comments Due by July 7th

Docket Number 2017-BSTD-01

[docket@energy.ca.gov](mailto:docket@energy.ca.gov)