

DOCKETED

Docket Number:	17-BSTD-01
Project Title:	2019 Building Energy Efficiency Standards PreRulemaking
TN #:	219882
Document Title:	UC Davis Comments Unrealistic Weekend Hours
Description:	N/A
Filer:	System
Organization:	UC Davis/Chris Jakober
Submitter Role:	Public Agency
Submission Date:	6/23/2017 2:18:21 PM
Docketed Date:	6/23/2017

Comment Received From: Chris Jakober

Submitted On: 6/23/2017

Docket Number: 17-BSTD-01

Unrealistic Weekend Hours

While the 8 total hours of occupancy for teaching labs over the weekends is reasonable, there will be research labs that meet the 1:35 fume hood density criteria. Weekend occupancy for those types of research environments is far more likely to be 8-12 hours per day, or 16-24 total hours of occupancy per weekend.