

DOCKETED

Docket Number:	17-BSTD-01
Project Title:	2019 Building Energy Efficiency Standards PreRulemaking
TN #:	220187
Document Title:	RNM Engineering, Inc. Comments On 2019 Nonresidential Standards
Description:	N/A
Filer:	System
Organization:	RNM Engineering, Inc.
Submitter Role:	Public
Submission Date:	7/14/2017 1:45:52 PM
Docketed Date:	7/14/2017

Comment Received From: RNM Engineering, Inc.

Submitted On: 7/14/2017

Docket Number: 17-BSTD-01

On 2019 Nonresidential Standards

Additional submitted attachment is included below.

From: rickmiller@rnm-eng.com
Sent: Friday, July 14, 2017 11:23 AM
To: Energy - Docket Optical System
Cc: Lee, Simon@Energy
Subject: Docket #17-BSTD-01 - 2019 Nonresidential Standards

Existing language:

SECTION 120.6

(f) Mandatory Requirements for Elevators

EXCEPTION 1 to Section 120.6(f)1: Interior signal lighting and interior display lighting are not included in the calculation of lighting power **density**.

Proposed language:

SECTION 120.6

(f) Mandatory Requirements for Elevators

EXCEPTION 1 to Section 120.6(f)1: Interior signal lighting and interior display lighting are not included in the calculation of lighting power.

Rational:

The calculations result in lighting power.
'Lighting Power Density' is a lookup value

Rick Miller
RNM Engineering, Inc.
90 Baron Canyon Ranch Road
San Luis Obispo, CA 93401
Fax: 805-781-0816
Mobile: 415-307-5106
Email: RickMiller@RNM-eng.com