

DOCKETED

| | |
|-------------------------|---|
| Docket Number: | 86-AFC-01C |
| Project Title: | Compliance - Application for Certification for the (ACE) Argus Cogeneration Expansion AFC |
| TN #: | 220694 |
| Document Title: | Attachment 3 - ACE Generator Permit - 1995 |
| Description: | Mojave Desert AQ Permit to Operate |
| Filer: | Mineka Foggie |
| Organization: | ACE Cogeneration Company |
| Submitter Role: | Applicant |
| Submission Date: | 8/11/2017 1:37:32 PM |
| Docketed Date: | 8/11/2017 |

Attachment 3 - ACE Generator Permit - 1995

MOJAVE DESERT

AIR QUALITY MANAGEMENT DISTRICT

15428 CIVIC DRIVE, VICTORVILLE, CA 92392 (619) 245-1661

E003369

PERMIT TO OPERATE

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit conditions, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If copy is posted, original must be maintained on site in central file available for inspection at all times.

EXPIRES LAST DAY OF: DECEMBER 1995

Page 1 of 1

LEGAL OWNER OR OPERATOR: (500)

A.C.E. COGENERATION CO.

12801 S. Mariposa

Trona, CA 93562

EQUIPMENT LOCATION: (1051)

A.C.E. COGENERATION CO.

12801 S. Mariposa

Trona, Ca 93562

DESCRIPTION:

GENERATOR, DIESEL EMERGENCY - Caterpillar engine Model No. 3208-175, 263 BHP @ 1800 rpm, Serial No. 5YF00392.

CONDITIONS:

1. The owner/operator (o/o) shall log all starting and stopping times of this generator to the nearest minute; the date; and the delivery of fuel.
2. The o/o shall comply with all applicable rules and regulations of the District.
3. The o/o shall not use diesel fuel whose sulfur concentration $\geq 0.05\%$ on w/w.
4. The o/o shall not use any fuel in this generator, other than diesel, without the written prior approval of the District. The o/o may use the supplier's sulfur analytical data, but at the discretion of the District shall take a sample of the fuel and submit it for analysis by an independent laboratory. The results of said analyses, by ASTM method D 2622-82, shall be logged.