

DOCKETED

Docket Number:	17-BSTD-01
Project Title:	2019 Building Energy Efficiency Standards PreRulemaking
TN #:	221258
Document Title:	Draft 2019 Standards Chapter 4-130
Description:	Draft version of Chapter 4-130 for the 2019 Standards update.
Filer:	Adrian Ownby
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	9/20/2017 3:11:19 PM
Docketed Date:	9/20/2017

SUBCHAPTER 4

NONRESIDENTIAL, HIGH-RISE RESIDENTIAL, AND HOTEL/MOTEL OCCUPANCIES—MANDATORY REQUIREMENTS FOR LIGHTING SYSTEMS AND EQUIPMENT, AND ELECTRICAL POWER DISTRIBUTION SYSTEMS

SECTION 130.0 – LIGHTING SYSTEMS AND EQUIPMENT, AND ELECTRICAL POWER DISTRIBUTION SYSTEMS —GENERAL

- (a) The design and installation of all lighting systems and equipment in nonresidential, high-rise residential, hotel/motel buildings, outdoor lighting, and electrical power distribution systems within the scope of Section 100.0(a) shall comply with the applicable provisions of Sections 130.0 through 130.5.

NOTE: The requirements of Sections 130.0 through 130.5 apply to newly constructed buildings. Section 141.0 specifies which requirements of Sections 130.0 through 130.5 also apply to additions and alterations to existing buildings.

- (b) **Functional areas where compliance with ~~the residential lighting standards~~ is required.** The design and installation of all lighting systems, lighting controls, and equipment in the following functional areas shall comply with the applicable ~~provisions-residential lighting requirements~~ of Section 150.0(k). In buildings containing these functional areas, all other functional areas, such as common areas, shall comply with the applicable nonresidential lighting ~~Standards~~ and ~~the applicable nonresidential~~ controlled receptacle requirements ~~in Section 130.5(d)~~.

1. High-rise residential dwelling units.
2. Outdoor lighting ~~that is~~ attached to a high-rise residential or hotel/motel building, and ~~is~~ separately controlled from the inside of a dwelling unit or guest room.
3. Fire station dwelling accommodations.
4. Hotel and motel guest rooms. Additionally, hotel and motel guest rooms shall meet the requirements of Section 130.1(c)~~86~~ and Section 130.5(d)4.
5. Dormitory and Senior housing dwelling accommodations.

NOTE: The requirements of Section 130.0(b) also apply to additions and alterations to functional areas of existing buildings as specified in Section 130.0(b).

- (c) **Luminaire classification and power.** Luminaires shall be classified and ~~their~~ wattage determined as follows:

1. ~~Luminaire labeling.~~ Luminaire wattage shall be labeled as follows:
 - A. The maximum relamping rated wattage of a luminaire shall be listed on a permanent, preprinted, factory-installed label, as specified by UL 1574, 1598, 2108, or 8750, as applicable; and
 - B. The factory-installed maximum relamping rated wattage label shall not consist of peel-off or peel-down layers or other methods that allow the rated wattage to be changed after the luminaire has been shipped from the manufacturer.

EXCEPTION to Section 130.0(c)1B: Peel-down labels may be used only for the following luminaires when they can accommodate a range of lamp wattages without changing the luminaire housing, ballast, transformer or wiring. Qualifying luminaires shall have a single lamp, and shall have integrated

- ballasts or transformers. Peel-down labels must be layered such that the rated wattage reduces as successive layers are removed.
- i. High intensity discharge luminaires, having an integral electronic ballast, with a maximum relamping rated wattage of 150 watts.
 - ii. Low-voltage luminaires (except low voltage track systems), ≤ 24 volts, with a maximum relamping rated wattage of 50 watts.
 - iii. Compact fluorescent luminaires, having an integral electronic ballast, with a maximum relamping rated wattage of 42 watts.
2. For luminaires with ~~line voltage~~ lamp holders ~~that do not containing~~ permanently installed ballasts, drivers, or other transformers; the wattage of such luminaires shall be ~~determined as follows~~:
 - ~~A. The maximum relamping~~ rated wattage of the luminaire or the rated wattage of the installed lamp, whichever is lower. If no lamp is installed, then the rated wattage shall be the maximum rated wattage of the lamp holder; and
 - ~~B. For recessed luminaires with line voltage medium screw base sockets, wattage shall not be less than 50 watts per socket.~~
 3. ~~Luminaires and luminaire housings designed to accommodate a variety of trims or modular components that allow the conversion between incandescent and any other lighting technology without changing the luminaire housing or wiring shall be classified as incandescent.~~
 4. ~~Screwbased adaptors shall not be used to convert an incandescent luminaire to any type of nonincandescent technology. Screw based adaptors, including screw base adaptors classified as permanent by the manufacturer, shall not be recognized for compliance with Part 6.~~
 5. ~~Luminaires and luminaire housings with incandescent screw base sockets shall be classified only as incandescent. Field modifications, including but not limited to hard wiring of an LED module, shall not be recognized as converting an incandescent luminaire or luminaire housing to a nonincandescent technology for compliance with Part 6 unless such sockets are removed.~~
 6. ~~For L~~ luminaires with lamp holders and permanently installed or remotely installed ballasts, ~~or drivers, or other transformers.~~; ~~the wattage of such luminaires shall be determined as follows~~ either the rated wattage of the ballast, driver, or transformer, or the rated wattage of the installed lamp and ballast, driver, or transformer combination, whichever is lower. If no lamp is installed, then the rated wattage shall be the wattage of the ballast, driver, or transformer.
 - A. ~~The operating input~~ wattage of the rated ballast or lamp/ballast combination shall be the operating input wattage published in the ballast manufacturer's catalogs based on independent testing lab reports as specified by UL 1598; ~~or~~
 - B. ~~The maximum input~~ wattage of the rated driver or transformer, or lamp/driver or lamp/transformer combination shall be the maximum input wattage published in the driver's manufacturer catalogs based on independent testing lab reports as specified by UL- 2108, 8750 or LM-79.
 4. ~~For inseparable SSL luminaires and SSLs that are not reliant on luminaires, the maximum rated wattage shall be the maximum rated input wattage of the SSL when tested in accordance with UL 1598, 2108, 8750, or IES LM-79-08.~~
 75. ~~Line voltage lighting track and plug in busway~~ For modular lighting systems that allows the addition or relocation of luminaires without altering the wiring of the system, including but not limited to modular LED undercabinet lighting and line-voltage lighting track and plug-in busway, ~~the wattage of such systems inclusive of any and all connected luminaires shall be determined by one of the following methods, based on the component that limits the current available to lighting added to the system:~~
 - A. ~~The wattage of line voltage busway and track rated for more than 20 amperes shall be the total volt-ampere rating of the branch circuit feeding the busway and track.~~
 - B. ~~The wattage of line voltage busway and track rated for 20 amperes or less shall be determined by one of the following methods:~~

- A. When there is no current limiting component on the circuit, the wattage shall be the greater of:
- i. 30 watts per linear foot of track or plug-in busway; or
 - ii. the rated wattage of all of the luminaires included in the system, where the luminaire wattage is determined as specified in Section 130.0(c)1. The volt-ampere rating of the branch circuit feeding the track or busway; or
 - ii. The higher of the rated wattage of all of the luminaires included in the system, where luminaire classification and wattage is determined according to the applicable provisions in Section 130.0(c), or 45 watts per linear foot; or
- ~~iii.B. When using the current limiting component is a line-voltage track lighting integral current limiter or a dedicated track lighting supplementary overcurrent protection panel, the rated wattage shall be the maximum rated input wattage of the current limiter device and the overcurrent protection panel as published in the manufacturer's catalog, or the product of the branch circuit voltages and the current rating of the current limiter device as listed by UL 1077 or the supplementary overcurrent device as listed by UL 489 the higher of the volt-ampere rating of an integral current limiter controlling the track or busway, or 12.5 watts per linear foot of track or busway. An Integral current limiter shall be certified to the Energy Commission in accordance with Section 110.9, and shall comply with the Lighting Control Installation Requirements in accordance with Section 130.4, to qualify to use Subsection Biii to determine luminaire power; or~~
- iv. When using a dedicated track lighting supplementary overcurrent protection panel, the rated power shall be the sum of the ampere (A) rating of all of the overcurrent protection devices times the branch circuit voltages. Track lighting supplementary overcurrent protection panels shall comply with the applicable requirements in Section 110.9, and shall comply with the Lighting Control Installation Requirements in accordance with Section 130.4, to qualify to use Subsection Biv to determine luminaire power.
- C. When the current limiting component is a driver or other type of transformer, the rated power/wattage shall be the maximum rated input wattage of the driver or transformer, labeled in accordance with Item 1, or the maximum rated input wattage published in the driver or transformer manufacturer's catalogs, as specified by UL 2108 or 8750.
- ~~8. Luminaires and lighting systems with permanently installed or remotely installed transformers. The wattage of such luminaires shall be determined as follows:~~
- ~~A. For low voltage luminaires that do not allow the addition of lamps, lamp holders, or luminaires without rewiring, the wattage shall be the rated wattage of the lamp/transformer combination.~~
 - ~~B. For low voltage lighting systems, including low voltage tracks and other low voltage lighting systems that allow the addition of lamps, lamp holders, or luminaires without rewiring, the wattage shall be the maximum rated input wattage of the transformer, labeled in accordance with Item 1, or the maximum rated wattage published in transformer manufacturer's catalogs, as specified by UL 2108.~~
- ~~9. Light-emitting diode (LED) Luminaires, and LED Light Engine.~~
- ~~A. The wattage of such luminaires shall be the maximum rated input wattage of the system when tested in accordance with IES LM 79-08.~~
 - ~~B. The maximum rated input wattage shall be labeled in accordance with Section 130.0(c)1.~~
 - ~~C. An LED lamp, integrated or nonintegrated type in accordance with the definition in ANSI/IES RP-16-2010, shall not be classified as a LED lighting system for compliance with Part 6. LED modules having screw bases, including but not limited to screw-based pig tails, screw-based sockets, or screw-based adaptors, shall not be recognized as a LED lighting system for compliance with Part 6.~~
 - ~~D. Luminaires manufactured or rated for use with low voltage incandescent lamps, into which have been installed LED modules or LED lamps, shall not be recognized as a LED lighting system for compliance with Part 6.~~

~~E. For LED lighting systems that allow the addition of luminaires or light engines without rewiring, the wattage of such luminaires shall be the maximum rated input wattage of the power supply, labeled in accordance with Section 130.0(c)1 or published in the power supply manufacturer's catalog.~~

~~**EXCEPTION to Section 130.0(c)9:** Luminaires in areas that must comply with Section 150.0(k), as specified by Section 130.0(b).~~

~~406. The wattage of all other ~~miscellaneous~~ lighting equipment not addressed by Sections 130.0(c)1 through 5 shall be the maximum rated wattage of the lighting equipment, or operating input wattage of the system, labeled in accordance with Section 130.0(c)1, or published in manufacturer's catalogs, based on independent testing lab reports as specified by UL 1574 or UL 1598. ~~Lighting technologies listed in Subsections 2 through 9 shall be determined in accordance with the applicable requirements in Subsections 1 through 9.~~~~

(d) **Lighting Controls.** All lighting controls and equipment shall comply with the applicable requirements in Sections 110.9, 130.1 and 130.2, and shall be installed in accordance with the manufacturer's instructions.

(e) **Energy Management Control System (EMCS).**

~~1.~~ An EMCS may be installed to comply with the requirements of one or more lighting controls if it meets the following minimum requirements:

~~A1.~~ Provides all applicable functionality for each specific lighting control or system for which it is installed in accordance with Sections 110.9, 130.1 and 130.2; and

~~B2.~~ Complies with all applicable Lighting Control Installation Requirements in accordance with Section 130.4 for each specific lighting control or system for which it is installed; and

~~C3.~~ Complies with all applicable application requirements for each specific lighting control or system for which it is installed, in accordance with Part 6.

SECTION 130.1 – MANDATORY INDOOR LIGHTING CONTROLS

Nonresidential, high-rise residential, and hotel/motel buildings shall comply with the applicable requirements of Sections 130.1(a) through 130.1(ef), in addition to the applicable requirements of Sections 110.9 and 130.0.

EXCEPTION to Section 130.1: Lighting connected to a Life Safety Branch or Critical Branch as specified in Section 517 of the California Electrical Code is not subject to the requirements of this Section.

(a) **Manual Area Controls.**

~~1. All luminaires shall be functionally controlled with manual ON and OFF lighting controls. Each area enclosed by ceiling-height partitions shall be independently controlled provide lighting controls that allow the lighting in that area to be manually turned on and off. The manual control shall:~~

- ~~1. Be readily accessible; and~~
- ~~2. Be located in the same enclosed area with the lighting it controls; and~~

EXCEPTION 1 to Section 130.1(a)2: For psychiatric and secure areas in healthcare facilities, malls and atria, auditorium areas, retail merchandise sales areas, wholesale showroom areas, commercial and industrial storage areas, general commercial and industrial work areas, convention centers, and arenas, the manual area control may instead be located so that a person using the control can see the lights or area controlled by that control, or provide a display that shows the current state of the controlled lighting.

EXCEPTION 2 to Section 130.1(a)2: In healthcare facilities, for restrooms and bathing rooms intended for a single occupant, the lighting control may be located outside the enclosed area but directly adjacent to the door.

- ~~3. Provide separate control of general, floor display, wall display, window display, case display, ornamental, and special effects lighting, such that each type of lighting can be turned on or off without turning on or off other types of lighting, and without turning on or off any other equipment.~~

EXCEPTION to Section 130.1(a)1: Up to 0.2 watts per square foot of indoor lighting in any area within a building may be continuously illuminated to allow for means of egress illumination consistent with California Building Code Section 1008.7. Dedicated egress lighting complying with this wattage limitation is not required to comply with manual area control requirements if:

- ~~A1.~~ The area is designated for means of egress on the plans and specifications submitted to the enforcement agency under Section 10-103(a)2 of Part 1; and
- ~~B2.~~ The controls for the egress lighting are not accessible to unauthorized personnel.
- ~~2. The lighting controls shall meet the following requirements:~~
 - ~~A. Be readily accessible; and~~
 - ~~B. Be operated with a manual control that is located in the same room or area with the lighting that is controlled by that lighting control.~~

EXCEPTION 1 to Section 130.1(a)2: In malls and atria, auditorium areas, retail merchandise sales areas, wholesale showroom areas, commercial and industrial storage areas, general commercial and industrial work areas, convention centers, and arenas, the lighting control shall

- ~~1. be located so that a person using the lighting control can see the lights or area controlled by that lighting control, or~~
- ~~2. so that the area being lit is annunciated.~~

EXCEPTION 2 to Section 130.1(a)2: Public restrooms having two or more stalls, parking areas, stairwells, and corridors may use a manual control not accessible to unauthorized personnel.

~~3. Other Lighting Controls.~~

- ~~A. Other lighting controls may be installed in addition to the manual lighting controls provided they do not override the functionality of controls installed in accordance with Section 130.1(a)1, 2, or 4.~~

- ~~4. **Separately Controlled Lighting Systems.** In addition to the requirements in Section 130.1(a)1, 2, and 3:~~
- ~~A. General lighting shall be separately controlled from all other lighting systems in an area.~~
 - ~~B. Floor and wall display, window display, case display, ornamental, and special effects lighting shall each be separately controlled on circuits that are 20 amps or less.~~
 - ~~C. When track lighting is used, general, display, ornamental, and special effects lighting shall each be separately controlled.~~

- (b) **Multi-Level Lighting Controls.** The general lighting of any enclosed area 100 square feet or larger, with a connected lighting load that exceeds 0.5 watts per square foot shall provide multi-level lighting controls that meets the following requirements allow the level of lighting to be adjusted up and down. The multi-level controls shall:

- ~~1. Lighting shall have provide the required number of control steps and meet the uniformity requirements specified in accordance with TABLE 130.1-A;~~
- ~~2. Multi-level lighting controls shall not override the functionality of other lighting controls required for compliance with Sections 130.1(a), and (c) through (e); and~~
- ~~3. Dimmable luminaires shall be controlled by a dimmer control that is capable of controlling lighting through all required lighting control steps and that allows the manual ON and OFF functionality required by Section 130.1(a).~~

~~**EXCEPTION 1 to Section 130.1(b):** Classrooms with a connected general lighting load of 0.7 watts per square foot or less and public restrooms shall have at least one control step between 30-70 percent of full rated power.~~

~~**EXCEPTION 2 1 to Section 130.1(b):** An area enclosed by ceiling height partitions that has only one luminaire with no more than two lamps.~~

~~**EXCEPTION 2 to Section 130.1(b): Restrooms.**~~

~~**EXCEPTION 3 to Section 130.1(b):** The areas specified in Sections 130.1(c)6 and 7 are not also required to meet the requirements of Section 130.1(b).~~

- (c) **Automatic Shut-OFF Controls.** All installed indoor lighting shall be equipped with controls able to automatically turn the lighting off when the space is typically unoccupied.
- 1. In addition to lighting controls installed to comply with Sections 130.1(a) and (b), all installed indoor lighting shall be equipped with controls that meet the following requirements. The automatic control shall:
 - A. Provide an occupant sensing control, automatic time-switch control, captive key, or other control function capable of automatically shutting OFF-off all of the lighting when the space is typically unoccupied; and
 - B. For enclosed spaces other than stairwells that span multiple floors, provide Sseparate controls for the lighting on each floor, other than lighting in stairwells; and
 - C. Provide Sseparate controls for a each space enclosed by ceiling height partitions or, if the enclosed area is greater than 5,000 square feet, provide separate control for each portion of the enclosed area not to exceed ing 5,000 square feet; and

~~**EXCEPTION to Section 130.1(c)1C:** In the following function areas the area controlled may not exceed 20,000 square feet: Malls, auditoriums, single tenant retail, industrial, convention centers, and arenas;~~

- ~~D. Provide Sseparate controls for general, floor, wall, display, and ornamental, and display case lighting, consistent with Section 130.1(a)3;-~~
- ~~E. For controls having an automatic time switch function, provide either occupant sensing or an override function that allows the lighting to remain on for no more than 2 hours when an override is initiated, or until no more than 30 minutes after a captive key is removed.~~
- ~~F. For controls having an automatic time switch function, provide the ability to operate in manual-ON mode.~~

G. For controls having an automatic time switch function, provide an automatic holiday shutoff feature that turns lighting off for a 24-hour period then resumes its normal scheduled operation.

EXCEPTION to Section 130.1(c)1G: In retail stores and associated malls, restaurants, grocery stores, churches, and theaters, the automatic time-switch control is not required to incorporate an automatic holiday shut-OFF feature.

H. For controls having a partial-off function, be capable of reducing power by at least 50 percent while in the partial-off mode.

EXCEPTION 1 to Section 130.1(c)1: Where the lighting is serving an area that is in continuous use, 24 hours per day/365 days per year.

EXCEPTION 2 to Section 130.1(c)1: Lighting complying with Section 130.1(c)5 or 7.

EXCEPTION 3 to Section 130.1(c)1: Up to 0.1 watts per square foot of lighting in any area within a building may be continuously illuminated, provided that the area is designated for means of egress on the plans and specifications submitted to the enforcement agency under Section 10 103(a)2 of Part 1.

EXCEPTION 4 to Section 130.1(c)1: Electrical equipment rooms subject to Article 110.26(D) of the California Electrical Code.

EXCEPTION 5 to Section 130.1(c): Illumination provided by lighting equipment that is designated for emergency lighting, connected to an emergency power source or battery supply, and is intended to function in emergency mode only when normal power is absent.

2. Countdown timer switches ~~shall not~~may be used to comply with the automatic shut-OFF control requirements in Section 130.1(c)1 only in closets less than 70 square feet, and server aisles in server rooms. The maximum timer setting shall be 10 minutes for closets, and 30 minutes for server aisles.

EXCEPTION 1 to Section 130.1(c)2: Single stall bathrooms less than 70 square feet, and closets less than 70 square feet may use countdown timer switches with a maximum setting capability of ten minutes to comply with the automatic shut Off requirements.

EXCEPTION 2 to Section 130.1(c)2: Lighting in a Server Aisle in a Server Room, as defined in Section 100.1, may use countdown timer switches with a maximum setting capability of 30 minutes to comply with the automatic shut OFF requirements.

3. ~~If an automatic time switch control, other than an occupant sensing control, is installed to comply with Section 130.1(c)1, it shall incorporate an override lighting control that:~~

~~A. Complies with Section 130.1(a); and~~

~~B. Allows the lighting to remain ON for no more than 2 hours when an override is initiated.~~

EXCEPTION to Section 130.1(c)3B: In the following function areas, the override time may exceed 2 hours: Malls, auditoriums, single tenant retail, industrial, and arenas where captive key override is utilized.

4. ~~If an automatic time switch control, other than an occupant sensing control, is installed to comply with Section 130.1(c)1, it shall incorporate an automatic holiday "shut-OFF" feature that turns OFF all loads for at least 24 hours, and then resumes the normally scheduled operation.~~

EXCEPTION to Section 130.1(c)4: In retail stores and associated malls, restaurants, grocery stores, churches, and theaters, the automatic time switch control is not required to incorporate an automatic holiday shut OFF feature.

5. **Areas where Occupant Sensing Controls are required to shut OFF All Lighting.** ~~Occupant sensing is required~~ in office areas 250 square feet or smaller, multipurpose rooms of less than 1,000 square feet, classrooms of any size, and conference rooms, and restrooms of any size, lighting shall be controlled with occupant sensing controls to automatically shut OFF all of the lighting when the room is unoccupied. Occupant sensing is also required in corridors, stairwells, aisle ways in warehouses, open areas in warehouses, parking garages, parking areas, loading and unloading areas, library book stack aisles 10 feet or longer that are accessible from only one end, and library book stack aisles 20 feet or longer that are accessible from both ends. These controls shall provide the following in addition to the requirements of 130.1(c)1:

- A. For library stack aisles, provide independent control for each aisle;
- B. For parking garages, parking areas, and loading and unloading areas, provide independent control for each 500 watts of lighting; and
- C. For corridors and stairwells, parking garages, parking areas, and loading and unloading areas, ensure that lighting within the area is automatically activated from all designed paths of egress.

~~In areas required by Section 130.1(b) to have multi-level lighting controls, the occupant sensing controls shall function either as a:~~

- ~~A. Partial ON Occupant Sensor capable of automatically activating between 50-70 percent of controlled lighting power, or~~
- ~~B. Vacancy Sensor, where all lighting responds to a manual ON input only.~~

~~In areas not required by Section 130.1(b) to have multi-level lighting controls, the occupant sensing controls shall function either as a:~~

- ~~A. Occupant Sensor; or~~
- ~~B. Partial ON Occupant Sensor, or~~
- ~~C. Vacancy Sensor, where all lighting responds to a manual ON input only.~~

~~In addition, controls shall be provided that allow the lights to be manually shut OFF in accordance with Section 130.1(a) regardless of the sensor status.~~

64. Areas where full or partial OFF occupant sensing controls are required. Lighting installed in the following areas shall meet the following requirements in addition to complying with Section 130.1(c)1:

- ~~A. In corridors, stairwells, ramps, library stack aisles, aisle ways in warehouses and open areas in warehouses, lighting shall be controlled with occupant sensing controls. The automatic shutoff controls may be configured with a partial-off function that automatically reduces lighting power by at least 50 percent when the areas are unoccupied instead of automatically turning the lighting off. The occupant sensing controls shall independently control lighting in each aisle way, and shall not control lighting beyond the aisle way being controlled by the sensor.~~

EXCEPTION to Section 130.1(c)4: Lighting in corridors, stairwells, ramps and aisles that provide egress for the building and for which egress lighting is required under Title 24, Part 2, Section 1008 shall be controlled with occupant sensing controls that automatically reduce lighting power to no less than the level necessary to maintain egress lighting levels when the spaces are unoccupied. When the building is unoccupied, egress lighting may be extinguished if approved by the Fire Marshal.

EXCEPTION 1 to Section 130.1(c)6A: In aisle ways and open areas in warehouses in which the installed lighting power is 80 percent or less of the value allowed under the Area Category Method, occupant sensing controls shall reduce lighting power by at least 40 percent.

EXCEPTION 2 to Section 130.1(c)6A: When metal halide lighting or high pressure sodium lighting is installed in warehouses, occupant sensing controls shall reduce lighting power by at least 40 percent.

- ~~B. In library book stack aisles 10 feet or longer that are accessible from only one end, and library book stack aisles 20 feet or longer that are accessible from both ends, lighting shall be controlled with occupant sensing controls that automatically reduce lighting power by at least 50 percent when the areas are unoccupied. The occupant sensing controls shall independently control lighting in each aisle way, and shall not control lighting beyond the aisle way being controlled by the sensor.~~

- ~~C. Lighting installed in corridors and stairwells shall be controlled by occupant sensing controls that separately reduce the lighting power in each space by at least 50 percent when the space is unoccupied. The occupant sensing controls shall be capable of automatically turning the lighting fully ON only in the separately controlled space, and shall be automatically activated from all designed paths of egress.~~

75. Areas where partial OFF occupant sensing controls are required. Lighting installed in the following areas shall meet the following requirements instead of complying with Section 130.1(c)1:

- ~~A. Lighting In parking garages, parking areas, loading and unloading areas, and for any lighting that provides means of egress illumination required by California Building Code Section 1008 in stairwells and common~~

~~area corridors that provide access to guestrooms and dwelling units of high-rise residential buildings and hotel/motels, shall be controlled with occupant sensing controls. Automatic shutoff controls shall provide a partial-off function that automatically reduces lighting power by at least 50 percent when the areas are unoccupied instead of automatically turning the lighting off. Lighting providing means of egress illumination shall be configured to provide no less than the amount of light required by California Building Code Section 1008 while in the partial-off mode.~~

~~The occupant sensing controls shall be capable of automatically turning the lighting fully ON only in the separately controlled space, and shall be automatically activated from all designed paths of egress.~~

~~**EXCEPTION to Section 130.1(c)7A:** In corridors and stairwells in which the installed lighting power is 80 percent or less of the value allowed under the Area Category Method, occupant sensing controls shall reduce power by at least 40 percent.~~

~~B. In parking garages, parking areas and loading and unloading areas, general lighting shall be controlled by occupant sensing controls having at least one control step between 20 percent and 50 percent of design lighting power. No more than 500 watts of rated lighting power shall be controlled together as a single zone. A reasonably uniform level of illuminance shall be achieved in accordance with the applicable requirements in TABLE 130.1 A. The occupant sensing controls shall be capable of automatically turning the lighting fully ON only in the separately controlled space, and shall be automatically activated from all designed paths of egress.~~

~~Interior areas of parking garages are classified as indoor lighting for compliance with Section 130.1(c)7B. Parking areas on the roof of a parking structure are classified as outdoor hardscape and shall comply with the applicable provisions in Section 130.2.~~

~~**EXCEPTION to Section 130.1(c)7B:** Metal halide luminaires with a lamp plus ballast mean system efficacy of greater than 75 lumens per watt, used for general lighting in parking garages, parking areas and loading and unloading areas, shall be controlled by occupant sensing controls having at least one control step between 20 percent and 60 percent of design lighting power.~~

~~86. In hotel/motel guest rooms providing transient lodging, the automatic shutoff controls shall have captive card key controls, occupancy sensing controls, or automatic controls such that, automatically turn the lighting off no longer than 30 minutes after the guest room has been vacated, lighting power is switched off.~~

~~**EXCEPTION 1 to Section 130.1(c):** Lighting serving an area that is in continuous use, 24 hours per day/365 days per year.~~

~~**EXCEPTION 2 to Section 130.1(c):** Dedicated egress lighting that qualifies for the Exception to Section 130.1(a).~~

~~**EXCEPTION 3 to Section 130.1(c):** Lighting in electrical equipment rooms subject to Article 110.26(D) of the California Electrical Code.~~

~~**EXCEPTION 4 to Section 130.1(c):** Lighting equipment that is designated for emergency lighting, connected to an emergency power source or battery supply, and intended to function in emergency mode only when normal power is absent.~~

~~**EXCEPTION 5 to Section 130.1(c)8:** For hotel-motel guest rooms, one high-efficacy luminaire as defined in TABLE 150.0 A that is switched separately and where the switch is located within 6 feet of the entry door.~~

~~**EXCEPTION 6 to Section 130.1(c):** Healthcare facilities.~~

(d) **Automatic Daylighting Controls.** ~~The general lighting in skylit/daylit zones and primary/sidelit daylit zones, as well as the general lighting in the combined primary and secondary sidelit daylit zones in parking garages, shall provide controls that automatically adjust the power of the installed lighting up and down to keep the total light level stable as the amount of incoming daylight changes. For skylight located in an atrium, the skylit/daylit zone definition shall apply to the floor area directly under the atrium and the top floor area directly adjacent to the atrium.~~

~~1. Daylit Zones shall be defined as follows:~~

~~A. **SKYLIT DAYLIT ZONE** is the rough area in plan view under each skylight, plus 0.7 times the average ceiling height in each direction from the edge of the rough opening of the skylight, minus any area on a plan beyond a permanent obstruction that is taller than the following: A permanent obstruction that is taller than~~

~~one half the distance from the floor to the bottom of the skylight. The bottom of the skylight is measured from the bottom of the skylight well for skylights having wells, or the bottom of the skylight if no skylight well exists.~~

- ~~— For the purpose of determining the skylit daylight zone, the geometric shape of the skylit daylight zone shall be identical to the plan view geometric shape of the rough opening of the skylight; for example, for a rectangular skylight the skylit daylight zone plan area shall be rectangular, and for a circular skylight the skylit daylight zone plan area shall be circular.~~

- ~~B. **PRIMARY SIDELIT DAYLIT ZONE** is the area in plan view and is directly adjacent to each vertical glazing, one window head height deep into the area, and window width plus 0.5 times window head height wide on each side of the rough opening of the window, minus any area on a plan beyond a permanent obstruction that is 6 feet or taller as measured from the floor.~~
- ~~C. **SECONDARY SIDELIT DAYLIT ZONE** is the area in plan view and is directly adjacent to each vertical glazing, two window head heights deep into the area, and window width plus 0.5 times window head height wide on each side of the rough opening of the window, minus any area on a plan beyond a permanent obstruction that is 6 feet or taller as measured from the floor.~~

~~**Note:** Modular furniture walls shall not be considered a permanent obstruction.~~

- ~~2. Luminaires providing general lighting that are in or are partially in the Skylit Daylit Zones or the Primary Sidelit Daylit Zones shall be controlled independently by fully functional automatic daylighting controls that meet the applicable requirements of Section 110.9, and the applicable requirements below:~~

- ~~A1. All S_{skylit} D_{daylit} Z_{zones}, and P_{primary} S_{sidelit} D_{daylit} Z_{zones}, and the combined primary and secondary sidelit daylight zones in parking garages shall be shown on the plans. Parking areas on the roof of a parking structure are classified as outdoor hardscape, not as skylit daylight area.~~

~~**EXCEPTION 1 to Section 130.1(d)1:** Areas under skylights where it is documented that existing adjacent structures or natural objects block direct sunlight for more than 1,500 daytime hours per year between 8a.m. and 4p.m.~~

~~**EXCEPTION 2 to Section 130.1(d)1:** Areas adjacent to vertical glazing below an overhang, where there is no vertical glazing above the overhang and where the ratio of the overhang projection to the window head height is greater than 1.0.~~

- ~~B2. Luminaires in the Skylit Daylit Zone shall be controlled separately from those in the Primary Sidelit Daylit Zones. The automatic daylighting controls shall provide separate control for luminaires in each type of daylight zone. C. Luminaires that fall in both a S_{skylit} and P_{primary} S_{sidelit} D_{daylit} Z_{zone} shall be controlled as part of the S_{skylit} Daylit Z_{zone}.~~

~~**EXCEPTION 1 to Section 130.1(d)2:** Rooms in which the combined total installed general lighting power in the Skylit Daylit Zone and Primary Sidelit Daylit Zone is less than 120 Watts, or parking garage areas where the total combined general lighting power in the primary sidelit daylight zones is less than 60 watts.~~

~~**EXCEPTION 2 to Section 130.1(d)2:** Rooms that have a total glazing area of less than 24 square feet, or parking garage areas with a combined total of less than 36 square feet of glazing or opening.~~

~~**EXCEPTION 3 to Section 130.1(d)2:** For parking garages, luminaires located in the daylight transition zone and luminaires for only dedicated ramps. Daylight transition zone and dedicated ramps are defined in Section 100.1.~~

- ~~D3. **Automatic Daylighting Control Installation and Operation.** For luminaires in daylight zones, The automatic daylighting controls shall be installed and configured to operate according to all of the following requirements:~~

- ~~i. Photosensors shall be located so that they are not readily accessible to unauthorized personnel. The location where calibration adjustments are made to automatic daylighting controls shall be readily accessible to authorized personnel and may be inside a locked case or under a cover which requires a tool for access.~~

~~iiA. For spaces required to install multilevel controls under Section 130.1(c), adjust lighting via continuous dimming or Automatic daylighting controls shall provide functional multilevel lighting having at least the number of control steps specified in TABLE 130.1. A provided by the multilevel controls;:-~~

~~EXCEPTION 1 to Section 130.1(d)2Dii: Controlled lighting having a lighting power density less than 0.3 W/ft² is not required to provide multilevel lighting controls.~~

~~iiiB. For each space, ensure the combined illuminance from the controlled lighting and daylight shall be not less than the illuminance from controlled lighting when no daylight is available.~~

~~ivC. In areas served by lighting that is daylight controlled—For areas other than parking garages, ensure that when the daylight illuminance is greater than 150 percent of the design illuminance received from the general lighting system at full power, the general lighting power in that daylight zone shall be reduced by a minimum of 65 percent; and~~

~~D. For parking garages, ensure that when illuminance levels measured at the farthest edge of the secondary sidelit zone away from the glazing of opening are greater than 150 percent of the illuminance provided by the controlled lighting when no daylight is available, the controlled lighting power consumption is zero.~~

~~4. When photosensors are located within the daylit zone, at least one photosensor shall be located so that they are not readily accessible to unauthorized personnel.~~

~~5. The location where calibration adjustments are made to the automatic daylighting controls shall be readily accessible to authorized personnel but may be inside a locked case or under a cover which requires a tool for access.~~

~~EXCEPTION 1 to Section 130.1(d)2: Rooms in which the combined total installed general lighting power in the Skylit Daylit Zone and Primary Sidelit Daylit Zone is less than 120 Watts.~~

~~EXCEPTION 2 to Section 130.1(d)2: Rooms that have a total glazing area of less than 24 square feet.~~

~~EXCEPTION 3 to Section 130.1(d)2: Parking garages complying with Section 130.1(d)3.~~

~~3. **Parking Garage Daylighting Requirements.** In a parking garage area with a combined total of 36 square feet or more of glazing or opening, luminaires providing general lighting that are in the combined primary and secondary sidelit daylit zones shall be controlled independently from other lighting in the parking garage by automatic daylighting controls, and shall meet the following requirements as applicable:~~

~~A. All primary and secondary sidelit daylit zones shall be shown on the plans.~~

~~B. Automatic Daylighting Control Installation and Operation. Automatic daylighting control shall be installed and configured to operate according to all of the following requirements:~~

~~i. Automatic daylighting controls shall have photosensors that are located so that they are not readily accessible to unauthorized personnel. The location where calibration adjustments are made to the automatic daylighting controls shall be readily accessible to authorized personnel but may be inside a locked case or under a cover which requires a tool for access.~~

~~ii. Automatic daylighting controls shall be multilevel, continuous dimming or ON/OFF.~~

~~iii. The combined illuminance from the controlled lighting and daylight shall not be less than the illuminance from controlled lighting when no daylight is available.~~

~~iv. When illuminance levels measured at the farthest edge of the secondary sidelit zone away from the glazing of opening are greater than 150 percent of the illuminance provided by the controlled lighting when no daylight is available, the controlled lighting power consumption shall be zero.~~

~~EXCEPTION 1 to Section 130.1(d)3: Luminaires located in the daylight transition zone and luminaires for only dedicated ramps. Daylight transition zone and dedicated ramps are defined in Section 100.1.~~

~~EXCEPTION 2 to Section 130.1(d)3: The total combined general lighting power in the primary sidelit daylight zones is less than 60 watts.~~

(e) **Demand Responsive Controls.** See Section 110.12 for requirements for demand responsive lighting controls.

~~1. foot or less, shall be capable of automatically reducing lighting power in response to a Demand Response Signal; so that the total lighting power of non-excluded spaces can be lowered by a minimum of 15 percent below the total installed lighting power when a Demand Response Signal is received. Lighting shall be reduced in a manner consistent with uniform level of illumination requirements in TABLE 130.1-A.~~

~~EXCEPTION to Section 130.1(c): Lighting not permitted by a health or life safety statute, ordinance, or regulation to be reduced shall not be counted toward the total lighting power.~~

~~2. Demand responsive controls and equipment shall be capable of receiving and automatically responding to at least one standards based messaging protocol by enabling demand response after receiving a demand response signal.~~

(f) Control Interactions. Each lighting control installed to comply with Section 130.1 shall permit or incorporate the functions of the other lighting controls required by this Section.

1. For general lighting, the manual area control shall permit the level or amount of light provided while the lighting is on to be set or adjusted by the controls specified in Section 130.1(b), (c), (d), and (e).

2. The manual area control shall permit the automatic shutoff control to turn the lighting off.

3. The multilevel control shall permit the automatic daylighting control to adjust the electric lighting level as the amount of daylighting increases or decreases, so that the total amount of light remains stable.

4. The multilevel control shall permit the demand responsive control to increase or decrease the lighting during a demand response event and to return it to the level set by the multilevel control after the event.

5. The automatic shutoff control shall permit the manual area control to turn the lighting on. If the on request occurs while an automatic time switch control would turn the lighting off, then the on request shall be treated as an override request consistent with Section 130.1(c)1F.

6. The automatic daylighting control shall permit the multilevel control to adjust the level of lighting up and down, and shall maintain the total amount of lighting at the adjusted level as incoming daylight changes.

TABLE 130.1-A MULTI-LEVEL LIGHTING CONTROLS AND UNIFORMITY REQUIREMENTS

Luminaire Type	Minimum Required Control Steps (percent of full rated power ¹)				Uniform level of illuminance shall be achieved by:
Line-voltage sockets except GU-24	Continuous dimming 10-100 percent				
Low-voltage incandescent systems					
LED luminaires and LED source systems					
GU-24 rated for LED					
GU-24 sockets rated for fluorescent > 20 watts	Continuous dimming 20-100 percent				
Pin-based compact fluorescent > 20 watts ²					
GU-24 sockets rated for fluorescent ≤ 20 watts	Minimum one step between 30-70 percent				Stepped dimming; or Continuous dimming; or Switching alternate lamps in a luminaire
Pin-based compact fluorescent ≤ 20 watts ²					
Linear fluorescent and U-bent fluorescent ≤ 13 watts					
Linear fluorescent and U-bent fluorescent > 13 watts	Minimum one step in each range:				Stepped dimming; or Continuous dimming; or Switching alternate lamps in each luminaire, having a minimum of 4 lamps per luminaire illuminating the same area and in the same manner
	20-40 %	50-70 %	75-85 %	100 %	
Track Lighting	Minimum one step between 30 – 70 percent				Step dimming; or Continuous dimming; or Separately switching circuits in multi-circuit track with a minimum of two circuits.
HID > 20 watts	Minimum one step between 50 - 70 percent				Stepped dimming; or Continuous dimming; or Switching alternate lamps in each luminaire, having a minimum of 2 lamps per luminaire, illuminating the same area and in the same manner.
Induction > 25 watts					
Other light sources					
<p>1. Full rated input power of ballast and lamp, corresponding to maximum ballast factor</p> <p>2. Includes only pin based lamps: twin tube, multiple twin tube, and spiral lamps</p>					
<p>EXCEPTION 1 to Table 130.1-A: Classrooms with a connected general lighting load of 0.7 watts per square feet or less and public restrooms shall have a minimum one control step between 30-70 percent of full rated power, regardless of luminaire type.</p>					
<p>EXCEPTION 2 to Table 130.1-A: Library stack aisles, aisle ways and open areas in warehouses, parking garages, parking areas, loading and unloading areas, stairwells, and corridors shall have a minimum one control step between 20-60 percent of full rated power, regardless of luminaire type.</p>					

SECTION 130.2 – OUTDOOR LIGHTING CONTROLS AND EQUIPMENT

Nonresidential, high-rise residential and hotel/motel buildings shall comply with the applicable requirements of Sections 130.2(a) through 130.2(c).

- (a) ~~RESERVED Outdoor Incandescent Lighting. All outdoor incandescent luminaires rated over 100 watts, determined in accordance with Section 130.0(c)2, shall be controlled by a motion sensor.~~
- (b) **Luminaire Cutoff Requirements.** All outdoor luminaires rated ~~for use with lamps~~ greater than ~~30~~ **150 lamp** watts, determined in accordance with Section 130.0(c), shall comply with Backlight, Uplight, and Glare (collectively referred to as "BUG" in accordance with IES TM-15-11, Addendum A) requirements as follows:
1. ~~Maximum zonal lumens for Backlight, Uplight, and Glare shall be in accordance with Title 24, Part 11, Section 5.106.8. There are no Backlight requirements in Section 130.2 of Part 6; and~~
 2. ~~Maximum zonal lumens for Uplight shall be in accordance with TABLE 130.2 A; and~~
 3. ~~Maximum zonal lumens for Glare shall be in accordance with TABLE 130.2 B.~~

~~NOTE: Title 24, Part 11, Section 5.106.8 includes additional restrictions on backlight, uplight and glare that may apply.~~

EXCEPTION 1 to Section 130.2(b): Signs.

EXCEPTION 2 to Section 130.2(b): Lighting for building facades, public monuments, statues, and vertical surfaces of bridges.

EXCEPTION 3 to Section 130.2(b): Lighting not permitted by a health or life safety statute, ordinance, or regulation to be a cutoff luminaire.

EXCEPTION 4 to Section 130.2(b): Temporary outdoor lighting.

EXCEPTION 5 to Section 130.2(b): Replacement of existing pole mounted luminaires in hardscape areas meeting all of the following conditions:

- A. Where the existing luminaire does not meet the luminaire BUG requirements in Section 130.2(b); and
- B. Spacing between existing poles is greater than six times the mounting height of the existing luminaires; and
- C. Where no additional poles are being added to the site; and
- D. Where new wiring to the luminaires is not being installed; and
- E. Provided that the connected lighting power wattage is not increased.

EXCEPTION 6 to Section 130.2(b): Luminaires that illuminate the public right of way on publicly maintained roadways, sidewalks, and bikeways.

- (c) **Controls for Outdoor Lighting.** Outdoor lighting controls shall be installed that meet the following requirements ~~as applicable~~ **for reducing lighting when daylight is available and during normally scheduled unoccupied periods:**

— **EXCEPTION 1 to Section 130.2(c):** Outdoor lighting not permitted by a health or life safety statute, ordinance, or regulation to be turned OFF ~~or dimmed~~.

— **EXCEPTION 2 to Section 130.2(c):** Lighting in tunnels required to be illuminated 24 hours per day and 365 days per year.

1. **Daylight Availability.** All installed outdoor lighting shall be controlled by a photo control, ~~or outdoor~~ astronomical time-switch control, **automatic scheduling control**, or other control capable of automatically shutting OFF the outdoor lighting when daylight is available.
2. **Unoccupied Periods.** All installed outdoor lighting shall be controlled by a control capable of reducing the outdoor lighting by at least 50 percent, or turning the lighting OFF, during normally scheduled unoccupied periods. This control shall be either an automatic scheduling control or an occupant sensing control, and shall include the following features:

- A. For automatic scheduling controls, the control shall provide an override function that turns the lighting ON during its scheduled dim or OFF period for no more than 2 hours when an override is initiated.
- B. For occupant sensing controls, no more than 800 watts of lighting shall be controlled by any single sensor, and the control shall return the lighting to its dim or OFF state no later than 15 minutes after the area has been vacated.

All installed outdoor lighting shall be independently controlled from other electrical loads by an automatic scheduling control.

3. All installed outdoor lighting, where the bottom of the luminaire is mounted 24 feet or less above the ground, shall be controlled with automatic lighting controls that meet all of the following requirements:

- A. Shall be motion sensors or other lighting control systems that automatically controls lighting in accordance with Item B in response to the area being vacated of occupants; and
- B. Shall be capable of automatically reducing the lighting power of each luminaire by at least 40 percent but not exceeding 90 percent, or provide continuous dimming through a range that includes 40 percent through 90 percent, and
- C. Shall employ auto ON functionality when the area becomes occupied; and
- D. No more than 1,500 watts of lighting power shall be controlled together.

EXCEPTION 1 to Section 130.2(e)3: Lighting for Outdoor Sales Frontage complying with Section 130.2(e)4.

EXCEPTION 2 to Section 130.2(e)3: Lighting for Building Facades, Ornamental Hardscape and Outdoor Dining complying with Section 130.2(e)5.

EXCEPTION 3 to Section 130.2(e)3: Outdoor lighting, where luminaire rated wattage is determined in accordance with Section 130.0(c), and which meet one of the following conditions:

- A. Pole mounted luminaires each with a maximum rated wattage of 75 watts; or
- B. Non-pole mounted luminaires with a maximum rated wattage of 30 watts each; or
- C. Linear lighting with a maximum wattage of 4 watts per linear foot of luminaire.

EXCEPTION 4 to Section 130.2(e)3: Applications listed as Exceptions to Section 140.7(a) shall not be required to meet the requirements of Section 130.2(e)3.

4. For Outdoor Sales Frontage lighting, an automatic lighting control shall be installed that meets the following requirements:

- A. A part night outdoor lighting control as defined in Section 100.1; or
- B. Motion sensors capable of automatically reducing lighting power by at least 40 percent but not exceeding 90 percent, and which have auto ON functionality.

5. For Building Facade, Ornamental Hardscape and Outdoor Dining lighting, an automatic lighting control shall be installed that meets one or more of the following requirements:

- A. A part night outdoor lighting control as defined in Section 100.1; or
- B. Motion sensors capable of automatically reducing lighting power by at least 40 percent but not exceeding 90 percent, and which have auto ON functionality; or
- C. A centralized time based zone lighting control capable of automatically reducing lighting power by at least 50 percent.
- D. Outdoor wall mounted luminaires having a bilaterally symmetric distribution as described in the IES Handbook (typically referred to as "wall packs") where the bottom of the luminaire is mounted 24 feet or less above the ground shall comply with the applicable requirements in Section 130.2(e)3.

TABLE 130.2 A—Uplight Ratings (Maximum Zonal Lumens)

Secondary Solid Angle	Maximum Zonal Lumens per Outdoor Lighting Zone				
	LZ0	LZ1	LZ2	LZ3	LZ4
Uplight High (UH) 100 to 180 degrees	0	10	50	500	1,000
Uplight Low (UL) 90 to <100 degrees	0	10	50	500	1,000

TABLE 130.2 B—Glare Ratings (Maximum Zonal Lumens)

Glare Rating for Asymmetrical Luminaire Types (Type I, Type II, Type III, Type IV)					
Secondary Solid Angle	Maximum Zonal Lumens per Outdoor Lighting Zone				
	LZ0	LZ1	LZ2	LZ3	LZ4
Forward Very High (FVH) 80 to 90 degrees	10	100	225	500	750
Backlight Very High (BVH) 80 to 90 degrees	10	100	225	500	750
Forward High (FH) 60 to <80 degrees	660	1,800	5,000	7,500	12,000
Backlight High (BH) 60 to <80 degrees	110	500	1,000	2,500	5,000
Glare Rating for Quadrilateral Symmetrical Luminaire Types (Type V, Type V Square)					
Secondary Solid Angle	Maximum Zonal Lumens per Outdoor Lighting Zone				
	LZ0	LZ1	LZ2	LZ3	LZ4
Forward Very High (FVH) 80 to 90 degrees	10	100	225	500	750
Backlight Very High (BVH) 80 to 90 degrees	10	100	225	500	750
Forward High (FH) 60 to <80 degrees	660	1,800	5,000	7,500	12,000
Backlight High (BH) 60 to <80 degrees	660	1,800	5,000	7,500	12,000

SECTION 130.3 – SIGN LIGHTING CONTROLS

Nonresidential buildings other than healthcare facilities, high-rise residential buildings, and hotel/motel buildings shall comply with the applicable requirements of Section 130.3(a)1 through 130.3(a)3.

(a) **Controls for Sign Lighting.** All sign lighting shall meet the requirements below as applicable:

1. **Indoor Signs.** All indoor sign lighting shall be controlled with an automatic time-switch control or astronomical time-switch control.

EXCEPTION to Section 130.3(a)1: Exit signs.

2. **Outdoor Signs.** Outdoor sign lighting shall meet the following requirements as applicable:

- A. All outdoor sign lighting shall be controlled with a photocontrol in addition to an automatic time-switch control, or an astronomical time-switch control.

EXCEPTION to Section 130.3(a)2A: Outdoor signs in tunnels, and signs in large permanently covered outdoor areas that are intended to be continuously lit, 24 hours per day and 365 days per year.

- B. All outdoor sign lighting that is ON both day and night shall be controlled with a dimmer that provides the ability to automatically reduce sign lighting power by a minimum of 65 percent during nighttime hours. Signs that are illuminated at night and for more than 1 hour during daylight hours shall be considered ON both day and night.

EXCEPTION to Section 130.3(a)2B: Outdoor signs in tunnels and large covered areas that are intended to be illuminated both day and night.

3. **Demand Responsive Electronic Message Center (EMC) Control.** See Section 110.12 for requirements for demand responsive EMC controls. An Electronic Message Center (EMC) having a new connected lighting power load greater than 15 kW shall have a control installed that is capable of reducing the lighting power by a minimum of 30 percent when receiving a demand response signal.

~~**EXCEPTION to Section 130.3(a)3:** Lighting for EMCs that is not permitted by a health or life safety statute, ordinance, or regulation to be reduced by 30 percent.~~

SECTION 130.4 –LIGHTING CONTROL ACCEPTANCE AND INSTALLATION CERTIFICATE REQUIREMENTS

Nonresidential buildings other than healthcare facilities, high-rise residential buildings, and hotel/motel buildings shall comply with the applicable requirements of Sections 130.4(a) through 130.4(c). Healthcare facilities shall comply with the applicable acceptance and installation documentation requirements of OSHPD.

- (a) **Lighting Control Acceptance Requirements.** Before an occupancy permit is granted, indoor and outdoor lighting controls serving the building, area, or site shall be certified as meeting the Acceptance Requirements for Code Compliance in accordance with Section 130.4(a). A Certificate of Acceptance shall be submitted to the enforcement agency under Section 10-103(a) of Part 1, that:
1. Certifies that all of the lighting acceptance testing necessary to meet the requirements of Part 6 is completed;
 2. Certifies that the applicable procedures in Reference Nonresidential Appendix NA7.6 and NA7.8 have been followed;
 3. Certifies that automatic daylight controls comply with Section 130.1(d) and Reference Nonresidential Appendix NA7.6.1;
 4. Certifies that lighting shut-OFF controls comply with Section 130.1(c) and Reference Nonresidential Appendix NA7.6.2;
 5. Certifies that demand responsive controls comply with Section 130.1(e) and Reference Nonresidential Appendix NA7.6.3; and
 6. Certifies that outdoor lighting controls comply with the applicable requirements of Section 130.2(c) and Reference Nonresidential Appendix NA7.8; and
 7. Certifies that lighting systems receiving the Institutional Tuning Power Adjustment Factor comply with Section 140.6(a)2J and Reference Nonresidential Appendix NA7.7.6.2.
- (b) **Lighting Control Installation Certificate Requirements.** To be recognized for compliance with Part 6 an Installation Certificate shall be submitted in accordance with Section 10-103(a) for any lighting control system, Energy Management Control System, track lighting integral current limiter, track lighting supplementary overcurrent protection panel, interlocked lighting system, lighting Power Adjustment Factor, or additional wattage available for a videoconference studio, in accordance with the following requirements, as applicable:
1. Certification that when a lighting control system is installed to comply with lighting control requirements in Part 6 it complies with the applicable requirements of Section 110.9; and complies with Reference Nonresidential Appendix NA7.7.1.
 2. Certification that when an Energy Management Control System is installed to function as a lighting control required by Part 6 it functionally meets all applicable requirements for each application for which it is installed, in accordance with Sections 110.9, 130.0 through 130.5, 140.6 through 150.0, and 150.2; and complies with Reference Nonresidential Appendix NA7.7.2.
 - ~~3. Certification that line voltage track lighting integral current limiters comply with the applicable requirements of Section 110.9 and installed wattage has been determined in accordance with Section 130.0(e); and comply with Reference Nonresidential Appendix NA7.7.3.~~
 - ~~4. Certification that line voltage track lighting supplementary overcurrent protection panels comply with the applicable requirements of Section 110.9 and installed wattage has been determined in accordance with Section 130.0(e); and comply with Reference Nonresidential Appendix NA7.7.4.~~
 - ~~5.~~ Certification that interlocked lighting systems used to serve an approved area comply with Section 140.6(a)1; and comply with Reference Nonresidential Appendix NA7.7.5.
 - ~~6.~~ Certification that lighting controls installed to earn a lighting Power Adjustment Factor (PAF) comply with Section 140.6(a)2; and comply with Reference Nonresidential Appendix NA7.7.6.

75. Certification that additional lighting wattage installed for a videoconference studio complies with Section 140.6(c)2Gvii; and complies with Reference Nonresidential Appendix NA7.7.7.

- (c) When certification is required by Title 24, Part 1, Section 10-103.1, the acceptance testing specified by Section 130.4 shall be performed by a Certified Lighting Controls Acceptance Test Technician (CLCATT). If the CLCATT is operating as an employee, the CLCATT shall be employed by a Certified Lighting Controls Acceptance Test Employer. The CLCATT shall disclose on the Certificate of Acceptance a valid CLCATT certification identification number issued by an approved Acceptance Test Technician Certification Provider. The CLCATT shall complete all Certificate of Acceptance documentation in accordance with the applicable requirements in Section 10-103(a)4.

NOTE: Authority: Sections 25402, 25402.1, 25213, Public Resources Code. Reference: Sections 25007, 25402(a)-(b), 25402.1, 25402.4, 25402.5, 25402.8 and 25910, Public Resources Code.

SECTION 130.5 –ELECTRICAL POWER DISTRIBUTION SYSTEMS

Nonresidential, high-rise residential and hotel/motel buildings shall comply with the applicable requirements of Sections 130.5(a) through 130.5(e).

- (a) **Service Electrical Metering.** Each electrical service or feeder shall have a permanently installed metering system which measures electrical energy use in accordance with TABLE 130.5-A.

EXCEPTION 1 to Section 130.5(a): Service or feeder for which the utility company provides a metering system that indicates instantaneous kW demand and kWh for a utility-defined period.

EXCEPTION 2 to Section 130.5(a): Electrical power distribution systems subject to California Electrical Code Article 517.

- (b) **Separation of Electrical Circuits for Electrical Energy Monitoring.** Electrical power distribution systems shall be designed so that measurement devices can monitor the electrical energy usage of load types according to TABLE 130.5-B.

EXCEPTION 1 to Section 130.5(b): For each separate load type, up to 10 percent of the connected load may be of any type.

EXCEPTION 2 to Section 130.5(b): Electrical power distribution systems subject to California Electrical Code Article 517.

- (c) **Voltage Drop.** The maximum combined voltage drop on both installed feeder conductors and branch circuit conductors to the farthest connected load or outlet shall not exceed 5 percent.

EXCEPTION to Section 130.5(c): Voltage drop permitted by California Electrical Code Sections 647.4, 695.6 and 695.7.

- (d) **Circuit Controls for 120-Volt Receptacles and Controlled Receptacles.** In all buildings, both controlled and uncontrolled 120 volt receptacles shall be provided in office areas, lobbies, conference rooms, kitchen areas in office spaces, and copy rooms. Additionally, hotel/motel guest rooms shall comply with Section 130.5(d)4. Controlled receptacles shall meet the following requirements, as applicable:

1. Install a control capable of automatically shutting OFF the controlled receptacles when the space is typically unoccupied, either at the receptacle or circuit level. When an automatic time switch control is installed it shall incorporate an override control that allows the controlled receptacle to remain ON for no more than 2 hours when an override is initiated and an automatic holiday “shut-OFF” feature that turns OFF all loads for at least 24 hours and then resumes the normally scheduled operation. Countdown timer switches shall not be used to comply with the automatic time switch control requirements; and
2. Install at least one controlled receptacle within 6 feet from each uncontrolled receptacle, or install a splitwired receptacle with at least one controlled and one uncontrolled receptacle. Where receptacles are installed in modular furniture in open office areas, at least one controlled receptacle shall be installed at each workstation; and
3. Provide a permanent and durable marking for controlled receptacles or circuits to differentiate them from uncontrolled receptacles or circuits; and
4. For hotel and motel guest rooms, install controlled receptacles for at least one-half of the 120-volt receptacles in each guestroom. Electric circuits serving controlled receptacles in guestrooms shall have captive card key controls, occupancy sensing controls, or automatic controls so the power is switched off no longer than 30 minutes after the guestroom has been vacated.

NOTE: A hardwired power strip controlled by an occupant sensing control may be used to comply with Section 130.5(d). Plug-in strips and other plug-in devices shall not be used to comply with the requirements of this Section.

EXCEPTION 1 to Section 130.5(d): Receptacles that are only for the following purposes:

- i. Receptacles specifically for refrigerators and water dispensers in kitchen areas.
- ii. Receptacles located a minimum of six feet above the floor that are specifically for clocks.

- iii. Receptacles for network copiers, fax machines, A/V and data equipment other than personal computers in copy rooms.
- iv. Receptacles on circuits rated more than 20 amperes.
- v. Receptacles connected to an uninterruptible power supply (UPS) that are intended to be in continuous use, 24 hours per day/365 days per year, and are marked to differentiate them from other uncontrolled receptacles or circuits.

EXCEPTION 2 to Section 130.5(d): Receptacles in healthcare facilities.

- (e) **Demand responsive controls and equipment.** [See Section 110.12 for requirements for demand responsive controls and equipment.](#) ~~Demand responsive controls and equipment, where installed, shall be capable of receiving and automatically responding to at least one standards-based messaging protocol which enables demand response after receiving a demand response signal.~~

NOTE: Definitions of terms and phrases in Section 130.5 are determined as specified in Section 100.1(b). Terms and phrases not found in Section 100.1(b) shall be defined as specified in Title 24, Part 3, Article 100 of the California Electrical Code.

TABLE 130.5-A MINIMUM REQUIREMENTS FOR METERING OF ELECTRICAL LOAD

Metering Functionality	Electrical Services rated 50 kVA or less	Electrical Services rated more than 50kVA and less than or equal to 250 kVA	Electrical Services rated more than 250 kVA and less than or equal to 1000kVA	Electrical Services rated more than 1000kVA
Instantaneous (at the time) kW demand	Required	Required	Required	Required
Historical peak demand (kW)	Not required	Not required	Required	Required
Tracking kWh for a user-definable period.	Required	Required	Required	Required
kWh per rate period	Not required	Not required	Not required	Required

TABLE 130.5-B MINIMUM REQUIREMENTS FOR SEPARATION OF ELECTRICAL LOAD

Electrical Load Type	Electrical Services rated 50 kVA or less	Electrical Services rated more than 50kVA and less than or equal to 250 kVA	Electrical Services rated more than 250 kVA and less than or equal to 1000kVA	Electrical Services rated more than 1000kVA
Lighting including exit and egress lighting and exterior lighting	Not required	All lighting in aggregate	All lighting disaggregated by floor, type or area	All lighting disaggregated by floor, type or area
HVAC systems and components including chillers, fans, heaters, furnaces, package units, cooling towers, and circulation pumps associated with HVAC	Not required	All HVAC in aggregate	All HVAC in aggregate and each HVAC load rated at least 50 kVA	All HVAC in aggregate and each HVAC load rated at least 50kVA
Domestic and service water system pumps and related systems and components	Not required	All loads in aggregate	All loads in aggregate	All loads in aggregate
Plug load including appliances rated less than 25 kVA	Not required	All plug load in aggregate Groups of plug loads exceeding 25 kVA connected load in an area less than 5000 sf	All plug load separated by floor, type or area Groups of plug loads exceeding 25 kVA connected load in an area less than 5000 sf	All plug load separated by floor, type or area All groups of plug loads exceeding 25 kVA connected load in an area less than 5000 sf
Elevators, escalators, moving walks, and transit systems	Not required	All loads in aggregate	All loads in aggregate	All loads in aggregate
Other individual non-HVAC loads or appliances rated 25kVA or greater	Not required	All loads in aggregate	All loads in aggregate	All loads in aggregate
Industrial and commercial load centers 25 kVA or greater including theatrical lighting installations and commercial kitchens	Not required	All loads in aggregate	All loads in aggregate	All loads in aggregate
Renewable power source (net or total)	Each group	Each group	Each group	Each group
Loads associated with renewable power source	Not required	All loads in aggregate	All loads in aggregate	All loads in aggregate
Charging stations for electric vehicles	All loads in aggregate	All loads in aggregate	All loads in aggregate	All loads in aggregate