

DOCKETED

Docket Number:	98-AFC-03C
Project Title:	Delta Energy Center Compliance
TN #:	222506
Document Title:	Delta Energy Center's Notification of Completion of Repairs and Availability to Restart in Combined Cycle Mode.
Description:	On January 1, 2018, all repairs were completed and the plant was declared available for full dispatch as a 3x1 combined cycle facility.
Filer:	Anwar Ali
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	2/9/2018 10:52:06 AM
Docketed Date:	2/9/2018



DELTA ENERGY CENTER, LLC
717 Texas Avenue, Suite 1000
Houston, TX 77002

February 8, 2018

Ali Anwar
Compliance Project Manager
California Energy Commission
1516 Ninth Street, MS-2000
Sacramento, CA 95814

Re. Delta Energy Center (98-AFC-03C) – Completion of Repairs Authorized by Order
Approving Petition to Amend (Order No: 17-0308-3)

Dear Mr. Ali:

On March 8, 2017, the California Energy Commission approved Delta Energy Center's petition to amend to make temporary safety modifications to the steam turbine condenser, which would allow for operation of the facility in simple cycle mode while repairs were performed on the steam turbine. (TN #: 216644, Order Approving Petition to Amend (Order No: 17-0308-3).) The following summarizes the completion of the repairs authorized by Order No: 17-0308-3.

On June 26, 2017, the temporary safety modifications and repairs were completed and the facility became available in 3x0 bypass operation mode to provide service to the grid, at the urging of the CAISO. The facility then operated in such mode periodically during the summer and supported the local grid area.

On October 13, 2017, the facility's temporary operations in bypass mode ceased and the facility commenced a full plant outage to begin restoration to combined cycle operation.

On January 1, 2018, all repairs were completed, the outage ended and the plant was declared available for full dispatch as a 3x1 combined cycle facility, as described in the project owner's email notification to the Compliance Project Manager. Since that time, the facility has been, and continues to be, available and dispatched as a combined cycle facility.

Please let me know if you have any questions.

Sincerely,

A handwritten signature in black ink, appearing to read 'Barbara McBride', with a long horizontal line extending to the right.

Barbara McBride
Director Environmental Services
Calpine Corporation

cc: Shawn Pittard, California Energy Commission
Christine Root, California Energy Commission