

DOCKETED

Docket Number:	17-BSTD-02
Project Title:	2019 Title 24, Part 6, Building Energy Efficiency Standards Rulemaking
TN #:	223413
Document Title:	NLCAA Comments On Non-Residential Lighting Measures for 2019 Standards-2
Description:	N/A
Filer:	System
Organization:	NLCAA
Submitter Role:	Public
Submission Date:	5/10/2018 8:05:52 AM
Docketed Date:	5/10/2018

Comment Received From: NLCAA

Submitted On: 5/10/2018

Docket Number: 17-BSTD-02

On Non-Residential Lighting Measures for 2019 Standards-2

Additional submitted attachment is included below.



California Energy Commission
Docket No. 17-BTSD-02
1516 Ninth Street
Sacramento, CA 95814-5512

RE: Docket No. 17-BTSD-02 – Non-Residential Lighting Measures for 2019 Standards-2

Thank you to the commission staff for your efforts and the opportunity to provide comments on this docket. I apologies that they are coming in late, please consider adding a clarification in the 2019 BEES

Please provide a clarification for EXCEPTION 1 to Section 130.1(a)2

There have been many misinterpretations regarding this exception, and now it has changed again in the 2019 BEES. Can you please add clarity to the code verbiage?

2019

EXCEPTION 1 to Section 130.1(a)2: For psychiatric and secure areas in healthcare facilities, malls and atria, auditorium areas, retail merchandise sales areas, wholesale showroom areas, commercial and industrial storage areas, general commercial and industrial work areas, convention centers, and arenas, psychiatric and secure areas in healthcare facilities, and other areas where placement of a manual area control poses a health and safety hazard, the manual area control may instead be located so that a person using the control can see the lights or area controlled by that control, or visually signal **or display the current state of the controlled lighting.**

Please define what “current state” means; i.e. ON, OFF, Dimmed?

Does the light level of controlled lighting (i.e. dimmed to 50%) need to be displayed to show a reduced light level of the controlled lighting?

2016

ANNUNCIATED is a type of visual signaling device that indicates the on, off, or **other status of a load.**

Please define what “other status of a load” means; i.e. ON, OFF, Dimmed?

Thank you for any and all considerations,

Michael Scalzo
Executive Director
National Lighting Contractors Association of America; Lighting ATTCP