

DOCKETED

Docket Number:	93-AFC-03C
Project Title:	Compliance - Application for Certification for SMUD's Campbell Soup Cogeneration Project
TN #:	225919
Document Title:	Campbell Cogen Project - Petition to Amend - Letter from Sacramento Air Quality Management District
Description:	Campbell Cogen Project - Petition to Amend - Letter from Sacramento Metropolitan Air Quality Management District regarding Preliminary Approval of Authority to Construct
Filer:	Mary Dyas
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	11/19/2018 8:53:10 AM
Docketed Date:	11/19/2018

November 15, 2018

Ms. Mary Dyas
Compliance Project Manager
Siting, Transmission and Environmental Protection (STEP) Division
California Energy Commission
1516 Ninth Street, MS-2000
Sacramento, CA 95814

Dear Ms. Dyas:

The Sacramento Metropolitan Air Quality Management District is giving notice of a preliminary decision to approve Authority to Construct application A/C 25725 for the modification of a turbine located at 3125 47th Ave., Sacramento, CA 95824. The modifications are to revise the carbon monoxide emission rate during startup and to install a wet compression upgrade that will allow an increase in power production under high ambient temperature conditions. The application is being processed under the District's enhanced new source review and the permit will be incorporated into the facility's Title V permit as an administrative amendment.

Please direct your written comments to: SMAQMD, 777 12th Street, 3rd Floor, Sacramento, CA 95814, Attention: Venk Reddy. You can also submit your comments via e-mail to VReddy@airquality.org. Comments must be received by December 17, 2018.

The SMAQMD notice is posted on the district's website and can be found on the following link:

<http://www.airquality.org/About-Us/News-Notices/News-Notices-Details?UniqueID={24DDBDF7-7F45-4B28-B6D6-CB61A958171A}>

The draft Authority to construct can be found on the following link:


<http://www.airquality.org/StationarySources/Documents/AC25725%20final%2011-14-18.pdf>

The Engineering Evaluation can be found on the following link:

<http://www.airquality.org/StationarySources/Documents/ev25725%20final%2011-14-18.pdf>

If you have any questions, you may contact me at (916) 874-4861.

Sincerely,



Venk Reddy