

DOCKETED

Docket Number:	93-AFC-03C
Project Title:	Compliance - Application for Certification for SMUD's Campbell Soup Cogeneration Project
TN #:	226203
Document Title:	SPA Campbell Cogen Staff Assessment Comments
Description:	N/A
Filer:	Jerry Salamy
Organization:	Jacobs
Submitter Role:	Applicant Consultant
Submission Date:	1/3/2019 8:56:57 AM
Docketed Date:	1/3/2019

S A C R A M E N T O
POWER AUTHORITY

P.O. Box 15830 • Sacramento, CA • 95852-1830 • SPA Cogeneration Project

SPA-19-001

January 2, 2019

Mary Dyas
Compliance Project Manager
California Energy Commission
Siting, Transmission, & Environmental Protection Division
1516 9th Street, MS-2000
Sacramento, CA 95814

Subject: Sacramento Power Authority's Comments on the Campbell Cogeneration Project (93-AFC-3C) Staff Assessment

Dear Ms. Dyas:

The Sacramento Power Authority (SPA) appreciates the opportunity to provides the following comments on the Campbell Cogeneration Project (CCP) Staff Assessment issued on December 14, 2018 (Transaction Number TN-226122). The comments are provided in a chronologic order with section heading and page numbers to assist your review.

Executive Summary, Page 1, Introduction, 1st Full Paragraph, 2nd to last sentence – Please delete the word “two” from this sentence as the CCP turbine has 2 combustion chambers, each with 6 burners. This change should also be made in the following sections – Description of Proposed Modifications (page 2), Land Use (page 5), and Air Quality Introduction (page 15).

If you require any clarifications or additional information, please let me know.

Sincerely,



Eric Poff
Manager, Thermal Generation, Power Generation

cc: E. McCormick/EthosEnergy
René Toledo/SMUD
Jeff Adkins/Trinity