DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	229126
Document Title:	Quarterly Operation Report Second Quarter 2019 Part 2
Description:	Quarterly Operation Report-Second Quarter 2019- Part 2
Filer:	Anwar Ali
Organization:	City of Roseville
Submitter Role:	Public Agency
Submission Date:	7/29/2019 2:58:07 PM
Docketed Date:	7/29/2019

ATTACHMENT 9

AQ-40

AQ-40 The Project owner shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F.

Verification: The Project owner shall include all CEMS quality assurance test failures that required corrective action as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Cylinder Gas Audit

Facility:	ROSEVILLE ENERGY			Instrument Name:	CT2_CODualRg_P_Instrume
Unit/Stack:	CT2	Test Date:	06/24/2019	Performance Spec:	15 Pct
Parameter/Scale:	CO / High	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
06/24/2019	09:01	L	200	50.000	49.900	25.0 %
06/24/2019	09:06	M	200	109.700	113.300	54.9 %
06/24/2019	09:18	L	200	50.000	50.100	25.0 %
06/24/2019	09:23	M	200	109.700	113.500	54.9 %
06/24/2019	09:35	L	200	50.000	49.900	25.0 %
06/24/2019	09:40	M	200	109.700	113.200	54.9 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.000	49.967	Std	**0.1**
M	109.700	113.333	Std	**3.3**

Cylinder Gas Audit

Facility:	ROSEVILLE ENERGY			Instrument Name:	CT2_CODualRg_P_Instrume
Unit/Stack:	CT2	Test Date:	06/24/2019	Performance Spec:	15 Pct
Parameter/Scale:	CO / Low	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
06/24/2019	09:58	L	10	2.400	2.300	24.0 %
06/24/2019	10:04	M	10	5.400	5.700	54.0 %
06/24/2019	10:10	L	10	2.400	2.200	24.0 %
06/24/2019	10:16	M	10	5.400	5.600	54.0 %
06/24/2019	10:23	L	10	2.400	2.200	24.0 %
06/24/2019	10:28	M	10	5.400	5.600	54.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.400		2.233	Std	**6.9**
M	5.400		5.633	Std	**4.3**

Cylinder Gas Audit

Facility:	ROSEVILLE ENERGY			Instrument Name:	CT1_CODualRg_P_Instrume
Unit/Stack:	CT1	Test Date:	06/24/2019	Performance Spec:	15 Pct
Parameter/Scale:	CO / High	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
06/24/2019	11:59	L	200	50.300	49.400	25.2 %
06/24/2019	12:04	M	200	107.500	108.900	53.8 %
06/24/2019	12:16	L	200	50.300	49.400	25.2 %
06/24/2019	12:21	M	200	107.500	108.800	53.8 %
06/24/2019	12:33	L	200	50.300	49.600	25.2 %
06/24/2019	12:38	M	200	107.500	108.800	53.8 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.300	49.467	Std	**1.7**
M	107.500	108.833	Std	**1.2**

Cylinder Gas Audit

Facility:	ROSEVILLE ENERGY			Instrument Name:	CT1_CODualRg_P_Instrume
Unit/Stack:	CT1	Test Date:	06/24/2019	Performance Spec:	15 Pct
Parameter/Scale:	CO / Low	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
06/24/2019	12:54	L	10	2.500	2.300	25.0 %
06/24/2019	13:00	M	10	5.400	5.600	54.0 %
06/24/2019	13:07	L	10	2.500	2.200	25.0 %
06/24/2019	13:12	M	10	5.400	5.600	54.0 %
06/24/2019	13:19	L	10	2.500	2.200	25.0 %
06/24/2019	13:24	M	10	5.400	5.600	54.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.500	2.233	Std	**10.7**
M	5.400	5.600	Std	**3.7**

Roseville Energy Park
Revision History

RegPerfect® by Teledyne Monitor Labs, Inc.
Teledyne Monitor Labs, Inc.
35 Inverness Drive East
Englewood, CO 80112-5189
Telephone: (800) 846-6062
http://www.teledyne-ml.com/
http://www.regperfect.com/
©1998-2005 Teledyne Monitor Labs, Inc. All rights reserved.
RegPerfect® is a registered trademark of Teledyne Monitor Labs, Inc.

NOTE: This server's C drive is only 20 GB in size!! Do not place large files on this drive.

6/24/19 Taylor Sullivan
EDR check

4/22/19 Taylor Sullivan
Q1 EDRs

4/19/19 Taylor Sullivan
Started recalculation for March GCVs

ATTACHMENT 10

AQ-41

AQ-41 The Project owner shall submit a written report to the APCO and the CPM for each calendar quarter, within 30 days of the end of the quarter, including: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting shall correspond to the averaging period for each respective emission standard; applicable time and date of each period during which the CEMS was inoperative (except for zero and span checks) and the nature of the system repairs and adjustments; and a negative declaration when no excess emission occurred.

Verification: The Project owner shall include the excess emission report as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Excess Emission Report

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/14/2019 00:16 **Location:** Roseville, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 7.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 84.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**7.00 Day(s)**
Total Duration (Online only):	**Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/14/2019 00:16 **Location:** Roseville, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 7.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 84.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	7.00 Day(s)
Total Duration (Online only):	Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/14/2019 00:16 **Location:** Roseville, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 7.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 84.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**7.00 Day(s)**
Total Duration (Online only):	**Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/14/2019 00:14 **Location:** Roseville, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 7.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 84.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	7.00 Day(s)
Total Duration (Online only):	Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/14/2019 00:15 **Location:** Roseville, CA

Tag Name: ALL_NOx_Lb_1D
Total Operating Time: 7.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 84.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	7.00 Day(s)
Total Duration (Online only):	Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:56 **Location:** Roseville, CA

Tag Name: CT1_NOx_Norm_LbPerHr_1H
Total Operating Time: 82.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,102.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**82.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:55 **Location:** Roseville, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 82.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,102.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**82.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx LbPerHr SUSD 1-Hour Block Excess Emissions

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:57 **Location:** Roseville, CA

Tag Name: CT1_NOx_SUSD_LbPerHr_1H
Total Operating Time: 82.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,102.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**82.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx Ppmvdc 1-Hour Block Excess Emissions

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:56 **Location:** Roseville, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 82.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,102.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	82.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

SO2 LbPerHr 1-Hour Block Excess Emissions

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:59 **Location:** Roseville, CA

Tag Name: CT1_SO2_Norm_LbPerHr_1H
Total Operating Time: 82.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,102.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**82.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

PM10 LbPerHr 1-Hour Block Excess Emissions

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:58 **Location:** Roseville, CA

Tag Name: CT1_PM10_Norm_LbPerHr_1H
Total Operating Time: 82.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,102.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	82.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 14:00 **Location:** Roseville, CA

Tag Name: CT1_VOC_Norm_LbPerHr_1H
Total Operating Time: 82.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,102.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**82.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO LbPerHr 3-Hour Rolling Excess Emissions

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:52 **Location:** Roseville, CA

Tag Name: CT1_CO_3Hr_LbPerHr_1H
Total Operating Time: 82.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,102.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	82.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:54 **Location:** Roseville, CA

Tag Name: CT1_CO_Ppmvdc_3H
Total Operating Time: 82.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,102.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**82.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO LbPerHr SUSD 1-Hour Block Excess Emissions

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:54 **Location:** Roseville, CA

Tag Name: CT1_CO_SUSD_LbPerHr_1H
Total Operating Time: 82.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,102.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**82.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx Ppmvdc 1-Hour Block Excess Emissions

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/11/2019 10:15 **Location:** Roseville, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 125.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,059.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**125.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx LbPerHr 1-Hour Block Excess Emissions

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 14:06 **Location:** Roseville, CA

Tag Name: CT2_NOx_Norm_LbPerHr_1H
Total Operating Time: 125.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,059.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**125.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx LbPerHr SUSD 1-Hour Block Excess Emissions

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/11/2019 10:16 **Location:** Roseville, CA

Tag Name: CT2_NOx_SUSD_LbPerHr_1H
Total Operating Time: 125.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,059.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	125.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

SO2 LbPerHr 1-Hour Block Excess Emissions

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/11/2019 10:17 **Location:** Roseville, CA

Tag Name: CT2_SO2_Norm_LbPerHr_1H
Total Operating Time: 125.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,059.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	125.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/11/2019 10:16 **Location:** Roseville, CA

Tag Name: CT2_PM10_Norm_LbPerHr_1H
Total Operating Time: 125.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,059.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	125.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/11/2019 10:18 **Location:** Roseville, CA

Tag Name: CT2_VOC_Norm_LbPerHr_1H
Total Operating Time: 125.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,059.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	125.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr 3-Hour Rolling Excess Emissions

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 14:00 **Location:** Roseville, CA

Tag Name: CT2_CO_3Hr_LbPerHr_1H
Total Operating Time: 125.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,059.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	125.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSD 1-Hour Block Excess Emissions

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 14:02 **Location:** Roseville, CA

Tag Name: CT2_CO_SUSD_LbPerHr_1H
Total Operating Time: 125.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,059.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**125.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO Ppmvdc 3-Hour Block Excess Emissions

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 14:01 **Location:** Roseville, CA

Tag Name: CT2_CO_Ppmvdc_3H
Total Operating Time: 125.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,059.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	125.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 14:06 **Location:** Roseville, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 125.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,059.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	125.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

ATTACHMENT 11

Roseville Energy Park Quarterly Emissions Summary

for PCAPCD

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/14/2019 00:17 **Location:** Roseville, CA

* = Excess Emission

Date	Unit CT1 CO, Ton 1 Day(s) Sum	Unit CT1 CO, Ton 1 Day(s) Rolling Sum	Unit CT1 NOx, Ton 1 Day(s) Sum	Unit CT1 NOx, Ton 1 Day(s) Rolling Sum	Unit CT1 OperatingTime, Hrs 1 Day(s) Sum	Unit CT1 OperatingTime, Hrs 1 Day(s) Rolling Sum	Unit CT2 CO, Ton 1 Day(s) Sum	Unit CT2 CO, Ton 1 Day(s) Rolling Sum	Unit CT2 NOx, Ton 1 Day(s) Sum	Unit CT2 NOx, Ton 1 Day(s) Rolling Sum	Unit CT2 OperatingTime, Hrs 1 Day(s) Sum	Unit CT2 OperatingTime, Hrs 1 Day(s) Rolling Sum
Apr 2019	0.0000	1.9774	0.0000	5.0933	0.00	3,635.23	0.0000	2.1904	0.0000	5.3960	0.00	3,720.17
May 2019	0.0482	1.8540	0.0835	5.0594	61.95	3,636.38	0.0525	2.0497	0.0903	5.3968	61.59	3,733.02
Jun 2019	0.0248	1.8526	0.0287	5.0589	16.32	3,639.33	0.0798	2.0714	0.0951	5.4284	95.95	3,759.12
Sum/Avg	1.8526		5.0589		3,639.33		2.0714		5.4284		3,759.12	
Limit Value												

12 Month Running Summary Report

AQ42 12 Month Running Summary Report

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/14/2019 00:21 **Location:** Roseville, CA

Date	Units CT1 & CT2 NOx, Ton 1 Day(s) Sum	Running Sum	Units CT1 & CT2 VOC, Ton 1 Day(s) Sum	Running Sum
Apr 19	0.0000	0.0000	0.0000	0.0000
May 19	0.1739	0.1739	0.0501	0.0501
Jun 19	0.1237	0.2976	0.0328	0.0829
Sum/Avg	0.2976		0.0829	

ATTACHMENT 12

AQ-47

AQ-47 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-47of Roseville Energy Park's 2Q19 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

ATTACHMENT 13

AQ-48

AQ-48 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-48 of Roseville Energy Park's 2Q19 QAQR, there were no violations of PCAPCD's Rule 202 for opacity.

ATTACHMENT 14

AQ-51

AQ-51 The ammonia slip shall not exceed 10 ppmv @ 15% o2 averaged over one hour. The SCR catalyst shall be replaced, repaired or otherwise reconditioned within 24 months of the ammonia slip reaching 7 ppm @ 15% O2 averaged over 24 hours. The SCR ammonia injection grid replacement, repair or reconditioning scheduled event may be cancelled if the Project owner can demonstrate to the CPM that, subsequent to the initial exceedance, the ammonia slip consistently remains below 7 ppm @ 15% O2 averaged over 24 hours and that the initial exceedance does not accurately indicate expected future operating conditions.

Compliance with ammonia slip limits shall be demonstrated by using the following calculation procedure:

Ammonia slip ppmv @ 15% O2 = ((a-(bxc/1,000,000)) x 1,000,000/b) x d,

Where

a = ammonia injection rate (lb/hr)/17(lb/lb mol)

b = dry exhaust gas flow rate (lb/hr)/ (29(lb/lb mol)

c = change in measured NOX conc. Ppmv @ 15% O2 across catalyst, and

d = correction factor

The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip.

Verification: The Project owner shall include the ammonia slip concentrations averaged on an hourly and 24 hour basis calculated via the protocol provided as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6. The Project owner shall notify the CPM within 10 days of an exceedance of the 7 ppm ammonia slip limit herein. The Project owner shall notify the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event. If the Project owner finds that the exceedance of the 7 ppm slip limit does not accurately reflect the expected future operations provided for in this condition, the Project owner shall submit all relevant information to the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event in order to cancel the event.

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmvdC 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/01/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmWdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/02/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Sx	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmwdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/03/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _BCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, Liberror 1 Hour(s)	Unit CT1 ExhaustFlow, Liberror 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/04/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _8CR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/05/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%DI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmWdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/06/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Y:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/07/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmwdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 BUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/08/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmAvc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUMD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/09/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmvDc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/10/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/11/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/12/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmwdC 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/13/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmWdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/14/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/11/2019 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmvdC 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 GUSO, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/15/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, Lbsperhr 1 Hour(s)	Unit CT1 ExhaustFlow, Lbsperhr 1 Hour(s)	Unit CT1 SUM, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/16/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/17/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmWdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/18/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/19/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1 NH3Slip, PpmvDc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _3CR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/20/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmWdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/21/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%DI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmAvc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/22/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmvDc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/23/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/24/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/25/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmvDc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 BHSO, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/26/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _3CH, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/27/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1 NH3Slip, PpmvDc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 BUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/28/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmWdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
04/29/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, PpmedC	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/30/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary
CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, Lbperhr 1 Hour(s)	Unit CT1 ExhaustFlow, Lbperhr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/01/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Si	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/02/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/03/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Xst	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmWdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SLBD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/04/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/05/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 BUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/06/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary
CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, Liperhr 1 Hour(s)	Unit CT1 ExhaustFlow, Lbperhr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/07/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/08/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Kst	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/09/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%%:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmvdC 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSO, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/10/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/11/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmWdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/12/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmvDc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/13/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Y	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmvdC 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/14/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%DI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/15/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Ø	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/16/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Ø	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/17/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmWdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 BUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/18/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/19/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _3CR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/20/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
KSI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 GUSD, Mr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/21/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmvDc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/22/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/22/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/22/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/22/2019 03:00	0	11.5	0.0	15.5	10.8	898,494.6	0.88	0.88
05/22/2019 04:00	0	1.7	0.0	14.5	31.6	963,090.5	0.03	1.00
05/22/2019 05:00	2	1.8	12.1	14.5	30.2	966,086.1	0.00	1.00
05/22/2019 06:00	2	1.8	11.4	14.5	28.5	960,094.9	0.00	1.00
05/22/2019 07:00	2	1.9	10.6	14.4	28.9	945,745.5	0.00	1.00
05/22/2019 08:00	2	2.2	16.0	12.9	38.0	972,804.8	0.00	1.00
05/22/2019 09:00	2	2.2	13.6	13.5	33.4	962,668.3	0.00	1.00
05/22/2019 10:00	3	2.3	16.2	12.8	38.1	967,557.5	0.00	1.00
05/22/2019 11:00	3	2.5	17.7	12.1	43.6	973,069.4	0.00	1.00
05/22/2019 12:00	4	2.6	18.5	11.8	47.3	976,655.4	0.00	1.00
05/22/2019 13:00	3	2.6	17.9	12.1	44.0	978,204.7	0.00	1.00
05/22/2019 14:00	4	2.6	18.4	11.8	46.7	966,121.4	0.00	1.00
05/22/2019 15:00	2	2.2	13.6	13.3	30.5	938,776.5	0.00	1.00
05/22/2019 16:00	1	1.9	12.3	14.4	21.6	713,364.8	0.00	1.00
05/22/2019 17:00	2	1.9	12.5	14.4	20.1	645,104.2	0.00	1.00
05/22/2019 18:00	2	1.9	12.4	14.4	20.0	643,840.1	0.00	1.00
05/22/2019 19:00	2	1.9	12.2	14.4	20.0	643,208.1	0.00	1.00
05/22/2019 20:00	2	1.9	11.8	14.5	19.5	644,485.4	0.00	1.00
05/22/2019 21:00	2	1.9	12.0	14.5	19.9	644,485.4	0.00	1.00
05/22/2019 22:00	2	1.9	12.2	14.5	20.4	643,629.5	0.00	1.00
05/22/2019 23:00	2	1.9	12.7	14.5	21.6	639,350.0	0.00	1.00
Average/Sum#:	2	2.5	13.9	13.8	29.3	842,230.3	0.91 #	20.88 #
Minimum:	1	1.7	10.6	11.8	10.8	639,350.0	0.00	0.00
Maximum:	4	11.5	18.5	15.5	47.3	978,204.7	0.88	1.00
%Ex	20.83	12.50	20.83	12.50	12.50	12.50	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/23/2019 00:00	2	1.9	12.9	14.5	21.8	635,712.5	0.00	1.00
05/23/2019 01:00	2	1.9	13.0	14.5	22.0	635,712.5	0.00	1.00
05/23/2019 02:00	2	1.9	13.1	14.5	22.3	635,712.5	0.00	1.00
05/23/2019 03:00	2	1.9	13.2	14.5	22.0	635,284.5	0.00	1.00
05/23/2019 04:00	2	1.8	13.5	14.5	22.5	634,856.6	0.00	1.00
05/23/2019 05:00	2	1.9	13.0	14.5	21.6	634,428.6	0.00	1.00
05/23/2019 06:00	2	1.8	12.6	14.5	21.7	655,184.0	0.00	1.00
05/23/2019 07:00	2	2.2	15.4	13.2	33.4	936,899.7	0.00	1.00
05/23/2019 08:00	2	2.0	12.2	14.1	28.1	924,965.6	0.00	1.00
05/23/2019 09:00	1	1.8	9.6	14.6	23.1	908,819.6	0.00	1.00
05/23/2019 10:00	1	1.9	11.4	14.4	22.6	811,331.3	0.00	1.00
05/23/2019 11:00	1	1.8	9.5	14.5	22.4	887,130.2	0.00	1.00
05/23/2019 12:00	2	1.9	9.4	14.4	24.0	929,944.5	0.00	1.00
05/23/2019 13:00	2	1.9	10.0	14.2	24.8	922,419.7	0.00	1.00
05/23/2019 14:00	2	1.8	9.3	14.5	22.9	900,610.5	0.00	1.00
05/23/2019 15:00	2	1.9	10.4	14.2	25.1	915,266.0	0.00	1.00
05/23/2019 16:00	2	1.9	12.0	14.5	19.6	654,542.1	0.00	1.00
05/23/2019 17:00	2	1.8	11.8	14.5	19.1	642,987.5	0.00	1.00
05/23/2019 18:00	2	1.9	12.2	14.5	20.2	638,494.1	0.00	1.00
05/23/2019 19:00	2	1.9	12.3	14.5	20.5	637,638.2	0.00	1.00
05/23/2019 20:00	2	1.9	12.5	14.5	21.0	637,424.3	0.00	1.00
05/23/2019 21:00	2	1.9	12.6	14.4	21.6	651,003.3	0.00	1.00
05/23/2019 22:00	2	1.9	12.5	14.5	20.6	640,847.8	0.00	1.00
05/23/2019 23:00	2	1.9	12.4	14.5	20.8	637,638.2	0.00	1.00
Average/Sum#:	2	1.9	12.0	14.4	22.7	739,368.9	0.00 #	24.00 #
Minimum:	1	1.8	9.3	13.2	19.1	634,428.6	0.00	1.00
Maximum:	2	2.2	15.4	14.6	33.4	936,899.7	0.00	1.00
Est	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmwdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 BLSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/24/2019 00:00	2	1.9	12.6	14.5	21.0	637,852.2	0.00	1.00
05/24/2019 01:00	2	1.9	13.0	14.5	21.9	638,280.1	0.00	1.00
05/24/2019 02:00	2	1.8	13.2	14.5	22.3	638,280.1	0.00	1.00
05/24/2019 03:00	2	1.9	13.3	14.5	22.6	638,066.2	0.00	1.00
05/24/2019 04:00	2	1.8	13.8	14.5	22.8	638,066.2	0.00	1.00
05/24/2019 05:00	2	1.9	13.7	14.5	23.6	638,922.1	0.00	1.00
05/24/2019 06:00	2	1.9	13.4	14.5	23.1	648,122.9	0.00	1.00
05/24/2019 07:00	2	1.9	13.1	14.3	23.8	686,164.6	0.00	1.00
05/24/2019 08:00	1	1.9	11.1	14.4	22.0	811,963.3	0.00	1.00
05/24/2019 09:00	2	2.2	14.2	13.3	31.5	952,290.5	0.00	1.00
05/24/2019 10:00	2	2.0	11.8	14.4	24.1	809,856.5	0.00	1.00
05/24/2019 11:00	2	1.9	12.7	14.3	22.9	689,484.4	0.00	1.00
05/24/2019 12:00	1	1.9	10.3	14.4	21.2	802,272.0	0.00	1.00
05/24/2019 13:00	3	2.5	17.4	12.0	42.1	978,138.3	0.00	1.00
05/24/2019 14:00	3	2.5	16.7	12.4	37.6	964,719.2	0.00	1.00
05/24/2019 15:00	3	2.6	17.4	11.9	42.9	958,597.1	0.00	1.00
05/24/2019 16:00	1	2.2	12.7	14.4	17.5	680,287.9	0.08	1.00
05/24/2019 17:00	0	15.7	37.7	16.5	0.0	472,140.2	0.07	0.07
05/24/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/24/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/24/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/24/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/24/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/24/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	2.8	14.9	14.1	24.6	737,972.4	0.15 #	17.07 #
Minimum:	1	1.8	10.3	11.9	0.0	472,140.2	0.00	0.00
Maximum:	3	15.7	37.7	16.5	42.9	978,138.3	0.08	1.00
%SI	29.17	25.00	25.00	25.00	25.00	25.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/25/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/11/2019 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmAdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/26/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Y	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/27/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/28/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3slip, Ppmwdc 1 Hour(s)	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 NOX, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/29/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/30/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%St	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
05/31/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1 NH3Slip, PpmvdC	Unit CT1 NOx, Ppm	Unit CT1 NOx, _BCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/01/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Ex:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1 NH3slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NHInj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/02/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmWdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/03/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Sr	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmmdC 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _3CR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbsPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/04/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmWdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/05/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmwdC 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/06/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%X	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 BUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/07/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/08/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%9I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1 NH3Slip, PpmVdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/09/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I:	100.00	100.00	100.00	100.00	100.00	100.00	95.83	95.83

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/10/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, @5%, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/11/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%DI	100.00	100.00	100.00	100.00	100.00	100.00	29.17	29.17

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/12/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/12/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/12/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/12/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/12/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/12/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/12/2019 06:00	0	21.9	25.3	18.0	0.0	664,879.1	0.27	0.27
06/12/2019 07:00	2	4.8	11.5	14.4	17.0	780,361.2	0.72	1.00
06/12/2019 08:00	2	1.8	9.1	14.6	23.7	934,903.9	0.00	1.00
06/12/2019 09:00	2	1.9	9.1	14.4	24.0	911,615.3	0.00	1.00
06/12/2019 10:00	2	2.1	11.4	13.7	26.9	930,638.0	0.00	1.00
06/12/2019 11:00	0	0.0	13.1	0.0	28.2	347,663.4	0.00	1.00
06/12/2019 12:00	2	2.2	13.6	13.0	31.0	934,848.8	0.00	1.00
06/12/2019 13:00	2	2.1	13.4	13.1	30.3	931,735.3	0.00	1.00
06/12/2019 14:00	2	2.1	12.7	13.4	28.5	934,495.2	0.00	1.00
06/12/2019 15:00	2	2.1	11.9	13.6	27.2	928,957.5	0.00	1.00
06/12/2019 16:00	3	2.4	16.1	12.2	38.1	929,162.3	0.00	1.00
06/12/2019 17:00	2	2.4	15.3	12.8	33.5	937,633.0	0.00	1.00
06/12/2019 18:00	2	2.4	15.3	12.8	33.4	940,169.0	0.00	1.00
06/12/2019 19:00	4	2.6	17.1	11.8	42.2	936,174.6	0.00	1.00
06/12/2019 20:00	3	2.6	16.1	12.0	39.4	940,132.9	0.00	1.00
06/12/2019 21:00	2	1.9	9.5	14.5	21.1	805,606.7	0.00	1.00
06/12/2019 22:00	2	2.6	12.4	14.6	18.5	712,318.0	0.12	1.00
06/12/2019 23:00	0	14.6	30.8	17.1	0.0	314,607.2	0.03	0.03
Average/Sum#:	2	4.3	14.7	13.9	25.7	851,072.8	1.14 #	16.30 #
Minimum:	2	1.8	9.1	11.8	0.0	314,607.2	0.00	0.00
Maximum:	4	21.9	30.8	18.0	42.2	940,169.0	0.72	1.00
%EI	37.50	29.17	25.00	29.17	25.00	29.17	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUMO, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/13/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/13/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Ex	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/14/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/15/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Ksi	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _BCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUM3, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/16/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/17/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Ut:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, PpmvDc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/18/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 14:00	0	0.0	0.0	21.0	0.0	0.0	0.02	0.02
06/18/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	21.0	0.0	0.0	0.02 #	0.02 #
Minimum:	0	0.0	0.0	21.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	21.0	0.0	0.0	0.02	0.02
%SI	100.00	95.83	95.83	95.83	95.83	95.83	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/19/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%DI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmWdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/20/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/21/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/22/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Σ:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/23/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%GI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/24/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 BUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/25/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/26/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Sf	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/11/2019 10:21 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/27/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%DT	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmWdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/28/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%X	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmvDc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _3CR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/29/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:21 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, PpmVdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
06/30/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Ø:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmWdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/01/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/01/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/02/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/02/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/03/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/03/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 BUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/04/2019 00:00	0	0.0	-	0.0	0.0	0.0	0.00	0.00
04/04/2019 01:00	0	0.0	-	0.0	0.0	0.0	0.00	0.00
04/04/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/04/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmWdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUMO, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/05/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/05/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/06/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/06/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
KSI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 30

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/07/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/07/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
KSI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmwdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/08/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/08/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/09/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/09/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Sx	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3slip, Ppmvdc	NOx, Ppm	NOx, _BCR, Ppm	O2, Dry, Pct	NH3inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/10/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/10/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3slip, Ppmvdc 1 Hour(s)	Unit CT2 Nox, Ppm 1 Hour(s)	Unit CT2 Nox, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbperHr 1 Hour(s)	Unit CT2 Exhaustflow, LbperHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/11/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/11/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/12/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/12/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, PpmvDc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/13/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/13/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3slip, PpmvdC 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SumD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/14/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/14/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmWdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _BCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/15/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/15/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/16/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/16/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/17/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/17/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/18/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/18/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/19/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/19/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmvdC 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/20/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/20/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/21/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/21/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/SUM#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Comrt. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	Samp, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/22/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/22/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmWdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/23/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/23/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Ir	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, PpmvdC	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/24/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/24/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _BCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 BUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/25/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/25/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Σ:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/26/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/26/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/27/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/27/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%X	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, PpmvDc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/28/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/28/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmvDc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/29/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/29/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%%:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmvDc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 BLSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
04/30/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
04/30/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
KSI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/01/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/01/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/02/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/02/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/03/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/03/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _BCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 GUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/04/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/04/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmvdC 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/05/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/05/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmAdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/06/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/06/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2 NH3Slip, PpmvdC 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/07/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/07/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%GT	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmWdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/08/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/08/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUMD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/09/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/09/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _BCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, Lbs/Hr 1 Hour(s)	Unit CT2 ExhaustFlow, Lb/Hr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/10/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/10/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmWdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 BUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/11/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/11/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited value | ^ = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, Liberter 1 Hour(s)	Unit CT2 ExhaustFlow, Liberter 1 Hour(s)	Unit CT2 SUMD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/12/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/12/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Sr	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _3CR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/13/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/13/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/14/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/14/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Y	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmvDc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/15/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/15/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 BLED, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/16/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/16/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2 NH3Slip, PpmvDc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/17/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/17/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/18/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/18/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _BCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/19/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/19/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Σ:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmvDc 1 Hour(s)	Unit CT2 Nox, Ppm 1 Hour(s)	Unit CT2 Nox, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUMD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/20/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/20/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmadc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbperHr	ExhaustFlow, LbperHr	SUBD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/21/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/21/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbsPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbsPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/22/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/22/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/22/2019 02:00	0	17.9	24.5	18.3	0.0	672,598.1	0.22	0.22
05/22/2019 03:00	0	22.9	26.7	17.6	0.0	753,183.4	0.27	0.27
05/22/2019 04:00	1	5.7	16.0	14.5	27.0	1,024,928.6	0.70	1.00
05/22/2019 05:00	1	1.8	16.2	14.5	35.0	1,037,339.0	0.00	1.00
05/22/2019 06:00	1	1.8	15.6	14.5	32.3	1,030,919.8	0.00	1.00
05/22/2019 07:00	1	1.9	15.5	14.5	32.5	1,031,133.8	0.00	1.00
05/22/2019 08:00	2	2.3	19.2	13.0	40.1	1,041,802.6	0.00	1.00
05/22/2019 09:00	2	2.1	17.1	13.5	36.6	1,022,071.7	0.00	1.00
05/22/2019 10:00	2	2.3	19.2	12.8	41.1	1,029,773.3	0.00	1.00
05/22/2019 11:00	3	2.6	19.7	12.2	45.4	1,028,012.7	0.00	1.00
05/22/2019 12:00	3	2.7	19.8	11.9	49.4	1,030,872.2	0.00	1.00
05/22/2019 13:00	3	2.6	19.5	12.2	47.1	1,033,836.7	0.00	1.00
05/22/2019 14:00	3	2.6	19.6	11.9	48.9	1,021,438.4	0.00	1.00
05/22/2019 15:00	2	2.2	16.3	13.4	34.5	1,002,783.8	0.00	1.00
05/22/2019 16:00	1	1.9	13.0	14.4	19.4	762,032.0	0.00	1.00
05/22/2019 17:00	1	1.9	12.7	14.5	18.8	697,978.5	0.00	1.00
05/22/2019 18:00	1	1.9	12.7	14.5	18.8	697,978.5	0.00	1.00
05/22/2019 19:00	1	1.9	12.6	14.5	18.6	697,978.5	0.00	1.00
05/22/2019 20:00	1	1.9	13.0	14.5	19.7	690,275.5	0.00	1.00
05/22/2019 21:00	1	1.9	13.2	14.5	20.1	690,275.5	0.00	1.00
05/22/2019 22:00	1	1.9	13.4	14.5	20.4	690,275.5	0.00	1.00
05/22/2019 23:00	1	1.8	14.5	14.5	22.9	685,782.1	0.00	1.00
Average/Sum#:	2	3.9	16.8	14.1	28.6	880,603.2	1.19 #	20.49 #
Minimum:	1	1.8	12.6	11.9	0.0	672,598.1	0.00	0.00
Maximum:	3	22.9	26.7	18.3	49.4	1,041,802.6	0.70	1.00
%SI	16.67	8.33	8.33	8.33	8.33	8.33	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/23/2019 00:00	1	1.9	15.2	14.5	23.8	682,572.5	0.00	1.00
05/23/2019 01:00	1	1.8	15.3	14.5	24.0	682,572.5	0.00	1.00
05/23/2019 02:00	1	1.8	15.6	14.5	24.4	682,358.5	0.00	1.00
05/23/2019 03:00	1	1.8	15.5	14.5	24.3	682,144.5	0.00	1.00
05/23/2019 04:00	1	1.8	15.6	14.5	23.9	681,502.6	0.00	1.00
05/23/2019 05:00	1	1.9	15.7	14.5	24.3	681,502.6	0.00	1.00
05/23/2019 06:00	1	1.8	15.1	14.6	23.2	712,535.4	0.00	1.00
05/23/2019 07:00	1	2.2	17.6	13.3	35.6	1,000,941.1	0.00	1.00
05/23/2019 08:00	1	2.0	15.0	14.2	32.4	991,095.3	0.00	1.00
05/23/2019 09:00	1	1.8	13.3	14.6	26.9	983,594.5	0.00	1.00
05/23/2019 10:00	1	1.9	12.1	14.5	21.5	903,392.1	0.00	1.00
05/23/2019 11:00	1	1.8	12.7	14.6	26.4	998,593.0	0.00	1.00
05/23/2019 12:00	1	1.8	13.4	14.6	28.4	1,023,590.4	0.00	1.00
05/23/2019 13:00	1	1.9	13.7	14.3	29.1	987,645.5	0.00	1.00
05/23/2019 14:00	1	1.9	12.5	14.5	25.5	972,505.3	0.00	1.00
05/23/2019 15:00	1	1.9	13.6	14.2	28.4	971,678.1	0.00	1.00
05/23/2019 16:00	1	1.9	12.6	14.5	17.1	697,122.6	0.00	1.00
05/23/2019 17:00	1	1.8	13.0	14.5	19.8	685,782.1	0.00	1.00
05/23/2019 18:00	1	1.8	14.1	14.5	21.2	682,786.4	0.00	1.00
05/23/2019 19:00	1	1.9	14.4	14.5	22.3	683,428.4	0.00	1.00
05/23/2019 20:00	1	1.8	14.7	14.5	22.8	683,642.3	0.00	1.00
05/23/2019 21:00	1	1.9	13.6	14.4	20.4	697,353.0	0.00	1.00
05/23/2019 22:00	1	1.9	14.8	14.5	23.7	687,279.9	0.00	1.00
05/23/2019 23:00	1	1.8	15.1	14.5	23.5	684,070.3	0.00	1.00
Average/Sum#:	1	1.9	14.3	14.4	24.7	797,487.0	0.00 #	24.00 #
Minimum:	1	1.8	12.1	13.3	17.1	681,502.6	0.00	1.00
Maximum:	1	2.2	17.6	14.6	35.6	1,023,590.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _BCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/24/2019 00:00	1	1.8	15.4	14.5	24.2	684,712.2	0.00	1.00
05/24/2019 01:00	1	1.8	15.8	14.5	25.1	685,140.1	0.00	1.00
05/24/2019 02:00	1	1.8	16.2	14.5	25.8	685,140.1	0.00	1.00
05/24/2019 03:00	1	1.8	16.4	14.5	26.2	685,354.1	0.00	1.00
05/24/2019 04:00	1	1.8	16.8	14.6	26.2	695,580.6	0.00	1.00
05/24/2019 05:00	1	1.8	16.7	14.6	26.6	695,580.6	0.00	1.00
05/24/2019 06:00	1	1.8	16.0	14.6	25.0	704,927.5	0.00	1.00
05/24/2019 07:00	1	1.9	14.0	14.3	21.1	747,166.2	0.00	1.00
05/24/2019 08:00	1	1.9	12.2	14.5	21.7	913,662.8	0.00	1.00
05/24/2019 09:00	2	2.1	16.8	13.3	35.6	1,007,788.2	0.00	1.00
05/24/2019 10:00	1	1.9	12.4	14.4	22.0	872,639.4	0.00	1.00
05/24/2019 11:00	1	1.9	13.4	14.3	20.6	747,788.7	0.00	1.00
05/24/2019 12:00	1	1.9	11.9	14.5	22.0	895,047.2	0.00	1.00
05/24/2019 13:00	3	2.5	18.6	12.1	45.5	1,027,379.5	0.00	1.00
05/24/2019 14:00	2	2.4	18.0	12.5	41.1	1,015,330.4	0.00	1.00
05/24/2019 15:00	3	2.6	18.9	12.0	47.3	1,017,990.1	0.00	1.00
05/24/2019 16:00	1	2.0	13.1	14.4	16.9	725,373.6	0.07	1.00
05/24/2019 17:00	0	16.1	34.3	16.4	0.0	473,820.8	0.10	0.10
05/24/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/24/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/24/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/24/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/24/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/24/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	2.8	16.5	14.1	26.3	793,356.8	0.17 #	17.10 #
Minimum:	1	1.8	11.9	12.0	0.0	473,820.8	0.00	0.00
Maximum:	3	16.1	34.3	16.4	47.3	1,027,379.5	0.10	1.00
%#:	29.17	25.00	25.00	25.00	25.00	25.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, PpmvDc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/25/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/25/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmWdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/26/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/26/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Σ:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/27/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/27/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Y	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2 NH3slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _8CR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/28/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/28/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/29/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/29/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Ɪ	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 BUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/30/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/30/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
05/31/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
05/31/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/01/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/01/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmWdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/02/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/02/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 GUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/03/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/03/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmvDc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/04/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/04/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3slip, ppmvdc 1 Hour(s)	Unit CT2 NOx, ppm 1 Hour(s)	Unit CT2 NOx, _SCR, ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUMD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/05/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/05/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/06/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/06/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 Nh3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Nh3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/07/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/07/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3inj, Lbs/hr 1 Hour(s)	Unit CT2 ExhaustFlow, Lb/hr 1 Hour(s)	Unit CT2 GLSO, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/08/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/08/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 GUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/09/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/09/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	95.83	95.83

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, Lbs/Hr 1 Hour(s)	Unit CT2 ExhaustFlow, Lbs/Hr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/10/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/10/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 BUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/11/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 13:00	0	26.7	30.7	17.8	0.0	700,615.2	0.25	0.25
06/11/2019 14:00	0	6.7	13.5	14.5	11.7	700,546.2	1.00	1.00
06/11/2019 15:00	1	2.1	13.3	14.5	30.5	880,069.1	0.28	1.00
06/11/2019 16:00	0	1.4	13.9	14.6	26.4	996,854.0	0.00	1.00
06/11/2019 17:00	1	1.5	13.8	14.6	29.1	996,854.0	0.00	1.00
06/11/2019 18:00	1	1.7	12.8	14.6	26.1	978,160.3	0.00	1.00
06/11/2019 19:00	1	1.8	12.6	14.6	23.6	960,118.7	0.00	1.00
06/11/2019 20:00	0	9.6	31.2	15.4	2.8	565,447.8	0.15	0.17
06/11/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/11/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	6.4	17.7	15.1	18.8	847,333.2	1.68 #	6.42 #
Minimum:	0	1.4	12.6	14.5	0.0	565,447.8	0.00	0.00
Maximum:	1	26.7	31.2	17.8	30.5	996,854.0	1.00	1.00
%SI	75.00	66.67	66.67	66.67	66.67	66.67	29.17	29.17

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/12/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/12/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/12/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/12/2019 03:00	0	18.6	26.2	17.7	0.0	739,061.2	0.28	0.28
06/12/2019 04:00	1	4.6	14.3	14.5	24.1	965,444.2	0.60	1.00
06/12/2019 05:00	0	1.9	12.5	14.4	21.2	877,695.7	0.00	1.00
06/12/2019 06:00	1	1.7	11.9	14.4	21.8	854,099.5	0.00	1.00
06/12/2019 07:00	1	1.6	12.8	14.5	27.0	977,426.7	0.00	1.00
06/12/2019 08:00	1	1.6	13.3	14.6	28.4	1,007,939.8	0.00	1.00
06/12/2019 09:00	1	1.7	13.3	14.5	29.2	992,618.7	0.00	1.00
06/12/2019 10:00	1	1.8	14.7	13.7	31.3	991,311.1	0.00	1.00
06/12/2019 11:00	2	1.6	16.1	13.2	35.5	996,478.5	0.00	1.00
06/12/2019 12:00	2	2.1	16.6	13.0	35.9	986,852.3	0.00	1.00
06/12/2019 13:00	2	2.0	16.4	13.1	34.8	984,756.6	0.00	1.00
06/12/2019 14:00	2	2.0	15.7	13.4	33.3	990,185.1	0.00	1.00
06/12/2019 15:00	2	2.0	14.9	13.6	32.1	987,486.3	0.00	1.00
06/12/2019 16:00	3	2.5	18.1	12.3	41.6	992,514.2	0.00	1.00
06/12/2019 17:00	2	2.3	17.6	12.8	37.3	990,888.4	0.00	1.00
06/12/2019 18:00	2	2.3	17.6	12.8	36.4	994,269.7	0.00	1.00
06/12/2019 19:00	3	2.6	18.6	11.9	44.9	995,267.2	0.00	1.00
06/12/2019 20:00	3	2.5	18.2	12.0	44.1	992,909.6	0.00	1.00
06/12/2019 21:00	1	1.9	11.9	14.5	20.4	874,077.9	0.00	1.00
06/12/2019 22:00	1	1.9	11.9	14.5	19.9	820,584.8	0.00	1.00
06/12/2019 23:00	1	1.8	13.0	14.6	28.2	1,008,157.2	0.00	1.00
Average/Sum#:	2	2.9	15.5	13.8	29.9	953,334.5	0.88 #	20.28 #
Minimum:	0	1.6	11.9	11.9	0.0	739,061.2	0.00	0.00
Maximum:	3	18.6	26.2	17.7	44.9	1,008,157.2	0.60	1.00
%I	16.67	12.50	12.50	12.50	12.50	12.50	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _@CR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/13/2019 00:00	1	1.9	12.3	14.4	18.8	794,687.5	0.00	1.00
06/13/2019 01:00	1	1.9	12.4	14.4	20.1	777,201.0	0.00	1.00
06/13/2019 02:00	1	1.9	13.0	14.4	21.0	765,192.2	0.00	1.00
06/13/2019 03:00	1	1.9	13.1	14.4	20.8	767,299.0	0.00	1.00
06/13/2019 04:00	1	1.9	13.3	14.4	20.9	772,355.4	0.00	1.00
06/13/2019 05:00	1	1.9	13.3	14.4	21.1	771,301.9	0.00	1.00
06/13/2019 06:00	1	1.9	13.2	14.4	20.6	769,827.2	0.00	1.00
06/13/2019 07:00	1	1.9	13.0	14.4	20.7	772,566.0	0.00	1.00
06/13/2019 08:00	1	1.8	13.0	14.6	25.6	928,165.4	0.00	1.00
06/13/2019 09:00	1	1.8	12.9	14.6	24.7	928,817.5	0.00	1.00
06/13/2019 10:00	1	1.9	12.0	14.6	21.3	863,824.2	0.00	1.00
06/13/2019 11:00	1	1.8	12.4	14.7	24.7	937,834.8	0.00	1.00
06/13/2019 12:00	1	1.8	11.9	14.6	20.8	852,955.8	0.00	1.00
06/13/2019 13:00	1	1.8	11.8	14.6	21.6	863,172.1	0.00	1.00
06/13/2019 14:00	1	1.8	11.8	14.7	21.5	877,536.0	0.00	1.00
06/13/2019 15:00	1	1.8	11.8	14.6	21.4	864,041.6	0.00	1.00
06/13/2019 16:00	1	1.8	12.1	14.6	23.4	915,340.6	0.00	1.00
06/13/2019 17:00	1	1.9	11.3	14.5	19.6	873,863.9	0.00	1.00
06/13/2019 18:00	1	2.0	14.3	13.7	30.5	990,740.5	0.00	1.00
06/13/2019 19:00	1	2.0	14.4	13.8	29.5	982,320.9	0.00	1.00
06/13/2019 20:00	1	1.9	12.8	14.5	27.3	992,618.7	0.00	1.00
06/13/2019 21:00	1	1.8	12.9	14.6	27.1	1,009,678.8	0.00	1.00
06/13/2019 22:00	1	2.0	13.4	14.5	21.4	889,483.9	0.07	1.00
06/13/2019 23:00		15.7	35.6	16.4	0.0	487,210.8	0.08	0.08
Average/Sum#:	1	2.5	13.7	14.5	21.9	852,001.5	0.15 #	23.08 #
Minimum:	1	1.8	11.3	13.7	0.0	487,210.8	0.00	0.08
Maximum:	1	15.7	35.6	16.4	30.5	1,009,678.8	0.08	1.00
%SI	4.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOX, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUMD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/14/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/14/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Ø:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmvdC 1 Hour(s)	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 NOX, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 BUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/15/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/15/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
KSI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, Lbsperhr 1 Hour(s)	Unit CT2 ExhaustFlow, Lbsperhr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/16/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/16/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Σ	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmvdC 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/17/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/17/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 BUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/18/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 14:00	0	2.7	6.7	20.1	0.0	754,895.2	0.07	0.07
06/18/2019 15:00	1	11.1	18.9	15.0	16.4	927,262.8	0.70	1.00
06/18/2019 16:00	1	1.9	13.8	14.6	27.1	987,289.8	0.00	1.00
06/18/2019 17:00	0	1.7	12.5	14.5	19.9	854,820.4	0.00	1.00
06/18/2019 18:00	0	1.7	11.6	14.4	18.6	810,699.2	0.00	1.00
06/18/2019 19:00	1	1.7	11.7	14.4	18.3	782,889.4	0.00	1.00
06/18/2019 20:00	1	1.8	12.7	14.5	19.0	751,471.6	0.05	1.00
06/18/2019 21:00	0	13.2	40.2	15.9	0.0	519,559.6	0.10	0.10
06/18/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/18/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	4.5	16.0	15.4	14.9	798,611.0	0.92 #	6.17 #
Minimum:	0	1.7	6.7	14.4	0.0	519,559.6	0.00	0.00
Maximum:	1	13.2	40.2	20.1	27.1	987,289.8	0.70	1.00
%I	75.00	66.67	66.67	66.67	66.67	66.67	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/19/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/19/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Ø:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOX, Ppm 1 Hour(s)	Unit CT2 NOX, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/20/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/20/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%Σ:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmvdC 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _BCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/21/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/21/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 To: 06/30/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SumD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/22/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/22/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 BUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/23/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/23/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/24/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/24/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
XSI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmWdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/25/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/25/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmWdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _BCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/26/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/26/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, PpmvDc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/27/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/27/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/28/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/28/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%:	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, PpmvdC 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/29/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/29/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%I	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/11/2019 10:23 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
06/30/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
06/30/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

ATTACHMENT 15

AQ-55

AQ-55 The emissions rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown shall not exceed the following:

Turbine emissions limitations during Startup and Shutdown		
Pollutant	**Max Lbs/ Hr (worst case turbine**	**Pounds per Startup or Shutdown (both turbines combined)**
NOx	**37.1**	**122.8**
CO	**89.5**	**204.8**

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Monthly Summary By Day Report

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:19 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOX_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOX_SUSD, LbPerHr 1 Hour(s)
04/01/2019	0.0	0.0	0.0	0.0
04/02/2019	0.0	0.0	0.0	0.0
04/03/2019	0.0	0.0	0.0	0.0
04/04/2019	0.0	0.0	0.0	0.0
04/05/2019	0.0	0.0	0.0	0.0
04/06/2019	0.0	0.0	0.0	0.0
04/07/2019	0.0	0.0	0.0	0.0
04/08/2019	0.0	0.0	0.0	0.0
04/09/2019	0.0	0.0	0.0	0.0
04/10/2019	0.0	0.0	0.0	0.0
04/11/2019	0.0	0.0	0.0	0.0
04/12/2019	0.0	0.0	0.0	0.0
04/13/2019	0.0	0.0	0.0	0.0
04/14/2019	0.0	0.0	0.0	0.0
04/15/2019	0.0	0.0	0.0	0.0
04/16/2019	0.0	0.0	0.0	0.0
04/17/2019	0.0	0.0	0.0	0.0
04/18/2019	0.0	0.0	0.0	0.0
04/19/2019	0.0	0.0	0.0	0.0
04/20/2019	0.0	0.0	0.0	0.0
04/21/2019	0.0	0.0	0.0	0.0
04/22/2019	0.0	0.0	0.0	0.0
04/23/2019	0.0	0.0	0.0	0.0
04/24/2019	0.0	0.0	0.0	0.0
04/25/2019	0.0	0.0	0.0	0.0
04/26/2019	0.0	0.0	0.0	0.0
04/27/2019	0.0	0.0	0.0	0.0
04/28/2019	0.0	0.0	0.0	0.0
04/29/2019	0.0	0.0	0.0	0.0
04/30/2019	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	- *	- *	- *	- *
Daily Min:	-	-	-	-
Daily Max:	-	-	-	-
Apr 2019 - Apr 2019	-	-	-	-
QTD:	0.0 *	0.0 *	0.0 *	0.0 *
YTD 2019:	198.6 *	68.0 *	173.9 *	82.0 *

Monthly Summary By Day Report

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:19 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOX_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOX_SUSD, LbPerHr 1 Hour(s)
05/01/2019	0.0	0.0	0.0	0.0
05/02/2019	0.0	0.0	0.0	0.0
05/03/2019	0.0	0.0	0.0	0.0
05/04/2019	0.0	0.0	0.0	0.0
05/05/2019	0.0	0.0	0.0	0.0
05/06/2019	0.0	0.0	0.0	0.0
05/07/2019	0.0	0.0	0.0	0.0
05/08/2019	0.0	0.0	0.0	0.0
05/09/2019	0.0	0.0	0.0	0.0
05/10/2019	0.0	0.0	0.0	0.0
05/11/2019	0.0	0.0	0.0	0.0
05/12/2019	0.0	0.0	0.0	0.0
05/13/2019	0.0	0.0	0.0	0.0
05/14/2019	0.0	0.0	0.0	0.0
05/15/2019	0.0	0.0	0.0	0.0
05/16/2019	0.0	0.0	0.0	0.0
05/17/2019	0.0	0.0	0.0	0.0
05/18/2019	0.0	0.0	0.0	0.0
05/19/2019	0.0	0.0	0.0	0.0
05/20/2019	0.0	0.0	0.0	0.0
05/21/2019	0.0	0.0	0.0	0.0
05/22/2019	38.3	12.6	70.2	19.3
05/23/2019	0.0	0.0	0.0	0.0
05/24/2019	9.7	1.2	0.0	1.3
05/25/2019	0.0	0.0	0.0	0.0
05/26/2019	0.0	0.0	0.0	0.0
05/27/2019	0.0	0.0	0.0	0.0
05/28/2019	0.0	0.0	0.0	0.0
05/29/2019	0.0	0.0	0.0	0.0
05/30/2019	0.0	0.0	0.0	0.0
05/31/2019	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	48.0 *	13.8 *	70.2 *	20.6 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	38.3	12.6	70.2	19.3
Apr 2019 - May 2019	48.0	13.8	70.2	20.6
QTD:	48.0 *	13.8 *	70.2 *	20.6 *
YTD 2019:	246.6 *	81.8 *	244.1 *	102.6 *

Monthly Summary By Day Report

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:19 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOx_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOx_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/01/2019	0.0	0.0	0.0	0.0
06/02/2019	0.0	0.0	0.0	0.0
06/03/2019	0.0	0.0	0.0	0.0
06/04/2019	0.0	0.0	0.0	0.0
06/05/2019	0.0	0.0	0.0	0.0
06/06/2019	0.0	0.0	0.0	0.0
06/07/2019	0.0	0.0	0.0	0.0
06/08/2019	0.0	0.0	0.0	0.0
06/09/2019	0.0	0.0	0.0	0.0
06/10/2019	0.0	0.0	0.0	0.0
06/11/2019	0.0	0.0	29.1	16.9
06/12/2019	39.5	11.9	27.3	11.6
06/13/2019	0.0	0.0	10.7	1.3
06/14/2019	0.0	0.0	0.0	0.0
06/15/2019	0.0	0.0	0.0	0.0
06/16/2019	0.0	0.0	0.0	0.0
06/17/2019	0.0	0.0	0.0	0.0
06/18/2019	0.0	0.0	28.7	14.9
06/19/2019	0.0	0.0	0.0	0.0
06/20/2019	0.0	0.0	0.0	0.0
06/21/2019	0.0	0.0	0.0	0.0
06/22/2019	0.0	0.0	0.0	0.0
06/23/2019	0.0	0.0	0.0	0.0
06/24/2019	0.0	0.0	0.0	0.0
06/25/2019	0.0	0.0	0.0	0.0
06/26/2019	0.0	0.0	0.0	0.0
06/27/2019	0.0	0.0	0.0	0.0
06/28/2019	0.0	0.0	0.0	0.0
06/29/2019	0.0	0.0	0.0	0.0
06/30/2019	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	39.5 *	11.9 *	95.8 *	44.7 *
Daily Min:	0.0	0.0	10.7	1.3
Daily Max:	39.5	11.9	29.1	16.9
Apr 2019 - Jun 2019	87.5	25.7	166.0	65.3
QTD:	87.5 *	25.7 *	166.0 *	65.3 *
YTD 2019:	286.1 *	93.7 *	339.9 *	147.3 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 00:00 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/10/2019 13:16 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
04/01/2019	0.00	0.00	0.00	0.00	0.00
04/02/2019	0.00	0.00	0.00	0.00	0.00
04/03/2019	0.00	0.00	0.00	0.00	0.00
04/04/2019	0.00	0.00	0.00	0.00	0.00
04/05/2019	0.00	0.00	0.00	0.00	0.00
04/06/2019	0.00	0.00	0.00	0.00	0.00
04/07/2019	0.00	0.00	0.00	0.00	0.00
04/08/2019	0.00	0.00	0.00	0.00	0.00
04/09/2019	0.00	0.00	0.00	0.00	0.00
04/10/2019	0.00	0.00	0.00	0.00	0.00
04/11/2019	0.00	0.00	0.00	0.00	0.00
04/12/2019	0.00	0.00	0.00	0.00	0.00
04/13/2019	0.00	0.00	0.00	0.00	0.00
04/14/2019	0.00	0.00	0.00	0.00	0.00
04/15/2019	0.00	0.00	0.00	0.00	0.00
04/16/2019	0.00	0.00	0.00	0.00	0.00
04/17/2019	0.00	0.00	0.00	0.00	0.00
04/18/2019	0.00	0.00	0.00	0.00	0.00
04/19/2019	0.00	0.00	0.00	0.00	0.00
04/20/2019	0.00	0.00	0.00	0.00	0.00
04/21/2019	0.00	0.00	0.00	0.00	0.00
04/22/2019	0.00	0.00	0.00	0.00	0.00
04/23/2019	0.00	0.00	0.00	0.00	0.00
04/24/2019	0.00	0.00	0.00	0.00	0.00
04/25/2019	0.00	0.00	0.00	0.00	0.00
04/26/2019	0.00	0.00	0.00	0.00	0.00
04/27/2019	0.00	0.00	0.00	0.00	0.00
04/28/2019	0.00	0.00	0.00	0.00	0.00
04/29/2019	0.00	0.00	0.00	0.00	0.00
04/30/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	- *	- *	- *	- *	- *
Daily Min:	-	-	-	-	-
Daily Max:	-	-	-	-	-
Apr 2019 - Apr 2019	-	-	-	-	-
QTD:	0.00 *	0.00 *	0.00 *	0.00 *	0.00 *
YTD 2019:	2,567.00 *	7,724.06 *	726.63 *	1,454.24 *	2,423.82 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 00:00 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/10/2019 13:16 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT2 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
05/01/2019	0.00	0.00	0.00	0.00	0.00
05/02/2019	0.00	0.00	0.00	0.00	0.00
05/03/2019	0.00	0.00	0.00	0.00	0.00
05/04/2019	0.00	0.00	0.00	0.00	0.00
05/05/2019	0.00	0.00	0.00	0.00	0.00
05/06/2019	0.00	0.00	0.00	0.00	0.00
05/07/2019	0.00	0.00	0.00	0.00	0.00
05/08/2019	0.00	0.00	0.00	0.00	0.00
05/09/2019	0.00	0.00	0.00	0.00	0.00
05/10/2019	0.00	0.00	0.00	0.00	0.00
05/11/2019	0.00	0.00	0.00	0.00	0.00
05/12/2019	0.00	0.00	0.00	0.00	0.00
05/13/2019	0.00	0.00	0.00	0.00	0.00
05/14/2019	0.00	0.00	0.00	0.00	0.00
05/15/2019	0.00	0.00	0.00	0.00	0.00
05/16/2019	0.00	0.00	0.00	0.00	0.00
05/17/2019	0.00	0.00	0.00	0.00	0.00
05/18/2019	0.00	0.00	0.00	0.00	0.00
05/19/2019	0.00	0.00	0.00	0.00	0.00
05/20/2019	0.00	0.00	0.00	0.00	0.00
05/21/2019	0.00	0.00	0.00	0.00	0.00
05/22/2019	141.84	148.90	11.34	22.68	37.79
05/23/2019	36.81	110.25	10.51	21.03	35.06
05/24/2019	22.41	88.52	8.23	16.44	27.47
05/25/2019	0.00	0.00	0.00	0.00	0.00
05/26/2019	0.00	0.00	0.00	0.00	0.00
05/27/2019	0.00	0.00	0.00	0.00	0.00
05/28/2019	0.00	0.00	0.00	0.00	0.00
05/29/2019	0.00	0.00	0.00	0.00	0.00
05/30/2019	0.00	0.00	0.00	0.00	0.00
05/31/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	201.06 *	347.67 *	30.08 *	60.17 *	100.32 *
Daily Min:	22.41	88.52	8.23	16.44	27.47
Daily Max:	141.84	148.90	11.34	22.68	37.79
Apr 2019 - May 2019	201.06	347.67	30.08	60.17	100.32
QTD:	201.06 *	347.67 *	30.08 *	60.17 *	100.32 *
YTD 2019:	2,768.06 *	8,071.73 *	756.71 *	1,514.41 *	2,524.14 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 00:00 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/10/2019 13:16 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
06/01/2019	0.00	0.00	0.00	0.00	0.00
06/02/2019	0.00	0.00	0.00	0.00	0.00
06/03/2019	0.00	0.00	0.00	0.00	0.00
06/04/2019	0.00	0.00	0.00	0.00	0.00
06/05/2019	0.00	0.00	0.00	0.00	0.00
06/06/2019	0.00	0.00	0.00	0.00	0.00
06/07/2019	0.00	0.00	0.00	0.00	0.00
06/08/2019	0.00	0.00	0.00	0.00	0.00
06/09/2019	0.00	0.00	0.00	0.00	0.00
06/10/2019	0.00	0.00	0.00	0.00	0.00
06/11/2019	38.15	29.24	1.59	3.15	5.25
06/12/2019	95.16	128.42	11.02	22.03	36.70
06/13/2019	35.67	60.33	5.68	11.33	18.81
06/14/2019	0.00	0.00	0.00	0.00	0.00
06/15/2019	0.00	0.00	0.00	0.00	0.00
06/16/2019	0.00	0.00	0.00	0.00	0.00
06/17/2019	0.00	0.00	0.00	0.00	0.00
06/18/2019	40.37	29.40	1.42	2.86	4.77
06/19/2019	0.00	0.00	0.00	0.00	0.00
06/20/2019	0.00	0.00	0.00	0.00	0.00
06/21/2019	0.00	0.00	0.00	0.00	0.00
06/22/2019	0.00	0.00	0.00	0.00	0.00
06/23/2019	0.00	0.00	0.00	0.00	0.00
06/24/2019	0.00	0.00	0.00	0.00	0.00
06/25/2019	0.00	0.00	0.00	0.00	0.00
06/26/2019	0.00	0.00	0.00	0.00	0.00
06/27/2019	0.00	0.00	0.00	0.00	0.00
06/28/2019	0.00	0.00	0.00	0.00	0.00
06/29/2019	0.00	0.00	0.00	0.00	0.00
06/30/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	209.35 *	247.39 *	19.71 *	39.37 *	65.53 *
Daily Min:	35.67	29.24	1.42	2.86	4.77
Daily Max:	95.16	128.42	11.02	22.03	36.70
Apr 2019 - Jun 2019	410.41	595.06	49.79	99.54	165.85
QTD:	410.41 *	595.06 *	49.79 *	99.54 *	165.85 *
YTD 2019:	2,977.41 *	8,319.12 *	776.42 *	1,553.78 *	2,589.67 *

Startup / Shutdown Events

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:21 **Location:** Roseville, CA

Unit Offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
04/01/2019 00:00	05/22/2019 02:00	1227
05/24/2019 18:00	06/12/2019 05:00	444
06/13/2019 00:00	06/18/2019 13:00	134
06/18/2019 15:00	06/30/2019 23:00	297

Startup / Shutdown Events

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:21 **Location:** Roseville, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,184.00 Hour(s)
Total offline:	2,102.00 Hour(s)
Offline Percentage:	96.25 %
Total Online:	82.00 Hour(s)
Online Percentage:	3.75 %

Startup / Shutdown Events

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:21 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	05/22/2019 03:07	05/22/2019 04:01	Cold Startup	55
2	05/24/2019 16:55	05/24/2019 17:03	Shutdown	9
3	06/12/2019 06:44	06/12/2019 07:42	Cold Startup	59
4	06/12/2019 22:53	06/12/2019 23:01	Shutdown	9
5	06/18/2019 14:45	06/18/2019 14:45	Cold Startup	1
6	06/18/2019 14:45	06/18/2019 14:45	Shutdown	1

Startup / Shutdown Events

CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:21 **Location:** Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	3	115	2.45
Warm Startup	0		0.00
Shutdown	3	19	0.40
Total Process Events:	6	134	2.85

Total Report Time:	2,183.98 Hour(s)
Total Operating Time:	78.27 Hour(s)
Total Startup Time:	115 Minute(s)
Total Shutdown Time:	19 Minute(s)
Total Startup/Shutdown Time:	134 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	2.85 %

CT1 SUSD EVENT 1

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
05/22/19 3:02	0			0			-0.1			0			0			0		
05/22/19 3:03	0			0			-0.1			0			0			0		
05/22/19 3:04	0			0			-0.1			0			0			0		
05/22/19 3:05	0			0			-0.1			0			0			0		
05/22/19 3:06	0			0			-0.1			0			0			0		
05/22/19 3:07	0			0.2			-0.1			0			0			1		
05/22/19 3:08	0			0.1			-0.1			0			0			1		
05/22/19 3:09	26031.4			1.5			0.5			0			0			1		
05/22/19 3:10	42666.8			680.2			17.28			67.45			2.82			1		
05/22/19 3:11	59148.3			517.2			20.32			71.21			4.6			1		
05/22/19 3:12	98965.5			321.6			25.87			73.99			9.72			1		
05/22/19 3:13	137781.6			167			36.68			53.53			19.35			1		
05/22/19 3:14	140554.2			65.9			55.74			21.54			29.98			1		
05/22/19 3:15	153338.8			1390.6			39.83			495.85			23.37			1		
05/22/19 3:16	172130.7			1954.3			37.72			782.2			24.85			1		
05/22/19 3:17	193387.1			1270.1			44.33			571.17			32.81			1		
05/22/19 3:18	217647.1			216.6			52.12			109.63			43.41			1		
05/22/19 3:19	238287.4			16.7			54.94			9.27			50.12			1		
05/22/19 3:20	264826.9			2.6			54.85			1.61			55.57			1		
05/22/19 3:21	288116.8			2			51.1			1.34			56.36			1		
05/22/19 3:22	309296.2			2			35.4			1.41			41.91			1		
05/22/19 3:23	328550.1			2.3			18.47			1.76			23.23			1		
05/22/19 3:24	346340.8			2.1			15.82			1.65			20.97			1		
05/22/19 3:25	364362.6			2			12.84			1.69			17.91			1		
05/22/19 3:26	384771.8			1.8			9.86			1.65			14.53			1		
05/22/19 3:27	407183.4			1.6			8.8			1.55			13.72			1		
05/22/19 3:28	433137.8			1.4			7.9			1.37			13.09			1		
05/22/19 3:29	441147.5			1.2			7.47			1.23			12.61			1		
05/22/19 3:30	437065.7			1.2			7.35			1.2			12.3			1		
05/22/19 3:31	436603.5			1.1			6.54			1.11			10.92			1		
05/22/19 3:32	436834.6			0.9			6.17			0.92			10.32			1		
05/22/19 3:33	437450.7			1			6.27			1.03			10.5			1		
05/22/19 3:34	436449.5			1			6.18			1.03			10.32			1		
05/22/19 3:35	435987.4			1.1			6.18			1.12			10.31			1		
05/22/19 3:36	435448.3			1			6.18			1.03			10.29			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/22/19 3:37	435910.4			0.9			6.18			0.93			10.31			1		
05/22/19 3:38	434524.1			0.8			6.08			0.84			10.12			1		
05/22/19 3:39	434524.1			0.7			6.08			0.75			10.12			1		
05/22/19 3:40	434524.1			0.7			6.18			0.75			10.27			1		
05/22/19 3:41	433831			0.8			6.27			0.84			10.41			1		
05/22/19 3:42	433137.8			0.8			6.45			0.84			10.7			1		
05/22/19 3:43	433831			0.8			6.64			0.84			11.02			1		
05/22/19 3:44	433754			0.7			6.73			0.74			11.17			1		
05/22/19 3:45	433676.9			0.8			6.82			0.84			11.32			1		
05/22/19 3:46	433060.8			0.8			7.01			0.84			11.61			1		
05/22/19 3:47	433599.9			0.8			5.44			0.84			9.03			1		
05/22/19 3:48	433445.9			0.9			3.5			0.93			5.81			1		
05/22/19 3:49	433599.9			1.1			3.13			1.12			5.2			1		
05/22/19 3:50	433599.9			1.1			3.04			1.12			5.05			1		
05/22/19 3:51	434139			1			2.95			1.02			4.9			1		
05/22/19 3:52	433291.9			1			2.95			1.02			4.89			1		
05/22/19 3:53	432444.7			1			2.95			1.02			4.88			1		
05/22/19 3:54	432290.7			0.9			2.86			0.93			4.73			1		
05/22/19 3:55	431982.6			0.8			2.67			0.83			4.42			1		
05/22/19 3:56	432059.6			0.8			2.49			0.83			4.12			1		
05/22/19 3:57	432829.8			0.8			2.21			0.84			3.67			1		
05/22/19 3:58	432367.7			0.9			2.03			0.93			3.36			1		
05/22/19 3:59	432906.8			1			1.94			1.02			3.21			1		
05/22/19 4:00	433060.8			0.9			1.75			0.93			2.9			1		
05/22/19 4:01	433368.9			1			1.75			1.02			2.91			1		
05/22/19 4:02	433214.8			0.7			1.66			0.74			2.75			0		
05/22/19 4:03	432675.7			0.6			1.66			0.65			2.75			0		
05/22/19 4:04	432444.7			0.8			1.57			0.83			2.59			0		
05/22/19 4:05	432290.7			0.9			1.57			0.93			2.59			0		
05/22/19 4:06	432444.7			1.1			1.57			1.11			2.59			0		

CT1 SUSD EVENT 2

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
05/24/19 16:50	296742.5			0.8			1.63			0.56			1.86			0		
05/24/19 16:51	296665.5			0.9			1.66			0.64			1.88			0		
05/24/19 16:52	297127.6			0.8			1.66			0.57			1.89			0		
05/24/19 16:53	297050.6			0.7			1.72			0.5			1.96			0		
05/24/19 16:54	296665.5			0.7			1.72			0.5			1.96			0		
05/24/19 16:55	295048.2			0.7			1.72			0.5			1.95			1		
05/24/19 16:56	275948.2			0.9			1.63			0.58			1.73			1		
05/24/19 16:57	252843.4			0.6			2.86			0.33			2.77			1		
05/24/19 16:58	233050.3			0.8			7.33			0.41			6.54			1		
05/24/19 16:59	209175.4			0.6			13.2			0.29			10.57			1		
05/24/19 17:00	184838.3			0.7			17.92			0.29			12.68			1		
05/24/19 17:01	164044			7.4			20.46			2.83			12.84			1		
05/24/19 17:02	146253.3			391			23.02			133.03			12.89			1		
05/24/19 17:03	88953.4			1452.9			23.6			300.5			8.03			1		
05/24/19 17:04	34965.3			0			25.49			146.55			3.41			0		
05/24/19 17:05	34580.2			0			0.3			0			0			0		
05/24/19 17:06	34041.1			0			0.2			0			0			0		
05/24/19 17:07	33501.9			0			0.1			0			0			0		
05/24/19 17:08	33039.9			0			0.1			0			0			0		

CT1 SUSD EVENT 3

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
06/12/19 6:39	0			0			0			0			0			0		
06/12/19 6:40	0			0			0			0			0			0		
06/12/19 6:41	0			0			0			0			0			0		
06/12/19 6:42	0			0			0			0			0			0		
06/12/19 6:43	0			0			0			0			0			0		
06/12/19 6:44	0			-0.8			0			0			0			1		
06/12/19 6:45	0			1			0			0			0			1		
06/12/19 6:46	15480.2			2.9			0.2			0			0			1		
06/12/19 6:47	37429.8			618.6			17.25			53.86			2.47			1		
06/12/19 6:48	53372.1			497.8			18.32			61.73			3.74			1		
06/12/19 6:48	83485.3			309.9			23.88			60.14			7.63			1		
06/12/19 6:50	128924.7			156			33.35			46.71			16.44			1		
06/12/19 6:51	136934.4			64.7			51.47			20.58			26.95			1		
06/12/19 6:52	142864.6			875.5			51.67			290.64			28.23			1		
06/12/19 6:53	155880.3			1926.4			51.31			697.72			30.59			1		
06/12/19 6:54	176982.7			1484.3			54.25			610.37			36.71			1		
06/12/19 6:55	200087.5			469.2			58.2			218.14			43			1		
06/12/19 6:56	224270.5			46.2			55.28			24.06			47.41			1		
06/12/19 6:57	246374.1			4.4			50.94			2.53			47.99			1		
06/12/19 6:58	272636.5			3.3			44.96			2.06			46.88			1		
06/12/19 6:59	294817.2			1.9			30.51			1.33			34.4			1		
06/12/19 7:00	314225.2			1.9			14.92			1.39			17.93			1		
06/12/19 7:01	333787.2			1.5			11.37			1.14			14.51			1		
06/12/19 7:02	344338.4			1.3			10.33			1.04			13.59			1		
06/12/19 7:03	345955.8			1.9			8.81			1.56			11.65			1		
06/12/19 7:04	345955.8			1.4			8.01			1.13			10.6			1		
06/12/19 7:05	346032.8			1.8			7.49			1.49			9.9			1		
06/12/19 7:06	345955.8			2.1			7.15			1.72			9.46			1		
06/12/19 7:07	344954.5			1.6			6.79			1.29			8.96			1		
06/12/19 7:08	344492.4			1.1			6.62			0.86			8.71			1		
06/12/19 7:09	343645.3			1.7			6.44			1.36			8.46			1		
06/12/19 7:10	342875.1			1.6			6.26			1.28			8.2			1		
06/12/19 7:11	342798.1			1.4			6.17			1.14			8.08			1		
06/12/19 7:12	342644.1			1.6			6.08			1.28			7.97			1		
06/12/19 7:13	342567			0.9			6.08			0.72			7.97			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/12/19 7:14	341950.9			0.2			6.08			0.14			7.95			1		
06/12/19 7:15	341257.8			2			6.08			1.58			7.94			1		
06/12/19 7:16	341796.9			0.8			6.08			0.65			7.95			1		
06/12/19 7:17	340641.7			1.4			6.08			1.08			7.92			1		
06/12/19 7:18	340872.7			1.5			6.17			1.15			8.04			1		
06/12/19 7:19	340333.6			0.5			6.17			0.36			8.03			1		
06/12/19 7:20	340641.7			1.3			6.26			1.01			8.15			1		
06/12/19 7:21	340102.5			1.1			6.44			0.88			8.38			1		
06/12/19 7:22	339948.5			0.6			6.54			0.5			8.5			1		
06/12/19 7:23	339948.5			1.1			6.63			0.86			8.61			1		
06/12/19 7:24	339563.4			1.2			6.08			0.93			7.9			1		
06/12/19 7:25	339563.4			0.8			3.99			0.64			5.19			1		
06/12/19 7:26	339486.4			1.5			3			1.15			3.89			1		
06/12/19 7:27	339409.4			1.3			2.81			1			3.65			1		
06/12/19 7:28	339486.4			1.6			2.72			1.29			3.54			1		
06/12/19 7:29	339563.4			1.5			2.63			1.15			3.42			1		
06/12/19 7:30	338947.3			1.2			2.63			0.93			3.41			1		
06/12/19 7:31	339178.3			0.6			2.54			0.5			3.3			1		
06/12/19 7:32	339178.3			2			2.54			1.57			3.3			1		
06/12/19 7:33	339024.3			3.1			2.45			2.43			3.18			1		
06/12/19 7:34	339255.3			1.2			2.27			0.93			2.94			1		
06/12/19 7:35	338870.3			1.6			2.18			1.29			2.82			1		
06/12/19 7:36	338870.3			1.1			2.09			0.86			2.7			1		
06/12/19 7:37	342567			1.5			1.91			1.16			2.5			1		
06/12/19 7:38	360665.8			0.6			1.84			0.54			2.54			1		
06/12/19 7:39	371756.1			1			1.69			0.89			2.4			1		
06/12/19 7:40	375992			0.5			1.62			0.42			2.33			1		
06/12/19 7:41	376993.2			2.1			1.5			1.8			2.16			1		
06/12/19 7:42	376762.1			2.2			1.5			1.97			2.18			1		
06/12/19 7:43	376993.2			0.2			1.5			0.16			2.16			0		
06/12/19 7:44	376762.1			1.2			1.5			1.07			2.16			0		
06/12/19 7:45	377224.2			0.5			1.5			0.41			2.16			0		
06/12/19 7:46	377609.3			0.7			1.5			0.66			2.16			0		
06/12/19 7:47	377455.3			0.9			1.5			0.82			2.16			0		

CT1 SUSD EVENT 4

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/12/19 22:48	327086.8			0.9			1.75			0.7			2.19			0		
06/12/19 22:49	326624.8			0.7			1.75			0.56			2.19			0		
06/12/19 22:50	326778.8			0.6			1.75			0.42			2.19			0		
06/12/19 22:51	320001.4			0.9			1.75			0.69			2.14			0		
06/12/19 22:52	299669.2			0.5			1.72			0.32			1.98			0		
06/12/19 22:53	284651			0.5			1.72			0.36			1.88			1		
06/12/19 22:54	267168.4			1			1.75			0.63			1.79			1		
06/12/19 22:55	244448.7			0.7			2.34			0.37			2.19			1		
06/12/19 22:56	224424.5			1.1			6.29			0.55			5.39			1		
06/12/19 22:57	199856.5			0			9.77			0			7.47			1		
06/12/19 22:58	175211.3			0.3			17.81			0.13			11.93			1		
06/12/19 22:59	153569.8			5.8			20.71			2.06			12.16			1		
06/12/19 23:00	134546.9			364.8			22.02			114.08			11.33			1		
06/12/19 23:01	33733			1448.4			23.43			113.47			3.02			1		
06/12/19 23:02	0			0			24.29			0			0			0		
06/12/19 23:03	0			0			0.3			0			0			0		
06/12/19 23:04	0			0			0.2			0			0			0		
06/12/19 23:05	0			0			0.2			0			0			0		
06/12/19 23:06	0			0			0.1			0			0			0		

CT1 SUSD EVENT 5

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
06/18/19 14:40	38199.9			0			0			0			0			0		
06/18/19 14:41	38122.9			0			0			0			0			0		
06/18/19 14:42	38045.9			0			0			0			0			0		
06/18/19 14:43	37891.9			0			0			0			0			0		
06/18/19 14:44	37891.9			0			0			0			0			0		
06/18/19 14:45	41203.5			0.4			0			0			0			1		
06/18/19 14:46	40972.5			0			0			0			0			0		
06/18/19 14:47	40664.4			0			0			0			0			0		
06/18/19 14:48	40433.4			0			0			0			0			0		
06/18/19 14:49	40587.4			0			0			0			0			0		
06/18/19 14:50	40510.4			0			0			0			0			0		

CT1 SUSD EVENT 6

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
06/18/19 14:40	38199.9			0			0			0			0			0		
06/18/19 14:41	38122.9			0			0			0			0			0		
06/18/19 14:42	38045.9			0			0			0			0			0		
06/18/19 14:43	37891.9			0			0			0			0			0		
06/18/19 14:44	37891.9			0			0			0			0			0		
06/18/19 14:45	41203.5			0.4			0			0			0			1		
06/18/19 14:46	40972.5			0			0			0			0			0		
06/18/19 14:47	40664.4			0			0			0			0			0		
06/18/19 14:48	40433.4			0			0			0			0			0		
06/18/19 14:49	40587.4			0			0			0			0			0		
06/18/19 14:50	40510.4			0			0			0			0			0		

Startup / Shutdown Events

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:23 **Location:** Roseville, CA

Unit Offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
04/01/2019 00:00	05/22/2019 01:00	1226
05/24/2019 18:00	06/11/2019 12:00	427
06/11/2019 21:00	06/12/2019 02:00	6
06/14/2019 00:00	06/18/2019 13:00	110
06/18/2019 22:00	06/30/2019 23:00	290

Startup / Shutdown Events

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:23 **Location:** Roseville, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,184.00 Hour(s)
Total Offline:	2,059.00 Hour(s)
Offline Percentage:	94.28 %
Total Online:	125.00 Hour(s)
Online Percentage:	5.72 %

Startup / Shutdown Events

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:23 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	05/22/2019 02:45	05/22/2019 02:57	Cold Startup	13
2	05/22/2019 02:57	05/22/2019 02:57	Shutdown	1
3	05/22/2019 03:44	05/22/2019 04:41	Cold Startup	58
4	05/24/2019 16:56	05/24/2019 17:05	Shutdown	10
5	06/11/2019 13:45	06/11/2019 15:16	Cold Startup	92
6	06/11/2019 20:01	06/11/2019 20:09	Shutdown	9
7	06/12/2019 03:43	06/12/2019 04:35	Cold Startup	53
8	06/13/2019 22:56	06/13/2019 23:04	Shutdown	9
9	06/18/2019 14:56	06/18/2019 15:41	Cold Startup	46
10	06/18/2019 20:57	06/18/2019 21:05	Shutdown	9

Startup / Shutdown Events

CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/10/2019 13:23 **Location:** Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	5	262	3.72
Warm Startup	0		0.00
Shutdown	5	38	0.54
Total Process Events:	10	300	4.25

Total Report Time:	2,183.98 Hour(s)
Total Operating Time:	117.53 Hour(s)
Total Startup Time:	262 Minute(s)
Total Shutdown Time:	38 Minute(s)
Total Startup/Shutdown Time:	300 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	4.25 %

CT2 SUSD EVENT 1

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
05/22/19 2:40	0			0			-0.1			0			0			0		
05/22/19 2:41	0			0			-0.1			0			0			0		
05/22/19 2:42	0			0			-0.1			0			0			0		
05/22/19 2:43	6623.4			0			-0.1			0			0			0		
05/22/19 2:44	0			0			-0.1			0			0			0		
05/22/19 2:45	22334.6			0.3			-0.1			0			0			1		
05/22/19 2:46	40125.3			1			0			0			0			1		
05/22/19 2:47	52062.8			579.2			15.73			70.14			3.14			1		
05/22/19 2:48	63923.3			526.7			17.39			78.28			4.25			1		
05/22/19 2:49	88491.4			376.4			23.6			77.44			7.99			1		
05/22/19 2:50	135240			233.1			25.75			73.3			13.33			1		
05/22/19 2:51	152029.5			105.5			44.14			37.33			25.69			1		
05/22/19 2:52	161425.5			519			44.07			194.83			27.22			1		
05/22/19 2:53	179370.2			1957.1			33.93			816.62			23.3			1		
05/22/19 2:54	200703.6			1327.3			39.01			619.49			29.96			1		
05/22/19 2:55	225658			363.9			46.91			191.85			40.7			1		
05/22/19 2:56	251149.1			27.4			49.08			15.98			47.18			1		
05/22/19 2:57	23797.9			3.4			54.69			0.19			4.98			1		
05/22/19 2:58	0			0			77.36			0			0			0		
05/22/19 2:59	0			0			9.1			0			0			0		
05/22/19 3:00	0			0			11.8			0			0			0		
05/22/19 3:01	0			0			15.5			0			0			0		
05/22/19 3:02	0			0			18.4			0			0			0		

CT2 SUSD EVENT 2

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/22/19 2:40	0			0			-0.1			0			0			0		
05/22/19 2:41	0			0			-0.1			0			0			0		
05/22/19 2:42	0			0			-0.1			0			0			0		
05/22/19 2:43	6623.4			0			-0.1			0			0			0		
05/22/19 2:44	0			0			-0.1			0			0			0		
05/22/19 2:45	22334.6			0.3			-0.1			0			0			1		
05/22/19 2:46	40125.3			1			0			0			0			1		
05/22/19 2:47	52062.8			579.2			15.73			70.14			3.14			1		
05/22/19 2:48	63923.3			526.7			17.39			78.28			4.25			1		
05/22/19 2:49	88491.4			376.4			23.6			77.44			7.99			1		
05/22/19 2:50	135240			233.1			25.75			73.3			13.33			1		
05/22/19 2:51	152029.5			106.5			44.14			37.33			25.69			1		
05/22/19 2:52	161425.5			519			44.07			194.83			27.22			1		
05/22/19 2:53	179370.2			1957.1			33.93			816.62			23.3			1		
05/22/19 2:54	200703.6			1327.3			39.01			619.49			29.96			1		
05/22/19 2:55	229656			363.9			46.91			191.85			40.7			1		
05/22/19 2:56	251149.1			27.4			49.08			15.98			47.18			1		
05/22/19 2:57	23797.9			3.4			54.69			0.19			4.98			1		
05/22/19 2:58	0			0			77.38			0			0			0		
05/22/19 2:59	0			0			9.1			0			0			0		
05/22/19 3:00	0			0			11.8			0			0			0		
05/22/19 3:01	0			0			15.5			0			0			0		
05/22/19 3:02	0			0			18.4			0			0			0		

CT2 SUSD EVENT 3

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
05/22/19 3:39	0			0			1.3			0			0			0		
05/22/19 3:40	0			0			1.6			0			0			0		
05/22/19 3:41	0			0			1.7			0			0			0		
05/22/19 3:42	0			0			1.9			0			0			0		
05/22/19 3:43	0			0			2.3			0			0			0		
05/22/19 3:44	14248			0.6			2.5			0			0			1		
05/22/19 3:45	35196.3			1.4			2.5			0			0			1		
05/22/19 3:46	47749.9			78.2			54.58			8.68			9.97			1		
05/22/19 3:47	59841.4			492.5			22.36			68.57			5.12			1		
05/22/19 3:48	77632.1			408			27.02			73.71			8.03			1		
05/22/19 3:49	122070.3			281.4			29.5			79.88			13.78			1		
05/22/19 3:50	150720.3			138.8			42.01			48.64			24.23			1		
05/22/19 3:51	161579.5			225.7			51.58			84.84			31.9			1		
05/22/19 3:52	180063.3			1828.4			48.86			785.78			33.68			1		
05/22/19 3:53	204531.4			1347.5			47.04			841.27			36.84			1		
05/22/19 3:54	228968.5			333.1			49.07			177.4			43.01			1		
05/22/19 3:55	253305.5			28.7			50.46			16.94			48.93			1		
05/22/19 3:56	275409.1			3.8			53.32			2.42			56.22			1		
05/22/19 3:57	304598.2			2.7			48.73			1.95			56.81			1		
05/22/19 3:58	328704.2			2.6			33			1.97			41.52			1		
05/22/19 3:59	349575.5			2.6			18.65			2.12			24.96			1		
05/22/19 4:00	368444.4			2.7			14.84			2.3			20.92			1		
05/22/19 4:01	388391.6			2.5			11.97			2.27			17.8			1		
05/22/19 4:02	407876.6			2.2			10.1			2.12			15.77			1		
05/22/19 4:03	433676.9			2			9.35			2.01			15.52			1		
05/22/19 4:04	457937			1.8			9.31			1.87			16.32			1		
05/22/19 4:05	470644.6			1.6			10.05			1.72			18.1			1		
05/22/19 4:06	467795			1.5			10.69			1.6			19.15			1		
05/22/19 4:07	467486.9			1.5			10.33			1.6			18.47			1		
05/22/19 4:08	467795			1.4			10.23			1.5			18.32			1		
05/22/19 4:09	466408.7			1.4			10.23			1.5			18.27			1		
05/22/19 4:10	467795			1.3			10.33			1.4			18.49			1		
05/22/19 4:11	466408.7			1.3			10.51			1.4			18.76			1		
05/22/19 4:12	464329.3			1.3			10.6			1.39			18.84			1		
05/22/19 4:13	463097			1.3			10.69			1.39			18.96			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/22/19 4:14	465484.5			1.2			10.88			1.3			19.38			1		
05/22/19 4:15	465022.4			1.2			11.06			1.3			19.69			1		
05/22/19 4:16	464483.3			1.2			11.34			1.29			20.16			1		
05/22/19 4:17	465407.5			1.2			11.25			1.3			20.04			1		
05/22/19 4:18	463790.2			1.2			7.28			1.29			12.93			1		
05/22/19 4:19	465715.6			1.2			6.27			1.3			11.18			1		
05/22/19 4:20	464714.4			1.2			5.81			1.3			10.33			1		
05/22/19 4:21	462249.9			1.2			5.44			1.29			9.62			1		
05/22/19 4:22	463251.1			1.2			4.98			1.29			8.83			1		
05/22/19 4:23	464560.3			1.2			4.79			1.29			8.52			1		
05/22/19 4:24	462789			1.2			4.7			1.29			8.33			1		
05/22/19 4:25	463559.1			1.1			4.52			1.19			8.01			1		
05/22/19 4:26	463790.2			1.1			4.43			1.19			7.86			1		
05/22/19 4:27	463328.1			1.2			4.33			1.29			7.68			1		
05/22/19 4:28	463328.1			1.2			4.15			1.29			7.36			1		
05/22/19 4:29	464888.4			1.2			4.06			1.3			7.22			1		
05/22/19 4:30	464483.3			1.2			3.78			1.29			6.72			1		
05/22/19 4:31	465638.6			1.3			3.32			1.4			5.92			1		
05/22/19 4:32	464408.3			1.4			2.86			1.49			5.08			1		
05/22/19 4:33	463948.6			1.5			2.67			1.6			4.77			1		
05/22/19 4:34	463944.2			1.4			2.4			1.49			4.26			1		
05/22/19 4:35	464483.3			1.4			2.3			1.49			4.1			1		
05/22/19 4:36	465638.6			1.4			2.21			1.5			3.94			1		
05/22/19 4:37	463636.2			1.3			2.12			1.39			3.76			1		
05/22/19 4:38	464021.2			1.4			2.03			1.49			3.6			1		
05/22/19 4:39	465792.6			1.5			2.03			1.6			3.62			1		
05/22/19 4:40	465099.5			1.5			1.94			1.6			3.45			1		
05/22/19 4:41	465484.5			1.4			1.94			1.5			3.45			1		
05/22/19 4:42	466793.8			1.3			1.84			1.4			3.29			0		
05/22/19 4:43	465792.6			1.2			1.75			1.3			3.12			0		
05/22/19 4:44	465022.4			1.2			1.75			1.3			3.12			0		
05/22/19 4:45	467795			1.1			1.66			1.2			2.97			0		
05/22/19 4:46	468257.1			1.1			1.66			1.2			2.97			0		

CT2 SUSD EVENT 4

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
05/24/19 16:51	312992.9			0.8	X		1.66			0.6	X		1.99			0		
05/24/19 16:52	313378			0.8	X		1.66			0.6	X		1.99			0		
05/24/19 16:53	314148.2			0.8	X		1.66			0.61	X		2			0		
05/24/19 16:54	314148.2			0.8	X		1.57			0.61	X		1.88			0		
05/24/19 16:55	312463.8			0.8	X		1.66			0.6	X		1.98			0		
05/24/19 16:56	312992.9			0.8	X		1.66			0.6	X		1.99			1		
05/24/19 16:57	296665.5			0.9	X		1.75			0.64	X		1.99			1		
05/24/19 16:58	272328.5			0.9	X		2.72			0.59	X		2.83			1		
05/24/19 16:59	252689.4			0.9	X		6.38			0.5	X		6.17			1		
05/24/19 17:00	228121.3			0.8	X		13.4			0.42	X		11.7			1		
05/24/19 17:01	199933.5			0.8	X		19.12			0.36	X		14.63			1		
05/24/19 17:02	175365.4			4.2	X		21.63			1.7	X		14.52			1		
05/24/19 17:03	166342.4			60.4	X		23.88			21.96	X		14.29			1		
05/24/19 17:04	139630			68.6	X		25.51			22.27	X		13.64			1		
05/24/19 17:05	0			79.3	X		28.21			0	X		0			1		
05/24/19 17:06	0			0	X		51.63			0	X		0			0		
05/24/19 17:07	0			0	X		0.2			0	X		0			0		
05/24/19 17:08	0			0	X		0.1			0	X		0			0		
05/24/19 17:09	0			0	X		0.1			0	X		0			0		
05/24/19 17:10	0			0	X		0.1			0	X		0			0		

CT2 SUSD EVENT 5

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
06/11/19 13:40	0			0			-0.1			0			0			0		
06/11/19 13:41	0			0			-0.1			0			0			0		
06/11/19 13:42	0			0			-0.1			0			0			0		
06/11/19 13:43	0			0			-0.1			0			0			0		
06/11/19 13:44	0			0			-0.1			0			0			0		
06/11/19 13:45	23335.8			0.3			-0.1			0			0			1		
06/11/19 13:46	33347.9			1.3			0.1			0			0			1		
06/11/19 13:47	46748.7			7			28.43			0.76			5.08			1		
06/11/19 13:48	58070			364.1			21.63			49.15			4.81			1		
06/11/19 13:49	73550.3			226.7			26.69			38.72			7.5			1		
06/11/19 13:50	119451.8			116.2			35.14			32.25			16.05			1		
06/11/19 13:51	146715.4			37.1			52.26			12.64			29.32			1		
06/11/19 13:52	148563.8			14.9			62.64			5.15			35.59			1		
06/11/19 13:53	161733.5			1396.5			55.6			524.86			34.39			1		
06/11/19 13:54	182527.9			1151			56.13			488.24			39.19			1		
06/11/19 13:55	208328.2			313			59.45			151.48			47.35			1		
06/11/19 13:56	235129.8			23.2			61.23			12.68			55.06			1		
06/11/19 13:57	259312.8			2.3			63.99			1.37			63.46			1		
06/11/19 13:58	286807.5			1.7			60.93			1.15			66.83			1		
06/11/19 13:59	308371.9			1.7			34.93			1.21			41.19			1		
06/11/19 14:00	314456.2			1.8			14.38			1.35			17.29			1		
06/11/19 14:01	313532			1.8			12.16			1.32			14.58			1		
06/11/19 14:02	311991.7			1.7			11.71			1.25			13.97			1		
06/11/19 14:03	314071.1			1.5			11.35			1.13			13.63			1		
06/11/19 14:04	319231.2			1.4			10.8			1.01			13.19			1		
06/11/19 14:05	320155.4			1.3			10.26			0.95			12.56			1		
06/11/19 14:06	320386.4			1.3			10.17			0.95			12.46			1		
06/11/19 14:07	320540.5			1.3			9.89			0.95			12.13			1		
06/11/19 14:08	319000.2			1.2			9.62			0.87			11.74			1		
06/11/19 14:09	317690.9			1.2			9.35			0.87			11.36			1		
06/11/19 14:10	317382.8			1.1			9.26			0.8			11.24			1		
06/11/19 14:11	316381.6			1.1			9.26			0.8			11.2			1		
06/11/19 14:12	317998.9			1.1			9.17			0.8			11.15			1		
06/11/19 14:13	317690.9			1.1			9.17			0.8			11.14			1		
06/11/19 14:14	317767.9			1			9.17			0.74			11.14			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/11/19 14:15	317998.9			1			9.31			0.75			11.32			1		
06/11/19 14:16	317305.8			0.9			9.31			0.68			11.3			1		
06/11/19 14:17	316381.6			0.9			9.4			0.68			11.38			1		
06/11/19 14:18	317382.8			0.9			9.5			0.68			11.52			1		
06/11/19 14:19	316458.6			0.9			9.59			0.68			11.6			1		
06/11/19 14:20	316381.6			0.9			9.68			0.68			11.71			1		
06/11/19 14:21	316612.7			0.9			9.77			0.68			11.83			1		
06/11/19 14:22	315996.5			0.9			9.96			0.68			12.03			1		
06/11/19 14:23	315534.4			0.9			8.85			0.68			10.68			1		
06/11/19 14:24	315534.4			0.8			5.72			0.61			6.9			1		
06/11/19 14:25	313763.1			0.8			5.35			0.6			6.42			1		
06/11/19 14:26	315226.4			0.8			5.07			0.61			6.11			1		
06/11/19 14:27	315072.3			0.9			4.79			0.67			5.77			1		
06/11/19 14:28	315149.3			0.9			4.52			0.67			5.44			1		
06/11/19 14:29	313763.1			0.9			4.33			0.67			5.2			1		
06/11/19 14:30	314764.3			0.9			4.24			0.67			5.1			1		
06/11/19 14:31	315457.4			0.9			4.06			0.68			4.89			1		
06/11/19 14:32	314841.3			0.9			3.96			0.67			4.77			1		
06/11/19 14:33	313994.1			0.9			3.87			0.67			4.65			1		
06/11/19 14:34	314379.2			0.9			3.78			0.67			4.54			1		
06/11/19 14:35	313089.9			0.8			3.69			0.6			4.42			1		
06/11/19 14:36	314148.2			0.8			3.6			0.61			4.32			1		
06/11/19 14:37	315457.4			0.8			3.5			0.61			4.23			1		
06/11/19 14:38	315226.4			0.8			3.41			0.61			4.11			1		
06/11/19 14:39	314533.2			0.8			3.32			0.61			3.99			1		
06/11/19 14:40	314995.3			0.9			3.23			0.67			3.89			1		
06/11/19 14:41	314687.3			0.8			3.23			0.61			3.88			1		
06/11/19 14:42	315457.4			0.9			3.23			0.68			3.89			1		
06/11/19 14:43	314225.2			0.9			3.23			0.67			3.88			1		
06/11/19 14:44	314764.3			0.9			3.13			0.67			3.77			1		
06/11/19 14:45	313301			0.8			3.13			0.6			3.76			1		
06/11/19 14:46	314071.1			0.8			3.13			0.61			3.76			1		
06/11/19 14:47	314302.2			0.8			3.23			0.61			3.88			1		
06/11/19 14:48	314533.2			0.8			3.41			0.61			4.1			1		
06/11/19 14:49	314071.1			0.9			3.32			0.67			3.99			1		
06/11/19 14:50	313840.1			0.9			3.23			0.67			3.87			1		
06/11/19 14:51	313301			0.8			3.13			0.6			3.76			1		
06/11/19 14:52	313917.1			0.8			3.04			0.61			3.65			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/11/19 14:53	313917.1			0.8			3.04			0.61			3.65			1		
06/11/19 14:54	313686.1			0.8			3.04			0.6			3.65			1		
06/11/19 14:55	313378			0.8			3.04			0.6			3.65			1		
06/11/19 14:56	313224			0.8			3.04			0.6			3.64			1		
06/11/19 14:57	313532			0.8			2.95			0.6			3.54			1		
06/11/19 14:58	314533.2			0.9			2.95			0.67			3.55			1		
06/11/19 14:59	313069.9			0.8			2.86			0.6			3.42			1		
06/11/19 15:00	313532			0.8			2.86			0.6			3.43			1		
06/11/19 15:01	313532			0.9			2.86			0.67			3.43			1		
06/11/19 15:02	314148.2			0.9			2.77			0.67			3.32			1		
06/11/19 15:03	313069.9			0.9			2.86			0.67			3.42			1		
06/11/19 15:04	313224			0.8			2.77			0.6			3.31			1		
06/11/19 15:05	313455			0.8			2.77			0.6			3.32			1		
06/11/19 15:06	314533.2			0.8			2.77			0.61			3.33			1		
06/11/19 15:07	313455			0.9			2.67			0.67			3.2			1		
06/11/19 15:08	314225.2			0.9			2.67			0.67			3.21			1		
06/11/19 15:09	313148.9			0.8			2.67			0.6			3.2			1		
06/11/19 15:10	313763.1			0.8			2.67			0.6			3.21			1		
06/11/19 15:11	312299.8			0.8			2.58			0.6			3.06			1		
06/11/19 15:12	312530.8			0.8			2.3			0.6			2.75			1		
06/11/19 15:13	314841.3			0.8			2.03			0.61			2.44			1		
06/11/19 15:14	313146.9			0.8			1.75			0.6			2.1			1		
06/11/19 15:15	312376.8			0.8			1.57			0.6			1.67			1		
06/11/19 15:16	313763.1			0.8			1.38			0.6			1.66			1		
06/11/19 15:17	314764.3			0.8			1.2			0.61			1.44			0		
06/11/19 15:18	324699.3			0.8			1.2			0.63			1.49			0		
06/11/19 15:19	344954.5			0.9			1.11			0.74			1.46			0		
06/11/19 15:20	365594.8			0.9			1.09			0.77			1.52			0		
06/11/19 15:21	386312.1			0.9			1.01			0.83			1.5			0		

CT2 SUSD EVENT 6

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/11/19 19:56	374066.6			1			1.66			0.88			2.37			0		
06/11/19 19:57	348651.3			1			1.54			0.81			2.06			0		
06/11/19 19:58	327780			1.1			1.52			0.82			1.9			0		
06/11/19 19:59	325084.4			1.1			1.43			0.81			1.78			0		
06/11/19 20:00	309912.3			1.1			1.45			0.78			1.72			0		
06/11/19 20:01	302749.8			1.1			1.57			0.78			1.81			1		
06/11/19 20:02	284959.1			1			1.5			0.68			1.63			1		
06/11/19 20:03	261469.2			1			2.47			0.58			2.47			1		
06/11/19 20:04	240906			0.9			6.49			0.5			5.98			1		
06/11/19 20:05	214181.4			0.8			14.04			0.4			11.5			1		
06/11/19 20:06	189382.3			0.8			18.7			0.34			13.55			1		
06/11/19 20:07	165892.4			4.8			21.47			1.84			13.62			1		
06/11/19 20:08	145021.1			357.3			24.9			120.37			13.8			1		
06/11/19 20:09	73011.1			1453.9			27.85			248.7			7.72			1		
06/11/19 20:10	0			0			30.62			0			0			0		
06/11/19 20:11	0			0			0.2			0			0			0		
06/11/19 20:12	0			0			0.1			0			0			0		
06/11/19 20:13	0			0			0.1			0			0			0		
06/11/19 20:14	0			0			0.1			0			0			0		

CT2 SUSD EVENT 7

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/12/19 3:38	0			0			-0.1			0			0			0		
06/12/19 3:39	0			0			-0.1			0			0			0		
06/12/19 3:40	0			0			-0.1			0			0			0		
06/12/19 3:41	0			0			-0.1			0			0			0		
06/12/19 3:42	0			0			-0.1			0			0			0		
06/12/19 3:43	3311.7			0.3			-0.1			0			0			1		
06/12/19 3:44	26724.5			0.3			0			0			0			1		
06/12/19 3:45	39509.2			94.4			17.7			8.66			2.67			1		
06/12/19 3:46	52293.8			475.3			15.12			57.77			3.02			1		
06/12/19 3:47	63846.2			403.3			16.52			59.85			4.03			1		
06/12/19 3:48	88722.4			237.7			21.35			49			7.24			1		
06/12/19 3:49	136395.3			129.3			23.6			40.98			12.31			1		
06/12/19 3:50	148486.8			47.2			41.91			16.28			23.79			1		
06/12/19 3:51	158961			554.1			41.84			204.64			25.43			1		
06/12/19 3:52	179293.2			1753.9			41.64			730.64			28.68			1		
06/12/19 3:53	204708.5			765.9			43.01			364.32			33.67			1		
06/12/19 3:54	228352.4			112.2			44.59			59.54			38.93			1		
06/12/19 3:55	253767.6			6.3			46.12			3.69			44.75			1		
06/12/19 3:56	279645			2.1			48.27			1.39			51.63			1		
06/12/19 3:57	305907.4			1.8			38.79			1.31			45.37			1		
06/12/19 3:58	321618.7			1.7			21.9			1.27			26.93			1		
06/12/19 3:59	336097.7			1.8			12.25			1.4			15.74			1		
06/12/19 4:00	338023.1			1.7			12.24			1.31			15.82			1		
06/12/19 4:01	336482.8			1.6			11.98			1.24			15.41			1		
06/12/19 4:02	336174.7			1.6			11.27			1.24			14.49			1		
06/12/19 4:03	334480.4			1.5			11			1.18			14.06			1		
06/12/19 4:04	340949.7			1.4			10.73			1.13			13.99			1		
06/12/19 4:05	358201.3			1.3			10.46			1.12			14.33			1		
06/12/19 4:06	378225.4			1.3			9.3			1.1			13.45			1		
06/12/19 4:07	401099.2			1.2			8.62			1.1			13.22			1		
06/12/19 4:08	424743.1			1.1			8.6			1.11			14.3			1		
06/12/19 4:09	440685.4			1			8.99			1.05			15.15			1		
06/12/19 4:10	437912.8			1			10.68			1.05			17.88			1		
06/12/19 4:11	436141.4			1			10.49			1.04			17.49			1		
06/12/19 4:12	439299.1			1			10.49			1.05			17.62			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/12/19 4:13	440916.4			1			10.11			1.06			17.05			1		
06/12/19 4:14	445460.4			1			7.96			1.07			13.56			1		
06/12/19 4:15	446230.5			1			5.15			1.07			8.79			1		
06/12/19 4:16	446923.7			1			4.59			1.07			7.84			1		
06/12/19 4:17	447616.8			1			3.93			1.07			6.73			1		
06/12/19 4:18	446153.5			1			3.84			1.07			6.55			1		
06/12/19 4:19	447770.9			1			3.56			1.07			6.09			1		
06/12/19 4:20	447770.9			1			3.37			1.07			5.77			1		
06/12/19 4:21	447616.8			1			3.18			1.07			5.45			1		
06/12/19 4:22	446695.1			1			3.09			1.07			5.3			1		
06/12/19 4:23	448387			1			2.9			1.07			4.96			1		
06/12/19 4:24	448078.9			1			2.81			1.07			4.81			1		
06/12/19 4:25	447693.9			1			2.72			1.07			4.65			1		
06/12/19 4:26	448772.1			1			2.62			1.07			4.5			1		
06/12/19 4:27	449080.1			1			2.62			1.07			4.5			1		
06/12/19 4:28	448078.9			1.1			2.72			1.17			4.65			1		
06/12/19 4:29	449927.3			1.1			2.72			1.17			4.67			1		
06/12/19 4:30	449157.2			1.1			2.49			1.15			4.27			1		
06/12/19 4:31	449388.2			1.1			2.34			1.17			4.02			1		
06/12/19 4:32	450543.4			1.1			2.15			1.18			3.71			1		
06/12/19 4:33	447847.9			1.1			2.06			1.17			3.53			1		
06/12/19 4:34	451467.6			1.1			1.97			1.18			3.4			1		
06/12/19 4:35	449311.2			1.1			1.75			1.15			3.01			1		
06/12/19 4:36	449311.2			1.1			1.66			1.15			2.85			0		
06/12/19 4:37	449003.1			1.1			1.57			1.15			2.69			0		
06/12/19 4:38	450235.4			1.1			1.48			1.16			2.54			0		
06/12/19 4:39	449619.3			1.1			1.38			1.16			2.38			0		
06/12/19 4:40	449773.3			1.1			1.38			1.16			2.38			0		

CT2 SUSD EVENT 8

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/13/19 22:51	305214.3			1.1			1.57			0.78			1.83			0		
06/13/19 22:52	305830.4			1			1.57			0.72			1.83			0		
06/13/19 22:53	303828			0.9			1.66			0.65			1.93			0		
06/13/19 22:54	305964.5			0.9			1.66			0.66			1.94			0		
06/13/19 22:55	305753.4			0.9			1.66			0.65			1.94			0		
06/13/19 22:56	303365.9			0.9			1.75			0.65			2.03			1		
06/13/19 22:57	282417.6			0.9			1.94			0.61			2.09			1		
06/13/19 22:58	260622			0.9			4.03			0.57			4.01			1		
06/13/19 22:59	239057.6			0.9			7.77			0.49			7.1			1		
06/13/19 23:00	213642.3			0.7			16.23			0.37			13.26			1		
06/13/19 23:01	186609.7			2.5			18.86			1.1			13.46			1		
06/13/19 23:02	164275.1			135.4			21.59			51.69			13.56			1		
06/13/19 23:03	144790			959.7			23.6			322.89			13.07			1		
06/13/19 23:04	61920.6			1860.6			26.03			287.8			6.17			1		
06/13/19 23:05	0			0			29.85			0			0			0		
06/13/19 23:06	0			0			0.1			0			0			0		
06/13/19 23:07	0			0			0.1			0			0			0		
06/13/19 23:08	0			0			0.1			0			0			0		
06/13/19 23:09	0			0			0.1			0			0			0		

CT2 SUSD EVENT 9

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
06/18/19 14:51	0			0			-0.1			0			0			0		
06/18/19 14:52	0			0			-0.1			0			0			0		
06/18/19 14:53	0			0			-0.1			0			0			0		
06/18/19 14:54	0			0			-0.1			0			0			0		
06/18/19 14:55	0			0			-0.1			0			0			0		
06/18/19 14:56	25030.2			0.3			-0.1			0			0			1		
06/18/19 14:57	36351.5			1.2			0.1			0			0			1		
06/18/19 14:58	48212			454.3			20.16			50.85			3.71			1		
06/18/19 14:59	60226.5			361.7			20.06			50.6			4.62			1		
06/18/19 15:00	83793.4			191.5			24.4			37.29			7.82			1		
06/18/19 15:01	131081.2			102.6			32.58			31.26			16.33			1		
06/18/19 15:02	144559			31.9			50.05			10.73			27.67			1		
06/18/19 15:03	151182.4			14.4			50.32			5.06			29.09			1		
06/18/19 15:04	169050.1			1613.6			41.48			633.89			26.82			1		
06/18/19 15:05	193541.1			840.6			54.58			378.02			40.39			1		
06/18/19 15:06	219880.6			113.2			63.21			57.84			53.14			1		
06/18/19 15:07	244371.7			6.5			65.15			3.7			60.89			1		
06/18/19 15:08	269941			1.9			69.27			1.16			71.5			1		
06/18/19 15:09	297656.7			1.8			56.35			1.22			64.14			1		
06/18/19 15:10	319385.3			1.8			24.8			1.37			30.28			1		
06/18/19 15:11	341257.8			1.9			16.25			1.51			21.2			1		
06/18/19 15:12	354119.4			1.9			15.29			1.54			20.7			1		
06/18/19 15:13	371217			1.9			13.34			1.64			18.94			1		
06/18/19 15:14	380535.9			1.8			12.45			1.55			18.11			1		
06/18/19 15:15	384771.8			1.6			11.14			1.42			16.4			1		
06/18/19 15:16	386235.1			1.5			11.14			1.34			16.46			1		
06/18/19 15:17	385156.9			1.4			10.42			1.24			15.34			1		
06/18/19 15:18	384001.6			1.4			10.02			1.25			14.71			1		
06/18/19 15:19	392088.3			1.3			9.18			1.19			13.76			1		
06/18/19 15:20	408954.8			1.2			7.33			1.18			11.46			1		
06/18/19 15:21	419506			1.1			7.04			1.11			11.3			1		
06/18/19 15:22	428208.8			1			7.71			1.04			12.62			1		
06/18/19 15:23	436757.6			1			7.77			1.05			12.98			1		
06/18/19 15:24	437912.8			1			8.62			1.05			14.43			1		
06/18/19 15:25	435371.3			1			9.08			1.04			15.12			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
06/18/19 15:26	435756.4			1			8.71			1.04			14.51			1		
06/18/19 15:27	436218.5			1			8.52			1.04			14.22			1		
06/18/19 15:28	437373.7			0.9			8.71			0.95			14.57			1		
06/18/19 15:29	437450.7			0.9			8.8			0.95			14.73			1		
06/18/19 15:30	438297.9			0.9			8.99			0.95			15.07			1		
06/18/19 15:31	438760			0.9			9.27			0.95			15.55			1		
06/18/19 15:32	437835.8			0.9			9.37			0.95			15.68			1		
06/18/19 15:33	438683			0.8			9.37			0.86			15.71			1		
06/18/19 15:34	438528.9			0.9			5.34			0.95			8.95			1		
06/18/19 15:35	438220.9			0.9			3			0.95			5.02			1		
06/18/19 15:36	438066.8			0.9			2.62			0.95			4.39			1		
06/18/19 15:37	439838.2			0.9			2.34			0.96			3.94			1		
06/18/19 15:38	438914			0.9			2.06			0.96			3.46			1		
06/18/19 15:39	439145.1			0.9			1.87			0.96			3.15			1		
06/18/19 15:40	439453.1			0.9			1.69			0.96			2.83			1		
06/18/19 15:41	439684.2			0.9			1.59			0.96			2.68			1		
06/18/19 15:42	440377.3			0.9			1.5			0.96			2.52			0		
06/18/19 15:43	439530.2			0.9			1.4			0.96			2.36			0		
06/18/19 15:44	439222.1			1			1.31			1.05			2.2			0		
06/18/19 15:45	439376.1			0.9			1.22			0.96			2.05			0		
06/18/19 15:46	439838.2			0.9			1.22			0.96			2.05			0		

CT2 SUSD EVENT 10

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/18/19 20:52	303982			0.9			1.69			0.66			1.96			0		
06/18/19 20:53	303597			0.8			1.59			0.59			1.85			0		
06/18/19 20:54	302826.8			1			1.52			0.67			1.76			0		
06/18/19 20:55	304675.2			1			1.52			0.67			1.77			0		
06/18/19 20:56	304598.2			1			1.52			0.67			1.77			0		
06/18/19 20:57	305060.3			1			1.52			0.67			1.78			1		
06/18/19 20:58	291505.5			0.9			1.5			0.63			1.67			1		
06/18/19 20:59	268400.7			1			1.81			0.59			1.86			1		
06/18/19 21:00	246451.1			0.9			4.72			0.51			4.45			1		
06/18/19 21:01	222653.2			0.8			8.75			0.42			7.45			1		
06/18/19 21:02	194234.3			0.8			18.25			0.35			13.55			1		
06/18/19 21:03	170821.4			3.1			21.14			1.22			13.81			1		
06/18/19 21:04	149950.1			269			23.32			93.7			13.37			1		
06/18/19 21:05	112289.3			1264.7			24.58			330.1			10.56			1		
06/18/19 21:06	0			0			28.28			0			0			0		
06/18/19 21:07	0			0			29.5			0			0			0		
06/18/19 21:08	0			0			0.1			0			0			0		
06/18/19 21:09	0			0			0.1			0			0			0		
06/18/19 21:10	0			0			0			0			0			0		

ATTACHMENT 16

AQ-57

AQ-57 The emissions rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown or excursions shall not exceed the following:

Combustion Turbine emissions limitations per Turbine excluding Startup and Shutdown	
Pollutant	**Pounds/Hour**
CO	6.2 3hr rolling
NOX	5.1 1 hour rolling
PM-10	4.7
SOX	1.0
VOC	1.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

AQ-57 If the Alstom GX100 turbines are selected for the Project, emission rates from each gas turbine and heat recovery steam generator exhaust, except during startup and/or shutdown, or excursions shall not exceed the following:

Alstom GTX100 - COMBUSTION TURBINE EMISSION LIMITATIONS PER TURBINE EXCLUDING STARTUP AND SHUTDOWN	
POLLUTANT	POUNDS/HOUR
Carbon Monoxide (CO)	6.2 (three-hour rolling average)
Nitrogen Oxides (NOx)	5.1 (one-hour average)
PM10	4.7
Sulfur Oxides (SOx)	1.0
Volatile Organic Compounds (VOCs)	1.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emission limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

AQ57 CT1 HOURLY EMISSIONS

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/01/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
04/02/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/04/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
04/05/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/07/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
04/08/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/10/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/11/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/13/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/15/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/16/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/18/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/19/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/21/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/23/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/24/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/26/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
04/27/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
04/29/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/30/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/02/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/04/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/05/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/07/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/08/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/10/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/12/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/13/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/15/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/16/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
05/18/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/19/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/21/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/22/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/22/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/22/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/22/19 3:00	0			0			0	X		0.43			0.21258			0.71		
05/22/19 4:00	1			1.6			0	X		0.54			0.27006			0.9		
05/22/19 5:00	0.9			1.7			2			0.54			0.2709			0.9		
05/22/19 6:00	0.9			1.7			2			0.54			0.26922			0.9		
05/22/19 7:00	0.9			1.7			2			0.54			0.26934			0.9		
05/22/19 8:00	0.5			1.7			2			0.68			0.34098			1.14		
05/22/19 9:00	0.7			1.7			2			0.62			0.31212			1.04		
05/22/19 10:00	0.4			1.7			3			0.69			0.34338			1.14		
05/22/19 11:00	0.2			1.7			3			0.75			0.37518			1.25		
05/22/19 12:00	0.2			1.7			4			0.78			0.3894			1.3		
05/22/19 13:00	0.2			1.7			3			0.75			0.37716			1.26		
05/22/19 14:00	0.2			1.7			4			0.77			0.3852			1.28		
05/22/19 15:00	0.6			1.7			2			0.63			0.3126			1.04		
05/22/19 16:00	0.7			1.7			1			0.41			0.20316			0.68		
05/22/19 17:00	0.7			1.7			2			0.37			0.18372			0.61		
05/22/19 18:00	0.7			1.7			2			0.37			0.18336			0.61		
05/22/19 19:00	0.7			1.7			2			0.37			0.18318			0.61		
05/22/19 20:00	0.8			1.7			2			0.36			0.18072			0.6		
05/22/19 21:00	0.9			1.7			2			0.36			0.18072			0.6		
05/22/19 22:00	0.8			1.7			2			0.36			0.18048			0.6		
05/22/19 23:00	0.7			1.7			2			0.36			0.17928			0.6		
05/23/19 0:00	0.7			1.7			2			0.36			0.17826			0.59		
05/23/19 1:00	0.7			1.7			2			0.36			0.17826			0.59		
05/23/19 2:00	0.7			1.7			2			0.36			0.17826			0.59		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/23/19 3:00	0.7			1.7			2			0.36			0.17814			0.59		
05/23/19 4:00	0.7			1.7			2			0.36			0.17802			0.59		
05/23/19 5:00	0.8			1.7			2			0.36			0.1779			0.59		
05/23/19 6:00	0.8			1.7			2			0.37			0.18372			0.61		
05/23/19 7:00	0.6			1.7			2			0.63			0.31608			1.05		
05/23/19 8:00	1.1			1.7			2			0.55			0.27558			0.92		
05/23/19 9:00	0.8			1.7			1			0.5			0.25086			0.84		
05/23/19 10:00	0.8			1.7			1			0.46			0.23106			0.77		
05/23/19 11:00	0.7			1.7			1			0.5			0.24876			0.83		
05/23/19 12:00	1.3			1.7			2			0.53			0.26484			0.88		
05/23/19 13:00	1.2			1.7			2			0.54			0.27078			0.9		
05/23/19 14:00	0.8			1.7			2			0.51			0.25254			0.84		
05/23/19 15:00	1.3			1.7			2			0.54			0.26868			0.9		
05/23/19 16:00	0.8			1.7			2			0.37			0.18354			0.61		
05/23/19 17:00	0.7			1.7			2			0.36			0.1803			0.6		
05/23/19 18:00	0.8			1.7			2			0.36			0.17904			0.6		
05/23/19 19:00	0.7			1.7			2			0.36			0.1788			0.6		
05/23/19 20:00	0.7			1.7			2			0.36			0.17874			0.6		
05/23/19 21:00	0.8			1.7			2			0.37			0.1854			0.62		
05/23/19 22:00	0.7			1.7			2			0.36			0.1797			0.6		
05/23/19 23:00	0.7			1.7			2			0.36			0.1788			0.6		
05/24/19 0:00	0.8			1.7			2			0.36			0.17886			0.6		
05/24/19 1:00	0.8			1.7			2			0.36			0.17898			0.6		
05/24/19 2:00	0.8			1.7			2			0.36			0.17898			0.6		
05/24/19 3:00	0.8			1.7			2			0.36			0.17892			0.6		
05/24/19 4:00	0.8			1.7			2			0.36			0.17892			0.6		
05/24/19 5:00	0.8			1.7			2			0.36			0.17916			0.6		
05/24/19 6:00	0.8			1.7			2			0.36			0.18174			0.61		
05/24/19 7:00	0.9			1.7			2			0.4			0.19842			0.66		
05/24/19 8:00	0.7			1.7			1			0.46			0.23124			0.77		
05/24/19 9:00	0.6			1.7			2			0.63			0.3171			1.06		
05/24/19 10:00	0.8			1.8			2			0.46			0.23064			0.77		
05/24/19 11:00	0.8			1.7			2			0.4			0.19938			0.66		
05/24/19 12:00	0.9			1.7			1			0.46			0.22848			0.76		
05/24/19 13:00	0.4			1.7			3			0.76			0.38142			1.27		
05/24/19 14:00	0.3			1.7			3			0.72			0.35928			1.2		
05/24/19 15:00	0.3			1.7			3			0.76			0.378			1.26		
05/24/19 16:00	0.8			1.8			1			0.39			0.19374			0.65		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/24/19 17:00	0			0			0	X		0.18			0.09102			0.3		
05/24/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/24/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/24/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/24/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/24/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/24/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/26/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/27/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/29/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/31/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
06/01/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/03/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/04/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/06/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/07/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/09/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/11/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/12/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/12/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/12/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/12/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/12/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/12/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/12/19 6:00	0			0			0	X		0.17			0.08448			0.28		
06/12/19 7:00	1			1.6			2			0.44			0.22224			0.74		
06/12/19 8:00	1.1			1.7			2			0.52			0.25806			0.86		
06/12/19 9:00	1.3			1.7			2			0.52			0.25962			0.87		
06/12/19 10:00	0.8			1.7			2			0.59			0.29358			0.98		
06/12/19 11:00	0	X		0	X		0	X		0.64			0.31836			1.06		
06/12/19 12:00	0.3			1.6			2			0.65			0.32358			1.08		
06/12/19 13:00	0.4			1.6			2			0.64			0.31842			1.06		
06/12/19 14:00	0.4			1.6			2			0.61			0.30708			1.02		
06/12/19 15:00	0.7			1.7			2			0.59			0.29712			0.99		
06/12/19 16:00	0.1			1.7			3			0.71			0.35418			1.18		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/12/19 17:00	0.2			1.7			2			0.67			0.33276			1.11		
06/12/19 18:00	0.2			1.7			2			0.67			0.33366			1.11		
06/12/19 19:00	0.1			1.7			4			0.75			0.37326			1.24		
06/12/19 20:00	0.1			1.7			3			0.73			0.3666			1.22		
06/12/19 21:00	0.7			1.8			2			0.45			0.2259			0.75		
06/12/19 22:00	0.7			1.7			2			0.39			0.19662			0.66		
06/12/19 23:00	0			0			0	X		0.1			0.05238			0.17		
06/13/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/13/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/14/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/15/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
06/17/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 14:00	0			0			0	X		0.05			0.02568			0.09		
06/18/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/19/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/20/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/22/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**St**	**Modc**	**Value**	**St**	**Modc**	**Value**	**St**	**Modc**	**Value**	**St**	**Modc**	**Value**	**St**	**Modc**	**Value**	**St**	**Modc**
06/23/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/25/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/26/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/28/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
06/30/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	

AQ57 CT2 HOURLY EMISSIONS

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
04/01/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/01/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
04/02/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/02/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/03/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/04/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/04/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/05/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/05/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/06/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/07/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/07/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/08/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/08/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/09/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/10/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/10/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/11/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/11/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/12/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/13/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/13/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/14/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
04/15/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/15/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/16/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/16/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/17/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/18/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/18/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
04/19/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/19/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/20/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/21/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/21/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/22/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/23/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/23/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/24/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/24/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/25/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
04/26/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/26/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/27/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/27/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/28/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
04/29/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/29/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
04/30/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmwdc_1H			CT2_NH3Slip_Ppmwdc_1H			CT2_NOx_Ppmwdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/30/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/01/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/02/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/02/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/03/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/04/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/04/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/05/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/05/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/06/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
05/07/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/07/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/08/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/08/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/09/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
05/10/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/10/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/11/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/12/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/12/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/13/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/13/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/14/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
05/15/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/15/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/16/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/16/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/17/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/18/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/18/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/19/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/19/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/20/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmwdc_1H			CT2_NH3Slip_Ppmwdc_1H			CT2_NOx_Ppmwdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/21/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/21/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/22/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/22/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/22/19 2:00	0			0	X		0			0	X		0.07662			0.26		
05/22/19 3:00	0			0	X		0			0.43			0.1089			0.36		
05/22/19 4:00	1.1			1			1.7			0.54			0.2874			0.96		
05/22/19 5:00	1			1			1.7			0.54			0.29068			0.97		
05/22/19 6:00	1			1			1.7			0.54			0.28908			0.96		
05/22/19 7:00	1.1			1			1.7			0.54			0.28914			0.96		
05/22/19 8:00	0.6			2			1.7			0.68			0.3606			1.2		
05/22/19 9:00	0.9			2			1.7			0.62			0.33138			1.1		
05/22/19 10:00	0.5			2			1.7			0.69			0.36546			1.22		
05/22/19 11:00	0.3			3			1.8			0.75			0.39186			1.31		
05/22/19 12:00	0.3			3			1.7			0.78			0.4065			1.36		
05/22/19 13:00	0.3			3			1.7			0.75			0.39408			1.31		
05/22/19 14:00	0.3			3			1.7			0.77			0.40278			1.34		
05/22/19 15:00	0.8			2			1.7			0.63			0.32952			1.1		
05/22/19 16:00	0.9			1			1.7			0.41			0.21702			0.72		
05/22/19 17:00	0.9			1			1.7			0.37			0.19572			0.65		
05/22/19 18:00	0.9			1			1.7			0.37			0.19572			0.65		
05/22/19 19:00	0.9			1			1.7			0.37			0.19572			0.65		
05/22/19 20:00	1			1			1.7			0.36			0.19356			0.65		
05/22/19 21:00	1			1			1.7			0.36			0.19356			0.65		
05/22/19 22:00	0.9			1			1.7			0.36			0.19356			0.65		
05/22/19 23:00	0.9			1			1.7			0.36			0.1923			0.64		
05/23/19 0:00	0.8			1			1.7			0.36			0.1914			0.64		
05/23/19 1:00	0.9			1			1.7			0.36			0.1914			0.64		
05/23/19 2:00	0.8			1			1.7			0.36			0.19134			0.64		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
05/23/19 3:00	0.9			1			1.7			0.36			0.19128			0.64		
05/23/19 4:00	0.9			1			1.7			0.36			0.1911			0.64		
05/23/19 5:00	0.9			1			1.7			0.36			0.1911			0.64		
05/23/19 6:00	0.9			1			1.7			0.37			0.19668			0.66		
05/23/19 7:00	0.7			1			1.7			0.63			0.3333			1.11		
05/23/19 8:00	1.3			1			1.7			0.55			0.29094			0.97		
05/23/19 9:00	1			1			1.7			0.5			0.2715			0.91		
05/23/19 10:00	1			1			1.7			0.46			0.25332			0.84		
05/23/19 11:00	0.9			1			1.7			0.5			0.27564			0.92		
05/23/19 12:00	0.9			1			1.7			0.53			0.28254			0.94		
05/23/19 13:00	1.8			1			1.7			0.54			0.2856			0.95		
05/23/19 14:00	0.9			1			1.7			0.51			0.2727			0.91		
05/23/19 15:00	1.4			1			1.7			0.54			0.28524			0.95		
05/23/19 16:00	0.9			1			1.7			0.37			0.19548			0.65		
05/23/19 17:00	0.9			1			1.7			0.36			0.1923			0.64		
05/23/19 18:00	0.9			1			1.7			0.36			0.19146			0.64		
05/23/19 19:00	0.9			1			1.7			0.36			0.19164			0.64		
05/23/19 20:00	0.9			1			1.7			0.36			0.1917			0.64		
05/23/19 21:00	0.9			1			1.7			0.37			0.1986			0.66		
05/23/19 22:00	0.9			1			1.7			0.36			0.19272			0.64		
05/23/19 23:00	0.9			1			1.7			0.36			0.19182			0.64		
05/24/19 0:00	0.9			1			1.7			0.36			0.192			0.64		
05/24/19 1:00	0.9			1			1.7			0.36			0.19212			0.64		
05/24/19 2:00	0.9			1			1.7			0.36			0.19212			0.64		
05/24/19 3:00	0.9			1			1.7			0.36			0.19218			0.64		
05/24/19 4:00	0.9			1			1.7			0.36			0.192			0.64		
05/24/19 5:00	0	X		1			1.7			0.36			0.192			0.64		
05/24/19 6:00	0	X		1			1.7			0.36			0.19458			0.65		
05/24/19 7:00	0	X		1			1.7			0.4			0.21606			0.72		
05/24/19 8:00	0	X		1			1.8			0.46			0.2562			0.85		
05/24/19 9:00	0	X		2			1.7			0.63			0.33558			1.12		
05/24/19 10:00	0	X		1			1.8			0.46			0.24852			0.83		
05/24/19 11:00	0	X		1			1.7			0.4			0.21624			0.72		
05/24/19 12:00	0	X		1			1.8			0.46			0.25098			0.84		
05/24/19 13:00	0	X		3			1.7			0.76			0.39612			1.32		
05/24/19 14:00	0	X		2			1.7			0.72			0.37368			1.25		
05/24/19 15:00	0	X		3			1.7			0.76			0.39696			1.32		
05/24/19 16:00	0	X		1			1.7			0.39			0.20658			0.69		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
05/24/19 17:00	0	X		0	X		0			0.18			0.09342			0.31		
05/24/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/24/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/24/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/24/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/24/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/24/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/25/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
05/26/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/26/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
05/27/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/27/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/28/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
05/29/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/29/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/30/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
05/31/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
05/31/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/01/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/01/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/02/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/03/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/03/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
06/04/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/04/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/05/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
06/06/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/06/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/07/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
06/07/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/08/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/09/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/09/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/10/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
06/11/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 13:00	0			0	X		0			0	X		0.09516			0.32		
06/11/19 14:00	0			0	X		0			0	X		0.19644			0.65		
06/11/19 15:00	0.9			1			1.5			0	X		0.24678			0.82		
06/11/19 16:00	0.9			0			1.3			0	X		0.27516			0.92		
06/11/19 17:00	0.9			1			1.4			0	X		0.27516			0.92		
06/11/19 18:00	0.9			1			1.6			0	X		0.27			0.9		
06/11/19 19:00	1			1			1.7			0	X		0.26502			0.88		
06/11/19 20:00	1.1			0			1.5			0	X		0.13626			0.45		
06/11/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/11/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/12/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/12/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/12/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/12/19 3:00	0			0	X		0			0	X		0.10362			0.35		
06/12/19 4:00	1.1			1			1.5			0	X		0.27072			0.9		
06/12/19 5:00	1.1			0			1.7			0	X		0.24996			0.83		
06/12/19 6:00	1.1			1			1.5			0.17			0.24324			0.81		
06/12/19 7:00	1.2			1			1.5			0.44			0.27408			0.91		
06/12/19 8:00	1			1			1.5			0.52			0.27822			0.93		
06/12/19 9:00	1.4			1			1.5			0.52			0.27834			0.93		
06/12/19 10:00	1.1			1			1.5			0.59			0.31272			1.04		
06/12/19 11:00	0.7			2			1.2			0.64			0.33618			1.12		
06/12/19 12:00	0.6			2			1.6			0.65			0.34158			1.14		
06/12/19 13:00	0.6			2			1.5			0.64			0.33654			1.12		
06/12/19 14:00	0.7			2			1.6			0.61			0.32538			1.08		
06/12/19 15:00	1			2			1.7			0.59			0.31564			1.05		
06/12/19 16:00	0.4			3			1.7			0.71			0.37398			1.25		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/12/19 17:00	0.5			2			1.7			0.67			0.35166			1.17		
06/12/19 18:00	0.5			2			1.7			0.67			0.35286			1.18		
06/12/19 19:00	0.3			3			1.7			0.75			0.39246			1.31		
06/12/19 20:00	0.4			3			1.7			0.73			0.38718			1.29		
06/12/19 21:00	1			1			1.7			0.45			0.2451			0.82		
06/12/19 22:00	1			1			1.7			0.39			0.2301			0.77		
06/12/19 23:00	1			1			1.7			0.1			0.27828			0.93		
06/13/19 0:00	1.1			1			1.7			0	X		0.22632			0.75		
06/13/19 1:00	1			1			1.7			0	X		0.22134			0.74		
06/13/19 2:00	1.1			1			1.7			0	X		0.21792			0.73		
06/13/19 3:00	1.1			1			1.7			0	X		0.21852			0.73		
06/13/19 4:00	1.1			1			1.7			0	X		0.21996			0.73		
06/13/19 5:00	1.1			1			1.7			0	X		0.21966			0.73		
06/13/19 6:00	1.1			1			1.7			0	X		0.21924			0.73		
06/13/19 7:00	1.1			1			1.7			0	X		0.22002			0.73		
06/13/19 8:00	1			1			1.7			0	X		0.2562			0.85		
06/13/19 9:00	1			1			1.7			0	X		0.25638			0.85		
06/13/19 10:00	1			1			1.8			0	X		0.23844			0.79		
06/13/19 11:00	1			1			1.7			0	X		0.25476			0.85		
06/13/19 12:00	1			1			1.7			0	X		0.23544			0.78		
06/13/19 13:00	1			1			1.7			0	X		0.23826			0.79		
06/13/19 14:00	1			1			1.7			0	X		0.23838			0.79		
06/13/19 15:00	1			1			1.7			0	X		0.2385			0.8		
06/13/19 16:00	1			1			1.7			0	X		0.25266			0.84		
06/13/19 17:00	1			1			1.8			0	X		0.24504			0.82		
06/13/19 18:00	1.1			1			1.7			0	X		0.31254			1.04		
06/13/19 19:00	1.1			1			1.7			0	X		0.30558			1.02		
06/13/19 20:00	1			1			1.7			0	X		0.27834			0.93		
06/13/19 21:00	1			1			1.7			0	X		0.2787			0.93		
06/13/19 22:00	1			1			1.7			0	X		0.24942			0.83		
06/13/19 23:00	0			0	X		0			0	X		0.09606			0.32		
06/14/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/14/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/14/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
06/15/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/15/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/16/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/17/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/17/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 14:00	0			0	X		0			0.05			0.02646			0.09		
06/18/19 15:00	0.9			1			1.2			0	X		0.2397			0.8		
06/18/19 16:00	0.9			1			1.8			0	X		0.27252			0.91		
06/18/19 17:00	0.9			0			1.6			0	X		0.2397			0.8		
06/18/19 18:00	1			0			1.5			0	X		0.23088			0.77		
06/18/19 19:00	1			1			1.6			0	X		0.22296			0.74		
06/18/19 20:00	1			1			1.7			0	X		0.21072			0.7		
06/18/19 21:00	0			0	X		0			0	X		0.11382			0.38		
06/18/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/18/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
06/19/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/19/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
06/20/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/20/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/21/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/22/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/22/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/23/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/23/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/24/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
06/25/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/25/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/26/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
06/26/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/27/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
06/28/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/28/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/29/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
06/30/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
06/30/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	

ATTACHMENT 17

AQ-59

AQ-59 The Daily Emissions shall not exceed the following rates:

POLLUTANT	TWO TURBINES	AUX BOILER	COOLING TOWER	EMERGENCY DIESEL GENERATOR	DIESEL FIRE PUMP
NOX	406.0	16.8	-	4.31	1.72
CO	629.5	52.8	-	0.84	0.09
VOC	223.1	7.2	-	0.16	0.05
PM-10	226.8	14.4	16.3	0.14	0.03
SO2	47.1	1.92	-	0.10	0.19

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 00:00 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/10/2019 13:16 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
04/01/2019	0.00	0.00	0.00	0.00	0.00
04/02/2019	0.00	0.00	0.00	0.00	0.00
04/03/2019	0.00	0.00	0.00	0.00	0.00
04/04/2019	0.00	0.00	0.00	0.00	0.00
04/05/2019	0.00	0.00	0.00	0.00	0.00
04/06/2019	0.00	0.00	0.00	0.00	0.00
04/07/2019	0.00	0.00	0.00	0.00	0.00
04/08/2019	0.00	0.00	0.00	0.00	0.00
04/09/2019	0.00	0.00	0.00	0.00	0.00
04/10/2019	0.00	0.00	0.00	0.00	0.00
04/11/2019	0.00	0.00	0.00	0.00	0.00
04/12/2019	0.00	0.00	0.00	0.00	0.00
04/13/2019	0.00	0.00	0.00	0.00	0.00
04/14/2019	0.00	0.00	0.00	0.00	0.00
04/15/2019	0.00	0.00	0.00	0.00	0.00
04/16/2019	0.00	0.00	0.00	0.00	0.00
04/17/2019	0.00	0.00	0.00	0.00	0.00
04/18/2019	0.00	0.00	0.00	0.00	0.00
04/19/2019	0.00	0.00	0.00	0.00	0.00
04/20/2019	0.00	0.00	0.00	0.00	0.00
04/21/2019	0.00	0.00	0.00	0.00	0.00
04/22/2019	0.00	0.00	0.00	0.00	0.00
04/23/2019	0.00	0.00	0.00	0.00	0.00
04/24/2019	0.00	0.00	0.00	0.00	0.00
04/25/2019	0.00	0.00	0.00	0.00	0.00
04/26/2019	0.00	0.00	0.00	0.00	0.00
04/27/2019	0.00	0.00	0.00	0.00	0.00
04/28/2019	0.00	0.00	0.00	0.00	0.00
04/29/2019	0.00	0.00	0.00	0.00	0.00
04/30/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	- *	- *	- *	- *	- *
Daily Min:	-	-	-	-	-
Daily Max:	-	-	-	-	-
Apr 2019 - Apr 2019	-	-	-	-	-
QTD:	0.00 *	0.00 *	0.00 *	0.00 *	0.00 *
YTD 2019:	2,567.00 *	7,724.06 *	726.63 *	1,454.24 *	2,423.82 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 00:00 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/10/2019 13:16 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
05/01/2019	0.00	0.00	0.00	0.00	0.00
05/02/2019	0.00	0.00	0.00	0.00	0.00
05/03/2019	0.00	0.00	0.00	0.00	0.00
05/04/2019	0.00	0.00	0.00	0.00	0.00
05/05/2019	0.00	0.00	0.00	0.00	0.00
05/06/2019	0.00	0.00	0.00	0.00	0.00
05/07/2019	0.00	0.00	0.00	0.00	0.00
05/08/2019	0.00	0.00	0.00	0.00	0.00
05/09/2019	0.00	0.00	0.00	0.00	0.00
05/10/2019	0.00	0.00	0.00	0.00	0.00
05/11/2019	0.00	0.00	0.00	0.00	0.00
05/12/2019	0.00	0.00	0.00	0.00	0.00
05/13/2019	0.00	0.00	0.00	0.00	0.00
05/14/2019	0.00	0.00	0.00	0.00	0.00
05/15/2019	0.00	0.00	0.00	0.00	0.00
05/16/2019	0.00	0.00	0.00	0.00	0.00
05/17/2019	0.00	0.00	0.00	0.00	0.00
05/18/2019	0.00	0.00	0.00	0.00	0.00
05/19/2019	0.00	0.00	0.00	0.00	0.00
05/20/2019	0.00	0.00	0.00	0.00	0.00
05/21/2019	0.00	0.00	0.00	0.00	0.00
05/22/2019	141.84	148.90	11.34	22.68	37.79
05/23/2019	36.81	110.25	10.51	21.05	35.06
05/24/2019	22.41	88.52	8.23	16.44	27.47
05/25/2019	0.00	0.00	0.00	0.00	0.00
05/26/2019	0.00	0.00	0.00	0.00	0.00
05/27/2019	0.00	0.00	0.00	0.00	0.00
05/28/2019	0.00	0.00	0.00	0.00	0.00
05/29/2019	0.00	0.00	0.00	0.00	0.00
05/30/2019	0.00	0.00	0.00	0.00	0.00
05/31/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	201.06 *	347.67 *	30.08 *	60.17 *	100.32 *
Daily Min:	22.41	88.52	8.23	16.44	27.47
Daily Max:	141.84	148.90	11.34	22.68	37.79
Apr 2019 - May 2019	201.06	347.67	30.01	60.17	100.32
QTD:	201.06 *	347.67 *	30.08 *	60.17 *	100.32 *
YTD 2019:	2,768.06 *	8,071.73 *	756.71 *	1,514.41 *	2,524.14 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 00:00 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/10/2019 13:16 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
06/01/2019	0.00	0.00	0.00	0.00	0.00
06/02/2019	0.00	0.00	0.00	0.00	0.00
06/03/2019	0.00	0.00	0.00	0.00	0.00
06/04/2019	0.00	0.00	0.00	0.00	0.00
06/05/2019	0.00	0.00	0.00	0.00	0.00
06/06/2019	0.00	0.00	0.00	0.00	0.00
06/07/2019	0.00	0.00	0.00	0.00	0.00
06/08/2019	0.00	0.00	0.00	0.00	0.00
06/09/2019	0.00	0.00	0.00	0.00	0.00
06/10/2019	0.00	0.00	0.00	0.00	0.00
06/11/2019	38.15	29.24	1.59	3.15	5.25
06/12/2019	95.16	128.42	11.02	22.03	36.70
06/13/2019	35.67	60.33	5.68	11.33	18.81
06/14/2019	0.00	0.00	0.00	0.00	0.00
06/15/2019	0.00	0.00	0.00	0.00	0.00
06/16/2019	0.00	0.00	0.00	0.00	0.00
06/17/2019	0.00	0.00	0.00	0.00	0.00
06/18/2019	40.37	29.40	1.42	2.86	4.77
06/19/2019	0.00	0.00	0.00	0.00	0.00
06/20/2019	0.00	0.00	0.00	0.00	0.00
06/21/2019	0.00	0.00	0.00	0.00	0.00
06/22/2019	0.00	0.00	0.00	0.00	0.00
06/23/2019	0.00	0.00	0.00	0.00	0.00
06/24/2019	0.00	0.00	0.00	0.00	0.00
06/25/2019	0.00	0.00	0.00	0.00	0.00
06/26/2019	0.00	0.00	0.00	0.00	0.00
06/27/2019	0.00	0.00	0.00	0.00	0.00
06/28/2019	0.00	0.00	0.00	0.00	0.00
06/29/2019	0.00	0.00	0.00	0.00	0.00
06/30/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	209.35 *	247.39 *	19.71 *	39.37 *	65.53 *
Daily Min:	35.67	29.24	1.42	2.86	4.77
Daily Max:	95.16	128.42	11.02	22.03	36.70
Apr 2019 - Jun 2019	410.41	595.06	49.79	99.54	165.85
QTD:	410.41 *	595.06 *	49.79 *	99.54 *	165.85 *
YTD 2019:	2,977.41 *	8,319.12 *	776.42 *	1,553.78 *	2,589.67 *

Monthly Summary By Day Report

Unit CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:36 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
04/01/2019	0.00	0.00	0.0	0.00	0.00
04/02/2019	0.00	0.00	0.0	0.00	0.00
04/03/2019	0.00	0.00	0.0	0.00	0.00
04/04/2019	0.00	0.00	0.0	0.00	0.00
04/05/2019	0.00	0.00	0.0	0.00	0.00
04/06/2019	0.00	0.00	0.0	0.00	0.00
04/07/2019	0.00	0.00	0.0	0.00	0.00
04/08/2019	0.00	0.00	0.0	0.00	0.00
04/09/2019	0.00	0.00	0.0	0.00	0.00
04/10/2019	0.00	0.00	0.0	0.00	0.00
04/11/2019	0.00	0.00	0.0	0.00	0.00
04/12/2019	0.00	0.00	0.0	0.00	0.00
04/13/2019	0.00	0.00	0.0	0.00	0.00
04/14/2019	0.00	0.00	0.0	0.00	0.00
04/15/2019	0.00	0.00	0.0	0.00	0.00
04/16/2019	0.00	0.00	0.0	0.00	0.00
04/17/2019	0.00	0.00	0.0	0.00	0.00
04/18/2019	0.00	0.00	0.0	0.00	0.00
04/19/2019	0.00	0.00	0.0	0.00	0.00
04/20/2019	0.00	0.00	0.0	0.00	0.00
04/21/2019	0.00	0.00	0.0	0.00	0.00
04/22/2019	0.00	0.00	0.0	0.00	0.00
04/23/2019	0.00	0.00	0.0	0.00	0.00
04/24/2019	0.00	0.00	0.0	0.00	0.00
04/25/2019	0.00	0.00	0.0	0.00	0.00
04/26/2019	0.00	0.00	0.0	0.00	0.00
04/27/2019	0.00	0.00	0.0	0.00	0.00
04/28/2019	0.00	0.00	0.0	0.00	0.00
04/29/2019	0.00	0.00	0.0	0.00	0.00
04/30/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	- *	- *	- *	- *	- *
Daily Min:	-	-	-	-	-
Daily Max:	-	-	-	-	-
Apr 2019 - Apr 2019	-	-	-	-	-
QTD:	0.00 *	0.00 *	0.0 *	0.00 *	0.00 *
YTD 2019:	959.32 *	3,422.24 *	337.4 *	646.38 *	1,077.11 *

Monthly Summary By Day Report

Unit CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:36 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
05/01/2019	0.00	0.00	0.0	0.00	0.00
05/02/2019	0.00	0.00	0.0	0.00	0.00
05/03/2019	0.00	0.00	0.0	0.00	0.00
05/04/2019	0.00	0.00	0.0	0.00	0.00
05/05/2019	0.00	0.00	0.0	0.00	0.00
05/06/2019	0.00	0.00	0.0	0.00	0.00
05/07/2019	0.00	0.00	0.0	0.00	0.00
05/08/2019	0.00	0.00	0.0	0.00	0.00
05/09/2019	0.00	0.00	0.0	0.00	0.00
05/10/2019	0.00	0.00	0.0	0.00	0.00
05/11/2019	0.00	0.00	0.0	0.00	0.00
05/12/2019	0.00	0.00	0.0	0.00	0.00
05/13/2019	0.00	0.00	0.0	0.00	0.00
05/14/2019	0.00	0.00	0.0	0.00	0.00
05/15/2019	0.00	0.00	0.0	0.00	0.00
05/16/2019	0.00	0.00	0.0	0.00	0.00
05/17/2019	0.00	0.00	0.0	0.00	0.00
05/18/2019	0.00	0.00	0.0	0.00	0.00
05/19/2019	0.00	0.00	0.0	0.00	0.00
05/20/2019	0.00	0.00	0.0	0.00	0.00
05/21/2019	0.00	0.00	0.0	0.00	0.00
05/22/2019	60.71	70.60	5.8	11.17	18.58
05/23/2019	16.41	53.36	5.5	10.19	16.91
05/24/2019	19.10	43.07	4.1	7.97	13.29
05/25/2019	0.00	0.00	0.0	0.00	0.00
05/26/2019	0.00	0.00	0.0	0.00	0.00
05/27/2019	0.00	0.00	0.0	0.00	0.00
05/28/2019	0.00	0.00	0.0	0.00	0.00
05/29/2019	0.00	0.00	0.0	0.00	0.00
05/30/2019	0.00	0.00	0.0	0.00	0.00
05/31/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	96.22 *	167.03 *	15.4 *	29.33 *	48.78 *
Daily Min:	16.41	43.07	4.1	7.97	13.29
Daily Max:	60.71	70.60	5.8	11.17	18.58
Apr 2019 - May 2019	96.22	167.03	15.4	29.33	48.78
QTD:	96.22 *	167.03 *	15.4 *	29.33 *	48.78 *
YTD 2019:	1,055.54 *	3,589.27 *	352.8 *	675.71 *	1,125.89 *

Monthly Summary By Day Report

Unit CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:36 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
06/01/2019	0.00	0.00	0.0	0.00	0.00
06/02/2019	0.00	0.00	0.0	0.00	0.00
06/03/2019	0.00	0.00	0.0	0.00	0.00
06/04/2010	0.00	0.00	0.0	0.00	0.00
06/05/2019	0.00	0.00	0.0	0.00	0.00
06/06/2019	0.00	0.00	0.0	0.00	0.00
06/07/2019	0.00	0.00	0.0	0.00	0.00
06/08/2019	0.00	0.00	0.0	0.00	0.00
06/09/2019	0.00	0.00	0.0	0.00	0.00
06/10/2019	0.00	0.00	0.0	0.00	0.00
06/11/2019	0.00	0.00	0.0	0.00	0.00
06/12/2019	49.69	57.31	4.8	9.62	16.02
06/13/2019	0.00	0.00	0.0	0.00	0.00
06/14/2019	0.00	0.00	0.0	0.00	0.00
06/15/2019	0.00	0.00	0.0	0.00	0.00
06/16/2019	0.00	0.00	0.0	0.00	0.00
06/17/2019	0.00	0.00	0.0	0.00	0.00
06/18/2019	-0.05	0.00	0.0	0.00	0.00
06/19/2019	0.00	0.00	0.0	0.00	0.00
06/20/2019	0.00	0.00	0.0	0.00	0.00
06/21/2019	0.00	0.00	0.0	0.00	0.00
06/22/2019	0.00	0.00	0.0	0.00	0.00
06/23/2019	0.00	0.00	0.0	0.00	0.00
06/24/2019	0.00	0.00	0.0	0.00	0.00
06/25/2019	0.00	0.00	0.0	0.00	0.00
06/26/2019	0.00	0.00	0.0	0.00	0.00
06/27/2019	0.00	0.00	0.0	0.00	0.00
06/28/2019	0.00	0.00	0.0	0.00	0.00
06/29/2019	0.00	0.00	0.0	0.00	0.00
06/30/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	49.64 *	57.31 *	4.8 *	9.62 *	16.02 *
Daily Min:	-0.05	0.00	0.0	0.00	0.00
Daily Max:	49.69	57.31	4.8	9.62	16.02
Apr 2019 - Jun 2019	145.86	224.34	20.2	38.95	64.80
QTD:	145.86 *	224.34 *	20.2 *	38.95 *	64.80 *
YTD 2019:	1,105.18 *	3,646.58 *	357.6 *	685.33 *	1,141.91 *

Monthly Summary By Day Report

Unit CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:39 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
04/01/2019	0.00	0.00	0.0	0.00	0.00
04/02/2019	0.00	0.00	0.0	0.00	0.00
04/03/2019	0.00	0.00	0.0	0.00	0.00
04/04/2019	0.00	0.00	0.0	0.00	0.00
04/05/2019	0.00	0.00	0.0	0.00	0.00
04/06/2019	0.00	0.00	0.0	0.00	0.00
04/07/2019	0.00	0.00	0.0	0.00	0.00
04/08/2019	0.00	0.00	0.0	0.00	0.00
04/09/2019	0.00	0.00	0.0	0.00	0.00
04/10/2019	0.00	0.00	0.0	0.00	0.00
04/11/2019	0.00	0.00	0.0	0.00	0.00
04/12/2019	0.00	0.00	0.0	0.00	0.00
04/13/2019	0.00	0.00	0.0	0.00	0.00
04/14/2019	0.00	0.00	0.0	0.00	0.00
04/15/2019	0.00	0.00	0.0	0.00	0.00
04/16/2019	0.00	0.00	0.0	0.00	0.00
04/17/2019	0.00	0.00	0.0	0.00	0.00
04/18/2019	0.00	0.00	0.0	0.00	0.00
04/19/2019	0.00	0.00	0.0	0.00	0.00
04/20/2019	0.00	0.00	0.0	0.00	0.00
04/21/2019	0.00	0.00	0.0	0.00	0.00
04/22/2019	0.00	0.00	0.0	0.00	0.00
04/23/2019	0.00	0.00	0.0	0.00	0.00
04/24/2019	0.00	0.00	0.0	0.00	0.00
04/25/2019	0.00	0.00	0.0	0.00	0.00
04/26/2019	0.00	0.00	0.0	0.00	0.00
04/27/2019	0.00	0.00	0.0	0.00	0.00
04/28/2019	0.00	0.00	0.0	0.00	0.00
04/29/2019	0.00	0.00	0.0	0.00	0.00
04/30/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	- *	- *	- *	- *	- *
Daily Min:	-	-	-	-	-
Daily Max:	-	-	-	-	-
Apr 2019 - Apr 2019	-	-	-	-	-
QTD:	0.00 *	0.00 *	0.0 *	0.00 *	0.00 *
YTD 2019:	1,607.68 *	4,301.82 *	408.6 *	807.86 *	1,346.71 *

Monthly Summary By Day Report

Unit CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:39 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
05/01/2019	0.00	0.00	0.0	0.00	0.00
05/02/2019	0.00	0.00	0.0	0.00	0.00
05/03/2019	0.00	0.00	0.0	0.00	0.00
05/04/2019	0.00	0.00	0.0	0.00	0.00
05/05/2019	0.00	0.00	0.0	0.00	0.00
05/06/2019	0.00	0.00	0.0	0.00	0.00
05/07/2019	0.00	0.00	0.0	0.00	0.00
05/08/2019	0.00	0.00	0.0	0.00	0.00
05/09/2019	0.00	0.00	0.0	0.00	0.00
05/10/2019	0.00	0.00	0.0	0.00	0.00
05/11/2019	0.00	0.00	0.0	0.00	0.00
05/12/2019	0.00	0.00	0.0	0.00	0.00
05/13/2019	0.00	0.00	0.0	0.00	0.00
05/14/2019	0.00	0.00	0.0	0.00	0.00
05/15/2019	0.00	0.00	0.0	0.00	0.00
05/16/2019	0.00	0.00	0.0	0.00	0.00
05/17/2019	0.00	0.00	0.0	0.00	0.00
05/18/2019	0.00	0.00	0.0	0.00	0.00
05/19/2019	0.00	0.00	0.0	0.00	0.00
05/20/2019	0.00	0.00	0.0	0.00	0.00
05/21/2019	0.00	0.00	0.0	0.00	0.00
05/22/2019	81.13	78.30	5.8	11.51	19.21
05/23/2019	20.40	56.89	5.7	10.86	18.15
05/24/2019	3.31	45.45	4.3	8.47	14.18
05/25/2019	0.00	0.00	0.0	0.00	0.00
05/26/2019	0.00	0.00	0.0	0.00	0.00
05/27/2019	0.00	0.00	0.0	0.00	0.00
05/28/2019	0.00	0.00	0.0	0.00	0.00
05/29/2019	0.00	0.00	0.0	0.00	0.00
05/30/2019	0.00	0.00	0.0	0.00	0.00
05/31/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	104.84 *	180.64 *	15.8 *	30.84 *	51.54 *
Daily Min:	3.31	45.45	4.3	8.47	14.18
Daily Max:	81.13	78.30	5.8	11.51	19.21
Apr 2019 - May 2019	104.84	180.64	15.8	30.84	51.54
QTD:	104.84 *	180.64 *	15.8 *	30.84 *	51.54 *
YTD 2019:	1,712.52 *	4,482.46 *	424.4 *	838.70 *	1,398.25 *

Monthly Summary By Day Report

Unit CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:39 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
06/01/2019	0.00	0.00	0.0	0.00	0.00
06/02/2019	0.00	0.00	0.0	0.00	0.00
06/03/2019	0.00	0.00	0.0	0.00	0.00
06/04/2019	0.00	0.00	0.0	0.00	0.00
06/05/2019	0.00	0.00	0.0	0.00	0.00
06/06/2019	0.00	0.00	0.0	0.00	0.00
06/07/2019	0.00	0.00	0.0	0.00	0.00
06/08/2019	0.00	0.00	0.0	0.00	0.00
06/09/2019	0.00	0.00	0.0	0.00	0.00
06/10/2019	0.00	0.00	0.0	0.00	0.00
06/11/2019	38.15	29.24	1.6	3.15	5.25
06/12/2019	45.47	71.11	6.2	12.41	20.68
06/13/2019	35.67	60.33	5.4	11.33	18.81
06/14/2019	0.00	0.00	0.0	0.00	0.00
06/15/2019	0.00	0.00	0.0	0.00	0.00
06/16/2019	0.00	0.00	0.0	0.00	0.00
06/17/2019	0.00	0.00	0.0	0.00	0.00
06/18/2019	40.42	29.40	1.3	2.86	4.77
06/19/2019	0.00	0.00	0.0	0.00	0.00
06/20/2019	0.00	0.00	0.0	0.00	0.00
06/21/2019	0.00	0.00	0.0	0.00	0.00
06/22/2019	0.00	0.00	0.0	0.00	0.00
06/23/2019	0.00	0.00	0.0	0.00	0.00
06/24/2019	0.00	0.00	0.0	0.00	0.00
06/25/2019	0.00	0.00	0.0	0.00	0.00
06/26/2019	0.00	0.00	0.0	0.00	0.00
06/27/2019	0.00	0.00	0.0	0.00	0.00
06/28/2019	0.00	0.00	0.0	0.00	0.00
06/29/2019	0.00	0.00	0.0	0.00	0.00
06/30/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	159.71 *	190.08 *	14.5 *	29.75 *	49.51 *
Daily Min:	35.67	29.24	1.3	2.86	4.77
Daily Max:	45.47	71.11	6.2	12.41	20.68
Apr 2019 - Jun 2019	264.55	370.72	30.3	60.59	101.05
QTD:	264.55 *	370.72 *	30.3 *	60.59 *	101.05 *
YTD 2019:	1,872.23 *	4,672.54 *	438.9 *	868.45 *	1,447.76 *

ATTACHMENT 18

AQ-60

AQ-60 If the Alstom GTX100 turbine are selected, the quarterly emissions shall not exceed the levels shown below:

Alstom GTX100 Gas Turbines					
Pollutant	Quarter 1 (lbs/quarter) Two turbines	Quarter 2 (lbs/quarter) Two Turbines	Quarter 3 (lbs/quarter) Two turbines	Quarter 4 (lbs/quarter) Two Turbines	Tons/ Year Two Turbines
NOx	15,399	12,965	17,496	15,422	30.64
CO	26,787	32,590	28,175	29,862	58.71
VOCs	5,791	7,306	6,630	6,848	13.29
PM0	16,300	13,692	17,789	17,569	32.67
SOx	3,385	2,843	3,694	3,648	6.78

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emission limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 00:00 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/10/2019 13:16 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT1 CO, Lb 1 Hour(s)	Units CT1 & CT1 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
04/01/2019	0.00	0.00	0.00	0.00	0.00
04/02/2019	0.00	0.00	0.00	0.00	0.00
04/03/2019	0.00	0.00	0.00	0.00	0.00
04/04/2019	0.00	0.00	0.00	0.00	0.00
04/05/2019	0.00	0.00	0.00	0.00	0.00
04/06/2019	0.00	0.00	0.00	0.00	0.00
04/07/2019	0.00	0.00	0.00	0.00	0.00
04/08/2019	0.00	0.00	0.00	0.00	0.00
04/09/2019	0.00	0.00	0.00	0.00	0.00
04/10/2019	0.00	0.00	0.00	0.00	0.00
04/11/2019	0.00	0.00	0.00	0.00	0.00
04/12/2019	0.00	0.00	0.00	0.00	0.00
04/13/2019	0.00	0.00	0.00	0.00	0.00
04/14/2019	0.00	0.00	0.00	0.00	0.00
04/15/2019	0.00	0.00	0.00	0.00	0.00
04/16/2019	0.00	0.00	0.00	0.00	0.00
04/17/2019	0.00	0.00	0.00	0.00	0.00
04/18/2019	0.00	0.00	0.00	0.00	0.00
04/19/2019	0.00	0.00	0.00	0.00	0.00
04/20/2019	0.00	0.00	0.00	0.00	0.00
04/21/2019	0.00	0.00	0.00	0.00	0.00
04/22/2019	0.00	0.00	0.00	0.00	0.00
04/23/2019	0.00	0.00	0.00	0.00	0.00
04/24/2019	0.00	0.00	0.00	0.00	0.00
04/25/2019	0.00	0.00	0.00	0.00	0.00
04/26/2019	0.00	0.00	0.00	0.00	0.00
04/27/2019	0.00	0.00	0.00	0.00	0.00
04/28/2019	0.00	0.00	0.00	0.00	0.00
04/29/2019	0.00	0.00	0.00	0.00	0.00
04/30/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	- *	- *	- *	- *	- *
Daily Min:	-	-	-	-	-
Daily Max:	-	-	-	-	-
Apr 2019 - Apr 2019	-	-	-	-	-
QTD:	0.00 *	0.00 *	0.00 *	0.00 *	0.00 *
YTD 2019:	2,567.00 *	7,724.06 *	726.63 *	1,454.24 *	2,423.82 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 00:00 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/10/2019 13:16 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT1 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT1 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
05/01/2019	0.00	0.00	0.00	0.00	0.00
05/02/2019	0.00	0.00	0.00	0.00	0.00
05/03/2019	0.00	0.00	0.00	0.00	0.00
05/04/2019	0.00	0.00	0.00	0.00	0.00
05/05/2019	0.00	0.00	0.00	0.00	0.00
05/06/2019	0.00	0.00	0.00	0.00	0.00
05/07/2019	0.00	0.00	0.00	0.00	0.00
05/08/2019	0.00	0.00	0.00	0.00	0.00
05/09/2019	0.00	0.00	0.00	0.00	0.00
05/10/2019	0.00	0.00	0.00	0.00	0.00
05/11/2019	0.00	0.00	0.00	0.00	0.00
05/12/2019	0.00	0.00	0.00	0.00	0.00
05/13/2019	0.00	0.00	0.00	0.00	0.00
05/14/2019	0.00	0.00	0.00	0.00	0.00
05/15/2019	0.00	0.00	0.00	0.00	0.00
05/16/2019	0.00	0.00	0.00	0.00	0.00
05/17/2019	0.00	0.00	0.00	0.00	0.00
05/18/2019	0.00	0.00	0.00	0.00	0.00
05/19/2019	0.00	0.00	0.00	0.00	0.00
05/20/2019	0.00	0.00	0.00	0.00	0.00
05/21/2019	0.00	0.00	0.00	0.00	0.00
05/22/2019	141.84	148.90	11.34	22.68	37.79
05/23/2019	36.81	110.25	10.51	21.05	35.06
05/24/2019	22.41	88.52	8.23	16.44	27.47
05/25/2019	0.00	0.00	0.00	0.00	0.00
05/26/2019	0.00	0.00	0.00	0.00	0.00
05/27/2019	0.00	0.00	0.00	0.00	0.00
05/28/2019	0.00	0.00	0.00	0.00	0.00
05/29/2019	0.00	0.00	0.00	0.00	0.00
05/30/2019	0.00	0.00	0.00	0.00	0.00
05/31/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	201.06 *	347.67 *	30.08 *	60.17 *	100.32 *
Daily Min:	22.41	88.52	8.23	16.44	27.47
Daily Max:	141.84	148.90	11.34	22.68	37.79
Apr 2019 - May 2019	201.06	347.67	30.08	60.17	100.32
QTD:	201.06 *	347.67 *	30.08 *	60.17 *	100.32 *
YTD 2019:	2,768.06 *	8,071.73 *	756.71 *	1,514.41 *	2,524.14 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 00:00 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/10/2019 13:16 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
06/01/2019	0.00	0.00	0.00	0.00	0.00
06/02/2019	0.00	0.00	0.00	0.00	0.00
06/03/2019	0.00	0.00	0.00	0.00	0.00
06/04/2019	0.00	0.00	0.00	0.00	0.00
06/05/2019	0.00	0.00	0.00	0.00	0.00
06/06/2019	0.00	0.00	0.00	0.00	0.00
06/07/2019	0.00	0.00	0.00	0.00	0.00
06/08/2019	0.00	0.00	0.00	0.00	0.00
06/09/2019	0.00	0.00	0.00	0.00	0.00
06/10/2019	0.00	0.00	0.00	0.00	0.00
06/11/2019	38.15	29.24	1.59	3.15	5.25
06/12/2019	95.16	128.42	11.02	22.03	36.70
06/13/2019	35.67	60.33	5.68	11.93	18.81
06/14/2019	0.00	0.00	0.00	0.00	0.00
06/15/2019	0.00	0.00	0.00	0.00	0.00
06/16/2019	0.00	0.00	0.00	0.00	0.00
06/17/2019	0.00	0.00	0.00	0.00	0.00
06/18/2019	40.37	29.40	1.42	2.86	4.77
06/19/2019	0.00	0.00	0.00	0.00	0.00
06/20/2019	0.00	0.00	0.00	0.00	0.00
06/21/2019	0.00	0.00	0.00	0.00	0.00
06/22/2019	0.00	0.00	0.00	0.00	0.00
06/23/2019	0.00	0.00	0.00	0.00	0.00
06/24/2019	0.00	0.00	0.00	0.00	0.00
06/25/2019	0.00	0.00	0.00	0.00	0.00
06/26/2019	0.00	0.00	0.00	0.00	0.00
06/27/2019	0.00	0.00	0.00	0.00	0.00
06/28/2019	0.00	0.00	0.00	0.00	0.00
06/29/2019	0.00	0.00	0.00	0.00	0.00
06/30/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	209.35 *	247.39 *	19.71 *	39.37 *	65.53 *
Daily Min:	35.67	29.24	1.42	2.86	4.77
Daily Max:	95.16	128.42	11.02	22.03	36.70
Apr 2019 - Jun 2019	410.41	595.06	49.79	99.54	165.85
QTD:	410.41 *	595.06 *	49.79 *	99.54 *	165.85 *
YTD 2019:	2,977.41 *	8,319.12 *	776.42 *	1,553.78 *	2,589.67 *

Monthly Summary By Day Report

Unit CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:36 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
04/01/2019	0.00	0.00	0.0	0.00	0.00
04/02/2019	0.00	0.00	0.0	0.00	0.00
04/03/2019	0.00	0.00	0.0	0.00	0.00
04/04/2019	0.00	0.00	0.0	0.00	0.00
04/05/2019	0.00	0.00	0.0	0.00	0.00
04/06/2019	0.00	0.00	0.0	0.00	0.00
04/07/2019	0.00	0.00	0.0	0.00	0.00
04/08/2019	0.00	0.00	0.0	0.00	0.00
04/09/2019	0.00	0.00	0.0	0.00	0.00
04/10/2019	0.00	0.00	0.0	0.00	0.00
04/11/2019	0.00	0.00	0.0	0.00	0.00
04/12/2019	0.00	0.00	0.0	0.00	0.00
04/13/2019	0.00	0.00	0.0	0.00	0.00
04/14/2019	0.00	0.00	0.0	0.00	0.00
04/15/2019	0.00	0.00	0.0	0.00	0.00
04/16/2019	0.00	0.00	0.0	0.00	0.00
04/17/2019	0.00	0.00	0.0	0.00	0.00
04/18/2019	0.00	0.00	0.0	0.00	0.00
04/19/2019	0.00	0.00	0.0	0.00	0.00
04/20/2019	0.00	0.00	0.0	0.00	0.00
04/21/2019	0.00	0.00	0.0	0.00	0.00
04/22/2019	0.00	0.00	0.0	0.00	0.00
04/23/2019	0.00	0.00	0.0	0.00	0.00
04/24/2019	0.00	0.00	0.0	0.00	0.00
04/25/2019	0.00	0.00	0.0	0.00	0.00
04/26/2019	0.00	0.00	0.0	0.00	0.00
04/27/2019	0.00	0.00	0.0	0.00	0.00
04/28/2019	0.00	0.00	0.0	0.00	0.00
04/29/2019	0.00	0.00	0.0	0.00	0.00
04/30/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	- *	- *	- *	- *	- *
Daily Min:	-	-	-	-	-
Daily Max:	-	-	-	-	-
Apr 2019 - Apr 2019	-	-	-	-	-
QTD:	0.00 *	0.00 *	0.0 *	0.00 *	0.00 *
YTD 2019:	959.32 *	3,422.24 *	337.4 *	646.38 *	1,077.11 *

Monthly Summary By Day Report

Unit CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:36 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
05/01/2019	0.00	0.00	0.0	0.00	0.00
05/02/2019	0.00	0.00	0.0	0.00	0.00
05/03/2019	0.00	0.00	0.0	0.00	0.00
05/04/2019	0.00	0.00	0.0	0.00	0.00
05/05/2019	0.00	0.00	0.0	0.00	0.00
05/06/2019	0.00	0.00	0.0	0.00	0.00
05/07/2019	0.00	0.00	0.0	0.00	0.00
05/08/2019	0.00	0.00	0.0	0.00	0.00
05/09/2019	0.00	0.00	0.0	0.00	0.00
05/10/2019	0.00	0.00	0.0	0.00	0.00
05/11/2019	0.00	0.00	0.0	0.00	0.00
05/12/2019	0.00	0.00	0.0	0.00	0.00
05/13/2019	0.00	0.00	0.0	0.00	0.00
05/14/2019	0.00	0.00	0.0	0.00	0.00
05/15/2019	0.00	0.00	0.0	0.00	0.00
05/16/2019	0.00	0.00	0.0	0.00	0.00
05/17/2019	0.00	0.00	0.0	0.00	0.00
05/18/2019	0.00	0.00	0.0	0.00	0.00
05/19/2019	0.00	0.00	0.0	0.00	0.00
05/20/2019	0.00	0.00	0.0	0.00	0.00
05/21/2019	0.00	0.00	0.0	0.00	0.00
05/22/2019	60.71	70.60	5.8	11.17	18.58
05/23/2019	16.41	53.36	5.5	10.19	16.91
05/24/2019	19.10	43.07	4.1	7.97	13.29
05/25/2019	0.00	0.00	0.0	0.00	0.00
05/26/2019	0.00	0.00	0.0	0.00	0.00
05/27/2019	0.00	0.00	0.0	0.00	0.00
05/28/2019	0.00	0.00	0.0	0.00	0.00
05/29/2019	0.00	0.00	0.0	0.00	0.00
05/30/2019	0.00	0.00	0.0	0.00	0.00
05/31/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	96.22 *	167.03 *	15.4 *	29.33 *	48.78 *
Daily Min:	16.41	43.07	4.1	7.97	13.29
Daily Max:	60.71	70.60	5.8	11.17	18.58
Apr 2019 - May 2019	96.22	167.03	15.4	29.33	48.78
QTD:	96.22 *	167.03 *	15.4 *	29.33 *	48.78 *
YTD 2019:	1,055.54 *	3,589.27 *	352.8 *	675.71 *	1,125.89 *

Monthly Summary By Day Report

Unit CT1

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:36 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
06/01/2019	0.00	0.00	0.0	0.00	0.00
06/02/2019	0.00	0.00	0.0	0.00	0.00
06/03/2019	0.00	0.00	0.0	0.00	0.00
06/04/2019	0.00	0.00	0.0	0.00	0.00
06/05/2019	0.00	0.00	0.0	0.00	0.00
06/06/2019	0.00	0.00	0.0	0.00	0.00
06/07/2019	0.00	0.00	0.0	0.00	0.00
06/08/2019	0.00	0.00	0.0	0.00	0.00
06/09/2019	0.00	0.00	0.0	0.00	0.00
06/10/2019	0.00	0.00	0.0	0.00	0.00
06/11/2019	0.00	0.00	0.0	0.00	0.00
06/12/2019	49.69	57.31	4.8	9.62	16.02
06/13/2019	0.00	0.00	0.0	0.00	0.00
06/14/2019	0.00	0.00	0.0	0.00	0.00
06/15/2019	0.00	0.00	0.0	0.00	0.00
06/16/2019	0.00	0.00	0.0	0.00	0.00
06/17/2019	0.00	0.00	0.0	0.00	0.00
06/18/2019	-0.05	0.00	0.0	0.00	0.00
06/19/2019	0.00	0.00	0.0	0.00	0.00
06/20/2019	0.00	0.00	0.0	0.00	0.00
06/21/2019	0.00	0.00	0.0	0.00	0.00
06/22/2019	0.00	0.00	0.0	0.00	0.00
06/23/2019	0.00	0.00	0.0	0.00	0.00
06/24/2019	0.00	0.00	0.0	0.00	0.00
06/25/2019	0.00	0.00	0.0	0.00	0.00
06/26/2019	0.00	0.00	0.0	0.00	0.00
06/27/2019	0.00	0.00	0.0	0.00	0.00
06/28/2019	0.00	0.00	0.0	0.00	0.00
06/29/2019	0.00	0.00	0.0	0.00	0.00
06/30/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	49.64 *	57.31 *	4.8 *	9.62 *	16.02 *
Daily Min:	-0.05	0.00	0.0	0.00	0.00
Daily Max:	49.69	57.31	4.8	9.62	16.02
Apr 2019 - Jun 2019	145.86	224.34	20.2	38.95	64.80
QTD:	145.86 *	224.34 *	20.2 *	38.95 *	64.80 *
YTD 2019:	1,105.18 *	3,646.58 *	357.6 *	685.33 *	1,141.91 *

Monthly Summary By Day Report

Unit CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:39 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
04/01/2019	0.00	0.00	0.0	0.00	0.00
04/02/2019	0.00	0.00	0.0	0.00	0.00
04/03/2019	0.00	0.00	0.0	0.00	0.00
04/04/2019	0.00	0.00	0.0	0.00	0.00
04/05/2019	0.00	0.00	0.0	0.00	0.00
04/06/2019	0.00	0.00	0.0	0.00	0.00
04/07/2019	0.00	0.00	0.0	0.00	0.00
04/08/2019	0.00	0.00	0.0	0.00	0.00
04/09/2019	0.00	0.00	0.0	0.00	0.00
04/10/2019	0.00	0.00	0.0	0.00	0.00
04/11/2019	0.00	0.00	0.0	0.00	0.00
04/12/2019	0.00	0.00	0.0	0.00	0.00
04/13/2019	0.00	0.00	0.0	0.00	0.00
04/14/2019	0.00	0.00	0.0	0.00	0.00
04/15/2019	0.00	0.00	0.0	0.00	0.00
04/16/2019	0.00	0.00	0.0	0.00	0.00
04/17/2019	0.00	0.00	0.0	0.00	0.00
04/18/2019	0.00	0.00	0.0	0.00	0.00
04/19/2019	0.00	0.00	0.0	0.00	0.00
04/20/2019	0.00	0.00	0.0	0.00	0.00
04/21/2019	0.00	0.00	0.0	0.00	0.00
04/22/2019	0.00	0.00	0.0	0.00	0.00
04/23/2019	0.00	0.00	0.0	0.00	0.00
04/24/2019	0.00	0.00	0.0	0.00	0.00
04/25/2019	0.00	0.00	0.0	0.00	0.00
04/26/2019	0.00	0.00	0.0	0.00	0.00
04/27/2019	0.00	0.00	0.0	0.00	0.00
04/28/2019	0.00	0.00	0.0	0.00	0.00
04/29/2019	0.00	0.00	0.0	0.00	0.00
04/30/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	- *	- *	- *	- *	- *
Daily Min:	-	-	-	-	-
Daily Max:	-	-	-	-	-
Apr 2019 - Apr 2019	-	-	-	-	-
QTD:	0.00 *	0.00 *	0.0 *	0.00 *	0.00 *
YTD 2019:	1,607.68 *	4,301.82 *	408.6 *	807.86 *	1,346.71 *

Monthly Summary By Day Report

Unit CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:39 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
05/01/2019	0.00	0.00	0.0	0.00	0.00
05/02/2019	0.00	0.00	0.0	0.00	0.00
05/03/2019	0.00	0.00	0.0	0.00	0.00
05/04/2019	0.00	0.00	0.0	0.00	0.00
05/05/2019	0.00	0.00	0.0	0.00	0.00
05/06/2019	0.00	0.00	0.0	0.00	0.00
05/07/2019	0.00	0.00	0.0	0.00	0.00
05/08/2019	0.00	0.00	0.0	0.00	0.00
05/09/2019	0.00	0.00	0.0	0.00	0.00
05/10/2019	0.00	0.00	0.0	0.00	0.00
05/11/2019	0.00	0.00	0.0	0.00	0.00
05/12/2019	0.00	0.00	0.0	0.00	0.00
05/13/2019	0.00	0.00	0.0	0.00	0.00
05/14/2019	0.00	0.00	0.0	0.00	0.00
05/15/2019	0.00	0.00	0.0	0.00	0.00
05/16/2019	0.00	0.00	0.0	0.00	0.00
05/17/2019	0.00	0.00	0.0	0.00	0.00
05/18/2019	0.00	0.00	0.0	0.00	0.00
05/19/2019	0.00	0.00	0.0	0.00	0.00
05/20/2019	0.00	0.00	0.0	0.00	0.00
05/21/2019	0.00	0.00	0.0	0.00	0.00
05/22/2019	81.13	78.30	5.8	11.51	19.21
05/23/2019	20.40	56.89	5.7	10.86	18.15
05/24/2019	3.31	45.45	4.3	8.47	14.18
05/25/2019	0.00	0.00	0.0	0.00	0.00
05/26/2019	0.00	0.00	0.0	0.00	0.00
05/27/2019	0.00	0.00	0.0	0.00	0.00
05/28/2019	0.00	0.00	0.0	0.00	0.00
05/29/2019	0.00	0.00	0.0	0.00	0.00
05/30/2019	0.00	0.00	0.0	0.00	0.00
05/31/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	104.84 *	180.64 *	15.8 *	30.84 *	51.54 *
Daily Min:	3.31	45.45	4.3	8.47	14.18
Daily Max:	81.13	78.30	5.8	11.51	19.21
Apr 2019 - May 2019	104.84	180.64	15.8	30.84	51.54
QTD:	104.84 *	180.64 *	15.8 *	30.84 *	51.54 *
YTD 2019:	1,712.52 *	4,482.46 *	424.4 *	838.70 *	1,398.25 *

Monthly Summary By Day Report

Unit CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:39 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
06/01/2019	0.00	0.00	0.0	0.00	0.00
06/02/2019	0.00	0.00	0.0	0.00	0.00
06/03/2019	0.00	0.00	0.0	0.00	0.00
06/04/2019	0.00	0.00	0.0	0.00	0.00
06/05/2019	0.00	0.00	0.0	0.00	0.00
06/06/2019	0.00	0.00	0.0	0.00	0.00
06/07/2019	0.00	0.00	0.0	0.00	0.00
06/08/2019	0.00	0.00	0.0	0.00	0.00
06/09/2019	0.00	0.00	0.0	0.00	0.00
06/10/2019	0.00	0.00	0.0	0.00	0.00
06/11/2019	38.15	29.24	1.6	3.15	5.25
06/12/2019	45.47	71.11	6.2	12.41	20.68
06/13/2019	35.67	60.33	5.4	11.33	18.81
06/14/2019	0.00	0.00	0.0	0.00	0.00
06/15/2019	0.00	0.00	0.0	0.00	0.00
06/16/2019	0.00	0.00	0.0	0.00	0.00
06/17/2019	0.00	0.00	0.0	0.00	0.00
06/18/2019	40.42	29.40	1.3	2.86	4.77
06/19/2019	0.00	0.00	0.0	0.00	0.00
06/20/2019	0.00	0.00	0.0	0.00	0.00
06/21/2019	0.00	0.00	0.0	0.00	0.00
06/22/2019	0.00	0.00	0.0	0.00	0.00
06/23/2019	0.00	0.00	0.0	0.00	0.00
06/24/2019	0.00	0.00	0.0	0.00	0.00
06/25/2019	0.00	0.00	0.0	0.00	0.00
06/26/2019	0.00	0.00	0.0	0.00	0.00
06/27/2019	0.00	0.00	0.0	0.00	0.00
06/28/2019	0.00	0.00	0.0	0.00	0.00
06/29/2019	0.00	0.00	0.0	0.00	0.00
06/30/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	159.71 *	190.08 *	14.5 *	29.75 *	49.51 *
Daily Min:	35.67	29.24	1.3	2.86	4.77
Daily Max:	45.47	71.11	6.2	12.41	20.68
Apr 2019 - Jun 2019	264.55	370.72	30.3	60.59	101.05
QTD:	264.55 *	370.72 *	30.3 *	60.59 *	101.05 *
YTD 2019:	1,872.23 *	4,672.54 *	438.9 *	868.45 *	1,447.76 *

ATTACHMENT 19

AQ-63

AQ-63 The Total Facility Emissions shall not exceed the following quarterly emissions rates.

POLLUTANT	Q1 (LBS)	Q2 (LBS)	Q3 (LBS)	Q4 (LBS)	TONS/YEAR
NOX	15546	13412	17646	15572	31.09
CO	27121	33872	28515	30202	59.86
VOC	5832	7455	6672	6890	13.42
PM-10	17854	15513	19378	19158	35.95
SO2	3400	2893	3709	3663	6.83

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 00:00 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/10/2019 13:16 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT1 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
04/01/2019	0.00	0.00	0.00	0.00	0.00
04/02/2019	0.00	0.00	0.00	0.00	0.00
04/03/2019	0.00	0.00	0.00	0.00	0.00
04/04/2019	0.00	0.00	0.00	0.00	0.00
04/05/2019	0.00	0.00	0.00	0.00	0.00
04/06/2019	0.00	0.00	0.00	0.00	0.00
04/07/2019	0.00	0.00	0.00	0.00	0.00
04/08/2019	0.00	0.00	0.00	0.00	0.00
04/09/2019	0.00	0.00	0.00	0.00	0.00
04/10/2019	0.00	0.00	0.00	0.00	0.00
04/11/2019	0.00	0.00	0.00	0.00	0.00
04/12/2019	0.00	0.00	0.00	0.00	0.00
04/13/2019	0.00	0.00	0.00	0.00	0.00
04/14/2019	0.00	0.00	0.00	0.00	0.00
04/15/2019	0.00	0.00	0.00	0.00	0.00
04/16/2019	0.00	0.00	0.00	0.00	0.00
04/17/2019	0.00	0.00	0.00	0.00	0.00
04/18/2019	0.00	0.00	0.00	0.00	0.00
04/19/2019	0.00	0.00	0.00	0.00	0.00
04/20/2019	0.00	0.00	0.00	0.00	0.00
04/21/2019	0.00	0.00	0.00	0.00	0.00
04/22/2019	0.00	0.00	0.00	0.00	0.00
04/23/2019	0.00	0.00	0.00	0.00	0.00
04/24/2019	0.00	0.00	0.00	0.00	0.00
04/25/2019	0.00	0.00	0.00	0.00	0.00
04/26/2019	0.00	0.00	0.00	0.00	0.00
04/27/2019	0.00	0.00	0.00	0.00	0.00
04/28/2019	0.00	0.00	0.00	0.00	0.00
04/29/2019	0.00	0.00	0.00	0.00	0.00
04/30/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	- *	- *	- *	- *	- *
Daily Min:	-	-	-	-	-
Daily Max:	-	-	-	-	-
Apr 2019 - Apr 2019	-	-	-	-	-
QTD:	0.00 *	0.00 *	0.00 *	0.00 *	0.00 *
YTD 2019:	2,567.00 *	7,724.06 *	726.63 *	1,454.24 *	2,423.82 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 00:00 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/10/2019 13:16 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT1 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
05/01/2019	0.00	0.00	0.00	0.00	0.00
05/02/2019	0.00	0.00	0.00	0.00	0.00
05/03/2019	0.00	0.00	0.00	0.00	0.00
05/04/2019	0.00	0.00	0.00	0.00	0.00
05/05/2019	0.00	0.00	0.00	0.00	0.00
05/06/2019	0.00	0.00	0.00	0.00	0.00
05/07/2019	0.00	0.00	0.00	0.00	0.00
05/08/2019	0.00	0.00	0.00	0.00	0.00
05/09/2019	0.00	0.00	0.00	0.00	0.00
05/10/2019	0.00	0.00	0.00	0.00	0.00
05/11/2019	0.00	0.00	0.00	0.00	0.00
05/12/2019	0.00	0.00	0.00	0.00	0.00
05/13/2019	0.00	0.00	0.00	0.00	0.00
05/14/2019	0.00	0.00	0.00	0.00	0.00
05/15/2019	0.00	0.00	0.00	0.00	0.00
05/16/2019	0.00	0.00	0.00	0.00	0.00
05/17/2019	0.00	0.00	0.00	0.00	0.00
05/18/2019	0.00	0.00	0.00	0.00	0.00
05/19/2019	0.00	0.00	0.00	0.00	0.00
05/20/2019	0.00	0.00	0.00	0.00	0.00
05/21/2019	0.00	0.00	0.00	0.00	0.00
05/22/2019	141.84	148.90	11.34	22.68	37.79
05/23/2019	36.81	110.25	10.51	21.05	35.06
05/24/2019	22.41	88.52	8.23	16.44	27.47
05/25/2019	0.00	0.00	0.00	0.00	0.00
05/26/2019	0.00	0.00	0.00	0.00	0.00
05/27/2019	0.00	0.00	0.00	0.00	0.00
05/28/2019	0.00	0.00	0.00	0.00	0.00
05/29/2019	0.00	0.00	0.00	0.00	0.00
05/30/2019	0.00	0.00	0.00	0.00	0.00
05/31/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	201.06 *	347.67 *	30.08 *	60.17 *	100.32 *
Daily Min:	22.41	88.52	8.23	16.44	27.47
Daily Max:	141.84	148.90	11.34	22.68	37.79
Apr 2019 - May 2019	201.06	347.67	30.08	60.17	100.32
QTD:	201.06 *	347.67 *	30.08 *	60.17 *	100.32 *
YTD 2019:	2,768.06 *	8,071.73 *	756.71 *	1,514.41 *	2,524.14 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2019 00:00 **To:** 06/30/2019 00:00 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/10/2019 13:16 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT1 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
06/01/2019	0.00	0.00	0.00	0.00	0.00
06/02/2019	0.00	0.00	0.00	0.00	0.00
06/03/2019	0.00	0.00	0.00	0.00	0.00
06/04/2019	0.00	0.00	0.00	0.00	0.00
06/05/2019	0.00	0.00	0.00	0.00	0.00
06/06/2019	0.00	0.00	0.00	0.00	0.00
06/07/2019	0.00	0.00	0.00	0.00	0.00
06/08/2019	0.00	0.00	0.00	0.00	0.00
06/09/2019	0.00	0.00	0.00	0.00	0.00
06/10/2019	0.00	0.00	0.00	0.00	0.00
06/11/2019	38.15	29.24	1.59	3.15	5.25
06/12/2019	95.16	128.42	11.02	22.03	36.70
06/13/2019	35.67	60.33	5.68	11.33	18.81
06/14/2019	0.00	0.00	0.00	0.00	0.00
06/15/2019	0.00	0.00	0.00	0.00	0.00
06/16/2019	0.00	0.00	0.00	0.00	0.00
06/17/2019	0.00	0.00	0.00	0.00	0.00
06/18/2019	40.37	29.40	1.42	2.86	4.77
06/19/2019	0.00	0.00	0.00	0.00	0.00
06/20/2019	0.00	0.00	0.00	0.00	0.00
06/21/2019	0.00	0.00	0.00	0.00	0.00
06/22/2019	0.00	0.00	0.00	0.00	0.00
06/23/2019	0.00	0.00	0.00	0.00	0.00
06/24/2019	0.00	0.00	0.00	0.00	0.00
06/25/2019	0.00	0.00	0.00	0.00	0.00
06/26/2019	0.00	0.00	0.00	0.00	0.00
06/27/2019	0.00	0.00	0.00	0.00	0.00
06/28/2019	0.00	0.00	0.00	0.00	0.00
06/29/2019	0.00	0.00	0.00	0.00	0.00
06/30/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	209.35 *	247.39 *	19.71 *	39.37 *	65.53 *
Daily Min:	35.67	29.24	1.42	2.86	4.77
Daily Max:	95.16	128.42	11.02	22.03	36.70
Apr 2019 - Jun 2019	410.41	595.06	49.79	99.54	165.85
QTD:	410.41 *	595.06 *	49.79 *	99.54 *	165.85 *
YTD 2019:	2,977.41 *	8,319.12 *	776.42 *	1,553.78 *	2,589.67 *

Tons 12 Month Rolling Summary

CT1 and CT2 Combined

From: 04/01/2019 00:00 **To:** 06/30/2019 00:00 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/11/2019 10:28 **Location:** Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2 CO, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 NOX, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 PM10, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 SO2, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 VOC, Ton 1 Day(s) Sum	Rolling Sum
Apr 2019	0.0000	4.2084	0.0000	10.5665	0.0000	1.9746	0.0000	0.9870	0.0000	3.2909
May 2019	0.1005	3.9382	0.1739	10.5337	0.0300	1.9759	0.0151	0.9877	0.0501	3.2932
Jun 2019	0.1047	3.9566	0.1237	10.5647	0.0197	1.9831	0.0098	0.9913	0.0328	3.3053
Sum/Avg	3.9586		10.5647		1.9831		0.9913		3.3053	
Limit Value										

Replace the dates with the ones you need

4/1/2019 0:00
6/30/2019 0:00

1D

TOWER AVG.

1238

	519-AIT-9504-1
4/1/19 0:00	1101.9
4/2/19 0:00	1109.3
4/3/19 0:00	1104.7
4/4/19 0:00	1112.3
4/5/19 0:00	1119.6
4/6/19 0:00	1114.8
4/7/19 0:00	1186.9
4/8/19 0:00	1165.3
4/9/19 0:00	1088.5
4/10/19 0:00	1019.1
4/11/19 0:00	1021.9
4/12/19 0:00	1031.1
4/13/19 0:00	1053.2
4/14/19 0:00	1111.5
4/15/19 0:00	1014.0
4/16/19 0:00	955.7
4/17/19 0:00	1158.7
4/18/19 0:00	1191.1
4/19/19 0:00	1274.6
4/20/19 0:00	1283.4
4/21/19 0:00	1150.6
4/22/19 0:00	1136.1
4/23/19 0:00	1168.2
4/24/19 0:00	1197.5
4/25/19 0:00	1232.5
4/26/19 0:00	1204.1
4/27/19 0:00	1176.7
4/28/19 0:00	1189.3
4/29/19 0:00	1098.9
4/30/19 0:00	1085.8
5/1/19 0:00	1032.5
5/2/19 0:00	1012.4
5/3/19 0:00	1031.9
5/4/19 0:00	1056.1
5/5/19 0:00	1113.8
5/6/19 0:00	1061.3
5/7/19 0:00	1054.9
5/8/19 0:00	1106.2
5/9/19 0:00	1142.6
5/10/19 0:00	1138.0
5/11/19 0:00	1155.2
5/12/19 0:00	1167.5
5/13/19 0:00	1134.3
5/14/19 0:00	1107.8
5/15/19 0:00	1098.6
5/16/19 0:00	1081.7
5/17/19 0:00	1029.1
5/18/19 0:00	1060.5
5/19/19 0:00	1017.1

5/20/19 0:00	980.8
5/21/19 0:00	990.9
5/22/19 0:00	906.1
5/23/19 0:00	2270.7
5/24/19 0:00	2573.1
5/25/19 0:00	2299.8
5/26/19 0:00	1794.4
5/27/19 0:00	1416.2
5/28/19 0:00	1339.1
5/29/19 0:00	1319.0
5/30/19 0:00	1287.3
5/31/19 0:00	1236.8
6/1/19 0:00	1234.7
6/2/19 0:00	1232.7
6/3/19 0:00	1201.8
6/4/19 0:00	1201.1
6/5/19 0:00	1171.7
6/6/19 0:00	1155.5
6/7/19 0:00	1058.8
6/8/19 0:00	1015.4
6/9/19 0:00	1094.0
6/10/19 0:00	1071.6
6/11/19 0:00	1282.9
6/12/19 0:00	1410.6
6/13/19 0:00	2161.8
6/14/19 0:00	2533.1
6/15/19 0:00	1958.1
6/16/19 0:00	1697.1
6/17/19 0:00	1592.3
6/18/19 0:00	1317.8
6/19/19 0:00	1611.6
6/20/19 0:00	1245.2
6/21/19 0:00	1124.5
6/22/19 0:00	1057.8
6/23/19 0:00	1228.5
6/24/19 0:00	1242.0
6/25/19 0:00	1280.8
6/26/19 0:00	1160.2
6/27/19 0:00	1102.3
6/28/19 0:00	1100.2
6/29/19 0:00	1099.7
6/30/19 0:00	1110.9

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
Circ pump flow rate	**64,550,969**	Pounds per day

	1238	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
Total dissolved solids	**0.00079232**	

Design drift rate	**0.005%**
PM-10 pounds per day	2.56
	91 Days in quarter
PM-10 pounds this quarter	233

2Q19

ATTACHMENT 20

AQ68

AQ68 A water sample analysis of cooling tower water shall be performed within 180 days of initial operation and annually thereafter.

Verification; The Project owner shall submit to the CPM and the PCAPCD the initial and annual cooling tower water sample analysis for approval no later than 60 days following the date of test performance.

The Cooling Tower Water Analysis was reported with the 1Q19 QAQR.

ATTACHMENT 21

AQ-69

AQ-69 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-69 of Roseville Energy Park's 2Q19 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

ATTACHMENT 22

AQ-70

AQ-70 PM-10 emission rates from the cooling tower shall not exceed the following limits

Cooling Tower Emissions Limitations					
Pollutant	Lbs/day	Quarter 1	Quarter 2	Quarter 3	Quarter 4
PM 10	16.3	1471	1487	1504	1504

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

4/1/2019 0:00
6/30/2019 0:00

1D

TOWER AVG.

1238

	519-AIT-9504-1
4/1/19 0:00	1101.9
4/2/19 0:00	1109.3
4/3/19 0:00	1104.7
4/4/19 0:00	1112.3
4/5/19 0:00	1119.6
4/6/19 0:00	1114.8
4/7/19 0:00	1186.9
4/8/19 0:00	1165.3
4/9/19 0:00	1088.5
4/10/19 0:00	1019.1
4/11/19 0:00	1021.9
4/12/19 0:00	1031.1
4/13/19 0:00	1053.2
4/14/19 0:00	1111.5
4/15/19 0:00	1014.0
4/16/19 0:00	955.7
4/17/19 0:00	1158.7
4/18/19 0:00	1191.1
4/19/19 0:00	1274.6
4/20/19 0:00	1283.4
4/21/19 0:00	1150.6
4/22/19 0:00	1136.1
4/23/19 0:00	1168.2
4/24/19 0:00	1197.5
4/25/19 0:00	1232.5
4/26/19 0:00	1204.1
4/27/19 0:00	1176.7
4/28/19 0:00	1189.3
4/29/19 0:00	1098.9
4/30/19 0:00	1085.8
5/1/19 0:00	1032.5
5/2/19 0:00	1012.4
5/3/19 0:00	1031.9
5/4/19 0:00	1056.1
5/5/19 0:00	1113.8
5/6/19 0:00	1061.3
5/7/19 0:00	1054.9
5/8/19 0:00	1106.2
5/9/19 0:00	1142.6
5/10/19 0:00	1138.0
5/11/19 0:00	1155.2
5/12/19 0:00	1167.5
5/13/19 0:00	1134.3
5/14/19 0:00	1107.8
5/15/19 0:00	1098.6
5/16/19 0:00	1081.7
5/17/19 0:00	1029.1
5/18/19 0:00	1060.5
5/19/19 0:00	1017.1

5/20/19 0:00	980.8
5/21/19 0:00	990.9
5/22/19 0:00	906.1
5/23/19 0:00	2270.7
5/24/19 0:00	2573.1
5/25/19 0:00	2299.8
5/26/19 0:00	1794.4
5/27/19 0:00	1416.2
5/28/19 0:00	1339.1
5/29/19 0:00	1319.0
5/30/19 0:00	1287.3
5/31/19 0:00	1236.8
6/1/19 0:00	1234.7
6/2/19 0:00	1232.7
6/3/19 0:00	1201.8
6/4/19 0:00	1201.1
6/5/19 0:00	1171.7
6/6/19 0:00	1155.5
6/7/19 0:00	1058.8
6/8/19 0:00	1015.4
6/9/19 0:00	1094.0
6/10/19 0:00	1071.6
6/11/19 0:00	1282.9
6/12/19 0:00	1410.6
6/13/19 0:00	2161.8
6/14/19 0:00	2533.1
6/15/19 0:00	1958.1
6/16/19 0:00	1697.1
6/17/19 0:00	1592.3
6/18/19 0:00	1317.8
6/19/19 0:00	1611.6
6/20/19 0:00	1245.2
6/21/19 0:00	1124.5
6/22/19 0:00	1057.8
6/23/19 0:00	1228.5
6/24/19 0:00	1242.0
6/25/19 0:00	1280.8
6/26/19 0:00	1160.2
6/27/19 0:00	1102.3
6/28/19 0:00	1100.2
6/29/19 0:00	1099.7
6/30/19 0:00	1110.9

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
Circ pump flow rate	**64,550,969**	Pounds per day

	1238	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
Total dissolved solids	**0.00079232**	

Design drift rate	**0.005%**
PM-10 pounds per day	2.56
	91 Days in quarter
PM-10 pounds this quarter	233

2Q19

ATTACHMENT 23

AQ-71

AQ-71 Compliance with the cooling tower PM-10 emission limit shall be demonstrated as follows: PM-10 = cooling water recirculation rate* total dissolved solids concentration in the blow own water* design drift rate.

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

4/1/2019 0:00
6/30/2019 0:00

1D

TOWER AVG.

1238

	519-AIT-9504-1
4/1/19 0:00	1101.9
4/2/19 0:00	1109.3
4/3/19 0:00	1104.7
4/4/19 0:00	1112.3
4/5/19 0:00	1119.6
4/6/19 0:00	1114.8
4/7/19 0:00	1186.9
4/8/19 0:00	1165.3
4/9/19 0:00	1088.5
4/10/19 0:00	1019.1
4/11/19 0:00	1021.9
4/12/19 0:00	1031.1
4/13/19 0:00	1053.2
4/14/19 0:00	1111.5
4/15/19 0:00	1014.0
4/16/19 0:00	955.7
4/17/19 0:00	1158.7
4/18/19 0:00	1191.1
4/19/19 0:00	1274.6
4/20/19 0:00	1283.4
4/21/19 0:00	1150.6
4/22/19 0:00	1136.1
4/23/19 0:00	1168.2
4/24/19 0:00	1197.5
4/25/19 0:00	1232.5
4/26/19 0:00	1204.1
4/27/19 0:00	1176.7
4/28/19 0:00	1189.3
4/29/19 0:00	1098.9
4/30/19 0:00	1085.8
5/1/19 0:00	1032.5
5/2/19 0:00	1012.4
5/3/19 0:00	1031.9
5/4/19 0:00	1056.1
5/5/19 0:00	1113.8
5/6/19 0:00	1061.3
5/7/19 0:00	1054.9
5/8/19 0:00	1106.2
5/9/19 0:00	1142.6
5/10/19 0:00	1138.0
5/11/19 0:00	1155.2
5/12/19 0:00	1167.5
5/13/19 0:00	1134.3
5/14/19 0:00	1107.8
5/15/19 0:00	1098.6
5/16/19 0:00	1081.7
5/17/19 0:00	1029.1
5/18/19 0:00	1060.5
5/19/19 0:00	1017.1

5/20/19 0:00	980.8
5/21/19 0:00	990.9
5/22/19 0:00	906.1
5/23/19 0:00	2270.7
5/24/19 0:00	2573.1
5/25/19 0:00	2299.8
5/26/19 0:00	1794.4
5/27/19 0:00	1416.2
5/28/19 0:00	1339.1
5/29/19 0:00	1319.0
5/30/19 0:00	1287.3
5/31/19 0:00	1236.8
6/1/19 0:00	1234.7
6/2/19 0:00	1232.7
6/3/19 0:00	1201.8
6/4/19 0:00	1201.1
6/5/19 0:00	1171.7
6/6/19 0:00	1155.5
6/7/19 0:00	1058.8
6/8/19 0:00	1015.4
6/9/19 0:00	1094.0
6/10/19 0:00	1071.6
6/11/19 0:00	1282.9
6/12/19 0:00	1410.6
6/13/19 0:00	2161.8
6/14/19 0:00	2533.1
6/15/19 0:00	1958.1
6/16/19 0:00	1697.1
6/17/19 0:00	1592.3
6/18/19 0:00	1317.8
6/19/19 0:00	1611.6
6/20/19 0:00	1245.2
6/21/19 0:00	1124.5
6/22/19 0:00	1057.8
6/23/19 0:00	1228.5
6/24/19 0:00	1242.0
6/25/19 0:00	1280.8
6/26/19 0:00	1160.2
6/27/19 0:00	1102.3
6/28/19 0:00	1100.2
6/29/19 0:00	1099.7
6/30/19 0:00	1110.9

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
Circ pump flow rate	**64,550,969**	Pounds per day

	1238	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
Total dissolved solids	**0.00079232**	

Design drift rate	**0.005%**
PM-10 pounds per day	2.56
	91 Days in quarter
PM-10 pounds this quarter	233

2Q19

ATTACHMENT 24

AQ-86

AQ-86 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	TECH	TIME START-S/D		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07	BI-WEEKLY TEST	97	305
1/6/19	LAO	1241 - 139	BI-WEEKLY TEST	97	30
1-20-19	Ray	0825 - 0855	Bi-Weekly Test	98	60
1-29-19	Ray	1013 - 1043	Bi-Weekly Test	98	90
2-17-19	Ry	1035 - 1105	Bi-Weekly Test	99	120
3-11-19	E.O.	0734 - 0770	OUTAGE / BLACK PRINT	99	126
4-29-19	ME	0920-0950	TEST / Unmatch	99	156
4/29/2019	ME	1202-1206	Post Maint Parameters	99	160

ATTACHMENT 25

AQ-87

AQ-87 Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	START	REASON	STOP	INITIALS	TOTAL	YTD
11/6/2018	0949	Inspection/Weekly	1019	WR	146.7	18.7
11-16-18		Cosco Fire connect pump	start	DWN	147.0	19.0
11-18-18	1434	Weekly Test	1504	DWN	147.5	19.5
11-25-2018	1420	Weekly Test	1500	RC	148.0	20.0
12-3-18	1604	Weekly Test Run	1638	BP	148.5	20.5
12-9-18	14[illegible]	Weekly test run	1850	KDS	149.0	21.0
12-16-18	1300	WEEKLY TEST RUN	1330	DB	149.5	21.5
12-24-18	15:39	WEEKLY TEST RUN	16:09	E.O.	150.0	22.0
12-30-18	13:49	WEEKLY TEST RUN		E.O.	150.5	22.5

2019

DATE	START	REASON	STOP	INITIALS	TOTAL	YTD
1-6-19	1348	WEEKLY TEST RUN	1418	KAB	151	.5
1-13-19	1339	WEEKLY TEST RUN	1409	DB	151.5	1.0
1-20-19	1027	Weekly Test	1057	RC	152	1.5
1-27-19	1211	WEEKLY TEST	1241	KAB	152.5	2.0
1-29-19	1029	Weekly Test	1059	RC	153.0	2.5
2-10-19	1532	Weekly Test	1552	WR	153.5	3.0
2-17-19	1500	Weekly Test	1530	RC	154.0	3.5
2-24-19	1630	weekly test	1700	EP	154.5	4.0
3-10-19	1635	WEEKLY TEST	1605	RC	155.0	4.5
3-17-19	[illegible]	Weekly Test	[illegible]	RC	155.5	5.0
3-24-19	1235	Weekly Test	1305	KDS	156.0	5.5
3-30-19	1646	WEEKLY TEST RUN	1716	KAB	156.5	6.0
4-7-19	1530	WEEKLY TES RUN	1600	RC	157.0	6.5
4/14/19	1412	Weekly Test Run	1442	RC	157.5	7.0
4/21/19	1448	Weekly Test Run	1518	WR	158.0	7.5
4/28/19	1357	Weekly Test Run	1427	WR	158.5	8.0
4/29/19	1045	Post Maint Demo	1045	WR	158.5	8.0
5/5/19	1436	WEEKLY TEST RUN	1500	RC	159.0	8.5
5/6/19	1325	MAINTENANCE RUN	1330	RC	159.1	8.6
5/7/19	1131	TEST RUN & FIRE [illegible]	1133	DB	159.1	8.6
5/12/19	1100	Weekly Test	1130	RC	159.6	9.1
5-19-19	1104	Weekly Test	1138	EP	160.1	9.6
5/26/19	1329	Weekly Test	1359	WR	160.6	10.1
6-2-19	1220	WEEKLY TEST	1250	RC	161.1	10.6

DATE	START	REASON	STOP	INITIALS	TOTAL	YTD
6-09-2019	1328	Weekly Test	1358	RC	161.6	11.1
6-15-2019	1611	Weekly Test	1641	WR	162.1	11.6
6-22-2019	1630	Weekly Test	1700	WR	162.6	12.1
6-30-2019	1020	WEEKLY TEST	1050	RC	163.1	12.6
7-7-2019	1128	Weekly Test	1158	KB	163.6	13.1

ATTACHMENT 26

AQ-88

AQ-88 The Sulfur content of the Diesel fuel used shall not exceed 15 ppm by weight.

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report as required in Condition of Certification AQ-SC6.

ATTACHMENT 27

AQ-89

AQ-89 Records of operation and maintenance shall be kept by the owner or Operator for a period of five years and shall be made available to the PCAPCD upon request. Information required for reporting to the PCAPCD includes, but is not limited to:

1. The hours of operation the engine was run for maintenance and testing;
2. The hours of operation the engine was run during interruption of electrical power; and
3. Records of the sulfur content of the diesel used.

VERIFICATION: The Project owner shall include these records as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	TECH	TIME START - S/D		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07	BI-WEEKLY TEST	97	905
1/6/19	RAD	1241 - 139	BI-WEEKLY TEST	97	30
1-20-19	Ray	0925-0955	Bi-Weekly Test	98	60
1-29-19	Ray	1013 - 1043	Bi Weekly Test	98	90
2-17-19	RG	1035 - 1105	Bi Weekly Test	99	120
3-11-19	E.O.	0700 - 0730	OVERAGE / BLACK PLANT	99	126
4-29-19	ME	0920-0950	TEST / Wamalton	99	156
4/29/2019	ME	1202-1204	Post Maint Functions	99	160

ATTACHMENT 28

AQ-90

AQ-90 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-90of Roseville Energy Park's 2Q19 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

ATTACHMENT 29

AQ-91

AQ-91 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-91of Roseville Energy Park's 2Q19 QAQR, there were no violations of PCAPCD's Rule 202 for opacity from the diesel fire pump.

ATTACHMENT 30

AQ-99

AQ-99 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project shall include all necessary operational data to demonstrate compliance with the limits provided as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

DATE	TECH	TIME START-S/D		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07	BI-WEEKLY TEST	97	805
1/6/19	HRO	1241 - 139	BI-WEEKLY TEST	97	30
1-20-19	Kg	0325-0335	Bi-Weekly Test	98	60
1-29-19	Fg	1013 - 1043	Bi-Weekly Test	98	90
2-17-19	Kg	1035 - 1105	Bi-Weekly Test	99	120
3-11-19	E.O.	0724 - 0730	OVERAGE / BLANK PLATE	99	126
4-29-19	ME	0920-0950	TEST / Wm Alto	99	156
4/29/2019	ME	1202-1206	Post Mint Printer	99	160

ATTACHMENT 31

AQ-100

AQ-100 In regards to the Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

DATE	TECH	Time START - S/D		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07	Bi-WEEKLY TEST	97	905
1/6/19	[illegible]	1241 - 139	BI-WEEKLY TEST	97	30
1-20 19	[illegible]	[illegible]	[illegible]	[illegible]	60
1-29-19	Ray	1013 - 1043	Bi-Weekly Test	98	90
2-17-19	Rg.	1035 - 1105	Bi-Weekly Test	99	120
3-11-19	EO.	0704 - 0730	OUTAGE / BLACK PLANT	99	126
4-29-19	ME	0920-0950	TEST / [illegible]	99	156
4/29/2019	ME	1202-1204	Post-Maint Functions	99	160

ATTACHMENT 32

AQ-101

AQ-101 The sulfur content of the diesel used shall not exceed 15ppm by weight

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report in Condition of Certification AQ-SC6

ATTACHMENT 33

AQ-102

AQ-102 Records of operation and maintenance shall be kept by the owner or operator for a period of five years and shall be made available to the PCAPCD by request. Information required for reporting to the PCAPCD includes, but is not limited to:

A. Hours of operation the engine was run for maintenance and testing
B. Hours of operation the engine was run during interruption of electrical power
C. Records of sulfur content of the diesel fuel used

Verification: The Project owner shall include these records as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

DATE	TECH	TIME START-S/D		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/19	E.O.	1337 - 14:07	BI-WEEKLY TEST	97	805
1/6/19	AAO	1241 - 1318	BI-WEEKLY TEST	97	30
1-20-19	KJ	0825-0955	Bi-Weekly Test	98	60
1-29-19	Ray	1013 - 1043	Bi-Weekly Test	98	90
2-11-19	RG	1035 - 1105	Bi-Weekly Test	99	120
3-11-19	E.O.	0700 - 0730	OVERHAUL / BLOCK PLANT	99	126
4-29-19	MLR	0920-0950	TEST / [illegible]	99	156
4/29/2019	ME	1202-1206	Post Maint Pressures	99	160

ATTACHMENT 34

AQ-103

AQ-103 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-103 of Roseville Energy Park's 2Q19 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

ATTACHMENT 35

AQ-104

AQ-104 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite opacity complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-104 of Roseville Energy Park's 2Q19 QAQR, there were no violations of PCAPCD's Rule 202 for opacity from stack emissions of the emergency diesel generator.

List of Attachments

Attachment 1: AQ15 – SCR Installed before commissioning in 2007

Attachment 2: AQ20 - The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas

Attachment 3: AQ21 – Startups and Shutdowns

Attachment 4: AQ32 – All hourly, quarter NOx and CO emissions AQ-SC6

Attachment 5: AQ33 – All hourly, daily, and quarterly Sox AQ-SC6

Attachment 6: AQ34 – Start Up and Shut downs

Attachment 7: AQ36 – Breakdown condition

Attachment 8: AQ37 – Violations of Emissions

Attachment 9: AQ40 – CEMS quality assurance test failures

Attachment 10: AQ41 – Excess Emissions

Attachment 11: AQ42 – Running 12 month summary

Attachment 12: AQ47 – All nuisance violations

N/A for this report period

Attachment 13: AQ48 – Nuisance complaints and stack emission opacity as dark as Ringlemann No. 1 (20% opacity) for periods aggregating more than 3 min.

N/A for this report period

Attachment 14: AQ51 – Ammonia slip exceedances

Attachment 15: AQ55 – Emission rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown – NOx and CO

Attachment 16: AQ57 – Emission exceedance rates during startup and shutdown – CO, NOX, PM-10, SOX, and VOC

Attachment 17: AQ59 – Emission limit exceedances – NOX, CO, VOC, PM-10, SO2

Attachment 18: AQ60 – Quarterly emission exceedances for Alstom GTX100 turbine – NOx, CO, VOCs, PMO, Sox

Attachment 19: AQ63 – Total facility emission exceedances – NOX, CO, VOC, PM-10, SO2

Attachment 20: AQ68 – Annual water sample analysis of cooling tower water

Attachment 21: AQ69 – Nuisance complaints

None

Attachment 22: AQ70 – PM-10 quarterly emission rate exceedances from cooling tower

Attachment 23: AQ71 – Exceedance of cooling tower PM-10 emission limit – PM-10 = cooling water recirculation rate*total dissolved solids concentration in the blow own water* design drift rate

Attachment 24: AQ86 – Limits for operation for maintenance and testing of emergency diesel engine and generator limited to 50 hours per year

Attachment 25: AQ87 – Operation for maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours

Attachment 26: AQ88 – Sulfur content of diesel fuel used shall not exceed 15 ppm by weight

N/A for this report period

Attachment 27: AQ89 – Records of hours of operation engine run for maintenance and testing, during interruption of electrical power, records of sulfur content of diesel used for five years

Attachment 28: AQ90 – No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance

N/A for this report period

Attachment 29: AQ91 – Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions

N/A for this report period

Attachment 30: AQ99 – Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Attachment 31: AQ100 – Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power

Attachment 32: AQ101 - The sulfur content of the diesel used shall not exceed 15ppm by weight

N/A for this report period

Attachment 33: AQ102 – Records of operation and maintenance shall be kept by the owner or operator for a period of five years

Attachment 34: AQ103 – No emissions are permitted, from any source, which are a nuisance

N/A for this report period

Attachment 35: AQ104 – Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited

N/A for this report period