

DOCKETED	
Docket Number:	19-SPPE-02
Project Title:	Walsh Data Center
TN #:	229547-2
Document Title:	WP LLC's Initial Response to CEC Data Request Set 1 Appendix Part II of II
Description:	N/A
Filer:	Scott Galati
Organization:	DayZenLLC
Submitter Role:	Applicant Representative
Submission Date:	8/26/2019 3:43:41 PM
Docketed Date:	8/26/2019

APPENDIX CRDR-15

7 5-minute Series Topographic Maps (Rosso 2016 11-13)



601-711 Walsh Avenue

601-711 Walsh Avenue

Santa Clara, CA 95050

Inquiry Number: 4771017.4

November 03, 2016

EDR Historical Topo Map Report

with QuadMatch™



6 Armstrong Road, 4th floor
Shelton, CT 06484
Toll Free: 800.352.0050
www.edrnet.com

EDR Historical Topo Map Report

11/03/16

Site Name:

601-711 Walsh Avenue
601-711 Walsh Avenue
Santa Clara, CA 95050
EDR Inquiry # 4771017.4

Client Name:

Rosso Environmental, Inc.
1400 Shattuck Ave, Suite 10
Berkeley, CA 94709
Contact: Philip McLaughlin



EDR Topographic Map Library has been searched by EDR and maps covering the target property location as provided by Rosso Environmental, Inc. were identified for the years listed below. EDR's Historical Topo Map Report is designed to assist professionals in evaluating potential liability on a target property resulting from past activities. EDR's Historical Topo Map Report includes a search of a collection of public and private color historical topographic maps, dating back to the late 1800s.

Search Results:**Coordinates:**

P.O.#	NA	Latitude:	37.370924 37° 22' 15" North
Project:	16-0062.00	Longitude:	-121.947011 -121° 56' 49" West
		UTM Zone:	Zone 10 North
		UTM X Meters:	593235.14
		UTM Y Meters:	4136541.52
		Elevation:	43.98' above sea level

Maps Provided:

2012	1889
1980	
1973	
1968	
1961	
1953	
1899	
1897	

Disclaimer - Copyright and Trademark Notice

This Report contains certain information obtained from a variety of public and other sources reasonably available to Environmental Data Resources, Inc. It cannot be concluded from this Report that coverage information for the target and surrounding properties does not exist from other sources. NO WARRANTY EXPRESSED OR IMPLIED, IS MADE WHATSOEVER IN CONNECTION WITH THIS REPORT. ENVIRONMENTAL DATA RESOURCES, INC. SPECIFICALLY DISCLAIMS THE MAKING OF ANY SUCH WARRANTIES, INCLUDING WITHOUT LIMITATION, MERCHANTABILITY OR FITNESS FOR A PARTICULAR USE OR PURPOSE. ALL RISK IS ASSUMED BY THE USER. IN NO EVENT SHALL ENVIRONMENTAL DATA RESOURCES, INC. BE LIABLE TO ANYONE, WHETHER ARISING OUT OF ERRORS OR OMISSIONS, NEGLIGENCE, ACCIDENT OR ANY OTHER CAUSE, FOR ANY LOSS OF DAMAGE, INCLUDING, WITHOUT LIMITATION, SPECIAL, INCIDENTAL, CONSEQUENTIAL, OR EXEMPLARY DAMAGES. ANY LIABILITY ON THE PART OF ENVIRONMENTAL DATA RESOURCES, INC. IS STRICTLY LIMITED TO A REFUND OF THE AMOUNT PAID FOR THIS REPORT. Purchaser accepts this Report "AS IS". Any analyses, estimates, ratings, environmental risk levels or risk codes provided in this Report are provided for illustrative purposes only, and are not intended to provide, nor should they be interpreted as providing any facts regarding, or prediction or forecast of, any environmental risk for any property. Only a Phase I Environmental Site Assessment performed by an environmental professional can provide information regarding the environmental risk for any property. Additionally, the information provided in this Report is not to be construed as legal advice.


Copyright 2016 by Environmental Data Resources, Inc. All rights reserved. Reproduction in any media or format, in whole or in part, of any report or map of Environmental Data Resources, Inc., or its affiliates, is prohibited without prior written permission.

EDR and its logos (including Sanborn and Sanborn Map) are trademarks of Environmental Data Resources, Inc. or its affiliates. All other trademarks used herein are the property of their respective owners.


Topo Sheet Key

This EDR Topo Map Report is based upon the following USGS topographic map sheets.

2012 Source Sheets



San Jose West
2012
7.5-minute, 24000




Milpitas
2012
7.5-minute, 24000

1980 Source Sheets




San Jose West
1980
7.5-minute, 24000
Photo Revised 1980
Aerial Photo Revised 1979




Milpitas
1980
7.5-minute, 24000
Photo Revised 1980
Aerial Photo Revised 1979

1973 Source Sheets




Milpitas
1973
7.5-minute, 24000
Photo Revised 1973
Aerial Photo Revised 1973



San Jose West
1973
7.5-minute, 24000
Photo Revised 1973
Aerial Photo Revised 1973

1968 Source Sheets



Milpitas
1968
7.5-minute, 24000
Photo Revised 1968
Aerial Photo Revised 1968




San Jose West
1968
7.5-minute, 24000
Photo Revised 1968
Aerial Photo Revised 1968


Topo Sheet Key

This EDR Topo Map Report is based upon the following USGS topographic map sheets.

1961 Source Sheets



Milpitas
1961
7.5-minute, 24000
Aerial Photo Revised 1960



San Jose West
1961
7.5-minute, 24000
Aerial Photo Revised 1960

1953 Source Sheets




Milpitas
1953
7.5-minute, 24000
Aerial Photo Revised 1948




San Jose West
1953
7.5-minute, 24000
Aerial Photo Revised 1948

1899 Source Sheets



San Jose
1899
15-minute, 62500

1897 Source Sheets




San Jose
1897
15-minute, 62500


Topo Sheet Key


This EDR Topo Map Report is based upon the following USGS topographic map sheets.

1889 Source Sheets




San Jose
1889
15-minute, 62500






This report includes information from the following map sheet(s).




TP, San Jose West, 1980, 7.5-minute
N, Milpitas, 1980, 7.5-minute

SITE NAME: 601-711 Walsh Avenue
ADDRESS: 601-711 Walsh Avenue
Santa Clara, CA 95050
CLIENT: Rosso Environmental, Inc.






This report includes information from the following map sheet(s).




TP, San Jose West, 1973, 7.5-minute
N, Milpitas, 1973, 7.5-minute

SITE NAME: 601-711 Walsh Avenue
ADDRESS: 601-711 Walsh Avenue
Santa Clara, CA 95050
CLIENT: Rosso Environmental, Inc.






This report includes information from the following map sheet(s).





TP, San Jose West, 1968, 7.5-minute
N, Milpitas, 1968, 7.5-minute

SITE NAME: 601-711 Walsh Avenue
ADDRESS: 601-711 Walsh Avenue
Santa Clara, CA 95050
CLIENT: Rosso Environmental, Inc.






This report includes information from the following map sheet(s).




TP, San Jose West, 1961, 7.5-minute
N, Milpitas, 1961, 7.5-minute

SITE NAME: 601-711 Walsh Avenue
ADDRESS: 601-711 Walsh Avenue
Santa Clara, CA 95050
CLIENT: Rosso Environmental, Inc.






This report includes information from the following map sheet(s).



TP, San Jose West, 1953, 7.5-minute
N, Milpitas, 1953, 7.5-minute

SITE NAME: 601-711 Walsh Avenue
ADDRESS: 601-711 Walsh Avenue
Santa Clara, CA 95050
CLIENT: Rosso Environmental, Inc.






This report includes information from the following map sheet(s).



TP, San Jose, 1899, 15-minute

SITE NAME: 601-711 Walsh Avenue
 ADDRESS: 601-711 Walsh Avenue
 Santa Clara, CA 95050
 CLIENT: Rosso Environmental, Inc.






This report includes information from the following map sheet(s).



TP, San Jose, 1897, 15-minute

SITE NAME: 601-711 Walsh Avenue
 ADDRESS: 601-711 Walsh Avenue
 Santa Clara, CA 95050
 CLIENT: Rosso Environmental, Inc.





This report includes information from the following map sheet(s).



TP, San Jose, 1889, 15-minute

SITE NAME: 601-711 Walsh Avenue
 ADDRESS: 601-711 Walsh Avenue
 Santa Clara, CA 95050
 CLIENT: Rosso Environmental, Inc.




APPENDIX PDDR-25

Drawing L-201, Landscape Plan

KEY	QTY.	BOTANICAL NAME	COMMON NAME	SIZE	ROOT	REMARKS	PLANT FACTORS	IRRIGATION
TREE(S)								
QAC	9	QUERCUS AGRIFOLIA	COAST LIVE OAK	2 1/2-3" CAL. 24"BOX	B+B	-	M/L	2
XCT	24	XCHITALPA TASHIKENTENSIS	CHITALPA	2 1/2-3" CAL. 24"BOX	B+B	-	M/L	2
AMA	4	ARBUTUS "MARINA"	MARINA STRAWBERRY TREE	2 1/2-3" CAL. 24"BOX	B+B	SINGLE STEM	L	2
EVERGREEN TREE(S)								
CAF	5	CEDRUS ATLANTICA FASTIGIATA	COLUMNAR BLUE ATLAS CEDAR	10' H MIN. 24"BOX	B+B	-	M/L	2
QDO	7	CEDRUS DEODARA	DEODAR CEDAR	2 1/2" CAL. 24"BOX	B+B	-	M/L	2
EVERGREEN SHRUB(S)								
ADWH	76	ARCTOSTAPHYLOS DENSIFLORA "HOWARD MCMINN"	MAZANTA "MCMINN"	48" H	CONTAINER #5	-	M/L	2
ADH	12	ARCTOSTAPHYLOS "DR HUIRD"	DR HUIRD MANZANITA	36" H	CONTAINER #3	-	M/L	2
CTS	56	CEANOTHUS "HYRSIFLORUS "SKYLARK"	SKYLARK CEANOTHUS	36" H	CONTAINER #5	-	M/L	2
GE	46	GARRYA ELIPTICA	SILK TASSEL	48" H	CONTAINER #5	-	M/L	2
HA	38	ETEROMELES ARBUTIFOLIA	TOYON	48" H	CONTAINER #5	-	M/L	2
ROLS	48	RHAMNUS CALIFORNICA "LITTLE SUR"	LITTLE SUR COFFEEBERRY	30" H	CONTAINER #5	-	M/L	2
DECIDUOUS SHRUB(S)								
MR	100	MAHONIA REPENS	SNOEWING OREGON GRAPE	30" H	CONTAINER #3	-	M/L	
SAL	63	SYMPHORICARPOS ALBUS	CREEPBERRY	30" H	CONTAINER #3	-	M/L	
GROUND COVER								
AEC	184	ARCTOSTAPHYLOS "EMERALD CARPET"	EMERALD CARPET MANZANITA	2 GAL.	CONTAINER	spaced @ 24" o.c.	M/L	2
FC	992	FESTUCA CALIFORNIA	CALIFORNIA FESCUE	1 GAL.	CONTAINER	spaced @ 18" o.c.	M/L	2
RCSI	1225	RHAMNUS CALIFORNICA "SEAVEW IMPROVED"	CALIFORNIA COFFEE BERRY	1 GAL.	CONTAINER	spaced @ 18" o.c.	M/L	2
PERENNIAL(S)								
AMI	388	ACHILLEA MILLEFOLIUM	COMMON YARROW	1 GAL.	CONTAINER	spaced @ 18" o.c.	M/L	2
LDG	417	LAVANDULA DENTATA "GOODWIN CREEK GRAY"	GOODWIN CREEK GRAY LAVENDER	1 GAL.	CONTAINER	spaced @ 24" o.c.	M/L	2
MM	532	MONARDELLA VILLOSA	COYOTE MINT	1 GAL.	CONTAINER	spaced @ 18" o.c.	M/L	2
SWV	207	SALVIA CLEVELANDII "WHIRLY BLUE"	CLEVELAND SAGE	2 GAL.	CONTAINER	spaced @ 24" o.c.	L/V	2
ZCA	336	ZAUSCHNERIA CALIFORNICA	CALIFORNIA FUCHSIA	1 GAL.	CONTAINER	spaced @ 18" o.c.	M/L	2
ORNAMENTAL GRASS(S)								
BGBA	210	BOUTELLOA GRACILIS "BLONDE AMBITION"	BLONDE AMBITION BLUE GRAMA GRASS	1 GAL.	CONTAINER	spaced @ 24" o.c.	L/V/L	2
QAK	296	CALAMAGOSTIS ARUNDINACEA "KARL FOERSTER"	FEATHER REED GRASS	1 GAL.	CONTAINER	spaced @ 24" o.c.	M/L	2
CSGS	390	DESCHAMPSIA CESPYTOSA	TUFTED HAIR GRASS	2 GAL.	CONTAINER	spaced @ 24" o.c.	M	2
IV	1268	IVA HAYESIANA	SAN DIEGO MARSH ELDER	1 GAL.	CONTAINER	spaced @ 18" o.c.	M	2
MRI	190	MUHLENBERGIA RIGENS	DEER GRASS	2 GAL.	CONTAINER	spaced @ 36" o.c.	M/L	2
VINE(S)								
CLA	32	CLEMATIS LASIANTHA	CHAPARRAL CLEMATIS	2 GAL.	CONTAINER	spaced @ 18" o.c.	M/L	2

NOTE: IF ANY DISCREPANCIES OCCUR BETWEEN AMOUNTS SHOWN IN THE PLAN AND THE PLANT LIST, THE PLAN SHALL DICTATE.
IRRIGATION GROUP 2: REDUCED SUMMER WATER.
M/L=15-25 IN. V/VL=10-15 IN.



Ordinance Chart					
Code section		Requirement	Calculation	Proposed	Compliance
Chapter 18.74 Parking	e. Screening and Landscaping	Parking areas which abut upon a public street right-of-way shall provide landscaping to a depth of at least 10 ft of said street right-of-way and of any plan line, with openings for walkway or drive purposes			Complies
		Additional 5% of gross lot area shall be devoted to landscaping. Major canopy trees shall be provided throughout the parking area and adjacent to buildings. Trees shall be spaced at either a min. distance of 30' o.c. or in an alternative design to accomplish an equivalent density of screening and degree of shading	76,447 sqft of parking x 5% =3,822 sqft of landscaped area	45,235 sqft of landscaped area proposed	Complies
12.35 Trees and Shrubs	Street Tree requirement	No tree or shrub shall be planted in the streets of the City. No tree, plant or shrub planted or growing in the streets of the City shall be altered or removed without obtaining a written permit from the superintendent of streets.			Permit required
18.50 MH-Heavy Industrial Zoning Districts	120. Open landscaped area	A minimum of 10ft of the required front and street side yards, exclusive of City-permitted driveway cuts, shall be developed into and permanently maintained as open landscaped areas			Complies
		A minimum landscaped area equal to at least 10% of the required parking area to be evenly distributed throughout the parking area and adjacent to buildings	76,447 sqft of parking x 10% =7,645 sqft of landscaped area	45,235 sqft of landscaped area proposed	Complies
	140.a.Fencing	Fencing shall not exceed 3ft in height in required frontage landscaping			Complies
		outdoor storage areas shall be screened from the street by a minimum 6ft high solid fence located behind required frontage landscaping		12 ft green fence provided	Complies
		c. Lighting	Lighting shall reflect away from residential areas and public streets		
d. Trash disposal	screened by a masonry enclosure, with solid wood gates, at least 6ft in height.			N.A.	
18.88.040	Landscape Irrigation	Landscape and irrigation design plans are required of landscape projects larger than 2,500 sqft		Irrigation provided	Complies

PCC Meeting Comments			Calculation	Proposed	Compliance
C4	Page 3, PCC Comments Jan 15, 2019	Landscaping installation shall meet City water conservation criteria in a manner acceptable to the Director of Planning and Inspection			Complies
C8	Page 7, PCC Comments Jan 15, 2019	Project shall provide a 5' wide sidewalk and at least 4' wide landscaping strip along the project frontage.		5' wide sidewalk and 4' wide landscaping strip provided	Complies
C9	Page 7, PCC Comments Jan 15, 2020	A complete landscape plan that includes, type, size and location of all plant species shall be required as part of architectural review of the project. Review and approval of the complete landscape plan, including water conservation calculations and irrigation plan shall be required prior to issuance of building permits. Installation of landscaping is required prior to occupancy permits.			Complies
C10	Page 8, PCC Comments Jan 15, 2021	Site landscaping shall be maintained in good condition throughout the life of the Development. No trees shall be removed without City review and approval and shall be replaced at a minimum of 2:1 with 24" box species approved by the City.	24 existing trees to be demolished x2 =48 proposed trees	48 proposed trees with 24" box	Complies

exp U.S. Services Inc.

t: +1.312.616.0000 f: +1.312.616.6069
205 North Michigan Avenue
Chicago, IL 60601
USA

www.exp.com



- BUILDINGS • EARTH & ENVIRONMENT • ENERGY •
- INDUSTRIAL • INFRASTRUCTURE • SUSTAINABILITY

CAUTION: DO NOT SCALE DRAWINGS.
THIS REPRODUCTION MAY BE AT A SIZE DIFFERENT THAN ORIGINALLY DRAWN. EXP
ASSUMES NO RESPONSIBILITY FOR INCORRECT SCALING. UNAUTHORIZED REPRODUCTION
OR USE IS STRICTLY PROHIBITED. NOT PUBLISHED - ALL RIGHTS RESERVED. EXP
EXPRESSLY DISCLAIMS RESPONSIBILITY ARISING FROM UNAUTHORIZED USE OF THESE
DRAWINGS AND NOTES. AUTHORIZATION MUST BE IN WRITING.

Project No.:770656701

LANGAN

Langan Engineering, Environmental, Surveying,
Landscape Architecture and Geology, D.P.C.
1 Almaden Boulevard, Suite 590
San Jose, CA 95113

T: 408.283.3600 F: 408.283.3601 www.langan.com

[illegible]

CONSTRUCTION DOCUMENTS

Professional Seal(s)

**NOT FOR
CONSTRUCTION**

Drawn By: **LANGAN**

Checked By: **LANGAN**

Approved By: **LANGAN**

Date Printed

File Name: L-201 - LANDSCAPE PLAN

Project Title

DLR 651 WALSH SANTA CLARA
PHASE 2A - CORE & SHELL
BUILDING
651 Walsh Ave,
Santa Clara, CA 95050
DLR Building Number: SJC-37

Dwg. Title

LANDSCAPE PLAN

Project No. 770656701


Dwg. No. **L-201**

Rev. No.

APPENDIX PDDR-27


Overall Utility Plan

OVERALL UTILITY PLAN



APPENDIX PDDR-31

SVP Typical Transmission Pole Configurations







MATERIAL ASSEMBLIES			
ITEM NO.	ASSEMBLY DESCRIPTION	ASSEMBLY DRAWING	QTY
1	60 kV DE INSULATOR, 715 KCM, ACCR, BUNDLED	PSI-A-T006-2	6
2	60 kV JUMPER POST, FLAT BASE, DBL. TRUNNION	PSI-A-T006-3	3
3	DE FIBERGLASS ARM, 10 FT. W/ INSULATOR ASSEMBLIES	PSI-A-T006-5	1
4	GROUND ROD ASSEMBLY	PER SVP STANDARDS	1

UNIQUE MATERIALS FOR PSI-B-T005-SH1					
ITEM	STOCK NO.	MATERIAL DESCRIPTION	VENDOR OR SVP BIN NO.	PART NO.	QTY
5	67	BOLT, SQUARE HEAD, 5/8IN DIA. X 5IN LONG, 3IN THREAD, WITH NUT	BIN NO. 70009	—	6
6	32	WASHER, ROUND, FLAT, GALV. STEEL, 5/8IN, 2IN O.D.	HUGHES BROTHERS	RW2-60	12
7	38	NUT, LOCK, 5/8IN, SQUARE	HUGHES BROTHERS	MF60	6
8	69	BOLT, SQUARE HEAD, 3/4IN DIA. X 6IN LONG, 4IN THREAD, WITH NUT	BIN NO. 70082	—	2
9	35	WASHER, ROUND, FLAT, GALV. STEEL, 3/4IN, 2IN O.D.	BIN NO. 70044	JOSLYN #J1089	4
10	36	NUT, LOCK, 3/4IN, SQUARE	HUGHES BROTHERS	MF70	2

STRUCTURE TABLE				
STRUCTURE NUMBER	STRUCTURE RAKE MEASURED AT TOP OF POLE (IN)	DIRECTION OF RAKE	POLE HEIGHT "H"	STRUCTURE QUANTITY
PAR-KEN 2	NOT REQUIRED	NOT REQUIRED	62'-0"	1

- NOTES:
- DISTANCE AND DIRECTION OF RAKE SHALL BE AS SHOWN IN THE STRUCTURE TABLE.
 - REFER TO DRAWING PSI-B-T003-1 FOR FOUNDATION DETAILS.
 - TRANSFER EXISTING CUT-OUT ARM, 3 POT TRANSFORMER BANK, CONDUCTORS, AND BOTH BRACKETS USED TO SUPPORT THE SERVICE SPAN FROM EXISTING STRUCTURE 57E14 TO STRUCTURE PAR-KEN 2 AT THE LOCATIONS SHOWN ON THE NEW STEEL POLE.
 - TRANSFER WIRE AND CLAMPS FROM EXISTING STRUCTURE 57E14 TO STRUCTURE PAR-KEN 2. THE FUSE CUTOUTS SHALL BE MOUNTED ON THE SIDE OF THE CROSSARM THAT IS FURTHEST FROM THE STEEL POLE.

ISSUED FOR CONSTRUCTION



MATERIAL ASSEMBLIES

ITEM NO.	ASSEMBLY DESCRIPTION	ASSEMBLY DRAWING	QTY
1	60 kV DE INSULATOR, 715 KCM, ACCR, BUNDLED	PSI-A-T006-2	6
2	GROUND ROD ASSEMBLY	PER SVP STANDARDS	1

STRUCTURE TABLE

STRUCTURE NUMBER	STRUCTURE RAKE MEASURED AT TOP OF POLE (IN)	DIRECTION OF RAKE	POLE HEIGHT "H"	STRUCTURE QUANTITY
PAR-KEN 1	6"	REFER TO SECTION A-A	61'-0"	1
MAT-PAR 4	6"	REFER TO SECTION A-A	66'-0"	1



NOTES:

- DISTANCE AND DIRECTION OF RAKE SHALL BE AS SHOWN IN THE STRUCTURE TABLE.
- REFER TO DRAWING PSI-B-T003-1 FOR FOUNDATION DETAILS.
- FOR BOTH STR. PAR-KEN 1 AND MAT-PAR 4, THE LOWER CONDUCTOR AT EACH PHASE LEVEL IS ORIENTED TOWARD PARKER SUB.

ISSUED FOR CONSTRUCTION

APPENDIX PDDR-34

One-Line Diagram of Laurelwood Substation Which Will Serve The WDC

APPENDIX PDDR-43

SVP Responses Filed in Laurelwood SPPE

have two 115/60kV transformers for redundancy and reliability. This arrangement allows for a high reliability electrical system.

The 60kV loop is designed to maintain power to all customers when any line on the loop is out of service due to either maintenance or an unplanned outage. Each Receiving Station on the loop ends, SRS and KRS, is capable of delivering power to the entire loop. The full redundancy design of the system allows any line segment on the loop to be taken out of service for regular maintenance activities without causing a service interruption to any customers. Additionally, the protection systems on the loop are designed to detect fault conditions and isolate the fault to a single line segment. The isolation of the fault allows for continuous service for all customers during fault conditions.

As discussed above, the Laurelwood substation will have three 30/40/50 MVA transformers. The maximum load being requested by the customer is 100 MVA. With 150MVA of transformers, one transformer can be removed from service for maintenance and the load can be provided by the remaining two transformers.

See attached SVP Network Diagram 8-2-19.

2. Please provide a description of the SVP system in general and the other 60 kV loops that would serve data centers.
 - a. Could you provide a one-line diagram and a "*.shp" file of the 60 kV and above lines serving the Silicon Valley Power System? Would you have any concerns with us using either of these in a public document?

See Attached Diagram SVP CA Energy Map 8-2-19 and the SVP Network Diagram

- b. Are each of the 60 kV loops designed similarly or do some of them have features that make them more or less reliable than the others?

They are all designed similarly with the same redundancy/reliability philosophy.

3. Please describe any outages or service interruptions on the 60 kV systems that will serve the proposed data centers:
 - a. How many 60 kV double looped lines serve data centers in SVP, and how many data centers are on each?

The City currently has five 60kV Loops. They are as follows:

- East Loop
- Northeast Loop
- Northwest Loop
- Center Loop
- South Loop

Customer location per loop is provided in Question 1 d. above.

The City is currently in design phase of expanding the East Loop to shift load from the South Loop to East Loop and expand system capacity. The East Loop and South Loop will continue to maintain double looped lines serving each substation both before and after completion of this project. This project is expected to be completed by January of 2021.

- b. What is the frequency of 60 kV double-looped lines having a "double outage" that would require use of backup generators?

Extremely Rare. There was only one outage between years 2009 current 2019 where SVP lost both 60kV feeds into a substation. The total duration of the outage was 7 hours and 23 min for the outage that occurred on May 28th, 2016 at 9:28 PM.

A balloon released by an individual made contact with the 60kV line between the Northwestern Substation (NWN) and the Zeno Substation (ZEN) at pole NWZ4. The balloon contact caused a pole fire and the bottom phase, bottom insulator and guy wire burned. The circuit breaker at ZEN substation tripped properly, isolating the fault from the ZEN substation and keeping the line from the ZEN substation to the Kiefer Receiving Station energized.

However, on the NWN Substation side, the circuit breaker failed to trip due to a faulty direct current (DC) voltage source which is required for the breaker tripping coil.

Once this breaker failed to open, due to the directional nature of the fault, the fault was picked up at the Scott Receiving Station (SRS) which caused the section of the loop from the ZEN to SRS to be without power. This included the NWN Substation and the Fairview (FVR) substation. Since this was an unusual event, SVP spent the required time determining the root cause and inspecting the system prior to re-energization.

- c. How long were any outages and what were their causes?

60kV outage data since 2009 is in the below chart (10 years of data). The items highlighted in yellow indicate that there was some kind of fault associated with the outage. The items highlighted in blue is when we had customers out of power as a result. The non-highlighted items are where an outage was taken to correct an observed situation.

From 2009 through current 2019 there have been:

1. 15-60kV impacted outages due to faults.
2. 4- 60 kV impacted outages that caused customers to be out of power. Only the 12/2/16 outage and 5/28/16 involved data centers.
3. 31- 60kV total outages
4. The average 60kv outage lasts for 2.75 hours

Date	Line(s)	Cause	Duration	Customers out of power
3/30/19	URA-WAL	Bird @ UW43	1 Hour 46 Min	0
11/22/18	HOM-SER	Pole Fire HS9 (force out)	1 Hour 27 Min	0
7/5/18	SER-HOM	Force out to remove balloons	9 Min	0
5/5/18	SER-HOM	Force out to remove balloons	11 Min	0
9/1/17	AGN-NAJ	Force out to cut trees	1 hour 5 min	0
8/8/17	URA-ZEN	Force out to remove balloons	20 Min	0
5/25/17	SRS-FRV	Tripped during SCADA commissioning	1 Min	0
5/8/17	NWN-ZEN	Force out to remove bird	50 Min	0
4/29/17	SRS-HOM	Force out to remove balloons	2 hours 22 min	0
03/20/17	JUL-CEN	Third Party got into 60kV	9 hours 55 min	0
01/22/17	SER-BRO	Tree in wires	3 hours 31 min	0
01/22/17	NAJ-PLM	A phase contact guy wire when winds pick up	1 hour 47 min	0
01/19/17	KRS-PLM	Palm frond between phases	41 min	0
01/18/17	NAJ-PLM	A phase contact guy wire when winds pick up	1 Hour 44 min	0
12/02/16	RAY T1 & T2	Dropped both transformers during restoration switching due to relay not reset	12 minutes	257
09/06/16	SRS-CEN	Bird Contact	40 Min	0
06/30/16	WAL-FIB	Bird nest contact	12 hours and 4 min	0
5/28/16	SRS-FRV-NWN-	Balloons in line and	7 hours 23 min	28

	ZEN	breaker fail		
02/17/16	SRS-FRV	Palm tree with fire	7 hours	0
11/18/15	SER-BRO	Arcing wires forced	2 hours 59 min	0
11/16/15	SER-BRO	Rotten Pole- forced	22 hours 32 min	0
11/09/15	JUL CB32	Possible lightning	53 min	0
10/29/15	SER-BRO	Roller arcing-forced	3 hours 33 min	0
08/12/15	BRO-DCJ, BRO T1	Squirrel on CB100	3 hours 55 min	2155
06/24/15	CCA CB22	Bad JMUX card	3 hours 23 min	0
05/30/15	SER-BRO	No cause found	3 hours 12 min	0
03/31/15	BRO-DCJ 12KV BUS 1 & 2	Squirrel across 12kv bus tie	3 hours 26 min	2927
01/28/15	Mission CB12	Shorted control cable	6 hours 29 min	0
04/24/14	DCJ CB42	Tripped during relay work. BF wired as TT	1 Hour 30 Min	0
10/14/13	URA_WAL	Sheared Hydrant hit 60kV above	2 hours 26 min	0
12/06/12	Jul CB 32	Tripped due to cabinet vibration	2 min	0

- d. Have there been any changes to the SVP system that would prevent these types of outages from occurring in the future?

Every outage is analyzed for root cause. Most of the outages that occur on the 60kV system are outside SVP's control, e.g. Mylar balloon, squirrels or animals, car accidents, and similar events. If the outage is suspected to be caused by a failure of the intended protection scheme or equipment, then further analysis is performed and appropriate changes are implemented to minimize impact of future outages. After the outage in May, 2016, SVP performed additional circuit breaker testing and DC wire checks to maintain the reliability of its system.

- e. Given the large number of data centers with backup generators being developed in the SVP service area, would future outages likely affect more than one data center or are there elements of the SVP system design that might limit the impact of transmission outages?

Adding more data centers on the 60kV looped system would not make it more or less likely that an outage will occur. A "double outage," which has occurred only once in the last ten years, has the potential to cause multiple data centers to go to back up generators depending on the locations of both line segments that are out of service.

- f. Are there data center customers served by SVP (ie, legacy data centers) that are not on the 60kV loops? How are they served and what are the expected service outage types and rates?

No, ALL data center customers are inherently part of our 60kV loop. The voltage level these data center customers are on our 12kV distribution system, which power is provided from our 60kV substations.

4. During the proceeding for the McClaren Backup Generating Facility, the project owner described a 5/29/2016 outage at their Vantage Santa Clara Campus. The project owner provided information that six backup generators operated during that outage; of those, two operated for 7 hours while four others operated approximately 19 hours.
- a. What was the reason for the outage?

Balloons made contact with the NWN-ZEN 60kV Line at Pole NWZ4. Original fault was A Phase and GRD due to contact with the Guy wire. NWN CB 32 failed to trip due to a bad DC power source to the breaker trip coil. FRV CB12 tripped as a result of NWN CB32 not tripping. FRV CB42 and SRS CB572 also tripped due to 3 phase differential fault that occurred which is believed to have been caused by the amount of time the A phase and ground fault lasted.

- b. How long did it last for the Vantage customer? For other customers on that loop?

The outage occurred on 5/28/2019 at 2128. On 5/29/19 @ 0429- Fairview was restored, @ 0434 NWN 60kV bus restored. The system outage was 7 hours and 23 minutes. We are not privileged to the information as to why the data center may have chosen to continue to operate on their back-up generators.

- c. Is there anything about the location or interconnection of the proposed data centers that protect against a similar outage?

No difference with this location.

- d. Does this description of one recent outage at the MECP1 Santa Clara 1, LLC seem to be a reasonable description of the event and applicable for the Laurelwood Data Center?

The description of the Vantage event is reasonable, however cannot be directly applied to the Laurelwood Data Center. The Vantage event had a unique combination of contributing factors for which the resulting outcome cannot be reasonably assumed to be the expected outcome for line faults on the SVP 60kV network.

5. Pacific Gas and Electric Company and other utilities have developed Public Safety Power Shutoff protocols that could disconnect electrical services during periods of concern in order to prevent their equipment from starting wildfires. These potential shutoffs could last hours or even days. How would these new protocols potentially affect SVP's service territory or access to bulk transmission assets?

The City of Santa Clara's SVP is not located in a California Public Utilities Commission/Cal Fire Tier 2 or Tier 3 high fire risk zone. Therefore, SVP does not have a Public Safety Power Shutoff as part of their Wildfire Mitigation Plan. However, we do receive power from PG&E through six interconnection points. Based on our discussion with PG&E, Santa Clara may be requested by PG&E or the California Independent System Operator (CAISO) to curtail load. This request may be because of the reduced capacity somewhere within the system which will require overall system load reduction. This experience may be similar to the energy crisis of the early 2000's when rolling black-outs were required to maintain electric grid reliability. SVP has the capability to provide 200 MW of generation in the City with its Donald Von Raesfeld Combined Cycle Power Plant (147 MW) and the Gianera Peaker Plant (49 MW) and Cogen Facility (6 MW), we may be requested to curtail load.

SVP is working with PG&E and the CAISO as to how this situation may occur.

Substation	Loop	Customer/Industry
Fairview	Center	Mfg1
Fairview	Center	Datacenter1
Fairview	Center	Datacenter2
Fairview	Center	Datacenter3
Fairview	Center	Datacenter4
FIB	Center	Mfg2
Lafayette	Center	Mfg3
Lafayette	Center	Datacenter5
Lafayette	Center	Mfg4
Lafayette	Center	Mfg5
Lafayette	Center	Datacenter6
Lafayette	Center	Mfg6
NWN	Center	Datacenter7
Uranium	Center	Datacenter8
Uranium	Center	R&D1
Uranium	Center	Property Management1
Uranium	Center	Datacenter9
Uranium	Center	Datacenter10
Uranium	Center	Datacenter11
Uranium	Center	Property Management2
Uranium	Center	Education1
Uranium	Center	Education2
Uranium	Center	Education3
Uranium	Center	Education4
Uranium	Center	Semiconductor/Telecommunications
Uranium	Center	Gaming/AI/Semiconductors1
Uranium	Center	R&D/Mfg
Uranium	Center	Mfg7
Walsh	Center	Semiconductor1
Walsh	Center	Gaming/AI/Semiconductors2
Walsh	Center	Mfg8
Walsh	Center	Gaming/AI/Semiconductors3
Walsh	Center	Datacenter12
Walsh	Center	Education5
Walsh	Center	Government1
Walsh	Center	Government2

Walsh	Center	Semiconductor2
Walsh	Center	Semiconductor/R&D/Mfg
Walsh	Center	Mfg9
Walsh	Center	Telecommunications1
Walsh	Center	Datacenter13
Walsh	Center	Education6
Walsh	Center	Datacenter14
Zeno	Center	Education7
Zeno	Center	Education8
Zeno	Center	Semiconductor3
Zeno	Center	Datacenter15
Zeno	Center	Bio Tech 1
Zeno	Center	Semiconductor/Telecommunications
Zeno	Center	Semiconductor/R&D/Mfg

Center 141MW	
Mfg1	
Datacenter1	
Datacenter2	
Datacenter3	
Datacenter4	
Mfg2	
Mfg3	
Datacenter5	
Mfg4	
Mfg5	
Datacenter6	
Mfg6	
Datacenter7	
Datacenter8	
R&D1	
Property Management1	
Datacenter9	
Datacenter10	
Datacenter11	
Property Management2	
Education1	
Education2	
Education3	
Education4	
Semiconductor/Telecommunications	
Gaming/AI/Semiconductors1	
R&D/Mfg	
Mfg7	
Semiconductor1	
Gaming/AI/Semiconductors2	
Mfg8	
Gaming/AI/Semiconductors3	
Datacenter12	
Education5	
Government1	
Government2	
Semiconductor2	
Semiconductor/R&D/Mfg	
Mfg9	
Telecommunications1	
Datacenter13	
Education6	
Datacenter14	
Education7	
Education8	
Semiconductor3	
Datacenter15	
Bio Tech 1	
Semiconductor/Telecommunications	
Semiconductor/R&D/Mfg	

East Loop 15MW	
Datacenter16	
Datacenter17	
Gaming/AI/Semiconductors4	

Northeast Loop 28MW	
Security1	
Property Management3	
Property Management4	
Entertainment1	
NFL1	
Property Management5	
Entertainment2	
Hotel1	
Datacenter18	
Medical1	
Mfg10	
Datacenter19	
Datacenter20	
Datacenter21	
Datacenter22	
Cyber Security 1	
Hotel2	
Property Management6	
Mfg11	
Datacenter/software/cloud computing	
NFL2	
NFL3	
NFL4	
Education9	
Education10	
Conventions 1	
Education11	
Semiconductor4	
Datacenter23	
Education12	
Real Estate1	
Network hardware1	
Semiconductors5	
Computer hardware/software 1	

Northwest Loop 112MW	
Medical2	
Real Estate2	
Real Estate3	
Real Estate4	
Datacenter24	
Datacenter25	
R&D2	
Real Estate5	
Real Estate6	
Healthcare equipment	
Education13	
Semiconductor/R&D	
Datacenter26	
Property Management7	
Computer hardware/software 2	
Real Estate7	
Datacenter27	
Software1	
Computer hardware/software 3	
Cyber Security 2	
Conventions 2	
Hotel3	
Medical3	
Cyber Security 3	
Education14	
Datacenter28	
R&D3	
Semiconductor6	
Storage1	
Entertainment3	
Property Management8	
Medical4	
Telecommunications2	
NFL5	
Datacenter29	
Datacenter30	
Datacenter31	
Datacenter32	
Telecommunications3	
Datacenter33	
Gaming/AI/Semiconductors5	
Datacenter34	

South Loop 65MW	
Government3	
Education15	
Education16	
Education17	
Real Estate8	
Design1	
Security 2	
Education18	
Education19	
Mfg12	
Datacenter35	
Education20	
Education21	
Education22	
Education23	
Education24	
Education25	
Education26	
Healthcare1	
Telecommunications4	
Education27	
Education28	
Datacenter36	
Datacenter37	
Medical device	
Education29	
Education30	
Healthcare2	
Healthcare3	
Healthcare4	
Healthcare5	




PRELIMINARY
05-07-2018



Engineers, Inc.
3350 West 14th Ave.
Suite 200, W-1000
(408) 986-0300
FAX (408) 986-0427
PROJECT NO. 18818-01

[illegible]



From: Kevin Kolnowski <KKolnowski@SantaClaraCA.gov>
Sent: Thursday, August 08, 2019 2:23 PM
To: Hesters, Mark@Energy <Mark.Hesters@energy.ca.gov>
Subject: FW: Follow up CEC questions

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Mark, outlined below are the responses to your Monday, August 5th questions.

Please let us know if you have additional questions.

Thank you,

Kevin Kolnowski

Electric Utility Chief Operating Officer

From: Hesters, Mark@Energy [<mailto:Mark.Hesters@energy.ca.gov>]
Sent: Monday, August 05, 2019 1:09 PM
To: Kevin Kolnowski <KKolnowski@SantaClaraCA.gov>
Subject: Follow up CEC questions

Yes, we can talk to SVP before we file this or something else that SVP and their legal counsel approves of to the docket. I also have some questions that we can pose to them or send the questions to them before hand. Also, we should see if anyone else some follow up questions.

1. The Aug 2 response talks about the May 28/29, 2016 outage and the 28 customers that lost power. The table of outages in their response seems to list outages that affected 60kV customers, and these customers appear to be data centers customers and other, non-data center customers. Does SVP know how many of the 28 customers referred to on the May 28, 2016 entry were data centers? **Two Data Centers were affected.**
2. The Aug 2 response talks about a Dec 2, 2016 outage and the 257 customers that lost power. The table of outages in their response seems to list outage that affected 60kV customers, and these customers appear to be data centers customers and other, non-data center customers. Does SVP know how many of the 257 referred to on the Dec 2, 2016 entry were data centers? **Four Data Centers were affected.**
3. The Aug 2 response talks about a Dec 2, 2016 outage and the 257 customers that lost power. Can we get more information about this outage? Was it also an N-1-1 cascade like the series of faults that caused the May 28/29, 2016 outage? Why did we not hear about this outage earlier - was it different that the May 2016 outage (eg, internal faults versus an external fault like a balloon or squirrel)? **This outage was caused during maintenance work with the Relay Technician. During the testing, the relay was required to be reset prior to returning to service. Since the relay was not reset, when put back into service the device tripped. The Standard Operating Procedure was revised to include the step of resetting the relay prior to placing back into service. This was not a N-1-1 cascading type outage. The outage lasted 12 minutes.**

4. The Aug 2 response has a table of 60kV outages. Just to confirm, only the Dec 2 and May 28, 2016 outages affected data centers. So, for example, none of the 2927 customers affected by Mar 31, 2015 outage were data centers - is that correct? Correct, no data centers were effected during March 31, 2015 outage.
5. Also, it sounds like some data center customers are connected to 12kV feeds, but these feed are connected to the dual feed 60kV loops that are highly reliable. Is this correct, and how many customers might be on a 12kV line that comes off a 60kV loop? And how is reliability maintained on the 12kV line - looping, breakers and redundant equipment - like the 60kV loops?
Yes, this is correct. The electric services that supply power to our 12kV data center customers are from our general 60kV distribution substations, which is inherently connected to our 60kV looped system. The number of customers that are off a 12kV feeder (line) is limited to SVP's operational loading philosophy, which is 4.5MVA or 50% of the maximum 9MVA. Said in another way, we can have as few as one customer or as many as one-hundred on a feeder, as long as the entire load is less than 4.5MVA. To address reliability, by operating our 12kV feeders at half-loaded, SVP has operational flexibility to completely transfer loads to other 12kV feeders in the event of an outage. SVP may make an operational determination to limit a feeder to one data center customer, but at this time is not contractually obligated to provide as such.
6. The Aug 2 response has a 4.d. response regarding how the Vantage MECP1 data center responded to the the May 28/29, 2016 SVP outage that said "[t]he description of the Vantage event is reasonable, however cannot be directly applied to the Laurelwood Data Center. The Vantage event had a unique combination of contributing factors for which the resulting outcome cannot be reasonably assumed to be the expected outcome for line faults on the SVP 60kV network." Do you have more information on what were the "contributing factors", and why should we not assume that other data centers would have similar "expected outcomes"? As discussed in the 8/2/19 document, had the DC voltage supply cable not had an issue, a similar event would have been contained. Our anticipation, an outage in the future the protection system would operate as expected.
7. Regarding the Aug 2 response to PG&E's PSPS plans, could SVP curtailments ever allow a data center to operate under emergency conditions? To date this has not happened, the decision to operate during this situation would be by the data center. Our understanding is during emergency situation, individuals can operate their emergency generators.

Are SVP curtailments to PSPS conditions voluntary or emergency conditions? We understand that diesel emergency gensets cannot operate for economic reasons, only in response to an unplanned emergency or upset on their supply grid. We will be instructed to reduce load to respond to emergency conditions somewhere within the CAISO controlled grid, we have to follow what the CAISO directs us to do. The CAISO instructions are not voluntary. We would request customers to reduce load to satisfy the emergency condition and if that is not sufficient we will begin shutdown of our customers to meet the emergency situation. We would be operating at the direction of the CAISO.

8. Are there any plans that part of the PSPS program might include payments to some loads to curtail or shed? SVP does not have a plan to pay a data center to shed or curtail load.

9. Would the 6 interconnection points with the PG&E system allow SVP/PG&E to wheel bulk deliveries around potential shutdowns on the PG&E system? In other words, is the current understanding of the PSPS program that most shutdown will be in specific areas and not across the greater PG&E system, and that would allow PG&E to work around an area that would be fully shutdown? The understanding is if the conditions are such where transmission has to be curtailed, the CAISO will require load reductions of the CAISO controlled grid, similar to the energy crisis from the early 2000's. SVP will request voluntary reductions to meet the CAISO demand or will make switching changes which to remove blocks of customers load. It will depend how much reductions the CAISO will be instructing us to reduce, voluntary load shedding and customer shutoff.

Matt

Mark Hesters
California Energy Commission
(916)654-5049