
DOCKETED	
Docket Number:	19-SPPE-03
Project Title:	Sequoia Data Center
TN #:	230893
Document Title:	Generator Tank Detail Revision to Respond to ALUC - Supplemental Response to DR 89
Description:	N/A
Filer:	Scott Galati
Organization:	DayZenLLC
Submitter Role:	Applicant Representative
Submission Date:	12/2/2019 7:25:41 AM
Docketed Date:	12/2/2019



Project Number: 18256.0000

CyrusOne.

BACK UP GENERATOR

6,800 GALLON UL 2085 FUEL TANKS DOUBLE STEEL WALLS W/ CONCRETE WITHIN INTERSTITIAL SPACE AND BUILT-IN CONTINUOUS MONITORING FOR LEAKS. DIRECT FILL WITHIN ENCLOSURE COMPLETE OVERFILL PROTECTION AND INTEGRAL 10 GALLON CONTAINMENT BASIN FOR FILL CONNECTION.

GRADE

CONCRETE PAVING

PUMP OUTLET TO SEPARATOR IN CASE OF OIL SHEEN

PRECAST CONCRETE SAND OIL / WATER SEPARATOR. PROVIDE WITH (2) MANWAY ACCESS CHAMBERS COMPLETE WITH EXTENSION RINGS AND TRAFFIC RATED MANHOLE COVERS.



CORGAN

