

DOCKETED

Docket Number:	09-AFC-05C
Project Title:	Abengoa Mojave Compliance
TN #:	231248
Document Title:	Mojave Solar Project 2018 Annual Compliance Report
Description:	Mojave Solar Project 2018 Annual Compliance Report, Part 2-1
Filer:	Jose Manuel Bravo Romero
Organization:	Mojave Solar Project
Submitter Role:	Applicant
Submission Date:	12/16/2019 10:54:03 AM
Docketed Date:	12/16/2019

Emergency Diesel Generator Weekly Test Log

Plant: *Sc.1A* Date: *9--\ -1*

Operator: *b \ - \ *

Main Generator Breaker **Comments**

Open *><*

Closed

Engine **Comments**

StartTime: *11:00*

StopTime: *11:00*

Total Run Time: *10:00*

Starting Hour Meter Reading *10,000*

Monthly Fuel Consumption(gal)

Oil Level *@ 1/2*

Coolant Level *1/2* **Coolant Temp.@ Start 4/£ *c** **Finish= 115*c**

Belt Condition *Good*

Oil Pressure **Start= 5, f bar** **Finish= , . bar**

Battery Condition *100%*

Battery Voltage *24.0*

Engine RPMs *1100 (Boo)*

Generator **Comments**

Generator Volts

Generator Amps

Generator "KVA"

Reason For Use **Comments**

Testing *X*

Emergency

Maintenance

Generator **Comments-**

Fuel Delivered *114.01*

Fuel Level 1/4 1/2 3/4 F

Sulfur Concentrations

<0.0015% (ISppm)

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: BE-10

Date: 1/11

Operator: sh. I

Main Generator Breaker		Comments	
Open	X		
Closed			
Engine		Comments	
Start Time:	1:00		
Stop Time:	1:00		
Total Run Time:	10 min		
Starting Hour Meter Reading	1117		
Monthly Fuel Consumption(gal)			
Oil Level	max		
Coolant Level	Good	Coolant Temp. @ Start	50 °C
Belt Condition	Good	Finish	50 °C
Oil Pressure		Start = 8.5 bar	Finish = 8.5 bar
Battery Condition	Good		
Battery Voltage	11.1V		
Engine RPMs	1800		
Generator		Comments	
Generator Volts			
Generator Amps			
Generator "KVA"			
Reason For Use		Comments	
Testing	X		
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered	114.01 gal		
Fuel Level	1/4 1/2 3/4 F		
Sulfur Concentrations <0.0015% (1 Sppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: *14* Date: *2/11/11*

Operator: *-A- L8 1*

Main Generator Breaker		Comments
Open	<i>/</i>	
Closed		

Engine		Comments
Start Time:	<i>0:31</i>	
Stop Time:	<i>03:00</i>	

Total Run Time:	<i>00:01</i>	
Starting Hour Meter Reading	<i>110</i>	
Monthly Fuel Consumption(gal)		

Oil Level	<i>W</i>	
Coolant Level	<i>C</i>	Coolant Temp.@ Start4(p*c Finish= *c 7/11 °
Belt Condition	<i>U</i>	
Oil Pressure	<i>6</i>	Start = 0 Obar Finish= bar <i>h/f</i>
Battery Condition	<i>G</i>	
Battery Voltage	<i>21.00V</i>	
engine RPMs	<i>1510</i>	

Generator		Comments
Generator Volts	<i>4.1</i>	
Generator Amps		
Generator "KVA"	<i>5.1</i>	

Reason For Use		Comments
Testing		
Emergency		
Maintenance		

Generator		Comments
Fuel Delivered		
Fuel Level	<i>1/4 11.1V4 F</i>	
Sulfur Concentrations <0.0015% (1 Sppm)	<i>0.10</i>	

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 1/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: **rs c,**

Date: **f-/Z-I Y**

Operator: **e, kb 56 4 vds**

Main Generator Breaker		Comments
Open	V	
Closed		
Engine		Comments
Start Time:	(1)e:(1/1)	
Stop Time:	r>C:-tJ	
Total Run Time:	1/1 y1:1' 1'v	
Starting Hour Meter Reading	LJ/nf(V	
Monthly Fuel Consumption(gal)	2..Z,f}	
Oil Level	X..y}	
Coolant Level	L..A	Coolant Temp.@ Start£/,: *c Finish=.) , *c
Belt Condition	1..0	
Oil Pressure	(6).	Start=;::, bar Finish= bar
Battery Condition	, "rH	
Battery Voltage	'S..L	
Engine RPMs	1W)t	
Generator		Comments
Generator Volts	1A ..	
Generator Amps	1/1. ..	
Generator "KVA"	V1 tr..	
Reason For Use		Comments
Testing	V	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	1A tA	
Fuel Level 1/4 1/2 3/4 F	m0."70	
Sulfur Concentrations <0.0015% (1 Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: *B + er*

Date: *f; -5 = -{<;}'*

Operator: *C vfeb* o v, /t vt!!f

Main Generator Breaker		Comments
Open	<i>√</i>	
Closed		
Engine		Comments
Start Time:	<i>07 7</i>	
Stop Time:	<i>11:47</i>	
Total Run Time:	<i>4:40</i>	
Starting Hour Meter Reading	<i>•, n = . J</i>	
Monthly Fuel Consumption(gal)		
Oil Level	<i>1/2</i>	
Coolant Level	<i>1/2</i>	Coolant Temp. @ Start <i>111</i> *c Finish = <i>111</i> *c
Belt Condition	<i>3-15</i>	
Oil Pressure	<i>1</i>	Start = <i>7, 7</i> bar Finish = <i>fn \$</i> bar
Battery Condition		
Battery Voltage	<i>v? c.s-</i>	
Engine RPMs	<i>t fm</i>	
Generator		Comments
Generator Volts	<i>√ c.</i>	
Generator Amps	<i>1. Ar.</i>	
Generator "KVA"	<i>1/1</i>	
Reason For Use		Comments
Testing	<i>√ /</i>	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	<i>√, t;</i>	
Fuel Level	<i>1/4 1/2 3/4 F</i>	<i>1/4 q '70</i>
Sulfur Concentrations <0.0015% (1 Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: Beic Beic		Date: 7-r;).1-1R	
Operator: m I Ae			
Main Generator Breaker		Comments	
Open	./		
Closed			
Engine		Comments	
Start Time:	1:00D		
Stop Time:	7:00		
Total Run Time:	11:01		
Starting Hour Meter Reading	4410		
Monthly Fuel Consumption(gal)			
Oil Level	(-w)		
Coolant Level	1	Coolant Temp. @ Start	11 *c Finish=" " *c
Belt Condition	i - i		
Oil Pressure		Start= S. A bar	Finish= , , /bar
Battery Condition	boo		
Battery Voltage	" 1		
Engine RPMs	\		
Generator		Comments	
Generator Volts	NA		
Generator Amps	1		
Generator "KVA"	1V		
Reason For Use		Comments	
Testing	./		
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered	110		
Fuel Level 1/4 1/2 3/4 F	g		
Sulfur Concentrations <0.0015% (1 Sppm)			
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p> <p>Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.</p>			

Emergency Diesel Generator Weekly Test Log

Plant: Ise;- \

Date: "l- t • 16

Operator: L. S V \ \

Main Generator Breaker		Comments	
Open	<u>X</u>		
Closed			
Engine		Comments	
Start Time:	10:01		
Stop Time:	10:12		
Total Run Time:	1 M: 11		
Starting Hour Meter Reading	159		
Monthly Fuel Consumption(gal)			
Oil level	Good		
Coolant level	Good	Coolant Temp.@ Start	11 *c Finish= 16 *c
Belt Condition	Good		
Oil Pressure		Start = 2.5 bar	Finish= 2.0 bar
Battery Condition	Good		
Battery Voltage	12.4		
engine RPMs	1500		
Generator		Comments	
Generator Volts			
Generator Amps			
Generator "KVA"			
Reason For Use		Comments	
Testing			
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered	150		
Fuel Level	1/4 1/2 3/4 F		
Sulfur Concentrations <0.0015% (1 Sppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: +a Date: ta |i'-d tY

Operator: 12_1

Main Generator Breaker		Comments
Open		
Closed		

Engine		Comments
Start Time:	<u>i-</u>	
Stop Time:	<u>q. D.L. M</u>	
Total Run Time:	<u>\0 M'h</u>	
Starting Hour Meter Reading	<u>L\5C\.</u>	
Monthly Fuel Consumption(gal)		
Oil Level	<u>v</u>	
Coolant Level	<u>v-</u>	Coolant Temp.@ StartLtc_ *c Finish='l(o *c
Belt Condition	<u>v'</u>	
Oil Pressure	<u>v</u>	Start = '&S bar Finish=to.'t bar
Battery Condition	<u>v</u>	
Battery Voltage	<u>91o\</u>	
Engine RPMs	<u>f'oc></u>	

Generator		Comments
Generator Volts	<u>4.\</u>	
Generator Amps	<u>α:>qd-</u>	
Generator "KVA"	<u>)Sd-D</u>	

Reason For Use		Comments
Testing	<u>v</u>	
Emergency		
Maintenance		

Generator		Comments
Fuel Delivered		
Fuel Level 1/4 1/2 3/4 F		
Sulfur Concentrations <0.0015% (1 Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

st

Emergency Diesel Generator Weekly Test Log

Plant: 13e+A Date: 10/1/1

Operator: -K.Jr-

Main Generator Breaker		Comments
Open		
Closed		

Engine		Comments
Start Time:	<u>9:40M</u>	
Stop Time:	<u>9:53</u>	
Total Run Time:	<u>10 13"</u>	
Starting Hour Meter Reading	<u>450.6</u>	
Monthly Fuel Consumption(gal)		
Oil level		
Coolant Level	<input checked="" type="checkbox"/>	Coolant Temp. @ Start = <u>11</u> *c Finish = <u>15</u> *c
Belt Condition	<input checked="" type="checkbox"/>	
Oil Pressure	<input checked="" type="checkbox"/>	Start = <u>3</u> bar Finish = <u>5.3</u> bar
Battery Condition	<input checked="" type="checkbox"/>	
Battery Voltage	<input checked="" type="checkbox"/>	
Engine RPMs	<u>1800</u>	

Generator		Comments
Generator Volts	<u>111.1</u>	
Generator Amps	<u>061.1</u>	
Generator "KVA"	<u>7.2</u>	

Reason For Use		Comments
Testing	<input checked="" type="checkbox"/>	
Emergency		
Maintenance		

Generator		Comments
Fuel Delivered		
Fuel level 1/4 1/2 3/4 F	<u>1/4</u>	
Sulfur Concentrations <0.0015% (1 Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: 'B * o.		Date: 0 - 9 - (
Operator: oh ,		
Main Generator Breaker		Comments
Open	X	
Closed		
Engine		Comments
Start Time:	0t.: OS	
Stop Time:	0 'lt	
Total Run Time:	0 . - " ?	
Starting Hour Meter Reading	SQ. i	
Monthly Fuel Consumption(gal)		
Oil Level	0^ .>(
Coolant Level		Coolant Temp. @ Start / t, *c Finish= 15 * c
Belt Condition	G- od	
Oil Pressure		Start = &-l bar Finish= br9 bar
Battery Condition	a- od	
Battery Voltage	'1. " "	
Engine RPMs	• 8 0	
Generator		Comments
Generator Volts	0 13,	
Generator Amps	J 3 "	
Generator "KVA"	tj d 1	
Reason For Use		Comments
Testing	'X	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	< 9%	
Fuel Level	1/4 1/2 3/4 F	
Sulfur Concentrations <0.0015% (1 Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: **Be+''**

Date: **6-24-10**

Operator: **(1, 1A/d'rJ.)**

Main Generator Breaker		Comments
Open	V	
Closed		
Engine		Comments
Start Time:	1:11	
Stop Time:	1:11	
Total Run Time:	0:00	
Starting Hour Meter Reading	1700	
Monthly Fuel Consumption(gal)		
Oil Level	U+	Le
Coolant Level	M.	Coolant Temp. @ Start: J.S-*c Finish: , c
Belt Condition	W	
Oil Pressure	W	Start= t; i; -bar Finish= t; X"bar
Battery Condition	Ji'	
Battery Voltage	< 12.7	
Engine RPMs	Jtx	
Generator		Comments
Generator Volts	417	
Generator Amps		
Generator "KVA"		
Reason For Use		Comments
Testing	V	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	11	
Fuel Level	1/4 1/2 3/4 F	
Sulfur Concentrations		
<0.0015% (1 Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 1/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant	ts	Date:	11 / dCl
Operator:	O ..VLv-€-\		
Main Generator Breaker		Comments	
Open	v'		
Closed			
Engine		Comments	
Start Time:	..2l : \		
Stop Time:			
Total Run Time:	IOKI "		
Starting Hour Meter Reading	4'0		
Monthly Fuel Consumption(gal)			
Oil Level	Gm	· £:::o ..-e.. "-A- "	Uut'
Coolant Level	c::, P	Coolant Temp.@ Start4	a..c Finish=7S-*c
Belt Condition	C.		
Oil Pressure	C1	Start = t,t{:l>ar	Finish=/, .51 bar
Battery Condition	ov		
Battery Voltage	d#3		
Engine RPMs	\?5UO		
Generator		Comments	
Generator Volts	4, I(o\67		
Generator Amps			
Generator "KVA"	I S' < S3		
Reason For Use		Comments	
Testing	/		
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered	f->A/		
Fuel Level	1/4 1/ J14 F (o'-Iff)		
Sulfur Concentrations			
<0.0015% (1 Sppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 1/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: - U		Date: 6, J / I
Operator: c; A-		
Main Generator Breaker		Comments
Open	✓	
Closed		
Engine		Comments
Start Time:	19	
Stop Time:	20:30	
Total Run Time:	1 hr 10 min	
Starting Hour Meter Reading	455	
Monthly Fuel Consumption(gal)		
Oil Level	Full	Above, Oil 11.0 J, Jo, U>W
Coolant Level	Full	Coolant Temp. @ Start *c Finish=, *c
Belt Condition	Good	
Oil Pressure	Good	Start = 0.0 bar Finish = 0.1 bar
Battery Condition	Good	
Battery Voltage	Good	
engine RPMs	1000	
Generator		Comments
Generator Volts	480	
Generator Amps	0	
Generator "KVA"	0	
Reason For Use		Comments
Testing	✓	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	0	
Fuel Level	1/4	(of 1/2)
Sulfur Concentrations <0.0015% (1 Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant (3? t'a		Date 4, - 2. - / f'	
Operator: (j,m) (") V V 4 i' J'f			
Main Generator '8'reaicer		Comments	
Open	V		
Closed			
Engine		Comments	
Start Time:	11-'7		
Stop Time:	D 11-		
Total Run Time:	/Om\va.		
Starting Hour Meter Reading	Ur:K 7		
Monthly Fuel Consumption(gal)			
Oil Level	11-'7		
Coolant Level	11	Coolant Temp.@ Start *c	Finish="?" *c
Belt Condition	h)		
Oil Pressure	0	Start = 7.0f bar	Finish . bar
Battery Condition	11/11 xx		
Battery Voltage	"Yr:		
engine RPMs	T		
Generator		Comments	
Generator Volts	V, 17		
Generator Amps	V 11		
Generator "KVA"	vie,		
Reason For Use		Comments	
Testing	11		
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered	NIA		
Fuel Level 1/4 1/2 3/4 F	r, i		
Sulfur Concentrations <0.0015% (1 Sppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility backfeed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: 13... \ \ α

Date: s-&r.- ,a

Operator: L, \$hc...l

Main Generator Breaker		Comments
Open) (
Closed		
Engine		Comments
Start Time:	t>J,Q	
Stop Time:	16	
Total Run Time:	10, "1;"	
Starting Hour Meter Reading	.	
Monthly Fuel Consumption(gal)		
Oil Level	No (p, al	
Coolant Level	6p.J	Coolant Temp.@ Start 57 *c Finish= 7S *c
Belt Condition	Sood	
Oil Pressure		Start= ? ,g bar Finish= /! bar
Battery Condition	Q...; ei	
Battery Voltage	2, ., .	
Engine RPMs	11 9 8	
Generator		Comments
Generator Volts		
Generator Amps		
Generator "KVA"		
Reason For Use		Comments
Testing	X	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	No	
Fuel Level 1/4 1/2 3/4 F	4CJ..	
Sulfur Concentrations <0.0015% (1 Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant <i>3cft</i>		Date: <i>-2f-/</i>
Operator: <i>/b)/vva vd</i>		
Main Generator Breaker		Comments
Open	<i>v</i>	
Closed		
Engine		Comments
Start Time:	<i>07:01</i>	
Stop Time:	<i>07:11</i>	
Total Run Time:	<i>10 min</i>	
Starting Hour Meter Reading	<i>41,4</i>	
Monthly Fuel Consumption(gal)		
Oil Level	<i>High</i>	
Coolant Level	<i>High</i>	Coolant Temp. @ Start: <i>?</i> *c Finish: <i>?</i> *c
Belt Condition	<i>Good</i>	
Oil Pressure	<i>Normal</i>	Start= <i>1.7</i> bar Finish= <i>1.7</i> bar
Battery Condition	<i>Good</i>	
Battery Voltage	<i>12.8</i>	
Engine RPMs	<i>1500</i>	
Generator		Comments
Generator Volts	<i>120</i>	
Generator Amps		
Generator "KVA"		
Reason For Use		Comments
Testing	<i>v</i>	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	<i>N/A</i>	
Fuel Level 1/4 1/2 3/4 F	<i>(1/4)</i>	
Sulfur Concentrations <0.0015% (1 Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: Ro Date: S / I / Y-

Operator: yipn

Main Generator Breaker		Comments
Open		
Closed		

Engine		Comments
Start Time:	<u>1:00 PM</u>	
Stop Time:	<u>1:10 PM</u>	
Total Run Time:	<u>10 min</u>	
Starting Hour Meter Reading	<u>4</u>	
Monthly Fuel Consumption(gal)		

Oil Level	<u>✓</u>	
Coolant Level	<u>✓</u>	Coolant Temp.@ StartS *c Finish= S *c
Belt Condition	<u>✓</u>	
Oil Pressure	<u>✓</u>	Start = . "\ bar Finish= . "\ bar
Battery Condition	<u>✓</u>	
Battery Voltage	<u>g.0</u>	
Engine RPMs	<u>1100</u>	

Generator		Comments
Generator Volts	<u>240</u>	
Generator Amps	<u>100</u>	
Generator "KVA"	<u>24</u>	

Reason For Use		Comments
Testing	<u>✓</u>	
Emergency		
Maintenance		

Generator		Comments
Fuel Delivered		
Fuel Level	<u>1/4</u> <u>1/2</u> <u>3/4</u> <u>F</u>	
Sulfur Concentrations <0.0015% (1 Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 1/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: <u>-i- K-</u>		Date: <u>/s/ 1</u>
Operator: <u>-i- K-</u>		
Main Generator Breaker		Comments
Open		
Closed		
Engine		Comments
Start Time:	<u>.s1</u>	
Stop Time:	<u>10:01</u>	
Total Run Time:	<u>10</u>	
Starting Hour Meter Reading	<u>1000</u>	
Monthly Fuel Consumption(gal)		
Oil Level	<u>/</u>	
Coolant Level	<u>/</u>	Coolant Temp. @ Start <u>Si</u> *c Finish= <u>rit...</u> *c
Belt Condition	<u>/</u>	
Oil Pressure		Start = <u>.</u> bar Finish= <u>lo, L</u> bar
Battery Condition	<u>v</u>	
Battery Voltage	<u>b</u>	
Engine RPMs	<u>1000</u>	
Generator		Comments
Generator Volts	<u>4.1</u>	
Generator Amps	<u>0.1</u>	
Generator "KVA"	<u>1.1</u>	
Reason For Use		Comments
Testing	<u>/</u>	<u>11/20/17</u>
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level 1/4 1/2 3/4 F	<u>to q</u>	
Sulfur Concentrations <0.0015% (1 Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: **e-rA** Date: **4-28-18**

Operator: **f>Hl\ . -1"b-..>|**

Main Generator Breaker		Comments
Open	✓	
Closed	-	
Engine		Comments
Start Time:	21:12-	
Stop Time:	22:12-	
Total Run Time:	45"6.1	
Starting Hour Meter Reading	1	45"18' fu01NG
Monthly Fuel Consumption(gal)	-	
Oil Level	C:000	
Coolant Level	(;col)	Coolant Temp. @ Start *c Finish= 75 *c
Belt Condition	Cc:..h>	
Oil Pressure	<caoon	Start= B:3 bar Finish: 1,b bar
Battery Condition	boon	
Battery Voltage	.u. .re.	
Engine RPMs	100	
Generator		Comments
Generator Volts	A. . fl, V	
Generator Amps	-	
Generator "KVA"		
Reason For Use		Comments
Testing	v.1	
Emergency	---	
Maintenance		
Generator		Comments
Fuel Delivered	-	
Fuel Level	14"1 J//W. I F	,0Z
Sulfur Concentrations <0.0015% (1 Sppm)	-	

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 1/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: *2.4a* Date: *1/14/17*

Operator: *T. J. ...*

Main Generator Breaker		Comments	
Open			
Closed			
Engine		Comments	
Start Time:	<i>TJOM</i>		
Stop Time:	<i>1:10 PM</i>		
Total Run Time:	<i>In Min</i>		
Starting Hour Meter Reading	<i>713.7</i>		
Monthly Fuel Consumption(gal)			
Oil Level	<i>OK</i>		
Coolant Level	<i>OK</i>	Coolant Temp. @ Start SC <i>100</i> *c	Finish= <i>100</i> *c
Belt Condition	<i>OK</i>		
Oil Pressure	<i>100</i> psi	Start = <i>100</i> bar	Finish= <i>100</i> bar
Battery Condition	<i>OK</i>		
Battery Voltage	<i>12.8</i> V		
Engine RPMs	<i>1800</i>		
Generator		Comments	
Generator Volts	<i>480</i> V		
Generator Amps	<i>100</i> A		
Generator "KVA"	<i>48</i> KVA		
Reason For Use		Comments	
Testing	<i>Yes</i>		
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered			
Fuel Level	<i>1/4</i> F		
Sulfur Concentrations	<i><0.0015%</i> (1 Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: Beta Date: 4/21/18

Operator: Manny Garcia

Main Generator Breaker		Comments	
Open			
Closed	✓		
Engine		Comments	
Start Time:	8:16 4/21/18		
Stop Time:	ON GOING		
Total Run Time:	4:00:00		
Starting Hour Meter Reading	400.8		
Monthly Fuel Consumption(gal)			
Oil Level	Good		
Coolant Level	Good	Coolant Temp. @ Start 58*c	Finish= *c
Belt Condition	Good		
Oil Pressure	Good	Start = 0 bar	Finish= bar
Battery Condition	Good		
Battery Voltage	26.6		
Engine RPMs	1800		
Generator		Comments	
Generator Volts	4.17		
Generator Amps			
Generator "KVA"	4021		
Reason For Use		Comments	
Testing			
Emergency			
Maintenance	✓	Outage	
Generator		Comments	
Fuel Delivered	4/21/18	78% → Top off	91% @ 8:35 AM
Fuel Level	1/4 1/2 <u>3/4</u> F		
Sulfur Concentrations <0.0015% (ISppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

() Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

ABENGOA

Beta

Operator(s): Ji!t- fi> t s/t-1/flj, Yf.

Date: 4-7-'2..S

Emergency Diesel Generator Bi-Hourly Readings

TimeOf Reading	Oil Pressure	Gen. voltage	Engine RPM	Coolant Temp.	Fuel Level	Hour Meter	Oil Temp	Gen. KWH
21	4.5	4.16	1000	110	100%	4515"	77	101.1
06:00	4.5	4.16	1000	110	100%	4515"	77	101.1
08:00	4.5	4.16	1000	110	100%	4515"	77	101.1
10:00	4.5	4.16	1000	110	100%	4515"	77	101.1
12:00	4.5	4.16	1000	110	100%	4515"	77	101.1
14:00	4.5	4.16	1000	110	100%	4515"	77	101.1
16:00	4.5	4.16	1000	110	100%	4515"	77	101.1
18:00	4.5	4.16	1000	110	100%	4515"	77	101.1
20:00	4.5	4.16	1000	110	100%	4515"	77	101.1
22:00	4.5	4.16	1000	110	100%	4515"	77	101.1
24:00	4.5	4.16	1000	110	100%	4515"	77	101.1

Pumping Fuel
STOP EDG

Comments: FIRST SKIPPED IN CONTROL ROOM - 4/23
FUEL DELIVERY 1:45 PM 4/23/18 380/1780 1834 gallons

Emergency Diesel Generator Weekly Test Log

Plant: **BETA** Date: **4 - 1 17 - 1 11**

Operator: **PHIL TOURBEUS**

Main Generator Breaker		Comments	
Open	OPEN		
Closed	—		
Engine		Comments	
Start Time:	06:26		
Stop Time:	06:36		
Total Run Time:	10 MIN		
Starting Hour Meter Reading	400.6	400.8 END HRs	
Monthly Fuel Consumption(gal)	—		
Oil Level	GOOD.		
Coolant_Level	GOOD	Coolant Temp. @ Start, O °c	Finish=J'> °c
Belt Condition	GOOD		
Oil Pressure		Start = 8.2 bar	Finish= 8-15 bar
Battery Condition	GOOD		
Battery Voltage	26.7		
Engine RPMs	1800		
Generator		Comments	
Generator Volts	4.17 kV		
Generator Amps	—		
Generator "KVA"	—		
Reason For Use		Comments	
Testing	weekly		
Emergency	—		
Maintenance	—		
Generator		Comments	
Fuel Delivered	N/A		
Fuel Level	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> F 78%		
Sulfur Concentrations <0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: **BETA PLANT** Date: **04/06/18**
 Operator: **MANUEL GARCIA**

Main Generator Breaker		Comments	
Open	✓		
Closed			
Engine		Comments	
Start Time:	21:35		
Stop Time:	2:45		
Total Run Time:	10 MINS		
Starting Hour Meter Reading	400.4		
Monthly Fuel Consumption(gal)			
Oil Level	Good		
Coolant Level	Good	Coolant Temp. @ Start 57°C	Finish=76°C
Belt Condition	Good		
Oil Pressure	Good	Start = 0.0 bar	Finish = 6.8 bar
Battery Condition	Good		
Battery Voltage	26.2		
Engine RPMs	1800		
Generator		Comments	
Generator Volts	4.12		
Generator Amps			
Generator "KVA"	4021		
Reason For Use		Comments	
Testing	✓	Weekly	
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered	N/A		
Fuel Level	1/4 1/2 3/4 F 28%		
Sulfur Concentrations <0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: Beta		Date: 4/1/18	
Operator: Rico			
Main Generator Breaker		Comments	
Open			
Closed			
Engine		Comments	
Start Time:	7:30pm 7:30pm		
Stop Time:	7:40pm		
Total Run Time:	10min		
Starting Hour Meter Reading	400.3		
Monthly Fuel Consumption(gal)			
Oil Level	<input checked="" type="checkbox"/>		
Coolant. Level	<input checked="" type="checkbox"/>	Coolant Temp. @ Start 56 °c	Finish= <input type="checkbox"/> °c
Belt Condition	<input checked="" type="checkbox"/>		
Oil Pressure	<input checked="" type="checkbox"/>	Start = 7.5 bar	Finish= <input type="checkbox"/> bar
Battery Condition	<input checked="" type="checkbox"/>		
Battery Voltage	26.7		
Engine RPMs	1800		
Generator		Comments	
Generator Volts	4.16		
Generator Amps	0272		
Generator "KVA"	4.18		
Reason For Use		Comments	
Testing	<input checked="" type="checkbox"/>	weekly	
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered			
Fuel Level	1/4 1/2 3/4 F	78%	
Sulfur Concentrations <0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: Beta		Date: 3-24-18	
Operator: Shell			
Main Generator Breaker		Comments	
Open	X		
Closed			
Engine		Comments	
Start Time:	s,C,,J		
Stop Time:	2,3} I		
Total Run Time:	/Om/'7,		
Starting Hour Meter Reading	""(06, 2		
Monthly Fuel Consumption(gal)			
Oil Level	good		
Coolan_Level	Good	Coolant Temp. @ Start t) °c	Finish= '(5 °c
Belt Condition	good		
Oil Pressure	-	Start= 8,3 bar	Finish= 4. bar
Battery Condition	Good		
Battery Voltage	K.,		
Engine RPMs			
Generator		Comments	
Generator Volts			
Generator Amps			
Generator "KVA"			
Reason For Use		Comments	
Testing	X		
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered			
Fuel level	1/4 1/2 3/4 F	78%	
Sulfur Concentrations <0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance elcluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

late: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

DL

Emergency Diesel Generator Weekly Test Log

Plant: **B'e.t** Date: **3-17-18**
 Operator: **S. V**

Main Generator Breaker		Comments	
Open	X	TESTING	
Closed	X	NORMAL OPS (STANDBY)	
Engine		Comments	
Start Time:	02:00		
Stop Time:	02:10		
Total Run Time:	10 min		
Starting Hour Meter Reading	400.0		
Monthly Fuel Consumption (gal)	-		
Oil Level	Normal		
Coolant Level	Normal	Coolant Temp. @ Start	70 °c Finish= 75 °c
Belt Condition	Good		
Oil Pressure		Start = 0 bar	Finish= 0 bar
Battery Condition	Good		
Battery Voltage		26.7	
Engine RPMs		1800	
Generator		Comments	
Generator Volts	4.17		
Generator Amps	NA		
Generator "KVA"	NA		
Reason For Use		Comments	
Testing	X		
Emergency	-		
Maintenance	-		
Generator		Comments	
Fuel Delivered	NA		
Fuel Level	1/4 1/2 3/4 F	78%	
Sulfur Concentrations <0.0015% (ISppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

04

Emergency Diesel Generator Weekly Test Log

Plant: Beta Date: 3/20/18
 Operator: Rico

Main Generator Breaker		Comments	
Open			
Closed	✓		
Engine		Comments	
Start Time:	6:33pm		
Stop Time:	6:43pm		
Total Run Time:	10min		
Starting Hour Meter Reading	349.8		
Monthly Fuel Consumption(gal)			
Oil Level	good		
Coolant. Level		Coolant Temp. @ Start 51 °c	Finish= 7(e)°c
Belt Condition	good		
Oil Pressure		Start =,,<i> bar	Finish=Co_ bar
Battery Condition	good		
Battery Voltage	26.6		
Engine RPMs	1800		
Generator		Comments	
Generator Volts	4.13		
Generator Amps	0264		
Generator "KVA"	1730		
Reason For Use		Comments	
Testing	✓		
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered			
Fuel Level	1/4 1/2 3/4 F		
Sulfur Concentrations <0.0015% {15ppm}			

This Emergency Generator shall be limited to use for emergency power, as defined as in resP.onse to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance e,ccluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

⊠ Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: £

Date: 3(2-1

Operator: b--K!-ctA

Main Generator Breaker		Comments	
Open	.. /		
Closed			
Engine		Comments	
Start Time:	;), (JO		
Stop Time:	0).-: \f\		
Total Run Time:	\ u -As		
Starting Hour Meter Reading	30 .- J		
Monthly Fuel Consumption(gal)	t'f.		
Oil Level	Gmd>		
Coolant Level	Chr.nc	Coolant Temp. @ Startj) f °c	Finish=I('*c
Belt Condition	Good		
Oil Pressure	r r r o c	Start= t).1Jbar	Finish=I .f bar
Battery Condition	C era<		
Battery Voltage	::2 (p. 3		
Line RPMs	180()		
Generator		Comments	
Generator Volts	4 ..lrJ		
Generator Amps	t j /A..		
Generator "KVA"	"n...:A		
Reason For Use		Comments	
Testing	V		
Emergency	J'		
Maintenance	H I		
Generator		Comments	
Fuel Delivered	○		
Fuel Level 1/4 1/2 (3/4) F	1"8,		
Sulfur Concentrations <0.0015% (ISppm)	○		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

e: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel (Generator) Weekly Test Log

Plant: *VIA* Date: *11/11/11*

Operator: *S. L. G*

Main Generator Breaker

Open	<i>X</i>	Comments
Closed		

Engine

Start Time:	<i>07:11</i>	Comments
Stop Time:	<i>07:11</i>	
Total Run Time:	<i>00:00</i>	
Starting Hour Meter Reading	<i>112,0</i>	
Monthly Fuel Consumption(gal)		
Oil Level	<i>d</i>	
Coolant Level	<i>G-1t</i>	Coolant Temp. @ Start <i>55</i> *c Finish= <i>60</i> *c
Belt Condition	<i>(...)</i>	
Oil Pressure		Start= <i>1,7</i> bar Finish= <i>2,1</i> bar
Battery Condition	<i>G 1,2</i>	
Battery Voltage	<i>22</i>	<i>22</i>
Engine RPMs	<i>1800</i>	

Generator

Generator Volts	<i>415</i>	Comments
Generator Amps		
Generator "KVA"		

Reason For Use

Testing	<i>X</i>	Comments
Emergency		
Maintenance		

Generator

Fuel Delivered	<i>NO</i>	Comments
Fuel Level <input type="checkbox"/> 1/4 <input type="checkbox"/> 1/2 <input type="checkbox"/> 3/4 <input type="checkbox"/> F	<i>3/4</i>	
Sulfur Concentrations <0.0015% (1 Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

ABENGOA

Emergency Diesel Generator Weekly Test log

Plant: **R.P,fn** Date: **-2/1-j?**

Operator: **UJ**

Main Generator Breaker

Open Comments

Closed

Engine

Start Time: **7J**

Stop Time: **2:11" L**

Total Run Time: **111.1M. 11**

Starting Hour Meter Reading: **119 1A**

Monthly Fuel Consumption(gal): **11**

Oil level: **11**

Coolant level: **11** Coolant Temp. @ Start: **11** *c Finish: **11** *c

Belt Condition: **11**

Oil Pressure: **11** Start **11** bar Finish: **0.5** bar

Battery Condition: **11**

Battery Voltage: **11**

Engine RPMs: **11**

Generator

Generator Volts

Generator Amps

Generator "KVA"

Reason For Use

Testing Comments

Emergency

Maintenance

Generator

Fuel Delivered

Fuel Level **J 1/4 | 1/2 | 3/4 | F** **110%**

Sulfur Concentrations <0.0015% (1 Sppm)

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

ABENGOA

Emergency Diesel Generator Weekly Test Log

Plant: COIP	Date: 12-fl /7
Operator: Va VJ5 n "Ja	
Main Generator Breaker	Connections
Open	-
Closed	V
Engine	Comms
Start Time: 5:57 q	t
Stop Time: 7:3	..
Total Run Time: 1:33	ft
Starting Hour Meter Reading	
Monthly Fuel Consumption (gal)	
Oil Level	V
Coolant Level	V
Coolant Temp. @ Start	73 °C
Coolant Temp. @ Finish	73 °C
Belt Condition	V
Oil Pressure	Start = 7 bar
Battery Condition	Finish = 7
Battery Voltage	11.8 V
Engine RPMs	1
Generator	Connections
Generator Volts	440 V
Generator Amps	1 A
Generator "KVA"	1 KVA
Reason For Use	Comments
Testing	1/
Emergency	
Maintenance	
Generator	Comments
Fuel Delivered	114.01 gal
Fuel Level	1/4 1/2 3/4 F <<<
Sulfur Concentrations	<0.0015% (1 Sppm)

This Emergency Generator shall be limited to use for emergency power as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: 3144

Date: 11/21/17

Operator: SJJ

Main Generator Breaker		Comments
Open	X	
Closed		
Engine		Comments
Start Time:	11:51	
Stop Time:	12:05	
Total Run Time:	5:14	
Starting Hour Meter Reading	11315	
Monthly Fuel Consumption(gal)		
Oil Level	V	
Coolant Level	Def	Coolant Temp. @ Start 51 *c Finish= 73 *c
Belt Condition	OK	
Oil Pressure		Start= 110 bar Finish= 110 bar
Battery Condition	Good	
Battery Voltage	24.1	
engine RPMs	1800	
Generator		Comments
Generator Volts		
Generator Amps		
Generator "KVA"		
Reason For Use		Comments
Testing	K	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level 1/4 1/2 3/4 F	9%	
Sulfur Concentrations <0.0015% (1 Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant *pkf 14*

Date: *7/21/17*

Operator: *st, J*

Main Generator Breaker		Comments
Open	<input checked="" type="checkbox"/>	
Closed	<input type="checkbox"/>	
Engine		Comments
Start Time:	<i>1&1<</i>	
Stop Time:	<i>18:11</i>	
Total Run Time:	<i>5 m:11</i>	
Starting Hour Meter Reading	<i>10</i>	
Monthly Fuel Consumption(gal)		
Oil Level	<i>Good</i>	
Coolant Level	<i>Good</i>	Coolant Temp. @ Start <i>5</i> *c Finish= <i>q</i> *c
Belt Condition	<i>(u.c.d)</i>	
Oil Pressure		Start= <i>79</i> bar Finish, <i>1</i> bar
Battery Condition	<i>Good</i>	
Battery Voltage	<i>12.8</i>	
Engine RPMs	<i>1800</i>	
Generator		Comments
Generator Volts		
Generator Amps		
Generator "KVA"		
Reason For Use		Comments
Testing	<input checked="" type="checkbox"/>	
Emergency	<input type="checkbox"/>	
Maintenance	<input type="checkbox"/>	
Generator		Comments
Fuel Delivered	<i>88 ?;</i>	
Fuel Level	<i>1/4</i> <i>1/2</i> <i>3/4</i> <i>F</i>	
Sulfur Concentrations		
<0.0015% (1 Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: 4/Jh1

Date: 10/17/2017

U-1JP-17

Operator: [Signature]

Main Generator - Breaker		Comments
Open		
Closed		
Engine		Comments
Start Time:	5	
Stop Time:	Alv?..	
Total Run Time:	fd Nl:ri	
Starting Hour Meter Reading	Q1	ertlr< . : g<to"
Monthly Fuel Consumption(gal)		
Oil Level	Ga.,/	
Coolant Level	'o .J	Coolant Temp. @ Start, I *c Finish= 7 [, *c
Belt Condition	Guurl.	
Oil Pressure		Start =<7.0 bar Finish={..7 bar
Battery Condition	GufJ rl	
Battery Voltage	-	
Engine RPMs	1800RPM	
Generator		Comments
Generator Volts	Lf. I(
Generator Amps	(: . ?II	
Generator "KVA"	Jk.}	
Reason For Use		Comments
Testing	. /	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level	1/4 1/2 3/4 F	
Sulfur Concentrations		
<0.0015% (1 Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: _____ Date: _____

Operator: *K. O.* _____

Main Generator Breaker	Comments
Open	
Closed	

Engine	Comments
Start Time:	<i>1:10 PM</i>
Stop Time:	<i>1:00 PM</i>
Total Run Time:	<i>10 MIN</i>
Starting Hour Meter Reading	<i>3.1</i>
Monthly Fuel Consumption(gal)	
Oil Level	<i>Full</i>
Coolant Level	<i>Low</i>
Belt Condition	<i>Normal</i>
Oil Pressure	Start= <i>1.9</i> bar Finish= <i>1.1</i> bar
Battery Condition	<i>Good</i>
Battery Voltage	<i>12.0</i>
engine RPMs	<i>1800</i>

Generator	Comments
Generator Volts	<i>120V</i>
Generator Amps	<i>15A</i>
Generator "KVA"	<i>1.8</i>

Reason For Use	Comments
Testing	<i>Weekly Test</i>
Emergency	
Maintenance	

Generator	Comments
Fuel Delivered	
Fuel Level	<i>1/4</i> F <i>10.0</i>
Sulfur Concentrations	<i><0.0015% (1 Sppm)</i>

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

ABENGOA

Emergency Diesel Generator Weekly Test Log

Plant: A\chtA Date: fl J -/7

Operator: TY - U;IA tr, ..

Main Generator Breaker		Comments
Open	<u>. /</u>	
Closed		

Enaine		Comments
Start Time:	<u>06.1</u>	
Stop Time:	<u>01.17</u>	
Total Run Time:	<u>15 M.11\</u>	
Starting Hour Meter Reading	<u>P-i.6</u>	
Monthly Fuel Consumption(gal)	<u>S.</u>	
Oil Level	<u>/</u>	
Coolant Level	<u>. /</u>	Coolant Temp.@ Start <u>l, l</u> *c Finish= <u>71</u> *c
Belt Condition	<u>/</u>	
Oil Pressure	<u>/</u>	Start = <u>A</u> bar Finish= <u>. 7oar</u>
Battery Condition	<u>/</u>	
Battery Voltage	<u>17.9..</u>	
Engine RPMs	<u>1e,00</u>	

Generator		Comments
Generator Volts	<u>y...x</u>	
Generator Amps	<u>tJP..</u>	
Generator "KVA"	<u>N/A</u>	

Reason For Use		Comments
Testing	<u>J</u>	
Emergency		
Maintenance		

Generator		Comments
Fuel Delivered	<u>/Jo</u>	
Fuel Level	<u>1/4 1/2 3/4 F</u>	<u>Be>'!</u>
Sulfur Concentrations		
<0.0015% (1 Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 1/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant 'g,_, Q

Date: . i -, - r - 1 1

Operator: Sh, 1

Main Genetater Bre,ker		Comments
Open	X	
Closed		
Engine		Comments
Start Time:	1 \$SS	
Stop Time:	i 9 DO	
Total Run Time:	S "11:"1	
Starting Hour Meter Reading	.3q3.1	1,1nr, Half, Me h... 193...
Monthly Fuel Consumption(gal)		
Oil Level		0 8 (, ' < 1: - 0) t! " > Yle.,
Coolant Level		Coolant Temp. @ Start 5 D *c Finish= a, - *c
Belt Condition	Good	
Oil Pressure	8 ii	Start= 8 ,/ bar Finish= t, 2 bar
Battery Condition	Good	
Battery Voltage	-	
c gine RPMs	11 '1	
Generator		Comments
Generator Volts		
Generator Amps		
Generator "KVA"		
Reason For Use		Comments'
Testing	X	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	1)	
Fuel Level [1/4] [1/2] [3/4] F	00 00	
Sulfur Concentrations <0.0015% (1 Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

ABENGOA

Emergency Diesel Generator Weekly Test Log

Plant: Al'hQ\ Date: fl-JA-17

Operator: 'M e r'fblll

MaiQ Generator breaker		Comments
------------------------	--	----------

Open	./	
------	----	--

Closed		
--------	--	--

Engine		Comments
--------	--	----------

Start Time:	11:10	
-------------	-------	--

Stop Time:	18:5	
------------	------	--

Total Run Time:	5 Min	
-----------------	-------	--

Starting Hour Meter Reading	PR.0	C.
-----------------------------	------	----

Monthly Fuel Consumption(gal)	0.0	
-------------------------------	-----	--

Oil Level	./	
-----------	----	--

Coolant Level	/	Coolant Temp. @ Start 5 - *c Finish= 7. *c
---------------	---	--

Belt Condition	/	
----------------	---	--

Oil Pressure	/	Start= 7.8 bar Finish=6.8 bar
--------------	---	-------------------------------

Battery Condition	7	
-------------------	---	--

Battery Voltage	11.2	
-----------------	------	--

Engine RPMs	1	
-------------	---	--

Generator		Comments
-----------	--	----------

Generator Volts	11.1	
-----------------	------	--

Generator Amps	0	
----------------	---	--

Generator "KVA"	a	
-----------------	---	--

Reason For Use'		Comments
-----------------	--	----------

Testing	/	
---------	---	--

Emergency		
-----------	--	--

Maintenance		
-------------	--	--

Generator		Comments
-----------	--	----------

Fuel Delivered	N	
----------------	---	--

Fuel Level <input type="checkbox"/> 1/4 <input type="checkbox"/> 1/2 <input type="checkbox"/> 3/4 <input type="checkbox"/> F	QJ	
--	----	--

Sulfur Concentrations		
-----------------------	--	--

<0.0015% (1 Sppm)		
-------------------	--	--

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

ABENGOA

Emergency Diesel Generator Weekly Test Log

Plant: JS

Date: 11/13/17

Operator: H. G. ...

Main Generator Breaker		Comments
Open	/	
Closed		
Engine		Comments
Start Time:	4	
Stop Time:	8:30	
Total Run Time:	4:30	
Starting Hour Meter Reading	5100	M 13
Monthly Fuel Consumption(gal)		
Oil Level	High	
Coolant Level	✓	Coolant Temp. @Start 59 °C Finish= 75 °C
Belt Condition	Good	
Oil Pressure	1.2	Start= 1.0 bar Finish= 1.0 bar
Battery Condition	6.00	
Battery Voltage	24.1	
Engine RPMs	1500	
Generator		Comments
Generator Volts	440	
Generator Amps		
Generator "KVA"	402	
Reason For Use		Comments
Testing	✓	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	110	
Fuel Level	1/4 1/2 3/4 (1) F	
Sulfur Concentrations	<0.0015% (1 Sppm)	

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 l/h) of load approximately.

ABENGOA

Emergency Diesel Generator Weekly Test Log

Plant:	A1Aha		Date:	11-1-11	
Operator:	\				
Main Gene, tor B.reaker			Comments		
Open	./				
Closed					
Engine			Comments		
Start Time:	1755				
Stop Time:	1810				
Total Run Time:	1141:20				
Starting Hour Meter Reading	B. (ie.3 !rl)				
Monthly Fuel Consumption(gal)					
Oil Level	✓				
Coolant Level			Coolant Temp. @ Start	5C, *c	Finish=i. *c
Belt Condition	./				
Oil Pressure			Start = 7, G	bar	Finish=t, (w) bar
Battery Condition	/				
Battery Voltage	.11.5				
Engine RPMs	IRC>0				
Generator			Comments		
Generator Volts	,,1a				
Generator Amps					
Generator "KVA"	-				
Reason For Use			Comments		
Testing	✓				
Emergency					
Maintenance					
Generator			Comments		
Fuel Delivered	No				
Fuel Level	1/4	1/2	3/4	F	Ri'
Sulfur Concentrations	<0.0015% (1 Sppm)				

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

ABENGOA

Operator(s): sk1/1/J'-Atl4'c (-flfil

C) NORTH AMERICA

Date: 11- a-(7

Emergency Diesel Generator Bi-Hourly Readings

Table with 10 columns: Time Of Reading, Oil Pressure, Gen. Voltage, Engine RPM, Coolant Temp. °C, Fuel Level, Hour Meter, Oil Temp, Gen. KWH, BTU. The table contains multiple rows of handwritten data entries.

Comments: R)py /{" uLl(0900 90%,

Three horizontal lines for additional notes or comments.

O

Emergency Diesel Generator Weekly Test Log

Plant: *ftlp* Date: *lt-'f-'17*

Operator: *Sc ...d*

Main Generator Breaker		Comments	
Open			
Closed			
Engine		Comments	
Start Time:			
Stop Time:			
Total Run Time:			
Starting Hour Meter Reading			
Monthly Fuel Consumption(gal)			
Oil Level			
Coolant Level		Coolant Temp.@ Start *c	Finish= *c
Belt Condition			
Oil Pressure		Start= bar	Finish= bar
Battery Condition			
Battery Voltage			
Engine RPMs			
Generator		Comments	
Generator Volts			
Generator Amps			
Generator "KVA"			
Reason For Use		Comments	
Testing			
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered	<i>100x)</i>		<i>A</i>
Fuel Level 1/4 1/2 3/4 F	<i>2,20,000</i>		
Sulfur Concentrations <0.0015% (1 Sppm)	<i>16.5</i>		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: 6

Date: // 4--I,

Operator: PHU

Main Generator Breaker		Comments	
Open			
Closed			
Engine		Comments	
Start Time:			
Stop Time:			
Total Run Time:			
Starting Hour Meter Reading			
Monthly Fuel Consumption(gal)			
Oil Level			
Coolant Level		Coolant Temp. @ Start *c	Finish= *c
Belt Condition			
Oil Pressure		Start= bar	Finish= bar
Battery Condition			
Battery Voltage			
Engine RPMs			
Generator		Comments	
Generator Volts			
Generator Amps			
Generator "KVA"			
Reason For Use		Comments	
Testing			
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered		<i>oeu vd 21: : : : fl oCfn</i>	
Fuel Level 1/4 1/2 3/4 N		'10-/6	
Sulfur Concentrations <0.0015% (1 Sppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

Emergency Diesel Generator Weekly Test Log

Plant: :lx tq

Date: 1/ -/7

Operator: \$ I / "f)H H..---

Main Generate* Breaker		Comments
Open	ct, 2D	
Closed	U.S	s nchroh, <cl
Engine		Comments
Start Time:	yg	
Stop Time:	\	
Total Run Time:	%J'1	
Starting Hour Meter Reading	3t..k. 3	tPJJO. 'f, 'L...9
Monthly Fuel Consumption(gal)		
Oil Level	aovd	
Coolant Level	Oood	Coolant Temp. @ Start 7 *c Finish=1S-*c
Belt Condition	&accJ	
Oil Pressure		Start= , .3 bar Finish= l:,t. bar
Battery Condition	G-ooJ	
Battery Voltage	:u. !5	
Engine RPMs	LZoo	
Generator		Comments
Generator Volts	4K: 0	
Generator Amps	rll	
Generator "KVA"	1,3	
Reason For Use		Comments
Testing		
Emergency	"X	r..G-o./c.r'-Mei" J-es:rf/-mq
Maintenance		
Generator		Comments
Fuel Delivered	o9c:.0 -11- -Lr '1d7o
Fuel Level J 1/4 1/2 3/4 F	loto%	
Sulfur Concentrations <0.0015% (1 Sppm)	41"	1-2,10 r (, .14- OltJ... J

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 1/h) of load approximately.

ABENGOA

Emergency Diesel Generator Weekly Test Log

Emergency Diesel Generator Weekly Test Log

Plant: A | Ph

Date: 10/11/17

Operator: tZ&K Mmh 5

Milin Generator Breaker		Cap111el:1ts	
Open	>.		
Closed			
Engine		Comments	
Start Time:	01f6		
Stop Time:	0i, Z&		
Total Run Time:	(M, 1)		
Starting Hour Meter Reading	87, ?A	frid'r.c g-g-1	
Monthly Fuel Consumption(gal)			
Oil Level	bh7 rf		
Coolant Level	G(0)E	Coolant Temp. @Start () *c	Finish=75 *c
Belt Condition	6tJr:}		
Oil Pressure		Start= C) bar	Finish=(•./h bar
Battery Condition	voov{		
Battery Voltage	A(, q		
Engine RPMs	10>0		
Generator		Comments	
Generator Volts	4.1L/Jtv		
Generator Amps			
Generator "KVA"			
Reason For Use		Comments	
Testing	>.		
Emergency			
Maintenance			
Generator		Comments	
Fuel Delivered			
Fuel level 1/4 1/2 3/4 F	(0L %		
Sulfur Concentrations			
<0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.571/h) of load approximately.

ABENGOA

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: '12: > *a* Date: /0 {-z.W} {w c 1

Operator: *t-v* *¥4*

Main Generator breaker		Comments
Open	<i>V.</i>	
Closed		
Engine		Comments
Start Time:	<i>ZOLF</i>	
Stop Time:	<i>'71 V</i>	
Total Run Time:	<i>\o MIN</i>	
Starting Hour Meter Reading	<i><10pi</i>	<i>0.1-0.1U>, 3W= (i)</i>
Monthly Fuel Consumption(gal)	<i>1.1</i>	
Oil Level	<i>100%</i>	
Coolant Level	<i>W.L.</i>	Coolant Temp.@ Start S *c Finish= <i>1</i> *c
Belt Condition	<i>a.c.v</i>	
Oil Pressure		Start= <i>0-0</i> bar Finish= <i>w.1</i> bar
Battery Condition	<i>(\Ob!)</i>	
Battery Voltage	<i>...</i>	
Engine RPMs	<i>1800</i>	
Generator		Comments
Generator Volts	<i>4.4</i>	
Generator Amps		
Generator "KVA"		
Reason For Use		Comments
Testing	<i>/</i>	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level 1/4 1/2 3/4 F	<i>(1)dn</i>	
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine *may* operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 1/h) of load approximately.

ABENGOA

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: *Avl.c.* Date: *10/11/11*

Operator: *C*

Main Generator Breaker		Comments
Open	<i>v''</i>	
Closed		
Engine		Comments
Start Time:	<i>19:15g</i>	
Stop Time:	<i>1/1/3</i>	
Total Run Time:	<i>1:00:00</i>	
Starting Hour Meter Reading	<i>K7,t</i>	
Monthly Fuel Consumption(gal)	<i>f,z,i,i</i>	
Oil Level	<i>1/2</i>	
Coolant Level	<i>1/2</i>	Coolant Temp. @ Start <i>h''</i> *c Finish= <i>7s</i> *c
Belt Condition	<i>o c,l</i>	
Oil Pressure		Start= <i>l,q</i> bar Finish= <i>6-6</i> bar
Battery Condition	<i>1cc-1</i>	
Battery Voltage	<i>1.71/</i>	
Engine RPMs	<i>1/1000</i>	
Generator		Comments
Generator Volts	<i>110.7</i>	
Generator Amps		
Generator "KVA"		
Reason For Use		Comments
Testing	<i>i/</i>	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level 1/4 1/2 3/4 F	<i>1/2</i>	
Sulfur Concentrations <0.0015% (1 Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Note: Fuel consumption 114.01 gal/h (431.57 1/h) of load approximately.

Diesel Generator Weekly Test Log

Plant: Beta

Date: 2-2-17

Operator: Cit/8 b Si, vd

Main Generator Breaker		Comments
Open		
Closed	/	
Engine		Comments
Start Time:	n4r:fl	
Stop Time:	1	
Total Run Time:	n	
Starting Hour Meter Reading	1	
Ending Hour Meter Reading	12.57	
Oil Level	yf	
Coolant Level	rrr	Coolant Temp. @ Start, *c Finish=7v, *c
Belt Condition	dry	
Oil Pressure	...	Start bar Finish= bar
Battery Condition	rttr	
Battery Voltage	U7(n	
Engine RPMs	111)	
Generator		Comments
Generator Volts		
Generator Amps		
Generator "KVA"		
Reason For Use		Comments
Testing	✓	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level 1/4 1/2 3/4 F	(11? C76	
Sulfur Concentrations <0.0015% (ISppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the

outage no longer imminent or in effect.

Diesel Generator Weekly Test Log

Plant: **Alo**

Date: **ID /6-17**

Operator: **W. L. Vrtel**

Main Generator Breaker		IG. OI' Wrtel's	
Open	/		
Closed			
Enalne		om enls	
Start Time:	JFY1		
Stop Time:	10		
Total Run Time:	16 n, ft1E,		
Starting Hour Meter Reading	'A1.?'>		
Ending Hour Meter Reading	fol. fI		
Oil Level	Nonna		
Coolant Level	frMn	Coolant Temp. @ Start 57 *c	Finish= 7!J* c
Belt Condition	o(
Oil Pressure		Start= 7.1=) bar	Finish= . C.bar
Battery Condition	1. = 7. 00		
Battery Voltage	9.0		
Engine RPMs	jcg0Q		
Geqer_at		Coml', lenj_s	
Generator Volts	t'lo		
Generator Amps	@		
Generator "KVA"	0		
Reason For Use		(Comments	
Testing	J		
Emergency			
Maintenance			
Generator		Commiets	
Fuel Delivered	NO		
Fuel Level	1/4 1/2 3/4 F	G/J..1'	
-Sulfur Concentrations			
<0.0015% (15ppm)			

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Diesel Generator Weekly Test Log

Plant: Beta

Date: 03/17

Operator: *JW/I*

Main Generator Breaker		Comments
Open	X	
Closed		
Engine		Comments
Start Time:	12:00	
Stop Time:	12:03	
Total Run Time:	6 min	
Starting Hour Meter Reading	365.1	
Ending Hour Meter Reading	371.1	
Oil Level	Good	
Coolant Level	Good	Coolant Temp.@ Start 50°C Finish= 55°C
Belt Condition	Good	
Oil Pressure	7	Start = 1.5 bar Finish= 7.5 bar
Battery Condition	Good	
Battery Voltage	12.8	
Engine RPMs	1500	
Generator		Comments
Generator Volts		
Generator Amps		
Generator "KYA"		
Reason For Use		Comments
Testing	X	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	1.0	
Fuel Level 1/4 1/2 3/4 F	0.7%	
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Diesel Generator Weekly Test Log

Plant: Beta

Date:

10-7-11

Operator: J. L. Hill

Main Generator Breaker		Comments
Open	X..	
Closed		
Engine		Comments
Start Time:	03:12	
Stop Time:	03:31	
Total Run Time:	5 MIN	
Starting Hour Meter Reading	115	
Ending Hour Meter Reading	315.1	
Oil Level	Good	
Coolant Level	Good	Coolant Temp. @ Start 50°C Finish= 70°C
Belt Condition	Good	
Oil Pressure		Start= 8.1 bar Finish= 9.1 bar
Battery Condition	Good	
Battery Voltage	12.1	
EngineRPMs	1500	
Generator		Comments
Generator Volts	240	
Generator Amps	20	
Generator "KVA"		
Reason for Use		Comments
Testing	Yes	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	1.0	
Fuel Level	1/4 1/2 3/4 F	1/4
Sulfur Concentrations	<0.0015% (15ppm)	See 10/7/11 Fuel Analysis

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Diesel Generator Weekly Test Log

Unit: *Alaska* Date: *10/5/17*
Steele

Operator: *Steele*

Main Generator Breaker		Comments				
Open	./					
Closed						
Engine		Comments				
Start Time:	<i>10:15</i>					
Stop Time:	<i>10:20</i>					
Total Run Time:	<i>5 min</i>					
Starting Hour Meter Reading	<i>1.1</i>					
Ending Hour Meter Reading	<i>81.3</i>					
Oil Level	<i>Full</i>					
Coolant Level	<i>Full</i>	Coolant Temp. @ Start <i>71</i> °C Finish = <i>71</i> °C				
Belt Condition	<i>Normal</i>					
Oil Pressure	<i>1.0</i>	Start = 1.3 bar Finish = 1.4 bar				
Battery Condition	<i>Good</i>					
Battery Voltage	<i>11.0</i>					
Engine RPMs	<i>900</i>					
Generator		Comments				
Generator Volts	<i>240</i>					
Generator Amps	<i>0</i>					
Generator "KVA"	<i>0</i>					
Reason For Use		Comments				
Testing	/					
Emergency						
Maintenance						
Generator		Comments				
Fuel Delivered						
Fuel Level	<table border="1" style="display: inline-table; border-collapse: collapse;"> <tr> <td style="width: 20px;">1/4</td> <td style="width: 20px;">1/2</td> <td style="width: 20px;">3/4</td> <td style="width: 20px;">F</td> </tr> </table> <i>3.5</i>	1/4	1/2	3/4	F	
1/4	1/2	3/4	F			
Sulfur Concentrations						
<0.0015% (15ppm)						

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Diesel Generator Weekly Test Log

Plant: Beta

Date:

8/11/11

Operator: C.O

Main Generator Breaker		Comments
Open		
Closed	✓	
Engine		Comments
Start Time:	11:45 AM	
Stop Time:	12:15 PM	
Total Run Time:	30 Min	
Starting Hour Meter Reading	3105	
Ending Hour Meter Reading	3135	
Oil Level	High	
Coolant Level	High	Coolant Temp. @ Start 51 °C Finish = 48 °C
Belt Condition	OK	
Oil Pressure	Normal	Start = 1.2 bar Finish = 1.1 bar
Battery Condition	Good	
Battery Voltage	12.8	
Engine RPMs	1600	
Generator		Comments
Generator Volts	240	
Generator Amps	10	
Generator "KVA"	1.5	
Reason For Use		Comments
Testing	/	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level 1/4 1/2 3/4 F	6, 0	
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Diesel Generator Weekly Test Log

Plant: *AY001* Date: *1/2-7, 117*

Generator: *Lo\ \n AY001 or,*

Main Generator Breaker		<i>r,omn.terit,</i>
Open	<i>-</i>	
Closed		
Engine		<i>t?Qmrnenu</i>
Start Time:	<i>21:77</i>	
Stop Time:	<i>22:77</i>	
Total Run Time:	<i>1 c; J,inc.Hc:5</i>	
Starting Hour Meter Reading	<i>fbf</i>	
Ending Hour Meter Reading	<i>g7 J</i>	
Oil Level	<i>))C'la2tlI</i>	
Coolant Level	<i>.v: >(1MI</i>	Coolant Temp. @ Start <i>S'1 *c</i> Finish= <i>75*c</i>
Belt Condition	<i>G&'oA</i>	
Oil Pressure	<i>.U.D/vyLAI</i>	Start= <i>7-;, bar</i> Finish= <i>&. bar</i>
Battery Condition	<i>&ooJ</i>	
Battery Voltage	<i>? 75</i>	
EngineRPMs	<i>1880</i>	
Generator		1:omrrients
Generator Volts	<i>1, / 7</i>	
Generator Amps		
Generator "KVA"		
Generator		C_pments
Testing	<i>V</i>	
Emergency		
Maintenance		
Generator		6000Lme
Fuel Delivered		
Fuel Level 1/4 <i>111.0</i> 3/4 F	<i>2- /</i>	
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Diesel Generator Weekly Test Log

Plant: **PP1a** Date: **9/11/16**

Operator: **14**

Main Generator Breaker		Comments
Open		
Closed	V	
Engine		Comments
Start Time:	10:11 PM	
Stop Time:	11:00 PM	
Total Run Time:	0 Min	
Starting Hour Meter Reading	305,000	
Ending Hour Meter Reading	305,000	
Oil Level	Full	
Coolant Level		Coolant Temp. @ Start 114.5 *c Finish: 114 *c
Belt Condition	Good	
Oil Pressure	40-50 PSI	Start = 40 , 1 bar Finish = 40 , 1 bar
Battery Condition	Good	
Battery Voltage	24.2	
Engine RPMs	1500	
Generator		Comments
Generator Volts	411	
Generator Amps	0	
Generator "KVA"	0	
Reason For Use		Comments
Testing	1	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level 1/4 1/2 3/4 F	100%	CLP/1
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut inmediately after the utility advises that the outage no longer imminent or in effect.

Diesel Generator Weekly Test Log

Plant: Beta

Date:

12/11/11

Operator: C.C

Main Generator Breaker		Comments
Open		
Closed	✓	
Engine		Comments
Start Time: 11:00 AM	11:00 AM	
Stop Time: 11:10 AM	11:10 AM	
Total Run Time:	10 Mins	
Starting Hour Meter Reading	111	
Ending Hour Meter Reading	121	
Oil Level	- / -	
Coolant Level	✓	Coolant Temp. @ Start 50 °c Finish= 110 °c
Belt Condition	✓	
Oil Pressure	✓	Start= 1.1 bar Finish 1 bar
Battery Condition	✓	
Battery Voltage	12.8V	
Engine RPMs	1500	
Generator		Comments
Generator Volts		
Generator Amps	113	
Generator "KVA"	1.1	
Reason For Use		Comments
Testing	✓	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level	1/4 1/2 3/4 F	
Sulfur Concentrations	<0.0015% (15ppm)	

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Diesel Generator Weekly Test Log

Plant: Beta

Date:

2/1/11

Operator:

ICo

Main Generator Breaker		Comments
Open		
Closed	✓	
Engine		Comments
Start Time:	1:00 PM	
Stop Time:	1:00 PM	
Total Run Time:	0:00	
Starting Hour Meter Reading	3500	
Ending Hour Meter Reading	3500	
Oil Level	Full	
Coolant Level	Normal	Coolant Temp. @ Start 50 °C Finish= 110 °C
Belt Condition	Good	
Oil Pressure	Normal	Start= 0.5 bar Finish= 1.5 bar
Battery Condition	Normal	
Battery Voltage	24V	
Engine RPMs	1500	
Generator		Comments
Generator Volts	240V	
Generator Amps	0A	
Generator "KVA"	0kVA	
Reason For Use		Comments
Testing	/	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level	1/4 1/2 3/4 Full	Full
Sulfur Concentrations	<0.0015% (15ppm)	OK

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Diesel Generator Weekly Test Log

Unit: **Rt1-In**

Date: **C[-]q-[-]7**

Operator: **O. A.**

Main Generator Breaker		Comments
Open 1.7		
Closed r		
Engine		Comments
Start Time:		
Stop Time:		
Total Run Time:		
Starting Hour Meter Reading	111.1	
Ending Hour Meter Reading	111.1	
Oil Level	1/2	
Coolant Level	1/2	Coolant Temp. @ Sta *c Finish=?/ *c
Belt Condition	OK	
Oil Pressure	75	Start =75, J bar Finish bar
Battery Condition	2't.f.	
Battery Voltage	26.0	
Engine RPMs	1000	
Generator		Comments
Generator Volts	440	
Generator Amps	11.5	
Generator "KVA"	1.7	
Reason For Use		Comments
Testing		
Emergency		
Maintenance	V	
Generator		Comments
Fuel Delivered		
Fuel Level 1/4 1/2 3/4 F	1.7	1.7
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Diesel Generator Weekly Test Log

Unit:

r--f-0

Date: 9/1/12

Operator:

AV

Main Generator Breaker		Comments
Open		
Closed	✓	
Engine		Comments
Start Time:	7:16	
Stop Time:	7:22	
Total Run Time:	6 min	
Starting Hour Meter Reading	7747	
Ending Hour Meter Reading	7753	
Oil Level	OK	
Coolant Level	MC	Coolant Temp. @ Start *c Finish=";6'*c
Belt Condition	OK	
Oil Pressure	77	Start = ff, 2. bar Finish=t; ar
Battery Condition	OK	
Battery Voltage	72.5V	
Engine RPMs	1800	
Generator		Comments
Generator Volts	117v	
Generator Amps	10	
Generator "KVA "	Alt	
Reason For Use		Comments
Testing	✓	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level 1/4 1/2 3/4 F	1/2	
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Diesel Generator Weekly Test Log

Plant: *AljA,,* Date: *9/7-8117*

Operator: *m. thcti*

Main Generator Breaker		Comments
Open		
Closed	<i>/</i>	
Engine		Comments
Start Time:	<i>JC>/C,</i>	
Stop Time:	<i>(\, /# . ¥i</i>	
Total Run Time:	<i>B1r... /iiuvfic:</i>	
Starting Hour Meter Reading	<i>71.0</i>	
Ending Hour Meter Reading	<i>8 !). O</i>	
Oil Level	<i>Mr... !</i>	
Coolant Level	<i>lllorM /</i>	Coolant Temp.@ StartC,8 *c Finish=70 *c
Belt Condition	<i>C-c.ctJ</i>	
Oil Pressure	<i>70</i>	Start=,,, bar Finish= 7:0bar
Battery Condition	<i>G>∞</i>	
Battery Voltage	<i>2 ?:::</i>	
Engine RPMs	<i>/</i>	
Generator		Comments
Generator Volts	<i>1.18</i>	
Generator Amps		
Generator "KVA "		
Reason For Use		Comments
Testing		
Emergency		
Maintenance		<i>Con h"&rcbjs w611q M Ti:hr.f.</i>
Generator		Comments
Fuel Delivered	<i>/</i>	<i>JJ.q8, Colt>s tJel,>r.a!</i>
Fuel Level I 1/4 1/2 3/4 F	<i>e11</i>	
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power. as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Diesel Generator Weekly Test Log

Unit: *Alett f* Date: *11, - 7/;7*

Operator: *f\;d\m'*

Main Generator Breaker		Comments
Open		
Closed	/	

Engine		Comments
Start Time:	<i>(:01</i>	
Stop Time:	<i>(iBC;</i>	
Total Run Time:	<i>5 hrs .21/rt. c</i>	
Starting Hour Meter Reading	<i>.B,J/</i>	
Ending Hour Meter Reading	<i>71.0</i>	
Oil Level	<i>,"In/</i>	
Coolant Level	<i>/VOI"MP.f</i>	Coolant Temp. @ Start <i>7,</i> *c Finish= <i>7</i> *c
Belt Condition	<i>VOOJ</i>	
Oil Pressure	<i>,7</i>	Start= <i>,</i> bar Finish= <i>,. 1</i> bar
Battery Condition	<i>J</i>	
Battery Voltage	<i>:17. I/</i>	
Engine RPMs	<i>/600</i>	

Generator		Comments
Generator Volts	<i>/6</i>	
Generator Am(S		
Generator "KVA"		

Reason For Use		Comments
Testing		
Emergency		
Maintenance	<i>v'</i>	<i>C,n n-tr hlt;S 1J1rJ;i0f DP f,-un L,-P./,</i>

Generator		Comments
Fuel Delivered		
Fuel Level 1/4 1/2 3/4 F	<i>,18J.</i>	
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Diesel Generator Weekly Test Log

Plant: A \ 11011
1)

Date: 1-5-17

Operator: J. Cle / J. Jr. fl > 11

Main Generator Breaker		Comments
Open	/	
Closed		
Engine		Comments
Start Time:	1:00	
Stop Time:	1:10	
Total Run Time:	11 min 5	
Starting Hour Meter Reading	10	
Ending Hour Meter Reading	21	
Oil Level	Normal	
Coolant Level	Normal	Coolant Temp. @ Start *c Finish= *c
Belt Condition	OK	
Oil Pressure		Start= bar Finish= bar
Battery Condition	Good	
Battery Voltage	12.7V	
Engine RPMs	1500	
Generator		Comments
Generator Volts	120	
Generator Amps		
Generator "KVA"		
Reason For Use		Comments
Testing	./	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level 1/4 1/2 3/4 F	S.	
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Diesel Generator Weekly Test Log

Plant: *Alpha*

Date: *C-LO-JI*

Operator: *fill; JJ*

Main Generator Breaker		Comments
Open		
Closed	<i>✓</i>	
Engine		Comments
Start Time:	<i>0740</i>	
Stop Time:	<i>0750</i>	
Total Run Time:	<i>10 min</i>	
Starting Hour Meter Reading	<i>82.3</i>	
Ending Hour Meter Reading	<i>82.4</i>	
Oil Level	<i>good</i>	
Coolant Level	<i>good</i>	Coolant Temp. @ Start <i>42</i> °c Finish= <i>73</i> °c
Belt Condition	<i>good</i>	
Oil Pressure	<i>7.8</i>	Start = <i>7.0</i> bar Finish= <i>7.0</i> bar
Battery Condition	<i>✓</i>	
Battery Voltage	<i>12.8</i>	
Engine RPMs	<i>1500</i>	
Generator		Comments
Generator Volts	<i>N/A</i>	
Generator Amps	<i>N/A</i>	
Generator "KVA"	<i>N/A</i>	
Reason For Use		Comments
Testing	<i>✓</i>	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level 1/4 1/2 3/4 F	<i>70%</i>	
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

ABENGOA

Operator(s): fib 1 I ... 6<-f-t\

C) NORTH AMERICA

Date: 9-1-11

Emergency Diesel Generator Bi-Hourly Readings

Time Of Reading	Oil Pressure	Gen. Voltage	Engine RPM	Coolant Temp.'c	Fuel Level %	Hour Meter	Oil Temp	Gen. KWH
00:30	.i.	.!t .11	12,;,	80 -	7 SJ	3-ltq., 1	, 8 'c	1008'
01:30	l, '(o	<f i J	/ E.Oo	19 °c:	<=>S	'5()/	- ... <	C/g
01:27	g ''-	J/11/	f 6 o()	"S" :	1	J51, D	7 f. "c	: 0.S3
02:30	l, ' b	<f i	/ BYO	78	8"i	- 6L	7	1 OI \$

Barr
va (IS
K0<j
'=.c/
*...o
?-7.0

C)

Comments: EJG6f6fr6P -00/02,
tx... \ ..-t l-1- 1 C A K S / (fi < 1

C)

ABENGOA

Operator(s): S. U. IVKLU

C) NORTH AMERICA

Date: 8 1 11

Emergency Diesel Generator Bi-Hourly Readings

Time Of Reading	Oil Pressure	Gen. Voltage	Engine RPM	Coolant Temp.	Fuel Level	Hour Meter	Oil Temp	Gen. KWH
02:00	31.0
04:00	330.1
06:00	334.0
08:00	350.0
10:00	360.0
12:00	370.0
14:00	380.0
16:00	390.0
18:00	400.0
20:00	410.0

11.0
& 1.0
11.0
11.0
11.0
11.0
11.0
11.0
11.0
11.0
11.0

Comments: 111 Re.e6N 10

fhG: Dtg CT. 1?Q- u & oea £\$;

'IID wR %Yet\VC, :iY.h .acJ I'% >YA

TRANSFORMER

O

CJ

ABENGOA

Operator(s): S Ly / J. J. w

CJ NORTH AMERICA

Date: 11/17

Emergency Diesel Generator Bi-Hourly Readings

Time ↓

Time Of Reading	Oil Pressure	Gen. Voltage	Engine RPM	Coolant Temp.	Fuel Level	Hour Meter	Oil Temp	Gen. KWH
0000	43	111S	1830	1g	S	303	46	35
0400	43	111S	1830	1g	S	304	46	38
1010	43	111S	1830	1g	S	305	46	41
1015	43	111S	1830	1g	S	306	46	44
1020	43	111S	1830	1g	S	307	46	47
1025	43	111S	1830	1g	S	308	46	50
1030	43	111S	1830	1g	S	309	46	53
1035	43	111S	1830	1g	S	310	46	56
1040	43	111S	1830	1g	S	311	46	59
1045	43	111S	1830	1g	S	312	46	62
1050	43	111S	1830	1g	S	313	46	65
1055	43	111S	1830	1g	S	314	46	68
1100	43	111S	1830	1g	S	315	46	71
1105	43	111S	1830	1g	S	316	46	74
1110	43	111S	1830	1g	S	317	46	77
1115	43	111S	1830	1g	S	318	46	80
1120	43	111S	1830	1g	S	319	46	83
1125	43	111S	1830	1g	S	320	46	86
1130	43	111S	1830	1g	S	321	46	89
1135	43	111S	1830	1g	S	322	46	92
1140	43	111S	1830	1g	S	323	46	95
1145	43	111S	1830	1g	S	324	46	98
1150	43	111S	1830	1g	S	325	46	101
1155	43	111S	1830	1g	S	326	46	104
1200	43	111S	1830	1g	S	327	46	107
1205	43	111S	1830	1g	S	328	46	110
1210	43	111S	1830	1g	S	329	46	113
1215	43	111S	1830	1g	S	330	46	116
1220	43	111S	1830	1g	S	331	46	119
1225	43	111S	1830	1g	S	332	46	122
1230	43	111S	1830	1g	S	333	46	125
1235	43	111S	1830	1g	S	334	46	128
1240	43	111S	1830	1g	S	335	46	131
1245	43	111S	1830	1g	S	336	46	134
1250	43	111S	1830	1g	S	337	46	137
1255	43	111S	1830	1g	S	338	46	140
1300	43	111S	1830	1g	S	339	46	143
1305	43	111S	1830	1g	S	340	46	146
1310	43	111S	1830	1g	S	341	46	149
1315	43	111S	1830	1g	S	342	46	152
1320	43	111S	1830	1g	S	343	46	155
1325	43	111S	1830	1g	S	344	46	158
1330	43	111S	1830	1g	S	345	46	161
1335	43	111S	1830	1g	S	346	46	164
1340	43	111S	1830	1g	S	347	46	167
1345	43	111S	1830	1g	S	348	46	170
1350	43	111S	1830	1g	S	349	46	173
1355	43	111S	1830	1g	S	350	46	176

B014...
 L>C)rt
 i7<
 1.0
 a1.1
 d1-0
)"l. 0
 21
 26.q
 dC.q
 la+f
 1. 8
 11. ?
 122,0

Comments: Delivery At 11:30 AM ^{gallons} ~~Before filling up:~~ 2101 gallons
^{gallons} After filling up: 1899 gallons

ABENGOA

Operator(s): Pb: / / ff, " " ..

ETA

C) NORTH AMERICA

Date: 9f- >>t)

Emergency Diesel Generator Bi-Hourly Readings

Time Of Reading	Oil Pressure	Gen. Voltage	Engine RPM	Coolant Temp.	Fuel Level	Hour Meter	Oil Temp	Gen. KWH	Bat Volts
0000	...	111J	1? '1 1	7	i 1.5)	105.0	'17	110	
07.00	1. >	1f 13	10"o	? &	i 1 %	? .0?	7r,	5 e	
0460	i 1/	4 f/f	1f50o	77	SS->	? . . \$. .	75	100	2)
0700	. 1	1 V	{b" ,	17	5Si,	11. 1/	- f	6J	? . 1
0800	(o.)	'f, 1A	1g0	7 "	5 /	13.j	7/.	818	7. 1
1000	Cl.	1.1	130	f:0	tt. 7-	'ti > 1	7J	1011	-70
1100	i. i	11 (L	1 "	91.	70%.	1.1/ 7.0		b ff? ...	7.0
1200	(d. t	'6. 11	10	7fK	r 4	11q."1	9"1	((.1	2... 6
1300	.../	1f, 11	10	15	121 1.	-Z.11 .R	S-1	Cio	2, .
1400	1	4	104	9.i,	19-%	22.3.1		10b4	1-1
1500	" . 1	1. i 11	100	9	1%	214-01	< 70	1066	VR
1600	(. 1	11&1	100	9)e,	1%	21-b,	1-i	< if? ?	e (
1700	b L	4-13	1"iroo	9	C:V	21'7.0	'1 < ?;	y > 11	")... ,
1800	G, >	4. 1i	1550	15	?C. 70	231.0	1 (-	y. : >	. i. ,
1900	b	4. , 'b	1600	11	6DJo	231.	'1')	::-5	z. r

Comments: Topped off at 1217 deck oil gave us 1836.2 gal

C)

ABENGOA

Operator(s): Rh, Jfg. : jw/sw

C) '1JURI' H AMERICA

Date: 8-1v 17

Emergency Diesel Generator Bi-Hourly Readings

Time Of Reading	Oil Pressure	Gen. Voltage	Engine RPM	Coolant Temp.	Fuel Level	Hour Meter	Oil Temp	Gen. KWH
0000	4.1	11.1	177	77	5.1	11.1	75	1.7, 1
0005	4.1	11.1	177	77	5.1	11.1	75	27.0
0010	4.1	11.1	177	77	5.1	11.1	75	17.0
0015	4.1	11.1	177	77	5.1	11.1	75	1.0
0020	4.1	11.1	177	77	5.1	11.1	75	27.0
0025	4.1	11.1	177	77	5.1	11.1	75	27.0
0030	4.1	11.1	177	77	5.1	11.1	75	27.0
0035	4.1	11.1	177	77	5.1	11.1	75	27.0
0040	4.1	11.1	177	77	5.1	11.1	75	27.0
0045	4.1	11.1	177	77	5.1	11.1	75	27.0
0050	4.1	11.1	177	77	5.1	11.1	75	27.0
0055	4.1	11.1	177	77	5.1	11.1	75	27.0
0100	4.1	11.1	177	77	5.1	11.1	75	27.0
0105	4.1	11.1	177	77	5.1	11.1	75	27.0
0110	4.1	11.1	177	77	5.1	11.1	75	27.0
0115	4.1	11.1	177	77	5.1	11.1	75	27.0
0120	4.1	11.1	177	77	5.1	11.1	75	27.0
0125	4.1	11.1	177	77	5.1	11.1	75	27.0
0130	4.1	11.1	177	77	5.1	11.1	75	27.0
0135	4.1	11.1	177	77	5.1	11.1	75	27.0
0140	4.1	11.1	177	77	5.1	11.1	75	27.0
0145	4.1	11.1	177	77	5.1	11.1	75	27.0
0150	4.1	11.1	177	77	5.1	11.1	75	27.0
0155	4.1	11.1	177	77	5.1	11.1	75	27.0
0200	4.1	11.1	177	77	5.1	11.1	75	27.0
0205	4.1	11.1	177	77	5.1	11.1	75	27.0
0210	4.1	11.1	177	77	5.1	11.1	75	27.0
0215	4.1	11.1	177	77	5.1	11.1	75	27.0
0220	4.1	11.1	177	77	5.1	11.1	75	27.0
0225	4.1	11.1	177	77	5.1	11.1	75	27.0
0230	4.1	11.1	177	77	5.1	11.1	75	27.0
0235	4.1	11.1	177	77	5.1	11.1	75	27.0
0240	4.1	11.1	177	77	5.1	11.1	75	27.0
0245	4.1	11.1	177	77	5.1	11.1	75	27.0
0250	4.1	11.1	177	77	5.1	11.1	75	27.0
0255	4.1	11.1	177	77	5.1	11.1	75	27.0
0300	4.1	11.1	177	77	5.1	11.1	75	27.0
0305	4.1	11.1	177	77	5.1	11.1	75	27.0
0310	4.1	11.1	177	77	5.1	11.1	75	27.0
0315	4.1	11.1	177	77	5.1	11.1	75	27.0
0320	4.1	11.1	177	77	5.1	11.1	75	27.0
0325	4.1	11.1	177	77	5.1	11.1	75	27.0
0330	4.1	11.1	177	77	5.1	11.1	75	27.0
0335	4.1	11.1	177	77	5.1	11.1	75	27.0
0340	4.1	11.1	177	77	5.1	11.1	75	27.0
0345	4.1	11.1	177	77	5.1	11.1	75	27.0
0350	4.1	11.1	177	77	5.1	11.1	75	27.0
0355	4.1	11.1	177	77	5.1	11.1	75	27.0
0400	4.1	11.1	177	77	5.1	11.1	75	27.0

Comments: 1/3 o A.d.l.o.f. 16. ... /5 &' & ct. 6:r...fn' s'u
S_v , ts ta:55.1 s j. is 10.9

CJ

ABENGOA

NORTH AMERICA

Operator(s): lu.ar

Date: 7-1-11

Emergency Diesel Generator Bi-Hourly Readings

Time Of Reading	Oil Pressure	Gen. Voltage	Engine RPM	Coolant Temp.	Fuel Level	Hour Meter	Oil Temp	Gen. KWH
t: 0:--	1	.N	nCct	16	179!	+(7.1	11° 6L	ID'-fl
In:0	L-	:11	Jtr()	tn.	Oo/	11'L.3	id-r-	/1}t
V) i:O-	3	Y1	\oD		'd'h	11f.	is c	Jo /o
'2o	1.1	fl."	YAO	is	<1	TY 3	s α	100
N.30-11A	L. 1	:L. q	.1qq	ts	TV.	J. S	α	mIQ
to 0	1.1	'2. G	17'IC	c:	1' /	/ .ct	i3	
::L.D: (3o)	G.,	...t'	igoo	3	70	id?, 1	g'	IJH9
::a.: /5-	G. .i.	r i c	1s Oil	30	6.5	ms'	8 o't.	/017
ELM: 0	.1	q i I	1,TOo	oJ	<- /	13	79t.e	r, '-fl
	1/01 .5-	.2ol?						
D	.3	'i i /	.79q	7.4a f	5&-	135 .a.	79.c	fo t
fY/ o-o		'-11	I .ao	?S'	.55	r3" cf	... 1'f...	/ 18
L. 1.00 fRM	- 1	't I 4	li"Oo	115	S 1,	J 3 q)	1' / ...	b. :..
... (MA)	!	L. J	.-37	, q	'-v7o	k-ill!l	.1 tc	100l
r."Y.fly...	L.O.	11<	V:..o	i \	Y<..	1'-i. S	D"	.1.
VT. ...	LI	'-1\	1f1H)	Qf	1.1 1	\-Y.	i::1	11io
... DO E I	t. I	'\ V	nqq	Y<	3il.	I41...q	-	1S!..
I. 0612	t. \	'<	1.c:g	l.	55io	I 'i q	Y<i	11ef9
..itoc	1. 1	'-J1	I'1 qq	8.1	23'I	14' .0	'a'	1d
ldfo r	&,'	4 li	797	954	33	tt.:l.	S'J.	11'i<
7. a 6	fl.?	.ft{	11	13'	3.8%	ISS.	i	1o7c
-ZCfo	.2-	... 13	1'7qf	81	11 lo	Is?, /	79	11&13

BATTERY volts

26.9
27.0
27.0

11.9

J.7.a

J1.0
a.0

1.0
1.0

10.0

2.1
J.C. \

6.7, 0

Comments: -----

C

CJ

ABENGOA

Operator(s): sk .ll / £fr, il

NORTH AMERICA

Date: 8-7-(?)

Emergency Diesel Generator Bi-Hourly Readings

Time Of Reading	Oil Pressure	Gen. Voltage	Engine RPM	Coolant Temp.	Fuel Level	Hour Meter	Oil Temp	Gen. KWH	Bar
0000	&1/	11.13	1000	77	357	11.1	15	22.1	27.1
0100	<t<	11.11	1000	78	357	11.14	7	27.0	27.0
0200	(&.)	11.11	1000	78	357	11.14	7	27.0	27.0
0300	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
0400	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
0500	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
0600	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
0700	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
0800	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
0900	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
1000	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
1100	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
1200	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
1300	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
1400	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
1500	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
1600	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
1700	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
1800	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
1900	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
2000	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
2100	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
2200	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
2300	t. I	11.11	1000	78	357	11.14	7	27.0	27.0
2400	t. I	11.11	1000	78	357	11.14	7	27.0	27.0

Comments: oct33 Be, ll-(, 11 Sv_w 1-e.S:11/a}- Ielfi: ; ...: kt J_w t' :5

Get it ct' " k. i r a, cl' enol- :1

Emergency Diesel Generator Weekly Test Log

Plant: Avila
 Date: 22, vel. 17
 Operator: ... (olJi1. &dl:r)OV\

Engine		Comments
Oil level	<u>ok</u>	
Start Time	<u>6:57</u>	
Starting Hour Meter Reading	<u>2320</u>	
Oil Pressure	<u>61</u>	
Battery Condition	<u>ok</u>	
Battery Voltage	<u>27.3</u>	
Engine RPM	<u>1800</u>	
Generator Volts	<u>111 kV</u>	
Coolant temperature	<u>71 °C</u>	
Oil temperature	<u>76 °F</u>	
Fuel level%	<u>68</u>	
Stop time	<u>2:335</u>	
End of hour meter reading	<u>2327</u>	
Total run time	<u>15 min. 5</u>	
Generator (when testing with load)		
Breaker close		
Generator Volts		
Breaker open		
Generator kW		
Reason For Use		
Testing:	<u>✓</u>	
Emergency:		
Maintenance:		
Confirm master control turned back in auto <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

Diesel Generator Weekly Test Log

Plant: Beta

Date:

11/17

Operator: [Signature]

Main Generator Breaker		Comments
Open	<input checked="" type="checkbox"/>	
Closed	<input type="checkbox"/>	
Engine		Comments
Start Time:	10:00 AM	
Stop Time:	10:10 AM	
Total Run Time:	10 MIN	
Starting Hour Meter Reading	478	
Ending Hour Meter Reading	488	
Oil Level	Full	
Coolant Level	Full	Coolant Temp. @ Start 5 °C Finish= 10 °C
Belt Condition	Good	
Oil Pressure	Normal	Start = 5.5 bar Finish= 1.5 bar
Battery Condition	Full	
Battery Voltage	24.2	
Engine RPMs	1700	
Generator		Comments
Generator Volts	240	
Generator Amps	11	
Generator "KVA"	2.64	
Reason For Use		Comments
Testing	<input checked="" type="checkbox"/>	
Emergency	<input type="checkbox"/>	
Maintenance	<input type="checkbox"/>	
Generator		Comments
Fuel Delivered		
Fuel Level	1/4	
Sulfur Concentrations	<0.0015% (15ppm)	

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the "Outage no longer imminent or in effect."

Emergency Diesel Generator Weekly Test Log

ALPHA *ii* BETA: 0

Date: *'0\', ; 11*

Operator: *rf1 lt u i l'or]*

Engine	Comments
Oil Level	<i>./</i>
Start Time	<i>11 X</i>
Starting Hour Meter reading	<i>(1-1</i>
Oil Pressure	<i>C.7</i>
Battery Condition	<i>./</i>
Battery Voltage	<i>11'4</i>
Engine RPM	<i>J'cJX</i>
Generator Volts	<i>4.1q</i>
Coolant Temperature	<i>7(p</i>
Oil Ptemperature	<i>150"</i>
Fuel Level%	
Stop Time	<i>);.45</i>
Ending Hour Meter Reading	<i>G.1q</i>
Total Run Time	<i>J6m.-h</i>
Generator (When Testing With Load)	
Breaker Close	<i>/</i>
Generator Volts	
Breaker Ooen	
Generator *KW*	
Reason For Use	
Testing:	<i>./</i>
Emergency:	
Maintenance:	
Confirm Master Control Turned Back on Auto:	Yes <i>ef</i> No D
<p>This emegency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power in not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage is no longer imminent or in effect.</p>	

ABENGOA SOLAR

(ilojc,.ve Sofar LLC

Emergency Diesel Generator Weekly Test Log

Plant: 4h
 Date: 4/21/17
 Operator: [Signature]

Enaine		Comments
Oil level	<u>not JAJ</u>	
Start Time	<u>1:27</u>	
Starting Hour Meter Reading	<u>57, C</u>	
Oil Pressure	<u>[Signature]</u>	
Battery Condition	<u>[Signature]</u>	
Battery Voltage	<u>[Signature]</u>	
Enaine RPM	<u>f'KfJP</u>	
Generator Volts	<u>11:17, W</u>	
Coolant temperature	<u>7</u>	
Oil temperature	<u>7/Er</u>	
Fuel level%	<u>0</u>	
Stoo time	<u>1m</u>	
Ending hour meter reading	<u>7, 7</u>	
Total run time	<u>1/1A/1, C</u>	
Generator (when testing with load)		
Breaker close		
Generator Volts		
Breaker ooen		
Generator "KW"		
Reason For Use		
Testing:	<u>V</u>	
Emerqencv:		
Maintenance:		
Confirm master control turned back in auto: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

Diesel Generator Weekly Test Log

Plant: Beta

Date:

7, / - / 7

Operator: m ; A 1-11-0

Main Generator Breaker		Comments
Open	/	
Closed		
Engine		Comments
Start Time:	1:00	
Stop Time:		
Total Run Time:	15 min	
Starting Hour Meter Reading	1100	
Ending Hour Meter Reading		
Oil Level	/	
Coolant Level	/	Coolant Temp. @ Start 10 *c Finish=7'/* c
Belt Condition	/	
Oil Pressure	1.0	Start= 1.0 bar Finish=0.8 , bar
Battery Condition	/	
Battery Voltage	12.8	
Engine RPMs	1500	
Generator		Comments
Generator Volts	480	
Generator Amps		
Generator "KVA"		
Reason For Use		Comments
Testing	/	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level 1/4 1/2 3/4 F	1/6	
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

ABENGOA SOLAR

(11)lojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Alr \
 Date: 7 - 1 - 1
 Operator: [fl-c-.1 ()

Engine		Comments
Oil level	<i>(?CIC" q</i>	
Start Time	<i>2... '10</i>	
Startina Hour Meter Readina	<i>&7VI-}</i>	
Oil Pressure	<i>l, 7 b r</i>	
Battery Condition	<i>GU, J</i>	
Battery Voltaae	<i>J <,,"</i>	
Enaine RPM	<i>(g °</i>	
Generator Volts	<i>LL17</i>	
Coolant temperature	<i><CQ...</i>	
Oil temperature	<i>7Sc.</i>	
Fuel level%	<i>If</i>	
Stop time	<i>'J&So</i>	
Endina hour meter readina	<i>(75</i>	
Total run time	<i>lom;''</i>	
Generator (when testinQ with load)		
Breaker dose		
Generator Volts		
Breaker open		
Generator •KW"		
Reason For Use		
Testina:	V	
Emeraency;		
Maintenance:		
Confirm master control turned back in auto: <input checked="" type="checkbox"/> No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

ABENGOA SOLAR

ojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: A

Date: 2/1/

Operator: 0,11:il" -Ob t5ob

Engine		Comments
Oil level	<i>ok</i>	
Start Time	<i>7:10</i>	
Starting Hour Meter Reading	<i>6,9</i>	
Oil Pressure	<i>G, R"</i>	
Battery Condition	<i>ok</i>	
Battery Voltage	<i>24.1</i>	
Engine RPM	<i>1500</i>	
Generator Volts	<i>141 id.I</i>	
Coolant temperature	<i>71 "F</i>	
Oil temperature	<i>175 "C</i>	
Fuel level%	<i>S</i>	
Stop time	<i>7:20</i>	
Ending hour meter reading	<i>67-J</i>	
Total run time	<i>10 min</i>	
Generator (when testing with load)		
Breaker close		
Generator Volts		
Breaker open		
Generator "KW"		
Reason For Use		
Testing:	<i>ok</i>	
Emergency:		
Maintenance:		
Confirm master control turned back in auto: <i>ff(y</i> No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

ABENGOA SOLAR

Objective Solar LLC

Emergency Diesel Generator Weekly Test Log

JIS, Z.II

Plant: Be-1
 Date: 6-11-11
 Operator: ire:/eol:r/

Engine		Comments
Oil level	<i>Oil</i>	
Start Time	<i>20:11</i>	
Startina Hour Meter Reading	<i>115</i>	
Oil Pressure	<i>8.7</i>	
Battery Condition		
Battery Voltage	<i>26.9</i>	
Enaine RPM	<i>1511</i>	
Generator Volts	<i>230V</i>	
Coolant temperature	<i>75</i>	
Oil temperature	<i>75</i>	
Fuel level%	<i>76</i>	
Stop time	<i>7:00</i>	
Endina hour meter readina	<i>117.1</i>	
Total run time	<i>JSM</i>	
Generator (when testing with load)		
Breaker close		
Generator Volts		
Breaker open		
Generator •KW•		
Reason For Use		
Testing:	<i>wed, Nfc5i</i>	
Emergency:		
Maintenance:		
Confirm master control turned back in auto: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

Diesel Generator Weekly Test Log

Plant: Beta

Date: 06 - 10 - 11

Operator: S J...v,e(

Main Generator Breaker		Comments
Open	<input checked="" type="checkbox"/>	
Closed	<input type="checkbox"/>	
Engine		Comments
Start Time:	11:03	
Stop Time:	11:18	
Total Run Time:		
Starting Hour Meter Reading	115	
Ending Hour Meter Reading	115	
Oil Level	OK	
Coolant Level	OK	Coolant Temp. @ Start 57 °C Finish= °C
Belt Condition	Good	
Oil Pressure		Start= 9.3 bar Finish= 7.0 bar
Battery Condition	OK	
Battery Voltage	7.2	
Engine RPMs	1500	
Generator		Comments
Generator Volts		
Generator Amps		
Generator "KVA"		
Reason For Use		Comments
Testing	<input checked="" type="checkbox"/>	
Emergency	<input type="checkbox"/>	
Maintenance	<input type="checkbox"/>	
Generator		Comments
Fuel Delivered		rvn
Fuel Level 1/4 1/2 3/4 F	72 %	
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Emergency Diesel Generator Weekly Test Log

ALPHA 0 BETA:

Date: h-'-'S-1 t

Operator: L-

Engine	Comments
Oil Level	V
Start Time	030z.
Starting Hour Meter reading	115. (,
Oil Pressure	G.-,
Battery Condition	(100C
Battery Voltage	'-b•)
Engine RPM	1560
Generator Volts	4.7"
Coolant Temperature	/
Oil Ptemperature	,S-'
Fuel Level%	.
Stop Time	0'3j 2.
Ending Hour Meter Reading	/ 15. 'if
Total Run Time	10. ...
Generator (When Testing With Load)	
Breaker Close	
Generator Volts	
Breaker Open	
Generator *KW*	
Reason for Use	
Testing:	'i
Emergency:	
Maintenance:	
Confirm Master Control Turned Back on Auto:	Yes No D
<p>This emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage is no longer imminent or in effect.</p>	

Emergency Diesel Generator Weekly Test Log

ALPHA BETA: D

Date: C,-3-17

Operator: m: lt, Hin

Engine	Comments
Oil Level	/
Start Time	:J/15
Starting Hour Meter reading	U.:
Oil Pressure	:J
Battery Condition	./
Battery Voltage	x.e
Engine RPM	i
Generator Volts	%.lb
Coolant Temperature	1,
Oil Ptemperature	7b
Fuel Level%	t/
Stop Time	:).130
Ending Hour Meter Reading	C. 7
Total Run Time	15.:.1.c
Generator (When Testing With Load)	
Breaker Close	:vA\
Generator Volts	/
Breaker Oopen	
Generator *KW*	
Reason For Use	
Testing:), (
Emergency:	
Maintenance:	
Confirm Master Control Turned Back on Auto: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> D	
<p>This emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power in not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the <i>engine</i> is operated no <i>more</i> than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage is no longer imminent or in effect.</p>	

Diesel Generator Weekly Test Log

Plant: Beta

Date: 8/28/17

Operator: K, a4

Main Generator Breaker		Comments
Open	✓	
Closed		
Engine		Comments
Start Time:	7:19	
Stop Time:	7:32	
Total Run Time:	10M4V76	
Starting Hour Meter Reading	115. +	
Ending Hour Meter Reading	125. k7	
Oil Level	N	
Coolant Level	N	Coolant Temp. @ Start °c Finish=7 °c
Belt Condition	t: vW	
Oil Pressure		Start = 7.7 bar Finish 7 bar
Battery Condition	(v f) t < 1	
Battery Voltage	2. -	
Engine RPMs	1700	
Generator		Comments
Generator Volts		
Generator Amps		
Generator "KVA"		
Reason For Use		Comments
Testing	V	
Emergency	10MAM	
Maintenance	t: 7T	
Generator		Comments
Fuel Delivered		
Fuel Level	1/4 1/2 3/4 F	
Sulfur Concentrations		
<0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

ABENGOA SOLAR

(f o j a v e Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: AIPA\
 Date: .- ? - 17
 Operator: €€'d)

Enaine		Comments
Oil level	<u>&ool.-</u>	
Start Time	<u>2.3 1 (6p</u>	
Startina Hour Meter Reading	<u>''' (6,;;</u>	
Oil Pressure	<u>6.7 P'r</u>	
Batterv Condition	<u>G'' p</u>	
Batterv Voltage	<u>J 7.0 V</u>	
Enaine RPM	<u>1 51'' on PPM</u>	
Generator Volts	<u>4.1 'v: <0.47</u>	
Coolant temperature	<u>X. 'e</u>	
Oil temperature	<u>t 5'e</u>	
Fuel level%	<u>4 n..</u>	
Stop time	<u>11'le</u>	
Ending hour meter reading	<u><, 7'''</u>	
Total run time	<u>0N:7</u>	
Generator (when testing with load)		
Breaker close		
Generator Volts		
Breaker ooen		
Generator ·KW"		
Reason For Use		
Testina:		
Emeraency:		
Maintenance:		
Confirm master control turned back in auto: <input checked="" type="checkbox"/> No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

Diesel Generator Weekly Test Log

Plant: Beta Date: 7/11

Operator: A. &

Main Generator Breaker		Comments
Open	<input checked="" type="checkbox"/>	
Closed	<input type="checkbox"/>	
Engine		Comments
Start Time:	-Z100	
Stop Time:	11:15	
Total Run Time:	1 D	n {1, JU1BS
Starting Hour Meter Reading	115, "?	
Ending Hour Meter Reading	115, "f	Ouvr f(J;o , C,JL; A) 0 T \ ft 1f:," •
Oil Level	qJ	
Coolant Level	"1	Coolant Temp. @ Start 51 *c Finish=i *c
Belt Condition	6000	
Oil Pressure		Start=Z "7 bar Finish=h, 7 bar
Battery Condition	(. 000	
Battery Voltage	21, 'f	
Engine RPMs	1900	
Generator		Comments
Generator Volts	4, J	
Generator Amps		
Generator "KVA"	e Cf.9	
Reason For Use		Comments
Testing	(...-"	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level	1/4 1/2 3/4 F	
Sulfur Concentrations	<0.0015% (15ppm)	

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

ABENGOA SOLAR

uojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: III eBA
 Date: 5-17
 Operator: B. i.

En<line		Comments
Oil level	riJ	
Start Time	fJL.P/1	
Startina Hour Meter Reading	r. &.)h	
Oil Pressure	i. 7 fJ"...	
Battery Condition	rL	
Battery Voltage	e. f. q	
Enaine RPM	. . P.P/1\	
Generator Volts	!J	
Coolant temperature	75(?c-	
Oil temperature	?3C-	
Fuel level%	?i-1%	
Stop time	e, "(J	
Endina hour meter readina	(io.5 h	
Total run time	/-, Nlir\	
Generator (when testing with load)		
Breaker dose		
Generator Volts		
Breaker ooen		
Generator "KW"		
Reason For Use		
Testina:	. /	
Emeraency:		
Maintenance:		
Confirm master control turned back in auto: {?eD No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

Q

0

ABENGOA SOA R

Emergency Diesel Generator Weekly Test Log

Plant: t)crA

Date: S -1 -1

Operator: 2.0'--

Engine		Comments
Oil level	D	
Start Time	03:11	
Starting Hour Meter Reading	ti	
Oil Pressure	C? 24a	
Battery Condition	(...)	
Battery Voltage	2.4 - 2.4	
Engine RPM	1500	
Generator Volts	415	
Coolant temperature	51	
Oil temperature	41	
Fuel level%	100	
Stop time	03:15	
Ending hour meter reading	03:15	
Total run time	04:00	
Generator (when tested with load)		
Breaker dose		
Generator Volts		
Breaker open		
Generator kW		
Reason For Use		
Testing:	1.1.1	
Emergency:		
Maintenance:		
Confirm master control turned back in auto: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

Emergency Diesel Generator Weekly Test Log

ALPHA

BETA: D

Date: 5.e.1 Z 1 7

Operator: Of 7C: _____

Engine	Comments
Oil Level	(...)
Start Time	7-7:2
Starting Hour Meter reading	C ro.1
Oil Pressure	7.7
Battery Condition	C
Battery Voltage	0?1
Engine RPM	KM
Generator Volts	A
Coolant Temperature	
Oil Ptemperature	7(7)
Fuel Level%	5/4
Stop Time	:r '3?
Ending Hour Meter Reading	00'1!
Total Run Time	10''''
Generator (When Testina With Load)	
Breaker Close	
Generator Volts	
Breaker Open	
Generator *KW*	
Reason For Use	
Testing:	<input checked="" type="checkbox"/>
Emergency:	
Maintenance:	
Confirm Master Control Turned Back on Auto:	Yes <u>at</u> No <u>D</u>
This emegency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power in not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no hmit on engine operation for Emergency use.	
This engine may operate in respoonse to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage is no longer imminent or in effect.	

ABENGOA SOLAR

Emergency Diesel Generator Weekly Test Log

Plant: 4LR-1A
 Date: S 42-'1
 Operator: Pr-\, '--

Engine		Comments
Oil level	G&C	
Start Time	2:30	
Starting Hour Meter Reading		
Oil Pressure	C	
Battery Condition		
Battery Voltage	2.7	
Engine RPM	1500	
Generator Volts	4.14 kv	
Coolant temperature	15'	
Oil temoerature	42-14	
Fuel level%	5%	
Stop time	2:50	
Ending hour meter reading	CL-1	
Total run time	10 : \ , " , J "	
Generator (when testing with load)		
Breaker close		
Generator Volts		
Breaker open		
Generator •KW"		
Reason For Use		
Testino:	Wff<t."I	
Emergency:		
Maintenance:		
Confirm master control turned back in auto: <input type="checkbox"/> No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no loner imminent or in effect.</p>		

ABENGOA SOLAR

Gojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: tzeh
 Date: 11/11/15
 Operator: JP

Engine		Comments
Oil level	High	
Start Time	11:51	
Starting Hour Meter Reading	1111	
Oil Pressure	70	
Battery Condition	Good	
Battery Voltage	12.8	
Engine RPM	1500	
Generator Volts	120	
Coolant temperature	100	
Oil temperature	100	
Fuel level%	75	
Stop time	12:05	
End of hour meter reading	1115	
Total run time	4	
Generator (when testing with load)		
Breaker dose		
Generator Volts		
Breaker open		
Generator kW		
Reason For Use		
Testino:	<input checked="" type="checkbox"/>	
Emergency:	<input type="checkbox"/>	
Maintenance:	<input type="checkbox"/>	
Confirm master control turned back in auto: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

0

Q

Diesel Generator Weekly Test Log

Plant: Beta

Date: 11/11/11

Operator: S V

Main Generator Breaker		Comments
Open	✓	
Closed		
Engine		Comments
Start Time:	08:00	
Stop Time:	13:00	
Total Run Time:	5 M.h.	
Starting Hour Meter Reading	118	
Ending Hour Meter Reading		
Oil Level	OK	
Coolant Level	OK	Coolant Temp. @ Start 115 °C Finish=73 °C
Belt Condition	OK	
Oil Pressure		Start = 1.0 bar Finish= 7.0 bar
Battery Condition	OK	
Battery Voltage	24.6	
Engine RPMs	1500	
Generator		Comments
Generator Volts		
Generator Amps		
Generator "KVA"		
Reason For Use		Comments
Testing	✓	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	1.2	
Fuel Level	1/4 1/2 3/4 F	7 g/hr
Sulfur Concentrations		
<0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

ABENGOA SOLAR

Emergency Diesel Generator Weekly Test Log

Plant: Al
 Date: 8/11/11
 Operator: H. n. e. t.

Enaine		Comments
Oil level	.	
Start Time	11	
Starting Hour Meter Reading	6.e	
Oil Pressure	1.1	
Battery Condition	/	
Battery Voltage	11.	
Engine RPM	1	
Generator Volts	110 Kv	
Coolant temperature	10	
Oil temperature	15	
Fuel level%	100	
Stop time	?	
Ending hour meter reading	11	
Total run time	1? n\LM	
Generator (when testing with load)		
Breaker close	tv/A	
Generator Volts		
Breaker open		
Generator •KW"	v	
Reason For Use		
Testing:	.	
Emergency:		
Maintenance:		
Confirm master control turned back in auto: No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

ABENGOA SOLAR

Emergency Diesel Generator Weekly Test Log

Plant: A
 Date: 12/11
 Operator: Tom Anje, SQa

Engine		Comments
Oil level	✓✓✓✓✓	
Start Time	11:00	
Start/Stop Hour Meter Reading	1234	
Oil Pressure	(100) 64.5	
Battery Condition	Good	
Battery Voltage	12.8V	
Engine RPM	1500	
Generator Volts	415V	
Coolant temperature	71°C	
Oil temperature	71°C	
Fuel level%	50%	
Stop time	1:00 PM	
End/Start hour meter reading	1234	
Total run time	1:00 PM	
Generator (when tested with load)		
Breaker close		
Generator Volts		
Breaker open		
Generator kW		
Reason For Use		
Test:	✓	
Emergency:		
Maintenance:		
Confirm master control turned back in auto: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage is no longer imminent or in effect.</p>		

Diesel Generator Weekly Test Log

Plant: Beta

Date:

11/11/11

Operator: [Signature]

Main Generator Breaker		Comments
Open		
Closed		
Engine		Comments
Start Time:	1:00 PM	
Stop Time:	1:20	
Total Run Time:	15 MIN	
Starting Hour Meter Reading	111.1	
Ending Hour Meter Reading	111.1	
Oil Level	✓	
Coolant Level	✓	Coolant Temp. @ Start 111 °C Finish=111 °C
Belt Condition	✓	
Oil Pressure	✓	Start = 111 bar Finish=111 bar
Battery Condition	✓	
Battery Voltage	111.1V	
Generator		Comments
Generator Volts	111.1V	
Generator Amps	35d	
Generator "KVA"	11.1	
Reason For Use		Comments
Testing	✓	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level	1/4 1/2 3/4 F	
Sulfur Concentrations		
<0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

Emergency Diesel Generator Weekly Test Log

ALPHA BETA: D

Date: 11/15/11

Operator: N/Alej;ofov,

Engine	Comments
Oil Level	/
Start Time	11:15
Starting Hour Meter reading	<15.1
Oil Pressure	11.7b-r
Battery Condition	. /
Battery Voltage	27.5
Engine RPM	1800
Generator Volts	11.1
Coolant Temperature	7e.c
Oil Ptemperature	15 (
Fuel Level%	50%
Stop Time	11:01
Ending Hour Meter Reading	6:58
Total Run Time	15m, 1
Generator (When Testing With Load)	
Breaker Close	11:01
Generator Volts	11.1
Breaker Ooen	11:01
Generator *KW*	11.1
Reason For Use	
Testing:	. /
Emergency:	
Maintenance:	
Confirm Master Control Turned Back on Auto: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
<p>This emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power in not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in respoonse to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular tfme the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage is no longer imminent or in effect.</p>	

Diesel Generator Weekly Test Log

Plant: Beta

Date:

4/11/11

Operator:

Main Generator Breaker		Comments
Open		
Closed		
Engine		Comments
Start Time:	11:00	
Stop Time:	11:00	
Total Run Time:	10 Min	
Starting Hour Meter Reading	11.5	
Ending Hour Meter Reading	14.1	
Oil Level	/	
Coolant Level	/	Coolant Temp. @ Start 5 *c Finish=11.1*c
Belt Condition	/	
Oil Pressure	/	Start = 1.1 bar Finish=1.0 bar
Battery Condition	/	
Battery Voltage	10.0	
Engine RPMs	1500	
Generator		Comments
Generator Volts	240	
Generator Amps	361	
Generator "KVA"	11.0	
Reason For Use		Comments
Testing	/	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level <input type="checkbox"/> 1/4 <input type="checkbox"/> 1/2 <input type="checkbox"/> 3/4 <input type="checkbox"/> F	1/2	
Sulfur Concentrations <0.0015% (Sppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

ABENGOA SOLAR

Emergency Diesel Generator Weekly Test Log

Plant: f>-rA
 Date: Lt; :- "\ - I1
 Operator: \5'1 r L -

Enaine		Comments
Oil level	(: ?rr--D	
Start Time	I-Z.	
Startina Hour Meter Reading	Lli.j-•'+	
Oil Pressure	0640	
Battery Condition	Good:>	
Battery VoltaQe	2G	
Enaine RPM	I c.o	
Generator Volts	t. o/b k v	
Coolant temperature	5'8 7b	
Oil temperature	117 -,,S-	
Fuel level%	75%	
Stop time	?-1-45	
Ending hour meter reading	11'+, -S-	
Total run time	I O M I') ; ; ; ;	
Generator (when testing with load)		
Breaker close		
Generator Volts		
Breaker open		
Generator •KW•		
Reason For Use		
Testing:	r., CcW,,-' /	
Emergency:		
Maintenance:		
Confirm master control turned back in auto: (Ye?) No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

ABENGOA SOLAR

Emergency Diesel Generator Weekly Test Log

Plant: Alr''
 Date: 11/21/17
 Operator: Co11 A bk: rSo''

Engine		Comments
Oil level	<i>4.10</i>	<i>C. e. Cor, !, t(v' (or. *''...''''T'' i,</i>
Start Time	<i>11</i>	<i>e > v-o-l.v. t... (\ t " I (e l</i>
Starting Hour Meter Reading	<i>[?]- 1</i>	
Oil Pressure	<i>(:</i>	
Battery Condition	<i>r''irl</i>	
Battery Voltage	<i>)} !:</i>	
Engine RPM	<i>IKor-</i>	
Generator Volts	<i>J. It fell</i>	
Coolant temperature	<i>75 °C</i>	
Oil temperature	<i>-;:S C...</i>	
Fuel level%	<i>S</i>	
Stop time	<i>20 'Ll-</i>	
Ending hour meter reading	<i>be; L</i>	
Total run time	<i>15 N, nttt.C:</i>	
Generator (when testing with load)		
Breaker close		
Generator Volts		
Breaker open		
Generator kW		
Reason For Use		
Testing:	<i>V</i>	
Emergency:		
Maintenance:		
Confirm master control turned back in auto: <i>fei</i> No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

ABENGOA SOLAR

Emergency Diesel Generator Weekly Test Log

Plant: ALPHA
 Date: tr
 Operator: H

Engine		Comments
Oil level	0	
Start Time	ao: 2	
Startina Hour Meter Readina	64	
Oil Pressure	0cf	
Battery Condition	bGOD	
Batterv Voltaa	11.0 21.r	
Engine RPM	t"te>0	
Generator Volts	4 . \ 4	
Coolant temperature	75	
Oil temperature	4f 7<-	
Fuel level%	7 % 16k	
Stop time	0 1:-o s	
Endina hour meter reading	r::4- /1	
Total run time	}(, tiV	
Generator (when testing with load)		
Breaker close		
Generator Volts		
Breaker oen		
Generator ·KW·		
Reason For Use		
Testinq:	lvau,	
Emeroency:		
Maintenance:		
Confirm master control turned back in auto: (Yey No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outaae no tonger imminent or in effect.</p>		

ABENGOA SOLAR

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Beta
 Date: 4-1-17
 Operator: Oye

Enaine		Comments
Oil level	(1.5-1.7)	
Start Time	11:45	
Startino Hour Meter Reading	114.5	
Oil Pressure	9.5	
Battery Condition	7.7	
Battery Voltaae	24.2	
Enoine RPM	1500	
Generator Volts	240	
Coolant temperature	7.5	
Oil temoerature	7.5	
Fuel level%	75	
Stop time	11:55	
Endino hour meter reading	115.5	
Total run time	10 min	
Generator (when testina with load)		
Breaker close		
Generator Volts		
Breaker open		
Generator •KW"		
Reason For Use		
Testina:	v	
Emeraencv:		
Maintenance:	/	
Confirm master control turned back in auto: VYes No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

ABENGOA SOLAR

Emergency Diesel Generator Weekly Test Log

Plant: Alpa
 Date: 3-25-11
 Operator: G. V. 1

Engine		Comments
Oil level	<i>OK</i>	
Start Time	<i>1341</i>	
Starting Hour Meter Reading	<i>141</i>	
Oil Pressure	<i>7.1 13r</i>	
Battery Condition	<i>OK</i>	
Battery Voltage	<i>24.0</i>	
Engine RPM	<i>1800</i>	
Generator Volts	<i>(11.1, 11.1)</i>	
Coolant temperature	<i>70°C</i>	
Oil temperature	<i>70°C</i>	
Fuel level%	<i>75%</i>	
Stop time	<i>SI</i>	
Ending hour meter reading	<i>4</i>	
Total run time	<i>10 Min</i>	
Generator (when testing with load)		
Breaker close		
Generator Volts		
Breaker open		
Generator "KW"		
Reason For Use		
Testing:		
Emergency:		
Maintenance:		
Confirm master control turned back in auto: (Yes) No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

ABENGOA SOLAR

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: 2Je-4A

Site: Holt

Engine	Comments
Oil level	./
Start Time	1115
Starting Hour Meter Reading	114.1
Oil Pressure	1.7 bar
Battery Condition	./
Battery Voltage	17.1
Engine RPM	1120
Generator Volts	117
Coolant temperature	110°C
Oil temperature	71°C
Fuel level%	5%
Stop time	1110
Ending hour meter reading	114.1
Total run time	1a
Generator (when tested with load)	
Breaker close	
Generator Volts	
Breaker open	
Generator kW	
Reason For Use	
Test:	✓
Emergency:	
Maintenance:	
Confirm master control turned back in auto:	<input checked="" type="checkbox"/> No
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>	

ABENGOA SOLAR

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: ~~t-i~~

Date: ~~11/11/11~~

Operator: ~~B~~

Engine		Comments
Oil level	N	
Start Time	00:	
Startina Hour Meter Reading	11 ;"	
Oil Pressure	2	
Battery Condition	6a OD	
Battery Voltaae	2.1, 1	
Enaine RPM	00	
Generator Volts	4-J	
Coolant temperature	16	
Oil temperature	70 v	
Fuel level%	1-	
Stoo time	01:c	
Endina hour meter readina	14- 1	
Total run time	10 1111,J	
Generator (when testing with load)		
Breaker close		
Generator Volts		
Breaker ooen		
Generator ·KW·		
Reason For Use		
Testing:	<input checked="" type="checkbox"/>	
Emeroencv:		
Maintenance:		
Confirm master control turned back in auto: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
<p>This Emergency Generator shall be limited to uor emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediatelv after the utility advises that the outaoe no longer imminent or in effect.</p>		

-ABENGOA SOLAR

Emergency Diesel Generator Weekly Test Log

Plant: A/Ph"-

Date: 3 - / - 1)

Operator: Eb:»:" fillo1.1)

Enaine		Comments
Oil level	(; t £	
Start Time	J/110	
Starting Hour Meter Readina	L If. 4h	
Oil Pressure	fl. Sr114	
Batterv Condition	(. 0 L	
Batterv Voltaae	2.75	
Enaine RPM	1800	
Generator Volts	L/1Y	
Coolant temperature	7ve-	
Oil temoerature	7 S-G	
Fuel level%)Y	
Stoo time	?-llo	
Endina hour meter readina	4.f.l	
Total run time	(1)1.1.1	
Generator (when testina with load)		
Breaker close		
Generator Volts		
Breaker ooen		
Generator ·KW·		
Reason For Use		
Testina:	X	
Emeroency:		
Maintenance:		
Confirm master control turned back in auto:	No	
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

ABENGOA SOLAR

Emergency Diesel Generator Weekly Test Log

Plant: _____
 Date: _____
 Operator: /1,1/i,a
 -/

Engine		Comments
Oil level	r-r	
Start Time	(X./ft.)	
Starting Hour Meter Reading	/, / J. -?	
Oil Pressure	1.7 - 1.8	
Battery Condition	C, Y, -	
Battery Voltage	24	
Engine RPM	1800	
Generator Volts	480	
Coolant temperature	(180 F)	
Oil temperature	180 F	
Fuel level%	75	
Stoo time	r / cr	
Ending hour meter reading	fn L / A	
Total run time	-r / 11 / 1	
Generator (when testing with load)		
Breaker close		
Generator Volts	480	
Breaker open		
Generator kW		
Reason For Use		
Testing:	/	
Emergency:		
Maintenance:		
Confirm master control turned back in auto: (Yes) No		
<p>This Emergency Generator shall be limited to emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outages no longer imminent or in effect.</p>		

Diesel Generator Weekly Test Log

Unit: Beta

Date: 01/20/11

Operator: *it-vk*

Main Generator Breaker		Comments
Open	<i>X</i>	
Closed		
Engine		Comments
Start Time:	<i>11:10</i>	
Stop Time:	<i>12:55</i>	
Total Run Time:	<i>5:45</i>	
Starting Hour Meter Reading	<i>113</i>	
Ending Hour Meter Reading	<i>118</i>	
Oil Level	<i>O&</i>	
Coolant Level	<i>100%</i>	Coolant Temp. @ Start <i>111</i> *c Finish= 11 *c
Belt Condition	<i>OK</i>	
Oil Pressure		Start= 7.0 bar Finish= 7.0 bar
Battery Condition		
Battery Voltage	<i>12.8</i>	
Engine RPMs	<i>1800</i>	
Generator		Comments
Generator Volts		
Generator Amps		
Generator "KVA"		
Reason For Use		Comments
Testing	<i>V</i>	
Emergency		<i>100% (17.4, f,)</i>
Maintenance		
Generator		Comments
Fuel Delivered	<i>1.7 D</i>	
Fuel Level 1/4 1/2 3/4 F	<i>1 1/2</i>	
Sulfur Concentrations <0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

ABENGOA SOLAR

Emergency Diesel Generator Weekly Test Log

Plant: W/
 Date: 02/21/20
 Operator: (#11, Aica)

Engine		Comments
Oil level	<u>OK</u>	<u>OK</u>
Start Time	<u>10:00</u>	<u>OK</u>
Starting Hour Meter Reading	<u>8.1</u>	
Oil Pressure	<u>1.10</u>	
Battery Condition	<u>Good</u>	
Battery Voltage	<u>27.6</u>	
Engine RPM	<u>1500</u>	
Generator Volts	<u>1.11 kV</u>	
Coolant temperature	<u>78°C</u>	
Oil temperature	<u>7.1</u>	
Fuel level%	<u>76%</u>	
Stop time	<u>10:15</u>	
Ending hour meter reading	<u>8.15</u>	
Total run time	<u>15 minutes</u>	
Generator (when testing with load)		
Breaker close		
Generator Volts		
Breaker open		
Generator •KW•		
Reason For Use		
Testing:	<u>J</u>	
Emergency:		
Maintenance:		
Confirm master control turned back in auto: <u>/res ;</u> } No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

Diesel Generator Weekly Test Log

Plant: Beta

Date:

11/1/11

Operator: R.C.

Main Generator Breaker		Comments
Open	/	
Closed		
Engine		Comments
Start Time:	5:00 AM	
Stop Time:	6:00 AM	
Total Run Time:	1 DM	
Starting Hour Meter Reading	11.1 h	
Ending Hour Meter Reading	13.1 h	
Oil Level	Full	
Coolant Level	Full	Coolant Temp. @ Start 55 °C Finish= 55 °C
Belt Condition	Good	
Oil Pressure	Start = 1.5 bar Finish= 1.1 bar	
Battery Condition	Good	
Battery Voltage	10.1	
Engine RPMs	1100	
Generator		Comments
Generator Volts	110	
Generator Amps	10	
Generator "KVA"	1.1	
Reason For Use		Comments
Testing	/	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level	1/4 (31) F	1.1 tk
Sulfur Concentrations	<0.0015% (15ppm)	

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

ABENGOA SOLAR

Emergency Diesel Generator Weekly Test Log

Plant: _____

Date: - -

Operator: ; ;

Enaine		Comments
Oil level	ffH,od	
Start Time	DL,1D	
Starting Hour Meter Reading	(. "1, .	
Oil Pressure	7.1 ,r	
Battery Condition	&a,1	
Battery Voltage	1), . Co	
Engine RPM	10,00	
Generator Volts	11.,1, \V	
Coolant temperature	(. f, . (
Oil temperature	(. L, Jy	
Fuel level%	- j, . .	
Stop time	rV, . -V, . .	
Ending hour meter reading	(. . 2i	
Total run time	It) M	
Generator (when testing with load)		
Breaker close		
Generator Volts		
Breaker open		
Generator kW		
Reason for Use		
Testing:	/	
Emergency:		
Maintenance:		
Confirm master control turned back in auto: (Ye?) No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

Diesel Generator Weekly Test Log

Plant: Beta

Date: 2/13/16

Operator: *pt. - A*

Main Generator Breaker		Comments
Open		
Closed		
Engine		Comments
Start Time:		
Stop Time:	2:5	-> 1/1t
Total Run Time:	30 min	
Starting Hour Meter Reading	3.4	
Ending Hour Meter Reading	113.8	
Oil Level	OK	
Coolant Level	1J	Coolant Temp. @ Start 57 *c Finish=71;-*c
Belt Condition	Good	
Oil Pressure	10.7	Start= -0 bar Finish= 0.1 bar
Battery Condition	Good	
Battery Voltage	27	
Engine RPMs	1500	
Generator		Comments
Generator Volts	400	
Generator Amps		
Generator "KVA"		
Reason For Use		Comments
Testing		
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered		
Fuel Level	1/4 1/2 (3/4) F	
Sulfur Concentrations		
<0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

ABENGOA SOLAR

Emergency Diesel Generator Weekly Test Log

Plant: A/JrJ
 Date: 'c - II. -It
 Operator: Gf&,,, m,nJ,,,)

Engine		Comments
Oil level	o, L	
Start Time	?..It"S	
Startino Hour Meter Reading	3. 5h	
Oil Pressure	7. 013r	
Battery Condition	Conl	
Battery Voltage	V	
Engine RPM	ISroor: Pm	
Generator Volts	q. 17	
Coolant temperature	7 /e.	
Oil temperature	t'c.	
Fuel level%	76.7.	
Stop time	? 15	
EndinCl hour meter reading	<3. 1 "	
Total run time	I M: J	
Generator (when testing with load)		
Breaker close		
Generator Volts		
Breaker open		
Generator "KW"		
Reason For Use		
Testing:	X	
Emergency:		
Maintenance:		
Confirm master control turned back in auto: (Ye) No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outaae no longer imminent or in effect.</p>		

ABENGOA SOLAR

Emergency Diesel Generator Weekly Test Log

6. Al/1-z-/C,

Operator:.....

Engine		Comments
Oil level	<i>£ II</i>	
Start Time	<i>... < t.-</i>	
Starting Hour Meter Reading	<i>7.?' II-</i>	
Oil Pressure	<i>\ Vil P rz;</i>	
Battery Condition	<i>1-1</i>	
Battery Voltage	<i>J-1.4</i>	
Engine RPM	<i>1(7-;</i>	
Generator Volts		<i>L, 1-1-Pv illt.; + -W V I I' f. ... S, v, W \</i>
Coolant temperature	<i>L -AT,</i>	
Oil temperature	<i>f. 7' (</i>	
Fuel level%	<i>7 (</i>	
Stop time	<i>... 7D</i>	
Ending hour meter reading	<i>7.5</i>	
Total run time	<i>It J m I >> S</i>	
Generator (when testing with load)		
Breaker close		
Generator Volts		
Breaker open		
Generator "KW"		
Reason For Use		
Testing:	<i>V</i>	
Emergency:		
Maintenance:		
Confirm master control turned back in auto: <i>ires \ No</i>		
This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.		
This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.		

ABENGOA SOLAR

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: f3erA _____

Date: -fj - 11 _____

Operator: PH 1L-- _____

Enaine		Comments
Oil level	rrY)f	
Start Time	10:50	
Starting Hour Meter Reading	120	
Oil Pressure	-	
Battery Condition	Good	
Battery Voltage	26.1 -	
Enoine RPM	1100	
Generator Volts	11	
Coolant temperature	%L- 1,	
Oil temperature	40c- 7	
Fuel level%	15% <	
Stop time	11:00	
Ending hour meter reading	11:00	
Total run time	1 Mt	
Generator (when testina with load)		
Breaker close	/	
Generator Volts	/	
Breaker open	/	
Generator ·KW·	/	
Reason For Use		
Testina:	WML	
Emeraencv:		
Maintenance:		
Confirm master control turned back in auto: (Yes) No		
<p>This Emergency Generator shall be limited to us'eior emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

ABENGOA SOLAR

Emergency Diesel Generator Weekly Test Log

Operator: J. A. f?

Engine		Comments
Oil level	vt	
Start Time	f 1 lb	
Starting Hour Meter Reading	(/ - , r/	
Oil Pressure	...isTS	
Battery Condition	.../1.11/	
Battery Voltage	v li	
Engine RPM	A(Y)	
Generator Volts	n	
Coolant temperature	.-?	
Oil temperature	v C	
Fuel level%	- (
Stop time	fJ 7fJ	
End of hour meter reading	() .4	
Total run time	JJwii	
Generator (when testing with load)		
Breaker close		
Generator Volts		
Breaker open		
Generator "KW"		
Reason For Use		
Testina:	v	
Emergency:		
Maintenance:		
Confirm master control turned back in auto:	No	
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

ABENGOA SOLAR

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: A
 Date: t- & P - 10
 Operator: '01 IL-

Engine		Comments
Oil level	<i>Good</i>	
Start Time	<i>0 J 10</i>	
Startina Hour Meter Readina	<i>11:00</i>	
Oil Pressure	<i>h-11</i>	
Battery Condition	<i>(...)</i>	
Battery Voltage	<i>12.1 : 21.1...</i>	
Engine RPM	<i>1400</i>	
Generator Volts	<i>117</i>	
Coolant temperature	<i>53 11</i>	
Oil temperature	<i>131 71</i>	
Fuel level%	<i>1/2</i>	
Stop time	<i>11:15</i>	
Endina hour meter readina	<i>11:15</i>	
Total run time	<i>11 M, 1 U</i>	
Generator (when testina with load)		
Breaker close		
Generator Volts		
Breaker open		
Generator kW		
Reason For Use		
Testina:	<i>t. (t) - V... - (</i>	
Emergency:		
Maintenance:		
Confirm master control turned back in auto: (g.) No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.</p>		

ABENGOA SOLAR

Mojave Solar LLC

Emergency Diesel Generator Weekly Test Log

Plant: Benko

Date: 1-3-11

Operator: Sh-c/f

Engine		Comments
Oil level	OK	
Start Time	2:20 PM	
Startina Hour Meter Readina	117.9	
Oil Pressure	7.2	High 7.2 f,,,l)l.
Battery Condition	Good	
Battery Voltage	26.7	
Enaine RPM	100	
Generator Volts	115	
Coolant temperature	51.0 C	71.0 C
Oil temoerature	41.0 C	41.0 C
Fuel level%	9.16	
Stop time	2:10:00	
Endina hour meter reading	118.0	
Total run time	40	
Generator (when testing with load)		
Breaker close		
Generator Volts		
Breaker open		
Generator "KW"		
Reason For Use		
Testina:	X	
Emeraency:		
Maintenance:		
Confirm master control turned back in auto: CYes] No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use,</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outaae no lonaaer imminent or in effect.</p>		

Diesel Generator Weekly Test Log

Plant: Beta

Date: 7-11

Operator: L. S. I

Main Generator Breaker		Comments
Open		
Closed		
Engine		Comments
Start Time:	11:00	
Stop Time:	11:00	
Total Run Time:	0:00	
Starting Hour Meter Reading	134	
Ending Hour Meter Reading	134	
Oil Level	4J	
Coolant Level	0.5	Coolant Temp. @ Start 51 *c Finish= 52 *c
Belt Condition	OK	
Oil Pressure	..	Start = 5.1 bar Finish= 7 bar
Battery Condition	OK	
Battery Voltage	12.8	
Engine RPMs	1000	
Generator		Comments
Generator Volts	413	
Generator Amps	100	
Generator "KVA"	10	
Reason For Use		Comments
Testing	Y	
Emergency		
Maintenance		
Generator		Comments
Fuel Delivered	0	
Fuel Level 1/4 1/2 3/4 F	0/0	
Sulfur Concentrations		
<0.0015% (15ppm)		

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the "Outage no longer imminent or in effect."

Diesel Generator Weekly Test Log

Plant: Beta

Date: 1.1.17

Operator: *dl*

Main Generator Breaker		Comments
Open	<input checked="" type="checkbox"/>	
Closed	<input type="checkbox"/>	
Engine		Comments
Start Time:	<i>11:58</i>	
Stop Time:	<i>12:05</i>	
Total Run Time:	<i>5:00</i>	
Starting Hour Meter Reading	<i>1000</i>	
Ending Hour Meter Reading	<i>1005</i>	
Oil Level	<i>OK</i>	
Coolant Level	<i>OK</i>	Coolant Temp. @ Start S.:? *c Finish= 8 *c
Belt Condition	<i>OK</i>	
Oil Pressure		Start = g. 3 bar Finish= i,,f bar
Battery Condition	<i>OK</i>	
Battery Voltage	<i>12.6</i>	
Engine RPMs	<i>1500</i>	
Generator		Comments
Generator Volts	<i>413</i>	
Generator Amps	<i>25</i>	
Generator "KVA"	<i>1.7</i>	
Reason For Use		Comments
Testing	<input checked="" type="checkbox"/>	
Emergency	<input type="checkbox"/>	
Maintenance	<input type="checkbox"/>	
Generator		Comments
Fuel Delivered	<i>No</i>	
Fuel Level 1/4 1/2 3/4 F	<i>3/4</i>	
Sulfur Concentrations <0.0015% (15ppm)		<i>2) e/1 VI' ...BA',:01 I4' .</i>

This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.

This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outage no longer imminent or in effect.

ABENGOA SOLAR

Emergency Diesel Generator w ekly Tf:st Log

Plant: Alpb,-
 Date: 17.12.17
 Operator: rauin AMC-fSon

Engine		Comments
Oil level	A...	
Start Time	19S	
StartinQ Hour Meter Reading	Cr:	
Oil Pressure	1.9 "	
Battery Condition		
Battery Voltaae	21.1"	
Engine RPM	1	
Generator Volts	11.99 kV	
Coolant temperature	7.0	
Oil temperature	111.8	
Fuel level%		
Stop time		
Ending hour meter readina	98899	
Total run time	1h - 11m - 5s	
Generator (when testing with load)		
Breaker dose		
Generator Volts		
Breaker open		
Generator ·KW·		
Reason For Use		
Testing:	J	
Emergency:		
Maintenance:		
Confirm master control turned back in auto: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
<p>This Emergency Generator shall be limited to use for emergency power, as defined as in response to a fire or when utility back-feed power is not available. In addition, this unit shall be operated no more than 30 minutes during any hour and 50 hours per year for testing and maintenance excluding compliance source testing. There is no limit on engine operation for Emergency use.</p> <p>This engine may operate in response to notification of impending loss of utility back-feed power if the interconnected utility has ordered an outage to the plant or expects to order such outages at a particular time the engine is operated no more than 30 minutes prior to the forecasted outage and the engine is shut immediately after the utility advises that the outaae no longer imminent or in effect</p>		

MATERIAL SAFETY DATA SHEET

UNLEADED GASOLINE (UNBRANDED)

MSDS No.
APPC975
Version: 1
Date
05/19/2003

IMPORTANT: Read this MSDS before handling and disposing of this product and pass this information on to employees, customers, and users of this product.

1. PRODUCT and COMPANY IDENTIFICATION

Material Identity	Unleaded Gasoline (Unbranded)		
Trade Name(s)	None		
Other Name(s)	Unleaded Motor Vehicle Gasoline, Unleaded Premium Gasoline, Unleaded Regular Gasoline or Petrol, Clear Gasoline.		
Chemical Description	Petroleum Hydrocarbons		
Manufacturer's Address	BP West Coast Products LLC Carson Business Unit 1801 E. Sepulveda Boulevard Carson, California 90749-6210	BP West Coast Products LLC Cherry Point Business Unit 4519 Grandview Road Blaine, Washington 98230	
Telephone Numbers	Emergency Health Information: Emergency Spill Information: Other Product Information:	1 (800) 447-8735 1 (800) 424-9300 CHEMTREC (USA) 1 (866) 4BP-MSDS (866-427-6737 Toll Free - North America) email: bpcares@bp.com	
	Customer Service:	1 (800) 322-3736 INFO	

2. COMPONENTS and EXPOSURE LIMITS

<u>Component</u> ¹	<u>CAS No.</u>	<u>% Composition By Volume</u> ²	<u>ACGIH TLV</u>	<u>Exposure Limits</u>		
				<u>OSHA PEL</u> ³	<u>Units</u>	<u>Type</u>
GASOLINE ⁽²⁾⁽⁴⁾	8006-61-9	EQ 100	500 300	500 300	ppm ppm	STEL TWA
which contains:						
BENZENE ⁽¹⁾⁽²⁾⁽³⁾⁽⁴⁾	71-43-2	AP 1 to 5	2.5 0.5 skin	5 1	ppm ppm	STEL TWA
CYCLOHEXANE	110-82-7	LT 2	400 300	N/AP 300	ppm ppm	STEL TWA
ETHYLBENZENE ⁽²⁾	100-41-4	AP 1 to 3	125 100	125 100	ppm ppm	STEL TWA
HEXANE (N-HEXANE)	110-54-3	AP 2 to 5	50 skin	50	ppm	TWA
TOLUENE	108-88-3	AP 7 to 14	N/AP 50 skin	150 100	ppm ppm	STEL TWA
TRIMETHYL BENZENE (ALL ISOMERS)	25551-13-7	LT 5	25	25	ppm	TWA
1,2,4-TRIMETHYLBENZENE	95-63-6	AP 1 to 4	25	25	ppm	TWA

2,2,4 TRIMETHYLPENTANE	540-84-1	AP	3 to 10	N/AP	N/AP		
XYLENE	1330-20-7	AP	8 to 15	150 100	150 100	ppm ppm	STEL TWA
which may contain:							
ETHANOL	64-17-5	AP	0 to 10	1000	1000	ppm	TWA
METHYL TERTIARY BUTYL ETHER (MTBE) ⁽⁴⁾	1634-04-4	AP	0 to 15	40	N/AP	ppm	TWA

¹ Carcinogen displayed after Component Name. Listed by ⁽¹⁾ NTP, ⁽²⁾ IARC, ⁽³⁾ OSHA, ⁽⁴⁾ Other

² See Abbreviations on last page

³ The OSHA exposure limits were changed in 1993 due to a federal court ruling. ARCO has chosen to list the 1989 OSHA exposure limits in this document as they are generally more stringent and therefore more protective than the current exposure limits. (Refer to 29 CFR 1910.1000).

3. HAZARD IDENTIFICATION

IMMEDIATE HAZARDS

DANGER

HIGHLY FLAMMABLE! OSHA/NFPA Class IB flammable liquid. Keep away from heat, sparks, and open flame.

Never siphon gas by mouth. Harmful if swallowed. Contains petroleum distillates.

ASPIRATION HAZARD! If swallowed, do not induce vomiting since aspiration into the lungs may cause chemical pneumonia. Obtain prompt medical attention.

Prolonged or repeated liquid contact may cause irritation. High vapor concentrations (greater than 1000 ppm) may cause irritation to eyes and respiratory system and may cause dizziness and other nervous system effects.

Generally, human exposures to gasoline are considerably lower than levels which have caused adverse health effects in animal studies or human case studies of gasoline misuse or abuse (such as gasoline sniffing). Adverse health effects are not expected to occur at exposure levels typically encountered in the use of gasoline as a motor fuel.

Avoid breathing vapors or mists. Use only with adequate ventilation. Use as a motor fuel only. Do not use as a cleaning solvent, thinner or for other non-motor fuel use.

Wash hands thoroughly after handling.

ACUTE HEALTH HAZARDS

Routes of Exposure

Signs and Symptoms

Inhalation (Primary)	Exposures at airborne concentrations well above the recommended exposure limits in Section 2 may cause irritation of the nose, throat, and lungs, headache, dizziness, drowsiness, confusion, loss of coordination, fatigue, nausea, labored breathing and irregular heartbeats. May lead to unconsciousness, convulsions, and possibly death.
Eye Contact	May cause some transitory eye irritation but not expected to cause prolonged or significant eye irritation.
Skin Contact	Moderate skin irritation may occur upon short-term exposure. May be absorbed and contribute to the acute inhalation health effects (see above).
Ingestion	<p>ASPIRATION HAZARD! This material can enter the lungs during swallowing or vomiting and may cause acute lung inflammation and damage which in severe cases may be fatal.</p> <p>Ingestion may cause irritation of the mouth, throat and gastrointestinal tract leading to nausea, vomiting, diarrhea, and restlessness.</p> <p>May cause headache, dizziness, drowsiness, confusion, loss of coordination, fatigue, nausea and labored breathing. May lead to unconsciousness, convulsions, and possibly death.</p>

Summary of Chronic Hazards and Special Health Effects

Exposures at airborne concentrations well above the recommended exposure limits in Section 2 may aggravate medical conditions such as chronic respiratory diseases, cardiovascular disease, skin diseases, or blood disorders.

Prolonged/repeated exposures above the recommended exposure limits via skin contact, inhalation or ingestion of this material may result in adverse dermal or systemic effects. Avoid prolonged or repeated overexposure.

Contains benzene, a chemical known to cause cancer in humans. Repeated and prolonged overexposure to benzene vapors may cause leukemia, aplastic anemia, or other blood disorders, immunotoxicity, reproductive harm or fetal toxicity.

Neurotoxic effects have been associated with n-hexane, a component of this material upon prolonged or repeated overexposure.

Generally, human exposures to gasoline are considerably lower than levels which have caused adverse health effects in animal studies or human case studies of gasoline misuse or abuse (such as gasoline sniffing). Adverse health effects are not expected to occur at exposure levels typically encountered in the use of gasoline as a motor fuel.

See Section 11 for Additional Toxicological Information.

4. EMERGENCY and FIRST AID**Inhalation**

Immediately move personnel to area with fresh air. For respiratory distress, give oxygen, rescue breathing or administer CPR (cardiopulmonary resuscitation). Obtain prompt medical attention.

Eye Contact

Flush with clean, low-pressure water for at least 15 minutes, occasionally lifting the eyelids. If pain or redness is present after flushing, obtain medical attention.

Skin Contact

Immediately remove contaminated clothing. Wash affected skin thoroughly with soap and water. If irritation persists, obtain medical attention.

Ingestion

Do not induce vomiting. Obtain prompt medical attention.

ASPIRATION HAZARD: This material can enter the lungs during swallowing or vomiting and may cause lung inflammation and damage.

Emergency Medical Treatment Procedures

See above procedures.

5. FIRE and EXPLOSION**Flash Point (Method)***

AP -45°F **

Autoignition Temperature (Method)*

AP 536°F **

Flammable Limits (% Vol. in Air)*

Lower

AP 1.4

Upper

AP 7.6

* At Normal Atmospheric Temperature and Pressure

** Based on NFPA Gasoline

NFPA Hazard Rating:

Health: 1 = Slight

Fire: 3 = High

Reactivity: 0 = Insignificant

Special: = ---

Fire and Explosion Hazards

HIGHLY FLAMMABLE! Vaporizes easily at normal and below normal temperatures. When mixed with air in certain proportions and exposed to an ignition source, these vapors can burn in the open or explode in confined spaces. Being heavier than air, flammable vapors may travel long distances along the ground before reaching a point of ignition and flashing back.

May accumulate static electricity.

Liquid floats on water and may travel to a source of ignition and spread fire.

"Empty" containers retain liquid and vapor residues and, if exposed to source of ignition, may explode.

Extinguishing Media	Foam, Water fog, Dry chemical, Carbon Dioxide (CO ₂) Water and water spray may cool the fire but may not extinguish the fire.
Special Firefighting Procedures	For fires involving this material, do not enter any enclosed or confined fire space without proper protective equipment. This may include self-contained breathing apparatus to protect against the hazardous effects of combustion products and oxygen deficiencies. If firefighters cannot work upwind to the fire, respiratory protective equipment must be worn. Cool tanks and containers exposed to fire with water.

6. ACCIDENTAL RELEASE MEASURES

Precautions if Material is Spilled or Released	Eliminate all potential sources of ignition. Handling equipment and tools should be grounded to prevent sparking. Contain spill, evacuate non-essential personnel, and safely stop flow. Blanket spill with foam or use water fog to reduce vapor cloud. On hard surfaces, spilled material may create a slipping hazard. Equip cleanup crews with proper protective equipment (as specified in Section 8) and advise of hazards. Clean up by recovering as much spilled or contaminated materials as possible and placing into closed containers. Consult with an environmental professional for the federal, state and local cleanup and reporting requirements for spills and releases.
---	--

7. HANDLING and STORAGE

Handling, Storage and Decontamination Procedures	<p>Avoid exposure to liquid and gas vapors. Odor is not a reliable warning of overexposure. Use only with adequate ventilation.</p> <p>Keep away from sources of heat, flames, sparks or other ignition sources. Storage and use areas should be "No Smoking" areas. Containers should be bonded and grounded for transfers to avoid static sparks.</p> <p>Outside or detached storage is preferred. Inside storage should be in a standard flammable liquids storage warehouse, room or cabinet. Separate from oxidizing materials.</p> <p>Filling Portable Containers (less than 10 gallons) - to minimize static spark hazard:</p> <ol style="list-style-type: none">1. Fill only metal containers or those approved to hold gasoline;2. Place containers on the ground while dispensing fuel;3. Keep hose nozzle in contact with the approved container during the entire filling process. <p>DO NOT fill any portable container in or on a vehicle.</p> <p>"Empty" containers retain liquid and vapor residues and can be dangerous. Do not pressurize, cut, weld, drill, grind or expose to heat, flame, sparks, static electricity, or other sources of ignition containers with ANY residue; they may explode and cause injury or death.</p> <p>For determining National Electrical Code (NEC) Hazardous (Classified) Location requirements for electrical installation, consider this material Class 1, Group D.</p> <p>KEEP OUT OF REACH OF CHILDREN!</p>
---	--

8. EXPOSURE CONTROLS/PERSONAL PROTECTION

Engineering Controls	Where possible, use adequate ventilation to keep vapor and mist concentrations of this material below the occupational exposure limits shown in Section 2. Electrical equipment should comply with National Electrical Code (NEC) standards (see Section 7).
Respiratory	A NIOSH/MSHA-approved air-purifying respirator with an organic vapor cartridge may be permissible under certain circumstances where airborne concentrations may exceed the exposure limits in Section 2. Consult a health and safety professional for guidance in respirator selection. Respirator use should comply with OSHA 29 CFR 1910.134.

CAUTION: The protection provided by air-purifying respirators is limited. Use a positive pressure air-supplied respirator if there is any potential for an uncontrolled release, if exposure levels are not known, or if concentrations exceed the protection limits of the air-purifying respirator.

Eyes	Eye protection should be worn. If there is potential for splashing or spraying, chemical protective goggles and a face shield should be worn. If contact lenses are worn, consult an eye specialist or a safety professional for additional precautions. Suitable eye wash water should be available in case of eye contact with this material.
Skin	Avoid prolonged and/or repeated skin contact. If conditions or frequency of use make significant contact likely, clean and impervious clothing such as gloves, apron, boots and facial protection should be worn. Nitrile and Viton protective clothing material is recommended. Non-impervious clothing which becomes contaminated with this material should be removed promptly and not reworn until the material is effectively removed from the clothing.
Other Hygienic and Work Practices	Use good personal hygiene practices. In case of skin contact, wash with mild soap and water or a waterless hand cleaner. Wash hands and other exposed areas thoroughly before eating, drinking, smoking, or using toilet facilities.

9. PHYSICAL and CHEMICAL PROPERTIES

Boiling Point:	AP 35°F to 437°F
Viscosity Units, Temp. (Method):	N/AP
Dry Point:	AP 430°F
Freezing Point:	N/AP
Vapor Pressure, Temp. (Method):	AP 5 to 15 at 100°F (REID-PSIA)
Volatile Characteristics:	Appreciable
Specific Gravity (H₂O = 1 @ 39.2°F):	AP 0.7 to 0.8
Vapor Sp. Gr. (Air = 1.0 @ 60°F - 90°F):	AP 4
Solubility in Water:	Slight
PH:	N/AP
Appearance and Odor:	Colorless to straw-colored liquid; petroleum naphtha odor.
Other Physical and Chemical Properties:	Vapor pressure will vary seasonally in compliance with industry standards and federal and state regulations.

10. STABILITY and REACTIVITY

Stability	Stable
Hazardous Polymerization	Not expected to occur.
Other Chemical Reactivity	Reacts with oxidizing materials.

Conditions to Avoid	Heat, sparks, flame, and build up of static electricity.
Materials to Avoid	Halogens, strong acids, alkalis, and oxidizers.
Hazardous or Decomposition Products	Burning or excessive heating may produce carbon monoxide and other harmful gases or vapors including oxides and/or other compounds of sulfur. The inhalation of components of exhaust from combusted fuel can be fatal in high concentrations in an enclosed area. Exposure to exhaust from this fuel should be minimized.

11. TOXICOLOGICAL INFORMATION

Toxicological Information	The information found in this section is written for medical, toxicology, occupational health and safety professionals. This section provides technical information on the toxicity testing of this or similar materials or its components. If clarification of the technical content is needed, consult a professional in the areas of expertise listed above.
Inhalation	Toxicity studies on this material resulted in LC50 values greater than 5.0 mg/l indicating a low potency. There were signs of respiratory tract irritation and central nervous system depression.
Eye Contact	Minimal to no irritation in animal studies.
Skin Contact	Animal studies resulted in moderate skin irritation following short term or prolonged/repeated exposure. The acute dermal toxicity tests indicate LD50 values greater than 2.0 g/kg indicating a low potency. Exposure to sunlight does not increase skin irritation. This material appears to be non-sensitizing.
Ingestion	The acute oral toxicity tests produced LD50 values greater than 5.0 g/kg indicating a low potency. There were signs of gastrointestinal tract irritation and central nervous system depression.
Prolonged/ Repeated Exposures	<p>Twenty-eight day dermal toxicity studies resulted in moderate skin irritation. In some studies changes in liver, kidney, testes and whole body weights were noted, but no significant systemic tissue changes characteristic of disease. Ninety-day dermal toxicity studies with similar material resulted in moderate skin irritation and not other significant observations or systemic tissue changes characteristic of disease. Twenty-eight day inhalation toxicity study similar materials resulted in kidney damage in male rats.</p> <p>A two-year inhalation study with a generic unleaded gasoline formulated by the American Petroleum Institute caused kidney damage and kidney tumors in male rats and liver tumors in female mice. These effects are considered specific to these laboratory animals and not applicable to humans.</p> <p>Exposure to components of gasoline such as benzene, toluene, xylene, ethylbenzene, trimethylbenzene, and N-hexane has also been shown to affect reproductive capacity and/or fetal development in laboratory animals.</p> <p>Studies with laboratory animals (dogs) indicate that exposure to extremely high concentrations of gasoline (greater than 50,000 ppm) may cause irregular heartbeats and sudden death. Exposures of laboratory animals to some components of this material at very high concentrations, well above the recommended exposure limits in Section 2, have resulted in cardiac sensitization with irregular heartbeats.</p> <p>Exposure to n-hexane at concentrations considerably higher than the current permissible exposure limit has reportedly been associated with peripheral neuropathy. Commercial hexane exposures up to 9000 ppm were not carcinogenic in laboratory animals.</p> <p>In animal studies and in workers with chronic benzene poisoning, alterations in structure of chromosomes in bone marrow and white blood cells have been observed.</p>
Additional Ethanol Toxicity Information	<p>Exposures to ethanol in gasoline are considerably lower than levels which have caused adverse health effects. Adverse health effects are not expected to occur at exposure levels typically encountered in the use of ethanol as a gasoline additive.</p> <p>Prolonged and repeated exposure to ethanol vapor above 1000 ppm may cause headache, lack of coordination, sleepiness, fatigue, and difficulty concentrating. Chronic ingestion of ethanol in the form of alcoholic beverages has resulted in liver, stomach, heart and nervous system damage as well as cancers of the mouth, pharynx, larynx, esophagus, and liver in humans. Repeated ingestion of ethanol in the form of alcoholic beverages by pregnant women has caused miscarriage, premature birth and low birth weight, and birth defects (fetal alcohol syndrome).</p>
Additional MTBE Toxicity Information	MTBE at very high exposure levels (8000 ppm) did induce developmental toxicity in mice, but only at levels where there was also maternal toxicity. In rabbits exposed to the same MTBE levels, there were no indicators of any effects on the offspring, even in the presence of maternal toxicity. The abnormal findings in the mice (cleft palate, etc.) are well-recognized effects of stress in the pregnant mouse and have no correlation with development hazards in humans.

Chronic toxicity studies have been completed for MTBE. In these studies, B6C3F1 mice and F344 rats were exposed to 400, 3000, or 8000 ppm MTBE vapors, 6 hrs/day, 5 days/week for life. Few adverse effects were noted for either rats or mice.

Male and female mice exposed to 8000 ppm MTBE vapors developed a slightly higher incidence of benign liver tumors during their lifetime. No other adverse effects or increases in tumor incidences were found.

Male and female rats exposed to high concentrations of MTBE vapors developed an increasing incidence of chronic progressive kidney damage, an effect typically noted in aging rats. These effects were most severe in 3000 and 8000 ppm exposure groups and were accompanied by an increased incidence of kidney tumors (males only). These findings are consistent with kidney damage associated with accumulation of protein in cells, an effect which may be unique to the male rat. Benign testicular tumors were numerically increased in high dose MTBE male rats, but this is an age-related lesion which typically occurs in a very high proportion of control untreated rats.

MTBE does not appear to be a mutagen.

All of these effects either occur in tissues prone to the development of tumors or may occur by a mechanism not considered relevant to humans. The significance of these findings for human health hazards estimation is unclear. Furthermore, IARC has determined that MTBE is not classifiable as to its carcinogenicity to humans (Group 3).

12. ECOLOGICAL INFORMATION

Not Available

13. DISPOSAL CONSIDERATIONS

Waste Disposal Methods Consult an environmental professional to determine if state or federal regulations would classify this material as a hazardous waste. Use only approved transporters, recyclers, treatment, storage or disposal facilities. Comply with all federal, state and local laws pertaining to waste management.

14. TRANSPORT INFORMATION

UN Proper Shipping Name	Gasoline
UN Hazard Class	3
UN Number	UN1203
UN Packing Group	PGII

15. REGULATORY INFORMATION**SUPERFUND AMENDMENTS AND REAUTHORIZATION ACT OF 1986 (SARA), TITLE III****Section 311/312 Hazard Categories:**

Acute Health Hazard
 Delayed (chronic) health hazard
 Fire hazard

Section 313:

This product contains the following chemicals subject to the reporting requirements established by SARA Title III:

BENZENE
 CYCLOHEXANE
 ETHYLBENZENE
 METHYL TERT-BUTYL ETHER
 TOLUENE
 XYLENE

TOXIC SUBSTANCES CONTROL ACT (TSCA)

All components of this product are listed on the TSCA Inventory.

COMPREHENSIVE ENVIRONMENTAL RESPONSE, COMPENSATION AND LIABILITY ACT (CERCLA)

This material is covered by CERCLA's PETROLEUM EXEMPTION.
 (Refer to 40 CFR 307.14)

CALIFORNIA SAFE DRINKING WATER AND TOXIC ENFORCEMENT ACT OF 1986 - PROPOSITION 65**PROP 65 WARNING LABEL:**

Chemicals known to the State to cause cancer, birth defects, or other reproductive harm are found in gasoline, crude oil, and many other petroleum products and their vapors, or result from their use. Read and follow label directions and use care when handling or using all petroleum products.

WARNING:

This product contains the following chemical(s) listed by the State of California as known to cause cancer or birth defects or other reproductive harm.

BENZENE ^(C) ^(R)
 TOLUENE ^(R)

Other Prop 65 chemicals will result under certain conditions from the use of this material. For example, burning fuels produces combustion products including carbon monoxide, a Prop 65 reproductive toxin.

^(C) = Carcinogen

^(R) = Birth Defects or other Reproductive Harm

16. OTHER INFORMATION**General Comments**

Because of volatility characteristics, gasoline vapors may have concentrations of components different from those of liquid gasoline. The major components of gasoline vapors from liquid gasoline are butane, isobutane, pentane and isopentane.

The information and conclusions herein reflect normal operating conditions and may be from sources other than direct test data on the mixture itself.

Abbreviations:

EQ = Equal

LT = Less Than

GT = Greater Than

AP = Approximately

UK = Unknown

TR = Trace

N/P = No Applicable Information Found

N/AP = Not Applicable

N/DA = No Data Available

Prepared by: Product Stewardship

Disclaimer of Liability


The information in this MSDS was obtained from sources which we believe are reliable. **HOWEVER, THE INFORMATION IS PROVIDED WITHOUT ANY WARRANTY, EXPRESS OR IMPLIED, REGARDING ITS CORRECTNESS.**

The conditions or methods of handling, storage, use and disposal of the product are beyond our control and may be beyond our knowledge. **FOR THIS AND OTHER REASONS, WE DO NOT ASSUME RESPONSIBILITY AND EXPRESSLY DISCLAIM LIABILITY FOR LOSS DAMAGE OR EXPENSE ARISING OUT OF OR IN ANY WAY CONNECTED WITH THE HANDLING, STORAGE, USE OR DISPOSAL OF THE PRODUCT.**

This MSDS was prepared and is to be used only for this product. If the product is used as a component in another product, this MSDS information may not be applicable.

Material Safety Data Sheet

Diesel Fuel - NR



TESORO

HMIS III:

HEALTH	1
FLAMMABILITY	2
PHYSICAL	0

O= Insignificant, 1 = Slight, 2 = Moderate, 3 = High, 4 = Extreme

SECTION 1. PRODUCT AND COMPANY IDENTIFICATION

Product name	: Diesel Fuel - NR		
Synonyms	: Dakota 50, Diesel Fuel - Non-Road, Red Dyed Diesel, Agricultural Diesel, Ag Diesel, 888100008799		
MSDS Number	: 888100008799	Version	: 1.3
Product Use Description	: Fuel		
Company	: For: Tesoro Refining & Marketing Co. 19100 Ridgewood Parkway, San Antonio, TX 78259		
Tesoro Call Center	: (877) 783-7676	Chemtrec (Emergency Contact)	: (800) 424-9300

SECTION 2. HAZARDS IDENTIFICATION

Emergency Overview

Regulatory status	: This material is considered hazardous by the Occupational Safety and Health Administration (OSHA) Hazard Communication Standard (29 CFR 1910.1200).
Signal Word	: WARNING
Hazard Summary	: Combustible Liquid
	Toxic

Potential Health Effects

Inhalation	: Vapors or mists from this material can irritate the nose, throat, and lungs, and can cause signs and symptoms of central nervous system depression, depending on the concentration and duration of exposure.
Eyes	: Eye irritation may result from contact with liquid, mists, and/or vapors.
Skin	: Skin irritation leading to dermatitis may occur upon prolonged or repeated contact. Liquid may be absorbed through the skin in toxic amounts if large areas of skin are repeatedly exposed. Long-term, repeated skin contact may cause skin cancer.
Ingestion	: Harmful or fatal if swallowed. Do NOT induce vomiting. This material can irritate the mouth, throat, stomach, and cause nausea, vomiting, diarrhea and restlessness. Aspiration hazard if liquid is inhaled into lungs, particularly from vomiting after ingestion. Aspiration may result in chemical pneumonia, severe

lung damage, respiratory failure and even death.

Target Organs

: Kidney, Liver, Central nervous system, Eyes, Skin

SECTION 3. COMPOSITION/INFORMATION ON INGREDIENTS

Component	CAS-No.	Weight%
Fuels, diesel, No 2; Gasoil - unspecified	68476-34-6	100%
Naphthalene	91-20-3	1 - 5%
Xylene	1330-20-7	1 - 5%
Nonane	111-84-2	0.75 - 1%
1,2,4-Trimethylbenzene	95-63-6	0.75 - 1%
Sulfur	7704-34-9	15 ppm Maximum

SECTION 4. FIRST AID MEASURES

Inhalation	: Move to fresh air. Give oxygen. If breathing is irregular or stopped, administer artificial respiration. Seek medical attention immediately.
Skin contact	: Take off all contaminated clothing immediately. Wash off immediately with soap and plenty of water. Wash contaminated clothing before re-use. If skin irritation persists, seek medical attention.
Eye contact	: Remove contact lenses. Rinse immediately with plenty of water, also under the eyelids, for at least 15 minutes. If eye irritation persists, seek medical attention.
Ingestion	: Do NOT induce vomiting. Ingestion may result in nausea, vomiting, diarrhea and restlessness. Aspiration may cause pulmonary edema and pneumonitis. Seek medical attention immediately.
Notes to physician	: Symptoms: Dizziness, Discomfort, Headache, Nausea, Disorder, Vomiting, Lung edema, Aspiration may cause pulmonary edema and pneumonitis. Liver disorders, Kidney disorders.

SECTION 5. FIRE-FIGHTING MEASURES

Form	: Liquid
Flash point	: 38 °C (100 °F) Minimum for #1 NRLM ; 52 ° Minimum for #2 NRLM
Lower explosive limit	: 0.7 %(V)
Upper explosive limit	: 5 %(V)
Suitable extinguishing media	: Carbon dioxide (CO2), Water spray, Dry chemical, Foam, Keep containers and surroundings cool with water spray.
Specific hazards during fire fighting	: Fire Hazard Do not use a solid water stream as it may scatter and spread fire. Cool closed containers exposed to fire with water spray.

- Special protective equipment for fire-fighters** : Wear self-contained breathing apparatus and protective suit. Use personal protective equipment.
- Further information** : Exposure to decomposition products may be a hazard to health. Isolate area around container involved in fire. Cool tanks, shells, and containers exposed to fire and excessive heat with water. For massive fires the use of unmanned hose holders or monitor nozzles may be advantageous to further minimize personnel exposure. Major fires may require withdrawal, allowing the tank to burn. Large storage tank fires typically require specially trained personnel and equipment to extinguish the fire, often including the need for properly applied fire fighting foam.

SECTION 6. ACCIDENTAL RELEASE MEASURES

- Personal precautions** : Consider wind direction; stay upwind and uphill, if possible. Evacuate nonessential personnel and remove or secure all ignition sources. Evaluate the direction of product travel, diking, sewers, etc. to contain spill areas. Spills may infiltrate subsurface soil and groundwater; professional assistance may be necessary to determine the extent of subsurface impact. Ensure adequate ventilation. Use personal protective equipment.
- Environmental precautions** : Carefully contain and stop the source of the spill, if safe to do so. Do not flush down sewer or drainage systems, unless system is designed and permitted to handle such material. The use of fire fighting foam may be useful in certain situations to reduce vapors. The proper use of water spray may effectively disperse product vapors or the liquid itself, preventing contact with ignition sources or areas/equipment that require protection. Discharge into the environment must be avoided. If the product contaminates rivers and lakes or drains inform respective authorities.
- Methods for cleaning up** : Take up with sand or oil absorbing materials. Carefully shovel, scoop or sweep up into a waste container for reclamation or disposal - caution, flammable vapors may accumulate in closed containers. Response and clean-up crews must be properly trained and must utilize proper protective equipment (see Section 8).

SECTION 7. HANDLING AND STORAGE

- Handling** : Keep away from fire, sparks and heated surfaces. No smoking near areas where material is stored or handled. The product should only be stored and handled in areas with intrinsically safe electrical classification.
- Advice on protection against fire and explosion** : Hydrocarbon liquids including this product can act as a non-conductive flammable liquid (or static accumulators), and may form ignitable vapor-air mixtures in storage tanks or other containers. Precautions to prevent static-initated fire or explosion during transfer, storage or handling, include but are not limited to these examples:
 - (1) Ground and bond containers during product transfers. Grounding and bonding may not be adequate protection to prevent ignition or explosion of hydrocarbon liquids and vapors that are static accumulators.
 - (2) Special slow load procedures for "switch loading" must be followed to avoid the static ignition hazard that can exist when higher flash point material (such as fuel oil or diesel) is loaded into tanks previously containing low flash point products (such as gasoline or naphtha).
 - (3) Storage tank level floats must be effectively bonded.

For more information on precautions to prevent static-initated fire or explosion, see NFPA 77, Recommended Practice on Static Electricity (2007), and API Recommended Practice 2003, Protection Against Ignitions Arising Out of Static, Lightning, and Stray Currents (2008).

- Dust explosion class** : Not applicable
- Requirements for storage areas and containers** : Keep away from flame, sparks, excessive temperatures and open flame. Use approved containers. Keep containers closed and clearly labeled. Empty or partially full product containers or vessels may contain explosive vapors. Do not pressurize, cut, heat, weld or expose containers to sources of ignition. Store in a well-ventilated area. The storage area should comply with NFPA 30 "Flammable and Combustible Liquid Code". The cleaning of tanks previously containing this product should follow API Recommended Practice (RP) 2013 "Cleaning Mobile Tanks in Flammable and Combustible Liquid Service" and API RP 2015 "Cleaning Petroleum Storage Tanks".
- Advice on common storage** : Keep away from food, drink and animal feed. Incompatible with oxidizing agents. Incompatible with acids.
- Other data** : No decomposition if stored and applied as directed.

SECTION 8. EXPOSURE CONTROLS / PERSONAL PROTECTION

Exposure Guidelines

Ust	Components	CAS-No.	Type:	Value
OSHAZ1	Naphthalene	91-20-3	PEL	10ppm 50mg/m3
	Xylene	1330-20-7	PEL	100 ppm 435 mg/m3
ACGIH	Diesel Fuel	68476-30-2	TWA	100 mg/m3
ACGIH	Naphthalene	91-20-3	TWA	10ppm
		91-20-3	STEL	15ppm
	Xylene	1330-20-7	TWA	100 ppm
		1330-20-7	STEL	150 ppm
	Nonane	111-84-2	TWA	200 ppm

- Engineering measures** : Use only intrinsically safe electrical equipment approved for use in classified areas.
- Eye protection** : Safety glasses with side-shields reference to 29 CFR 1910.133
- Hand protection** : Gloves constructed of nitrile, neoprene, or PVC are recommended. Consult manufacturer specifications for further information.
- Skin and body protection** : If needed to prevent skin contact, chemical protective clothing such as of DuPont TyChem®, Saranex or equivalent recommended based on degree of exposure. The resistance of specific material may vary from product to product as well as with degree of exposure.

- Respiratory protection** : A NIOSH/ MSHA-approved air-purifying respirator with organic vapor cartridges or canister may be permissible under certain circumstances where airborne concentrations are or may be expected to exceed exposure limits or for odor or irritation. Protection provided by air-purifying respirators is limited. Refer to OSHA 29 CFR 1910.134, ANSI 288.2-1992, NIOSH Respirator Decision Logic, and the manufacturer for additional guidance on respiratory protection selection. NIOSH/MSHA approved positive-pressure self-contained breathing apparatus (SCBA) or Type C positive-pressure supplied air with escape bottle must be used for gas concentrations above occupational exposure limits, for potential of uncontrolled release, if exposure levels are not known, or in an oxygen-deficient atmosphere.
- Work /Hygiene practices** : Emergency eye wash capability should be available in the near proximity to operations presenting a potential splash exposure. Use good personal hygiene practices. Avoid repeated and/or prolonged skin exposure. Wash hands before eating, drinking, smoking, or using toilet facilities. Do not use as a cleaning solvent on the skin. Do not use solvents or harsh abrasive skin cleaners for washing this product from exposed skin areas. Waterless hand cleaners are effective. Promptly remove contaminated clothing and launder before reuse. Use care when laundering to prevent the formation of flammable vapors which could ignite via washer or dryer. Consider the need to discard contaminated leather shoes and gloves.

SECTION 9. PHYSICAL AND CHEMICAL PROPERTIES

- Form** : Liquid
- Appearance** : Clear, straw colored.
- Odor** : Characteristic petroleum (kerosene) odor
- Flash point** : 38 °C (100 °F) Minimum for #1 NRLM; 52 ° Minimum for #2 NRLM
- Thermal decomposition** : No decomposition if stored and applied as directed.
- Lower explosive limit** : 0.7 %(V)
- Upper explosive limit** : 5 %(V)
- Freezing point** : Not applicable
- Boiling point** : 160 °C(320 °F)
- Vapor Pressure** : < 2 mm Hg at 20 °C
- Relative Vapor Density** : 5.7 (Air= 1.0)
- Water solubility** : Negligible
- Percent Volatiles** : 100 %
- Conductivity (conductivity can be reduced by environmental factors such as a decrease in temperature)** Diesel Fuel Oils at terminal load rack: At least 25 pS/m
 Ultra Low Sulfur Diesel (ULSD) without conductivity additive: 0 pS/m to 5 pS/m
 ULSD at terminal load rack with conductivity additive: At least 50 pS/m but conductivity may decrease from environmental factors such as temperature drop.
 JP-8 at terminal load rack: 150 pS/m to 600 pS/m

SECTION 10. STABILITY AND REACTIVITY

- Conditions to avoid** : Avoid high temperatures, open flames, sparks, welding, smoking and other ignition sources. Keep away from strong oxidizers. Viton ®; Fluorel ®
- Materials to avoid** : Strong oxidizing agents Peroxides
- Hazardous decomposition products** : Carbon monoxide, carbon dioxide and noncombusted hydrocarbons (smoke). Diesel exhaust particulates may be a lung hazard - see Section 11.
- Thermal decomposition** : No decomposition if stored and applied as directed. No decomposition if used as directed.
- Hazardous reactions** : Keep away from oxidizing agents, and acidic or alkaline products.

SECTION 11. TOXICOLOGICAL INFORMATION

Carcinogenicity

- NTP** : Naphthalene (GAS-No.: 91-20-3)
- IARC** : Naphthalene (GAS-No.: 91-20-3)
- OSHA** : No component of this product which is present at levels greater than or equal to 0.1 % is identified as a carcinogen or potential carcinogen by OSHA.
- CA Prop 65** : WARNING! This product contains a chemical known to the State of California to cause cancer.
Naphthalene (CAS-No.: 91-20-3)
- Skin irritation** : Irritating to skin.
- Eye irritation** : Irritating to eyes.
- Further information** : Studies have shown that similar products produce skin cancer or skin tumors in laboratory animals following repeated applications without washing or removal. The significance of this finding to human exposure has not been determined. Other studies with active skin carcinogens have shown that washing the animal's skin with soap and water between applications reduced tumor formation.
Positive mutagenicity results have been reported.
Repeated over-exposure may cause liver and kidney injury
IARC classifies whole diesel fuel exhaust particulates as probably carcinogenic to humans (Group 2A). NIOSH regards whole diesel fuel exhaust particulates as a potential cause of occupational lung cancer based on animal studies and limited evidence in humans.

Component:

Fuels, diesel, No 2; Gasoil - unspecified	68476-34-6	<u>Acute oral toxicity:</u> LD50 rat Dose: 5,001 mg/kg <u>Acute dermal toxicity:</u> LD50 rabbit Dose: 2,001 mg/kg <u>Acute inhalation toxicity:</u> LC50 rat Dose: 7.64 mg/l Exposure time: 4 h <u>Skin irritation:</u> Classification: Irritating to skin. Result: Severe skin irritation <u>Eye irritation:</u> Classification: Irritating to eyes. Result: Mild eye irritation
Naphthalene	91-20-3	<u>Acute oral toxicity:</u> LD50 rat

		Dose: 2,001 mg/kg
		<u>Acute dermal toxicity:</u> LD50 rat Dose: 2,501 mg/kg
		<u>Acute inhalation toxicity:</u> LC50 rat Dose: 101 mg/l Exposure time: 4 h
		<u>Skin irritation:</u> Classification: Irritating to skin. Result: Mild skin irritation
		<u>Eye irritation:</u> Classification: Irritating to eyes. Result: Mild eye irritation
		<u>Carcinogenicity:</u> N11.00422130
Xylene	1330-20-7	<u>Acute oral toxicity:</u> LD50 rat Dose: 2,840 mg/kg
		<u>Acute dermal toxicity:</u> LD50 rabbit Dose: ca. 4,500 mg/kg
		<u>Acute inhalation toxicity:</u> LC50 rat Dose: 6,350 mg/l Exposure time: 4 h
		<u>Skin irritation:</u> Classification: Irritating to skin. Result: Mild skin irritation Repeated or prolonged exposure may cause skin irritation and dermatitis, due to degreasing properties of the product.
		<u>Eye irritation:</u> Classification: Irritating to eyes. Result: Mild eye irritation
Nonane	111-84-2	<u>Acute oral toxicity:</u> LD50 mouse Dose: 218 mg/kg
		<u>Acute inhalation toxicity:</u> LC50 rat Exposure time: 4 h
1,2,4-Trimethylbenzene	95-63-6	<u>Acute inhalation toxicity:</u> LC50 rat Dose: 18 mg/l Exposure time: 4 h
		<u>Skin irritation:</u> Classification: Irritating to skin. Result: Skin irritation
		<u>Eye irritation:</u> Classification: Irritating to eyes. Result: Eye irritation
Sulfur	7704-34-9	<u>Acute oral toxicity:</u> LD50 rat Dose: 5,001 mg/kg
		<u>Acute dermal toxicity:</u> LD50 rabbit Dose: 2,001 mg/kg
		<u>Acute inhalation toxicity:</u> LC50 rat Dose: 9.24 mg/l Exposure time: 4 h
		<u>Eye irritation:</u> Classification: Irritating to eyes. Result: Mild eye irritation

SECTION 12. ECOLOGICAL INFORMATION

Biochemical Oxygen Demand (BOD) : No data available

Chemical Oxygen Demand (COD) : No data available

Adsorbed organic bound halogens (AOX) : Not included

Additional ecological information : Keep out of sewers, drainage areas, and waterways. Report spills and releases, as applicable, under Federal and State regulations.

Component:

Naphthalene	91-20-3	<u>Toxicity to algae:</u> EC50 Species: Dose: 33 mg/l Exposure time: 24 h
1,2,4-Trimethylbenzene	95-63-6	<u>Toxicity to fish:</u> LC50 Species: Pimephales promelas (fathead minnow) Dose: 7.72 mg/l Exposure time: 96 h <u>Acute and prolonged toxicity for aquatic invertebrates:</u> EC50 Species: Daphnia Dose: 3.6 mg/l Exposure time: 48 h
Sulfur	7704-34-9	<u>Acute and prolonged toxicity for aquatic invertebrates:</u> EC0 Species: Daphnia magna (Water flea) Dose: > 10,000 mg/l Exposure time: 24 h

SECTION 13. DISPOSAL CONSIDERATIONS

Disposal : Consult federal, state and local waste regulations to determine appropriate waste characterization of material and allowable disposal methods.

SECTION 14. TRANSPORT INFORMATION

CFR

Proper shipping name : DIESEL FUEL
 UN-No. : 1202 (NA 1993)
 Class : 3
 Packing group : III

TDG

Proper shipping name : DIESEL FUEL
 UN-No. : UN1202 (NA 1993)
 Class : 3
 Packing group : III

IATA Cargo Transport

UN UN-No. : UN1202 (NA 1993)
 Description of the goods : DIESEL FUEL
 Class : 3
 Packaging group : III

ICAO-Labels : 3
 Packing instruction (cargo aircraft) : 366
 Packing instruction (cargo aircraft) : Y344

IATA Passenger Transport

UN UN-No. : UN1202 (NA 1993)
 Description of the goods : DIESEL FUEL
 Class : 3
 Packaging group : III
 ICAO-Labels : 3
 Packing instruction (passenger aircraft) : 355
 Packing instruction (passenger aircraft) : Y344

IMDG-Code

UN-No. : UN 1202 (NA 1993)
 Description of the goods : DIESEL FUEL
 Class : 3
 Packaging group : III
 IMDG-Labels : 3
 Ems Number : F-ES-E
 Marine pollutant : No

SECTION 15. REGULATORY INFORMATION

OSHA Hazards : Combustible Liquid
 Toxic by ingestion
 Severe skin irritant
 Moderate eye irritant
 Possible Cancer Hazard

CERCLA SECTION 103 and SARA SECTION 304 (RELEASE TO THE ENVIROMENT)

The CERCLA definition of hazardous substances contains a "petroleum exclusion" clause which exempts crude oil. Fractions of crude oil, and products (both finished and intermediate) from the crude oil refining process and any indigenous components of such from the CERCLA Section 103 reporting requirements. However, other federal reporting requirements, including SARA Section 304, as well as the Clean Water Act may still apply.

TSCA Status : On TSCA Inventory
 DSL Status : All components of this product are on the Canadian DSL list.
 SARA 311/312 Hazards : Fire Hazard
 Acute Health Hazard
 Chronic Health Hazard

SARA III US. EPA Emergency Planning and Community Right-To-Know Act (EPCRA) SARA Title III Section 313 Toxic Chemicals (40 CFR 372.65) - Supplier Notification Required

<u>Components</u>	<u>GAS-No.</u>
Naphthalene	91-20-3

Xylene 1330-20-7

1,2,4-trimethylbenzene 95-63-6

PENN RTK US. Pennsylvania Worker and Community Right-to-Know Law (34 Pa. Code Chap. 301-323)

Components CAS-No.

Sulfur 7704-34-9

1,2,4-trimethylbenzene 95-63-6

Nonane 111-84-2

Xylene 1330-20-7

Naphthalene 91-20-3

Fuels, diesel, No 2; Gasoil - unspecified 68476-34-6

MASS RTK US. Massachusetts Commonwealth's Right-to-Know Law (Appendix A to 105 Code of Massachusetts Regulations Section 670.000)

Components CAS-No.

Sulfur 7704-34-9

1,2,4-Trimethylbenzene 95-63-6

Nonane 111-84-2

Xylene 1330-20-7

Naphthalene 91-20-3

NJ RTK US. New Jersey Worker and Community Right-to-Know Act (New Jersey Statute Annotated Section 34:SA-5)

Components CAS-No.

Sulfur 7704-34-9

1,2,4-Trimethylbenzene 95-63-6

Nonane 111-84-2

Xylene 1330-20-7

Naphthalene 91-20-3

Fuels, diesel, No 2; Gasoil - unspecified 68476-34-6

California Prop. 65 : WARNING! This product contains a chemical known to the State of California to cause cancer.

Naphthalene 91-20-3

SECTION 16. OTHER INFORMATION

Further information

The information provided in this Safety Data Sheet is correct to the best of our knowledge, information and belief at the date of its publication. The information given is designed only as guidance for safe handling, use, processing, storage, transportation, disposal and release and is not to be considered a warranty or quality specification. The information relates only to the specific material designated and may not be valid for such material used in

combination with any other materials or in any process, unless specified in the text.

Template : GWU mbH
Prepared by : Birlenbacher Str. 18
D-57078 Siegen
Germany
Telephone: +49-(0)271-88072-0
Revision Date : 02/01/2011

105